

Environment Agency

Review of an Environmental Permit for an Installation subject to Chapter II of the Industrial Emissions Directive under the Environmental Permitting (England & Wales) Regulations 2016

Decision document recording our decision-making process following review of a permit

The Permit number is: EPR/AP3630LG
The Operator is: RWE Generation UK Plc
The Installation is: Little Barford Power Station
This Variation Notice number is: EPR/AP3630LG/V006

What this document is about

Article 21(3) of the Industrial Emissions Directive (IED) requires the Environment Agency to review conditions in permits that it has issued and to ensure that the permit delivers compliance with relevant standards, within four years of the publication of updated decisions on best available techniques (BAT) conclusions.

We have reviewed the permit for this installation against the revised BAT Conclusions for large combustion plant published on 17th August 2017. This is our decision document, which explains the reasoning for the consolidated variation notice that we are issuing.

It explains how we have reviewed and considered the techniques used by the Operator in the operation and control of the plant and activities of the installation. This review has been undertaken with reference to the decision made by the European Commission establishing best available techniques (BAT) conclusions ('BAT Conclusions') for large combustion plant as detailed in document reference IEDC-7-1. It is our record of our decision-making process and shows how we have taken into account all relevant factors in reaching our position. It also provides a justification for the inclusion of any specific conditions in the permit that are in addition to those included in our generic permit template.

As well as considering the review of the operating techniques used by the Operator for the operation of the plant and activities of the installation, the consolidated variation notice takes into account and brings together in a single document all previous variations that relate to the original permit issued. It also modernises the entire permit to reflect the conditions contained in our current generic permit template.

The introduction of new template conditions makes the Permit consistent with our current general approach and philosophy and with other permits issued to installations in this sector. Although the wording of some conditions has changed, while others have been removed because of the new regulatory approach, it does not reduce the level of environmental protection achieved by the Permit in any way. In this document we therefore address only our determination of substantive issues relating to the new BAT Conclusions.

This is our record of our decision-making process and shows how we have taken into account all relevant factors in reaching our position.

Throughout this document we will use a number of expressions. These are as referred to in the glossary and have the same meaning as described in “Schedule 6 Interpretation” of the Permit.

We try to explain our decision as accurately, comprehensively and plainly as possible. We would welcome any feedback as to how we might improve our decision documents in future. A lot of technical terms and acronyms are inevitable in a document of this nature: we provide a glossary of acronyms near the front of the document, for ease of reference.

How this document is structured

Glossary of terms

- 1 Our decision
- 2 How we reached our decision
- 2.1 Requesting information to demonstrate compliance with BAT Conclusions for Large Combustion Plant
- 2.2 Review of our own information in respect to the capability of the installation to meet revised standards included in the BAT Conclusions document
- 2.3 Summary of how we considered the responses from public consultation.
- 3 The legal framework
- 4 Key Issues
- 5 Decision checklist regarding relevant BAT Conclusions
- 6 Review and assessment of derogation requests made by the operator in relation to BAT Conclusions which include an associated emission level (AEL) value
- 7 Emissions to Water
- 8 Additional IED Chapter II requirements
- 9 Review and assessment of changes that are not part of the BAT Conclusions derived permit review.

Glossary of acronyms used in this document

(Please note that this glossary is standard for our decision documents and therefore not all these acronyms are necessarily used in this document.)

APC	Air Pollution Control
BAT	Best Available Technique(s)
BAT-AEEL	BAT Associated Energy Efficiency Level
BAT-AEL	BAT Associated Emission Level
BATc	BAT conclusion
BREF	Best available techniques reference document
CCGT	Combined Cycle Gas Turbine
CEM	Continuous emissions monitor
CHP	Combined heat and power
CV	Calorific value
DAA	Directly associated activity – Additional activities necessary to be carried out to allow the principal activity to be carried out
DLN	Dry Low NOx burners
DLN-E	Dry Low NOx effective
EIONET	European environment information and observation network is a partnership network of the European Environment Agency
ELV	Emission limit value derived under BAT or an emission limit value set out in IED
EMS	Environmental Management System
EPR	Environmental Permitting (England and Wales) Regulations 2016 (SI 2016 No. 1154)
EWC	European waste catalogue
IC	Improvement Condition
IED	Industrial Emissions Directive (2010/75/EU)
IPPCD	Integrated Pollution Prevention and Control Directive (2008/1/EC) – now superseded by IED
LCP	Large Combustion Plant subject to Chapter III of IED
MSUL/MSDL	Minimum start up load/minimum shut-down load
NOx	Oxides of nitrogen (NO plus NO ₂ expressed as NO ₂)
OCGT	Open Cycle Gas Turbine
SGN	Sector guidance note
TGN	Technical guidance note
TNP	Transitional National Plan
TOC	Total Organic Carbon
WFD	Water Framework Directive (2000/60/EC)

1 Our decision

We have decided to issue the consolidated variation notice to the Operator. This will allow it to continue to operate the Installation, subject to the conditions in the consolidated variation notice.

We consider that, in reaching that decision, we have taken into account all relevant considerations and legal requirements and that the varied permit will ensure that a high level of protection is provided for the environment and human health.

The consolidated variation notice contains many conditions taken from our standard Environmental Permit template including the relevant Annexes. We developed these conditions in consultation with industry, having regard to the legal requirements of the Environmental Permitting Regulations and other relevant legislation. This document does not therefore include an explanation for these standard conditions. Where they are included in the Notice, we have considered the techniques identified by the operator for the operation of their installation, and have accepted that the details are sufficient and satisfactory to make those standard conditions appropriate. This document does, however, provide an explanation of our use of “tailor-made” or installation-specific conditions, or where our Permit template provides two or more options.

2 How we reached our decision

2.1 Requesting information to demonstrate compliance with BAT Conclusions for Large Combustion Plant

We issued a Notice under Regulation 61(1) of the Environmental Permitting (England and Wales) Regulations 2016 (a Regulation 61 Notice) on 1st May 2018 requiring the Operator to provide information to demonstrate how the operation of their installation currently meets, or will subsequently meet, the revised standards described in the large combustion plant BAT Conclusions document. The Notice also required that where the revised standards are not currently met, the operator should provide information that:

- Describes the techniques that will be implemented before 17th August 2021, which will then ensure that operations meet the revised standard, or
- Justifies why standards will not be met by 17th August 2021, and confirmation of the date when the operation of those processes will cease within the installation or an explanation of why the revised BAT standard is not applicable to those processes, or
- Justifies why an alternative technique will achieve the same level of environmental protection equivalent to the revised standard described in the BAT Conclusions.

Where the Operator proposed that they were not intending to meet a BAT standard that also included a BAT Associated Emission Level (BAT AEL) described in the BAT Conclusions Document, the Regulation 61 Notice requested that the Operator make a formal request for derogation from compliance with that AEL (as provisioned by Article 15(4) of IED). In this circumstance, the Notice identified that any such request for derogation must be supported and justified by sufficient technical and commercial information that would enable us to determine acceptability of the derogation request.

The Regulation 61 Notice response from the Operator was received on 31st October 2018.

We considered it was in the correct form and contained sufficient information for us to begin our determination of the permit review but not that it necessarily contained all the information we would need to complete that review.

2.2 Review of our own information in respect to the capability of the installation to meet revised standards included in the BAT Conclusions document

Based on our records and previous regulatory activities with the facility we have no reason to consider that the operator will not be able to comply with the conditions that we include in the permit.

3 The legal framework

The consolidated variation notice will be issued under Regulation 20 of the EPR. The Environmental Permitting regime is a legal vehicle which delivers most of the relevant legal requirements for activities falling within its scope. In particular, the regulated facility is:

- an *installation* as described by the IED;
- subject to aspects of other relevant legislation which also have to be addressed.

We consider that the consolidated variation notice will ensure that the operation of the Installation complies with all relevant legal requirements and that a high level of protection will be delivered for the environment and human health.

We explain how we have addressed specific statutory requirements more fully in the rest of this document.

4 The key issues

The key issues arising during this permit review are:

- Emissions to air and the emission limits applied to the plant.
- The energy efficiency levels associated with the Best Available Techniques (BAT-AEELs)
- The review and assessment of the availability of BAT for gas turbines operating <500 hours per year

We therefore describe how we determined these issues in most detail in the relevant sections of this document.

4.1 Emissions to air and the emission limits applied to the plant

A number of general principles were applied during the permit review. These included:

- The upper value of the BAT AELs ranges specified were used unless use of the tighter limit was justified.
- The principle of no backsliding where if existing limits in the permit were already tighter than those specified in the BREF, the existing permit limits were retained.
- Where a limit was specified in both IED Annex V and the BAT Conclusions for a particular reference period, the tighter limit was applied and in the majority of cases this was from the BAT Conclusions.
- Where AELs are indicative in the BAT Conclusions, these were applied unless adequate justification was provided by the operator to demonstrate that an alternative limit was more appropriate.
- For gas turbines where the IED specified that limits applied over 70% load and the BAT Conclusions specified that AELs applied when dry low NO_x is effective (DLN-E), we have used DLN-E as a default across all monitoring requirements for NO_x and CO.

The LCPs on site consist of:

- LCP 272 and 273 are 644 MWth engines, operating as a single CCGT module, each venting its waste gases to its own dedicated stack at emission points A1 and A2. The units burn natural gas and gas oil as a standby fuel.
- LCP 394 is a 58 MWth OCGT module, venting its waste gases to an individual stack at emission point A3. The unit burns gas oil for black start and short term operation reserve to the grid.

The plant was put into operation before IED came into force and therefore the existing limits in the permit are from Part 1 of IED Annex V applicable to existing.

The ELVs and AELs are based on the following operating regimes:

- Unlimited hours operation (LCP 272 and LCP 273)
- <500 hours, non-emergency plant (LCP 394)

LCP 272 and LCP 273

The following tables outline the limits that have been incorporated into the permit for LCP 272 and LCP 273 where these were derived from and the reference periods at which they apply. The emission limits refer to concentrations, expressed as mass of emitted substance per volume of flue-gas under the following standard conditions: dry gas at a temperature of 273,15 K, pressure of 101,3 kPa and 15% volume reference oxygen concentration if flue gases. The emission limits and monitoring requirements have been incorporated into Schedule 3 of the permit.

Where a natural gas fired plant uses gas oil as a standby fuel for less than 10 days, we have not assessed the site against the BAT Conclusions applicable to that fuel as the use is not considered significant. We expect the site to have demonstrated that the site will be operated in a manner such that use of the standby fuel is minimised.

By the end of the TNP on 30 June 2020, as a minimum plant must meet the limits set out in Annex V of the Industrial Emission Directive subject to BAT assessment and the principle of no backsliding. From the implementation date of the BAT Conclusion in 2021 the relevant AELs will also apply.

NOx limits (mg/Nm ³)							
Averaging	Permit – Existing (non-IED limit)	IED (Annex V Part 1) - Existing	BREF	Expected permit limits	Basis	Limits apply	Monitoring
Annual	None	None	40	40	BREF	DLN-E	Continuous
Monthly	50	50	None	50	Permit/ IED	DLN-E	
Daily	50	55	50	50	Permit/ BREF	DLN-E and MSUL/ MSDL to base load	
95 th %ile of hr means	100	100	None	100	Permit/ IED	DLN-E	

CO limits (mg/Nm ³)							
Averaging	Permit – Existing (non-IED limit)	IED (Annex V Part 1) - Existing	BREF	Expected permit limits	Basis	Limits apply	Monitoring
Annual	None	None	30	30	BREF	DLN-E	Continuous
Monthly	100	100	None	100	Permit/ IED	DLN-E	
Daily	100	110	None	100	Permit	DLN-E and MSUL/ MSDL to base load	
95 th %ile of hr means	200	200	None	200	Permit/ IED	DLN-E	

LCP 394

Under Chapter III gas turbines and gas engines operating for less than 500 hours per year were considered to be emergency plant and therefore were not covered by the emission limits set out in IED Annex V. However, for the purposes of the LCP BAT review, plants operated for emergency use may only be defined as plants which operate for the sole purpose of providing power at a site during an onsite emergency and/or during a black start and which do not provide balancing services or demand side response services. As this site runs commercially on an intermittent basis to support the Grid, it is not considered emergency plant and therefore indicative BAT applies.

We have set the indicative limits requiring validation through emission factors based on the principle that we will not require plant to fire up with the sole purpose of performing an emission measurement, as set out the UK Regulators Interpretation Document.

NOx limits (mg/Nm ³) – indicative in <i>italics</i>					
Averaging	IED (Annex V Part 1) - Existing	BREF	Expected permit limits	Basis	Monitoring
Annual	None	None	None	N/A	Concentration by calculation, every 2 years Note 3
Monthly	None	None	None	N/A	
Daily average or average over the sampling period	None	None	400 ^{Note 1}	JEP report UTG/18/PMP/774/R Note 1	
95 th %ile of hr means	None	None	None	N/A	
<p>Note 1: BATc 38 provides an indicative emission level of 250 mg/Nm³ for combustion of gas oil in dual fuel gas turbines operating less than 500 hours per year. However this indicative figure is not strictly applicable to LCP 394, because gas turbines within LCP 394 are not dual fuel. We have therefore set a benchmark emission level in the revised and consolidated permit notice at 400 mg/m³, based on justification supplied by the Operator and supported by the JEP report UTG/18/PMP/774/R.</p> <p>Note 2: Footnote 2 to BAT conclusion 4 specifies that the monitoring frequency does not apply where plant operation would be for the sole purpose of performing an emission measurement.</p>					

BATc 38 provides an indicative emission level of 250 mg/Nm³ for combustion of gas oil in dual fuel gas turbines operating less than 500 hours per year. However this indicative figure is not strictly applicable to LCP 394, because gas turbines within LCP 394 are not dual fuel. We have therefore set a benchmark emission level in the revised and consolidated permit notice at 400 mg/m³, this is based on justification supplied by the Operator and supported by the JEP report UTG/18/PMP/774/R 'BAT assessment for existing natural gas, gas oil and dual fuel fired OCGTs and CCGTs with a thermal rating of 50MWth or greater operating <500 hours per year' dated October 2018. This report gives a NOx level of 400 mg/m³ for the GE frame 5 OCGT when burning gas oil. This

covers all conditions under which the gas turbine may operate as well as the normal variation in emission performance between outages.

SO₂ limits (mg/Nm³) – indicative in <i>italics</i>						
Averaging	Permit – Existing (non-IED limit)	IED (Annex V Part 1) - Existing	BREF	Expected permit limits	Basis	Monitoring
Annual	None	None	None	None	N/A	Concentration by calculation, every 2 years Notes 1, 2
Monthly	None	None	None	None	N/A	
Daily average or average over the sampling period	None	None	66	66	BREF	
95th %ile of hr means	None	None	None	None	N/A	
<p>Note 1: Footnote 2 to BAT conclusion 4 specifies that the monitoring frequency does not apply where plant operation would be for the sole purpose of performing an emission measurement.</p> <p>Note 2: Footnote 8 to BAT conclusion 4 specifies that, as an alternative to the continuous measurement, in the case of plants combusting oil with a known sulphur content and where there is no flue- gas desulphurisation system, periodic measurements at least once every three months and/or other procedures ensuring the provision of data of an equivalent scientific quality may be used to determine the SO₂ emissions.</p>						

Dust limits (mg/Nm³) – indicative in <i>italics</i>						
Averaging	Permit – Existing (non-IED limit)	IED (Annex V Part 1) - Existing	BREF	Expected permit limits	Basis	Monitoring
Annual	None	None	None	None	N/A	Concentration by calculation, every 2 years Note 1
Monthly	None	None	None	None	N/A	
Daily average or average over the sampling period	None	None	10	10	BREF	
95th %ile of hr means	None	None	None	None	N/A	
<p>Note 1: Footnote 2 to BAT conclusion 4 specifies that the monitoring frequency does not apply where plant operation would be for the sole purpose of performing an emission measurement.</p>						

We have specified in the revised permit monitoring and reporting requirements for LCP 394 based on calculation of emissions according to the agreed protocol established in JEP Report JEP17EMG02/UTG/18/ERG/CT/773/R 'Maintaining the Emissions

Performance of Open Cycle Gas Turbines that operate for less than 500 hours per year', October 2018. This is because we consider footnote 2 to BAT conclusion 4 to be relevant, this footnote specifies that the monitoring frequency does not apply where plant operation would be for the sole purpose of performing an emission measurement.

4.2 The energy efficiency levels associated with the Best Available Techniques Conclusions

An energy efficiency level associated with the best available techniques (BAT-AEEL) refers to the ratio between the combustion unit's net energy output(s) and the combustion unit's fuel/feedstock energy input at actual unit design. The net energy output(s) is determined at the combustion unit boundaries, including auxiliary systems (e.g. flue-gas treatment systems), and for the unit operated at full load.

For LCP 394, Table 21 of the BAT Conclusions specifies that the AEELs for this type of plant are not applicable to plant operating less than 1500 hours per year. We have therefore not assessed this operational aspect of the plant for LCP 394. We have however included a process monitoring requirement in table S3.4 of the consolidated variation notice. This is required to demonstrate that efficiency levels are maintained following any significant overhauls of equipment in order to fulfil the requirement of BAT Conclusion 2. For <500 hour plant we have specified that the assessment of efficiency can be based on calculation. This is because we will not require plant to fire up with the sole purpose of carrying out an assessment of efficiency.

For LCP 272 and LCP 273, the table below sets out the BAT-AEELs specified in the LCP BAT Conclusions for the large combustion plant on the site and the energy efficiency levels confirmed through the Regulation 61 notice response. A full load performance test was undertaken in October 2017. The Operator confirmed that the test was carried out according to the appropriate standards, including ASME PTX 46, ISO2314 and IEC953-2. We consider this plant is BAT in relation to the AEELs.

BAT AEELs (%)			Plant efficiency (%)		
Net electrical efficiency	Net total fuel utilisation	Net mechanical efficiency	Net electrical efficiency	Net total fuel utilisation	Net mechanical efficiency
LCP 272: CCGT >= 600 MWth – existing unit					
50 - 60	None	None	55.4	NA	NA
LCP 273: CCGT >= 600 MWth – existing unit					
50 - 60	None	None	55.4	NA	NA

4.3 The review and assessment of BAT for gas turbines operating < 500 hours per year – LCP 394

Joint Environmental Programme (JEP) produced a document '*BAT Assessment for Existing Gas and Liquid Fuel Fired OCGTs, CCGTs and Dual-fuel GTs with a Thermal Input Rating of 50MWth or Greater Operating <500 Hours Per Year*' dated October 2018.

The content of this document has been agreed in principle by the Environment Agency and we have therefore taken the document into account during our determination of this variation.

In order to prevent or reduce NO_x emissions to air from the combustion of gas oil in gas turbines, BAT is to use one or a combination of the techniques given in BAT 37. The Operator has considered the following techniques as those potentially applicable to gas turbines firing gas oil and operating less than 500 hours per year:

- a. Water/Steam injection;
- b. Use of Dry Low NO_x burners.

The Operator has concluded that the use of Dry Low NO_x burners is not available for LCP 394 and that the currently permitted performance, along with continued appropriate maintenance, are BAT to prevent or reduce emissions of NO_x from these gas turbines.

The JEP cost benefit analysis (Appendix A to *BAT Assessment for Existing Gas and Liquid Fuel Fired OCGTs, CCGTs and Dual-fuel GTs with a Thermal Input Rating of 50MWth or Greater Operating <500 Hours Per Year*) concludes that retrofitting Dry Low NO_x (DLN) or Wet Low Emissions (WLE) to existing OCGTs firing natural gas or gas oil, and operating for less than 500 hour per year, is not justified from a cost-benefit perspective. Meaning there is insufficient environmental benefit in reducing the already low annual mass emission, when considering the high conversion costs.

We agree that the techniques reported under BAT conclusion 37 are not applicable to LCP 394.

In all cases, the minimum BAT requirements are considered to be: i) the continued compliance with any permit requirements already in place to protect air quality and ii) the demonstration of an appropriate maintenance regime to maintain plant emissions performance.

5 Decision checklist regarding relevant BAT Conclusions

BAT Conclusions for large combustion plant, were published by the European Commission on 17th August 2017. There are 75 BAT Conclusions. Only the BAT Conclusions relevant to the particular fuel type used on site have been replicated below.

This annex provides a record of decisions made in relation to each relevant BAT Conclusion applicable to the installation. This annex should be read in conjunction with the Consolidated Variation Notice.

The conditions in the permit through which the relevant BAT Conclusions are implemented include but are not limited to the following:

BAT Conclusion requirement topic	Permit condition(s)	Permit table(s)
Environmental Management System	1.1.1	S1.2
BAT AELs	3.1.1 and 3.5.1	S3.1a
Monitoring	2.3, 3.5 and 3.6	S1.2, S1.4, S1.5, S3.1a
Energy efficiency	1.2 and 2.3	S3.4
Noise	3.4 and 2.3	S1.2
Other operating techniques	2.3	S1.2

The overall status of compliance with the BAT conclusion is indicated in the table as:

- NA Not Applicable
- CC Currently Compliant
- FC Compliant in the future (within 4 years of publication of BAT conclusions)
- NC Not Compliant
- PC Partially Compliant

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
General			
1	<p>In order to improve the overall environmental performance, BAT is to implement and adhere to an environmental management system (EMS) that incorporates all of the following features:</p> <ul style="list-style-type: none"> i. commitment of the management, including senior management; ii. definition of an environmental policy that includes the continuous improvement of the installation by the management; iii. planning and establishing the necessary procedures, objectives and targets, in conjunction with financial planning and investment; iv. implementation of procedures <ul style="list-style-type: none"> (a) Structure and responsibility (b) Training (c) Communication (d) Employee involvement (e) Documentation (f) Efficient process control (g) Maintenance programmes (h) Emergency preparedness and response (i) Safeguarding compliance with environmental legislation v. checking performance and taking corrective action, paying particular attention to: <ul style="list-style-type: none"> (a) monitoring and measurement (see also the Reference Document on the General Principles of Monitoring) (b) corrective and preventive action (c) maintenance of records (d) independent (where practicable) internal and external auditing in order to determine whether or not the EMS conforms to planned arrangements and has been properly implemented and maintained; vi. review of the EMS and its continuing suitability, adequacy and effectiveness by senior management; vii. following the development of cleaner technologies; viii. consideration for the environmental impacts from the eventual decommissioning of the installation at the stage of designing a new plant, and throughout its operating life; viii. consideration for the environmental impacts from the eventual decommissioning of the installation at the stage of designing a new plant, and throughout its operating life; ix. application of sectoral benchmarking on a regular basis. <p>Etc - see BAT Conclusions</p>	CC	<p>An EMS is in place which the Operator has confirmed is compliant with the requirements listed in BAT 1. The station operates a local EMS which is fully integrated with the RWE Generation UK EMS which is certified to ISO14001: 2015.</p>

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement								
	<p>Applicability. The scope (e.g. level of detail) and nature of the EMS (e.g. standardised or non-standardised) will generally be related to the nature, scale and complexity of the installation, and the range of environmental impacts it may have.</p>										
2	<p>BAT is to determine the net electrical efficiency and/or the net total fuel utilisation and/or the net mechanical energy efficiency of the gasification, IGCC and/or combustion units by carrying out a performance test at full load (1), according to EN standards, after the commissioning of the unit and after each modification that could significantly affect the net electrical efficiency and/or the net total fuel utilisation and/or the net mechanical energy efficiency of the unit. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.</p>	CC	<p>For LCP 272 and LCP 273, a full load performance test was carried out in October 2017. This demonstrated that the main module (LCP 272 and LCP 273 operating as designed in combined cycle mode with a single steam turbine) has an efficiency of 55.4%.</p> <p>For LCP 394, the Operator provided an efficiency level based on the name plate. We consider this to be sufficient for this type of plant. Name plate efficiency of LCP 394 is 28.4 % and the Operator confirms that operational data demonstrates that this has been maintained.</p> <p>For LCP 394, the BAT-AEELs are not applicable to plant operating <1500 hours.</p> <p>A process monitoring requirement has been set in table S3.4 which requires energy efficiency monitoring after an overhaul.</p>								
3	<p>BAT is to monitor key process parameters relevant for emissions to air and water including those given below.</p> <table border="1" data-bbox="338 1278 1494 1378"> <thead> <tr> <th data-bbox="338 1278 696 1315">Stream</th> <th data-bbox="696 1278 1128 1315">Parameter(s)</th> <th data-bbox="1128 1278 1494 1315">Monitoring</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 1315 696 1351" rowspan="2">Flue-gas</td> <td data-bbox="696 1315 1128 1351">Flow</td> <td data-bbox="1128 1315 1494 1351">Periodic or continuous determination</td> </tr> <tr> <td data-bbox="696 1351 1128 1378">Oxygen content, temperature, and pressure</td> <td data-bbox="1128 1351 1494 1378">Periodic or continuous measurement</td> </tr> </tbody> </table>	Stream	Parameter(s)	Monitoring	Flue-gas	Flow	Periodic or continuous determination	Oxygen content, temperature, and pressure	Periodic or continuous measurement	CC	<p>Flow is calculated based on fuel consumption and the calculation is validated annually. We are satisfied that continuous determination with validation is appropriate. The</p>
Stream	Parameter(s)	Monitoring									
Flue-gas	Flow	Periodic or continuous determination									
	Oxygen content, temperature, and pressure	Periodic or continuous measurement									

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement						
	<table border="1" data-bbox="338 384 1494 456"> <tr> <td data-bbox="338 384 698 419"></td> <td data-bbox="698 384 1128 419">Water vapour content ⁽²⁾</td> <td data-bbox="1128 384 1494 419"></td> </tr> <tr> <td data-bbox="338 419 698 456">Waste water from flue-gas treatment</td> <td data-bbox="698 419 1128 456">Flow, pH, and temperature</td> <td data-bbox="1128 419 1494 456">Continuous measurement</td> </tr> </table>		Water vapour content ⁽²⁾		Waste water from flue-gas treatment	Flow, pH, and temperature	Continuous measurement		<p>relevant standard for flow rate determination is EN ISO 16911.</p> <p>The station continuously monitors flue gas emissions from LCP 272 and LCP 272 for oxygen content, temperature and pressure as required by BAT 3.</p> <p>Water vapour content is not monitored as the sample is dried prior to analysis. This is in line with footnote 1 to BAT 3.</p> <p>Monitoring of the parameters listed under BAT 3 are not required where there is no periodic or continuous monitoring specified in the permit. Emissions monitoring is not carried out on LCP 394 and emissions are instead determined through emissions factors based on fuel consumption, fuel sulphur content and results from commissioning tests.</p> <p>BAT 3 specifies monitoring of process water only applicable to waste water from flue gas treatment. This is not applicable to the installation as no flue gas treatment is undertaken on site.</p>
	Water vapour content ⁽²⁾								
Waste water from flue-gas treatment	Flow, pH, and temperature	Continuous measurement							
4	BAT is to monitor emissions to air with at least the frequency given below and in accordance with EN standards. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.	CC	The site monitors CO and NO _x emissions from LCP 272 and 273 as required by BAT 4 for natural gas						

BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	Substance/ Parameter	Fuel/Process/Type of combustion plant	Combustion plant total rated thermal input	Standard(s) ⁽⁴⁾	Minimum monitoring frequency ⁽⁵⁾	Monitoring associated with	<p>fired turbines. Monitoring is carried out continuously in accordance with EN14181.</p> <p>The monitoring frequencies described in BAT 4 do not apply where plant operation would be for the sole purpose of performing an emission measurement. Therefore we consider that monitoring is not required for LCP 272 and LCP 273 when burning gas oil as an emergency back-up fuel or LCP 394 which operates less than 500 hours per year.</p>	
	NH ₃	— When SCR and/or SNCR is used	All sizes	Generic EN standards	Continuous ⁽⁷⁾	BAT 7		
	NO _x	<ul style="list-style-type: none"> — Coal and/or lignite including waste co-incineration — Solid biomass and/or peat including waste co-incineration — HFO- and/or gas-oil-fired boilers and engines — Gas-oil-fired gas turbines — Natural-gas-fired boilers, engines, and turbines — Iron and steel process gases — Process fuels from the chemical industry — IGCC plants 	All sizes	Generic EN standards	Continuous ⁽⁸⁾	BAT 20 BAT 24 BAT 28 BAT 32 BAT 37 BAT 41 BAT 42 BAT 43 BAT 47 BAT 48 BAT 56 BAT 64 BAT 65 BAT 73		
		— Combustion plants on offshore platforms	All sizes	EN 14792	Once every year ⁽⁹⁾	BAT 53		
	N ₂ O	<ul style="list-style-type: none"> — Coal and/or lignite in circulating fluidised bed boilers — Solid biomass and/or peat in circulating fluidised bed boilers 	All sizes	EN 21258	Once every year ⁽¹⁰⁾	BAT 20 BAT 24		
	CO	— Coal and/or lignite including waste co-incineration	All sizes	Generic EN standards	Continuous ⁽⁸⁾	BAT 20 BAT 24 BAT 28 BAT 33 BAT 38 BAT 44		

BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
		<ul style="list-style-type: none"> — Solid biomass and/or peat including waste co-incineration — HFO- and/or gas-oil-fired boilers and engines — Gas-oil-fired gas turbines — Natural-gas-fired boilers, engines, and turbines — Iron and steel process gases — Process fuels from the chemical industry — IGCC plants 				BAT 49 BAT 56 BAT 64 BAT 65 BAT 73		
		<ul style="list-style-type: none"> — Combustion plants on offshore platforms 	All sizes	EN 15058	Once every year ⁽⁹⁾	BAT 54		
SO ₂		<ul style="list-style-type: none"> — Coal and/or lignite incl waste co-incineration — Solid biomass and/or peat incl waste co-incineration — HFO- and/or gas-oil-fired boilers — HFO- and/or gas-oil-fired engines — Gas-oil-fired gas turbines — Iron and steel process gases — Process fuels from the chemical industry in boilers — IGCC plants 	All sizes	Generic EN standards and EN 14791	Continuous ⁽⁶⁾ ⁽¹¹⁾ ⁽¹²⁾	BAT 21 BAT 25 BAT 29 BAT 34 BAT 39 BAT 50 BAT 57 BAT 66 BAT 67 BAT 74		
SO ₃		<ul style="list-style-type: none"> — When SCR is used 	All sizes	No EN standard available	Once every year	—		
Gaseous chlorides,		<ul style="list-style-type: none"> — Coal and/or lignite 	All sizes	EN 1911	Once every three months ⁽⁶⁾ ⁽¹³⁾ ⁽¹⁴⁾	BAT 21 BAT 57		

BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	expressed as HCl	— Process fuels from the chemical industry in boilers						
		— Solid biomass and/or peat	All sizes	Generic EN standards	Continuous ₍₁₅₎ (16)	BAT 25		
		— Waste co-incineration	All sizes	Generic EN standards	Continuous ₍₆₎ (16)	BAT 66 BAT 67		
	HF	— Coal and/or lignite — Process fuels from the chemical industry in boilers	All sizes	No EN standard available	Once every three months ₍₆₎ (13)(14)	BAT 21 BAT 57		
		— Solid biomass and/or peat	All sizes	No EN standard available	Once every year	BAT 25		
		— Waste co-incineration	All sizes	Generic EN standards	Continuous ₍₆₎ (16)	BAT 66 BAT 67		
	Dust	— Coal and/or lignite — Solid biomass and/or peat — HFO- and/or gas-oil-fired boilers — Iron and steel process gases — Process fuels from the chemical industry in boilers — IGCC plants — HFO- and/or gas-oil-fired engines — Gas-oil-fired gas turbines	All sizes	Generic EN standards and EN 13284-1 and EN 13284-2	Continuous ₍₆₎ (17)	BAT 22 BAT 26 BAT 30 BAT 35 BAT 39 BAT 51 BAT 58 BAT 75		
		— Waste co-incineration	All sizes	Generic EN standards and EN 13284-2	Continuous	BAT 68 BAT 69		
5	BAT is to monitor emissions to water from flue-gas treatment with at least the frequency given in BAT 5 and in accordance with EN standards. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.						NA	The site does not carry out flue-gas treatment.

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																						
6	<p>In order to improve the general environmental performance of combustion plants and to reduce emissions to air of CO and unburnt substances, BAT is to ensure optimised combustion and to use an appropriate combination of the techniques given below.</p> <table border="1" data-bbox="349 475 1487 1102"> <thead> <tr> <th data-bbox="349 475 568 507">Technique</th> <th data-bbox="568 475 1003 507">Description</th> <th data-bbox="1003 475 1487 507">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="349 507 389 592">a.</td> <td data-bbox="389 507 568 592">Fuel blending and mixing</td> <td data-bbox="568 507 1003 592">Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type</td> <td data-bbox="1003 507 1487 592" rowspan="2">Generally applicable</td> </tr> <tr> <td data-bbox="349 592 389 676">b.</td> <td data-bbox="389 592 568 676">Maintenance of the combustion system</td> <td data-bbox="568 592 1003 676">Regular planned maintenance according to suppliers' recommendations</td> </tr> <tr> <td data-bbox="349 676 389 761">c.</td> <td data-bbox="389 676 568 761">Advanced control system</td> <td data-bbox="568 676 1003 761">See description in Section 8.1</td> <td data-bbox="1003 676 1487 761">The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> <tr> <td data-bbox="349 761 389 845">d.</td> <td data-bbox="389 761 568 845">Good design of the combustion equipment</td> <td data-bbox="568 761 1003 845">Good design of furnace, combustion chambers, burners and associated devices</td> <td data-bbox="1003 761 1487 845">Generally applicable to new combustion plants</td> </tr> <tr> <td data-bbox="349 845 389 1102">e.</td> <td data-bbox="389 845 568 1102">Fuel choice</td> <td data-bbox="568 845 1003 1102">Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used</td> <td data-bbox="1003 845 1487 1102">Applicable within the constraints associated with the availability of suitable types of fuel with a better environmental profile as a whole, which may be impacted by the energy policy of the Member State, or by the integrated site's fuel balance in the case of combustion of industrial process fuels. For existing combustion plants, the type of fuel chosen may be limited by the configuration and the design of the plant</td> </tr> </tbody> </table>	Technique	Description	Applicability	a.	Fuel blending and mixing	Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type	Generally applicable	b.	Maintenance of the combustion system	Regular planned maintenance according to suppliers' recommendations	c.	Advanced control system	See description in Section 8.1	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system	d.	Good design of the combustion equipment	Good design of furnace, combustion chambers, burners and associated devices	Generally applicable to new combustion plants	e.	Fuel choice	Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used	Applicable within the constraints associated with the availability of suitable types of fuel with a better environmental profile as a whole, which may be impacted by the energy policy of the Member State, or by the integrated site's fuel balance in the case of combustion of industrial process fuels. For existing combustion plants, the type of fuel chosen may be limited by the configuration and the design of the plant	CC	<p>The station optimises the environmental performance of LCP 272 and LCP 273 through the following techniques:</p> <ul style="list-style-type: none"> - Maintenance of the combustion system (b) - Advanced control system (c) - Good design of the combustion equipment (d) and - Fuel choice (e) <p>There is no requirement to blend or mix fuels. The plant has a contractual agreement to receive natural gas from the National Transmission System (NTS), which requires the gas to comply with specified quality criteria</p> <p>The performance of LCP 394 is optimised through techniques b (Maintenance of the combustion system) and d (Good design of the combustion equipment).</p>
Technique	Description	Applicability																							
a.	Fuel blending and mixing	Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type	Generally applicable																						
b.	Maintenance of the combustion system	Regular planned maintenance according to suppliers' recommendations																							
c.	Advanced control system	See description in Section 8.1	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system																						
d.	Good design of the combustion equipment	Good design of furnace, combustion chambers, burners and associated devices	Generally applicable to new combustion plants																						
e.	Fuel choice	Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used	Applicable within the constraints associated with the availability of suitable types of fuel with a better environmental profile as a whole, which may be impacted by the energy policy of the Member State, or by the integrated site's fuel balance in the case of combustion of industrial process fuels. For existing combustion plants, the type of fuel chosen may be limited by the configuration and the design of the plant																						

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement						
7	<p>In order to reduce emissions of ammonia to air from the use of selective catalytic reduction (SCR) and/or selective non-catalytic reduction (SNCR) for the abatement of NO_x emissions, BAT is to optimise the design and/or operation of SCR and/or SNCR (e.g. optimised reagent to NO_x ratio, homogeneous reagent distribution and optimum size of the reagent drops).</p> <p>BAT-associated emission levels</p> <p>The BAT-associated emission level (BAT-AEL) for emissions of NH₃ to air from the use of SCR and/or SNCR is < 3–10 mg/Nm³ as a yearly average or average over the sampling period. The lower end of the range can be achieved when using SCR and the upper end of the range can be achieved when using SNCR without wet abatement techniques. In the case of plants combusting biomass and operating at variable loads as well as in the case of engines combusting HFO and/or gas oil, the higher end of the BAT-AEL range is 15 mg/Nm³.</p>	NA	Not applicable - no SCR or SNCR on site.						
8	<p>In order to prevent or reduce emissions to air during normal operating conditions, BAT is to ensure, by appropriate design, operation and maintenance, that the emission abatement systems are used at optimal capacity and availability.</p>	NA	Not applicable - the LCPs are not fitted with emissions abatement.						
9	<p>In order to improve the general environmental performance of combustion and/or gasification plants and to reduce emissions to air, BAT is to include the following elements in the quality assurance/quality control programmes for all the fuels used, as part of the environmental management system (see BAT 1):</p> <ul style="list-style-type: none"> (i) Initial full characterisation of the fuel used including at least the parameters listed below and in accordance with EN standards. ISO, national or other international standards may be used provided they ensure the provision of data of an equivalent scientific quality; (ii) Regular testing of the fuel quality to check that it is consistent with the initial characterisation and according to the plant design specifications. The frequency of testing and the parameters chosen from the table below are based on the variability of the fuel and an assessment of the relevance of pollutant releases (e.g. concentration in fuel, flue-gas treatment employed); (iii) Subsequent adjustment of the plant settings as and when needed and practicable (e.g. integration of the fuel characterisation and control in the advanced control system (see description in Section 8.1)). <p>Description</p> <p>Initial characterisation and regular testing of the fuel can be performed by the operator and/or the fuel supplier. If performed by the supplier, the full results are provided to the operator in the form of a product (fuel) supplier specification and/or guarantee.</p> <table border="1" data-bbox="338 1257 1496 1374"> <thead> <tr> <th data-bbox="338 1257 723 1294">Fuel(s)</th> <th data-bbox="723 1257 1496 1294">Substances/Parameters subject to characterisation</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 1294 723 1331">Biomass/peat</td> <td data-bbox="723 1294 1496 1331">— LHV</td> </tr> <tr> <td data-bbox="338 1331 723 1374"></td> <td data-bbox="723 1331 1496 1374">— moisture</td> </tr> </tbody> </table>	Fuel(s)	Substances/Parameters subject to characterisation	Biomass/peat	— LHV		— moisture	CC	<p>Natural gas is the primary fuel for LCP 272 and 273. This gas has to meet a nationally agreed specification for all the parameters listed. We consider that for plant which burns natural gas from the National Grid as a fuel it is not necessary for the operator to replicate the testing carried out by the National Grid.</p> <p>LCP 394 is run on gas oil. LCP 272 and LCP 273 can also utilise gas oil for back-up when natural gas is not available. The Operator has stated that an analysis of the gas oil is carried out for a range of parameters including ash, N, C and S at the time of each delivery.</p>
Fuel(s)	Substances/Parameters subject to characterisation								
Biomass/peat	— LHV								
	— moisture								

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																
	<table border="1"> <tr> <td data-bbox="338 384 725 507"></td> <td data-bbox="725 384 1494 507"> <ul style="list-style-type: none"> — Ash — C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn) </td> </tr> <tr> <td data-bbox="338 507 725 719">Coal/lignite</td> <td data-bbox="725 507 1494 719"> <ul style="list-style-type: none"> — LHV — Moisture — Volatiles, ash, fixed carbon, C, H, N, O, S — Br, Cl, F — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) </td> </tr> <tr> <td data-bbox="338 719 725 804">HFO</td> <td data-bbox="725 719 1494 804"> <ul style="list-style-type: none"> — Ash — C, S, N, Ni, V </td> </tr> <tr> <td data-bbox="338 804 725 888">Gas oil</td> <td data-bbox="725 804 1494 888"> <ul style="list-style-type: none"> — Ash — N, C, S </td> </tr> <tr> <td data-bbox="338 888 725 973">Natural gas</td> <td data-bbox="725 888 1494 973"> <ul style="list-style-type: none"> — LHV — CH₄, C₂H₆, C₃, C₄₊, CO₂, N₂, Wobbe index </td> </tr> <tr> <td data-bbox="338 973 725 1058">Process fuels from the chemical industry⁽²⁷⁾</td> <td data-bbox="725 973 1494 1058"> <ul style="list-style-type: none"> — Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) </td> </tr> <tr> <td data-bbox="338 1058 725 1126">Iron and steel process gases</td> <td data-bbox="725 1058 1494 1126"> <ul style="list-style-type: none"> — LHV, CH₄ (for COG), C_xH_y (for COG), CO₂, H₂, N₂, total sulphur, dust, Wobbe index </td> </tr> <tr> <td data-bbox="338 1126 725 1281">Waste⁽²⁸⁾</td> <td data-bbox="725 1126 1494 1281"> <ul style="list-style-type: none"> — LHV — Moisture — Volatiles, ash, Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) </td> </tr> </table>		<ul style="list-style-type: none"> — Ash — C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn) 	Coal/lignite	<ul style="list-style-type: none"> — LHV — Moisture — Volatiles, ash, fixed carbon, C, H, N, O, S — Br, Cl, F — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) 	HFO	<ul style="list-style-type: none"> — Ash — C, S, N, Ni, V 	Gas oil	<ul style="list-style-type: none"> — Ash — N, C, S 	Natural gas	<ul style="list-style-type: none"> — LHV — CH₄, C₂H₆, C₃, C₄₊, CO₂, N₂, Wobbe index 	Process fuels from the chemical industry ⁽²⁷⁾	<ul style="list-style-type: none"> — Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) 	Iron and steel process gases	<ul style="list-style-type: none"> — LHV, CH₄ (for COG), C_xH_y (for COG), CO₂, H₂, N₂, total sulphur, dust, Wobbe index 	Waste ⁽²⁸⁾	<ul style="list-style-type: none"> — LHV — Moisture — Volatiles, ash, Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) 		Table S2.1 of the permit limits the sulphur content of gas oil to 0.1% w/w.
	<ul style="list-style-type: none"> — Ash — C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn) 																		
Coal/lignite	<ul style="list-style-type: none"> — LHV — Moisture — Volatiles, ash, fixed carbon, C, H, N, O, S — Br, Cl, F — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) 																		
HFO	<ul style="list-style-type: none"> — Ash — C, S, N, Ni, V 																		
Gas oil	<ul style="list-style-type: none"> — Ash — N, C, S 																		
Natural gas	<ul style="list-style-type: none"> — LHV — CH₄, C₂H₆, C₃, C₄₊, CO₂, N₂, Wobbe index 																		
Process fuels from the chemical industry ⁽²⁷⁾	<ul style="list-style-type: none"> — Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) 																		
Iron and steel process gases	<ul style="list-style-type: none"> — LHV, CH₄ (for COG), C_xH_y (for COG), CO₂, H₂, N₂, total sulphur, dust, Wobbe index 																		
Waste ⁽²⁸⁾	<ul style="list-style-type: none"> — LHV — Moisture — Volatiles, ash, Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) 																		
10	In order to reduce emissions to air and/or to water during other than normal operating conditions (OTNOC), BAT is to set up and implement a management plan as part of the environmental management system (see BAT 1), commensurate with the relevance of potential pollutant releases, that includes the following elements:	CC	The requirements of BAT11 are met by existing site documentation, for example;																

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	<ul style="list-style-type: none"> — appropriate design of the systems considered relevant in causing OTNOC that may have an impact on emissions to air, water and/or soil (e.g. low-load design concepts for reducing the minimum start-up and shutdown loads for stable generation in gas turbines), — set-up and implementation of a specific preventive maintenance plan for these relevant systems, — review and recording of emissions caused by OTNOC and associated circumstances and implementation of corrective actions if necessary, — periodic assessment of the overall emissions during OTNOC (e.g. frequency of events, duration, emissions quantification/estimation) and implementation of corrective actions if necessary. 		<ul style="list-style-type: none"> • gas turbine starts are optimised based on plant condition (.i.e. warmth category) to minimise emissions during start-up. • All plant components are included within the site specific preventative maintenance programmes. The frequency of maintenance is dependent on component duty. • Emissions during start-up and shutdown operations are monitored and reviewed to identify if corrective actions are required. • Emissions to air and water are assessed as part of the annual environmental performance report. • In the event of an accident or environmental incident, we would review the emissions, cause etc. as part of our incident investigation process and ensure any relevant corrective and / or preventive action is implemented.
11	<p>BAT is to appropriately monitor emissions to air and/or to water during OTNOC.</p> <p>Description</p> <p>The monitoring can be carried out by direct measurement of emissions or by monitoring of surrogate parameters if this proves to be of equal or better scientific quality than the direct measurement of emissions. Emissions during start-up and shutdown (SU/SD) may be assessed based on a detailed emission measurement carried out for a typical SU/SD procedure at least once every year, and using the results of this measurement to estimate the emissions for each and every SU/SD throughout the year.</p>	CC	<p>The monitoring equipment for emissions to air and water is fully operable when the stations is discharging to the environment and is not affected by OTNOC events.</p>

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																											
12	<p>In order to increase the energy efficiency of combustion, gasification and/or IGCC units operated $\geq 1\,500$ h/yr, BAT is to use an appropriate combination of the techniques given below.</p> <table border="1" data-bbox="338 440 1494 1375"> <thead> <tr> <th data-bbox="338 440 591 475">Technique</th> <th data-bbox="591 440 1066 475">Description</th> <th data-bbox="1066 440 1494 475">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 475 591 584">a. Combustion optimisation</td> <td data-bbox="591 475 1066 584">See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues</td> <td data-bbox="1066 475 1494 584" rowspan="4">Generally applicable</td> </tr> <tr> <td data-bbox="338 584 591 719">b. Optimisation of the working medium conditions</td> <td data-bbox="591 584 1066 719">Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO_x emissions or the characteristics of energy demanded</td> </tr> <tr> <td data-bbox="338 719 591 828">c. Optimisation of the steam cycle</td> <td data-bbox="591 719 1066 828">Operate with lower turbine exhaust pressure by utilisation of the lowest possible temperature of the condenser cooling water, within the design conditions</td> </tr> <tr> <td data-bbox="338 828 591 884">d. Minimisation of energy consumption</td> <td data-bbox="591 828 1066 884">Minimising the internal energy consumption (e.g. greater efficiency of the feed-water pump)</td> </tr> <tr> <td data-bbox="338 884 591 970">e. Preheating of combustion air</td> <td data-bbox="591 884 1066 970">Reuse of part of the heat recovered from the combustion flue-gas to preheat the air used in combustion</td> <td data-bbox="1066 884 1494 970">Generally applicable within the constraints related to the need to control NO_x emissions</td> </tr> <tr> <td data-bbox="338 970 591 1051">f. Fuel preheating</td> <td data-bbox="591 970 1066 1051">Preheating of fuel using recovered heat</td> <td data-bbox="1066 970 1494 1051">Generally applicable within the constraints associated with the boiler design and the need to control NO_x emissions</td> </tr> <tr> <td data-bbox="338 1051 591 1160">g. Advanced control system</td> <td data-bbox="591 1051 1066 1160">See description in Section 8.2. Computerised control of the main combustion parameters enables the combustion efficiency to be improved</td> <td data-bbox="1066 1051 1494 1160">Generally applicable to new units. The applicability to old units may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> <tr> <td data-bbox="338 1160 591 1321">h. Feed-water preheating using recovered heat</td> <td data-bbox="591 1160 1066 1321">Preheat water coming out of the steam condenser with recovered heat, before reusing it in the boiler</td> <td data-bbox="1066 1160 1494 1321">Only applicable to steam circuits and not to hot boilers. Applicability to existing units may be limited due to constraints associated with the plant configuration and the amount of recoverable heat</td> </tr> <tr> <td data-bbox="338 1321 591 1375">i. Heat recovery by cogeneration (CHP)</td> <td data-bbox="591 1321 1066 1375">Recovery of heat (mainly from the steam system) for producing hot water/steam to be</td> <td data-bbox="1066 1321 1494 1375">Applicable within the constraints associated with the local heat and power demand.</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Combustion optimisation	See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues	Generally applicable	b. Optimisation of the working medium conditions	Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO _x emissions or the characteristics of energy demanded	c. Optimisation of the steam cycle	Operate with lower turbine exhaust pressure by utilisation of the lowest possible temperature of the condenser cooling water, within the design conditions	d. Minimisation of energy consumption	Minimising the internal energy consumption (e.g. greater efficiency of the feed-water pump)	e. Preheating of combustion air	Reuse of part of the heat recovered from the combustion flue-gas to preheat the air used in combustion	Generally applicable within the constraints related to the need to control NO _x emissions	f. Fuel preheating	Preheating of fuel using recovered heat	Generally applicable within the constraints associated with the boiler design and the need to control NO _x emissions	g. Advanced control system	See description in Section 8.2. Computerised control of the main combustion parameters enables the combustion efficiency to be improved	Generally applicable to new units. The applicability to old units may be constrained by the need to retrofit the combustion system and/or control command system	h. Feed-water preheating using recovered heat	Preheat water coming out of the steam condenser with recovered heat, before reusing it in the boiler	Only applicable to steam circuits and not to hot boilers. Applicability to existing units may be limited due to constraints associated with the plant configuration and the amount of recoverable heat	i. Heat recovery by cogeneration (CHP)	Recovery of heat (mainly from the steam system) for producing hot water/steam to be	Applicable within the constraints associated with the local heat and power demand.	CC	<p>The station uses the following techniques to increase the energy efficiency of combustion:</p> <ul style="list-style-type: none"> - Combustion optimisation (a) - Optimisation of the working medium conditions (b) - Optimisation of the steam cycle (c) - Minimisation of energy consumption (d) - Fuel preheating (f) and - Advanced control system (g) <p>The efficiency of LCP 272 and LCP 273 when burning gas is 55.4%.</p> <p>BAT 12 is not applicable to LCP 394 – as only applicable to plant which operates more than 1500 hours per year.</p>
Technique	Description	Applicability																												
a. Combustion optimisation	See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues	Generally applicable																												
b. Optimisation of the working medium conditions	Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO _x emissions or the characteristics of energy demanded																													
c. Optimisation of the steam cycle	Operate with lower turbine exhaust pressure by utilisation of the lowest possible temperature of the condenser cooling water, within the design conditions																													
d. Minimisation of energy consumption	Minimising the internal energy consumption (e.g. greater efficiency of the feed-water pump)																													
e. Preheating of combustion air	Reuse of part of the heat recovered from the combustion flue-gas to preheat the air used in combustion	Generally applicable within the constraints related to the need to control NO _x emissions																												
f. Fuel preheating	Preheating of fuel using recovered heat	Generally applicable within the constraints associated with the boiler design and the need to control NO _x emissions																												
g. Advanced control system	See description in Section 8.2. Computerised control of the main combustion parameters enables the combustion efficiency to be improved	Generally applicable to new units. The applicability to old units may be constrained by the need to retrofit the combustion system and/or control command system																												
h. Feed-water preheating using recovered heat	Preheat water coming out of the steam condenser with recovered heat, before reusing it in the boiler	Only applicable to steam circuits and not to hot boilers. Applicability to existing units may be limited due to constraints associated with the plant configuration and the amount of recoverable heat																												
i. Heat recovery by cogeneration (CHP)	Recovery of heat (mainly from the steam system) for producing hot water/steam to be	Applicable within the constraints associated with the local heat and power demand.																												

BAT Concn. Number	Summary of BAT Conclusion requirement				Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
			<p>used in industrial processes/activities or in a public network for district heating. Additional heat recovery is possible from:</p> <ul style="list-style-type: none"> — flue-gas — grate cooling — circulating fluidised bed 	<p>The applicability may be limited in the case of gas compressors with an unpredictable operational heat profile</p>		
	j.	CHP readiness	See description in Section 8.2.	Only applicable to new units where there is a realistic potential for the future use of heat in the vicinity of the unit		
	k.	Flue-gas condenser	See description in Section 8.2.	Generally applicable to CHP units provided there is enough demand for low-temperature heat		
	l.	Heat accumulation	Heat accumulation storage in CHP mode	Only applicable to CHP plants. The applicability may be limited in the case of low heat load demand		
	m.	Wet stack	See description in Section 8.2.	Generally applicable to new and existing units fitted with wet FGD		
	n.	Cooling tower discharge	The release of emissions to air through a cooling tower and not via a dedicated stack	Only applicable to units fitted with wet FGD where reheating of the flue-gas is necessary before release, and where the unit cooling system is a cooling tower		
	o.	Fuel pre-drying	The reduction of fuel moisture content before combustion to improve combustion conditions	<p>Applicable to the combustion of biomass and/or peat within the constraints associated with spontaneous combustion risks (e.g. the moisture content of peat is kept above 40 % throughout the delivery chain).</p> <p>The retrofit of existing plants may be restricted by the extra calorific value that can be obtained from the drying operation and by the limited retrofit possibilities offered by some boiler designs or plant configurations</p>		
	p.	Minimisation of heat losses	Minimising residual heat losses, e.g. those that occur via the slag or those that can be reduced by insulating radiating sources	Only applicable to solid-fuel-fired combustion units and to gasification/IGCC units		

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement									
	q.	Advanced materials	Use of advanced materials proven to be capable of withstanding high operating temperatures and pressures and thus to achieve increased steam/combustion process efficiencies	Only applicable to new plants										
	r.	Steam turbine upgrades	This includes techniques such as increasing the temperature and pressure of medium-pressure steam, addition of a low-pressure turbine, and modifications to the geometry of the turbine rotor blades	The applicability may be restricted by demand, steam conditions and/or limited plant lifetime										
	s.	Supercritical and ultra-supercritical steam conditions	Use of a steam circuit, including steam reheating systems, in which steam can reach pressures above 220,6 bar and temperatures above 374 °C in the case of supercritical conditions, and above 250 – 300 bar and temperatures above 580 – 600 °C in the case of ultra-supercritical conditions	Only applicable to new units of $\geq 600 \text{ MW}_{\text{th}}$ operated $> 4\,000 \text{ h/yr}$. Not applicable when the purpose of the unit is to produce low steam temperatures and/or pressures in process industries. Not applicable to gas turbines and engines generating steam in CHP mode. For units combusting biomass, the applicability may be constrained by high-temperature corrosion in the case of certain biomasses										
13	In order to reduce water usage and the volume of contaminated waste water discharged, BAT is to use one or both of the techniques given below.			CC	The Operator states that water used within the cooling water system is not of suitable quality to be re-used in other processes on site. The quality of the water recovered would have an adverse impact on the operation of the water treatment plant and may lead to increased chemical and energy usage. However, water usage is optimised and minimised where plant design allows. Process water usage including boiler feedwater is optimised through minimisation of blowdown from the water steam cycle.									
	<table border="1"> <thead> <tr> <th data-bbox="322 979 535 1018">Technique</th> <th data-bbox="535 979 1068 1018">Description</th> <th data-bbox="1068 979 1509 1018">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 1018 383 1150">a.</td> <td data-bbox="383 1018 535 1150">Water recycling</td> <td data-bbox="535 1018 1068 1150">Residual aqueous streams, including run-off water, from the plant are reused for other purposes. The degree of recycling is limited by the quality requirements of the recipient water stream and the water balance of the plant</td> </tr> <tr> <td data-bbox="322 1150 383 1375">b.</td> <td data-bbox="383 1150 535 1375">Dry bottom ash handling</td> <td data-bbox="535 1150 1068 1375">Dry, hot bottom ash falls from the furnace onto a mechanical conveyor system and is cooled down by ambient air. No water is used in the process.</td> </tr> </tbody> </table>			Technique	Description	Applicability	a.	Water recycling	Residual aqueous streams, including run-off water, from the plant are reused for other purposes. The degree of recycling is limited by the quality requirements of the recipient water stream and the water balance of the plant	b.	Dry bottom ash handling	Dry, hot bottom ash falls from the furnace onto a mechanical conveyor system and is cooled down by ambient air. No water is used in the process.		
Technique	Description	Applicability												
a.	Water recycling	Residual aqueous streams, including run-off water, from the plant are reused for other purposes. The degree of recycling is limited by the quality requirements of the recipient water stream and the water balance of the plant												
b.	Dry bottom ash handling	Dry, hot bottom ash falls from the furnace onto a mechanical conveyor system and is cooled down by ambient air. No water is used in the process.												

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement						
			<p>Almost all drainage on site including blow down from the water steam cycle is reused within the cooling water system as it has lower quality requirements.</p> <p>As the primary fuel used is natural gas, no ash is generated. Therefore, no associated wastewater is generated at the site.</p>						
14	<p>In order to prevent the contamination of uncontaminated waste water and to reduce emissions to water, BAT is to segregate waste water streams and to treat them separately, depending on the pollutant content.</p> <p>Description Waste water streams that are typically segregated and treated include surface run-off water, cooling water, and waste water from flue-gas treatment.</p> <p>Applicability The applicability may be restricted in the case of existing plants due to the configuration of the drainage systems.</p>	CC	All waste water streams are segregated, treated and where necessary monitored separately prior to discharge.						
15	In order to reduce emissions to water from flue-gas treatment, BAT is to use an appropriate combination of the techniques given in BAT 15, and to use secondary techniques as close as possible to the source in order to avoid dilution.	N/A	Not applicable - the site does not have flue gas treatment.						
16	<p>In order to reduce the quantity of waste sent for disposal from the combustion and/or gasification process and abatement techniques, BAT is to organise operations so as to maximise, in order of priority and taking into account life-cycle thinking:</p> <ul style="list-style-type: none"> (a) waste prevention, e.g. maximise the proportion of residues which arise as by-products; (b) waste preparation for reuse, e.g. according to the specific requested quality criteria; (c) waste recycling; (d) other waste recovery (e.g. energy recovery), <p>by implementing an appropriate combination of techniques such as:</p> <table border="1" data-bbox="338 1289 1496 1326"> <thead> <tr> <th data-bbox="338 1289 584 1326">Technique</th> <th data-bbox="584 1289 1088 1326">Description</th> <th data-bbox="1088 1289 1496 1326">Applicability</th> </tr> </thead> <tbody> <tr> <td> </td> <td> </td> <td> </td> </tr> </tbody> </table>	Technique	Description	Applicability				CC	Specific techniques of BAT16 are not applicable to the installation because no waste is produced as a by-product of combustion and there is no flue gas treatment used on site. Other waste arising from site activities are dealt with according the waste hierarchy.
Technique	Description	Applicability							

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement						
	a.	Generation of gypsum as a by-product	Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g. as raw material in the plasterboard industry). The quality of limestone used in the wet FGD influences the purity of the gypsum produced	Generally applicable within the constraints associated with the required gypsum quality, the health requirements associated to each specific use, and by the market conditions							
	b.	Recycling or recovery of residues in the construction sector	Recycling or recovery of residues (e.g. from semi-dry desulphurisation processes, fly ash, bottom ash) as a construction material (e.g. in road building, to replace sand in concrete production, or in the cement industry)	Generally applicable within the constraints associated with the required material quality (e.g. physical properties, content of harmful substances) associated to each specific use, and by the market conditions							
	c.	Energy recovery by using waste in the fuel mix	The residual energy content of carbon-rich ash and sludges generated by the combustion of coal, lignite, heavy fuel oil, peat or biomass can be recovered for example by mixing with the fuel	Generally applicable where plants can accept waste in the fuel mix and are technically able to feed the fuels into the combustion chamber							
	d.	Preparation of spent catalyst for reuse	Preparation of catalyst for reuse (e.g. up to four times for SCR catalysts) restores some or all of the original performance, extending the service life of the catalyst to several decades. Preparation of spent catalyst for reuse is integrated in a catalyst management scheme	The applicability may be limited by the mechanical condition of the catalyst and the required performance with respect to controlling NO _x and NH ₃ emissions							
17	In order to reduce noise emissions, BAT is to use one or a combination of the techniques given below.			CC	Noise emissions are reduced by the application of techniques a, b, c, d and e. Additional noise attenuation barriers were added during the 2012 upgrade to the site.						
	<table border="1"> <thead> <tr> <th data-bbox="322 1134 591 1174">Technique</th> <th data-bbox="591 1134 1088 1174">Description</th> <th data-bbox="1088 1134 1509 1174">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 1174 591 1380">a. Operational measures</td> <td data-bbox="591 1174 1088 1380"> These include: <ul style="list-style-type: none"> — improved inspection and maintenance of equipment — closing of doors and windows of enclosed areas, if possible — equipment operated by experienced staff — avoidance of noisy activities at night, if possible — provisions for noise control during maintenance activities </td> <td data-bbox="1088 1174 1509 1380">Generally applicable</td> </tr> </tbody> </table>			Technique	Description	Applicability	a. Operational measures	These include: <ul style="list-style-type: none"> — improved inspection and maintenance of equipment — closing of doors and windows of enclosed areas, if possible — equipment operated by experienced staff — avoidance of noisy activities at night, if possible — provisions for noise control during maintenance activities 	Generally applicable		
Technique	Description	Applicability									
a. Operational measures	These include: <ul style="list-style-type: none"> — improved inspection and maintenance of equipment — closing of doors and windows of enclosed areas, if possible — equipment operated by experienced staff — avoidance of noisy activities at night, if possible — provisions for noise control during maintenance activities 	Generally applicable									

BAT Concn. Number	Summary of BAT Conclusion requirement				Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																		
	b.	Low-noise equipment	This potentially includes compressors, pumps and disks	Generally applicable when the equipment is new or replaced																				
	c.	Noise attenuation	Noise propagation can be reduced by inserting obstacles between the emitter and the receiver. Appropriate obstacles include protection walls, embankments and buildings	Generally applicable to new plants. In the case of existing plants, the insertion of obstacles may be restricted by lack of space																				
	d.	Noise-control equipment	This includes: <ul style="list-style-type: none"> — noise-reducers — equipment insulation — enclosure of noisy equipment — soundproofing of buildings 	The applicability may be restricted by lack of space																				
	e.	Appropriate location of equipment and buildings	Noise levels can be reduced by increasing the distance between the emitter and the receiver and by using buildings as noise screens	Generally applicable to new plant																				
Combustion of liquid fuels																								
Table 13	<p style="text-align: center;">BAT-associated energy efficiency levels (BAT-AEELs) for HFO and/or gas oil combustion in boilers</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="3" style="width: 30%;">Type of combustion unit</th> <th colspan="4" style="text-align: center;">BAT-AEELs ⁽⁹⁹⁾ ₍₁₀₀₎</th> </tr> <tr> <th colspan="2" style="text-align: center;">Net electrical efficiency (%)</th> <th colspan="2" style="text-align: center;">Net total fuel utilisation (%) ⁽¹⁰¹⁾</th> </tr> <tr> <th style="text-align: center;">New unit</th> <th style="text-align: center;">Existing unit</th> <th style="text-align: center;">New unit</th> <th style="text-align: center;">Existing unit</th> </tr> </thead> <tbody> <tr> <td>HFO- and/or gas-oil-fired boiler</td> <td style="text-align: center;">> 36,4</td> <td style="text-align: center;">35,6–37,4</td> <td style="text-align: center;">80–96</td> <td style="text-align: center;">80–96</td> </tr> </tbody> </table>				Type of combustion unit	BAT-AEELs ⁽⁹⁹⁾ ₍₁₀₀₎				Net electrical efficiency (%)		Net total fuel utilisation (%) ⁽¹⁰¹⁾		New unit	Existing unit	New unit	Existing unit	HFO- and/or gas-oil-fired boiler	> 36,4	35,6–37,4	80–96	80–96	N/A	Not applicable to gas turbines
Type of combustion unit	BAT-AEELs ⁽⁹⁹⁾ ₍₁₀₀₎																							
	Net electrical efficiency (%)		Net total fuel utilisation (%) ⁽¹⁰¹⁾																					
	New unit	Existing unit	New unit	Existing unit																				
HFO- and/or gas-oil-fired boiler	> 36,4	35,6–37,4	80–96	80–96																				
28	In order to prevent or reduce NO _x emissions to air while limiting CO emissions to air from the combustion of HFO and/or gas oil in boilers, BAT is to use one or a combination of the techniques given in BAT 28.				N/A	Not applicable to gas turbines																		

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement										
29	In order to prevent or reduce SO _x , HCl and HF emissions to air from the combustion of HFO and/or gas oil in boilers, BAT is to use one or a combination of the techniques given in BAT 29.	N/A	Not applicable to gas turbines										
30	In order to reduce dust and particulate-bound metal emissions to air from the combustion of HFO and/or gas oil in boilers, BAT is to use one or a combination of the techniques given in BAT 30.	N/A	Not applicable to gas turbines										
31	In order to increase the energy efficiency of HFO and/or gas oil combustion in reciprocating engines, BAT is to use an appropriate combination of the techniques given in BAT 12 and BAT 31.	N/A	Not applicable to gas turbines										
32	In order to prevent or reduce NO _x emissions to air from the combustion of HFO and/or gas oil in reciprocating engines, BAT is to use one or a combination of the techniques given in BAT 32.	N/A	Not applicable to gas turbines										
33	In order to prevent or reduce emissions of CO and volatile organic compounds to air from the combustion of HFO and/or gas oil in reciprocating engines, BAT is to use one or both of the techniques given in BAT 33.	N/A	Not applicable to gas turbines										
34	In order to prevent or reduce SO _x , HCl and HF emissions to air from the combustion of HFO and/or gas oil in reciprocating engines, BAT is to use one or a combination of the techniques given in BAT 34.	N/A	Not applicable to gas turbines										
35	In order to prevent or reduce dust and particulate-bound metal emissions from the combustion of HFO and/or gas oil in reciprocating engines, BAT is to use one or a combination of the techniques given in BAT 35.	N/A	Not applicable to gas turbines										
36	<p>In order to increase the energy efficiency of gas oil combustion in gas turbines, BAT is to use an appropriate combination of the techniques given in BAT 12 and below.</p> <table border="1" data-bbox="338 1139 1494 1283"> <thead> <tr> <th data-bbox="338 1139 521 1171">Technique</th> <th data-bbox="521 1139 763 1171">Description</th> <th data-bbox="763 1139 1494 1171">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 1171 521 1283">a. Combined cycle</td> <td data-bbox="521 1171 763 1283">See description in Section 8.2</td> <td data-bbox="763 1171 1494 1283">Generally applicable to new units operated ≥ 1 500 h/yr. Applicable to existing units within the constraints associated with the steam cycle design and the space availability. Not applicable to existing units operated < 1 500 h/yr</td> </tr> </tbody> </table> <p style="text-align: center;">BAT-associated energy efficiency levels (BAT-AEELs) for gas-oil-fired gas turbines</p> <table border="1" data-bbox="338 1337 1494 1374"> <thead> <tr> <th data-bbox="338 1337 981 1374">Type of combustion unit</th> <th data-bbox="981 1337 1494 1374">BAT-AEELs ⁽¹³²⁾</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 1374 981 1393"></td> <td data-bbox="981 1374 1494 1393"></td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Combined cycle	See description in Section 8.2	Generally applicable to new units operated ≥ 1 500 h/yr. Applicable to existing units within the constraints associated with the steam cycle design and the space availability. Not applicable to existing units operated < 1 500 h/yr	Type of combustion unit	BAT-AEELs ⁽¹³²⁾			CC	<p>LCP 272 and 273 only operate in combined cycle mode. For LCP 394, combined cycle is not applicable to existing units operated less than 1,500 hours per year.</p> <p>For LCP 394, BAT 12 is not applicable to plant which operates less than 1500 hours per year. However the Operator confirms that technique 1 (combustion</p>
Technique	Description	Applicability											
a. Combined cycle	See description in Section 8.2	Generally applicable to new units operated ≥ 1 500 h/yr. Applicable to existing units within the constraints associated with the steam cycle design and the space availability. Not applicable to existing units operated < 1 500 h/yr											
Type of combustion unit	BAT-AEELs ⁽¹³²⁾												

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement												
	<table border="1" data-bbox="338 384 1494 523"> <thead> <tr> <th data-bbox="338 384 981 416"></th> <th colspan="2" data-bbox="981 384 1494 416">Net electrical efficiency (%) ⁽¹³³⁾</th> </tr> <tr> <th data-bbox="338 416 981 448"></th> <th data-bbox="981 416 1205 448">New unit</th> <th data-bbox="1205 416 1494 448">Existing unit</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 448 981 480">Gas-oil-fired open-cycle gas turbine</td> <td data-bbox="981 448 1205 480">> 33</td> <td data-bbox="1205 448 1494 480">25–35,7</td> </tr> <tr> <td data-bbox="338 480 981 512">Gas-oil-fired combined cycle gas turbine</td> <td data-bbox="981 480 1205 512">> 40</td> <td data-bbox="1205 480 1494 512">33–44</td> </tr> </tbody> </table>		Net electrical efficiency (%) ⁽¹³³⁾			New unit	Existing unit	Gas-oil-fired open-cycle gas turbine	> 33	25–35,7	Gas-oil-fired combined cycle gas turbine	> 40	33–44		<p>optimisation) is used to maintain the efficiency of all three LCPs on site.</p> <p>The station uses techniques a, b, c, d, f and g given in BAT 12 for LCP 272 and LCP 273.</p> <p>For LCP 272 and LCP 273, the primary fuel is natural gas, with gas oil being used only as supplementary/ emergency fuel. The operator has confirmed that the efficiency when burning gas oil is 51.4% and therefore above the BAT-AEEL range for existing combined cycle gas turbines burning gas oil.</p> <p>LCP 394 operates for <500 hours a year and in accordance with BAT conclusion 36 footnote 1 the BAT-AEEL does not apply. However LCP 394 has an efficiency of 28.4% which is within the BAT range for existing open cycle gas turbines.</p>
	Net electrical efficiency (%) ⁽¹³³⁾														
	New unit	Existing unit													
Gas-oil-fired open-cycle gas turbine	> 33	25–35,7													
Gas-oil-fired combined cycle gas turbine	> 40	33–44													
37	<p>In order to prevent or reduce NO_x emissions to air from the combustion of gas oil in gas turbines, BAT is to use one or a combination of the techniques given below.</p> <table border="1" data-bbox="338 1206 1494 1334"> <thead> <tr> <th data-bbox="338 1206 600 1238">Technique</th> <th data-bbox="600 1206 824 1238">Description</th> <th data-bbox="824 1206 1494 1238">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 1238 600 1270">a. Water/steam addition</td> <td data-bbox="600 1238 824 1286" rowspan="2">See description in Section 8.3</td> <td data-bbox="824 1238 1494 1270">The applicability may be limited due to water availability</td> </tr> <tr> <td data-bbox="338 1270 600 1334">b. Low-NO_x burners (LNB)</td> <td data-bbox="824 1270 1494 1334">Only applicable to turbine models for which low-NO_x burners are available on the market</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Water/steam addition	See description in Section 8.3	The applicability may be limited due to water availability	b. Low-NO _x burners (LNB)	Only applicable to turbine models for which low-NO _x burners are available on the market	CC	<p>For LCP 272 and LCP 273, the primary fuel is natural gas, with gas oil being used only as supplementary/ emergency fuel. The gas turbines are fitted with dry low NO_x burners. NO_x is additionally controlled by water</p>				
Technique	Description	Applicability													
a. Water/steam addition	See description in Section 8.3	The applicability may be limited due to water availability													
b. Low-NO _x burners (LNB)		Only applicable to turbine models for which low-NO _x burners are available on the market													

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement									
	c. Selective catalytic reduction (SCR)		Not applicable to combustion plants operated < 500 h/yr. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr. Retrofitting existing combustion plants may be constrained by the availability of sufficient space		injection (reducing flame temperature) when firing on gas oil. LCP 394: We consider that there are currently no NOx emission reduction options available for the LCP 394. In making this assessment, we have considered the Joint Environmental Programme (JEP) report UTG/18/PMP/774/R, 'BAT Assessment for Existing Gas & Liquid Fuel Fired OCGTs, CCGTs and Dual-fuel GTs with a Thermal Input Rating of 50 MWth or Greater Operating <500 Hours Per Year'.									
38	In order to prevent or reduce CO emissions to air from the combustion of gas oil in gas turbines, BAT is to use one or a combination of the techniques given below.			CC	For LCP 272 and LCP 273, the primary fuel is natural gas, with gas oil being used only as supplementary/ emergency fuel. However, the operator has confirmed that combustion optimisation is utilised on all three LCP to minimise carbon monoxide emissions. BAT 38 provides an indicative NOx emission level of 250mg/Nm ³ for combustion of gas oil in dual fuel gas turbines operating less than 500 hours per year. However, this indicative figure is not strictly applicable to LCP 394, because it is not a dual fuel gas turbine. Therefore this figure is considered									
<table border="1"> <thead> <tr> <th data-bbox="349 906 602 943">Technique</th> <th data-bbox="602 906 846 943">Description</th> <th data-bbox="846 906 1496 943">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="349 943 602 1002">a. Combustion optimisation</td> <td data-bbox="602 943 846 1002">See description in Section 8.3</td> <td data-bbox="846 943 1496 1002">Generally applicable</td> </tr> <tr> <td data-bbox="349 1002 602 1086">b. Oxidation catalysts</td> <td data-bbox="602 1002 846 1086"></td> <td data-bbox="846 1002 1496 1086">Not applicable to combustion plants operated < 500 h/yr. Retrofitting existing combustion plants may be constrained by the availability of sufficient space</td> </tr> </tbody> </table>						Technique	Description	Applicability	a. Combustion optimisation	See description in Section 8.3	Generally applicable	b. Oxidation catalysts		Not applicable to combustion plants operated < 500 h/yr. Retrofitting existing combustion plants may be constrained by the availability of sufficient space
Technique	Description	Applicability												
a. Combustion optimisation	See description in Section 8.3	Generally applicable												
b. Oxidation catalysts		Not applicable to combustion plants operated < 500 h/yr. Retrofitting existing combustion plants may be constrained by the availability of sufficient space												
As an indication, the emission level for NO _x emissions to air from the combustion of gas oil in dual fuel gas turbines for emergency use operated < 500 h/yr will generally be 145–250 mg/Nm ³ as a daily average or average over the sampling period.														

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement										
			<p>to be a benchmark figure and for guidance only.</p> <p>We accept that the current NOx emission levels, along with appropriate maintenance of the gas turbines, is BAT for LCP394. Accordingly, we have set an indicative emission level of 400 mg/m³ in the varied and consolidated permit. this is based on justification supplied by the Operator and supported by the JEP report UTG/18/PMP/774/R 'BAT assessment for existing natural gas, gas oil and dual fuel fired OCGTS and CCGTs with a thermal rating of 50MWth or greater operating <500 hours per year' dated October 2018. This report gives a NOx level of 400 mg/m³ for the GE frame 5 OCGT when burning gas oil. This covers all conditions under which the gas turbine may operate as well as the normal variation in emission performance between outages.</p>										
39	<p>In order to prevent or reduce SO_x and dust emissions to air from the combustion of gas oil in gas turbines, BAT is to use the technique given below.</p> <table border="1" data-bbox="338 1177 1494 1361"> <thead> <tr> <th data-bbox="338 1177 490 1214">Technique</th> <th data-bbox="490 1177 714 1214">Description</th> <th data-bbox="714 1177 1494 1214">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 1214 490 1273">a. Fuel choice</td> <td data-bbox="490 1214 714 1273">See description in Section 8.4</td> <td data-bbox="714 1214 1494 1273">Applicable within the constraints associated with the availability of different types of fuel, which may be impacted by the energy policy of the Member State</td> </tr> </tbody> </table> <p>BAT-associated emission levels for SO₂ and dust emissions to air from the combustion of gas oil in gas turbines, including dual fuel gas turbines</p> <table border="1" data-bbox="338 1329 1494 1361"> <thead> <tr> <th data-bbox="338 1329 544 1361"></th> <th data-bbox="544 1329 1494 1361">BAT-AELs (mg/Nm³)</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 1361 544 1367"></td> <td data-bbox="544 1361 1494 1367"></td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Fuel choice	See description in Section 8.4	Applicable within the constraints associated with the availability of different types of fuel, which may be impacted by the energy policy of the Member State		BAT-AELs (mg/Nm ³)				<p>The installation implements 'fuel choice' as a technique to prevent and reduce emissions of SO_x and dust from combustion of liquid fuel.</p> <p>LCP 394 is permitted to operate for no more than 500 hours per year. The yearly BAT-AELs for SO₂ and dust are not applicable to existing</p>
Technique	Description	Applicability											
a. Fuel choice	See description in Section 8.4	Applicable within the constraints associated with the availability of different types of fuel, which may be impacted by the energy policy of the Member State											
	BAT-AELs (mg/Nm ³)												

BAT Concn. Number	Summary of BAT Conclusion requirement				Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement														
	<table border="1"> <thead> <tr> <th data-bbox="338 384 539 504" rowspan="2">Type of combustion plant</th> <th colspan="2" data-bbox="539 384 1016 424">SO₂</th> <th colspan="2" data-bbox="1016 384 1494 424">Dust</th> </tr> <tr> <th data-bbox="539 424 723 504">Yearly average ⁽¹³⁴⁾</th> <th data-bbox="723 424 1016 504">Daily average or average over the sampling period ⁽¹³⁵⁾</th> <th data-bbox="1016 424 1200 504">Yearly average ⁽¹³⁴⁾</th> <th data-bbox="1200 424 1494 504">Daily average or average over the sampling period ⁽¹³⁵⁾</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 504 539 564">New and existing plants</td> <td data-bbox="539 504 723 564">35–60</td> <td data-bbox="723 504 1016 564">50–66</td> <td data-bbox="1016 504 1200 564">2–5</td> <td data-bbox="1200 504 1494 564">2–10</td> </tr> </tbody> </table>				Type of combustion plant	SO ₂		Dust		Yearly average ⁽¹³⁴⁾	Daily average or average over the sampling period ⁽¹³⁵⁾	Yearly average ⁽¹³⁴⁾	Daily average or average over the sampling period ⁽¹³⁵⁾	New and existing plants	35–60	50–66	2–5	2–10		<p>plants operating for less than 1500 hours per year. The daily (or average over sampling period) BAT-AELs for SO₂ and dust are indicative for existing plants operating for less than 500 hours per year.</p> <p>In their Reg 61 response the operator confirms that the sulphur content of gas oil is regulated to <0.1% by mass, equivalent to 55 mg/m³ in the flue gas for LCP 394 (JEP report UTG/18/ERG/773/R).</p> <p>Dust emissions for LCP 394 are quantified in JEP report UTG/18/ERG/773/R and the levels are less than the indicative BAT AEL.</p>
Type of combustion plant	SO ₂		Dust																	
	Yearly average ⁽¹³⁴⁾	Daily average or average over the sampling period ⁽¹³⁵⁾	Yearly average ⁽¹³⁴⁾	Daily average or average over the sampling period ⁽¹³⁵⁾																
New and existing plants	35–60	50–66	2–5	2–10																
Combustion of gaseous fuels																				
40	In order to increase the energy efficiency of natural gas combustion, BAT is to use an appropriate combination of the techniques given in BAT 12 and below.				CC	<p>The station uses techniques a, b, c, d, f and g given in BAT 12 for LCP 272 and LCP 273.</p> <p>LCP 272 and 273 only operate in combined cycle mode.</p> <p>The BAT-AEEL range for net electrical efficiency applicable to the CCGTs is 50-60%. The Operator has confirmed that the efficiency when burning natural gas is 55.4% and therefore above the BAT-AEEL</p>														
<table border="1"> <thead> <tr> <th data-bbox="338 1062 512 1094">Technique</th> <th data-bbox="512 1062 736 1094">Description</th> <th data-bbox="736 1062 1494 1094">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 1094 512 1302">a. Combined cycle</td> <td data-bbox="512 1094 736 1302">See description in Section 8.2</td> <td data-bbox="736 1094 1494 1302">Generally applicable to new gas turbines and engines except when operated < 1 500 h/yr. Applicable to existing gas turbines and engines within the constraints associated with the steam cycle design and the space availability. Not applicable to existing gas turbines and engines operated < 1 500 h/yr. Not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns. Not applicable to boilers</td> </tr> </tbody> </table> <p data-bbox="338 1302 1494 1334">BAT-associated energy efficiency levels (BAT-AEELs) for the combustion of natural gas</p> <table border="1" data-bbox="338 1334 1494 1370"> <thead> <tr> <th data-bbox="338 1334 607 1370"></th> <th data-bbox="607 1334 1494 1370">BAT-AEELs ⁽¹³⁶⁾ ⁽¹³⁷⁾</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 1370 607 1370"></td> <td data-bbox="607 1370 1494 1370"></td> </tr> </tbody> </table>							Technique	Description	Applicability	a. Combined cycle	See description in Section 8.2	Generally applicable to new gas turbines and engines except when operated < 1 500 h/yr. Applicable to existing gas turbines and engines within the constraints associated with the steam cycle design and the space availability. Not applicable to existing gas turbines and engines operated < 1 500 h/yr. Not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns. Not applicable to boilers		BAT-AEELs ⁽¹³⁶⁾ ⁽¹³⁷⁾						
Technique	Description	Applicability																		
a. Combined cycle	See description in Section 8.2	Generally applicable to new gas turbines and engines except when operated < 1 500 h/yr. Applicable to existing gas turbines and engines within the constraints associated with the steam cycle design and the space availability. Not applicable to existing gas turbines and engines operated < 1 500 h/yr. Not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns. Not applicable to boilers																		
	BAT-AEELs ⁽¹³⁶⁾ ⁽¹³⁷⁾																			

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																																																										
	<table border="1"> <thead> <tr> <th rowspan="2">Type of combustion unit</th> <th colspan="2">Net electrical efficiency (%)</th> <th rowspan="2">Net total fuel utilisation (%)⁽¹³⁸⁾ ⁽¹³⁹⁾</th> <th colspan="2">Net mechanical energy efficiency (%)⁽¹³⁹⁾ ⁽¹⁴⁰⁾</th> </tr> <tr> <th>New unit</th> <th>Existing unit</th> <th>New unit</th> <th>Existing unit</th> </tr> </thead> <tbody> <tr> <td>Gas engine</td> <td>39,5–44⁽¹⁴¹⁾</td> <td>35–44⁽¹⁴¹⁾</td> <td>56–85⁽¹⁴¹⁾</td> <td colspan="2">No BAT-AEEL.</td> </tr> <tr> <td>Gas-fired boiler</td> <td>39–42,5</td> <td>38–40</td> <td>78–95</td> <td colspan="2">No BAT-AEEL.</td> </tr> <tr> <td>Open cycle gas turbine, ≥ 50 MW_{th}</td> <td>36–41,5</td> <td>33–41,5</td> <td>No BAT-AEEL</td> <td>36,5–41</td> <td>33,5–41</td> </tr> <tr> <td colspan="6" style="text-align: center;">Combined cycle gas turbine (CCGT)</td> </tr> <tr> <td>CCGT, 50–600 MW_{th}</td> <td>53–58,5</td> <td>46–54</td> <td>No BAT-AEEL</td> <td colspan="2">No BAT-AEEL</td> </tr> <tr> <td>CCGT, ≥ 600 MW_{th}</td> <td>57–60,5</td> <td>50–60</td> <td>No BAT-AEEL</td> <td colspan="2">No BAT-AEEL</td> </tr> <tr> <td>CHP CCGT, 50–600 MW_{th}</td> <td>53–58,5</td> <td>46–54</td> <td>65–95</td> <td colspan="2">No BAT-AEEL</td> </tr> <tr> <td>CHP CCGT, ≥ 600 MW_{th}</td> <td>57–60,5</td> <td>50–60</td> <td>65–95</td> <td colspan="2">No BAT-AEEL</td> </tr> </tbody> </table>	Type of combustion unit	Net electrical efficiency (%)		Net total fuel utilisation (%) ⁽¹³⁸⁾ ⁽¹³⁹⁾	Net mechanical energy efficiency (%) ⁽¹³⁹⁾ ⁽¹⁴⁰⁾		New unit	Existing unit	New unit	Existing unit	Gas engine	39,5–44 ⁽¹⁴¹⁾	35–44 ⁽¹⁴¹⁾	56–85 ⁽¹⁴¹⁾	No BAT-AEEL.		Gas-fired boiler	39–42,5	38–40	78–95	No BAT-AEEL.		Open cycle gas turbine, ≥ 50 MW _{th}	36–41,5	33–41,5	No BAT-AEEL	36,5–41	33,5–41	Combined cycle gas turbine (CCGT)						CCGT, 50–600 MW _{th}	53–58,5	46–54	No BAT-AEEL	No BAT-AEEL		CCGT, ≥ 600 MW _{th}	57–60,5	50–60	No BAT-AEEL	No BAT-AEEL		CHP CCGT, 50–600 MW _{th}	53–58,5	46–54	65–95	No BAT-AEEL		CHP CCGT, ≥ 600 MW _{th}	57–60,5	50–60	65–95	No BAT-AEEL			<p>range for existing combined cycle gas turbines.</p> <p>LCP394 burns gas oil, therefore BAT 40 is not applicable.</p>
Type of combustion unit	Net electrical efficiency (%)		Net total fuel utilisation (%) ⁽¹³⁸⁾ ⁽¹³⁹⁾	Net mechanical energy efficiency (%) ⁽¹³⁹⁾ ⁽¹⁴⁰⁾																																																									
	New unit	Existing unit		New unit	Existing unit																																																								
Gas engine	39,5–44 ⁽¹⁴¹⁾	35–44 ⁽¹⁴¹⁾	56–85 ⁽¹⁴¹⁾	No BAT-AEEL.																																																									
Gas-fired boiler	39–42,5	38–40	78–95	No BAT-AEEL.																																																									
Open cycle gas turbine, ≥ 50 MW _{th}	36–41,5	33–41,5	No BAT-AEEL	36,5–41	33,5–41																																																								
Combined cycle gas turbine (CCGT)																																																													
CCGT, 50–600 MW _{th}	53–58,5	46–54	No BAT-AEEL	No BAT-AEEL																																																									
CCGT, ≥ 600 MW _{th}	57–60,5	50–60	No BAT-AEEL	No BAT-AEEL																																																									
CHP CCGT, 50–600 MW _{th}	53–58,5	46–54	65–95	No BAT-AEEL																																																									
CHP CCGT, ≥ 600 MW _{th}	57–60,5	50–60	65–95	No BAT-AEEL																																																									
41	In order to prevent or reduce NO _x emissions to air from the combustion of natural gas in boilers, BAT is to use one or a combination of the techniques given in BAT 41.	N/A	Not Applicable to gas turbines																																																										
42	<p>In order to prevent or reduce NO_x emissions to air from the combustion of natural gas in gas turbines, BAT is to use one or a combination of the techniques given below.</p> <table border="1"> <thead> <tr> <th>Technique</th> <th>Description</th> <th>Applicability</th> </tr> </thead> <tbody> <tr> <td>a. Advanced control system</td> <td>See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr</td> <td>The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> <tr> <td>b. Water/steam addition</td> <td rowspan="2">See description in Section 8.3</td> <td>The applicability may be limited due to water availability</td> </tr> <tr> <td>c. Dry low-NO_x burners (DLN)</td> <td>The applicability may be limited in the case of turbines where a retrofit package is not available or when water/steam addition systems are installed</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system	b. Water/steam addition	See description in Section 8.3	The applicability may be limited due to water availability	c. Dry low-NO _x burners (DLN)	The applicability may be limited in the case of turbines where a retrofit package is not available or when water/steam addition systems are installed	CC	<p>In order to prevent or reduce NO_x emissions to air, the following combination of techniques from BAT 42 Table are implemented:</p> <ul style="list-style-type: none"> - Advanced control system (a), - Dry-low NO_x (DLN) burners (c), - Low NO_x burners (e) <p>The proposed E-DLN operating point for both LCP 272 and LCP 273 is defined as 120 MWe (equivalent to 50% of individual GT Base Load). The effective DLN is quoted as a percentage of individual GT load rather than module load due to the</p>																																															
Technique	Description	Applicability																																																											
a. Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system																																																											
b. Water/steam addition	See description in Section 8.3	The applicability may be limited due to water availability																																																											
c. Dry low-NO _x burners (DLN)		The applicability may be limited in the case of turbines where a retrofit package is not available or when water/steam addition systems are installed																																																											

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	
	d.	Low-load design concept	Adaptation of the process control and related equipment to maintain good combustion efficiency when the demand in energy varies, e.g. by improving the inlet airflow control capability or by splitting the combustion process into decoupled combustion stages	The applicability may be limited by the gas turbine design	2+1 configuration (2 gas turbines and one steam turbine). LCP394 burns gas oil, therefore BAT 42 is not applicable.	
	e.	Low-NO _x burners (LNB)	See description in Section 8.3	Generally applicable to supplementary firing for heat recovery steam generators (HRSGs) in the case of combined-cycle gas turbine (CCGT) combustion plants		
	f.	Selective catalytic reduction (SCR)		Not applicable in the case of combustion plants operated < 500 h/yr. Not generally applicable to existing combustion plants of < 100 MW _{th} . Retrofitting existing combustion plants may be constrained by the availability of sufficient space. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr		
43	In order to prevent or reduce NO _x emissions to air from the combustion of natural gas in engines, BAT is to use one or a combination of the techniques given below.			N/A	Not applicable to gas turbines	
		Technique	Description			Applicability
	a.	Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr			The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system
	b.	Lean-burn concept	See description in Section 8.3. Generally used in combination with SCR			Only applicable to new gas-fired engines
	c.	Advanced lean-burn concept	See descriptions in Section 8.3	Only applicable to new spark plug ignited engines		
	d.	Selective catalytic reduction (SCR)		Retrofitting existing combustion plants may be constrained by the availability of sufficient space. Not applicable to combustion plants operated < 500 h/yr.		

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																																																		
	<table border="1"> <tr> <td data-bbox="338 387 546 475"></td> <td data-bbox="546 387 1010 475"></td> <td data-bbox="1010 387 1496 475">There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr</td> </tr> </table>			There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr																																																	
		There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr																																																			
44	<p>In order to prevent or reduce CO emissions to air from the combustion of natural gas, BAT is to ensure optimised combustion and/or to use oxidation catalysts.</p> <p>Description - See descriptions in Section 8.3.</p> <p>BAT-associated emission levels (BAT-AELs) for NO_x emissions to air from the combustion of natural gas in gas turbines</p> <table border="1"> <thead> <tr> <th data-bbox="338 627 797 746" rowspan="2">Type of combustion plant</th> <th data-bbox="797 627 1032 746" rowspan="2">Combustion plant total rated thermal input (MW_{th})</th> <th colspan="2" data-bbox="1032 627 1496 659">BAT-AELs (mg/Nm³) ⁽¹⁴²⁾ ⁽¹⁴³⁾</th> </tr> <tr> <th data-bbox="1032 659 1256 746">Yearly average ⁽¹⁴⁴⁾ ⁽¹⁴⁵⁾</th> <th data-bbox="1256 659 1496 746">Daily average or average over the sampling period</th> </tr> </thead> <tbody> <tr> <td colspan="4" data-bbox="338 746 1496 786" style="text-align: center;">Open-cycle gas turbines (OCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁷⁾</td> </tr> <tr> <td data-bbox="338 786 797 826">New OCGT</td> <td data-bbox="797 786 1032 826">≥ 50</td> <td data-bbox="1032 786 1256 826">15–35</td> <td data-bbox="1256 786 1496 826">25–50</td> </tr> <tr> <td data-bbox="338 826 797 906">Existing OCGT (excluding turbines for mechanical drive applications) — All but plants operated < 500 h/yr</td> <td data-bbox="797 826 1032 906">≥ 50</td> <td data-bbox="1032 826 1256 906">15–50</td> <td data-bbox="1256 826 1496 906">25–55 ⁽¹⁴⁸⁾</td> </tr> <tr> <td colspan="4" data-bbox="338 906 1496 946" style="text-align: center;">Combined-cycle gas turbines (CCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁹⁾</td> </tr> <tr> <td data-bbox="338 946 797 986">New CCGT</td> <td data-bbox="797 946 1032 986">≥ 50</td> <td data-bbox="1032 946 1256 986">10–30</td> <td data-bbox="1256 946 1496 986">15–40</td> </tr> <tr> <td data-bbox="338 986 797 1042">Existing CCGT with a net total fuel utilisation of < 75 %</td> <td data-bbox="797 986 1032 1042">≥ 600</td> <td data-bbox="1032 986 1256 1042">10–40</td> <td data-bbox="1256 986 1496 1042">18–50</td> </tr> <tr> <td data-bbox="338 1042 797 1098">Existing CCGT with a net total fuel utilisation of ≥ 75 %</td> <td data-bbox="797 1042 1032 1098">≥ 600</td> <td data-bbox="1032 1042 1256 1098">10–50</td> <td data-bbox="1256 1042 1496 1098">18–55 ⁽¹⁵⁰⁾</td> </tr> <tr> <td data-bbox="338 1098 797 1153">Existing CCGT with a net total fuel utilisation of < 75 %</td> <td data-bbox="797 1098 1032 1153">50–600</td> <td data-bbox="1032 1098 1256 1153">10–45</td> <td data-bbox="1256 1098 1496 1153">35–55</td> </tr> <tr> <td data-bbox="338 1153 797 1225">Existing CCGT with a net total fuel utilisation of ≥ 75 %</td> <td data-bbox="797 1153 1032 1225">50–600</td> <td data-bbox="1032 1153 1256 1225">25–50 ⁽¹⁵¹⁾</td> <td data-bbox="1256 1153 1496 1225">35–55 ⁽¹⁵²⁾</td> </tr> <tr> <td colspan="4" data-bbox="338 1225 1496 1265" style="text-align: center;">Open- and combined-cycle gas turbines</td> </tr> <tr> <td data-bbox="338 1265 797 1353">Gas turbine put into operation no later than 27 November 2003, or existing gas turbine for emergency use and operated < 500 h/yr</td> <td data-bbox="797 1265 1032 1353">≥ 50</td> <td data-bbox="1032 1265 1256 1353">No BAT-AEL</td> <td data-bbox="1256 1265 1496 1353">60–140 ⁽¹⁵³⁾ ⁽¹⁵⁴⁾</td> </tr> </tbody> </table>	Type of combustion plant	Combustion plant total rated thermal input (MW _{th})	BAT-AELs (mg/Nm ³) ⁽¹⁴²⁾ ⁽¹⁴³⁾		Yearly average ⁽¹⁴⁴⁾ ⁽¹⁴⁵⁾	Daily average or average over the sampling period	Open-cycle gas turbines (OCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁷⁾				New OCGT	≥ 50	15–35	25–50	Existing OCGT (excluding turbines for mechanical drive applications) — All but plants operated < 500 h/yr	≥ 50	15–50	25–55 ⁽¹⁴⁸⁾	Combined-cycle gas turbines (CCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁹⁾				New CCGT	≥ 50	10–30	15–40	Existing CCGT with a net total fuel utilisation of < 75 %	≥ 600	10–40	18–50	Existing CCGT with a net total fuel utilisation of ≥ 75 %	≥ 600	10–50	18–55 ⁽¹⁵⁰⁾	Existing CCGT with a net total fuel utilisation of < 75 %	50–600	10–45	35–55	Existing CCGT with a net total fuel utilisation of ≥ 75 %	50–600	25–50 ⁽¹⁵¹⁾	35–55 ⁽¹⁵²⁾	Open- and combined-cycle gas turbines				Gas turbine put into operation no later than 27 November 2003, or existing gas turbine for emergency use and operated < 500 h/yr	≥ 50	No BAT-AEL	60–140 ⁽¹⁵³⁾ ⁽¹⁵⁴⁾	CC	<p>CO emissions are reduced as far as possible by optimising combustion.</p> <p>For LCP 272 and LCP 273, the Operator confirms that the CO indicative yearly average of 30 mg/Nm³ for existing CCGTs will be met above the E-DLN.</p> <p>As an existing CCGT plant, operating with unlimited hours, with a thermal input >600 MW_{th} and a net fuel utilisation of <75% the applicable NO_x BAT-AELs are 40 mg/m³ (annually) and 50 mg/m³ (daily). These limits are applicable when the DLN system is fully effective.</p> <p>The existing permit also sets monthly, daily and hourly average emission limits for CO and NO_x. Under the principal of “no backsliding”, the current emission limits will be retained unless tighter limits are set by the BREF.</p> <p>LCP394 burns gas oil, therefore BAT 44 is not applicable.</p>
Type of combustion plant	Combustion plant total rated thermal input (MW _{th})			BAT-AELs (mg/Nm ³) ⁽¹⁴²⁾ ⁽¹⁴³⁾																																																	
		Yearly average ⁽¹⁴⁴⁾ ⁽¹⁴⁵⁾	Daily average or average over the sampling period																																																		
Open-cycle gas turbines (OCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁷⁾																																																					
New OCGT	≥ 50	15–35	25–50																																																		
Existing OCGT (excluding turbines for mechanical drive applications) — All but plants operated < 500 h/yr	≥ 50	15–50	25–55 ⁽¹⁴⁸⁾																																																		
Combined-cycle gas turbines (CCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁹⁾																																																					
New CCGT	≥ 50	10–30	15–40																																																		
Existing CCGT with a net total fuel utilisation of < 75 %	≥ 600	10–40	18–50																																																		
Existing CCGT with a net total fuel utilisation of ≥ 75 %	≥ 600	10–50	18–55 ⁽¹⁵⁰⁾																																																		
Existing CCGT with a net total fuel utilisation of < 75 %	50–600	10–45	35–55																																																		
Existing CCGT with a net total fuel utilisation of ≥ 75 %	50–600	25–50 ⁽¹⁵¹⁾	35–55 ⁽¹⁵²⁾																																																		
Open- and combined-cycle gas turbines																																																					
Gas turbine put into operation no later than 27 November 2003, or existing gas turbine for emergency use and operated < 500 h/yr	≥ 50	No BAT-AEL	60–140 ⁽¹⁵³⁾ ⁽¹⁵⁴⁾																																																		

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																											
	<table border="1" data-bbox="338 384 1494 472"> <tr> <td data-bbox="338 384 792 472">Existing gas turbine for mechanical drive applications — All but plants operated < 500 h/yr</td> <td data-bbox="792 384 1032 472">≥ 50</td> <td data-bbox="1032 384 1256 472">15–50 ⁽¹⁵⁵⁾</td> <td data-bbox="1256 384 1494 472">25–55 ⁽¹⁵⁶⁾</td> </tr> </table> <p data-bbox="338 472 1494 528">As an indication, the yearly average CO emission levels for each type of existing combustion plant operated ≥ 1 500 h/yr and for each type of new combustion plant will generally be as follows:</p> <ul data-bbox="338 528 1494 903" style="list-style-type: none"> — New OCGT of ≥ 50 MW_{th}: < 5–40 mg/Nm³. For plants with a net electrical efficiency (EE) greater than 39 %, a correction factor may be applied to the higher end of this range, corresponding to [higher end] × EE/39, where EE is the net electrical energy efficiency or net mechanical energy efficiency of the plant determined at ISO baseload conditions. — Existing OCGT of ≥ 50 MW_{th} (excluding turbines for mechanical drive applications): < 5–40 mg/Nm³. The higher end of this range will generally be 80 mg/Nm³ in the case of existing plants that cannot be fitted with dry techniques for NO_x reduction, or 50 mg/Nm³ for plants that operate at low load. — New CCGT of ≥ 50 MW_{th}: < 5–30 mg/Nm³. For plants with a net electrical efficiency (EE) greater than 55 %, a correction factor may be applied to the higher end of the range, corresponding to [higher end] × EE/55, where EE is the net electrical energy efficiency of the plant determined at ISO baseload conditions. — Existing CCGT of ≥ 50 MW_{th}: < 5–30 mg/Nm³. The higher end of this range will generally be 50 mg/Nm³ for plants that operate at low load. — Existing gas turbines of ≥ 50 MW_{th} for mechanical drive applications: < 5–40 mg/Nm³. The higher end of the range will generally be 50 mg/Nm³ when plants operate at low load. <p data-bbox="338 903 1494 959">In the case of a gas turbine equipped with DLN burners, these indicative levels correspond to when the DLN operation is effective.</p> <p data-bbox="338 959 1494 1015">BAT-associated emission levels (BAT-AELs) for NO_x emissions to air from the combustion of natural gas in boilers and engines</p> <table border="1" data-bbox="338 1015 1494 1238"> <thead> <tr> <th data-bbox="338 1015 622 1174" rowspan="3">Type of combustion plant</th> <th colspan="4" data-bbox="622 1015 1494 1046">BAT-AELs (mg/Nm³)</th> </tr> <tr> <th colspan="2" data-bbox="622 1046 972 1110">Yearly average ⁽¹⁵⁷⁾</th> <th colspan="2" data-bbox="972 1046 1494 1110">Daily average or average over the sampling period</th> </tr> <tr> <th data-bbox="622 1110 763 1174">New plant</th> <th data-bbox="763 1110 972 1174">Existing plant ⁽¹⁵⁸⁾</th> <th data-bbox="972 1110 1180 1174">New plant</th> <th data-bbox="1180 1110 1494 1174">Existing plant ⁽¹⁵⁹⁾</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 1174 622 1206">Boiler</td> <td data-bbox="622 1174 763 1206">10–60</td> <td data-bbox="763 1174 972 1206">50–100</td> <td data-bbox="972 1174 1180 1206">30–85</td> <td data-bbox="1180 1174 1494 1206">85–110</td> </tr> <tr> <td data-bbox="338 1206 622 1238">Engine ⁽¹⁶⁰⁾</td> <td data-bbox="622 1206 763 1238">20–75</td> <td data-bbox="763 1206 972 1238">20–100</td> <td data-bbox="972 1206 1180 1238">55–85</td> <td data-bbox="1180 1206 1494 1238">55–110 ⁽¹⁶¹⁾</td> </tr> </tbody> </table> <p data-bbox="338 1238 1494 1278">As an indication, the yearly average CO emission levels will generally be:</p> <ul data-bbox="338 1278 1494 1394" style="list-style-type: none"> — < 5–40 mg/Nm³ for existing boilers operated ≥ 1 500 h/yr, — < 5–15 mg/Nm³ for new boilers, — 30–100 mg/Nm³ for existing engines operated ≥ 1 500 h/yr and for new engines. 	Existing gas turbine for mechanical drive applications — All but plants operated < 500 h/yr	≥ 50	15–50 ⁽¹⁵⁵⁾	25–55 ⁽¹⁵⁶⁾	Type of combustion plant	BAT-AELs (mg/Nm ³)				Yearly average ⁽¹⁵⁷⁾		Daily average or average over the sampling period		New plant	Existing plant ⁽¹⁵⁸⁾	New plant	Existing plant ⁽¹⁵⁹⁾	Boiler	10–60	50–100	30–85	85–110	Engine ⁽¹⁶⁰⁾	20–75	20–100	55–85	55–110 ⁽¹⁶¹⁾		
Existing gas turbine for mechanical drive applications — All but plants operated < 500 h/yr	≥ 50	15–50 ⁽¹⁵⁵⁾	25–55 ⁽¹⁵⁶⁾																											
Type of combustion plant	BAT-AELs (mg/Nm ³)																													
	Yearly average ⁽¹⁵⁷⁾		Daily average or average over the sampling period																											
	New plant	Existing plant ⁽¹⁵⁸⁾	New plant	Existing plant ⁽¹⁵⁹⁾																										
Boiler	10–60	50–100	30–85	85–110																										
Engine ⁽¹⁶⁰⁾	20–75	20–100	55–85	55–110 ⁽¹⁶¹⁾																										

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
45	In order to reduce non-methane volatile organic compounds (NMVOC) and methane (CH ₄) emissions to air from the combustion of natural gas in spark-ignited lean-burn gas engines, BAT is to ensure optimised combustion and/or to use oxidation catalysts.	N/A	Not applicable

6. Emissions to Water

The consolidated permit incorporates the existing surface water discharges to controlled waters identified as RD1 to RD3 on site plan in schedule 7 of the permit. Emission to the River Great Ouse.

There are no BAT AELs specified in the BAT Conclusions for this type of plant. There are also no additional treatment options identified as BAT for the installation. We have therefore not carried out any additional assessment of the emissions to water as part of this review.

8 Additional IED Chapter II requirements:

Plant efficiency:

The BAT for balancing plant guidance ((working draft version 1.0, August 2018) sets out additional restrictions on hours for <1500 hour non-emergency plant which are low efficiency. Table 1 of the guidance sets out categories for LCP peaking plant.

LCP 394 falls into category B because it's NOx emissions are below 500mg/m³ and its efficiency, at 28.4%, is above that set out in table 2 of the guidance for this type of plant. Table 1 therefore confirms that there are no additional restrictions applied to the hours of operation.

Black start:

In the event of a black out National Grid would call on combustion plant to operate and may require them to do so outside their permitted conditions. We have dedicated black start plant and they are permitted to run as such but this scenario is relevant to the rest of the large combustion plant which could be called depending on the circumstances.

A risk assessment will be carried out by Energy UK/Joint Environmental Programme on behalf of Large Combustion Plant connected to the National Transmission System. Air emissions modelling will be based on generic black start scenarios to establish whether they have the potential to have local impact on the environment or not (on a national basis). If the modelling demonstrates that no significant impacts are likely, the plant can operate under condition 2.3.9. This conditions allows the hourly ELVs for plants operating under a black start instruction to be discounted for the purpose of reporting. We would also require there to be a procedure in place for minimisation of emissions in the case of a black start event and for reporting in the event of a black start. This modelling and the procedures have not been agreed in advance of the issue of the permit review and therefore a condition linking back to an improvement condition has been included in the permit.

9 Review and assessment of changes that are not part of the BAT Conclusions derived permit review.

This document should be read in conjunction with the application, supporting information and notice.

Aspect considered	Decision
Receipt of application	
Confidential information	A claim for commercial or industrial confidentiality has not been made.
Identifying confidential information	We have not identified information provided as part of the application that we consider to be confidential. The decision was taken in accordance with our guidance on confidentiality.
The site	
Biodiversity, heritage, landscape and nature conservation	The application is within the relevant distance criteria of a site of heritage, landscape or nature conservation, and/or protected species or habitat. A full assessment of the application and its potential to affect the site(s)/species/habitat has not been carried out as part of the permit review process. We consider that the review will not affect the features of the site(s)/species/habitat as the conditions will provide at least the same level of protection as those in the previous permit and in some cases will provide a higher level of protection to those in the previous permit. We have not consulted Natural England on the application. The decision was taken in accordance with our guidance.
Operating techniques	
General operating techniques	We have reviewed the techniques used by the operator where they are relevant to the BAT Conclusions and compared these with the relevant guidance notes. The permit conditions ensure compliance with the relevant BREF, BAT Conclusions. The ELVs deliver compliance with the BAT-AELs.
Permit conditions	
Updating permit conditions during consolidation	We have updated permit conditions to those in the current generic permit template as part of permit consolidation. The conditions will provide at least the same level of protection as those in the previous permit and in some cases will provide a higher level of protection to those in the previous permit.

Aspect considered	Decision
Changes to the permit conditions due to an Environment Agency initiated variation	We have varied the permit as stated in the variation notice.
Improvement programme	<p>We have removed the completed improvement conditions from the permit improvement conditions 1 to 14 (IC1 to IC14).</p> <p>We have added Improvement Condition 15 (IC15), this condition concerns black start operation. See section 8 for further information.</p>
Emission limits	<p>We have decided that emission limits should be set for the parameters listed in the permit.</p> <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p> <p>It is considered that the ELVs/equivalent parameters or technical measures described above will ensure that significant pollution of the environment is prevented and a high level of protection for the environment is secured.</p>
Monitoring	<p>We have decided that monitoring should be carried out for the parameters listed in the permit, using the methods detailed and to the frequencies specified.</p> <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p> <p>Table S3.4 Process monitoring requirements was amended to include the requirement to monitor energy efficiency after overhauls on site in line with BAT2.</p> <p>Based on the information in the application we are [not fully] satisfied that the operator's techniques, personnel and equipment have either MCERTS certification or MCERTS accreditation as appropriate.</p>
Reporting	<p>We have specified reporting in the permit for the following parameters:</p> <ul style="list-style-type: none"> • Nitrogen dioxide • Carbon monoxide • Sulphur dioxide • Dust <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p>

Aspect considered	Decision
Operator competence	
Management system	There is no known reason to consider that the operator will not have the management system to enable it to comply with the permit conditions.
Growth Duty	
Section 108 Deregulation Act 2015 – Growth duty	<p>We have considered our duty to have regard to the desirability of promoting economic growth set out in section 108(1) of the Deregulation Act 2015 and the guidance issued under section 110 of that Act in deciding whether to grant this permit.</p> <p>Paragraph 1.3 of the guidance says:</p> <p>“The primary role of regulators, in delivering regulation, is to achieve the regulatory outcomes for which they are responsible. For a number of regulators, these regulatory outcomes include an explicit reference to development or growth. The growth duty establishes economic growth as a factor that all specified regulators should have regard to, alongside the delivery of the protections set out in the relevant legislation.”</p> <p>We have addressed the legislative requirements and environmental standards to be set for this operation in the body of the decision document above. The guidance is clear at paragraph 1.5 that the growth duty does not legitimise non-compliance and its purpose is not to achieve or pursue economic growth at the expense of necessary protections.</p> <p>We consider the requirements and standards we have set in this permit are reasonable and necessary to avoid a risk of an unacceptable level of pollution. This also promotes growth amongst legitimate operators because the standards applied to the operator are consistent across businesses in this sector and have been set to achieve the required legislative standards.</p>