

## Environment Agency

# Review of an Environmental Permit for an Installation subject to Chapter II of the Industrial Emissions Directive under the Environmental Permitting (England & Wales) Regulations 2016

## Decision document recording our decision-making process following review of a permit

The Permit number is:                   EPR/FP3835LS

The Operator is:                         Sutton Bridge Power Generation

The Installation is:                     Sutton Bridge Power Station, Centenary  
Way, Sutton Bridge, Spalding, Lincolnshire,  
PE12 9TF

This Variation Notice number is: EPR/FP3835LS/V006

### What this document is about

Article 21(3) of the Industrial Emissions Directive (IED) requires the Environment Agency to review conditions in permits that it has issued and to ensure that the permit delivers compliance with relevant standards, within four years of the publication of updated decisions on best available techniques (BAT) conclusions.

We have reviewed the permit for this installation against the revised BAT Conclusions for large combustion plant published on 17<sup>th</sup> August 2017. This is our decision document, which explains the reasoning for the consolidated variation notice that we are issuing.

It explains how we have reviewed and considered the techniques used by the Operator in the operation and control of the plant and activities of the installation. This review has been undertaken with reference to the decision made by the European Commission establishing best available techniques (BAT) conclusions ('BAT Conclusions') for large combustion plant as detailed in document reference IEDC-7-1. It is our record of our decision-making process and shows how we have taken into account all relevant factors in reaching our position. It also provides a justification for the inclusion of any specific conditions in the permit that are in addition to those included in our generic permit template.

As well as considering the review of the operating techniques used by the Operator for the operation of the plant and activities of the installation, the consolidated variation notice takes into account and brings together in a single document all previous variations that relate to the original permit issued. It also modernises the entire permit to reflect the conditions contained in our current generic permit template.

The introduction of new template conditions makes the Permit consistent with our current general approach and philosophy and with other permits issued to installations in this sector. Although the wording of some conditions has changed, while others have been removed because of the new regulatory approach, it does not reduce the level of environmental protection achieved by the Permit in any way. In this document we therefore address only our determination of substantive issues relating to the new BAT Conclusions.

This is our record of our decision-making process and shows how we have taken into account all relevant factors in reaching our position.

Throughout this document we will use a number of expressions. These are as referred to in the glossary and have the same meaning as described in “Schedule 6 Interpretation” of the Permit.

We try to explain our decision as accurately, comprehensively and plainly as possible. We would welcome any feedback as to how we might improve our decision documents in future. A lot of technical terms and acronyms are inevitable in a document of this nature: we provide a glossary of acronyms near the front of the document, for ease of reference.

## How this document is structured

### Glossary of terms

- 1 Our decision
- 2 How we reached our decision
  - 2.1 Requesting information to demonstrate compliance with BAT Conclusions for Large Combustion Plant
  - 2.2 Review of our own information in respect to the capability of the installation to meet revised standards included in the BAT Conclusions document
- 3 The legal framework
- 4 Key Issues
  - 4.1 Emissions to air and the emission limits applied to the plant
  - 4.2 The energy efficiency levels associated with the Best Available Techniques Conclusions
- 5 Decision checklist regarding relevant BAT Conclusions
- 6 Emissions to Water
- 7 Additional IED Chapter II requirements
- 8 Review and assessment of changes that are not part of the BAT Conclusions derived permit review.

## Glossary of acronyms used in this document

(Please note that this glossary is standard for our decision documents and therefore not all these acronyms are necessarily used in this document.)

APC	Air Pollution Control
BAT	Best Available Technique(s)
BAT-AEL	BAT Associated Emission Level
BATc	BAT conclusion
BREF	Best available techniques reference document
CCGT	Combined Cycle Gas Turbine
CEM	Continuous emissions monitor
CHP	Combined heat and power
CROW	Countryside and rights of way Act 2000
CV	Calorific value
DAA	Directly associated activity – Additional activities necessary to be carried out to allow the principal activity to be carried out
Derogation	from BAT AELs stated in BAT Conclusions under specific circumstances as detailed under Article 15(4) of IED where an assessment shows that the achievement of emission levels associated with the best available techniques as described in BAT conclusions would lead to disproportionately higher costs
DLN	Dry Low NOx
DLN-E	Dry Low NOx effective
EIONET	European environment information and observation network is a partnership network of the European Environment Agency
ELV	Emission limit value derived under BAT or an emission limit value set out in IED
EMS	Environmental Management System
EPR	Environmental Permitting (England and Wales) Regulations 2016 (SI 2010 No. 1154)
EWG	European waste catalogue
FSA	Food Standards Agency
IED	Industrial Emissions Directive (2010/75/EU)
IPPCD	Integrated Pollution Prevention and Control Directive (2008/1/EC) – now superseded by IED
LCP	Large Combustion Plant subject to Chapter III of IED
MSUL/MSDL	Minimum start up load/minimum shut-down load
NOx	Oxides of nitrogen (NO plus NO <sub>2</sub> expressed as NO <sub>2</sub> )
NPV	Net Present Value
PHE	Public Health England
PPS	Public participation statement
SAC	Special Area of Conservation
SGN	Sector guidance note
TGN	Technical guidance note
TOC	Total Organic Carbon
WFD	Water Framework Directive (2000/60/EC)

## 1 Our decision

We have decided to issue the consolidated variation notice to the Operator. This will allow it to continue to operate the Installation, subject to the conditions in the consolidated variation notice.

We consider that, in reaching that decision, we have taken into account all relevant considerations and legal requirements and that the varied permit will ensure that a high level of protection is provided for the environment and human health.

The consolidated variation notice contains many conditions taken from our standard Environmental Permit template including the relevant Annexes. We developed these conditions in consultation with industry, having regard to the legal requirements of the Environmental Permitting Regulations and other relevant legislation. This document does not therefore include an explanation for these standard conditions. Where they are included in the Notice, we have considered the techniques identified by the operator for the operation of their installation, and have accepted that the details are sufficient and satisfactory to make those standard conditions appropriate. This document does, however, provide an explanation of our use of “tailor-made” or installation-specific conditions, or where our Permit template provides two or more options.

## 2 How we reached our decision

### 2.1 Requesting information to demonstrate compliance with BAT Conclusions for Large Combustion Plant

We issued a Notice under Regulation 61(1) of the Environmental Permitting (England and Wales) Regulations 2016 (a Regulation 61 Notice) on 01/05/18 requiring the Operator to provide information to demonstrate how the operation of their installation currently meets, or will subsequently meet, the revised standards described in the large combustion plant BAT Conclusions document. The Notice also required that where the revised standards are not currently met, the operator should provide information that:

- Describes the techniques that will be implemented before 17<sup>th</sup> August 2021, which will then ensure that operations meet the revised standard, or
- Justifies why standards will not be met by 17<sup>th</sup> August 2021, and confirmation of the date when the operation of those processes will cease within the installation or an explanation of why the revised BAT standard is not applicable to those processes, or
- Justifies why an alternative technique will achieve the same level of environmental protection equivalent to the revised standard described in the BAT Conclusions.

Where the Operator proposed that they were not intending to meet a BAT standard that also included a BAT Associated Emission Level (BAT AEL) described in the BAT Conclusions Document, the Regulation 61 Notice requested that the Operator make a formal request for derogation from compliance with that AEL (as provisioned by Article 15(4) of IED). In this circumstance, the Notice identified that any such request for derogation must be supported and justified by sufficient technical and commercial information that would enable us to determine acceptability of the derogation request.

The Regulation 61 Notice response from the Operator was received on 01/11/18. We considered it was in the correct form and contained sufficient information for us to begin our determination of the permit review but not that it necessarily contained all the information we would need to complete that review: see below.

We issued a further information request to the Operator on 25/02/19. Suitable further information was provided by the Operator on 05/03/19, 06/03/19 and 12/03/19.

We have not received any information in relation to the Regulation 61(1) Notice response that appears to be confidential in relation to any party.

## **2.2 Review of our own information in respect to the capability of the installation to meet revised standards included in the BAT Conclusions document**

Based on our records and previous regulatory activities with the facility we have no reason to consider that the operator will not be able to comply with the conditions that we include in the permit.

### 3 The legal framework

The consolidated variation notice will be issued under Regulation 20 of the EPR. The Environmental Permitting regime is a legal vehicle which delivers most of the relevant legal requirements for activities falling within its scope. In particular, the regulated facility is:

- an *installation* as described by the IED;
- subject to aspects of other relevant legislation which also have to be addressed.

We consider that the consolidated variation notice will ensure that the operation of the Installation complies with all relevant legal requirements and that a high level of protection will be delivered for the environment and human health.

We explain how we have addressed specific statutory requirements more fully in the rest of this document.



## 4 The key issues

The key issues arising during this permit review are:

- Emissions to air and the emission limits applied to the plant.
- The energy efficiency levels associated with the Best Available Techniques (BAT-AEELs)

We therefore describe how we determined these issues in most detail in the relevant sections of this document.

### 4.1 Emissions to air and the emission limits applied to the plant

A number of general principles were applied during the permit review. These included:

- The upper value of the BAT AELs ranges specified were used unless use of the tighter limit was justified.
- The principle of no backsliding where if existing limits in the permit were already tighter than those specified in the BREF, the existing permit limits were retained.
- Where a limit was specified in both IED Annex V and the BAT Conclusions for a particular reference period, the tighter limit was applied and in the majority of cases this was from the BAT Conclusions.
- Where AELs are indicative in the BAT Conclusions, these were applied unless adequate justification was provided by the operator to demonstrate that an alternative limit was more appropriate.
- For gas turbines where the IED specified that limits applied over 70% load and the BAT Conclusions specified that AELs applied when dry low NO<sub>x</sub> is effective (DLN-E), we have used DLN-E as a default across all monitoring requirements for NO<sub>x</sub> and CO.

The LCPs on site consist of LCP 128 a 743 MWth Combined Cycle Natural Gas Turbine and LCP 129 a 743 MWth Combined Cycle Natural Gas Turbine.

The plant was put into operation before IED came into force and therefore the existing limits in the permit are from Part 1 of Annex V applicable to existing/new plant.

The ELVs and AELs are based on the following operating regime:

- Unlimited hours operation

The following table outlines the limits that have been incorporated into the permit for LCP 128 and LCP 129, where these were derived from and the reference periods at which they apply. The emission limits refer to concentrations, expressed as mass of emitted substance per volume of flue-

gas under the following standard conditions: dry gas at a temperature of 273,15 K, pressure of 101,3 kPa and 15% volume reference oxygen concentration if flue gases.

The emission limits and monitoring requirements have been incorporated into Schedule 3 of the permit. The emissions limits have been set at Effective Dry Low NO<sub>x</sub> to baseload with MSUL to baseload also included for all daily limits. The definition for both of these are the same and are defined in tables S1.4 and S1.5. The inclusion of both definitions is to ensure consistency between all permits.

NO <sub>x</sub> limits (mg/Nm <sup>3</sup> )						
Averaging	IED (Annex V Part 1) - Existing	BREF (table 24 BAT-c)	Expected permit limits	Basis	Limits apply	Monitoring
Annual	None	40	40	BREF	E-DLN	Continuous
Monthly	50	None	50	IED	E-DLN	
Daily	55	50	50	BREF	E-DLN and MSUL/MSDL	
95 <sup>th</sup> %ile of hr means	100	None	100	IED	E-DLN	

CO limits (mg/Nm <sup>3</sup> )						
Averaging	IED (Annex V Part 1) - Existing	BREF (after table 24 BAT-c)	Expected permit limits	Basis	Limits apply	Monitoring
Annual	None	30	30	BREF	E-DLN	Continuous
Monthly	100	None	100	IED	E-DLN	
Daily	110	None	110	IED	E-DLN and MSUL/MSDL	
95 <sup>th</sup> %ile of hr means	200	None	200	IED	E-DLN	

#### 4.2 The energy efficiency levels associated with the Best Available Techniques Conclusions

An energy efficiency level associated with the best available techniques (BAT-AEEL) refers to the ratio between the combustion unit's net energy output(s) and the combustion unit's fuel/feedstock energy input at actual unit design. The net energy output(s) is determined at the combustion unit boundaries, including auxiliary systems (e.g. flue-gas treatment systems), and for the unit operated at full load.

The table below sets out the AEELs specified in the BAT Conclusions for the large combustion plant on the site and the energy efficiency levels confirmed

through the Regulation 61 notice response. The evidence provided to demonstrate that the AEELs are met was in the form of a commissioning report which assessed the energy efficiency of the plant following a technical upgrade completed on July 2016:

*‘Combined Cycle Thermal Performance Test Report: Calon Energy – Sutton Bridge Power Station, Sutton Bridge, United Kingdom’. GE Power, 19 December 2017).*

We consider this plant is BAT in relation to the AEELs.

BAT AEELs (%)			Plant efficiency (%)		
Net electrical efficiency	Net total fuel utilisation	Net mechanical efficiency	Net electrical efficiency	Net total fuel utilisation	Net mechanical efficiency
LCP:128 and 129 unit description from the AEEL table					
50 - 60	None	None	56.8%	NA	NA

## 5 Decision checklist regarding relevant BAT Conclusions

BAT Conclusions for large combustion plant, were published by the European Commission on 17<sup>th</sup> August 2017. There are 75 BAT Conclusions. Only the BAT Conclusions relevant to the particular fuel type used on site have been replicated below.

This annex provides a record of decisions made in relation to each relevant BAT Conclusion applicable to the installation. This annex should be read in conjunction with the Consolidated Variation Notice.

The conditions in the permit through which the relevant BAT Conclusions are implemented include but are not limited to the following:

BAT Conclusion requirement topic	Permit condition(s)	Permit table(s)
Environmental Management System	1.1.1	S1.2
BAT AELs	3.1.1 and 3.5.1	S3.1a
Monitoring	2.3, 3.5 and 3.6	S1.4, S1.5, S1.2, S3.1a
Energy efficiency	1.2 and 2.3	S3.3
Noise	3.4 and 2.3	S2.1
Other operating techniques	2.3	S1.2

The overall status of compliance with the BAT conclusion is indicated in the table as:

- NA Not Applicable
- CC Currently Compliant
- FC Compliant in the future (within 4 years of publication of BAT conclusions)
- NC Not Compliant
- PC Partially Compliant

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
<b>General</b>			
1	<p><b>In order to improve the overall environmental performance, BAT is to implement and adhere to an environmental management system (EMS) that incorporates all of the following features:</b></p> <ul style="list-style-type: none"> <li>i. commitment of the management, including senior management;</li> <li>ii. definition of an environmental policy that includes the continuous improvement of the installation by the management;</li> <li>iii. planning and establishing the necessary procedures, objectives and targets, in conjunction with financial planning and investment;</li> <li>iv. implementation of procedures <ul style="list-style-type: none"> <li>(a) Structure and responsibility</li> <li>(b) Training</li> <li>(c) Communication</li> <li>(d) Employee involvement</li> <li>(e) Documentation</li> <li>(f) Efficient process control</li> <li>(g) Maintenance programmes</li> <li>(h) Emergency preparedness and response</li> <li>(i) Safeguarding compliance with environmental legislation</li> </ul> </li> <li>v. checking performance and taking corrective action, paying particular attention to: <ul style="list-style-type: none"> <li>(a) monitoring and measurement (see also the Reference Document on the General Principles of Monitoring)</li> <li>(b) corrective and preventive action</li> <li>(c) maintenance of records</li> <li>(d) independent (where practicable) internal and external auditing in order to determine whether or not the EMS conforms to planned arrangements and has been properly implemented and maintained;</li> </ul> </li> <li>vi. review of the EMS and its continuing suitability, adequacy and effectiveness by senior management;</li> <li>vii. following the development of cleaner technologies;</li> <li>viii. consideration for the environmental impacts from the eventual decommissioning of the installation at the stage of designing a new plant, and throughout its operating life;</li> <li>viii. consideration for the environmental impacts from the eventual decommissioning of the installation at the stage of designing a new plant, and throughout its operating life;</li> <li>ix. application of sectoral benchmarking on a regular basis.</li> </ul> <p>Etc - see BAT Conclusions</p>	CC	<p>The installation has an Environment Management System (EMS) certified in accordance with ISO 14001:2015. This is subject to an annual audit.</p> <p>All of the features set out under BAT 1 numbered (i-ix) have been confirmed by the operator as being incorporated into the EMS.</p>

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement												
	<p><b>Applicability.</b> The scope (e.g. level of detail) and nature of the EMS (e.g. standardised or non-standardised) will generally be related to the nature, scale and complexity of the installation, and the range of environmental impacts it may have.</p>														
2	<p>BAT is to determine the net electrical efficiency and/or the net total fuel utilisation and/or the net mechanical energy efficiency of the gasification, IGCC and/or combustion units by carrying out a performance test at full load (1), according to EN standards, after the commissioning of the unit and after each modification that could significantly affect the net electrical efficiency and/or the net total fuel utilisation and/or the net mechanical energy efficiency of the unit. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.</p>	CC	<p>Following a technical upgrade to the plant which was completed in July 2016 the thermal performance of the plant was tested. The tests were undertaken in accordance with ASME PTC 46-1996. The results were presented to the Environment Agency in the report: <i>'Combined Cycle Thermal Performance Test Report: Calon Energy – Sutton Bridge Power Station, Sutton Bridge, United Kingdom'. GE Power, 19 December 2017'</i></p>												
3	<p><b>BAT is to monitor key process parameters relevant for emissions to air and water including those given below.</b></p> <table border="1" data-bbox="349 933 1395 1182"> <thead> <tr> <th data-bbox="349 933 674 970">Stream</th> <th data-bbox="678 933 1061 970">Parameter(s)</th> <th data-bbox="1066 933 1395 970">Monitoring</th> </tr> </thead> <tbody> <tr> <td data-bbox="349 973 674 1125" rowspan="3">Flue-gas</td> <td data-bbox="678 973 1061 1029">Flow</td> <td data-bbox="1066 973 1395 1029">Periodic or continuous determination</td> </tr> <tr> <td data-bbox="678 1032 1061 1088">Oxygen content, temperature, and pressure</td> <td data-bbox="1066 1032 1395 1088" rowspan="2">Periodic or continuous measurement</td> </tr> <tr> <td data-bbox="678 1091 1061 1125">Water vapour content (%)</td> </tr> <tr> <td data-bbox="349 1128 674 1182">Waste water from flue-gas treatment</td> <td data-bbox="678 1128 1061 1182">Flow, pH, and temperature</td> <td data-bbox="1066 1128 1395 1182">Continuous measurement</td> </tr> </tbody> </table>	Stream	Parameter(s)	Monitoring	Flue-gas	Flow	Periodic or continuous determination	Oxygen content, temperature, and pressure	Periodic or continuous measurement	Water vapour content (%)	Waste water from flue-gas treatment	Flow, pH, and temperature	Continuous measurement	CC	<p>Oxygen and water vapour content, monitoring is undertaken in accordance with BS EN 14181:2014.</p> <p>For stack temperature and stack gas temperature and stack gas pressure, monitoring is traceable to national standards. Flow is measured by an independent orifice flow meter.</p> <p>These reporting requirements are stipulated in the permit.</p>
Stream	Parameter(s)	Monitoring													
Flue-gas	Flow	Periodic or continuous determination													
	Oxygen content, temperature, and pressure	Periodic or continuous measurement													
	Water vapour content (%)														
Waste water from flue-gas treatment	Flow, pH, and temperature	Continuous measurement													
4	<p>BAT is to monitor emissions to air with at least the frequency given below and in accordance with EN standards. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.</p>	CC	<p>For gas fired turbines, BAT is to monitor Nitrogen Oxides and Carbon Monoxide.</p>												

BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement									
Substance /Parameter	Fuel/Process/Type of combustion plant	Combustion plant total rated thermal input	Standard(s) (4)	Minimum monitoring frequency (5)	Monitoring associated with												
NH <sub>3</sub>	— When SCR and/or SNCR is used	All sizes	Generic EN standards	Continuous (6) (7)	BAT 7			<p>Monitoring of NO<sub>x</sub> and CO is undertaken on a continuous basis. The frequency of monitoring is in accordance with the BAT Conclusions.</p> <p>For NO<sub>x</sub> and CO, monitoring is undertaken in accordance with BS EN 14181:2014 ('Stationary Source Emissions: Quality Assurance of Automated Measuring Systems').</p>									
NO <sub>x</sub>	<ul style="list-style-type: none"> <li>— Coal and/or lignite including waste co-incineration</li> <li>— Solid biomass and/or peat including waste co-incineration</li> <li>— HFO- and/or gas-oil-fired boilers and engines</li> <li>— Gas-oil-fired gas turbines</li> <li>— Natural-gas-fired boilers, engines, and turbines</li> <li>— Iron and steel process gases</li> <li>— Process fuels from the chemical industry</li> <li>— IGCC plants</li> </ul>	All sizes	Generic EN standards	Continuous (6) (8)	BAT 20 BAT 24 BAT 28 BAT 32 BAT 37 BAT 41 BAT 42 BAT 43 BAT 47 BAT 48 BAT 56 BAT 64 BAT 65 BAT 73												
	— Combustion plants on offshore platforms	All sizes	EN 14792	Once every year (9)	BAT 53												
N <sub>2</sub> O	<ul style="list-style-type: none"> <li>— Coal and/or lignite in circulating fluidised bed boilers</li> <li>— Solid biomass and/or peat in circulating fluidised bed boilers</li> </ul>	All sizes	EN 21258	Once every year (10)	BAT 20 BAT 24												
CO	— Coal and/or lignite including waste co-incineration	All sizes	Generic EN standards	Continuous (6) (8)	BAT 20 BAT 24 BAT 28 BAT 33												

BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
		<ul style="list-style-type: none"> <li>— Solid biomass and/or peat including waste co-incineration</li> <li>— HFO- and/or gas-oil-fired boilers and engines</li> <li>— Gas-oil-fired gas turbines</li> <li>— Natural-gas-fired boilers, engines, and turbines</li> <li>— Iron and steel process gases</li> <li>— Process fuels from the chemical industry</li> <li>— IGCC plants</li> </ul>				BAT 38 BAT 44 BAT 49 BAT 56 BAT 64 BAT 65 BAT 73		
		<ul style="list-style-type: none"> <li>— Combustion plants on offshore platforms</li> </ul>	All sizes	EN 15058	Once every year <sup>(9)</sup>	BAT 54		
SO <sub>2</sub>		<ul style="list-style-type: none"> <li>— Coal and/or lignite incl waste co-incineration</li> <li>— Solid biomass and/or peat incl waste co-incineration</li> <li>— HFO- and/or gas-oil-fired boilers</li> <li>— HFO- and/or gas-oil-fired engines</li> <li>— Gas-oil-fired gas turbines</li> <li>— Iron and steel process gases</li> <li>— Process fuels from the chemical industry in boilers</li> <li>— IGCC plants</li> </ul>	All sizes	Generic EN standards and EN 14791	Continuous <sup>(6)</sup> <sup>(11)</sup> <sup>(12)</sup>	BAT 21 BAT 25 BAT 29 BAT 34 BAT 39 BAT 50 BAT 57 BAT 66 BAT 67 BAT 74		
SO <sub>3</sub>		<ul style="list-style-type: none"> <li>— When SCR is used</li> </ul>	All sizes	No EN standard available	Once every year	—		



BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	Gaseous chlorides, expressed as HCl	— Coal and/or lignite	All sizes	EN 1911	Once every three months <sub>(6)</sub> (13) (14)	BAT 21 BAT 57		
		— Process fuels from the chemical industry in boilers	All sizes	Generic EN standards	Continuous <sub>(15)</sub> (16)	BAT 25		
		— Waste co-incineration	All sizes	Generic EN standards	Continuous <sub>(6)</sub> (16)	BAT 66 BAT 67		
	HF	— Coal and/or lignite	All sizes	No EN standard available	Once every three months <sub>(6)</sub> (13) (14)	BAT 21 BAT 57		
		— Solid biomass and/or peat	All sizes	No EN standard available	Once every year	BAT 25		
		— Waste co-incineration	All sizes	Generic EN standards	Continuous <sub>(6)</sub> (16)	BAT 66 BAT 67		
	Dust	<ul style="list-style-type: none"> <li>— Coal and/or lignite</li> <li>— Solid biomass and/or peat</li> <li>— HFO- and/or gas-oil-fired boilers</li> <li>— Iron and steel process gases</li> <li>— Process fuels from the chemical industry in boilers</li> <li>— IGCC plants</li> <li>— HFO- and/or gas-oil-fired engines</li> <li>— Gas-oil-fired gas turbines</li> </ul>	All sizes	Generic EN standards and EN 13284-1 and EN 13284-2	Continuous <sub>(6)</sub> (17)	BAT 22 BAT 26 BAT 30 BAT 35 BAT 39 BAT 51 BAT 58 BAT 75		
		— Waste co-incineration	All sizes	Generic EN standards and EN 13284-2	Continuous	BAT 68 BAT 69		
		— Coal and/or lignite	All sizes	EN 14385	Once every year <sub>(18)</sub>	BAT 22		

BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	Metals and metalloids except mercury (As, Cd, Co, Cr, Cu, Mn, Ni, Pb, Sb, Se, Tl, V, Zn)	— Solid biomass and/or peat				BAT 26 BAT 30		
— HFO- and/or gas-oil-fired boilers and engines					BAT 68 BAT 69			
— Waste co-incineration		< 300 MW <sub>th</sub>	EN 14385	Once every six months <sub>(13)</sub>	BAT 68 BAT 69			
	≥ 300 MW <sub>th</sub>	EN 14385	Once every three months <sub>(19)</sub> <sub>(13)</sub>					
— IGCC plants	≥ 100 MW <sub>th</sub>	EN 14385	Once every year <sub>(18)</sub>	BAT 75				
Hg	— Coal and/or lignite including waste co-incineration	< 300 MW <sub>th</sub>	EN 13211	Once every three months <sub>(13)</sub> <sub>(20)</sub>	BAT 23			
		≥ 300 MW <sub>th</sub>	Generic EN standards and EN 14884	Continuous <sub>(16)</sub> <sub>(21)</sub>				
	— Solid biomass and/or peat	All sizes	EN 13211	Once every year <sub>(22)</sub>	BAT 27			
	— Waste co-incineration with solid biomass and/or peat	All sizes	EN 13211	Once every three months <sub>(13)</sub>	BAT 70			
	— IGCC plants	≥ 100 MW <sub>th</sub>	EN 13211	Once every year <sub>(23)</sub>	BAT 75			
TVOC	— HFO- and/or gas-oil-fired engines	All sizes	EN 12619	Once every six months <sub>(13)</sub>	BAT 33 BAT 59			
	— Process fuels from chemical industry in boilers							
— Waste co-incineration with coal, lignite, solid biomass and/or peat	All sizes	Generic EN standards	Continuous	BAT 71				
Formaldehyde	— Natural-gas in spark-ignited lean-burn gas and dual fuel engines	All sizes	No EN standard available	Once every year	BAT 45			
CH <sub>4</sub>	— Natural-gas-fired engines	All sizes	EN ISO 25139	Once every year <sub>(24)</sub>	BAT 45			

BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																																				
	PCDD/F	<ul style="list-style-type: none"> <li>— Process fuels from chemical industry in boilers</li> <li>— Waste co-incineration</li> </ul>	All sizes	EN 1948-1, EN 1948-2, EN 1948-3	Once every six months <sup>(13)</sup> <sup>(25)</sup>	BAT 59 BAT 71																																						
5	<p>BAT is to monitor emissions to water from flue-gas treatment with at least the frequency given below and in accordance with EN standards. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.</p> <table border="1" data-bbox="360 612 1386 1340"> <thead> <tr> <th data-bbox="360 612 658 699">Substance/Parameter</th> <th data-bbox="663 612 976 699">Standard(s)</th> <th data-bbox="981 612 1189 699">Minimum monitoring frequency</th> <th data-bbox="1193 612 1386 699">Monitoring associated with</th> </tr> </thead> <tbody> <tr> <td data-bbox="360 702 658 756">Total organic carbon (TOC) <sup>(26)</sup></td> <td data-bbox="663 702 976 756">EN 1484</td> <td data-bbox="981 702 1189 756" rowspan="8">Once every month</td> <td data-bbox="1193 702 1386 756" rowspan="8">BAT 15</td> </tr> <tr> <td data-bbox="360 759 658 813">Chemical oxygen demand (COD) <sup>(26)</sup></td> <td data-bbox="663 759 976 813">No EN standard available</td> </tr> <tr> <td data-bbox="360 817 658 847">Total suspended solids (TSS)</td> <td data-bbox="663 817 976 847">EN 872</td> </tr> <tr> <td data-bbox="360 850 658 880">Fluoride (F<sup>-</sup>)</td> <td data-bbox="663 850 976 880">EN ISO 10304-1</td> </tr> <tr> <td data-bbox="360 884 658 914">Sulphate (SO<sub>4</sub><sup>2-</sup>)</td> <td data-bbox="663 884 976 914">EN ISO 10304-1</td> </tr> <tr> <td data-bbox="360 917 658 971">Sulphide, easily released (S<sup>2-</sup>)</td> <td data-bbox="663 917 976 971">No EN standard available</td> </tr> <tr> <td data-bbox="360 975 658 1005">Sulphite (SO<sub>3</sub><sup>2-</sup>)</td> <td data-bbox="663 975 976 1005">EN ISO 10304-3</td> </tr> <tr> <td data-bbox="360 1008 658 1340">Metals and metalloids</td> <td data-bbox="663 1008 976 1340"> <table border="1" data-bbox="600 1008 658 1340"> <tr><td data-bbox="600 1008 658 1038">As</td></tr> <tr><td data-bbox="600 1042 658 1072">Cd</td></tr> <tr><td data-bbox="600 1075 658 1106">Cr</td></tr> <tr><td data-bbox="600 1109 658 1139">Cu</td></tr> <tr><td data-bbox="600 1142 658 1173">Ni</td></tr> <tr><td data-bbox="600 1176 658 1206">Pb</td></tr> <tr><td data-bbox="600 1209 658 1240">Zn</td></tr> <tr><td data-bbox="600 1243 658 1340">Hg</td></tr> </table>           Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)         </td> <td data-bbox="981 1008 1189 1340"></td> <td data-bbox="1193 1008 1386 1340"></td> </tr> <tr> <td data-bbox="360 1343 658 1347"></td> <td data-bbox="663 1343 976 1347"></td> <td data-bbox="981 1343 1189 1347"></td> <td data-bbox="1193 1343 1386 1347"></td> </tr> </tbody> </table>						Substance/Parameter	Standard(s)	Minimum monitoring frequency	Monitoring associated with	Total organic carbon (TOC) <sup>(26)</sup>	EN 1484	Once every month	BAT 15	Chemical oxygen demand (COD) <sup>(26)</sup>	No EN standard available	Total suspended solids (TSS)	EN 872	Fluoride (F <sup>-</sup> )	EN ISO 10304-1	Sulphate (SO <sub>4</sub> <sup>2-</sup> )	EN ISO 10304-1	Sulphide, easily released (S <sup>2-</sup> )	No EN standard available	Sulphite (SO <sub>3</sub> <sup>2-</sup> )	EN ISO 10304-3	Metals and metalloids	<table border="1" data-bbox="600 1008 658 1340"> <tr><td data-bbox="600 1008 658 1038">As</td></tr> <tr><td data-bbox="600 1042 658 1072">Cd</td></tr> <tr><td data-bbox="600 1075 658 1106">Cr</td></tr> <tr><td data-bbox="600 1109 658 1139">Cu</td></tr> <tr><td data-bbox="600 1142 658 1173">Ni</td></tr> <tr><td data-bbox="600 1176 658 1206">Pb</td></tr> <tr><td data-bbox="600 1209 658 1240">Zn</td></tr> <tr><td data-bbox="600 1243 658 1340">Hg</td></tr> </table> Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)	As	Cd	Cr	Cu	Ni	Pb	Zn	Hg							NA	There is no flue gas treatment undertaken at this installation.
Substance/Parameter	Standard(s)	Minimum monitoring frequency	Monitoring associated with																																									
Total organic carbon (TOC) <sup>(26)</sup>	EN 1484	Once every month	BAT 15																																									
Chemical oxygen demand (COD) <sup>(26)</sup>	No EN standard available																																											
Total suspended solids (TSS)	EN 872																																											
Fluoride (F <sup>-</sup> )	EN ISO 10304-1																																											
Sulphate (SO <sub>4</sub> <sup>2-</sup> )	EN ISO 10304-1																																											
Sulphide, easily released (S <sup>2-</sup> )	No EN standard available																																											
Sulphite (SO <sub>3</sub> <sup>2-</sup> )	EN ISO 10304-3																																											
Metals and metalloids	<table border="1" data-bbox="600 1008 658 1340"> <tr><td data-bbox="600 1008 658 1038">As</td></tr> <tr><td data-bbox="600 1042 658 1072">Cd</td></tr> <tr><td data-bbox="600 1075 658 1106">Cr</td></tr> <tr><td data-bbox="600 1109 658 1139">Cu</td></tr> <tr><td data-bbox="600 1142 658 1173">Ni</td></tr> <tr><td data-bbox="600 1176 658 1206">Pb</td></tr> <tr><td data-bbox="600 1209 658 1240">Zn</td></tr> <tr><td data-bbox="600 1243 658 1340">Hg</td></tr> </table> Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)			As	Cd	Cr	Cu	Ni	Pb	Zn	Hg																																	
As																																												
Cd																																												
Cr																																												
Cu																																												
Ni																																												
Pb																																												
Zn																																												
Hg																																												

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																	
	<table border="1"> <tr> <td data-bbox="360 363 656 448">Chloride (Cl<sup>-</sup>)</td> <td data-bbox="660 363 978 448">Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)</td> <td data-bbox="983 363 1189 448"></td> <td data-bbox="1193 363 1391 448">—</td> </tr> <tr> <td data-bbox="360 451 656 483">Total nitrogen</td> <td data-bbox="660 451 978 483">EN 12260</td> <td data-bbox="983 451 1189 483"></td> <td data-bbox="1193 451 1391 483">—</td> </tr> </table>	Chloride (Cl <sup>-</sup> )	Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)		—	Total nitrogen	EN 12260		—											
Chloride (Cl <sup>-</sup> )	Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)		—																	
Total nitrogen	EN 12260		—																	
6	<p>In order to improve the general environmental performance of combustion plants and to reduce emissions to air of CO and unburnt substances, BAT is to ensure optimised combustion and to use an appropriate combination of the techniques given below.</p> <table border="1"> <thead> <tr> <th data-bbox="360 595 562 627">Technique</th> <th data-bbox="566 595 952 627">Description</th> <th data-bbox="956 595 1391 627">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="360 630 562 738">a. Fuel blending and mixing</td> <td data-bbox="566 630 952 738">Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type</td> <td data-bbox="956 630 1391 738" rowspan="2">Generally applicable</td> </tr> <tr> <td data-bbox="360 742 562 821">b. Maintenance of the combustion system</td> <td data-bbox="566 742 952 821">Regular planned maintenance according to suppliers' recommendations</td> </tr> <tr> <td data-bbox="360 825 562 933">c. Advanced control system</td> <td data-bbox="566 825 952 933">See description in Section 8.1</td> <td data-bbox="956 825 1391 933">The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> <tr> <td data-bbox="360 936 562 1016">d. Good design of the combustion equipment</td> <td data-bbox="566 936 952 1016">Good design of furnace, combustion chambers, burners and associated devices</td> <td data-bbox="956 936 1391 1016">Generally applicable to new combustion plants</td> </tr> <tr> <td data-bbox="360 1019 562 1272">e. Fuel choice</td> <td data-bbox="566 1019 952 1272">Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used</td> <td data-bbox="956 1019 1391 1272">Applicable within the constraints associated with the availability of suitable types of fuel with a better environmental profile as a whole, which may be impacted by the energy policy of the Member State, or by the integrated site's fuel balance in the case of combustion of industrial process fuels. For existing combustion plants, the type of fuel chosen may be limited by the configuration and the design of the plant</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Fuel blending and mixing	Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type	Generally applicable	b. Maintenance of the combustion system	Regular planned maintenance according to suppliers' recommendations	c. Advanced control system	See description in Section 8.1	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system	d. Good design of the combustion equipment	Good design of furnace, combustion chambers, burners and associated devices	Generally applicable to new combustion plants	e. Fuel choice	Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used	Applicable within the constraints associated with the availability of suitable types of fuel with a better environmental profile as a whole, which may be impacted by the energy policy of the Member State, or by the integrated site's fuel balance in the case of combustion of industrial process fuels. For existing combustion plants, the type of fuel chosen may be limited by the configuration and the design of the plant	CC	<p>a) Fuel blending and mixing – Not applicable to natural gas-fired turbines.</p> <p>b) Maintenance of the combustion system – Regular and planned maintenance is undertaken in accordance with the original equipment manufacturers recommendations.</p> <p>c) Advanced control system – A computer-based advanced control system is in place to automatically control and optimise combustion efficiency, and support the prevention and reduction of emissions.</p> <p>Following the technical upgrade to the plant in July 2016 a monitoring system was installed referred to as 'OPFlex' to improve monitoring capabilities at the plant.</p> <p>d) The operator has confirmed that the plant is well-designed. This is reflected in the compliance with the energy efficiency BAT-AEELs.</p> <p>e) LCP 128 and LCP 129 both burn natural gas only. Natural gas does not emit particulate matter (PM<sub>10</sub>) or sulphur</p>
Technique	Description	Applicability																		
a. Fuel blending and mixing	Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type	Generally applicable																		
b. Maintenance of the combustion system	Regular planned maintenance according to suppliers' recommendations																			
c. Advanced control system	See description in Section 8.1	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system																		
d. Good design of the combustion equipment	Good design of furnace, combustion chambers, burners and associated devices	Generally applicable to new combustion plants																		
e. Fuel choice	Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used	Applicable within the constraints associated with the availability of suitable types of fuel with a better environmental profile as a whole, which may be impacted by the energy policy of the Member State, or by the integrated site's fuel balance in the case of combustion of industrial process fuels. For existing combustion plants, the type of fuel chosen may be limited by the configuration and the design of the plant																		

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
			dioxide (SO <sub>2</sub> ) associated with the combustion of other fuels.
7	<p>In order to reduce emissions of ammonia to air from the use of selective catalytic reduction (SCR) and/or selective non-catalytic reduction (SNCR) for the abatement of NO<sub>x</sub> emissions, BAT is to optimise the design and/or operation of SCR and/or SNCR (e.g. optimised reagent to NO<sub>x</sub> ratio, homogeneous reagent distribution and optimum size of the reagent drops).</p> <p><b>BAT-associated emission levels</b></p> <p>The BAT-associated emission level (BAT-AEL) for emissions of NH<sub>3</sub> to air from the use of SCR and/or SNCR is &lt; 3–10 mg/Nm<sup>3</sup> as a yearly average or average over the sampling period. The lower end of the range can be achieved when using SCR and the upper end of the range can be achieved when using SNCR without wet abatement techniques. In the case of plants combusting biomass and operating at variable loads as well as in the case of engines combusting HFO and/or gas oil, the higher end of the BAT-AEL range is 15 mg/Nm<sup>3</sup>.</p>	NA	Selective Catalytic Reduction (SCR) is not used at this installation. Nitrogen Oxide (NO <sub>x</sub> ) Emissions are controlled as part of the combustion process. Additional abatement is not required in order to meet emission limits.
8	In order to prevent or reduce emissions to air during normal operating conditions, BAT is to ensure, by appropriate design, operation and maintenance, that the emission abatement systems are used at optimal capacity and availability.	CC	Abatement equipment is not used on this site. Nitrogen Oxide (NO <sub>x</sub> ) Emissions are controlled as part of the combustion process. Additional abatement is not required in order to meet emission limits.

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																
9	<p>In order to improve the general environmental performance of combustion and/or gasification plants and to reduce emissions to air, BAT is to include the following elements in the quality assurance/quality control programmes for all the fuels used, as part of the environmental management system (see BAT 1):</p> <ul style="list-style-type: none"> <li>(i) Initial full characterisation of the fuel used including at least the parameters listed below and in accordance with EN standards. ISO, national or other international standards may be used provided they ensure the provision of data of an equivalent scientific quality;</li> <li>(ii) Regular testing of the fuel quality to check that it is consistent with the initial characterisation and according to the plant design specifications. The frequency of testing and the parameters chosen from the table below are based on the variability of the fuel and an assessment of the relevance of pollutant releases (e.g. concentration in fuel, flue-gas treatment employed);</li> <li>(iii) Subsequent adjustment of the plant settings as and when needed and practicable (e.g. integration of the fuel characterisation and control in the advanced control system (see description in Section 8.1)).</li> </ul> <p><b>Description</b> Initial characterisation and regular testing of the fuel can be performed by the operator and/or the fuel supplier. If performed by the supplier, the full results are provided to the operator in the form of a product (fuel) supplier specification and/or guarantee.</p> <table border="1" data-bbox="349 836 1395 1359"> <thead> <tr> <th data-bbox="349 836 698 871">Fuel(s)</th> <th data-bbox="703 836 1395 871">Substances/Parameters subject to characterisation</th> </tr> </thead> <tbody> <tr> <td data-bbox="349 874 698 1075" rowspan="4">Biomass/peat</td> <td data-bbox="703 874 1395 909">— LHV</td> </tr> <tr> <td data-bbox="703 912 1395 948">— moisture</td> </tr> <tr> <td data-bbox="703 951 1395 1002">— Ash</td> </tr> <tr> <td data-bbox="703 1005 1395 1075">— C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn)</td> </tr> <tr> <td data-bbox="349 1078 698 1315" rowspan="4">Coal/lignite</td> <td data-bbox="703 1078 1395 1114">— LHV</td> </tr> <tr> <td data-bbox="703 1117 1395 1152">— Moisture</td> </tr> <tr> <td data-bbox="703 1155 1395 1190">— Volatiles, ash, fixed carbon, C, H, N, O, S</td> </tr> <tr> <td data-bbox="703 1193 1395 1228">— Br, Cl, F</td> </tr> <tr> <td data-bbox="349 1232 698 1315"></td> <td data-bbox="703 1232 1395 1315">— Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)</td> </tr> <tr> <td data-bbox="349 1318 698 1359">HFO</td> <td data-bbox="703 1318 1395 1359">— Ash</td> </tr> </tbody> </table>	Fuel(s)	Substances/Parameters subject to characterisation	Biomass/peat	— LHV	— moisture	— Ash	— C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn)	Coal/lignite	— LHV	— Moisture	— Volatiles, ash, fixed carbon, C, H, N, O, S	— Br, Cl, F		— Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)	HFO	— Ash	CC	Natural Gas is the only fuel burnt in the LCPs. This is provided by the National Gas Transmission System. As such it is provided to the site at the UK standard for Natural Gas.
Fuel(s)	Substances/Parameters subject to characterisation																		
Biomass/peat	— LHV																		
	— moisture																		
	— Ash																		
	— C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn)																		
Coal/lignite	— LHV																		
	— Moisture																		
	— Volatiles, ash, fixed carbon, C, H, N, O, S																		
	— Br, Cl, F																		
	— Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)																		
HFO	— Ash																		

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement												
	<table border="1"> <tr> <td data-bbox="349 359 701 403"></td> <td data-bbox="705 359 1395 403">— C, S, N, Ni, V</td> </tr> <tr> <td data-bbox="349 406 701 486">Gas oil</td> <td data-bbox="705 406 1395 486">— Ash — N, C, S</td> </tr> <tr> <td data-bbox="349 489 701 569">Natural gas</td> <td data-bbox="705 489 1395 569">— LHV — CH<sub>4</sub>, C<sub>2</sub>H<sub>6</sub>, C<sub>3</sub>, C<sub>4</sub>+, CO<sub>2</sub>, N<sub>2</sub>, Wobbe index</td> </tr> <tr> <td data-bbox="349 572 701 676">Process fuels from the chemical industry <sup>(27)</sup></td> <td data-bbox="705 572 1395 676">— Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)</td> </tr> <tr> <td data-bbox="349 679 701 751">Iron and steel process gases</td> <td data-bbox="705 679 1395 751">— LHV, CH<sub>4</sub> (for COG), C<sub>x</sub>H<sub>y</sub> (for COG), CO<sub>2</sub>, H<sub>2</sub>, N<sub>2</sub>, total sulphur, dust, Wobbe index</td> </tr> <tr> <td data-bbox="349 754 701 930">Waste <sup>(28)</sup></td> <td data-bbox="705 754 1395 930">— LHV — Moisture — Volatiles, ash, Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)</td> </tr> </table>		— C, S, N, Ni, V	Gas oil	— Ash — N, C, S	Natural gas	— LHV — CH <sub>4</sub> , C <sub>2</sub> H <sub>6</sub> , C <sub>3</sub> , C <sub>4</sub> +, CO <sub>2</sub> , N <sub>2</sub> , Wobbe index	Process fuels from the chemical industry <sup>(27)</sup>	— Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)	Iron and steel process gases	— LHV, CH <sub>4</sub> (for COG), C <sub>x</sub> H <sub>y</sub> (for COG), CO <sub>2</sub> , H <sub>2</sub> , N <sub>2</sub> , total sulphur, dust, Wobbe index	Waste <sup>(28)</sup>	— LHV — Moisture — Volatiles, ash, Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)		
	— C, S, N, Ni, V														
Gas oil	— Ash — N, C, S														
Natural gas	— LHV — CH <sub>4</sub> , C <sub>2</sub> H <sub>6</sub> , C <sub>3</sub> , C <sub>4</sub> +, CO <sub>2</sub> , N <sub>2</sub> , Wobbe index														
Process fuels from the chemical industry <sup>(27)</sup>	— Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)														
Iron and steel process gases	— LHV, CH <sub>4</sub> (for COG), C <sub>x</sub> H <sub>y</sub> (for COG), CO <sub>2</sub> , H <sub>2</sub> , N <sub>2</sub> , total sulphur, dust, Wobbe index														
Waste <sup>(28)</sup>	— LHV — Moisture — Volatiles, ash, Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)														
10	<p>In order to reduce emissions to air and/or to water during other than normal operating conditions (OTNOC), BAT is to set up and implement a management plan as part of the environmental management system (see BAT 1), commensurate with the relevance of potential pollutant releases, that includes the following elements:</p> <ul style="list-style-type: none"> <li>— appropriate design of the systems considered relevant in causing OTNOC that may have an impact on emissions to air, water and/or soil (e.g. low-load design concepts for reducing the minimum start-up and shutdown loads for stable generation in gas turbines),</li> <li>— set-up and implementation of a specific preventive maintenance plan for these relevant systems,</li> <li>— review and recording of emissions caused by OTNOC and associated circumstances and implementation of corrective actions if necessary,</li> <li>— periodic assessment of the overall emissions during OTNOC (e.g. frequency of events, duration, emissions quantification/estimation) and implementation of corrective actions if necessary.</li> </ul>	CC	<p>-A computer system is used to automatically control and optimise combustion efficiency, and to support the prevention and reduction of emissions. In addition, GE Power's 'OPFlex' and DLN2.6+ were installed as part of the upgrade to the plant in 2016. Used together these systems reduce emissions to air and/or water during ONTOC (including start up and shut down).</p> <p>-The site is run in accordance with the EMS, which includes the maintenance</p>												

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement											
			<p>requirements that are implemented at the installation.</p> <p>-The plan / procedure related to the reduction of emissions to air and / or water during OTNOC (including start-up and shut-down periods) also includes an approach to checking performance, including:</p> <ul style="list-style-type: none"> <li>• Monitoring and measurement;</li> <li>• Preventative and corrective action; and,</li> <li>• Maintenance of records.</li> </ul>											
11	<p>BAT is to appropriately monitor emissions to air and/or to water during OTNOC.</p> <p><b>Description</b></p> <p>The monitoring can be carried out by direct measurement of emissions or by monitoring of surrogate parameters if this proves to be of equal or better scientific quality than the direct measurement of emissions. Emissions during start-up and shutdown (SU/SD) may be assessed based on a detailed emission measurement carried out for a typical SU/SD procedure at least once every year, and using the results of this measurement to estimate the emissions for each and every SU/SD throughout the year.</p>	CC	The site has a continuous monitoring system in place. This is undertaken in line with BS EN 14181:2014.											
12	<p>In order to increase the energy efficiency of combustion, gasification and/or IGCC units operated <math>\geq 1\,500</math> h/yr, BAT is to use an appropriate combination of the techniques given below.</p> <table border="1" data-bbox="349 1061 1395 1361"> <thead> <tr> <th data-bbox="349 1061 394 1093"></th> <th data-bbox="398 1061 577 1093">Technique</th> <th data-bbox="582 1061 1003 1093">Description</th> <th data-bbox="1008 1061 1395 1093">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="349 1096 394 1201">a.</td> <td data-bbox="398 1096 577 1201">Combustion optimisation</td> <td data-bbox="582 1096 1003 1201">See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues</td> <td data-bbox="1008 1096 1395 1201" rowspan="2">Generally applicable</td> </tr> <tr> <td data-bbox="349 1204 394 1361">b.</td> <td data-bbox="398 1204 577 1361">Optimisation of the working medium conditions</td> <td data-bbox="582 1204 1003 1361">Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO<sub>x</sub> emissions or the characteristics of energy demanded</td> </tr> </tbody> </table>		Technique	Description	Applicability	a.	Combustion optimisation	See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues	Generally applicable	b.	Optimisation of the working medium conditions	Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO <sub>x</sub> emissions or the characteristics of energy demanded	CC	<p>a) Measures used to ensure combustion optimisation include: well-designed combustion system; optimisation of the temperature and residence time in the combustion zone; and the use of a computer-based advanced control system, including GE Power's 'OPFlex' system to allow for high-performance monitoring.</p> <p>b) A computer-based advanced control system to automatically control and</p>
	Technique	Description	Applicability											
a.	Combustion optimisation	See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues	Generally applicable											
b.	Optimisation of the working medium conditions	Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO <sub>x</sub> emissions or the characteristics of energy demanded												



BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	c.	Optimisation of the steam cycle	Operate with lower turbine exhaust pressure by utilisation of the lowest possible temperature of the condenser cooling water, within the design conditions		<p>optimise the working medium (natural gas and steam) conditions.</p> <p>c) As part of the design and installation of Sutton Bridge, the steam cycle was optimised.</p> <p>d) As part of the upgrades to the plant completed in July 2016 a number of energy efficiency measures were implemented as detailed in the Commissioning report</p> <p><i>'Combined Cycle Thermal Performance Test Report: Calon Energy – Sutton Bridge Power Station, Sutton Bridge, United Kingdom'. GE Power, 19 December 2017'</i></p> <p>e) Not applicable – under normal conditions preheating of combustion air lowers the energy efficiency of gas turbines.</p> <p>f) Measures are in place to allow for fuel preheating. During start-up, fuel pre-heating is via the use of hot water from the auxiliary boiler and during normal operation, fuel pre-heating is via the use of hot water from the HRSG or gas turbine compressor.</p> <p>g) A computer- control system to automatically control and optimise combustion efficiency, and support the</p>
d.	Minimisation of energy consumption	Minimising the internal energy consumption (e.g. greater efficiency of the feed-water pump)			
e.	Preheating of combustion air	Reuse of part of the heat recovered from the combustion flue-gas to preheat the air used in combustion	Generally applicable within the constraints related to the need to control NO <sub>x</sub> emissions		
f.	Fuel preheating	Preheating of fuel using recovered heat	Generally applicable within the constraints associated with the boiler design and the need to control NO <sub>x</sub> emissions		
g.	Advanced control system	See description in Section 8.2. Computerised control of the main combustion parameters enables the combustion efficiency to be improved	Generally applicable to new units. The applicability to old units may be constrained by the need to retrofit the combustion system and/or control command system		
h.	Feed-water preheating using recovered heat	Preheat water coming out of the steam condenser with recovered heat, before reusing it in the boiler	Only applicable to steam circuits and not to hot boilers. Applicability to existing units may be limited due to constraints associated with the plant configuration and the amount of recoverable heat		
i.	Heat recovery by cogeneration (CHP)	Recovery of heat (mainly from the steam system) for producing hot water/steam to be used in industrial processes/activities or in a public network for district heating. Additional heat recovery is possible from: <ul style="list-style-type: none"> <li>— flue-gas</li> <li>— grate cooling</li> <li>— circulating fluidised bed</li> </ul>	Applicable within the constraints associated with the local heat and power demand. The applicability may be limited in the case of gas compressors with an unpredictable operational heat profile		
j.	CHP readiness	See description in Section 8.2.	Only applicable to new units where there is a realistic potential for the future use of heat in the vicinity of the unit		

BAT Concn. Number	Summary of BAT Conclusion requirement				Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	k.	Flue-gas condenser	See description in Section 8.2.	Generally applicable to CHP units provided there is enough demand for low-temperature heat		<p>prevention and reduction of emissions. In addition, as part of the major technical upgrade, GE Power's 'OPFlex' system was installed to allow for high-performance monitoring to improve general environmental performance and reduce emission events.</p> <p>h) To increase feed-water temperature within the deaerator a low-temperature economiser (pre-heater), with recirculation, and a low pressure boiler which recover heat from the flue gases.</p> <p>i) The site does not have a Combined Heat and Power (CHP) plant in place.</p> <p>j) The plant is CHP ready. Opportunities for the implementation of CHP are annually reviewed in accordance with the reporting requirements of the permit.</p> <p>k) Not Applicable – applicable to CHP plants</p> <p>l) Not Applicable – applicable to CHP plants</p> <p>m) Not Applicable – applicable to plant fitted with flue gas desulphurisation (FGD)</p> <p>n) Not Applicable – applicable to plant fitted with flue gas desulphurisation (FGD)</p>
l.	Heat accumulation	Heat accumulation storage in CHP mode	Only applicable to CHP plants. The applicability may be limited in the case of low heat load demand			
m.	Wet stack	See description in Section 8.2.	Generally applicable to new and existing units fitted with wet FGD			
n.	Cooling tower discharge	The release of emissions to air through a cooling tower and not via a dedicated stack	Only applicable to units fitted with wet FGD where reheating of the flue-gas is necessary before release, and where the unit cooling system is a cooling tower			
o.	Fuel pre-drying	The reduction of fuel moisture content before combustion to improve combustion conditions	Applicable to the combustion of biomass and/or peat within the constraints associated with spontaneous combustion risks (e.g. the moisture content of peat is kept above 40 % throughout the delivery chain). The retrofit of existing plants may be restricted by the extra calorific value that can be obtained from the drying operation and by the limited retrofit possibilities offered by some boiler designs or plant configurations			
p.	Minimisation of heat losses	Minimising residual heat losses, e.g. those that occur via the slag or those that can be reduced by insulating radiating sources	Only applicable to solid-fuel-fired combustion units and to gasification/IGCC units			
q.	Advanced materials	Use of advanced materials proven to be capable of withstanding high operating temperatures and pressures and thus to achieve increased steam/combustion process efficiencies	Only applicable to new plants			
r.	Steam turbine upgrades	This includes techniques such as increasing the temperature and pressure of medium-pressure steam, addition of a low-pressure turbine, and modifications to the geometry of the turbine rotor blades	The applicability may be restricted by demand, steam conditions and/or limited plant lifetime			

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement		
	s.	Supercritical and ultra-supercritical steam conditions	Use of a steam circuit, including steam reheating systems, in which steam can reach pressures above 220,6 bar and temperatures above 374 °C in the case of supercritical conditions, and above 250 – 300 bar and temperatures above 580 – 600 °C in the case of ultra-supercritical conditions	Only applicable to new units of $\geq 600 \text{ MW}_{th}$ operated $> 4\,000 \text{ h/yr}$ . Not applicable when the purpose of the unit is to produce low steam temperatures and/or pressures in process industries. Not applicable to gas turbines and engines generating steam in CHP mode. For units combusting biomass, the applicability may be constrained by high-temperature corrosion in the case of certain biomasses		<p>o) Not Applicable – applicable to combustion of biomass and/or peat</p> <p>p) Not Applicable – applicable to combustion solid fuels and gasification/ integrated gasification combined cycle plants/ units.</p> <p>q) Not Applicable – applicable to new plants/units.</p> <p>r) During steam turbine upgrades the operator considered techniques for increasing energy efficiency.</p> <p>s) Not Applicable – applicable to new plants/units with a thermal input <math>\geq 600 \text{ MW}</math>.</p>	
13	In order to reduce water usage and the volume of contaminated waste water discharged, BAT is to use one or both of the techniques given below.			CC	Water used to generate steam is used in a closed loop cycle, which reduces water usage.		
		<b>Technique</b>	<b>Description</b>	<b>Applicability</b>			
		a.	Water recycling	Residual aqueous streams, including run-off water, from the plant are reused for other purposes. The degree of recycling is limited by the quality requirements of the recipient water stream and the water balance of the plant	Not applicable to waste water from cooling systems when water treatment chemicals and/or high concentrations of salts from seawater are present		
		b.	Dry bottom ash handling	Dry, hot bottom ash falls from the furnace onto a mechanical conveyor system and is cooled down by ambient air. No water is used in the process.	Only applicable to plants combusting solid fuels. There may be technical restrictions that prevent retrofitting to existing combustion plants		
14	In order to prevent the contamination of uncontaminated waste water and to reduce emissions to water, BAT is to segregate waste water streams and to treat them separately, depending on the pollutant content.			CC	The drainage system segregates waste water streams to prevent the mixing of uncontaminated surface waters with process waters.		
		<b>Description</b>					

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																																							
	<p>Waste water streams that are typically segregated and treated include surface run-off water, cooling water, and waste water from flue-gas treatment.</p> <p><b>Applicability</b> The applicability may be restricted in the case of existing plants due to the configuration of the drainage systems.</p>																																									
15	<p>In order to reduce emissions to water from flue-gas treatment, BAT is to use an appropriate combination of the techniques given below, and to use secondary techniques as close as possible to the source in order to avoid dilution.</p> <table border="1" data-bbox="349 595 1395 1377"> <thead> <tr> <th data-bbox="349 595 698 655">Technique</th> <th data-bbox="703 595 976 655">Typical pollutants prevented/abated</th> <th data-bbox="981 595 1395 655">Applicability</th> </tr> </thead> <tbody> <tr> <td colspan="3" data-bbox="349 659 1395 687" style="text-align: center;"><b>Primary techniques</b></td> </tr> <tr> <td data-bbox="349 691 394 802">a.</td> <td data-bbox="398 691 698 802">Optimised combustion (see BAT 6) and flue-gas treatment systems (e.g. SCR/SNCR, see BAT 7)</td> <td data-bbox="703 691 976 802">Organic compounds, ammonia (NH<sub>3</sub>)</td> </tr> <tr> <td colspan="3" data-bbox="349 805 1395 834" style="text-align: center;"><b>Secondary techniques <sup>(29)</sup></b></td> </tr> <tr> <td data-bbox="349 837 394 898">b.</td> <td data-bbox="398 837 698 898">Adsorption on activated carbon</td> <td data-bbox="703 837 976 898">Organic compounds, mercury (Hg)</td> </tr> <tr> <td data-bbox="349 901 394 1029">c.</td> <td data-bbox="398 901 698 1029">Aerobic biological treatment</td> <td data-bbox="703 901 976 1029">Biodegradable organic compounds, ammonium (NH<sub>4</sub><sup>+</sup>)</td> </tr> <tr> <td data-bbox="349 1032 394 1093">d.</td> <td data-bbox="398 1032 698 1093">Anoxic/anaerobic biological treatment</td> <td data-bbox="703 1032 976 1093">Mercury (Hg), nitrate (NO<sub>3</sub><sup>-</sup>), nitrite (NO<sub>2</sub><sup>-</sup>)</td> </tr> <tr> <td data-bbox="349 1096 394 1125">e.</td> <td data-bbox="398 1096 698 1125">Coagulation and flocculation</td> <td data-bbox="703 1096 976 1125">Suspended solids</td> </tr> <tr> <td data-bbox="349 1128 394 1208">f.</td> <td data-bbox="398 1128 698 1208">Crystallisation</td> <td data-bbox="703 1128 976 1208">Metals and metalloids, sulphate (SO<sub>4</sub><sup>2-</sup>), fluoride (F<sup>-</sup>)</td> </tr> <tr> <td data-bbox="349 1211 394 1272">g.</td> <td data-bbox="398 1211 698 1272">Filtration (e.g. sand filtration, microfiltration, ultrafiltration)</td> <td data-bbox="703 1211 976 1272">Suspended solids, metals</td> </tr> <tr> <td data-bbox="349 1275 394 1303">h.</td> <td data-bbox="398 1275 698 1303">Flotation</td> <td data-bbox="703 1275 976 1303">Suspended solids, free oil</td> </tr> <tr> <td data-bbox="349 1307 394 1335">i.</td> <td data-bbox="398 1307 698 1335">Ion exchange</td> <td data-bbox="703 1307 976 1335">Metals</td> </tr> <tr> <td data-bbox="349 1339 394 1367">j.</td> <td data-bbox="398 1339 698 1367">Neutralisation</td> <td data-bbox="703 1339 976 1367">Acids, alkalis</td> </tr> </tbody> </table>	Technique	Typical pollutants prevented/abated	Applicability	<b>Primary techniques</b>			a.	Optimised combustion (see BAT 6) and flue-gas treatment systems (e.g. SCR/SNCR, see BAT 7)	Organic compounds, ammonia (NH <sub>3</sub> )	<b>Secondary techniques <sup>(29)</sup></b>			b.	Adsorption on activated carbon	Organic compounds, mercury (Hg)	c.	Aerobic biological treatment	Biodegradable organic compounds, ammonium (NH <sub>4</sub> <sup>+</sup> )	d.	Anoxic/anaerobic biological treatment	Mercury (Hg), nitrate (NO <sub>3</sub> <sup>-</sup> ), nitrite (NO <sub>2</sub> <sup>-</sup> )	e.	Coagulation and flocculation	Suspended solids	f.	Crystallisation	Metals and metalloids, sulphate (SO <sub>4</sub> <sup>2-</sup> ), fluoride (F <sup>-</sup> )	g.	Filtration (e.g. sand filtration, microfiltration, ultrafiltration)	Suspended solids, metals	h.	Flotation	Suspended solids, free oil	i.	Ion exchange	Metals	j.	Neutralisation	Acids, alkalis	NA	This relates to flue-gas treatment which is not used at this site.
Technique	Typical pollutants prevented/abated	Applicability																																								
<b>Primary techniques</b>																																										
a.	Optimised combustion (see BAT 6) and flue-gas treatment systems (e.g. SCR/SNCR, see BAT 7)	Organic compounds, ammonia (NH <sub>3</sub> )																																								
<b>Secondary techniques <sup>(29)</sup></b>																																										
b.	Adsorption on activated carbon	Organic compounds, mercury (Hg)																																								
c.	Aerobic biological treatment	Biodegradable organic compounds, ammonium (NH <sub>4</sub> <sup>+</sup> )																																								
d.	Anoxic/anaerobic biological treatment	Mercury (Hg), nitrate (NO <sub>3</sub> <sup>-</sup> ), nitrite (NO <sub>2</sub> <sup>-</sup> )																																								
e.	Coagulation and flocculation	Suspended solids																																								
f.	Crystallisation	Metals and metalloids, sulphate (SO <sub>4</sub> <sup>2-</sup> ), fluoride (F <sup>-</sup> )																																								
g.	Filtration (e.g. sand filtration, microfiltration, ultrafiltration)	Suspended solids, metals																																								
h.	Flotation	Suspended solids, free oil																																								
i.	Ion exchange	Metals																																								
j.	Neutralisation	Acids, alkalis																																								

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	k.	Oxidation	Sulphide (S <sup>2-</sup> ), sulphite (SO <sub>3</sub> <sup>2-</sup> )	Generally applicable	
l.	Precipitation	Metals and metalloids, sulphate (SO <sub>4</sub> <sup>2-</sup> ), fluoride (F <sup>-</sup> )	Generally applicable		
m.	Sedimentation	Suspended solids	Generally applicable		
n.	Stripping	Ammonia (NH <sub>3</sub> )	Generally applicable		
The BAT-AELs refer to direct discharges to a receiving water body at the point where the emission leaves the installation.					
<b>BAT-AELs for direct discharges to a receiving water body from flue-gas treatment</b>					
<b>Substance/Parameter</b>		<b>BAT-AELs</b>			
		<b>Daily average</b>			
Total organic carbon (TOC)		20–50 mg/l <sup>(30)</sup> <sup>(31)</sup> <sup>(32)</sup>			
Chemical oxygen demand (COD)		60–150 mg/l <sup>(30)</sup> <sup>(31)</sup> <sup>(32)</sup>			
Total suspended solids (TSS)		10–30 mg/l			
Fluoride (F <sup>-</sup> )		10–25 mg/l <sup>(32)</sup>			
Sulphate (SO <sub>4</sub> <sup>2-</sup> )		1,3–2,0 g/l <sup>(32)</sup> <sup>(33)</sup> <sup>(34)</sup> <sup>(35)</sup>			
Sulphide (S <sup>2-</sup> ), easily released		0,1–0,2 mg/l <sup>(32)</sup>			
Sulphite (SO <sub>3</sub> <sup>2-</sup> )		1–20 mg/l <sup>(32)</sup>			
Metals and metalloids		As	10–50 µg/l		
		Cd	2–5 µg/l		
		Cr	10–50 µg/l		
		Cu	10–50 µg/l		
		Hg	0,2–3 µg/l		
		Ni	10–50 µg/l		
		Pb	10–20 µg/l		
		Zn	50–200 µg/l		
16	<p>In order to reduce the quantity of waste sent for disposal from the combustion and/or gasification process and abatement techniques, BAT is to organise operations so as to maximise, in order of priority and taking into account life-cycle thinking:</p> <p>(a) waste prevention, e.g. maximise the proportion of residues which arise as by-products;</p>			CC	The site operates under the combined requirements of the EMS and the GE Integrated Management System (IMS). The EMS and the GE

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement															
	<p>(b) waste preparation for reuse, e.g. according to the specific requested quality criteria;</p> <p>(c) waste recycling;</p> <p>(d) other waste recovery (e.g. energy recovery),</p> <p>by implementing an appropriate combination of techniques such as:</p> <table border="1" data-bbox="349 504 1395 1193"> <thead> <tr> <th data-bbox="349 504 577 536">Technique</th> <th data-bbox="582 504 1025 536">Description</th> <th data-bbox="1030 504 1395 536">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="349 539 577 719">a. Generation of gypsum as a by-product</td> <td data-bbox="582 539 1025 719">Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g. as raw material in the plasterboard industry). The quality of limestone used in the wet FGD influences the purity of the gypsum produced</td> <td data-bbox="1030 539 1395 719">Generally applicable within the constraints associated with the required gypsum quality, the health requirements associated to each specific use, and by the market conditions</td> </tr> <tr> <td data-bbox="349 722 577 903">b. Recycling or recovery of residues in the construction sector</td> <td data-bbox="582 722 1025 903">Recycling or recovery of residues (e.g. from semi-dry desulphurisation processes, fly ash, bottom ash) as a construction material (e.g. in road building, to replace sand in concrete production, or in the cement industry)</td> <td data-bbox="1030 722 1395 903">Generally applicable within the constraints associated with the required material quality (e.g. physical properties, content of harmful substances) associated to each specific use, and by the market conditions</td> </tr> <tr> <td data-bbox="349 906 577 1034">c. Energy recovery by using waste in the fuel mix</td> <td data-bbox="582 906 1025 1034">The residual energy content of carbon-rich ash and sludges generated by the combustion of coal, lignite, heavy fuel oil, peat or biomass can be recovered for example by mixing with the fuel</td> <td data-bbox="1030 906 1395 1034">Generally applicable where plants can accept waste in the fuel mix and are technically able to feed the fuels into the combustion chamber</td> </tr> <tr> <td data-bbox="349 1037 577 1193">d. Preparation of spent catalyst for reuse</td> <td data-bbox="582 1037 1025 1193">Preparation of catalyst for reuse (e.g. up to four times for SCR catalysts) restores some or all of the original performance, extending the service life of the catalyst to several decades. Preparation of spent catalyst for reuse is integrated in a catalyst management scheme</td> <td data-bbox="1030 1037 1395 1193">The applicability may be limited by the mechanical condition of the catalyst and the required performance with respect to controlling NO<sub>x</sub> and NH<sub>3</sub> emissions</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Generation of gypsum as a by-product	Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g. as raw material in the plasterboard industry). The quality of limestone used in the wet FGD influences the purity of the gypsum produced	Generally applicable within the constraints associated with the required gypsum quality, the health requirements associated to each specific use, and by the market conditions	b. Recycling or recovery of residues in the construction sector	Recycling or recovery of residues (e.g. from semi-dry desulphurisation processes, fly ash, bottom ash) as a construction material (e.g. in road building, to replace sand in concrete production, or in the cement industry)	Generally applicable within the constraints associated with the required material quality (e.g. physical properties, content of harmful substances) associated to each specific use, and by the market conditions	c. Energy recovery by using waste in the fuel mix	The residual energy content of carbon-rich ash and sludges generated by the combustion of coal, lignite, heavy fuel oil, peat or biomass can be recovered for example by mixing with the fuel	Generally applicable where plants can accept waste in the fuel mix and are technically able to feed the fuels into the combustion chamber	d. Preparation of spent catalyst for reuse	Preparation of catalyst for reuse (e.g. up to four times for SCR catalysts) restores some or all of the original performance, extending the service life of the catalyst to several decades. Preparation of spent catalyst for reuse is integrated in a catalyst management scheme	The applicability may be limited by the mechanical condition of the catalyst and the required performance with respect to controlling NO <sub>x</sub> and NH <sub>3</sub> emissions		<p>IMS are certified in accordance with ISO 14001:2015. As part of the GE IMS, a specific site operational plan / procedure is included to related to waste management. In addition, the site operates in accordance with the waste hierarchy referred to in Article 4 of the Waste Framework Directive.</p>
Technique	Description	Applicability																
a. Generation of gypsum as a by-product	Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g. as raw material in the plasterboard industry). The quality of limestone used in the wet FGD influences the purity of the gypsum produced	Generally applicable within the constraints associated with the required gypsum quality, the health requirements associated to each specific use, and by the market conditions																
b. Recycling or recovery of residues in the construction sector	Recycling or recovery of residues (e.g. from semi-dry desulphurisation processes, fly ash, bottom ash) as a construction material (e.g. in road building, to replace sand in concrete production, or in the cement industry)	Generally applicable within the constraints associated with the required material quality (e.g. physical properties, content of harmful substances) associated to each specific use, and by the market conditions																
c. Energy recovery by using waste in the fuel mix	The residual energy content of carbon-rich ash and sludges generated by the combustion of coal, lignite, heavy fuel oil, peat or biomass can be recovered for example by mixing with the fuel	Generally applicable where plants can accept waste in the fuel mix and are technically able to feed the fuels into the combustion chamber																
d. Preparation of spent catalyst for reuse	Preparation of catalyst for reuse (e.g. up to four times for SCR catalysts) restores some or all of the original performance, extending the service life of the catalyst to several decades. Preparation of spent catalyst for reuse is integrated in a catalyst management scheme	The applicability may be limited by the mechanical condition of the catalyst and the required performance with respect to controlling NO <sub>x</sub> and NH <sub>3</sub> emissions																
17	<p>In order to reduce noise emissions, BAT is to use one or a combination of the techniques given below.</p> <table border="1" data-bbox="349 1270 1395 1361"> <thead> <tr> <th data-bbox="349 1270 577 1302">Technique</th> <th data-bbox="582 1270 1025 1302">Description</th> <th data-bbox="1030 1270 1395 1302">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="349 1305 577 1361">a. Operational measures</td> <td data-bbox="582 1305 1025 1361">These include:</td> <td data-bbox="1030 1305 1395 1361">Generally applicable</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Operational measures	These include:	Generally applicable	CC	<p>a) Sutton Bridge operates under the combined requirements of EMS and the GE IMS. The EMS and the GE IMS are certified in accordance with ISO 14001:2015.</p>									
Technique	Description	Applicability																
a. Operational measures	These include:	Generally applicable																

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
		<ul style="list-style-type: none"> <li>— improved inspection and maintenance of equipment</li> <li>— closing of doors and windows of enclosed areas, if possible</li> <li>— equipment operated by experienced staff</li> <li>— avoidance of noisy activities at night, if possible</li> <li>— provisions for noise control during maintenance activities</li> </ul>			<p>The EMS and the GE IMS include specific site-operational plans / procedures, with each of these plans / procedures including an approach for implementation covering safeguarding compliance with environmental legislation.</p> <p>b-e) During the design and consenting (via Section 36 of the Electricity Act 1989) of Sutton Bridge, noise emissions were considered and a noise impact assessment was undertaken. The noise impact assessment considered the proposed location of equipment and buildings with regards to nearby Noise Sensitive Receptors. Subsequently, an appropriate combination of low-noise equipment, noise attenuation and noise-control equipment was implemented. In addition, through conditions of the consent (under Section 36 of the Electricity Act 1989) operational noise monitoring is undertaken to ensure compliance with both near field and far field noise limits. Such monitoring was required to be undertaken annually for the first 10 years of operational, and is now required to be undertaken biennially.</p>
	b. Low-noise equipment	This potentially includes compressors, pumps and disks	Generally applicable when the equipment is new or replaced		
	c. Noise attenuation	Noise propagation can be reduced by inserting obstacles between the emitter and the receiver. Appropriate obstacles include protection walls, embankments and buildings	Generally applicable to new plants. In the case of existing plants, the insertion of obstacles may be restricted by lack of space		
	d. Noise-control equipment	This includes: <ul style="list-style-type: none"> <li>— noise-reducers</li> <li>— equipment insulation</li> <li>— enclosure of noisy equipment</li> <li>— soundproofing of buildings</li> </ul>	The applicability may be restricted by lack of space		
	e. Appropriate location of equipment and buildings	Noise levels can be reduced by increasing the distance between the emitter and the receiver and by using buildings as noise screens	Generally applicable to new plant		
40	In order to increase the energy efficiency of natural gas combustion, BAT is to use an appropriate combination of the techniques given in BAT 12 and below.			CC	The site operates two Combined Cycle Gas Turbines (CCGT).
	<b>Technique</b>	<b>Description</b>	<b>Applicability</b>		

BAT Concn. Number	Summary of BAT Conclusion requirement				Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	
	a. Combined cycle	See description in Section 8.2	<p>Generally applicable to new gas turbines and engines except when operated &lt; 1 500 h/yr.            Applicable to existing gas turbines and engines within the constraints associated with the steam cycle design and the space availability.            Not applicable to existing gas turbines and engines operated &lt; 1 500 h/yr.            Not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns.            Not applicable to boilers</p>			<p>Following the completion of the technical upgrade to the plant in July 2016. The performance of the plant was tested and the outcomes were detailed in the report:</p> <p><i>'Combined Cycle Thermal Performance Test Report: Calon Energy – Sutton Bridge Power Station, Sutton Bridge, United Kingdom'. GE Power, 19 December 2017'</i></p> <p>The results of the thermal performance test indicated that, post-upgrade, the net electrical efficiency of the plant was 56.8 per cent. This is within the BAT-AEEL range.</p>	
<b>BAT-associated energy efficiency levels (BAT-AEELs) for the combustion of natural gas</b>							
<b>Type of combustion unit</b>		<b>BAT-AEELs <sup>(136)</sup> <sup>(137)</sup></b>					
		<b>Net electrical efficiency (%)</b>		<b>Net total fuel utilisation (%) <sup>(138)</sup> <sup>(139)</sup></b>	<b>Net mechanical energy efficiency (%) <sup>(139)</sup> <sup>(140)</sup></b>		
		<b>New unit</b>	<b>Existing unit</b>			<b>New unit</b>	<b>Existing unit</b>
Gas engine		39,5–44 <sup>(141)</sup>	35–44 <sup>(141)</sup>	56–85 <sup>(141)</sup>	No BAT-AEEL.		
Gas-fired boiler		39–42,5	38–40	78–95	No BAT-AEEL.		
Open cycle gas turbine, ≥ 50 MW <sub>th</sub>		36–41,5	33–41,5	No BAT-AEEL	36,5–41	33,5–41	
<b>Combined cycle gas turbine (CCGT)</b>							
CCGT, 50–600 MW <sub>th</sub>		53–58,5	46–54	No BAT-AEEL	No BAT-AEEL		
CCGT, ≥ 600 MW <sub>th</sub>		57–60,5	50–60	No BAT-AEEL	No BAT-AEEL		
CHP CCGT, 50–600 MW <sub>th</sub>		53–58,5	46–54	65–95	No BAT-AEEL		
CHP CCGT, ≥ 600 MW <sub>th</sub>		57–60,5	50–60	65–95	No BAT-AEEL		
41	In order to prevent or reduce NO <sub>x</sub> emissions to air from the combustion of natural gas in boilers, BAT is to use one or a combination of the techniques given below.				N/A	Not Applicable – There are no natural gas boilers located on this site.	
<b>Technique</b>		<b>Description</b>		<b>Applicability</b>			
a.	Air and/or fuel staging	See descriptions in Section 8.3. Air staging is often associated with low-NO <sub>x</sub> burners		Generally applicable			



BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	b. Flue-gas recirculation	See description in Section 8.3			
	c. Low-NO <sub>x</sub> burners (LNB)				
	d. Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system		
	e. Reduction of the combustion air temperature	See description in Section 8.3	Generally applicable within the constraints associated with the process needs		
	f. Selective non-catalytic reduction (SNCR)		Not applicable to combustion plants operated < 500 h/yr with highly variable boiler loads. The applicability may be limited in the case of combustion plants operated between 500 h/yr and 1 500 h/yr with highly variable boiler loads		
	g. Selective catalytic reduction (SCR)		Not applicable to combustion plants operated < 500 h/yr. Not generally applicable to combustion plants of < 100 MW <sub>th</sub> . There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr		
42	In order to prevent or reduce NO <sub>x</sub> emissions to air from the combustion of natural gas in gas turbines, BAT is to use one or a combination of the techniques given below.			CC	The site is currently compliant with the BAT-AELs for NO <sub>x</sub> as specified under this BAT conclusion, based upon the last 3 months of monitoring data.  a) A computer-based advanced control system to automatically control and optimise combustion efficiency, and support the reduction of emissions.
	<b>Technique</b>	<b>Description</b>	<b>Applicability</b>		
	a. Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system		
	b. Water/steam addition	See description in Section 8.3	The applicability may be limited due to water availability		

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	c. Dry low-NO <sub>x</sub> burners (DLN)		The applicability may be limited in the case of turbines where a retrofit package is not available or when water/steam addition systems are installed		<p>In addition, as part of the major technical upgrade, GE Power's 'OPFlex' system was installed to allow for high-performance monitoring to improve general environmental performance and reduce emission events.</p> <p>b) Not applicable</p> <p>c) Both LCP128 and LCP129 are fitted with DLN burners. The DLN burners become effective at 37.8% of the Gas turbines rates electrical output.</p> <p>d) A computer system is used to optimise combustion efficiency, and support the prevention and reduction of emissions.</p> <p>The GE Power OpPFlex system that has been installed allows for good combustion when the demand in energy varies.</p> <p>e) Not applicable</p> <p>f) Not applicable – combination of the above techniques allows for site to meet BAT-AELs</p>
d. Low-load design concept	Adaptation of the process control and related equipment to maintain good combustion efficiency when the demand in energy varies, e.g. by improving the inlet airflow control capability or by splitting the combustion process into decoupled combustion stages	The applicability may be limited by the gas turbine design			
e. Low-NO <sub>x</sub> burners (LNB)	See description in Section 8.3		Generally applicable to supplementary firing for heat recovery steam generators (HRSGs) in the case of combined-cycle gas turbine (CCGT) combustion plants		
f. Selective catalytic reduction (SCR)			<p>Not applicable in the case of combustion plants operated &lt; 500 h/yr.</p> <p>Not generally applicable to existing combustion plants of &lt; 100 MW<sub>th</sub>.</p> <p>Retrofitting existing combustion plants may be constrained by the availability of sufficient space.</p> <p>There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr</p>		
43	In order to prevent or reduce NO <sub>x</sub> emissions to air from the combustion of natural gas in engines, BAT is to use one or a combination of the techniques given below.			CC	A computer system is used to optimise combustion efficiency, and support the prevention and reduction of emissions.
		<b>Technique</b>	<b>Description</b>		
a.	Advanced control system	See description in Section 8.3.	The applicability to old combustion plants may be constrained by the need to retrofit		

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	
		This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	the combustion system and/or control command system		The GE Power OpPFlex system that has been installed allows for good combustion when the demand in energy varies.	
	b. Lean-burn concept	See description in Section 8.3. Generally used in combination with SCR	Only applicable to new gas-fired engines			
	c. Advanced lean-burn concept	See descriptions in Section 8.3	Only applicable to new spark plug ignited engines			
	d. Selective catalytic reduction (SCR)		Retrofitting existing combustion plants may be constrained by the availability of sufficient space. Not applicable to combustion plants operated < 500 h/yr. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr			
44	<p>In order to prevent or reduce CO emissions to air from the combustion of natural gas, BAT is to ensure optimised combustion and/or to use oxidation catalysts.</p> <p><b>Description - See descriptions in Section 8.3.</b></p> <p><b>BAT-associated emission levels (BAT-AELs) for NO<sub>x</sub> emissions to air from the combustion of natural gas in gas turbines</b></p>			CC	The site is currently compliant with the BAT-AELs for CO as specified under this BAT conclusion, based upon the last 3 months of monitoring data.	
Type of combustion plant		Combustion plant total rated thermal input (MW <sub>th</sub> )	BAT-AELs (mg/Nm <sup>3</sup> ) <sup>(142)</sup> <sup>(143)</sup>			
			Yearly average <sup>(144)</sup> <sup>(145)</sup>			Daily average or average over the sampling period
<b>Open-cycle gas turbines (OCGTs) <sup>(146)</sup> <sup>(147)</sup></b>						
New OCGT	≥ 50	15–35	25–50			
Existing OCGT (excluding turbines for mechanical drive applications) — All but plants operated < 500 h/yr	≥ 50	15–50	25–55 <sup>(148)</sup>			
<b>Combined-cycle gas turbines (CCGTs) <sup>(146)</sup> <sup>(149)</sup></b>						
New CCGT	≥ 50	10–30	15–40			

BAT Concn. Number	Summary of BAT Conclusion requirement				Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	
	Existing CCGT with a net total fuel utilisation of < 75 %	≥ 600	10–40	18–50			
	Existing CCGT with a net total fuel utilisation of ≥ 75 %	≥ 600	10–50	18–55 <sup>(150)</sup>			
	Existing CCGT with a net total fuel utilisation of < 75 %	50–600	10–45	35–55			
	Existing CCGT with a net total fuel utilisation of ≥ 75 %	50–600	25–50 <sup>(151)</sup>	35–55 <sup>(152)</sup>			
	<b>Open- and combined-cycle gas turbines</b>						
	Gas turbine put into operation no later than 27 November 2003, or existing gas turbine for emergency use and operated < 500 h/yr	≥ 50	No BAT-AEL	60–140 <sup>(153)</sup> <sup>(154)</sup>			
	Existing gas turbine for mechanical drive applications — All but plants operated < 500 h/yr	≥ 50	15–50 <sup>(155)</sup>	25–55 <sup>(156)</sup>			
	<p>As an indication, the yearly average CO emission levels for each type of existing combustion plant operated ≥ 1 500 h/yr and for each type of new combustion plant will generally be as follows:</p> <ul style="list-style-type: none"> <li>— New OCGT of ≥ 50 MW<sub>th</sub>: &lt; 5–40 mg/Nm<sup>3</sup>. For plants with a net electrical efficiency (EE) greater than 39 %, a correction factor may be applied to the higher end of this range, corresponding to [higher end] × EE/39, where EE is the net electrical energy efficiency or net mechanical energy efficiency of the plant determined at ISO baseload conditions.</li> <li>— Existing OCGT of ≥ 50 MW<sub>th</sub> (excluding turbines for mechanical drive applications): &lt; 5–40 mg/Nm<sup>3</sup>. The higher end of this range will generally be 80 mg/Nm<sup>3</sup> in the case of existing plants that cannot be fitted with dry techniques for NO<sub>x</sub> reduction, or 50 mg/Nm<sup>3</sup> for plants that operate at low load.</li> <li>— New CCGT of ≥ 50 MW<sub>th</sub>: &lt; 5–30 mg/Nm<sup>3</sup>. For plants with a net electrical efficiency (EE) greater than 55 %, a correction factor may be applied to the higher end of the range, corresponding to [higher end] × EE/55, where EE is the net electrical energy efficiency of the plant determined at ISO baseload conditions.</li> <li>— Existing CCGT of ≥ 50 MW<sub>th</sub>: &lt; 5–30 mg/Nm<sup>3</sup>. The higher end of this range will generally be 50 mg/Nm<sup>3</sup> for plants that operate at low load.</li> <li>— Existing gas turbines of ≥ 50 MW<sub>th</sub> for mechanical drive applications: &lt; 5–40 mg/Nm<sup>3</sup>. The higher end of the range will generally be 50 mg/Nm<sup>3</sup> when plants operate at low load.</li> </ul> <p>In the case of a gas turbine equipped with DLN burners, these indicative levels correspond to when the DLN operation is effective.</p>						

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																							
	<p><b>BAT-associated emission levels (BAT-AELs) for NO<sub>x</sub> emissions to air from the combustion of natural gas in boilers and engines</b></p> <table border="1" data-bbox="351 411 1397 635"> <thead> <tr> <th rowspan="3">Type of combustion plant</th> <th colspan="4">BAT-AELs (mg/Nm<sup>3</sup>)</th> </tr> <tr> <th colspan="2">Yearly average <sup>(157)</sup></th> <th colspan="2">Daily average or average over the sampling period</th> </tr> <tr> <th>New plant</th> <th>Existing plant <sup>(158)</sup></th> <th>New plant</th> <th>Existing plant <sup>(159)</sup></th> </tr> </thead> <tbody> <tr> <td>Boiler</td> <td>10–60</td> <td>50–100</td> <td>30–85</td> <td>85–110</td> </tr> <tr> <td>Engine <sup>(160)</sup></td> <td>20–75</td> <td>20–100</td> <td>55–85</td> <td>55–110 <sup>(161)</sup></td> </tr> </tbody> </table> <p>As an indication, the yearly average CO emission levels will generally be:</p> <ul style="list-style-type: none"> <li>— &lt; 5–40 mg/Nm<sup>3</sup> for existing boilers operated ≥ 1 500 h/yr,</li> <li>— &lt; 5–15 mg/Nm<sup>3</sup> for new boilers,</li> <li>— 30–100 mg/Nm<sup>3</sup> for existing engines operated ≥ 1 500 h/yr and for new engines.</li> </ul>	Type of combustion plant	BAT-AELs (mg/Nm <sup>3</sup> )				Yearly average <sup>(157)</sup>		Daily average or average over the sampling period		New plant	Existing plant <sup>(158)</sup>	New plant	Existing plant <sup>(159)</sup>	Boiler	10–60	50–100	30–85	85–110	Engine <sup>(160)</sup>	20–75	20–100	55–85	55–110 <sup>(161)</sup>		
Type of combustion plant	BAT-AELs (mg/Nm <sup>3</sup> )																									
	Yearly average <sup>(157)</sup>		Daily average or average over the sampling period																							
	New plant	Existing plant <sup>(158)</sup>	New plant	Existing plant <sup>(159)</sup>																						
Boiler	10–60	50–100	30–85	85–110																						
Engine <sup>(160)</sup>	20–75	20–100	55–85	55–110 <sup>(161)</sup>																						

## 6 Emissions to Water

All process waters are treated at the onsite effluent treatment plant before being discharge to sewer. Water arising from the storm water discharge point is also discharged to sewer. The discharge is subsequently treated at Anglian Water Sewage Treatment Works.

## **7 Additional IED Chapter II requirements:**

In the event of a black out National Grid would call on combustion plant to operate and may require them to do so outside their permitted conditions. We have dedicated black start plant and they are permitted to run as such but this scenario is relevant to the rest of the large combustion plant which could be called depending on the circumstances.

A risk assessment will be carried out by Energy UK/Joint Environmental Programme on behalf of Large Combustion Plant connected to the National Transmission System. Air emissions modelling will be based on generic black start scenarios to establish whether they have the potential to have local impact on the environment or not (on a national basis). If the modelling demonstrates that no significant impacts are likely, the plant can operate under condition 2.3.7. This conditions allows the hourly ELVs for plants operating under a black start instruction to be discounted for the purpose of reporting. We would also require there to be a procedure in place for minimisation of emissions in the case of a black start event and for reporting in the event of a black start. This modelling and the procedures have not been agreed in advance of the issue of the permit review and therefore a condition linking back to an improvement condition have been included in the permit.

## 8 Review and assessment of changes that are not part of the BAT Conclusions derived permit review.

This document should be read in conjunction with the application, supporting information and notice.

Aspect considered	Decision
<b>Receipt of application</b>	
Confidential information	A claim for commercial or industrial confidentiality has not been made.
Identifying confidential information	We have not identified information provided as part of the application that we consider to be confidential.
<b>Operating techniques</b>	
General operating techniques	<p>We have reviewed the techniques used by the operator where they are relevant to the BAT Conclusions and compared these with the relevant guidance notes.</p> <p>The permit conditions ensure compliance with the relevant BREF, BAT Conclusions. The ELVs deliver compliance with the BAT-AELs.</p>
<b>Permit conditions</b>	
Updating permit conditions during consolidation	We have updated permit conditions to those in the current generic permit template as part of permit consolidation. The conditions will provide at least the same level of protection as those in the previous permit and in some cases will provide a higher level of protection to those in the previous permit.
Changes to the permit conditions due to an Environment Agency initiated variation	We have varied the permit as stated in the variation notice.
Emission limits	<p>We have decided that emission limits should be set for the parameters listed in the permit.</p> <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p> <p>It is considered that the ELVs/equivalent parameters or technical measures described above will ensure that significant pollution of the environment is prevented and a high level of protection for the environment is secured.</p>



Aspect considered	Decision
Monitoring	<p>We have decided that monitoring should be carried out for the parameters listed in the permit, using the methods detailed and to the frequencies specified.</p> <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p> <p>Table S3.3 was amended to include the requirement to monitor energy efficiency</p> <p>Based on the information in the application we are satisfied that the operator's techniques, personnel and equipment have either MCERTS certification or MCERTS accreditation as appropriate.</p>
Reporting	<p>We have specified reporting in the permit for the following parameters:</p> <ul style="list-style-type: none"> <li>• Nitrogen dioxide</li> <li>• Carbon monoxide</li> </ul> <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p>
<b>Operator competence</b>	
Management system	<p>There is no known reason to consider that the operator will not have the management system to enable it to comply with the permit conditions.</p>
<b>Growth Duty</b>	
Section 108 Deregulation Act 2015 – Growth duty	<p>We have considered our duty to have regard to the desirability of promoting economic growth set out in section 108(1) of the Deregulation Act 2015 and the guidance issued under section 110 of that Act in deciding whether to grant this permit.</p> <p>Paragraph 1.3 of the guidance says:</p> <p>“The primary role of regulators, in delivering regulation, is to achieve the regulatory outcomes for which they are responsible. For a number of regulators, these regulatory outcomes include an explicit reference to development or growth. The growth duty establishes economic growth as a factor that all specified regulators should have regard to, alongside the delivery of the protections set out in the relevant legislation.”</p> <p>We have addressed the legislative requirements and environmental standards to be set for this operation in the body of the decision document above. The guidance is clear at paragraph 1.5 that the growth duty does not legitimise non-compliance and its purpose is not to achieve or pursue economic growth at the expense of necessary protections.</p> <p>We consider the requirements and standards we have set in this permit are reasonable and necessary to avoid a risk of an unacceptable level of pollution. This also promotes growth</p>

Aspect considered	Decision
	amongst legitimate operators because the standards applied to the operator are consistent across businesses in this sector and have been set to achieve the required legislative standards.