

Environment Agency

Review of an Environmental Permit for an Installation subject to Chapter II of the Industrial Emissions Directive under the Environmental Permitting (England & Wales) Regulations 2016

Decision document recording our decision-making process following review of a permit

The Permit number is: EPR/VP3538XX/V005
The Operator is: RWE Generation UK Plc
The Installation is: Staythorpe C Power Station
This Variation Notice number is: EPR/VP3538XX/V005

What this document is about

Article 21(3) of the Industrial Emissions Directive (IED) requires the Environment Agency to review conditions in permits that it has issued and to ensure that the permit delivers compliance with relevant standards, within four years of the publication of updated decisions on best available techniques (BAT) conclusions.

We have reviewed the permit for this installation against the revised BAT Conclusions for large combustion plant published on 17th August 2017. This is our decision document, which explains the reasoning for the consolidated variation notice that we are issuing.

It explains how we have reviewed and considered the techniques used by the Operator in the operation and control of the plant and activities of the installation. This review has been undertaken with reference to the decision made by the European Commission establishing best available techniques (BAT) conclusions ('BAT Conclusions') for large combustion plant as detailed in document reference IEDC-7-1. It is our record of our decision-making process and shows how we have taken into account all relevant factors in reaching our position. It also provides a justification for the inclusion of any specific conditions in the permit that are in addition to those included in our generic permit template.

As well as considering the review of the operating techniques used by the Operator for the operation of the plant and activities of the installation, the consolidated variation notice takes into account and brings together in a single document all previous variations that relate to the original permit

issued. It also modernises the entire permit to reflect the conditions contained in our current generic permit template.

The introduction of new template conditions makes the Permit consistent with our current general approach and philosophy and with other permits issued to installations in this sector. Although the wording of some conditions has changed, while others have been removed because of the new regulatory approach, it does not reduce the level of environmental protection achieved by the Permit in any way. In this document we therefore address only our determination of substantive issues relating to the new BAT Conclusions.

This is our record of our decision-making process and shows how we have taken into account all relevant factors in reaching our position.

Throughout this document we will use a number of expressions. These are as referred to in the glossary and have the same meaning as described in “Schedule 6 Interpretation” of the Permit.

We try to explain our decision as accurately, comprehensively and plainly as possible. We would welcome any feedback as to how we might improve our decision documents in future. A lot of technical terms and acronyms are inevitable in a document of this nature: we provide a glossary of acronyms near the front of the document, for ease of reference.

How this document is structured

Glossary of terms

- 1 Our decision
- 2 How we reached our decision
- 2.1 Requesting information to demonstrate compliance with BAT Conclusions for Large Combustion Plant
- 2.2 Review of our own information in respect to the capability of the installation to meet revised standards included in the BAT Conclusions document
- 3 The legal framework
- 4 Key Issues
- 4.1 Emissions to air and the emission limits applied to the plant.
- 4.2 The energy efficiency levels associated with the Best Available Techniques
- 4.3 Effective Dry low NO_x point
- 5 Decision checklist regarding relevant BAT Conclusions
- 6 Review and assessment of derogation requests made by the operator in relation to BAT Conclusions which include an associated emission level (AEL) value
- 7 Emissions to Water
- 8 Additional IED Chapter II requirements
- 9 Review and assessment of changes that are not part of the BAT Conclusions derived permit review.

Glossary of acronyms used in this document

(Please note that this glossary is standard for our decision documents and therefore not all these acronyms are necessarily used in this document.)

APC	Air Pollution Control
BAT	Best Available Technique(s)
BAT-AEEL	BAT Associated Energy Efficiency Level
BAT-AEL	BAT Associated Emission Level
BATc	BAT conclusion
BREF	Best available techniques reference document
CCGT	Combined Cycle Gas Turbine
CEM	Continuous emissions monitor
CHP	Combined heat and power
CV	Calorific value
DAA	Directly associated activity – Additional activities necessary to be carried out to allow the principal activity to be carried out
DLN	Dry Low NOx burners
DLN-E	Dry Low NOx effective
EIONET	European environment information and observation network is a partnership network of the European Environment Agency
ELV	Emission limit value derived under BAT or an emission limit value set out in IED
EMS	Environmental Management System
EPR	Environmental Permitting (England and Wales) Regulations 2016 (SI 2010 No. 1154)
EWC	European waste catalogue
FSA	Food Standards Agency
IED	Industrial Emissions Directive (2010/75/EU)
IPPCD	Integrated Pollution Prevention and Control Directive (2008/1/EC) – now superseded by IED
LCP	Large Combustion Plant subject to Chapter III of IED
MSUL/MSDL	Minimum start up load/minimum shut-down load
NOx	Oxides of nitrogen (NO plus NO ₂ expressed as NO ₂)
NPV	Net Present Value
PHE	Public Health England
SAC	Special Area of Conservation
SGN	Sector guidance note
TGN	Technical guidance note
TOC	Total Organic Carbon
WFD	Water Framework Directive (2000/60/EC)

1 Our decision

We have decided to issue the consolidated variation notice to the Operator. This will allow it to continue to operate the Installation, subject to the conditions in the consolidated variation notice.

We consider that, in reaching that decision, we have taken into account all relevant considerations and legal requirements and that the varied permit will ensure that a high level of protection is provided for the environment and human health.

The consolidated variation notice contains many conditions taken from our standard Environmental Permit template including the relevant Annexes. We developed these conditions in consultation with industry, having regard to the legal requirements of the Environmental Permitting Regulations and other relevant legislation. This document does not therefore include an explanation for these standard conditions. Where they are included in the Notice, we have considered the techniques identified by the operator for the operation of their installation, and have accepted that the details are sufficient and satisfactory to make those standard conditions appropriate. This document does, however, provide an explanation of our use of “tailor-made” or installation-specific conditions, or where our Permit template provides two or more options.

2 How we reached our decision

2.1 Requesting information to demonstrate compliance with BAT Conclusions for Large Combustion Plant

We issued a Notice under Regulation 61(1) of the Environmental Permitting (England and Wales) Regulations 2016 (a Regulation 61 Notice) on 1st May 2018 requiring the Operator to provide information to demonstrate how the operation of their installation currently meets, or will subsequently meet, the revised standards described in the large combustion plant BAT Conclusions document. The Notice also required that where the revised standards are not currently met, the operator should provide information that:

- Describes the techniques that will be implemented before 17th August 2021, which will then ensure that operations meet the revised standard, or
- Justifies why standards will not be met by 17th August 2021, and confirmation of the date when the operation of those processes will cease within the installation or an explanation of why the revised BAT standard is not applicable to those processes, or
- Justifies why an alternative technique will achieve the same level of environmental protection equivalent to the revised standard described in the BAT Conclusions.

Where the Operator proposed that they were not intending to meet a BAT standard that also included a BAT Associated Emission Level (BAT AEL) described in the BAT Conclusions Document, the Regulation 61 Notice requested that the Operator make a formal request for derogation from compliance with that AEL (as provisioned by Article 15(4) of IED). In this circumstance, the Notice identified that any such request for derogation must be supported and justified by sufficient technical and commercial information that would enable us to determine acceptability of the derogation request.

The Regulation 61 Notice response from the Operator was received on 1st November 2018. We considered it was in the correct form and contained sufficient information for us to begin our determination of the permit review but not that it necessarily contained all the information we would need to complete that review: see below.

We therefore issued a further information request to the Operator on 01/07/19. Suitable further information was provided by the Operator on 19/07/19.

We have not received any information in relation to the Regulation 61 Notice response that appears to be confidential in relation to any party.

2.2 Review of our own information in respect to the capability of the installation to meet revised standards included in the BAT Conclusions document

Based on our records and previous regulatory activities with the facility we have no reason to consider that the operator will not be able to comply with the conditions that we include in the permit.

3 The legal framework

The consolidated variation notice will be issued under Regulation 20 of the EPR. The Environmental Permitting regime is a legal vehicle which delivers most of the relevant legal requirements for activities falling within its scope. In particular, the regulated facility is:

- an *installation* as described by the IED;
- subject to aspects of other relevant legislation which also have to be addressed.

We consider that the consolidated variation notice will ensure that the operation of the Installation complies with all relevant legal requirements and that a high level of protection will be delivered for the environment and human health.

We explain how we have addressed specific statutory requirements more fully in the rest of this document.

4 The key issues

The key issues arising during this permit review are:

- Emissions to air and the emission limits applied to the plant.
- The energy efficiency levels associated with the Best Available Techniques (BAT-AEELs)
- Effective Dry Low NO_x point.

We therefore describe how we determined these issues in most detail in the relevant sections of this document.

4.1 Emissions to air and the emission limits applied to the plant

A number of general principles were applied during the permit review. These included:

- The upper value of the BAT AELs ranges specified were used unless use of the tighter limit was justified.
- The principle of no backsliding where if existing limits in the permit were already tighter than those specified in the BREF, the existing permit limits were retained.
- Where a limit was specified in both IED Annex V and the BAT Conclusions for a particular reference period, the tighter limit was applied and in the majority of cases this was from the BAT Conclusions.
- Where AELs are indicative in the BAT Conclusions, these were applied unless adequate justification was provided by the operator to demonstrate that an alternative limit was more appropriate.
- For gas turbines where the IED specified that limits applied over 70% load and the BAT Conclusions specified that AELs applied when dry low NO_x is effective (DLN-E), we have used DLN-E as a default across all monitoring requirements for NO_x and CO.

The LCPs on site consist of LCP No. 333, 334, 335 and 336. Combined Cycle Natural Gas Turbines.

The plant was put into operation before IED came into force and therefore the existing limits in the permit are from Part 1 of IED Annex V applicable to existing.

The ELVs and AELs are based on the following operating regime:

- Unlimited hours operation

The following tables outline the limits that have been incorporated into the permit for LCP 333, LCP 334, LCP 335 and LCP 336, where these were derived from and the reference periods at which they apply. The emission limits refer to concentrations, expressed as mass of emitted substance per

volume of flue-gas under the following standard conditions: dry gas at a temperature of 273,15 K, pressure of 101,3 kPa and 15% volume reference oxygen concentration if flue gases. The emission limits and monitoring requirements have been incorporated into Schedule 3 of the permit.

NOx limits (mg/Nm ³)						
Averaging	IED (Annex V Part 1) - Existing	BREF (Table 24 BAT-c)	Expected permit limits	Basis	Limits apply	Monitoring
Annual	None	40	42	BREF	DLN-E	Continuous
Monthly	50	None	50	IED	DLN-E	
Daily	55	50	50	IED	DLN-E	
Daily	55	50	60	IED	MSUL/MSDL	
95 th %ile of hr means	100	None	50	Existing Permit	DLN-E	

Annual NOx limit has been set as 42 mg/Nm³. This has been set based upon Table 24 footnote 8 in the BAT conclusions document using the energy efficiency figure of 57.77%, which is the average efficiency of the four gas turbines.

Daily NOx limit has been set as 60 mg/Nm³ for MSUL/MSDL to baseload and we accept that this is appropriate for this type of plant.

The emission limit of 50 mg/Nm³ was already set for the hourly average so that there is no backsliding in emission limits this has been retained in the permit.

CO limits (mg/Nm ³)						
Averaging	IED (Annex V Part 1) - Existing	BREF (after Table 24 BAT-c)	Expected permit limits	Basis	Limits apply	Monitoring
Annual	None	30	30	BREF	DLN-E	Continuous
Monthly	100	None	100	IED	DLN-E	
Daily	110	None	100	Existing Permit	DLN-E	
Daily	110	None	200	IED	MSUL/MSDL	
95 th %ile of hr means	200	None	100	Existing Permit	DLN-E	

Daily CO limit has been set as 100 mg/Nm³ for DLN-E so that there is no backsliding in emission limits this has been retained in the permit.

Daily CO limit has been set as 200 mg/Nm³ for MSUL/MSDL to baseload and we accept that this is appropriate for this type of plant.

Hourly CO limit has been set as 100 mg/Nm³ for DLN-E so that there is no backsliding in emission limits this has been retained in the permit.

4.2 The energy efficiency levels associated with the Best Available Techniques Conclusions

An energy efficiency level associated with the best available techniques (BAT-AEEL) refers to the ratio between the combustion unit's net energy output(s) and the combustion unit's fuel/feedstock energy input at actual unit design. The net energy output(s) is determined at the combustion unit boundaries, including auxiliary systems (e.g. flue-gas treatment systems), and for the unit operated at full load.

The table below sets out the BAT-AEELs specified in the LCP BAT Conclusions for the large combustion plant on the site and the energy efficiency levels confirmed through the Regulation 61 notice response. The evidence provided to demonstrate that the AEELs are met was in the form of the guarantee of performance test reports for the 4 gas turbines following the upgrades undertaken in 2014-2015. We consider this plant is BAT in relation to the AEELs.

BAT AEELs (%)			Plant efficiency (%)		
Net electrical efficiency	Net total fuel utilisation	Net mechanical efficiency	Net electrical efficiency	Net total fuel utilisation	Net mechanical efficiency
LCP333: unit description from the AEEL table					
50 - 60	None	None	57.69%	NA	NA
LCP334: unit description from the AEEL table					
50 - 60	None	None	57.77%	NA	NA
LCP335: unit description from the AEEL table					
50 - 60	None	None	57.78%	NA	NA
LCP336: unit description from the AEEL table					
50 - 60	None	None	57.84%	NA	NA

4.3 Effective Dry Low NO_x point.

The operator provided curves showing NO_x and CO emissions in order to demonstrate when the Dry Low NO_x (DLN) become effective (DLN-E). The DNL-E point put forward by the operator was 300MW. The graphs provided suggested that the DLN-E point could potentially be set lower at 195MW. Setting a lower DLN-E would mean monitoring of NO_x for some reference periods would begin earlier so we asked for justification for why a lower DLN-

E was not appropriate. The operator justified the higher DLN-E point because a significantly higher emission limit for CO would be needed for the higher DLN-E MWth. We agreed CO emissions of 250 mg/m³ would be too high, therefore, the DLN-E was left at 300MW as was applied for in the application.

5 Decision checklist regarding relevant BAT Conclusions

BAT Conclusions for large combustion plant, were published by the European Commission on 17th August 2017. There are 75 BAT Conclusions. Only the BAT Conclusions relevant to the particular fuel type used on site have been replicated below.

This annex provides a record of decisions made in relation to each relevant BAT Conclusion applicable to the installation. This annex should be read in conjunction with the Consolidated Variation Notice.

The conditions in the permit through which the relevant BAT Conclusions are implemented include but are not limited to the following:

BAT Conclusion requirement topic	Permit condition(s)	Permit table(s)
Environmental Management System	1.1.1	S1.2
BAT AELs	3.1.1 and 3.5.1	S3.1a
Monitoring	2.3, 3.5 and 3.6	S1.4, S1.2, S3.1a
Energy efficiency	1.2 and 2.3	S3.3
Noise	3.4 and 2.3	S2.1
Other operating techniques	2.3	S1.2

The overall status of compliance with the BAT conclusion is indicated in the table as:

- NA Not Applicable
- CC Currently Compliant
- FC Compliant in the future (within 4 years of publication of BAT conclusions)
- NC Not Compliant
- PC Partially Compliant

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
General			
1	<p>In order to improve the overall environmental performance, BAT is to implement and adhere to an environmental management system (EMS) that incorporates all of the following features:</p> <ul style="list-style-type: none"> i. commitment of the management, including senior management; ii. definition of an environmental policy that includes the continuous improvement of the installation by the management; iii. planning and establishing the necessary procedures, objectives and targets, in conjunction with financial planning and investment; iv. implementation of procedures <ul style="list-style-type: none"> (a) Structure and responsibility (b) Training (c) Communication (d) Employee involvement (e) Documentation (f) Efficient process control (g) Maintenance programmes (h) Emergency preparedness and response (i) Safeguarding compliance with environmental legislation v. checking performance and taking corrective action, paying particular attention to: <ul style="list-style-type: none"> (a) monitoring and measurement (see also the Reference Document on the General Principles of Monitoring) (b) corrective and preventive action (c) maintenance of records (d) independent (where practicable) internal and external auditing in order to determine whether or not the EMS conforms to planned arrangements and has been properly implemented and maintained; vi. review of the EMS and its continuing suitability, adequacy and effectiveness by senior management; vii. following the development of cleaner technologies; viii. consideration for the environmental impacts from the eventual decommissioning of the installation at the stage of designing a new plant, and throughout its operating life; viii. consideration for the environmental impacts from the eventual decommissioning of the installation at the stage of designing a new plant, and throughout its operating life; ix. application of sectoral benchmarking on a regular basis. 	CC	The installation has an Environment Management System (EMS). This is certified to ISO14001:2015 (approval number ISO14001-00012295).

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement													
	<p>Etc - see BAT Conclusions</p> <p>Applicability. The scope (e.g. level of detail) and nature of the EMS (e.g. standardised or non-standardised) will generally be related to the nature, scale and complexity of the installation, and the range of environmental impacts it may have.</p>															
2	<p>BAT is to determine the net electrical efficiency and/or the net total fuel utilisation and/or the net mechanical energy efficiency of the gasification, IGCC and/or combustion units by carrying out a performance test at full load (1), according to EN standards, after the commissioning of the unit and after each modification that could significantly affect the net electrical efficiency and/or the net total fuel utilisation and/or the net mechanical energy efficiency of the unit. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.</p>	CC	<p>The energy efficiency was determined when the site was first commissioned. The report has been provided The plant was upgraded between 2014-2015. The guarantee performance test report for each of the engines has been provided, which corroborates the energy efficiency figures quoted.</p>													
3	<p>BAT is to monitor key process parameters relevant for emissions to air and water including those given below.</p> <table border="1" data-bbox="322 778 1220 1024"> <thead> <tr> <th data-bbox="322 778 602 810">Stream</th> <th data-bbox="602 778 936 810">Parameter(s)</th> <th data-bbox="936 778 1220 810">Monitoring</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 810 602 970" rowspan="3">Flue-gas</td> <td data-bbox="602 810 936 874">Flow</td> <td data-bbox="936 810 1220 874">Periodic or continuous determination</td> </tr> <tr> <td data-bbox="602 874 936 938">Oxygen content, temperature, and pressure</td> <td data-bbox="936 874 1220 938">Periodic or continuous measurement</td> </tr> <tr> <td data-bbox="602 938 936 970">Water vapour content ⁽³⁾</td> <td data-bbox="936 938 1220 970"></td> </tr> <tr> <td data-bbox="322 970 602 1024">Waste water from flue-gas treatment</td> <td data-bbox="602 970 936 1024">Flow, pH, and temperature</td> <td data-bbox="936 970 1220 1024">Continuous measurement</td> </tr> </tbody> </table>	Stream	Parameter(s)	Monitoring	Flue-gas	Flow	Periodic or continuous determination	Oxygen content, temperature, and pressure	Periodic or continuous measurement	Water vapour content ⁽³⁾		Waste water from flue-gas treatment	Flow, pH, and temperature	Continuous measurement	CC	<p>The installation continuously monitors flue gas emissions from each LCP for flow, oxygen, temperature and pressure. The water vapour content is not measured in the flue gas as it is dried before analysis (this is stipulated under footnote 1 in BAT 3).</p>
Stream	Parameter(s)	Monitoring														
Flue-gas	Flow	Periodic or continuous determination														
	Oxygen content, temperature, and pressure	Periodic or continuous measurement														
	Water vapour content ⁽³⁾															
Waste water from flue-gas treatment	Flow, pH, and temperature	Continuous measurement														
4	<p>BAT is to monitor emissions to air with at least the frequency given below and in accordance with EN standards. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.</p> <table border="1" data-bbox="322 1155 1220 1375"> <thead> <tr> <th data-bbox="322 1155 439 1315">Substance/Parameter</th> <th data-bbox="439 1155 680 1315">Fuel/Process/Type of combustion plant</th> <th data-bbox="680 1155 797 1315">Combustion plant total rated thermal input</th> <th data-bbox="797 1155 936 1315">Standard(s) ⁽⁴⁾</th> <th data-bbox="936 1155 1102 1315">Minimum monitoring frequency ⁽⁵⁾</th> <th data-bbox="1102 1155 1220 1315">Monitoring associated with</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 1315 439 1375">NH₃</td> <td data-bbox="439 1315 680 1375">— When SCR and/or SNCR is used</td> <td data-bbox="680 1315 797 1375">All sizes</td> <td data-bbox="797 1315 936 1375">Generic EN standards</td> <td data-bbox="936 1315 1102 1375">Continuous ⁽⁶⁾ ⁽⁷⁾</td> <td data-bbox="1102 1315 1220 1375">BAT 7</td> </tr> </tbody> </table>	Substance/Parameter	Fuel/Process/Type of combustion plant	Combustion plant total rated thermal input	Standard(s) ⁽⁴⁾	Minimum monitoring frequency ⁽⁵⁾	Monitoring associated with	NH ₃	— When SCR and/or SNCR is used	All sizes	Generic EN standards	Continuous ⁽⁶⁾ ⁽⁷⁾	BAT 7	CC	<p>The installation monitors NO_x and CO on a continuous basis, which is in line with the requirements of BAT 4.</p>	
Substance/Parameter	Fuel/Process/Type of combustion plant	Combustion plant total rated thermal input	Standard(s) ⁽⁴⁾	Minimum monitoring frequency ⁽⁵⁾	Monitoring associated with											
NH ₃	— When SCR and/or SNCR is used	All sizes	Generic EN standards	Continuous ⁽⁶⁾ ⁽⁷⁾	BAT 7											

BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	NO _x	<ul style="list-style-type: none"> — Coal and/or lignite including waste co-incineration — Solid biomass and/or peat including waste co-incineration — HFO- and/or gas-oil-fired boilers and engines — Gas-oil-fired gas turbines — Natural-gas-fired boilers, engines, and turbines — Iron and steel process gases — Process fuels from the chemical industry — IGCC plants 	All sizes	Generic EN standards	Continuous ⁽⁶⁾ / ₍₈₎	BAT 20 BAT 24 BAT 28 BAT 32 BAT 37 BAT 41 BAT 42 BAT 43 BAT 47 BAT 48 BAT 56 BAT 64 BAT 65 BAT 73		
		<ul style="list-style-type: none"> — Combustion plants on offshore platforms 	All sizes	EN 14792	Once every year ⁽⁹⁾ / ₍₁₎	BAT 53		
	N ₂ O	<ul style="list-style-type: none"> — Coal and/or lignite in circulating fluidised bed boilers — Solid biomass and/or peat in circulating fluidised bed boilers 	All sizes	EN 21258	Once every year ⁽¹⁰⁾ / ₍₁₎	BAT 20 BAT 24		
	CO	<ul style="list-style-type: none"> — Coal and/or lignite including waste co-incineration — Solid biomass and/or peat including waste co-incineration 	All sizes	Generic EN standards	Continuous ⁽⁶⁾ / ₍₈₎	BAT 20 BAT 24 BAT 28 BAT 33 BAT 38 BAT 44 BAT 49 BAT 56 BAT 64		

BAT Concn. Number	Summary of BAT Conclusion requirement					Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	
		<ul style="list-style-type: none"> — HFO- and/or gas-oil-fired boilers and engines — Gas-oil-fired gas turbines — Natural-gas-fired boilers, engines, and turbines — Iron and steel process gases — Process fuels from the chemical industry — IGCC plants 				BAT 65 BAT 73		
	SO ₂	<ul style="list-style-type: none"> — Coal and/or lignite incl waste co-incineration — Solid biomass and/or peat incl waste co-incineration — HFO- and/or gas-oil-fired boilers — HFO- and/or gas-oil-fired engines — Gas-oil-fired gas turbines — Iron and steel process gases — Process fuels from the chemical industry in boilers — IGCC plants 	All sizes	Generic EN standards and EN 14791	Once every year ⁽⁹⁾	BAT 54		
					Continuous ⁽⁶⁾ ⁽¹¹⁾ ₍₁₂₎	BAT 21 BAT 25 BAT 29 BAT 34 BAT 39 BAT 50 BAT 57 BAT 66 BAT 67 BAT 74		

BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	SO ₃	— When SCR is used	All sizes	No EN standard available	Once every year	—		
	Gaseous chlorides, expressed as HCl	— Coal and/or lignite — Process fuels from the chemical industry in boilers	All sizes	EN 1911	Once every three months ⁽⁶⁾ ₍₁₃₎ ₍₁₄₎	BAT 21 BAT 57		
— Solid biomass and/or peat		All sizes	Generic EN standards	Continuous ⁽¹⁵⁾ ₍₁₆₎	BAT 25			
— Waste co-incineration		All sizes	Generic EN standards	Continuous ⁽⁶⁾ ₍₁₆₎	BAT 66 BAT 67			
	HF	— Coal and/or lignite — Process fuels from the chemical industry in boilers	All sizes	No EN standard available	Once every three months ⁽⁶⁾ ₍₁₃₎ ₍₁₄₎	BAT 21 BAT 57		
— Solid biomass and/or peat		All sizes	No EN standard available	Once every year	BAT 25			
— Waste co-incineration		All sizes	Generic EN standards	Continuous ⁽⁶⁾ ₍₁₆₎	BAT 66 BAT 67			
	Dust	— Coal and/or lignite	All sizes	Generic EN standards and EN 13284-1 and EN 13284-2	Continuous ⁽⁶⁾ ₍₁₇₎	BAT 22 BAT 26 BAT 30 BAT 35 BAT 39 BAT 51 BAT 58 BAT 75		
— Solid biomass and/or peat								
— HFO- and/or gas-oil-fired boilers								
— Iron and steel process gases								
— Process fuels from the chemical industry in boilers								
— IGCC plants								
— HFO- and/or gas-oil-fired engines								
— Gas-oil-fired gas turbines								

BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
		— Waste co-incineration	All sizes	Generic EN standards and EN 13284-2	Continuous	BAT 68 BAT 69		
	Metals and metalloids except mercury (As, Cd, Co, Cr, Cu, Mn, Ni, Pb, Sb, Se, Ti, V, Zn)	— Coal and/or lignite — Solid biomass and/or peat — HFO- and/or gas-oil-fired boilers and engines	All sizes	EN 14385	Once every year ₍₁₈₎	BAT 22 BAT 26 BAT 30		
— Waste co-incineration		< 300 MW _{th}	EN 14385	Once every six months ₍₁₃₎	BAT 68 BAT 69			
		≥ 300 MW _{th}	EN 14385	Once every three months ₍₁₉₎ ₍₁₃₎				
— IGCC plants		≥ 100 MW _{th}	EN 14385	Once every year ₍₁₈₎	BAT 75			
	Hg	— Coal and/or lignite including waste co-incineration	< 300 MW _{th}	EN 13211	Once every three months ₍₁₃₎ ₍₂₀₎	BAT 23		
		≥ 300 MW _{th}	Generic EN standards and EN 14884	Continuous ₍₁₆₎ ₍₂₁₎				
— Solid biomass and/or peat		All sizes	EN 13211	Once every year ₍₂₂₎	BAT 27			
— Waste co-incineration with solid biomass and/or peat		All sizes	EN 13211	Once every three months ₍₁₃₎	BAT 70			
	TVOC	— HFO- and/or gas-oil-fired engines — Process fuels from chemical industry in boilers	All sizes	EN 12619	Once every six months ₍₁₃₎	BAT 33 BAT 59		
— Waste co-incineration with coal, lignite, solid biomass and/or peat		All sizes	Generic EN standards	Continuous	BAT 71			

BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																												
	Formaldehyde	— Natural-gas in spark-ignited lean-burn gas and dual fuel engines	All sizes	No EN standard available	Once every year	BAT 45																														
	CH ₄	— Natural-gas-fired engines	All sizes	EN ISO 25139	Once every year ⁽²⁴⁾	BAT 45																														
	PCDD/F	— Process fuels from chemical industry in boilers — Waste co-incineration	All sizes	EN 1948-1, EN 1948-2, EN 1948-3	Once every six months ⁽¹³⁾ ⁽²⁵⁾	BAT 59 BAT 71																														
5	<p>BAT is to monitor emissions to water from flue-gas treatment with at least the frequency given below and in accordance with EN standards. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.</p> <table border="1" data-bbox="331 778 1211 1383"> <thead> <tr> <th data-bbox="331 778 584 863">Substance/Parameter</th> <th data-bbox="584 778 860 863">Standard(s)</th> <th data-bbox="860 778 1043 863">Minimum monitoring frequency</th> <th data-bbox="1043 778 1211 863">Monitoring associated with</th> </tr> </thead> <tbody> <tr> <td data-bbox="331 863 584 922">Total organic carbon (TOC)⁽²⁶⁾</td> <td data-bbox="584 863 860 922">EN 1484</td> <td data-bbox="860 863 1043 1383" rowspan="8">Once every month</td> <td data-bbox="1043 863 1211 1383" rowspan="8">BAT 15</td> </tr> <tr> <td data-bbox="331 922 584 981">Chemical oxygen demand (COD)⁽²⁶⁾</td> <td data-bbox="584 922 860 981">No EN standard available</td> </tr> <tr> <td data-bbox="331 981 584 1040">Total suspended solids (TSS)</td> <td data-bbox="584 981 860 1040">EN 872</td> </tr> <tr> <td data-bbox="331 1040 584 1099">Fluoride (F⁻)</td> <td data-bbox="584 1040 860 1099">EN ISO 10304-1</td> </tr> <tr> <td data-bbox="331 1099 584 1158">Sulphate (SO₄²⁻)</td> <td data-bbox="584 1099 860 1158">EN ISO 10304-1</td> </tr> <tr> <td data-bbox="331 1158 584 1217">Sulphide, easily released (S²⁻)</td> <td data-bbox="584 1158 860 1217">No EN standard available</td> </tr> <tr> <td data-bbox="331 1217 584 1276">Sulphite (SO₃²⁻)</td> <td data-bbox="584 1217 860 1276">EN ISO 10304-3</td> </tr> <tr> <td data-bbox="331 1276 584 1383">Metals and metalloids</td> <td data-bbox="584 1276 860 1383"> <table border="1" data-bbox="533 1217 860 1383"> <tr> <td data-bbox="533 1217 584 1246">As</td> <td data-bbox="584 1217 860 1383" rowspan="5">Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)</td> </tr> <tr> <td data-bbox="533 1246 584 1276">Cd</td> </tr> <tr> <td data-bbox="533 1276 584 1307">Cr</td> </tr> <tr> <td data-bbox="533 1307 584 1337">Cu</td> </tr> <tr> <td data-bbox="533 1337 584 1383">Ni</td> </tr> </table> </td> </tr> </tbody> </table>						Substance/Parameter	Standard(s)	Minimum monitoring frequency	Monitoring associated with	Total organic carbon (TOC) ⁽²⁶⁾	EN 1484	Once every month	BAT 15	Chemical oxygen demand (COD) ⁽²⁶⁾	No EN standard available	Total suspended solids (TSS)	EN 872	Fluoride (F ⁻)	EN ISO 10304-1	Sulphate (SO ₄ ²⁻)	EN ISO 10304-1	Sulphide, easily released (S ²⁻)	No EN standard available	Sulphite (SO ₃ ²⁻)	EN ISO 10304-3	Metals and metalloids	<table border="1" data-bbox="533 1217 860 1383"> <tr> <td data-bbox="533 1217 584 1246">As</td> <td data-bbox="584 1217 860 1383" rowspan="5">Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)</td> </tr> <tr> <td data-bbox="533 1246 584 1276">Cd</td> </tr> <tr> <td data-bbox="533 1276 584 1307">Cr</td> </tr> <tr> <td data-bbox="533 1307 584 1337">Cu</td> </tr> <tr> <td data-bbox="533 1337 584 1383">Ni</td> </tr> </table>	As	Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)	Cd	Cr	Cu	Ni	NA	There is no flue gas treatment at this installation.
Substance/Parameter	Standard(s)	Minimum monitoring frequency	Monitoring associated with																																	
Total organic carbon (TOC) ⁽²⁶⁾	EN 1484	Once every month	BAT 15																																	
Chemical oxygen demand (COD) ⁽²⁶⁾	No EN standard available																																			
Total suspended solids (TSS)	EN 872																																			
Fluoride (F ⁻)	EN ISO 10304-1																																			
Sulphate (SO ₄ ²⁻)	EN ISO 10304-1																																			
Sulphide, easily released (S ²⁻)	No EN standard available																																			
Sulphite (SO ₃ ²⁻)	EN ISO 10304-3																																			
Metals and metalloids	<table border="1" data-bbox="533 1217 860 1383"> <tr> <td data-bbox="533 1217 584 1246">As</td> <td data-bbox="584 1217 860 1383" rowspan="5">Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)</td> </tr> <tr> <td data-bbox="533 1246 584 1276">Cd</td> </tr> <tr> <td data-bbox="533 1276 584 1307">Cr</td> </tr> <tr> <td data-bbox="533 1307 584 1337">Cu</td> </tr> <tr> <td data-bbox="533 1337 584 1383">Ni</td> </tr> </table>			As	Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)	Cd	Cr	Cu	Ni																											
As	Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)																																			
Cd																																				
Cr																																				
Cu																																				
Ni																																				

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																				
	<table border="1"> <tr> <td data-bbox="331 336 533 405"></td> <td data-bbox="539 336 860 405">Pb</td> <td data-bbox="866 336 1048 405"></td> <td data-bbox="1055 336 1211 405"></td> </tr> <tr> <td data-bbox="331 410 533 512"></td> <td data-bbox="539 410 860 512">Zn</td> <td data-bbox="866 410 1048 512"></td> <td data-bbox="1055 410 1211 512"></td> </tr> <tr> <td data-bbox="331 517 533 619"></td> <td data-bbox="539 517 860 619">Hg</td> <td data-bbox="866 517 1048 619">Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)</td> <td data-bbox="1055 517 1211 619"></td> </tr> <tr> <td data-bbox="331 624 533 655">Chloride (Cl⁻)</td> <td data-bbox="539 624 860 655"></td> <td data-bbox="866 624 1048 655">Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)</td> <td data-bbox="1055 624 1211 655">—</td> </tr> <tr> <td data-bbox="331 660 533 667">Total nitrogen</td> <td data-bbox="539 660 860 667"></td> <td data-bbox="866 660 1048 667">EN 12260</td> <td data-bbox="1055 660 1211 667">—</td> </tr> </table>		Pb				Zn				Hg	Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)		Chloride (Cl ⁻)		Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)	—	Total nitrogen		EN 12260	—		
	Pb																						
	Zn																						
	Hg	Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)																					
Chloride (Cl ⁻)		Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)	—																				
Total nitrogen		EN 12260	—																				
6	<p>In order to improve the general environmental performance of combustion plants and to reduce emissions to air of CO and unburnt substances, BAT is to ensure optimised combustion and to use an appropriate combination of the techniques given below.</p> <table border="1"> <thead> <tr> <th data-bbox="331 772 510 804">Technique</th> <th data-bbox="517 772 837 804">Description</th> <th data-bbox="844 772 1211 804">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="331 809 510 938">a Fuel blending and mixing</td> <td data-bbox="517 809 837 938">Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type</td> <td data-bbox="844 809 1211 938">Generally applicable</td> </tr> <tr> <td data-bbox="331 943 510 1045">b Maintenance of the combustion system</td> <td data-bbox="517 943 837 1045">Regular planned maintenance according to suppliers' recommendations</td> <td data-bbox="844 943 1211 1045"></td> </tr> <tr> <td data-bbox="331 1050 510 1181">c Advanced control system</td> <td data-bbox="517 1050 837 1181">See description in Section 8.1</td> <td data-bbox="844 1050 1211 1181">The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> <tr> <td data-bbox="331 1185 510 1287">d Good design of the combustion equipment</td> <td data-bbox="517 1185 837 1287">Good design of furnace, combustion chambers, burners and associated devices</td> <td data-bbox="844 1185 1211 1287">Generally applicable to new combustion plants</td> </tr> <tr> <td data-bbox="331 1292 510 1367">e Fuel choice</td> <td data-bbox="517 1292 837 1367">Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with</td> <td data-bbox="844 1292 1211 1367">Applicable within the constraints associated with the availability of suitable types of fuel with a better</td> </tr> </tbody> </table>	Technique	Description	Applicability	a Fuel blending and mixing	Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type	Generally applicable	b Maintenance of the combustion system	Regular planned maintenance according to suppliers' recommendations		c Advanced control system	See description in Section 8.1	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system	d Good design of the combustion equipment	Good design of furnace, combustion chambers, burners and associated devices	Generally applicable to new combustion plants	e Fuel choice	Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with	Applicable within the constraints associated with the availability of suitable types of fuel with a better	CC	<p>The environmental performance of the combustion plant is optimised through the use of techniques b, c, d, e.</p> <p>B – Regular planned maintenance undertaken in accordance with supplier' recommendations. A planned programme of maintenance is in place based upon hours operated.</p> <p>C – Combustion conditions are continuously monitored allowing for early identification of potential issues and for optimisation of emissions.</p> <p>D – dry low NO_x burners are installed at the installation and are designed to minimise emissions.</p> <p>E – Natural gas is burnt from the national transmission system.</p>		
Technique	Description	Applicability																					
a Fuel blending and mixing	Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type	Generally applicable																					
b Maintenance of the combustion system	Regular planned maintenance according to suppliers' recommendations																						
c Advanced control system	See description in Section 8.1	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system																					
d Good design of the combustion equipment	Good design of furnace, combustion chambers, burners and associated devices	Generally applicable to new combustion plants																					
e Fuel choice	Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with	Applicable within the constraints associated with the availability of suitable types of fuel with a better																					

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement		
	<table border="1" style="width: 100%;"> <tr> <td style="width: 50%; vertical-align: top;"> <p>low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used</p> </td> <td style="width: 50%; vertical-align: top;"> <p>environmental profile as a whole, which may be impacted by the energy policy of the Member State, or by the integrated site's fuel balance in the case of combustion of industrial process fuels. For existing combustion plants, the type of fuel chosen may be limited by the configuration and the design of the plant</p> </td> </tr> </table>	<p>low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used</p>	<p>environmental profile as a whole, which may be impacted by the energy policy of the Member State, or by the integrated site's fuel balance in the case of combustion of industrial process fuels. For existing combustion plants, the type of fuel chosen may be limited by the configuration and the design of the plant</p>		
<p>low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used</p>	<p>environmental profile as a whole, which may be impacted by the energy policy of the Member State, or by the integrated site's fuel balance in the case of combustion of industrial process fuels. For existing combustion plants, the type of fuel chosen may be limited by the configuration and the design of the plant</p>				
7	<p>In order to reduce emissions of ammonia to air from the use of selective catalytic reduction (SCR) and/or selective non-catalytic reduction (SNCR) for the abatement of NO_x emissions, BAT is to optimise the design and/or operation of SCR and/or SNCR (e.g. optimised reagent to NO_x ratio, homogeneous reagent distribution and optimum size of the reagent drops).</p> <p>BAT-associated emission levels</p> <p>The BAT-associated emission level (BAT-AEL) for emissions of NH₃ to air from the use of SCR and/or SNCR is < 3–10 mg/Nm³ as a yearly average or average over the sampling period. The lower end of the range can be achieved when using SCR and the upper end of the range can be achieved when using SNCR without wet abatement techniques. In the case of plants combusting biomass and operating at variable loads as well as in the case of engines combusting HFO and/or gas oil, the higher end of the BAT-AEL range is 15 mg/Nm³.</p>	NA	The installation is not fitted with SCR or SNCR abatement. NO _x emissions are controlled through combustion optimisation.		
8	<p>In order to prevent or reduce emissions to air during normal operating conditions, BAT is to ensure, by appropriate design, operation and maintenance, that the emission abatement systems are used at optimal capacity and availability.</p>	NA	The installation is not fitted with abatement equipment.		
9	<p>In order to improve the general environmental performance of combustion and/or gasification plants and to reduce emissions to air, BAT is to include the following elements in the quality assurance/quality control programmes for all the fuels used, as part of the environmental management system (see BAT 1):</p> <ul style="list-style-type: none"> (i) Initial full characterisation of the fuel used including at least the parameters listed below and in accordance with EN standards. ISO, national or other international standards may be used provided they ensure the provision of data of an equivalent scientific quality; (ii) Regular testing of the fuel quality to check that it is consistent with the initial characterisation and according to the plant design specifications. The frequency of testing and the parameters chosen from the table below are based on the variability of the fuel 	CC	<p>At this installation fuel gas supplied to the site has been assessed in accordance with technique (i) and is continuously monitored in accordance with technique (ii) Measurement of HHV (which is used to derived LHV for performance calculations), CH₄, C₂H₆, C₃, C₄+, CO₂, N₂ and Wobbe index is carried out continuously using an online gas chromatograph which carries out calculations in accordance with ISO6976. The gas chromatograph is calibrated annually in accordance with ISO17025. The data supplied from the gas monitoring system is used to assess the performance of the plant in accordance with technique (iii)</p>		

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																						
	<p>and an assessment of the relevance of pollutant releases (e.g. concentration in fuel, flue-gas treatment employed);</p> <p>(iii) Subsequent adjustment of the plant settings as and when needed and practicable (e.g. integration of the fuel characterisation and control in the advanced control system (see description in Section 8.1)).</p> <p>Description Initial characterisation and regular testing of the fuel can be performed by the operator and/or the fuel supplier. If performed by the supplier, the full results are provided to the operator in the form of a product (fuel) supplier specification and/or guarantee.</p> <table border="1" data-bbox="322 587 1220 1374"> <thead> <tr> <th data-bbox="322 587 622 624">Fuel(s)</th> <th data-bbox="622 587 1220 624">Substances/Parameters subject to characterisation</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 624 622 826" rowspan="3">Biomass/peat</td> <td data-bbox="622 624 1220 660">— LHV</td> </tr> <tr> <td data-bbox="622 660 1220 703">— moisture</td> </tr> <tr> <td data-bbox="622 703 1220 826">— Ash — C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn)</td> </tr> <tr> <td data-bbox="322 826 622 1066" rowspan="4">Coal/lignite</td> <td data-bbox="622 826 1220 869">— LHV</td> </tr> <tr> <td data-bbox="622 869 1220 912">— Moisture</td> </tr> <tr> <td data-bbox="622 912 1220 956">— Volatiles, ash, fixed carbon, C, H, N, O, S</td> </tr> <tr> <td data-bbox="622 956 1220 1066">— Br, Cl, F — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)</td> </tr> <tr> <td data-bbox="322 1066 622 1150" rowspan="2">HFO</td> <td data-bbox="622 1066 1220 1109">— Ash</td> </tr> <tr> <td data-bbox="622 1109 1220 1150">— C, S, N, Ni, V</td> </tr> <tr> <td data-bbox="322 1150 622 1235" rowspan="2">Gas oil</td> <td data-bbox="622 1150 1220 1193">— Ash</td> </tr> <tr> <td data-bbox="622 1193 1220 1235">— N, C, S</td> </tr> <tr> <td data-bbox="322 1235 622 1319" rowspan="2">Natural gas</td> <td data-bbox="622 1235 1220 1278">— LHV</td> </tr> <tr> <td data-bbox="622 1278 1220 1319">— CH₄, C₂H₆, C₃, C₄+, CO₂, N₂, Wobbe index</td> </tr> <tr> <td data-bbox="322 1319 622 1374">Process fuels from the chemical industry⁽²⁷⁾</td> <td data-bbox="622 1319 1220 1374">— Br, C, Cl, F, H, N, O, S</td> </tr> </tbody> </table>	Fuel(s)	Substances/Parameters subject to characterisation	Biomass/peat	— LHV	— moisture	— Ash — C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn)	Coal/lignite	— LHV	— Moisture	— Volatiles, ash, fixed carbon, C, H, N, O, S	— Br, Cl, F — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)	HFO	— Ash	— C, S, N, Ni, V	Gas oil	— Ash	— N, C, S	Natural gas	— LHV	— CH ₄ , C ₂ H ₆ , C ₃ , C ₄ +, CO ₂ , N ₂ , Wobbe index	Process fuels from the chemical industry ⁽²⁷⁾	— Br, C, Cl, F, H, N, O, S		
Fuel(s)	Substances/Parameters subject to characterisation																								
Biomass/peat	— LHV																								
	— moisture																								
	— Ash — C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn)																								
Coal/lignite	— LHV																								
	— Moisture																								
	— Volatiles, ash, fixed carbon, C, H, N, O, S																								
	— Br, Cl, F — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)																								
HFO	— Ash																								
	— C, S, N, Ni, V																								
Gas oil	— Ash																								
	— N, C, S																								
Natural gas	— LHV																								
	— CH ₄ , C ₂ H ₆ , C ₃ , C ₄ +, CO ₂ , N ₂ , Wobbe index																								
Process fuels from the chemical industry ⁽²⁷⁾	— Br, C, Cl, F, H, N, O, S																								

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement						
	<table border="1"> <tr> <td data-bbox="327 328 622 400"></td> <td data-bbox="633 328 1216 400"> <ul style="list-style-type: none"> — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) </td> </tr> <tr> <td data-bbox="327 408 622 472">Iron and steel process gases</td> <td data-bbox="633 408 1216 472"> <ul style="list-style-type: none"> — LHV, CH₄ (for COG), C_xH_y (for COG), CO₂, H₂, N₂, total sulphur, dust, Wobbe index </td> </tr> <tr> <td data-bbox="327 480 622 652">Waste⁽²⁸⁾</td> <td data-bbox="633 480 1216 652"> <ul style="list-style-type: none"> — LHV — Moisture — Volatiles, ash, Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) </td> </tr> </table>		<ul style="list-style-type: none"> — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) 	Iron and steel process gases	<ul style="list-style-type: none"> — LHV, CH₄ (for COG), C_xH_y (for COG), CO₂, H₂, N₂, total sulphur, dust, Wobbe index 	Waste ⁽²⁸⁾	<ul style="list-style-type: none"> — LHV — Moisture — Volatiles, ash, Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) 		
	<ul style="list-style-type: none"> — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) 								
Iron and steel process gases	<ul style="list-style-type: none"> — LHV, CH₄ (for COG), C_xH_y (for COG), CO₂, H₂, N₂, total sulphur, dust, Wobbe index 								
Waste ⁽²⁸⁾	<ul style="list-style-type: none"> — LHV — Moisture — Volatiles, ash, Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) 								
10	<p>In order to reduce emissions to air and/or to water during other than normal operating conditions (OTNOC), BAT is to set up and implement a management plan as part of the environmental management system (see BAT 1), commensurate with the relevance of potential pollutant releases, that includes the following elements:</p> <ul style="list-style-type: none"> — appropriate design of the systems considered relevant in causing OTNOC that may have an impact on emissions to air, water and/or soil (e.g. low-load design concepts for reducing the minimum start-up and shutdown loads for stable generation in gas turbines), — set-up and implementation of a specific preventive maintenance plan for these relevant systems, — review and recording of emissions caused by OTNOC and associated circumstances and implementation of corrective actions if necessary, — periodic assessment of the overall emissions during OTNOC (e.g. frequency of events, duration, emissions quantification/estimation) and implementation of corrective actions if necessary. 	CC	<p>The installation does not have a specific OTNOC management plan. However, the requirements of BAT11 are met by existing management procedures. For example; gas turbine starts are optimised based on plant condition (i.e. warmth category) to minimise emissions during start-up. All plant components are included within the site specific preventative maintenance programmes. The frequency of maintenance is dependent on component duty. Emissions during start-up and shutdown operations are monitored and reviewed to identify if corrective actions are required. Emissions to air and water are assessed as part of the annual environmental performance report. In the event of an accident or environmental incident, we would review the emissions, cause etc. as part of our incident investigation process and ensure any relevant corrective and / or preventive action is implemented.</p>						
11	<p>BAT is to appropriately monitor emissions to air and/or to water during OTNOC.</p> <p>Description</p> <p>The monitoring can be carried out by direct measurement of emissions or by monitoring of surrogate parameters if this proves to be of equal or better scientific quality than the direct measurement of emissions. Emissions during start-up and shutdown (SU/SD) may be assessed based on a detailed emission measurement carried out for a typical SU/SD procedure at least once every year, and using the results of this measurement to estimate the emissions for each and every SU/SD throughout the year.</p>	CC	<p>Monitoring equipment for emissions to air and water is fully operable when installation is discharging to the environment. It is not affected by OTNOC events.</p>						

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																								
12	In order to increase the energy efficiency of combustion, gasification and/or IGCC units operated $\geq 1\,500$ h/yr, BAT is to use an appropriate combination of the techniques given below.			CC	<p>The installations uses a combination of techniques a, b, c, d, f, g and h.</p> <p>Combustion is optimised through</p> <ul style="list-style-type: none"> -regular planned maintenance undertaken in accordance with supplier' recommendations. -Combustion conditions are continuously monitored allowing for early identification of potential issues and for optimisation of emissions. - Dry low NO_x burners are installed at the installation and are designed to minimise emissions. - Natural gas is burnt from the national transmission system. 																								
<table border="1"> <thead> <tr> <th data-bbox="324 416 360 443">Technique</th> <th data-bbox="367 416 891 443">Description</th> <th data-bbox="898 416 1218 443">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="324 448 360 576">a.</td> <td data-bbox="367 448 891 576">Combustion optimisation See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues</td> <td data-bbox="898 448 1218 576">Generally applicable</td> </tr> <tr> <td data-bbox="324 580 360 762">b.</td> <td data-bbox="367 580 891 762">Optimisation of the working medium conditions Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO_x emissions or the characteristics of energy demanded</td> <td data-bbox="898 580 1218 762"></td> </tr> <tr> <td data-bbox="324 767 360 895">c.</td> <td data-bbox="367 767 891 895">Optimisation of the steam cycle Operate with lower turbine exhaust pressure by utilisation of the lowest possible temperature of the condenser cooling water, within the design conditions</td> <td data-bbox="898 767 1218 895"></td> </tr> <tr> <td data-bbox="324 900 360 979">d.</td> <td data-bbox="367 900 891 979">Minimisation of energy consumption Minimising the internal energy consumption (e.g. greater efficiency of the feed-water pump)</td> <td data-bbox="898 900 1218 979"></td> </tr> <tr> <td data-bbox="324 984 360 1064">e.</td> <td data-bbox="367 984 891 1064">Preheating of combustion air Reuse of part of the heat recovered from the combustion flue-gas to preheat the air used in combustion</td> <td data-bbox="898 984 1218 1064">Generally applicable within the constraints related to the need to control NO_x emissions</td> </tr> <tr> <td data-bbox="324 1069 360 1171">f.</td> <td data-bbox="367 1069 891 1171">Fuel preheating Preheating of fuel using recovered heat</td> <td data-bbox="898 1069 1218 1171">Generally applicable within the constraints associated with the boiler design and the need to control NO_xemissions</td> </tr> <tr> <td data-bbox="324 1176 360 1326">g.</td> <td data-bbox="367 1176 891 1326">Advanced control system See description in Section 8.2. Computerised control of the main combustion parameters enables the combustion efficiency to be improved</td> <td data-bbox="898 1176 1218 1326">Generally applicable to new units. The applicability to old units may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> </tbody> </table>						Technique	Description	Applicability	a.	Combustion optimisation See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues	Generally applicable	b.	Optimisation of the working medium conditions Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO _x emissions or the characteristics of energy demanded		c.	Optimisation of the steam cycle Operate with lower turbine exhaust pressure by utilisation of the lowest possible temperature of the condenser cooling water, within the design conditions		d.	Minimisation of energy consumption Minimising the internal energy consumption (e.g. greater efficiency of the feed-water pump)		e.	Preheating of combustion air Reuse of part of the heat recovered from the combustion flue-gas to preheat the air used in combustion	Generally applicable within the constraints related to the need to control NO _x emissions	f.	Fuel preheating Preheating of fuel using recovered heat	Generally applicable within the constraints associated with the boiler design and the need to control NO _x emissions	g.	Advanced control system See description in Section 8.2. Computerised control of the main combustion parameters enables the combustion efficiency to be improved	Generally applicable to new units. The applicability to old units may be constrained by the need to retrofit the combustion system and/or control command system
Technique	Description	Applicability																											
a.	Combustion optimisation See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues	Generally applicable																											
b.	Optimisation of the working medium conditions Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO _x emissions or the characteristics of energy demanded																												
c.	Optimisation of the steam cycle Operate with lower turbine exhaust pressure by utilisation of the lowest possible temperature of the condenser cooling water, within the design conditions																												
d.	Minimisation of energy consumption Minimising the internal energy consumption (e.g. greater efficiency of the feed-water pump)																												
e.	Preheating of combustion air Reuse of part of the heat recovered from the combustion flue-gas to preheat the air used in combustion	Generally applicable within the constraints related to the need to control NO _x emissions																											
f.	Fuel preheating Preheating of fuel using recovered heat	Generally applicable within the constraints associated with the boiler design and the need to control NO _x emissions																											
g.	Advanced control system See description in Section 8.2. Computerised control of the main combustion parameters enables the combustion efficiency to be improved	Generally applicable to new units. The applicability to old units may be constrained by the need to retrofit the combustion system and/or control command system																											

BAT Concn. Numbe r	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	h.	Feed-water preheating using recovered heat	Preheat water coming out of the steam condenser with recovered heat, before reusing it in the boiler	Only applicable to steam circuits and not to hot boilers. Applicability to existing units may be limited due to constraints associated with the plant configuration and the amount of recoverable heat	
	i.	Heat recovery by cogeneration (CHP)	Recovery of heat (mainly from the steam system) for producing hot water/steam to be used in industrial processes/activities or in a public network for district heating. Additional heat recovery is possible from: — flue-gas — grate cooling — circulating fluidised bed	Applicable within the constraints associated with the local heat and power demand. The applicability may be limited in the case of gas compressors with an unpredictable operational heat profile	
	j.	CHP readiness	See description in Section 8.2.	Only applicable to new units where there is a realistic potential for the future use of heat in the vicinity of the unit	
	k.	Flue-gas condenser	See description in Section 8.2.	Generally applicable to CHP units provided there is enough demand for low-temperature heat	
	l.	Heat accumulation	Heat accumulation storage in CHP mode	Only applicable to CHP plants. The applicability may be limited in the case of low heat load demand	
	m.	Wet stack	See description in Section 8.2.	Generally applicable to new and existing units fitted with wet FGD	
	n.	Cooling tower discharge	The release of emissions to air through a cooling tower and not via a dedicated stack	Only applicable to units fitted with wet FGD where reheating of the flue-gas is necessary before release, and where the unit cooling system is a cooling tower	
	o.	Fuel pre-drying	The reduction of fuel moisture content before combustion to improve combustion conditions	Applicable to the combustion of biomass and/or peat within the constraints associated with	

BAT Concn. Number	Summary of BAT Conclusion requirement				Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
				<p>spontaneous combustion risks (e.g. the moisture content of peat is kept above 40 % throughout the delivery chain).</p> <p>The retrofit of existing plants may be restricted by the extra calorific value that can be obtained from the drying operation and by the limited retrofit possibilities offered by some boiler designs or plant configurations</p>		
	p.	Minimisation of heat losses	Minimising residual heat losses, e.g. those that occur via the slag or those that can be reduced by insulating radiating sources	Only applicable to solid-fuel-fired combustion units and to gasification/IGCC units		
	q.	Advanced materials	Use of advanced materials proven to be capable of withstanding high operating temperatures and pressures and thus to achieve increased steam/combustion process efficiencies	Only applicable to new plants		
	r.	Steam turbine upgrades	This includes techniques such as increasing the temperature and pressure of medium-pressure steam, addition of a low-pressure turbine, and modifications to the geometry of the turbine rotor blades	The applicability may be restricted by demand, steam conditions and/or limited plant lifetime		
	s.	Supercritical and ultra-supercritical steam conditions	Use of a steam circuit, including steam reheating systems, in which steam can reach pressures above 220,6 bar and temperatures above 374 °C in the case of supercritical conditions, and above 250 – 300 bar and temperatures above 580 – 600 °C in the case of ultra-supercritical conditions	<p>Only applicable to new units of $\geq 600 \text{ MW}_{th}$ operated $> 4\,000 \text{ h/yr}$.</p> <p>Not applicable when the purpose of the unit is to produce low steam temperatures and/or pressures in process industries.</p> <p>Not applicable to gas turbines and engines generating steam in CHP mode.</p> <p>For units combusting biomass, the applicability may be constrained by high-temperature</p>		

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement									
	<table border="1"> <tr> <td data-bbox="322 330 360 391"></td> <td data-bbox="367 330 521 391"></td> <td data-bbox="528 330 891 391"></td> <td data-bbox="898 330 1220 391">corrosion in the case of certain biomasses</td> </tr> </table>				corrosion in the case of certain biomasses							
			corrosion in the case of certain biomasses									
13	<p>In order to reduce water usage and the volume of contaminated waste water discharged, BAT is to use one or both of the techniques given below.</p> <table border="1"> <thead> <tr> <th data-bbox="322 464 479 496">Technique</th> <th data-bbox="486 464 891 496">Description</th> <th data-bbox="898 464 1220 496">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 501 479 655">a. Water recycling</td> <td data-bbox="486 501 891 655">Residual aqueous streams, including run-off water, from the plant are reused for other purposes. The degree of recycling is limited by the quality requirements of the recipient water stream and the water balance of the plant</td> <td data-bbox="898 501 1220 655">Not applicable to waste water from cooling systems when water treatment chemicals and/or high concentrations of salts from seawater are present</td> </tr> <tr> <td data-bbox="322 660 479 815">b. Dry bottom ash handling</td> <td data-bbox="486 660 891 815">Dry, hot bottom ash falls from the furnace onto a mechanical conveyor system and is cooled down by ambient air. No water is used in the process.</td> <td data-bbox="898 660 1220 815">Only applicable to plants combusting solid fuels. There may be technical restrictions that prevent retrofitting to existing combustion plants</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Water recycling	Residual aqueous streams, including run-off water, from the plant are reused for other purposes. The degree of recycling is limited by the quality requirements of the recipient water stream and the water balance of the plant	Not applicable to waste water from cooling systems when water treatment chemicals and/or high concentrations of salts from seawater are present	b. Dry bottom ash handling	Dry, hot bottom ash falls from the furnace onto a mechanical conveyor system and is cooled down by ambient air. No water is used in the process.	Only applicable to plants combusting solid fuels. There may be technical restrictions that prevent retrofitting to existing combustion plants	CC	<p>Boiler feed water is optimised by minimising blow down from the water steam cycle. Water usage is also minimised by optimising the cooling tower cycles of concentration.</p> <p>Water that cannot be re-circulated within the cooling system is re-used in other processes on site.</p>
Technique	Description	Applicability										
a. Water recycling	Residual aqueous streams, including run-off water, from the plant are reused for other purposes. The degree of recycling is limited by the quality requirements of the recipient water stream and the water balance of the plant	Not applicable to waste water from cooling systems when water treatment chemicals and/or high concentrations of salts from seawater are present										
b. Dry bottom ash handling	Dry, hot bottom ash falls from the furnace onto a mechanical conveyor system and is cooled down by ambient air. No water is used in the process.	Only applicable to plants combusting solid fuels. There may be technical restrictions that prevent retrofitting to existing combustion plants										
14	<p>In order to prevent the contamination of uncontaminated waste water and to reduce emissions to water, BAT is to segregate waste water streams and to treat them separately, depending on the pollutant content.</p> <p>Description Waste water streams that are typically segregated and treated include surface run-off water, cooling water, and waste water from flue-gas treatment.</p> <p>Applicability The applicability may be restricted in the case of existing plants due to the configuration of the drainage systems.</p>	CC	<p>All water from the installation discharges via a single point referred to as W1. However, all water streams are kept separate.</p> <p>Surface water drains treat water via an oil interceptor prior to discharge.</p> <p>Effluent is treated in a water treatment plant and is monitored prior to discharge.</p> <p>Cooling water is again monitored prior to discharge.</p>									
15	<p>In order to reduce emissions to water from flue-gas treatment, BAT is to use an appropriate combination of the techniques given below, and to use secondary techniques as close as possible to the source in order to avoid dilution.</p> <table border="1"> <thead> <tr> <th data-bbox="322 1182 622 1241">Technique</th> <th data-bbox="629 1182 860 1241">Typical pollutants prevented/abated</th> <th data-bbox="866 1182 1220 1241">Applicability</th> </tr> </thead> <tbody> <tr> <td colspan="3" data-bbox="322 1246 1220 1278" style="text-align: center;">Primary techniques</td> </tr> <tr> <td data-bbox="322 1283 622 1385">a. Optimised combustion (see BAT 6) and flue-gas treatment systems (e.g. SCR/SNCR, see BAT 7)</td> <td data-bbox="629 1283 860 1385">Organic compounds, ammonia (NH₃)</td> <td data-bbox="866 1283 1220 1385">Generally applicable</td> </tr> </tbody> </table>	Technique	Typical pollutants prevented/abated	Applicability	Primary techniques			a. Optimised combustion (see BAT 6) and flue-gas treatment systems (e.g. SCR/SNCR, see BAT 7)	Organic compounds, ammonia (NH ₃)	Generally applicable	NA	<p>The installation does not use flue gas treatment.</p>
Technique	Typical pollutants prevented/abated	Applicability										
Primary techniques												
a. Optimised combustion (see BAT 6) and flue-gas treatment systems (e.g. SCR/SNCR, see BAT 7)	Organic compounds, ammonia (NH ₃)	Generally applicable										

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	Secondary techniques ⁽²⁹⁾		
	b. Adsorption on activated carbon	Organic compounds, mercury (Hg)	Generally applicable
	c. Aerobic biological treatment	Biodegradable organic compounds, ammonium (NH ₄ ⁺)	Generally applicable for the treatment of organic compounds. Aerobic biological treatment of ammonium (NH ₄ ⁺) may not be applicable in the case of high chloride concentrations (i.e. around 10 g/l)
	d. Anoxic/anaerobic biological treatment	Mercury (Hg), nitrate (NO ₃ ⁻), nitrite (NO ₂ ⁻)	Generally applicable
	e. Coagulation and flocculation	Suspended solids	Generally applicable
	f. Crystallisation	Metals and metalloids, sulphate (SO ₄ ²⁻), fluoride (F ⁻)	Generally applicable
	g. Filtration (e.g. sand filtration, microfiltration, ultrafiltration)	Suspended solids, metals	Generally applicable
	h. Flotation	Suspended solids, free oil	Generally applicable
	i. Ion exchange	Metals	Generally applicable
	j. Neutralisation	Acids, alkalis	Generally applicable
	k. Oxidation	Sulphide (S ²⁻), sulphite (SO ₃ ²⁻)	Generally applicable
	l. Precipitation	Metals and metalloids, sulphate (SO ₄ ²⁻), fluoride (F ⁻)	Generally applicable
	m. Sedimentation	Suspended solids	Generally applicable
	n. Stripping	Ammonia (NH ₃)	Generally applicable
	The BAT-AELs refer to direct discharges to a receiving water body at the point where the emission leaves the installation.		
	BAT-AELs for direct discharges to a receiving water body from flue-gas treatment		
	Substance/Parameter		BAT-AELs

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																																									
	<table border="1"> <thead> <tr> <th colspan="2"></th> <th>Daily average</th> </tr> </thead> <tbody> <tr> <td colspan="2">Total organic carbon (TOC)</td> <td>20–50 mg/l _(³⁰) _(³¹) _(³²)</td> </tr> <tr> <td colspan="2">Chemical oxygen demand (COD)</td> <td>60–150 mg/l _(³⁰) _(³¹) _(³²)</td> </tr> <tr> <td colspan="2">Total suspended solids (TSS)</td> <td>10–30 mg/l</td> </tr> <tr> <td colspan="2">Fluoride (F⁻)</td> <td>10–25 mg/l _(³²)</td> </tr> <tr> <td colspan="2">Sulphate (SO₄²⁻)</td> <td>1,3–2,0 g/l _(³²) _(³³) _(³⁴) _(³⁵)</td> </tr> <tr> <td colspan="2">Sulphide (S²⁻), easily released</td> <td>0,1–0,2 mg/l _(³²)</td> </tr> <tr> <td colspan="2">Sulphite (SO₃²⁻)</td> <td>1–20 mg/l _(³²)</td> </tr> <tr> <td rowspan="8">Metals and metalloids</td> <td>As</td> <td>10–50 µg/l</td> </tr> <tr> <td>Cd</td> <td>2–5 µg/l</td> </tr> <tr> <td>Cr</td> <td>10–50 µg/l</td> </tr> <tr> <td>Cu</td> <td>10–50 µg/l</td> </tr> <tr> <td>Hg</td> <td>0,2–3 µg/l</td> </tr> <tr> <td>Ni</td> <td>10–50 µg/l</td> </tr> <tr> <td>Pb</td> <td>10–20 µg/l</td> </tr> <tr> <td>Zn</td> <td>50–200 µg/l</td> </tr> </tbody> </table>			Daily average	Total organic carbon (TOC)		20–50 mg/l _(³⁰) _(³¹) _(³²)	Chemical oxygen demand (COD)		60–150 mg/l _(³⁰) _(³¹) _(³²)	Total suspended solids (TSS)		10–30 mg/l	Fluoride (F ⁻)		10–25 mg/l _(³²)	Sulphate (SO ₄ ²⁻)		1,3–2,0 g/l _(³²) _(³³) _(³⁴) _(³⁵)	Sulphide (S ²⁻), easily released		0,1–0,2 mg/l _(³²)	Sulphite (SO ₃ ²⁻)		1–20 mg/l _(³²)	Metals and metalloids	As	10–50 µg/l	Cd	2–5 µg/l	Cr	10–50 µg/l	Cu	10–50 µg/l	Hg	0,2–3 µg/l	Ni	10–50 µg/l	Pb	10–20 µg/l	Zn	50–200 µg/l		
		Daily average																																										
Total organic carbon (TOC)		20–50 mg/l _(³⁰) _(³¹) _(³²)																																										
Chemical oxygen demand (COD)		60–150 mg/l _(³⁰) _(³¹) _(³²)																																										
Total suspended solids (TSS)		10–30 mg/l																																										
Fluoride (F ⁻)		10–25 mg/l _(³²)																																										
Sulphate (SO ₄ ²⁻)		1,3–2,0 g/l _(³²) _(³³) _(³⁴) _(³⁵)																																										
Sulphide (S ²⁻), easily released		0,1–0,2 mg/l _(³²)																																										
Sulphite (SO ₃ ²⁻)		1–20 mg/l _(³²)																																										
Metals and metalloids	As	10–50 µg/l																																										
	Cd	2–5 µg/l																																										
	Cr	10–50 µg/l																																										
	Cu	10–50 µg/l																																										
	Hg	0,2–3 µg/l																																										
	Ni	10–50 µg/l																																										
	Pb	10–20 µg/l																																										
	Zn	50–200 µg/l																																										
16	<p>In order to reduce the quantity of waste sent for disposal from the combustion and/or gasification process and abatement techniques, BAT is to organise operations so as to maximise, in order of priority and taking into account life-cycle thinking:</p> <p>(a) waste prevention, e.g. maximise the proportion of residues which arise as by-products;</p> <p>(b) waste preparation for reuse, e.g. according to the specific requested quality criteria;</p> <p>(c) waste recycling;</p> <p>(d) other waste recovery (e.g. energy recovery),</p> <p>by implementing an appropriate combination of techniques such as:</p> <table border="1"> <thead> <tr> <th>Technique</th> <th>Description</th> <th>Applicability</th> </tr> </thead> <tbody> <tr> <td>a . Generation of gypsum as a by-product</td> <td>Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g.</td> <td>Generally applicable within the constraints associated with the required gypsum quality, the health requirements associated</td> </tr> </tbody> </table>	Technique	Description	Applicability	a . Generation of gypsum as a by-product	Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g.	Generally applicable within the constraints associated with the required gypsum quality, the health requirements associated	CC	None of the waste products specified are produced during the combustion process at this installation. All other wastes generated at the site are dealt with according to the waste hierarchy.																																			
Technique	Description	Applicability																																										
a . Generation of gypsum as a by-product	Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g.	Generally applicable within the constraints associated with the required gypsum quality, the health requirements associated																																										

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement						
		as raw material in the plasterboard industry). The quality of limestone used in the wet FGD influences the purity of the gypsum produced	to each specific use, and by the market conditions								
	b. Recycling or recovery of residues in the construction sector	Recycling or recovery of residues (e.g. from semi-dry desulphurisation processes, fly ash, bottom ash) as a construction material (e.g. in road building, to replace sand in concrete production, or in the cement industry)	Generally applicable within the constraints associated with the required material quality (e.g. physical properties, content of harmful substances) associated to each specific use, and by the market conditions								
	c. Energy recovery by using waste in the fuel mix	The residual energy content of carbon-rich ash and sludges generated by the combustion of coal, lignite, heavy fuel oil, peat or biomass can be recovered for example by mixing with the fuel	Generally applicable where plants can accept waste in the fuel mix and are technically able to feed the fuels into the combustion chamber								
	d. Preparation of spent catalyst for reuse	Preparation of catalyst for reuse (e.g. up to four times for SCR catalysts) restores some or all of the original performance, extending the service life of the catalyst to several decades. Preparation of spent catalyst for reuse is integrated in a catalyst management scheme	The applicability may be limited by the mechanical condition of the catalyst and the required performance with respect to controlling NO _x and NH ₃ emissions								
17	In order to reduce noise emissions, BAT is to use one or a combination of the techniques given below.			CC	Noise emissions are reduced by the application of techniques a, b, c, d and e. Further details included in documents as below. -Noise and Vibration Monitoring Plan ENV/350/2009 -Noise Monitoring Programme for Operation of Staythorpe C Power Station ENV/346/2009, Noise Improvement and Action Plan STY/RPT/0023/012						
	<table border="1"> <thead> <tr> <th data-bbox="324 1045 353 1066">Technique</th> <th data-bbox="360 1045 508 1066">Description</th> <th data-bbox="515 1045 1218 1066">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="324 1070 353 1342">a. Operational measures</td> <td data-bbox="360 1070 508 1342"> These include: <ul style="list-style-type: none"> — improved inspection and maintenance of equipment — closing of doors and windows of enclosed areas, if possible — equipment operated by experienced staff — avoidance of noisy activities at night, if possible </td> <td data-bbox="515 1070 1218 1342">Generally applicable</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Operational measures	These include: <ul style="list-style-type: none"> — improved inspection and maintenance of equipment — closing of doors and windows of enclosed areas, if possible — equipment operated by experienced staff — avoidance of noisy activities at night, if possible 	Generally applicable				
Technique	Description	Applicability									
a. Operational measures	These include: <ul style="list-style-type: none"> — improved inspection and maintenance of equipment — closing of doors and windows of enclosed areas, if possible — equipment operated by experienced staff — avoidance of noisy activities at night, if possible 	Generally applicable									

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement							
		— provisions for noise control during maintenance activities										
	b. Low-noise equipment	This potentially includes compressors, pumps and disks	Generally applicable when the equipment is new or replaced									
	c. Noise attenuation	Noise propagation can be reduced by inserting obstacles between the emitter and the receiver. Appropriate obstacles include protection walls, embankments and buildings	Generally applicable to new plants. In the case of existing plants, the insertion of obstacles may be restricted by lack of space									
	d. Noise-control equipment	This includes: — noise-reducers — equipment insulation — enclosure of noisy equipment — soundproofing of buildings	The applicability may be restricted by lack of space									
	e. Appropriate location of equipment and buildings	Noise levels can be reduced by increasing the distance between the emitter and the receiver and by using buildings as noise screens	Generally applicable to new plant									
40	In order to increase the energy efficiency of natural gas combustion, BAT is to use an appropriate combination of the techniques given in BAT 12 and below.			CC	<p>The installations uses a combination of techniques a, b, c, d, f, g and h.</p> <p>Combustion is optimised through</p> <ul style="list-style-type: none"> -regular planned maintenance undertaken in accordance with supplier' recommendations. -Combustion conditions are continuously monitored allowing for early identification of potential issues and for optimisation of emissions. - Dry low NOx burners are installed at the installation and are designed to minimise emissions. - Natural gas is burnt from the national transmission system. <p>The BAT-AEEL for each of the gas turbines are within the specified range of 50-60% as required for an existing CCGT greater than or equal to 600MWe. See section 4.2 of this document.</p>							
	<table border="1"> <thead> <tr> <th data-bbox="322 968 459 1023">Technique</th> <th data-bbox="472 968 636 1023">Description</th> <th data-bbox="642 968 1220 1023">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 1027 459 1358">a. Combined cycle</td> <td data-bbox="472 1027 636 1358">See description in Section 8.2</td> <td data-bbox="642 1027 1220 1358"> Generally applicable to new gas turbines and engines except when operated < 1 500 h/yr. Applicable to existing gas turbines and engines within the constraints associated with the steam cycle design and the space availability. Not applicable to existing gas turbines and engines operated < 1 500 h/yr. Not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns. Not applicable to boilers </td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Combined cycle	See description in Section 8.2	Generally applicable to new gas turbines and engines except when operated < 1 500 h/yr. Applicable to existing gas turbines and engines within the constraints associated with the steam cycle design and the space availability. Not applicable to existing gas turbines and engines operated < 1 500 h/yr. Not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns. Not applicable to boilers	BAT-associated energy efficiency levels (BAT-AEELs) for the combustion of natural gas				
Technique	Description	Applicability										
a. Combined cycle	See description in Section 8.2	Generally applicable to new gas turbines and engines except when operated < 1 500 h/yr. Applicable to existing gas turbines and engines within the constraints associated with the steam cycle design and the space availability. Not applicable to existing gas turbines and engines operated < 1 500 h/yr. Not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns. Not applicable to boilers										

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																																																															
	<table border="1"> <thead> <tr> <th rowspan="3">Type of combustion unit</th> <th colspan="5">BAT-AEELs ⁽¹³⁶⁾ ⁽¹³⁷⁾</th> </tr> <tr> <th colspan="2">Net electrical efficiency (%)</th> <th rowspan="2">Net total fuel utilisation (%) ⁽¹³⁸⁾ ⁽¹³⁹⁾</th> <th colspan="2">Net mechanical energy efficiency (%) ⁽¹³⁹⁾ ⁽¹⁴⁰⁾</th> </tr> <tr> <th>New unit</th> <th>Existing unit</th> <th>New unit</th> <th>Existing unit</th> </tr> </thead> <tbody> <tr> <td>Gas engine</td> <td>39,5–44 ⁽¹⁴¹⁾</td> <td>35–44 ⁽¹⁴¹⁾</td> <td>56–85 ⁽¹⁴¹⁾</td> <td colspan="2">No BAT-AEEL.</td> </tr> <tr> <td>Gas-fired boiler</td> <td>39–42,5</td> <td>38–40</td> <td>78–95</td> <td colspan="2">No BAT-AEEL.</td> </tr> <tr> <td>Open cycle gas turbine, ≥ 50 MW_{th}</td> <td>36–41,5</td> <td>33–41,5</td> <td>No BAT-AEEL</td> <td>36,5–41</td> <td>33,5–41</td> </tr> <tr> <td colspan="6" style="text-align: center;">Combined cycle gas turbine (CCGT)</td> </tr> <tr> <td>CCGT, 50–600 MW_{th}</td> <td>53–58,5</td> <td>46–54</td> <td>No BAT-AEEL</td> <td colspan="2">No BAT-AEEL</td> </tr> <tr> <td>CCGT, ≥ 600 MW_{th}</td> <td>57–60,5</td> <td>50–60</td> <td>No BAT-AEEL</td> <td colspan="2">No BAT-AEEL</td> </tr> <tr> <td>CHP CCGT, 50–600 MW_{th}</td> <td>53–58,5</td> <td>46–54</td> <td>65–95</td> <td colspan="2">No BAT-AEEL</td> </tr> <tr> <td>CHP CCGT, ≥ 600 MW_{th}</td> <td>57–60,5</td> <td>50–60</td> <td>65–95</td> <td colspan="2">No BAT-AEEL</td> </tr> </tbody> </table>	Type of combustion unit	BAT-AEELs ⁽¹³⁶⁾ ⁽¹³⁷⁾					Net electrical efficiency (%)		Net total fuel utilisation (%) ⁽¹³⁸⁾ ⁽¹³⁹⁾	Net mechanical energy efficiency (%) ⁽¹³⁹⁾ ⁽¹⁴⁰⁾		New unit	Existing unit	New unit	Existing unit	Gas engine	39,5–44 ⁽¹⁴¹⁾	35–44 ⁽¹⁴¹⁾	56–85 ⁽¹⁴¹⁾	No BAT-AEEL.		Gas-fired boiler	39–42,5	38–40	78–95	No BAT-AEEL.		Open cycle gas turbine, ≥ 50 MW _{th}	36–41,5	33–41,5	No BAT-AEEL	36,5–41	33,5–41	Combined cycle gas turbine (CCGT)						CCGT, 50–600 MW _{th}	53–58,5	46–54	No BAT-AEEL	No BAT-AEEL		CCGT, ≥ 600 MW _{th}	57–60,5	50–60	No BAT-AEEL	No BAT-AEEL		CHP CCGT, 50–600 MW _{th}	53–58,5	46–54	65–95	No BAT-AEEL		CHP CCGT, ≥ 600 MW _{th}	57–60,5	50–60	65–95	No BAT-AEEL			
Type of combustion unit	BAT-AEELs ⁽¹³⁶⁾ ⁽¹³⁷⁾																																																																	
	Net electrical efficiency (%)		Net total fuel utilisation (%) ⁽¹³⁸⁾ ⁽¹³⁹⁾	Net mechanical energy efficiency (%) ⁽¹³⁹⁾ ⁽¹⁴⁰⁾																																																														
	New unit	Existing unit		New unit	Existing unit																																																													
Gas engine	39,5–44 ⁽¹⁴¹⁾	35–44 ⁽¹⁴¹⁾	56–85 ⁽¹⁴¹⁾	No BAT-AEEL.																																																														
Gas-fired boiler	39–42,5	38–40	78–95	No BAT-AEEL.																																																														
Open cycle gas turbine, ≥ 50 MW _{th}	36–41,5	33–41,5	No BAT-AEEL	36,5–41	33,5–41																																																													
Combined cycle gas turbine (CCGT)																																																																		
CCGT, 50–600 MW _{th}	53–58,5	46–54	No BAT-AEEL	No BAT-AEEL																																																														
CCGT, ≥ 600 MW _{th}	57–60,5	50–60	No BAT-AEEL	No BAT-AEEL																																																														
CHP CCGT, 50–600 MW _{th}	53–58,5	46–54	65–95	No BAT-AEEL																																																														
CHP CCGT, ≥ 600 MW _{th}	57–60,5	50–60	65–95	No BAT-AEEL																																																														
41	<p>In order to prevent or reduce NO_x emissions to air from the combustion of natural gas in boilers, BAT is to use one or a combination of the techniques given below.</p> <table border="1"> <thead> <tr> <th>Technique</th> <th>Description</th> <th>Applicability</th> </tr> </thead> <tbody> <tr> <td>a. Air and/or fuel staging</td> <td>See descriptions in Section 8.3. Air staging is often associated with low-NO_x burners</td> <td rowspan="3">Generally applicable</td> </tr> <tr> <td>b. Flue-gas recirculation</td> <td>See description in Section 8.3</td> </tr> <tr> <td>c. Low-NO_x burners (LNB)</td> <td></td> </tr> <tr> <td>d. Advanced control system</td> <td>See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for</td> <td>The applicability to old combustion plants may be constrained by the need to retrofit the combustion</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Air and/or fuel staging	See descriptions in Section 8.3. Air staging is often associated with low-NO _x burners	Generally applicable	b. Flue-gas recirculation	See description in Section 8.3	c. Low-NO _x burners (LNB)		d. Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for	The applicability to old combustion plants may be constrained by the need to retrofit the combustion	NA	There are no natural gas boilers located at this installation.																																																		
Technique	Description	Applicability																																																																
a. Air and/or fuel staging	See descriptions in Section 8.3. Air staging is often associated with low-NO _x burners	Generally applicable																																																																
b. Flue-gas recirculation	See description in Section 8.3																																																																	
c. Low-NO _x burners (LNB)																																																																		
d. Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for	The applicability to old combustion plants may be constrained by the need to retrofit the combustion																																																																

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement											
		combustion plants operated < 500 h/yr	system and/or control command system													
	e. Reduction of the combustion air temperature	See description in Section 8.3	Generally applicable within the constraints associated with the process needs													
	f. Selective non-catalytic reduction (SNCR)		Not applicable to combustion plants operated < 500 h/yr with highly variable boiler loads. The applicability may be limited in the case of combustion plants operated between 500 h/yr and 1 500 h/yr with highly variable boiler loads													
	g. Selective catalytic reduction (SCR)		Not applicable to combustion plants operated < 500 h/yr. Not generally applicable to combustion plants of < 100 MW _{th} . There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr													
42	In order to prevent or reduce NO _x emissions to air from the combustion of natural gas in gas turbines, BAT is to use one or a combination of the techniques given below.			CC	<p>The installation uses techniques a and c in order to control emissions of NO_x.</p> <p>A – The installation continuously monitors combustion conditions within the gas turbines allow early identification of potential issues.</p> <p>C - Dry Low NO_x (DLN) burners are installed at the installation. The effective DLN is defined as 300MW of baseload which equates to 67.4%. DLN curves have been provided with the Reg61 response as evidence.</p>											
	<table border="1"> <thead> <tr> <th data-bbox="324 970 495 995">Technique</th> <th data-bbox="501 970 913 995">Description</th> <th data-bbox="920 970 1218 995">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="324 1000 495 1155">a. Advanced control system</td> <td data-bbox="501 1000 913 1155">See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr</td> <td data-bbox="920 1000 1218 1155">The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> <tr> <td data-bbox="324 1160 495 1214">b. Water/steam addition</td> <td data-bbox="501 1160 913 1214" rowspan="2">See description in Section 8.3</td> <td data-bbox="920 1160 1218 1214">The applicability may be limited due to water availability</td> </tr> <tr> <td data-bbox="324 1219 495 1345">c. Dry low-NO_x burners (DLN)</td> <td data-bbox="920 1219 1218 1345">The applicability may be limited in the case of turbines where a retrofit package is not available or when water/steam addition systems are installed</td> </tr> </tbody> </table>			Technique	Description	Applicability	a. Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system	b. Water/steam addition	See description in Section 8.3	The applicability may be limited due to water availability	c. Dry low-NO _x burners (DLN)	The applicability may be limited in the case of turbines where a retrofit package is not available or when water/steam addition systems are installed		
Technique	Description	Applicability														
a. Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system														
b. Water/steam addition	See description in Section 8.3	The applicability may be limited due to water availability														
c. Dry low-NO _x burners (DLN)		The applicability may be limited in the case of turbines where a retrofit package is not available or when water/steam addition systems are installed														

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	d.	Low-load design concept	Adaptation of the process control and related equipment to maintain good combustion efficiency when the demand in energy varies, e.g. by improving the inlet airflow control capability or by splitting the combustion process into decoupled combustion stages	The applicability may be limited by the gas turbine design	
	e.	Low-NO _x burners (LNB)	See description in Section 8.3	Generally applicable to supplementary firing for heat recovery steam generators (HRSGs) in the case of combined-cycle gas turbine (CCGT) combustion plants	
	f.	Selective catalytic reduction (SCR)		Not applicable in the case of combustion plants operated < 500 h/yr. Not generally applicable to existing combustion plants of < 100 MW _{th} . Retrofitting existing combustion plants may be constrained by the availability of sufficient space. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr	
43	In order to prevent or reduce NO _x emissions to air from the combustion of natural gas in engines, BAT is to use one or a combination of the techniques given below.			NA	There are no natural gas engines located at this installation.
	Technique		Description	Applicability	
	a.	Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system	
	b.	Lean-burn concept	See description in Section 8.3.	Only applicable to new gas-fired engines	

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																														
		Generally used in combination with SCR																																	
c.	Advanced lean-burn concept	See descriptions in Section 8.3	Only applicable to new spark plug ignited engines																																
d.	Selective catalytic reduction (SCR)		Retrofitting existing combustion plants may be constrained by the availability of sufficient space. Not applicable to combustion plants operated < 500 h/yr. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr																																
44	<p>In order to prevent or reduce CO emissions to air from the combustion of natural gas, BAT is to ensure optimised combustion and/or to use oxidation catalysts.</p> <p>Description - See descriptions in Section 8.3.</p> <p>BAT-associated emission levels (BAT-AELs) for NO_x emissions to air from the combustion of natural gas in gas turbines</p>			CC	<p>The installation optimises combustion in order to control CO emissions.</p> <p>Dry Low NO_x (DLN) burners are installed at the installation. The effective DLN is defined as 300MW of baseload which equates to 67.4%. DLN curves have been provided with the Reg61 response as evidence.</p>																														
<table border="1"> <thead> <tr> <th data-bbox="324 866 674 1034" rowspan="2">Type of combustion plant</th> <th data-bbox="685 866 857 1034" rowspan="2">Combustion plant total rated thermal input (MW_{th})</th> <th colspan="2" data-bbox="869 866 1218 898">BAT-AELs (mg/Nm³) ⁽¹⁴²⁾ ⁽¹⁴³⁾</th> </tr> <tr> <th data-bbox="869 906 1032 1034">Yearly average ⁽¹⁴⁴⁾ ⁽¹⁴⁵⁾</th> <th data-bbox="1043 906 1218 1034">Daily average or average over the sampling period</th> </tr> </thead> <tbody> <tr> <td colspan="4" data-bbox="324 1042 1218 1074" style="text-align: center;">Open-cycle gas turbines (OCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁷⁾</td> </tr> <tr> <td data-bbox="324 1082 674 1114">New OCGT</td> <td data-bbox="685 1082 857 1114">≥ 50</td> <td data-bbox="869 1082 1032 1114">15–35</td> <td data-bbox="1043 1082 1218 1114">25–50</td> </tr> <tr> <td data-bbox="324 1121 674 1217">Existing OCGT (excluding turbines for mechanical drive applications) — All but plants operated < 500 h/yr</td> <td data-bbox="685 1121 857 1217">≥ 50</td> <td data-bbox="869 1121 1032 1217">15–50</td> <td data-bbox="1043 1121 1218 1217">25–55 ⁽¹⁴⁸⁾</td> </tr> <tr> <td colspan="4" data-bbox="324 1225 1218 1257" style="text-align: center;">Combined-cycle gas turbines (CCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁹⁾</td> </tr> <tr> <td data-bbox="324 1265 674 1297">New CCGT</td> <td data-bbox="685 1265 857 1297">≥ 50</td> <td data-bbox="869 1265 1032 1297">10–30</td> <td data-bbox="1043 1265 1218 1297">15–40</td> </tr> <tr> <td data-bbox="324 1305 674 1361">Existing CCGT with a net total fuel utilisation of < 75 %</td> <td data-bbox="685 1305 857 1361">≥ 600</td> <td data-bbox="869 1305 1032 1361">10–40</td> <td data-bbox="1043 1305 1218 1361">18–50</td> </tr> </tbody> </table>						Type of combustion plant	Combustion plant total rated thermal input (MW _{th})	BAT-AELs (mg/Nm ³) ⁽¹⁴²⁾ ⁽¹⁴³⁾		Yearly average ⁽¹⁴⁴⁾ ⁽¹⁴⁵⁾	Daily average or average over the sampling period	Open-cycle gas turbines (OCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁷⁾				New OCGT	≥ 50	15–35	25–50	Existing OCGT (excluding turbines for mechanical drive applications) — All but plants operated < 500 h/yr	≥ 50	15–50	25–55 ⁽¹⁴⁸⁾	Combined-cycle gas turbines (CCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁹⁾				New CCGT	≥ 50	10–30	15–40	Existing CCGT with a net total fuel utilisation of < 75 %	≥ 600	10–40	18–50
Type of combustion plant	Combustion plant total rated thermal input (MW _{th})	BAT-AELs (mg/Nm ³) ⁽¹⁴²⁾ ⁽¹⁴³⁾																																	
		Yearly average ⁽¹⁴⁴⁾ ⁽¹⁴⁵⁾	Daily average or average over the sampling period																																
Open-cycle gas turbines (OCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁷⁾																																			
New OCGT	≥ 50	15–35	25–50																																
Existing OCGT (excluding turbines for mechanical drive applications) — All but plants operated < 500 h/yr	≥ 50	15–50	25–55 ⁽¹⁴⁸⁾																																
Combined-cycle gas turbines (CCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁹⁾																																			
New CCGT	≥ 50	10–30	15–40																																
Existing CCGT with a net total fuel utilisation of < 75 %	≥ 600	10–40	18–50																																

BAT Concn. Number	Summary of BAT Conclusion requirement				Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	Existing CCGT with a net total fuel utilisation of $\geq 75\%$	≥ 600	10–50	18–55 ⁽¹⁵⁰⁾		
	Existing CCGT with a net total fuel utilisation of $< 75\%$	50–600	10–45	35–55		
	Existing CCGT with a net total fuel utilisation of $\geq 75\%$	50–600	25–50 ⁽¹⁵¹⁾	35–55 ⁽¹⁵²⁾		
	Open- and combined-cycle gas turbines					
	Gas turbine put into operation no later than 27 November 2003, or existing gas turbine for emergency use and operated < 500 h/yr	≥ 50	No BAT-AEL	60–140 ⁽¹⁵³⁾ ⁽¹⁵⁴⁾		
	Existing gas turbine for mechanical drive applications — All but plants operated < 500 h/yr	≥ 50	15–50 ⁽¹⁵⁵⁾	25–55 ⁽¹⁵⁶⁾		
	<p>As an indication, the yearly average CO emission levels for each type of existing combustion plant operated $\geq 1\,500$ h/yr and for each type of new combustion plant will generally be as follows:</p> <ul style="list-style-type: none"> — New OCGT of ≥ 50 MW_{th}: $< 5\text{--}40$ mg/Nm³. For plants with a net electrical efficiency (EE) greater than 39 %, a correction factor may be applied to the higher end of this range, corresponding to [higher end] \times EE/39, where EE is the net electrical energy efficiency or net mechanical energy efficiency of the plant determined at ISO baseload conditions. — Existing OCGT of ≥ 50 MW_{th} (excluding turbines for mechanical drive applications): $< 5\text{--}40$ mg/Nm³. The higher end of this range will generally be 80 mg/Nm³ in the case of existing plants that cannot be fitted with dry techniques for NO_x reduction, or 50 mg/Nm³ for plants that operate at low load. — New CCGT of ≥ 50 MW_{th}: $< 5\text{--}30$ mg/Nm³. For plants with a net electrical efficiency (EE) greater than 55 %, a correction factor may be applied to the higher end of the range, corresponding to [higher end] \times EE/55, where EE is the net electrical energy efficiency of the plant determined at ISO baseload conditions. — Existing CCGT of ≥ 50 MW_{th}: $< 5\text{--}30$ mg/Nm³. The higher end of this range will generally be 50 mg/Nm³ for plants that operate at low load. — Existing gas turbines of ≥ 50 MW_{th} for mechanical drive applications: $< 5\text{--}40$ mg/Nm³. The higher end of the range will generally be 50 mg/Nm³ when plants operate at low load. <p>In the case of a gas turbine equipped with DLN burners, these indicative levels correspond to when the DLN operation is effective.</p>					

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																							
	<p>BAT-associated emission levels (BAT-AELs) for NO_x emissions to air from the combustion of natural gas in boilers and engines</p> <table border="1" data-bbox="324 384 1218 608"> <thead> <tr> <th rowspan="3">Type of combustion plant</th> <th colspan="4">BAT-AELs (mg/Nm³)</th> </tr> <tr> <th colspan="2">Yearly average ⁽¹⁵⁷⁾</th> <th colspan="2">Daily average or average over the sampling period</th> </tr> <tr> <th>New plant</th> <th>Existing plant ⁽¹⁵⁸⁾</th> <th>New plant</th> <th>Existing plant ⁽¹⁵⁹⁾</th> </tr> </thead> <tbody> <tr> <td>Boiler</td> <td>10–60</td> <td>50–100</td> <td>30–85</td> <td>85–110</td> </tr> <tr> <td>Engine ⁽¹⁶⁰⁾</td> <td>20–75</td> <td>20–100</td> <td>55–85</td> <td>55–110 ⁽¹⁶¹⁾</td> </tr> </tbody> </table> <p>As an indication, the yearly average CO emission levels will generally be:</p> <ul style="list-style-type: none"> — < 5–40 mg/Nm³ for existing boilers operated ≥ 1 500 h/yr, — < 5–15 mg/Nm³ for new boilers, — 30–100 mg/Nm³ for existing engines operated ≥ 1 500 h/yr and for new engines. 	Type of combustion plant	BAT-AELs (mg/Nm ³)				Yearly average ⁽¹⁵⁷⁾		Daily average or average over the sampling period		New plant	Existing plant ⁽¹⁵⁸⁾	New plant	Existing plant ⁽¹⁵⁹⁾	Boiler	10–60	50–100	30–85	85–110	Engine ⁽¹⁶⁰⁾	20–75	20–100	55–85	55–110 ⁽¹⁶¹⁾		
Type of combustion plant	BAT-AELs (mg/Nm ³)																									
	Yearly average ⁽¹⁵⁷⁾		Daily average or average over the sampling period																							
	New plant	Existing plant ⁽¹⁵⁸⁾	New plant	Existing plant ⁽¹⁵⁹⁾																						
Boiler	10–60	50–100	30–85	85–110																						
Engine ⁽¹⁶⁰⁾	20–75	20–100	55–85	55–110 ⁽¹⁶¹⁾																						

6 Review and assessment of derogation requests made by the operator in relation to BAT Conclusions which include an associated emission level (AEL) value

The IED enables a competent authority to allow derogations from BAT AELs stated in BAT Conclusions under specific circumstances as detailed under Article 15(4):

By way of derogation from paragraph 3, and without prejudice to Article 18, the competent authority may, in specific cases, set less strict emission limit values. Such a derogation may apply only where an assessment shows that the achievement of emission levels associated with the best available techniques as described in BAT conclusions would lead to disproportionately higher costs compared to the environmental benefits due to:

(a) the geographical location or the local environmental conditions of the installation concerned; or

(b) the technical characteristics of the installation concerned.

As part of their Regulation 61 Note response, the operator has not requested a derogation from compliance with any AEL values.

7 Emissions to Water

All process waters are treated at the onsite effluent treatment plant before being discharge to the River Trent via emission point W1. Surface water is treated using an oil interceptor before it is discharged via Water arising from the storm water discharge point is also discharged to sewer. The discharge is subsequently treated at Anglian Water Sewage Treatment Works.

8 Additional IED Chapter II requirements:

In the event of a black out National Grid would call on combustion plant to operate and may require them to do so outside their permitted conditions. We have dedicated black start plant and they are permitted to run as such but this scenario is relevant to the rest of the large combustion plant which could be called depending on the circumstances.

A risk assessment will be carried out by Energy UK/Joint Environmental Programme on behalf of Large Combustion Plant connected to the National Transmission System. Air emissions modelling will be based on generic black start scenarios to establish whether they have the potential to have local impact on the environment or not (on a national basis). If the modelling demonstrates that no significant impacts are likely, the plant can operate under condition 2.3.7. This conditions allows the hourly ELVs for plants operating under a black start instruction to be discounted for the purpose of reporting. We would also require there to be a procedure in place for minimisation of emissions in the case of a black start event and for reporting in the event of a black start. This modelling and the procedures have not been agreed in advance of the issue of the permit review and therefore a condition linking back to an improvement condition have been included in the permit.

9 Review and assessment of changes that are not part of the BAT Conclusions derived permit review.

This document should be read in conjunction with the application, supporting information and notice.

Aspect considered	Decision
Receipt of application	
Confidential information	A claim for commercial or industrial confidentiality has not been made.
Identifying confidential information	We have not identified information provided as part of the application that we consider to be confidential.
Operating techniques	
General operating techniques	<p>We have reviewed the techniques used by the operator where they are relevant to the BAT Conclusions and compared these with the relevant guidance notes.</p> <p>The permit conditions ensure compliance with the relevant BREF, BAT Conclusions. The ELVs deliver compliance with the BAT-AELs.</p>
Permit conditions	
Updating permit conditions during consolidation	We have updated permit conditions to those in the current generic permit template as part of permit consolidation. The conditions will provide at least the same level of protection as those in the previous permit and in some cases will provide a higher level of protection to those in the previous permit.
Changes to the permit conditions due to an Environment Agency initiated variation	We have varied the permit as stated in the variation notice.
Improvement programme	All improvement conditions have now been completed. All improvement conditions have been removed from the permit and a note has been included in table S1.3 in the permit.
Emission limits	<p>We have decided that emission limits should be set for the parameters listed in the permit.</p> <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p> <p>It is considered that the ELVs/equivalent parameters or technical measures described above will ensure that significant pollution of the environment is prevented and a high level of protection for the environment is secured.</p>

Aspect considered	Decision
Monitoring	<p>We have decided that monitoring should be carried out for the parameters listed in the permit, using the methods detailed and to the frequencies specified.</p> <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p> <p>Table S3.3 was amended to include the requirement to monitor energy efficiency</p> <p>Based on the information in the application we are [not fully] satisfied that the operator's techniques, personnel and equipment have either MCERTS certification or MCERTS accreditation as appropriate.</p>
Reporting	<p>We have specified reporting in the permit for the following parameters:</p> <ul style="list-style-type: none"> • Nitrogen dioxide • Carbon monoxide <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p>
Operator competence	
Management system	<p>There is no known reason to consider that the operator will not have the management system to enable it to comply with the permit conditions.</p>
Growth Duty	
Section 108 Deregulation Act 2015 – Growth duty	<p>We have considered our duty to have regard to the desirability of promoting economic growth set out in section 108(1) of the Deregulation Act 2015 and the guidance issued under section 110 of that Act in deciding whether to grant this permit.</p> <p>Paragraph 1.3 of the guidance says:</p> <p>“The primary role of regulators, in delivering regulation, is to achieve the regulatory outcomes for which they are responsible. For a number of regulators, these regulatory outcomes include an explicit reference to development or growth. The growth duty establishes economic growth as a factor that all specified regulators should have regard to, alongside the delivery of the protections set out in the relevant legislation.”</p> <p>We have addressed the legislative requirements and environmental standards to be set for this operation in the body of the decision document above. The guidance is clear at paragraph 1.5 that the growth duty does not legitimise non-compliance and its purpose is not to achieve or pursue economic growth at the expense of necessary protections.</p> <p>We consider the requirements and standards we have set in this permit are reasonable and necessary to avoid a risk of an unacceptable level of pollution. This also promotes growth</p>

Aspect considered	Decision
	amongst legitimate operators because the standards applied to the operator are consistent across businesses in this sector and have been set to achieve the required legislative standards.