

Environment Agency

Review of an Environmental Permit for an Installation subject to Chapter II of the Industrial Emissions Directive under the Environmental Permitting (England & Wales) Regulations 2016

Decision document recording our decision-making process following review of a permit

The Permit number is: EPR/BJ8022IZ
The Operator is: VPI Immingham LLP
The Installation is: Immingham CHP Power Plant
This Variation Notice number is: EPR/BJ8022IZ/V012

What this document is about

Article 21(3) of the Industrial Emissions Directive (IED) requires the Environment Agency to review conditions in permits that it has issued and to ensure that the permit delivers compliance with relevant standards, within four years of the publication of updated decisions on best available techniques (BAT) conclusions.

We have reviewed the permit for this installation against the revised BAT Conclusions for large combustion plant published on 17th August 2017. This is our decision document, which explains the reasoning for the consolidated variation notice that we are issuing.

It explains how we have reviewed and considered the techniques used by the Operator in the operation and control of the plant and activities of the installation. This review has been undertaken with reference to the decision made by the European Commission establishing best available techniques (BAT) conclusions ('BAT Conclusions') for large combustion plant as detailed in document reference IEDC-7-1. It is our record of our decision-making process and shows how we have taken into account all relevant factors in reaching our position. It also provides a justification for the inclusion of any specific conditions in the permit that are in addition to those included in our generic permit template.

As well as considering the review of the operating techniques used by the Operator for the operation of the plant and activities of the installation, the consolidated variation notice takes into account and brings together in a single document all previous variations that relate to the original permit

issued. It also modernises the entire permit to reflect the conditions contained in our current generic permit template.

The introduction of new template conditions makes the Permit consistent with our current general approach and philosophy and with other permits issued to installations in this sector. Although the wording of some conditions has changed, while others have been removed because of the new regulatory approach, it does not reduce the level of environmental protection achieved by the Permit in any way. In this document we therefore address only our determination of substantive issues relating to the new BAT Conclusions.

This is our record of our decision-making process and shows how we have taken into account all relevant factors in reaching our position.

Throughout this document we will use a number of expressions. These are as referred to in the glossary and have the same meaning as described in “Schedule 6 Interpretation” of the Permit.

We try to explain our decision as accurately, comprehensively and plainly as possible. We would welcome any feedback as to how we might improve our decision documents in future. A lot of technical terms and acronyms are inevitable in a document of this nature: we provide a glossary of acronyms near the front of the document, for ease of reference.

How this document is structured

Glossary of terms

- 1 Our decision
- 2 How we reached our decision
- 2.1 Requesting information to demonstrate compliance with BAT
Conclusions for Large Combustion Plant
- 2.2 Review of our own information in respect to the capability of the
installation to meet revised standards included in the BAT Conclusions
document
- 3 The legal framework
- 4 Key Issues
- 5 Decision checklist regarding relevant BAT Conclusions
- 6 Emissions to water
- 7 Additional IED Chapter II requirements
- 8 Review and assessment of changes that are not part of the BAT
Conclusions derived permit review

Glossary of acronyms used in this document

(Please note that this glossary is standard for our decision documents and therefore not all these acronyms are necessarily used in this document.)

APC	Air Pollution Control
BAT	Best Available Technique(s)
BAT-AEEL	BAT Associated Energy Efficiency Level
BAT-AEL	BAT Associated Emission Level
BATc	BAT conclusion
BREF	Best available techniques reference document
CCGT	Combined Cycle Gas Turbine
CEM	Continuous emissions monitor
CHP	Combined heat and power
CV	Calorific value
DAA	Directly associated activity – Additional activities necessary to be carried out to allow the principal activity to be carried out
DLN	Dry Low NOx burners
DLN-E	Dry Low NOx effective
EIONET	European environment information and observation network is a partnership network of the European Environment Agency
ELV	Emission limit value derived under BAT or an emission limit value set out in IED
EMS	Environmental Management System
EPR	Environmental Permitting (England and Wales) Regulations 2016 (SI 2016 No. 1154)
EWC	European waste catalogue
FSA	Food Standards Agency
GT	Gas Turbine (generator)
HRSG	Heat Recovery Steam Generator
IC	Improvement Condition
IED	Industrial Emissions Directive (2010/75/EU)
IPPCD	Integrated Pollution Prevention and Control Directive (2008/1/EC) – now superseded by IED
LCP	Large Combustion Plant subject to Chapter III of IED
MSUL/MSDL	Minimum start up load/minimum shut-down load
NOx	Oxides of nitrogen (NO plus NO ₂ expressed as NO ₂)
NPV	Net Present Value
OCGT	Open Cycle Gas Turbine
PHE	Public Health England
REF	Refining of Mineral Oil (BATc and BREF)
RFG	Refinery Fuel Gas (interchangeably used with ROG)

ROG	Refinery Off-Gas (interchangeably used with RFG)
SAC	Special Area of Conservation
SGN	Sector guidance note
TGN	Technical guidance note
TNP	Transitional National Plan
TOC	Total Organic Carbon
WFD	Water Framework Directive (2000/60/EC)

1 Our decision

We have decided to issue the consolidated variation notice to the Operator. This will allow them to continue to operate the installation, subject to the conditions in the consolidated variation notice.

We consider that, in reaching that decision, we have taken into account all relevant considerations and legal requirements and that the varied permit will ensure that a high level of protection is provided for the environment and human health.

The consolidated variation notice contains many conditions taken from our standard Environmental Permit template including the relevant Annexes. We developed these conditions in consultation with industry, having regard to the legal requirements of the Environmental Permitting Regulations and other relevant legislation. This document does not therefore include an explanation for these standard conditions. Where they are included in the Notice, we have considered the techniques identified by the Operator for the operation of their installation, and have accepted that the details are sufficient and satisfactory to make those standard conditions appropriate. This document does, however, provide an explanation of our use of “tailor-made” or installation-specific conditions, or where our Permit template provides two or more options.

2 How we reached our decision

2.1 Requesting information to demonstrate compliance with BAT Conclusions for Large Combustion Plant

We issued a Notice under Regulation 61(1) of the Environmental Permitting (England and Wales) Regulations 2016 (a Regulation 61 Notice) on 1st May 2018 requiring the Operator to provide information to demonstrate how the operation of their installation currently meets, or will subsequently meet, the revised standards described in the large combustion plant BAT Conclusions document. The Notice also required that where the revised standards are not currently met, the Operator should provide information that:

- Describes the techniques that will be implemented before 17th August 2021, which will then ensure that operations meet the revised standard, or
- Justifies why standards will not be met by 17th August 2021, and confirmation of the date when the operation of those processes will cease within the installation or an explanation of why the revised BAT standard is not applicable to those processes, or
- Justifies why an alternative technique will achieve the same level of environmental protection equivalent to the revised standard described in the BAT Conclusions.

Where the Operator proposed that they were not intending to meet a BAT standard that also included a BAT Associated Emission Level (BAT AEL) described in the BAT Conclusions Document, the Regulation 61 Notice requested that the Operator make a formal request for derogation from compliance with that AEL (as provisioned by Article 15(4) of IED). In this circumstance, the Notice identified that any such request for derogation must be supported and justified by sufficient technical and commercial information that would enable us to determine acceptability of the derogation request.

The Regulation 61 Notice response from the Operator was received on 30/08/2018.

We considered that the response did not contain sufficient information for us to commence the permit review. We therefore issued a further information request to the Operator on 19/11/2019. Suitable further information was provided by the Operator on 20/12/2019.

We considered it was in the correct form and contained sufficient information for us to begin our determination of the permit review but not that it necessarily contained all the information we would need to complete that review: we requested additional information and clarification on the responses provided by the Operator on 20/12/2019. We received this additional information on 05/02/2020 and 18/02/2020.

2.2 Review of our own information in respect to the capability of the installation to meet revised standards included in the BAT Conclusions document

Based on our records and previous regulatory activities with the facility we have no reason to consider that the Operator will not be able to comply with the conditions that we include in the permit.

In relation to BAT conclusion 3, we agree with the Operator in respect to their current stated capability as recorded in their Regulation 61 Notice responses that improvements are required.

3 The legal framework

The consolidated variation notice will be issued under Regulation 20 of the EPR. The Environmental Permitting regime is a legal vehicle which delivers most of the relevant legal requirements for activities falling within its scope. In particular, the regulated facility is:

- an *installation* as described by the IED;
- subject to aspects of other relevant legislation which also have to be addressed.

We consider that the consolidated variation notice will ensure that the operation of the Installation complies with all relevant legal requirements and that a high level of protection will be delivered for the environment and human health.

We explain how we have addressed specific statutory requirements more fully in the rest of this document.

4 The key issues

The key issues arising during this permit review are:

- Emissions to air and the emission limits applied to the plant;
- The applicable requirements of the BAT Conclusions on the refining of mineral oil and gas (EU Commission implementing decision 2014/738/EU) (REF BAT conclusions), relevant to the combustion of refinery fuel gas at the installation;
- The energy efficiency levels associated with the Best Available Techniques (BAT-AEELs);
- BAT conclusion 3 on monitoring of flue gas parameters;
- The requirements for multi-fuel combustion plants set out by Article 40 of the IED.

We therefore describe how we determined these issues in most detail in the relevant sections of this document.

4.1 Emissions to air and the emission limits applied to the plant

A number of general principles were applied during the permit review. These included:

- The upper value of the BAT AELs ranges specified were used unless use of the tighter limit was justified.
- The principle of no backsliding where if existing limits in the permit were already tighter than those specified in the BREF, the existing permit limits were retained.
- Where a limit was specified in both IED Annex V and the BAT Conclusions for a particular reference period, the tighter limit was applied and in the majority of cases this was from the BAT Conclusions.
- Where AELs are indicative in the BAT Conclusions, these were applied unless adequate justification was provided by the Operator to demonstrate that an alternative limit was more appropriate.
- For gas turbines where the IED specified that limits applied over 70% load and the BAT Conclusions specified that AELs applied when dry low NOx is effective (DLN-E), we have used DLN-E as a default across all monitoring requirements for NOx and CO.

The installation consist of two LCPs, whose characteristics are summarised in the following table:

LCP	Emission Point	Equipment type	Thermal Input	Fuels	Operating scenario
LCP 188	A1	CCGT (GT 1 + HRSG 1)	GT = 730 MWth HRSG = 111 MWth	Natural gas	>1500 hrs
	A2	CCGT (GT 2 + HRSG 2)	GT = 743 MWth HRSG = 111 MWth	Natural gas	>1500 hrs
	A3	Auxiliary Boiler 1	290 MWth	<ul style="list-style-type: none"> • Natural gas • Refinery fuel gas • Fuel oil (stand-by only if natural gas is not available) 	>1500 hrs
	A4	Auxiliary Boiler 3	290 MWth	<ul style="list-style-type: none"> • Natural gas • Refinery fuel gas 	>1500 hrs

				<ul style="list-style-type: none"> Fuel oil (stand-by only if natural gas is not available) 	
LCP 415	A5	CCGT (GT 3 + HRSG 3)	GT = 751 MWth HRSG = 193 MWth	GT <ul style="list-style-type: none"> Natural gas only HRSG <ul style="list-style-type: none"> Natural gas Refinery fuel gas 	>1500 hrs

The plant was put into operation before IED came into force and therefore the existing limits in the permit are from Part 1 of IED Annex V applicable to existing plant.

The ELVs and AELs are based on the following operating regime:

- Unlimited hours operation (for gas turbines, heat recovery steam generators and auxiliary boilers fired on natural gas and/or refinery fuel gas, see table above)

The installation makes use of refinery fuel gas (RFG), also referred as Refinery Off-Gas (ROG) throughout the permit, imported from the nearby Philips 66 Humber Oil Refinery. In the LCP BAT conclusion document there are no specific provisions or BAT-AEL specified for the combustion of this fuel. Article 14(6) of the Industrial Emissions Directive requires that, where an activity or a type of production process carried out within an installation is not covered by any of the BAT conclusions or where those conclusions do not address all the potential environmental effects of the activity or process, the Competent Authority needs to set the permit conditions on the basis of the best available techniques that it has determined for the activities or processes concerned, by giving special consideration to the criteria listed in Annex III of the IED, which include, among others:

- comparable processes, facilities or methods of operation which have been tried with success on an industrial scale;
- the nature, effects and volume of the emissions concerned;

- information published by public international organisations.

Taking into account these criteria set in the IED, we have therefore determined BAT for the combustion of RFG in the combustion equipment at the installation, by referring to the requirements of the BAT Conclusions on the refining of mineral oil and gas (EU Commission implementing decision 2014/738/EU) (REF BAT conclusions), which include specific provisions and BAT-AELs for the combustion of this fuel. We have therefore considered the relevant parts of the REF BAT conclusions applicable to this installation, as a comparable process according to the provisions of Article 14(6) and Annex III of the IED.

The following tables outline the limits that have been incorporated into the permit for LCP188 and LCP415, where these were derived from and the reference periods at which they apply. The emission limits refer to concentrations, expressed as mass of emitted substance per volume of flue-gas under the following standard conditions: dry gas at a temperature of 273,15 K, pressure of 101,3 kPa and 15% (for gas turbines and their associated HRSG), 3% (for auxiliary boilers) volume reference oxygen concentration if flue gases. The emission limits and monitoring requirements have been incorporated into Schedule 3 of the permit.

The installation also uses distillate fuel oil as back-up fuel in the auxiliary boilers of LCP188, for emergency scenarios when the supply of natural gas is interrupted. This operation is restricted in the permit to 'no more than 500 hours per calendar year with a maximum period of 240 hours' (i.e. less than 10 days), in line with the requirements of Article 30(6) of IED and its interpretation made by the UK Regulators at the time of the IED Chapter III implementation. Where a natural gas fired plant uses gas oil as a standby fuel for less than 10 days, we have not assessed the site against the BAT Conclusions applicable to that fuel as the use is not considered significant. As part of the on-going compliance assurance, the Operator will be required to demonstrate that the site is operated in a manner such that use of the standby fuel is minimised.

The emission limits for combustion of fuel oil specified in the permit, prior to this variation, have been retained, based on the non-backsliding principle.

LCP188 – GT 1 / HRSG 1, GT 2 / HRSG 2 (emission points A1, A2)

Fuel: natural gas

Operating hours: unlimited

Plant configuration: CCGT (steam cycle is common between LCP188 and LCP415), gas turbine operating at low load

Age: permitted before publication of the LCP BREF

Thermal input: >600 MW_{th}

Net total fuel utilisation: <75%

Electric Efficiency: <55%

NOx limits (mg/Nm ³)								
Averaging	IED (Annex V Part 1) - Existing	LCP BREF	Expected permit limits	Basis	Limits apply	Monitoring	Current Permit Limit	Revised Permit Limit
Annual	None	40 (≥600 MW _{th} , η <75%) ^{1,2}	40	BREF	E-DLN	Continuous	None	40
Monthly	50 (75 if EE>55% or η >75%)	None	50	IED	E-DLN		50	50
Daily	55 (82.5 if EE>55% or η >75%)	50 (≥600 MW _{th} , η <75%) ^{1,2}	50	BREF - IED compliance.	E-DLN		55	50
95 th %ile of hr means	100 (150 if EE>55% or η >75%)	None	100	IED	E-DLN		100	100
1 - If electrical generating efficiency (EE) > 55% then limit is [limit] x EE/55 2 - Overall plant efficiency, η, based on 'net total fuel utilisation'								

CO limits (mg/Nm ³) – indicative in <i>italics</i>								
Averaging	IED (Annex V Part 1) - Existing	LCP BREF	Expected permit limits	Basis	Limits apply	Monitoring	Current Permit Limit	Revised Permit Limit
Annual	None	<i>30</i> <i>(50 for plant operating at low load)</i>	<i>50</i>	BREF	E-DLN	Continuous	None	50
Monthly	100	None	100	IED	E-DLN		100	100
Daily	110	None	110	IED	E-DLN		110	110
95 th %ile of hr means	200	None	200	IED	E-DLN		200	200

In response to the additional Regulation 61(1) Notice served on 19/11/2019 (updated response received 05/02/2020), the Operator proposed an annual emission limit at 50 mg/m³ for emissions of carbon monoxide from GT1/HRSG1 and GT2/HRSG2. This is above the indicative emission limit of 30 mg/m³ set in the LCP BAT conclusions, for existing gas turbines in this tier of thermal input. However, the Operator justified the requested emission limit explaining that higher emissions of CO are associated with low load operation of the gas turbines. We have accepted this technical justification, which is in line with the provision of the BAT conclusions for a higher indicative CO emission limit when operating at low load. We have set this limit in table S3.1a of the variation notice.

The permit, prior to this variation, included emission limits for SO₂ and a requirement for continuous monitoring of this pollutant in GT/HRSG 1 and 2. However, in response to the additional Regulation 61(1) Notice served on 19/11/2019 and responded on 20/12/2019, the Operator has clarified that they considered this requirement a legacy from when these gas turbines and HRSGs were permitted to operate with refinery off-gas as a fuel. Therefore, the Operator has requested that the requirement for continuous monitoring of SO₂ in these two emission points is removed from the varied and consolidated permit.

We agree that emissions of SO₂ from the combustion of natural gas are not a concern, due to the low sulphur content of this fuel. We have therefore accepted the request made by the Operator and specified in the varied and consolidated permit that emissions

of SO₂ from these two emission points will need to be reported by calculation, based on the sulphur content in the natural gas. We have also removed the emission limit value for SO₂ from these two emission points, since there is no requirement to specify these limits for gas turbines operating on natural gas, in either IED Chapter III, Annex V or the LCP BAT conclusions. We consider that the use of natural gas, which is specified to contain low sulphur concentrations, ensures that emissions of this pollutant are maintained to levels of environmental non-significance and therefore we consider that this decision is not against the non-backsliding principle set for the permit review.

LCP188 - Auxiliary Boilers AB1, AB2 (emission points A3, A4)

Fuel: **natural gas**

Operating hours: unlimited

Age: permitted before publication of the LCP BREF

NOx limits (mg/Nm ³)								
Averaging	IED (Annex V Part 1) - Existing	LCP BREF (Table 25 BAT-c)	Expected permit limits	Basis	Limits apply	Monitoring	Current Permit Limit	Revised Permit Limit
Annual	None	100	100	BREF	MSUL/MSDL to baseload	Continuous	None	100
Monthly	100	None	100	IED	MSUL/MSDL to baseload		100	100
Daily	110	110	110	BREF	MSUL/MSDL to baseload		110	110
95 th %ile of hr means	200	None	200	IED	MSUL/MSDL to baseload		200	200

CO limits (mg/Nm ³) – indicative in <i>italics</i>								
Averaging	IED (Annex V Part 1) - Existing	LCP BREF	Expected permit limits	Basis	Limits apply	Monitoring	Current Permit Limit	Revised Permit Limit
Annual	None	<i>40</i>	<i>40</i>	BREF	MSUL/MSDL to baseload	Continuous	None	<i>40</i>
Monthly	<i>100</i>	None	<i>100</i>	IED	MSUL/MSDL to baseload		<i>100</i>	<i>100</i>
Daily	<i>110</i>	None	<i>110</i>	IED	MSUL/MSDL to baseload		<i>110</i>	<i>110</i>
95 th %ile of hr means	<i>200</i>	None	<i>200</i>	IED	MSUL/MSDL to baseload		<i>200</i>	<i>200</i>
Dust limits (mg/Nm ³)								
Averaging	IED (Annex V Part 1) - Existing	LCP BREF	Expected permit limits	Basis	Limits apply	Monitoring	Current Permit Limit	Revised Permit Limit
Annual	None	None	None	NA	NA	Periodic or by calculation	<i>5</i> ^{Note 1}	None
Monthly	<i>5</i>	None	<i>5</i>	IED	MSUL/MSDL to baseload			<i>5</i> ^{Note 2}
Daily	<i>5.5</i>	None	<i>5.5</i>	IED	MSUL/MSDL to baseload			<i>5.5</i> ^{Note 2}
95 th %ile of hr means	<i>10</i>	None	<i>10</i>	IED	MSUL/MSDL to baseload			<i>10</i> ^{Note 2}
Notes: <ol style="list-style-type: none"> 1. Emission limit applicable to periodic measurement, no averaging is applied since there is no requirement for continuous measurement in the current permit. 2. Monthly, daily and hourly emission limits have been specified in the revised permit since the Operator has opted for continuous monitoring of dust from these emission points and installed continuous emissions monitoring systems accordingly. 								

SO ₂ limits (mg/Nm ³)								
Averaging	IED (Annex V Part 1) - Existing	LCP BREF	Expected permit limits	Basis	Limits apply	Monitoring	Current Permit Limit	Revised Permit Limit
Annual	None	None	None	NA	NA	Periodic or by calculation	None	None
Monthly	35	None	35	IED	MSUL/MSDL to baseload		35	35
Daily	38.5	None	38.5	IED	MSUL/MSDL to baseload		39	38.5 ^{Note 1}
95 th %ile of hr means	70	None	70	IED	MSUL/MSDL to baseload		70	70
Notes: 1. Emission limit was approximated to the nearest unit when the permit was issued prior to this variation. We have now approximated this to one decimal digit according to our most recent guidance.								

Fuel: **refinery fuel gas**

Operating hours: unlimited

Age: permitted before publication of the REF BREF

NO _x limits (mg/Nm ³)								
Averaging	IED (Annex V Part 1) - Existing	REF BREF (Table 10 BAT-c)	Expected permit limits	Basis	Limits apply	Monitoring	Current Permit Limit	Revised Permit Limit
Annual	None	None	None	-	--	Continuous	None	None
Monthly	200	150	150	REF BREF	MSUL/MSDL to baseload		200	150
Daily	220	None	220	IED	MSUL/MSDL to baseload		220	220

95 th %ile of hr means	400	None	400	IED	MSUL/MSDL to baseload		400	400
CO limits (mg/Nm³)								
Averaging	IED (Annex V Part 1) - Existing	REF BREF (Table 15 BAT-c)	Expected permit limits	Basis	Limits apply	Monitoring	Current Permit Limit	Revised Permit Limit
Annual	None	None	None	-	--	Continuous	None	None
Monthly	None	100	100	REF BREF	MSUL/MSDL to baseload		None	100
Daily	None	None	None	-	--		None	None
95 th %ile of hr means	None	None	None	-	--		None	None
Dust limits (mg/Nm³)								
Averaging	IED (Annex V Part 1) - Existing	REF BREF (Table 12 BAT-c)	Expected permit limits	Basis	Limits apply	Monitoring	Current Permit Limit	Revised Permit Limit
Annual	None	None	None	-	NA	Continuous	5 ^{Note 2}	None
Monthly	5	5-50 ^{Note 1}	5	IED	MSUL/MSDL to baseload			5 ^{Note 3}
Daily	5.5	None	None	-	MSUL/MSDL to baseload			5.5 ^{Note 3}
95 th %ile of hr means	10	None	None	-	MSUL/MSDL to baseload			10 ^{Note 3}
Notes:								
<ol style="list-style-type: none"> BAT-AEL range is for multi-fuel combustion, including liquid fuels. Emission limit applicable to periodic measurement, no averaging is applied since there is no requirement for continuous measurement in the current permit. Monthly, daily and hourly emission limits have been specified in the revised permit since the Operator has installed continuous emissions monitoring for dust. 								

SO2 limits (mg/Nm ³)								
Averaging	IED (Annex V Part 1) - Existing	REF BREF (Table 13BAT-c)	Expected permit limits	Basis	Limits apply	Monitoring	Current Permit Limit	Revised Permit Limit
Annual	None	None	None	NA	NA	Continuous	None	None
Monthly	35	35	35	IED	MSUL/MSDL to baseload		35	35
Daily	38.5	None	38.5	IED	MSUL/MSDL to baseload		39	38.5 ^{Note 1}
95 th %ile of hr means	70	None	70	IED	MSUL/MSDL to baseload		70	70
Notes:								
1. Emission limit was approximated to the nearest unit when the permit was issued prior to this variation. We have now approximated this to one decimal digit according to our most recent guidance.								

LCP415 - GT 3 / HRSG 3 (emission points A5)

Fuel: **natural gas**

Operating hours: unlimited

Plant configuration: CCGT (steam cycle is common between LCP188 and LCP415), gas turbine operating at low load

Age: permitted before publication of the LCP BREF

Thermal input: >600 MWth

Net total fuel utilisation: <75%

Electric Efficiency: <55%

NOx limits (mg/Nm ³)								
Averaging	IED (Annex V Part 1) - Existing	LCP BREF	Expected permit limits	Basis	Limits apply	Monitoring	Current Permit Limit	Revised Permit Limit
Annual	None	40 (≥600 MW _{th} , η <75%) ^{1,2}	40	BREF	E-DLN	Continuous	None	40
Monthly	50 (75 if EE>55% or η >75%)	None	50	IED	E-DLN		50	50
Daily	55 (82.5 if EE>55% or η >75%)	50 (≥600 MW _{th} , η <75%) ^{1,2}	50	BREF - IED compliance.	E-DLN		55	50
95 th %ile of hr means	100 (150 if EE>55% or η >75%)	None	100	IED	E-DLN		100	100
1 - If electrical generating efficiency (EE) > 55% then limit is [limit] x EE/55 2 - Overall plant efficiency, η, based on 'net total fuel utilisation'								
CO limits (mg/Nm ³) – indicative in <i>italics</i>								
Averaging	IED (Annex V Part 1) - Existing	LCP BREF	Expected permit limits	Basis	Limits apply	Monitoring	Current Permit Limit	Revised Permit Limit
Annual	None	30 (50 for plant operating at low load)	50	BREF	E-DLN	Continuous	None	50
Monthly	100	None	100	IED	E-DLN		100	100

Daily	110	None	110	IED	E-DLN		110	110
95th %ile of hr means	200	None	200	IED	E-DLN		200	200

In response to the additional Regulation 61(1) Notice served on 19/11/2019 (updated response received 05/02/2020), the Operator proposed an annual emission limit at 50 mg/m³ for emissions of carbon monoxide from GT3/HRSG3. This is above the indicative emission limit of 30 mg/m³ set in the LCP BAT conclusions, for existing gas turbines in this tier of thermal input. However, the Operator justified the requested emission limit explaining that higher emissions of CO are associated with low load operation of the gas turbine. We have accepted this technical justification, which is in line with the provision of the BAT conclusions for a higher indicative CO emission limit when operating at low load. We have set this limit in table S3.1a of the variation notice.

No BAT-AEL are specified for SO₂ in natural gas fired gas turbines in the LCP BAT conclusions and, for this type of fuel, the low sulphur content in the fuel specification would be sufficient per se to ensure that emissions of this pollutant are not of environmental significance. However, the current permit already included emission limits for SO₂ prior to this permit review and GT3/HRSG3 is a multi-fuel plant, fired on natural gas and refinery fuel gas. Since we consider appropriate the specification of an emission limit for SO₂ emissions when the plant is operating as multi-fuel (see section below for refinery fuel gas), we have also retained the existing emission limits for SO₂ for natural gas operation, based on the no-backsliding principle and to ensure that the multi-fuel operation is covered by an emission limit for this parameter.

Fuel: **refinery fuel gas**

Operating hours: unlimited

Plant configuration: CCGT (steam cycle is common between LCP188 and LCP415), gas turbine operating at low load

Age: permitted before publication of the REF BREF

Thermal input: >600 MWth

Net total fuel utilisation: <75%

Electric Efficiency: <55%

NOx limits (mg/Nm ³)								
Averaging	IED (Annex V Part 1) - Existing	REF BREF	Expected permit limits	Basis	Limits apply	Monitoring	Current Permit Limit	Revised Permit Limit
Annual	None	None	None	N/A	N/A	Continuous	None	None
Monthly	120	120	120	IED and REF BREF	E-DLN ¹		120	120
Daily	132	None	132	IED	E-DLN ¹		132	132
95 th %ile of hr means	240	None	240	IED	E-DLN ¹		240	240
1. Although for gas turbines where the IED specified that limits apply over 70% load, we have considered them to apply when low NOx is effective (DLN-E) as a default across all monitoring requirements for NOx and CO to use a consistent approach with the LCP BREF								
CO limits (mg/Nm ³) – indicative in <i>italics</i>								
Averaging	IED (Annex V Part 1) - Existing	REF BREF	Expected permit limits	Basis	Limits apply	Monitoring	Current Permit Limit	Revised Permit Limit
Annual	None	None	None	N/A	N/A	Continuous	None	None
Monthly	None	100	100	REF BREF	E-DLN ¹		None	100

Daily	None	None	None	N/A	N/A		None	None
95th %ile of hr means	None	None	None	N/A	N/A		None	None
1. Although for gas turbines where the IED specified that limits apply over 70% load, we have considered them to apply when low NOx is effective (DLN-E) as a default across all monitoring requirements for NOx and CO to use a consistent approach with the LCP BREF								
SO₂ limits (mg/Nm³)								
Averaging	IED (Annex V Part 1) - Existing	REF BREF	Expected permit limits	Basis	Limits apply	Monitoring	Current Permit Limit	Revised Permit Limit
Annual	None	None	None	NA	NA	N/A	None	None
Monthly	None	None	None	IED	MSUL/MSDL to baseload		35	35 ^{1,2}
Daily	None	None	None	IED	MSUL/MSDL to baseload		39	39 ^{1,2}
95th %ile of hr means	None	None	None	IED	MSUL/MSDL to baseload		70	70 ^{1,2}
Notes:								
1. Emission limits are retained from the existing permit based on the non-backsliding principle. Although the sulphur content of the RFG is specified in table S2.1 of the permit, since sulphur might be present in RFG due to the source, nature and variability of this fuel, we consider that the specification of an emission limit for SO ₂ emissions when firing this fuel is appropriate.								
2. Requirement for continuous emissions monitoring of SO ₂ is retained from the current permit based on the non-backsliding principle.								

No emission limits for dust for combustion of RFG in gas turbines apply from either IED or the REF BREF / BAT conclusions. According to our guidance, we have therefore considered that no monitoring is required for this parameter.

4.2 The energy efficiency levels associated with the Best Available Techniques Conclusions

An energy efficiency level associated with the best available techniques (BAT-AEEL) refers to the ratio between the combustion unit's net energy output(s) and the combustion unit's fuel/feedstock energy input at actual unit design. The net energy output(s) is determined at the combustion unit boundaries, including auxiliary systems (e.g. flue-gas treatment systems), and for the unit operated at full load.

The table below sets out the BAT-AEELs specified in the LCP BAT Conclusions for the large combustion plant on the site and the energy efficiency levels confirmed through the Regulation 61 notice response.

BAT AEELs (%)			Plant efficiency (%)		
Net electrical efficiency	Net total fuel utilisation	Net mechanical efficiency	Net electrical efficiency	Net total fuel utilisation	Net mechanical efficiency
Combined LCP188 and LCP415: CHP CCGT, ≥ 600 MWth, existing plant					
50–60	N/A	N/A	52%	N/A	NA

Taking the above into account, we consider this plant is BAT in relation to the AEELs. See additional explanation below.

The evidence provided to demonstrate that the AEELs are met was in the form of a response to our request for additional information (additional information in Response to Regulation 61, received 05/02/2020), supplemented by operational data and calculations taking into account the energy content of the steam export from the CHP.

The Operator responded that the performance of each gas turbine at the installation was tested independently according to international standards ASME PTC 22 that we consider compliant with the requirements of BAT conclusion 2.

Due to the process configuration of the CHP, with common steam headers supplying steam to 3 steam turbines operating in parallel, fed by steam generated in the HRSG1 and 2 (part of LCP188), supplementary steam in the Auxiliary Boilers 1 and 2 (part of LCP188) when required, and steam generated in the HRSG3 (part of LCP415), the Operator has provided information on the overall energy efficiency of the CHP installation, as opposed to specific information for each LCP. We agree with this approach.

In addition to the above, note 1 to BAT conclusion 2 recognises that, in the case of CHP units, if for technical reasons the performance test cannot be carried out with the unit operated at full load for the heat supply, the test can

be supplemented or substituted by a calculation using full load parameters. The Operator has reported that the CHP unit at the installation cannot operate at full load, without exceeding the users' steam requirements.

For the reasons summarised above, the Operator has provided calculations referring to operational data for example hours to demonstrate the energy efficiency levels of the installation. These example hours were selected to represent operational conditions close to the nominal base loads of the gas turbines, as measured at their respective performance tests.

The LCP BAT conclusions, specify that, in the case of CHP units, only one of the two BAT-AEELs 'Net electrical efficiency' or 'Net total fuel utilisation' applies, depending on the CHP unit design, i.e. either more oriented towards electricity generation or heat generation. We have reviewed the information provided by the Operator and we consider that, since the VPI Immingham CHP Plant is more oriented toward electricity generation, the appropriate BAT-AEEL to be considered is the Net Electrical Efficiency.

In the additional information in Response to Regulation 61, received 05/02/2020, the Operator has reported a calculated Net Electrical Efficiency of 52%, for the combined CHP operation of LCP188 and LCP415, example hour 14:00 (GMT) 14th June 2019. This particular hour of operation was selected because:

- The net electricity exported was consistent with the installation baseload output under nominal conditions;
- The CHP was operating at a low steam export load; since the steam for export is spilled from the steam turbine, higher steam export loads result in lower net electric efficiency figures, because the steam exported does not contribute to the electricity generation in the steam turbine where it is spilled from. For this reason, the Operator has theoretically adjusted the net electrical efficiency to account for the potential electricity generation of the exported steam.

We have reviewed the information provided by the Operator and the supporting calculation and we agree with their conclusion that the installation meets the applicable BAT-AEEL.

4.2 Monitoring of flue gas parameters – LCP BAT conclusion 3

BAT conclusion 3 requires the Operator to monitor the following key parameters for the flue-gas:

Stream	Parameter(s)	Monitoring
Flue-gas	Flow	Periodic or continuous determination
	Oxygen content, temperature, and pressure	Periodic or continuous measurement
	Water vapour content (%)	

In response to the Regulation 61 Notice, the Operator has confirmed that LCP415 (Gas Turbine 3/HRSG3) is currently compliant with the requirements of this BAT conclusion as flue-gas flow rate, oxygen content, temperature and pressure are measured continuously, whilst the sampled flue gas is dried before analysis for emissions and therefore measurement of water vapour content is not necessary.

For LCP188, the Operator has confirmed the following:

Auxiliary Boilers 1 and 2 – currently compliant: flue-gas flow rate, oxygen content, temperature, pressure are measured continuously. The sampled flue gas is dried before analysis for emissions and therefore measurement of vapour content is not necessary.

Gas Turbine 1/HRSG1 and Gas Turbine2/HRSG2 – compliant in the future: flue-gas flow rate, oxygen content, temperature, are measured continuously. The sampled flue gas is dried before analysis for emissions and therefore measurement of water vapour content is not necessary. However, pressure measurement is currently not in place.

In response to the additional Regulation 61(1) Notice served on 19/11/2019 and responded on 20/12/2019, the Operator had confirmed that pressure sensors will be installed in GT 1/HRSG 1 and 2 by the compliance date of 17/08/2021. We have therefore set an improvement condition (IC19) to reflect this requirement.

4.3 Requirements for multi-fuel combustion plants

The EPR Compliance Assessment Report BJ8022IZ/0342536, dated 26/09/2019, recorded an inconsistent approach between the way the existing permit addressed the requirements for multi-fuel firing and our current interpretation of multi-fuel compliance requirements for LCP, according to Article 40 of the IED.

Article 40 (1) of IED applies to multi-fuel firing combustion plant involving the simultaneous use of two or more fuels.

Article 40 (2) of IED includes specific provisions for multi-fuel firing combustion plants permit before 7 January 2013, which use refinery fuels from the refining of crude-oil for own consumption.

LCP188 and LCP415, part of the Immingham CHP Power Plant, were developed in technical connection with the nearby refineries, in particular Phillips 66 Humber Oil Refinery and permitted before 7 January 2013. The installation receives refinery fuel gas from Phillips 66 Humber Oil Refinery and exports steam and power to this refinery and export steam to Total Lindsey Oil Refinery. For this reason, we consider that the specific provisions of Article 40 (2) of the Industrial Emission Directive are applicable to calculate multi-

fuels emission limits for equipment fired on refinery off-gas at the installation, instead of the general provisions of Article 40 (1).

For refinery combustion plants, the Environment Agency decided to exercise its discretion, by applying the provisions of article 40(2) and developed the document titled 'IED Chapter III Protocol for Multi-fuel Firing Refinery Combustion Plants granted a Permit prior to 7th January 2013'. The approaches described in this document are referred to for setting multi-fuel weighted emission limits at the installation.

As part of this permit review, we have therefore addressed this historical inconsistency and varied the permit to make it compliant with our current regulatory interpretation of the multi-fuel requirements of the IED.

We have specified in Tables S3.1 and S3.1a of the varied and consolidated permit that equipment fired on multi-fuel shall comply with emission limits calculated according to the multi-fuel weighting formulae of the IED Article 40 (2).

In response to the Regulation 61 Notice served on 19/11/19, the Operator has submitted a draft multi-fuel firing plan (document titled 'BJ8022IZ – Multi Fuel Firing Plan (MFFP)', received 20/12/19). We have reviewed this document and we consider it still needs further development to be aligned to the requirements of the 'IED Chapter III Protocol for Multi-fuel Firing Refinery Combustion Plants granted a Permit prior to 7th January 2013'.

We have therefore set an improvement condition (IC18) requiring the Operator to fully develop within six months a plan to report and assess compliance of the emissions from the multi-fuel combustion equipment of LCP188 and LCP415 against the multi-fuel weighted emission limits calculated from the limits specified in Tables S3.1 and S3.1a, according to the formulae provided in IED Article 40(2), following the methodologies described in the document titled 'IED Chapter III Protocol for Multi-fuel Firing Refinery Combustion Plants granted a Permit prior to 7th January 2013'. We have also included in the variation notice a table (table S3.3) specifying the requirement for setting annual mass emission limits for multi-fuel operating equipment. These emission limits for multi-fuel firing equipment are to be determined upon completion of improvement condition IC18, if fixed multi-fuel weighted emission limit values are proposed, according to the methodology described in the document titled 'IED Chapter III Protocol for Multi-fuel Firing Refinery Combustion Plants granted a Permit prior to 7th January 2013'.

5 Decision checklist regarding relevant LCP BAT Conclusions

BAT Conclusions for large combustion plant, were published by the European Commission on 17th August 2017. There are 75 BAT Conclusions. Only the BAT Conclusions relevant to the particular fuel type used on site have been replicated below.

This annex provides a record of decisions made in relation to each relevant BAT Conclusion applicable to the installation. This annex should be read in conjunction with the Consolidated Variation Notice.

The conditions in the permit through which the relevant BAT Conclusions are implemented include but are not limited to the following:

BAT Conclusion requirement topic	Permit condition(s)	Permit table(s)
Environmental Management System	1.1.1	S1.2
BAT AELs	3.1.1 and 3.5.1	S3.1a
Monitoring	2.3, 3.5 and 3.6	S1.2, S1.4, S1.5, S3.1a
Energy efficiency	1.2 and 2.3	S3.4
Noise	3.4 and 2.3	S2.1
Other operating techniques	1.2	S1.2

The overall status of compliance with the BAT conclusion is indicated in the table as:

- NA Not Applicable
- CC Currently Compliant
- FC Compliant in the future (within 4 years of publication of BAT conclusions)
- NC Not Compliant
- PC Partially Compliant

BAT C. No.	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the Operator to demonstrate compliance with the BAT Conclusion requirement
General			
1	<p>In order to improve the overall environmental performance, BAT is to implement and adhere to an environmental management system (EMS) that incorporates all of the following features:</p> <ul style="list-style-type: none"> i. commitment of the management, including senior management; ii. definition of an environmental policy that includes the continuous improvement of the installation by the management; iii. planning and establishing the necessary procedures, objectives and targets, in conjunction with financial planning and investment; iv. implementation of procedures <ul style="list-style-type: none"> (a) Structure and responsibility (b) Training (c) Communication (d) Employee involvement (e) Documentation (f) Efficient process control (g) Maintenance programmes (h) Emergency preparedness and response (i) Safeguarding compliance with environmental legislation v. checking performance and taking corrective action, paying particular attention to: <ul style="list-style-type: none"> (a) monitoring and measurement (see also the Reference Document on the General Principles of Monitoring) (b) corrective and preventive action (c) maintenance of records (d) independent (where practicable) internal and external auditing in order to determine whether or not the EMS conforms to planned arrangements and has been properly implemented and maintained; vi. review of the EMS and its continuing suitability, adequacy and effectiveness by senior management; vii. following the development of cleaner technologies; viii. consideration for the environmental impacts from the eventual decommissioning of the installation at the stage of designing a new plant, and throughout its operating life; viii. consideration for the environmental impacts from the eventual decommissioning of the installation at the stage of designing a new plant, and throughout its operating life; ix. application of sectoral benchmarking on a regular basis. 	CC	<p>The Operator has addressed compliance with this BAT conclusion, in response to the additional Regulation 61(1) Notice served on 19/11/2019 and responded on 20/12/2019. This confirmed that the Operator's environmental management system, certified to ISO14001:2015, incorporates all the applicable requirements set out in this BAT conclusion.</p> <p>We agree with the Operator's stated compliance.</p>

BAT C. No.	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the Operator to demonstrate compliance with the BAT Conclusion requirement												
	<p>Etc - see BAT Conclusions</p> <p>Applicability. The scope (e.g. level of detail) and nature of the EMS (e.g. standardised or non-standardised) will generally be related to the nature, scale and complexity of the installation, and the range of environmental impacts it may have.</p>														
2	<p>BAT is to determine the net electrical efficiency and/or the net total fuel utilisation and/or the net mechanical energy efficiency of the gasification, IGCC and/or combustion units by carrying out a performance test at full load (1), according to EN standards, after the commissioning of the unit and after each modification that could significantly affect the net electrical efficiency and/or the net total fuel utilisation and/or the net mechanical energy efficiency of the unit. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.</p>	CC	<p>The Operator has confirmed that the gas turbines were tested according to international standard ASME PTC 22 (in 2017 and 2018) and the auxiliary boilers were tested according to international standard ASME PTC 4 when they were originally commissioned. We consider that these international standards ensure provision of data of an equivalent scientific quality to EN standards.</p> <p>The Operator has claimed that the Auxiliary Boilers cannot be performance tested due to the variable steam demand of both refineries. This is consistent with note 1 to BAT conclusion 2: In the case of CHP units, if for technical reasons the performance test cannot be carried out with the unit operated at full load for the heat supply, the test can be supplemented or substituted by a calculation using full load parameters.</p> <p>We consider the operating techniques stated by the Operator are compliant with this BAT conclusion. We have set a process monitoring requirement in the permit to test the Net Electric efficiency and/or Net Total Fuel Utilisation, according to EN standards or equivalent, after each modification which that could significantly affect these parameters.</p>												
3	<p>BAT is to monitor key process parameters relevant for emissions to air and water including those given below.</p> <table border="1" data-bbox="280 1082 1176 1332"> <thead> <tr> <th>Stream</th> <th>Parameter(s)</th> <th>Monitoring</th> </tr> </thead> <tbody> <tr> <td rowspan="3">Flue-gas</td> <td>Flow</td> <td>Periodic or continuous determination</td> </tr> <tr> <td>Oxygen content, temperature, and pressure</td> <td rowspan="2">Periodic or continuous measurement</td> </tr> <tr> <td>Water vapour content (%)</td> </tr> <tr> <td>Waste water from flue-gas treatment</td> <td>Flow, pH, and temperature</td> <td>Continuous measurement</td> </tr> </tbody> </table>	Stream	Parameter(s)	Monitoring	Flue-gas	Flow	Periodic or continuous determination	Oxygen content, temperature, and pressure	Periodic or continuous measurement	Water vapour content (%)	Waste water from flue-gas treatment	Flow, pH, and temperature	Continuous measurement	FC	<p>The Operator has confirmed that LCP415 (Gas Turbine 3/HRSG 3) is currently compliant with the requirements of this BAT conclusion: oxygen content, temperature and pressure are measured continuously; the flue-gas flow rate is continuously determined from the measurement of fuel consumption; the sampled flue gas is dried before analysis for emissions and therefore measurement of water vapour content is not necessary.</p> <p>For LCP188, the Operator has confirmed the following:</p> <p>Auxiliary Boilers 1 and 2 – currently compliant: oxygen content, temperature, pressure are measured continuously; the flue-gas flow rate is continuously determined from the measurement of fuel</p>
Stream	Parameter(s)	Monitoring													
Flue-gas	Flow	Periodic or continuous determination													
	Oxygen content, temperature, and pressure	Periodic or continuous measurement													
	Water vapour content (%)														
Waste water from flue-gas treatment	Flow, pH, and temperature	Continuous measurement													

BAT C. No.	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the Operator to demonstrate compliance with the BAT Conclusion requirement																		
			<p>consumption; the sampled flue gas is dried before analysis for emissions and therefore measurement of water vapour content is not necessary.</p> <p>Gas Turbine 1/HRSG 1 and Gas Turbine 2/HRSG 2 – compliant in the future: oxygen content, temperature, are measured continuously; the flue-gas flow rate is continuously determined from the measurement of fuel consumption; the sampled flue gas is dried before analysis for emissions and therefore measurement of water vapour content is not necessary. However, pressure measurement is currently not in place.</p> <p>In response to the additional Regulation 61(1) Notice served on 19/11/2019 and responded on 20/12/2019, the Operator had confirmed that pressure sensors will be installed in GT 1/HRSG 1 and 2 by the compliance date of 17/08/2021. We have set an improvement condition (IC19) to reflect this requirement.</p>																		
4	<p>BAT is to monitor emissions to air with at least the frequency given below and in accordance with EN standards. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.</p> <table border="1" data-bbox="280 927 1180 1375"> <thead> <tr> <th data-bbox="280 927 398 1086">Substance/Parameter</th> <th data-bbox="398 927 638 1086">Fuel/Process/Type of combustion plant</th> <th data-bbox="638 927 757 1086">Combustion plant total rated thermal input</th> <th data-bbox="757 927 891 1086">Standard(s)⁽⁴⁾</th> <th data-bbox="891 927 1061 1086">Minimum monitoring frequency⁽⁵⁾</th> <th data-bbox="1061 927 1180 1086">Monitoring associated with</th> </tr> </thead> <tbody> <tr> <td data-bbox="280 1086 398 1155">NH₃</td> <td data-bbox="398 1086 638 1155">— When SCR and/or SNCR is used</td> <td data-bbox="638 1086 757 1155">All sizes</td> <td data-bbox="757 1086 891 1155">Generic EN standards</td> <td data-bbox="891 1086 1061 1155">Continuous⁽⁶⁾/⁽⁷⁾</td> <td data-bbox="1061 1086 1180 1155">BAT 7</td> </tr> <tr> <td data-bbox="280 1155 398 1375">NO_x</td> <td data-bbox="398 1155 638 1375"> <ul style="list-style-type: none"> — Coal and/or lignite including waste co-incineration — Solid biomass and/or peat including waste co-incineration — HFO- and/or gas- </td> <td data-bbox="638 1155 757 1375">All sizes</td> <td data-bbox="757 1155 891 1375">Generic EN standards</td> <td data-bbox="891 1155 1061 1375">Continuous⁽⁶⁾/⁽⁸⁾</td> <td data-bbox="1061 1155 1180 1375"> BAT 20 BAT 24 BAT 28 BAT 32 BAT 37 BAT 41 BAT 42 BAT 43 BAT 47 BAT 48 </td> </tr> </tbody> </table>	Substance/Parameter	Fuel/Process/Type of combustion plant	Combustion plant total rated thermal input	Standard(s) ⁽⁴⁾	Minimum monitoring frequency ⁽⁵⁾	Monitoring associated with	NH ₃	— When SCR and/or SNCR is used	All sizes	Generic EN standards	Continuous ⁽⁶⁾ / ⁽⁷⁾	BAT 7	NO _x	<ul style="list-style-type: none"> — Coal and/or lignite including waste co-incineration — Solid biomass and/or peat including waste co-incineration — HFO- and/or gas- 	All sizes	Generic EN standards	Continuous ⁽⁶⁾ / ⁽⁸⁾	BAT 20 BAT 24 BAT 28 BAT 32 BAT 37 BAT 41 BAT 42 BAT 43 BAT 47 BAT 48	CC	<p>The Operator has provided information confirming that they comply with the requirements of this BAT conclusion. The details are described in the following.</p> <p>LCP188: Gas Turbines and HRSG 1 & 2, fired on natural gas, include continuous monitoring for NO_x & CO. The current permit, also includes emission limits for SO₂ and a requirement for continuous monitoring of this pollutant in GT/HRSG 1 and 2. However, in response to the additional Regulation 61(1) Notice served on 19/11/2019 and responded on 20/12/2019, the Operator has clarified that they considered this requirement a legacy from when these gas turbines and HRSGs were permitted to operate with refinery off-gas as a fuel. Therefore, the Operator has requested that the requirement for continuous monitoring of SO₂ in these two emission points is removed from the varied and consolidated permit. We agree that emissions of SO₂ from the combustion of natural gas are not a concern, due to the low sulphur content of this fuel. We have therefore accepted the request made by the Operator and specified in the varied and consolidated permit that emissions of</p>
Substance/Parameter	Fuel/Process/Type of combustion plant	Combustion plant total rated thermal input	Standard(s) ⁽⁴⁾	Minimum monitoring frequency ⁽⁵⁾	Monitoring associated with																
NH ₃	— When SCR and/or SNCR is used	All sizes	Generic EN standards	Continuous ⁽⁶⁾ / ⁽⁷⁾	BAT 7																
NO _x	<ul style="list-style-type: none"> — Coal and/or lignite including waste co-incineration — Solid biomass and/or peat including waste co-incineration — HFO- and/or gas- 	All sizes	Generic EN standards	Continuous ⁽⁶⁾ / ⁽⁸⁾	BAT 20 BAT 24 BAT 28 BAT 32 BAT 37 BAT 41 BAT 42 BAT 43 BAT 47 BAT 48																

BAT C. No.	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the Operator to demonstrate compliance with the BAT Conclusion requirement
	<ul style="list-style-type: none"> oil-fired boilers and engines — Gas-oil-fired gas turbines — Natural-gas-fired boilers, engines, and turbines — Iron and steel process gases — Process fuels from the chemical industry — IGCC plants 					BAT 56 BAT 64 BAT 65 BAT 73	<p>SO2 from these two emission points will need to be reported by calculation, based on the sulphur content in the natural gas. We have also removed the emission limit value for SO2 from these two emission points, since there is no requirement to specify this emission limit for gas turbines operating on natural gas, in either IED Chapter III, Annex V or the LCP BAT conclusions and we consider that the use of natural gas, which is specified to contain low sulphur concentrations, ensures that emissions of this pollutant are maintained low.</p> <p>Auxiliary Boilers 1 & 2 fired on natural gas and refinery fuel gas, include continuous monitoring for NOx, SO2 and dust (the latter fully installed and being connected to the DCS as 20/12/2019).</p> <p>LCP415: Gas Turbine 3 is fired on natural gas and the associated HRSG 3 is fired either or natural gas or refinery fuel gas. LCP415 includes continuous monitoring for NOx, CO and SO2.</p>	
	<ul style="list-style-type: none"> — Combustion plants on offshore platforms 	All sizes	EN 14792	Once every year ⁽⁹⁾	BAT 53			
N ₂ O	<ul style="list-style-type: none"> — Coal and/or lignite in circulating fluidised bed boilers — Solid biomass and/or peat in circulating fluidised bed boilers 	All sizes	EN 21258	Once every year ⁽¹⁰⁾	BAT 20 BAT 24			
CO	<ul style="list-style-type: none"> — Coal and/or lignite including waste co-incineration — Solid biomass and/or peat including waste co-incineration — HFO- and/or gas-oil-fired boilers and engines — Gas-oil-fired gas turbines — Natural-gas-fired boilers, engines, and turbines 	All sizes	Generic EN standards	Continuous ⁽⁶⁾ ⁽⁸⁾	BAT 20 BAT 24 BAT 28 BAT 33 BAT 38 BAT 44 BAT 49 BAT 56 BAT 64 BAT 65 BAT 73			

BAT C. No.	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the Operator to demonstrate compliance with the BAT Conclusion requirement
	<ul style="list-style-type: none"> — Iron and steel process gases — Process fuels from the chemical industry — IGCC plants 							
	SO ₂	<ul style="list-style-type: none"> — Combustion plants on offshore platforms — Coal and/or lignite incl waste co-incineration — Solid biomass and/or peat incl waste co-incineration — HFO- and/or gas-oil-fired boilers — HFO- and/or gas-oil-fired engines — Gas-oil-fired gas turbines — Iron and steel process gases — Process fuels from the chemical industry in boilers — IGCC plants 	All sizes	EN 15058	Once every year ⁽⁹⁾	BAT 54		
	SO ₃	<ul style="list-style-type: none"> — When SCR is used 	All sizes	No EN standard available	Once every year	—		
	Gaseous chlorides, expressed as HCl	<ul style="list-style-type: none"> — Coal and/or lignite — Process fuels from the chemical industry in boilers — Solid biomass and/or peat 	All sizes	EN 1911	Once every three months ⁽⁶⁾ ⁽¹³⁾ ⁽¹⁴⁾	BAT 21 BAT 57		
			All sizes	Generic EN standards	Continuous ⁽¹⁵⁾ ⁽¹⁶⁾	BAT 25		

BAT C. No.	Summary of BAT Conclusion requirement					Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the Operator to demonstrate compliance with the BAT Conclusion requirement
	— Waste co-incineration	All sizes	Generic EN standards	Continuous ₍₆₎ (16)	BAT 66 BAT 67		
HF	— Coal and/or lignite	All sizes	No EN standard available	Once every three months ₍₆₎ (13)(14)	BAT 21 BAT 57		
	— Process fuels from the chemical industry in boilers						
	— Solid biomass and/or peat	All sizes	No EN standard available	Once every year	BAT 25		
	— Waste co-incineration	All sizes	Generic EN standards	Continuous ₍₆₎ (16)	BAT 66 BAT 67		
Dust	— Coal and/or lignite	All sizes	Generic EN standards and EN 13284-1 and EN 13284-2	Continuous ₍₆₎ (17)	BAT 22 BAT 26 BAT 30 BAT 35 BAT 39 BAT 51 BAT 58 BAT 75		
	— Solid biomass and/or peat						
	— HFO- and/or gas-oil-fired boilers						
	— Iron and steel process gases						
	— Process fuels from the chemical industry in boilers						
	— IGCC plants						
	— HFO- and/or gas-oil-fired engines						
	— Gas-oil-fired gas turbines						
	— Waste co-incineration	All sizes	Generic EN standards and EN 13284-2	Continuous	BAT 68 BAT 69		
Metals and metalloids except mercury (As, Cd, Co, Cr, Cu, Mn, Ni, Pb, Sb, Se, Tl, V, Zn)	— Coal and/or lignite	All sizes	EN 14385	Once every year ₍₁₈₎	BAT 22 BAT 26 BAT 30		
	— Solid biomass and/or peat						
	— HFO- and/or gas-oil-fired boilers and engines						
	— Waste co-	< 300 MW _{th}	EN 14385	Once every six months ₍₁₃₎	BAT 68 BAT 69		

BAT C. No.	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the Operator to demonstrate compliance with the BAT Conclusion requirement
	incineration	≥ 300 MW _{th}	EN 14385	Once every three months ₍₁₉₎ ₍₁₃₎				
	— IGCC plants	≥ 100 MW _{th}	EN 14385	Once every year ₍₁₈₎	BAT 75			
Hg	— Coal and/or lignite including waste co-incineration	< 300 MW _{th}	EN 13211	Once every three months ₍₁₃₎ ₍₂₀₎	BAT 23			
		≥ 300 MW _{th}	Generic EN standards and EN 14884	Continuous ₍₁₆₎ ₍₂₁₎				
	— Solid biomass and/or peat	All sizes	EN 13211	Once every year ₍₂₂₎	BAT 27			
	— Waste co-incineration with solid biomass and/or peat	All sizes	EN 13211	Once every three months ₍₁₃₎	BAT 70			
	— IGCC plants	≥ 100 MW _{th}	EN 13211	Once every year ₍₂₃₎	BAT 75			
TVOC	— HFO- and/or gas-oil-fired engines — Process fuels from chemical industry in boilers	All sizes	EN 12619	Once every six months ₍₁₃₎	BAT 33 BAT 59			
		— Waste co-incineration with coal, lignite, solid biomass and/or peat	All sizes	Generic EN standards	Continuous	BAT 71		
Formaldehyde	— Natural-gas in spark-ignited lean-burn gas and dual fuel engines	All sizes	No EN standard available	Once every year	BAT 45			
CH ₄	— Natural-gas-fired engines	All sizes	EN ISO 25139	Once every year ₍₂₄₎	BAT 45			
PCDD/F	— Process fuels from chemical industry in boilers	All sizes	EN 1948-1, EN 1948-2, EN 1948-3	Once every six months ₍₁₃₎ ₍₂₅₎	BAT 59 BAT 71			
	— Waste co-incineration							

BAT C. No.	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the Operator to demonstrate compliance with the BAT Conclusion requirement																																						
5	<p>BAT is to monitor emissions to water from flue-gas treatment with at least the frequency given below and in accordance with EN standards. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.</p> <table border="1" data-bbox="286 443 1173 1362"> <thead> <tr> <th data-bbox="286 443 546 528">Substance/Parameter</th> <th data-bbox="546 443 819 528">Standard(s)</th> <th data-bbox="819 443 1003 528">Minimum monitoring frequency</th> <th data-bbox="1003 443 1173 528">Monitoring associated with</th> </tr> </thead> <tbody> <tr> <td data-bbox="286 528 546 587">Total organic carbon (TOC)₍₂₆₎</td> <td data-bbox="546 528 819 587">EN 1484</td> <td data-bbox="819 528 1003 1362" rowspan="8">Once every month</td> <td data-bbox="1003 528 1173 1362" rowspan="8">BAT 15</td> </tr> <tr> <td data-bbox="286 587 546 646">Chemical oxygen demand (COD)₍₂₆₎</td> <td data-bbox="546 587 819 646">No EN standard available</td> </tr> <tr> <td data-bbox="286 646 546 705">Total suspended solids (TSS)</td> <td data-bbox="546 646 819 705">EN 872</td> </tr> <tr> <td data-bbox="286 705 546 764">Fluoride (F⁻)</td> <td data-bbox="546 705 819 764">EN ISO 10304-1</td> </tr> <tr> <td data-bbox="286 764 546 823">Sulphate (SO₄²⁻)</td> <td data-bbox="546 764 819 823">EN ISO 10304-1</td> </tr> <tr> <td data-bbox="286 823 546 882">Sulphide, easily released (S²⁻)</td> <td data-bbox="546 823 819 882">No EN standard available</td> </tr> <tr> <td data-bbox="286 882 546 941">Sulphite (SO₃²⁻)</td> <td data-bbox="546 882 819 941">EN ISO 10304-3</td> </tr> <tr> <td data-bbox="286 941 546 1222">Metals and metalloids</td> <td data-bbox="546 941 819 1222"> <table border="1" data-bbox="495 874 819 1222"> <tr><td data-bbox="495 874 546 911">As</td><td data-bbox="546 874 819 1117" rowspan="6">Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)</td></tr> <tr><td data-bbox="495 911 546 948">Cd</td></tr> <tr><td data-bbox="495 948 546 984">Cr</td></tr> <tr><td data-bbox="495 984 546 1021">Cu</td></tr> <tr><td data-bbox="495 1021 546 1058">Ni</td></tr> <tr><td data-bbox="495 1058 546 1094">Pb</td></tr> <tr><td data-bbox="495 1094 546 1131">Zn</td></tr> <tr><td data-bbox="495 1131 546 1222">Hg</td><td data-bbox="546 1131 819 1222">Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)</td></tr> </table> </td> <td data-bbox="1003 1222 1173 1362" rowspan="2">—</td> </tr> <tr> <td data-bbox="286 1222 546 1331">Chloride (Cl⁻)</td> <td data-bbox="546 1222 819 1331">Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)</td> </tr> <tr> <td data-bbox="286 1331 546 1362">Total nitrogen</td> <td data-bbox="546 1331 819 1362">EN 12260</td> <td data-bbox="1003 1331 1173 1362">—</td> </tr> </tbody> </table>	Substance/Parameter	Standard(s)	Minimum monitoring frequency	Monitoring associated with	Total organic carbon (TOC) ₍₂₆₎	EN 1484	Once every month	BAT 15	Chemical oxygen demand (COD) ₍₂₆₎	No EN standard available	Total suspended solids (TSS)	EN 872	Fluoride (F ⁻)	EN ISO 10304-1	Sulphate (SO ₄ ²⁻)	EN ISO 10304-1	Sulphide, easily released (S ²⁻)	No EN standard available	Sulphite (SO ₃ ²⁻)	EN ISO 10304-3	Metals and metalloids	<table border="1" data-bbox="495 874 819 1222"> <tr><td data-bbox="495 874 546 911">As</td><td data-bbox="546 874 819 1117" rowspan="6">Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)</td></tr> <tr><td data-bbox="495 911 546 948">Cd</td></tr> <tr><td data-bbox="495 948 546 984">Cr</td></tr> <tr><td data-bbox="495 984 546 1021">Cu</td></tr> <tr><td data-bbox="495 1021 546 1058">Ni</td></tr> <tr><td data-bbox="495 1058 546 1094">Pb</td></tr> <tr><td data-bbox="495 1094 546 1131">Zn</td></tr> <tr><td data-bbox="495 1131 546 1222">Hg</td><td data-bbox="546 1131 819 1222">Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)</td></tr> </table>	As	Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)	Cd	Cr	Cu	Ni	Pb	Zn	Hg	Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)	—	Chloride (Cl ⁻)	Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)	Total nitrogen	EN 12260	—	NA	We agree that this BAT Conclusion is not applicable to the activities carried out at the installation as flue-gas treatment techniques are not implemented at the installation.
Substance/Parameter	Standard(s)	Minimum monitoring frequency	Monitoring associated with																																						
Total organic carbon (TOC) ₍₂₆₎	EN 1484	Once every month	BAT 15																																						
Chemical oxygen demand (COD) ₍₂₆₎	No EN standard available																																								
Total suspended solids (TSS)	EN 872																																								
Fluoride (F ⁻)	EN ISO 10304-1																																								
Sulphate (SO ₄ ²⁻)	EN ISO 10304-1																																								
Sulphide, easily released (S ²⁻)	No EN standard available																																								
Sulphite (SO ₃ ²⁻)	EN ISO 10304-3																																								
Metals and metalloids	<table border="1" data-bbox="495 874 819 1222"> <tr><td data-bbox="495 874 546 911">As</td><td data-bbox="546 874 819 1117" rowspan="6">Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)</td></tr> <tr><td data-bbox="495 911 546 948">Cd</td></tr> <tr><td data-bbox="495 948 546 984">Cr</td></tr> <tr><td data-bbox="495 984 546 1021">Cu</td></tr> <tr><td data-bbox="495 1021 546 1058">Ni</td></tr> <tr><td data-bbox="495 1058 546 1094">Pb</td></tr> <tr><td data-bbox="495 1094 546 1131">Zn</td></tr> <tr><td data-bbox="495 1131 546 1222">Hg</td><td data-bbox="546 1131 819 1222">Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)</td></tr> </table>			As	Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)	Cd	Cr	Cu	Ni	Pb	Zn	Hg	Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)	—																											
As	Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)																																								
Cd																																									
Cr																																									
Cu																																									
Ni																																									
Pb																																									
Zn																																									
Hg	Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)																																								
Chloride (Cl ⁻)	Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)																																								
Total nitrogen	EN 12260	—																																							

BAT C. No.	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the Operator to demonstrate compliance with the BAT Conclusion requirement																		
6	<p>In order to improve the general environmental performance of combustion plants and to reduce emissions to air of CO and unburnt substances, BAT is to ensure optimised combustion and to use an appropriate combination of the techniques given below.</p> <table border="1" data-bbox="286 443 1173 1294"> <thead> <tr> <th data-bbox="286 443 322 480">Technique</th> <th data-bbox="322 443 465 480">Description</th> <th data-bbox="465 443 1173 480">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="286 480 322 619">a</td> <td data-bbox="322 480 465 619">Fuel blending and mixing</td> <td data-bbox="465 480 1173 619">Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type</td> </tr> <tr> <td data-bbox="286 619 322 722">b</td> <td data-bbox="322 619 465 722">Maintenance of the combustion system</td> <td data-bbox="465 619 1173 722">Regular planned maintenance according to suppliers' recommendations</td> </tr> <tr> <td data-bbox="286 722 322 858">c</td> <td data-bbox="322 722 465 858">Advanced control system</td> <td data-bbox="465 722 1173 858">See description in Section 8.1</td> </tr> <tr> <td data-bbox="286 858 322 962">d</td> <td data-bbox="322 858 465 962">Good design of the combustion equipment</td> <td data-bbox="465 858 1173 962">Good design of furnace, combustion chambers, burners and associated devices</td> </tr> <tr> <td data-bbox="286 962 322 1294">e</td> <td data-bbox="322 962 465 1294">Fuel choice</td> <td data-bbox="465 962 1173 1294">Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used</td> </tr> </tbody> </table>			Technique	Description	Applicability	a	Fuel blending and mixing	Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type	b	Maintenance of the combustion system	Regular planned maintenance according to suppliers' recommendations	c	Advanced control system	See description in Section 8.1	d	Good design of the combustion equipment	Good design of furnace, combustion chambers, burners and associated devices	e	Fuel choice	Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used	CC	<p>The Operator has confirmed that an appropriate combination of techniques is used, as described below:</p> <ul style="list-style-type: none"> a. Refinery off gas is gradually mixed with NG during the combustion phase to ensure stable conditions are maintained. b. Maintenance of the combustion system by regular planned maintenance according to suppliers' recommendations. c. Advanced control system by use of a computer-based automatic system to control the combustion efficiency and support the prevention and/or reduction of emissions and also includes the use of high-performance monitoring. d. Good design of the combustion equipment by use of latest design of combustion burners and associated devices. e. For back up firing of the auxiliary boilers gas oil not exceeding 0.1% sulphur content is specified.
Technique	Description	Applicability																					
a	Fuel blending and mixing	Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type																					
b	Maintenance of the combustion system	Regular planned maintenance according to suppliers' recommendations																					
c	Advanced control system	See description in Section 8.1																					
d	Good design of the combustion equipment	Good design of furnace, combustion chambers, burners and associated devices																					
e	Fuel choice	Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used																					

BAT C. No.	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the Operator to demonstrate compliance with the BAT Conclusion requirement
7	<p>In order to reduce emissions of ammonia to air from the use of selective catalytic reduction (SCR) and/or selective non-catalytic reduction (SNCR) for the abatement of NO_x emissions, BAT is to optimise the design and/or operation of SCR and/or SNCR (e.g. optimised reagent to NO_x ratio, homogeneous reagent distribution and optimum size of the reagent drops).</p> <p>BAT-associated emission levels</p> <p>The BAT-associated emission level (BAT-AEL) for emissions of NH₃ to air from the use of SCR and/or SNCR is < 3–10 mg/Nm³ as a yearly average or average over the sampling period. The lower end of the range can be achieved when using SCR and the upper end of the range can be achieved when using SNCR without wet abatement techniques. In the case of plants combusting biomass and operating at variable loads as well as in the case of engines combusting HFO and/or gas oil, the higher end of the BAT-AEL range is 15 mg/Nm³.</p>	NA	Not applicable as there are no emissions of ammonia or abatement of NO _x emissions.
8	<p>In order to prevent or reduce emissions to air during normal operating conditions, BAT is to ensure, by appropriate design, operation and maintenance, that the emission abatement systems are used at optimal capacity and availability.</p>	NA	Not applicable as there are no emissions abatement systems.
9	<p>In order to improve the general environmental performance of combustion and/or gasification plants and to reduce emissions to air, BAT is to include the following elements in the quality assurance/quality control programmes for all the fuels used, as part of the environmental management system (see BAT 1):</p> <ul style="list-style-type: none"> (i) Initial full characterisation of the fuel used including at least the parameters listed below and in accordance with EN standards. ISO, national or other international standards may be used provided they ensure the provision of data of an equivalent scientific quality; (ii) Regular testing of the fuel quality to check that it is consistent with the initial characterisation and according to the plant design specifications. The frequency of testing and the parameters chosen from the table below are based on the variability of the fuel and an assessment of the relevance of pollutant releases (e.g. concentration in fuel, flue-gas treatment employed); (iii) Subsequent adjustment of the plant settings as and when needed and practicable (e.g. integration of the fuel characterisation and control in the advanced control system (see description in Section 8.1)). <p>Description</p> <p>Initial characterisation and regular testing of the fuel can be performed by the operator and/or the fuel supplier. If performed by the supplier, the full results are provided to the operator in the form of a product (fuel) supplier specification and/or guarantee.</p>	CC	<p>The following fuels are used at this installation:</p> <ol style="list-style-type: none"> 1. Natural gas, supplied from the National Grid; 2. Refinery fuel gas (also referred to as refinery off-gas (ROG) throughout this document and the permit), imported from Phillips 66 Humber Oil Refinery; 3. Liquid fuel oil (distillate oil), used as back-up fuel in Auxiliary Boilers 1 and 2, only in case of emergency interruption to the gas supply. <p>Compliance with the requirements of BAT conclusion 9 for each of these three fuels, as described by the operator in response to the Regulation 61(1) Notices, is addressed in the following:</p> <ol style="list-style-type: none"> 1. We consider that for plants which burn natural gas from the National Grid as a fuel that it is not necessary for the Operator to replicate the testing carried out by the National Grid. 2. The refinery fuel gas was initially analysed by external laboratories to provide full analysis. This included: <ul style="list-style-type: none"> - Determination of hydrocarbons from methane to hexadecane and

BAT C. No.	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the Operator to demonstrate compliance with the BAT Conclusion requirement																		
	<table border="1"> <thead> <tr> <th data-bbox="280 330 580 363">Fuel(s)</th> <th data-bbox="580 330 1180 363">Substances/Parameters subject to characterisation</th> </tr> </thead> <tbody> <tr> <td data-bbox="280 363 580 568">Biomass/peat</td> <td data-bbox="580 363 1180 568"> — LHV — moisture — Ash — C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn) </td> </tr> <tr> <td data-bbox="280 568 580 807">Coal/lignite</td> <td data-bbox="580 568 1180 807"> — LHV — Moisture — Volatiles, ash, fixed carbon, C, H, N, O, S — Br, Cl, F — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) </td> </tr> <tr> <td data-bbox="280 807 580 887">HFO</td> <td data-bbox="580 807 1180 887"> — Ash — C, S, N, Ni, V </td> </tr> <tr> <td data-bbox="280 887 580 967">Gas oil</td> <td data-bbox="580 887 1180 967"> — Ash — N, C, S </td> </tr> <tr> <td data-bbox="280 967 580 1054">Natural gas</td> <td data-bbox="580 967 1180 1054"> — LHV — CH₄, C₂H₆, C₃, C₄₊, CO₂, N₂, Wobbe index </td> </tr> <tr> <td data-bbox="280 1054 580 1166">Process fuels from the chemical industry⁽²⁷⁾</td> <td data-bbox="580 1054 1180 1166"> — Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) </td> </tr> <tr> <td data-bbox="280 1166 580 1238">Iron and steel process gases</td> <td data-bbox="580 1166 1180 1238"> — LHV, CH₄ (for COG), C_xH_y (for COG), CO₂, H₂, N₂, total sulphur, dust, Wobbe index </td> </tr> <tr> <td data-bbox="280 1238 580 1350">Waste⁽²⁸⁾</td> <td data-bbox="580 1238 1180 1350"> — LHV — Moisture — Volatiles, ash, Br, C, Cl, F, H, N, O, S </td> </tr> </tbody> </table>	Fuel(s)	Substances/Parameters subject to characterisation	Biomass/peat	— LHV — moisture — Ash — C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn)	Coal/lignite	— LHV — Moisture — Volatiles, ash, fixed carbon, C, H, N, O, S — Br, Cl, F — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)	HFO	— Ash — C, S, N, Ni, V	Gas oil	— Ash — N, C, S	Natural gas	— LHV — CH ₄ , C ₂ H ₆ , C ₃ , C ₄₊ , CO ₂ , N ₂ , Wobbe index	Process fuels from the chemical industry ⁽²⁷⁾	— Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)	Iron and steel process gases	— LHV, CH ₄ (for COG), C _x H _y (for COG), CO ₂ , H ₂ , N ₂ , total sulphur, dust, Wobbe index	Waste ⁽²⁸⁾	— LHV — Moisture — Volatiles, ash, Br, C, Cl, F, H, N, O, S		<p>inert gases in natural and associated petroleum gases (according to standards: ASTM D1945-03, ISO 6974-1:2001, ISO 6974-6:2002 and ISO 6975:1997) and by gas chromatography (UKAS Accredited Tests)</p> <ul style="list-style-type: none"> - Calculation of density, relative density, calorific value, Wobbe index and apparent molecular weight from gas composition by ISO 6976 - Determination of calorific value & relative density according to standards ASTM D3588-1991, density @ base conditions – AGA 8 - 1985 (Non UKAS Accredited Tests) <p>The ROG is continuously analysed by gas chromatography and verified as required for the EUETS.</p> <p>Although requirements for refinery fuel gas are not included in BAT 9, we consider that the initial characterisation and monitoring routine described by the Operator meets the intent of this BAT conclusion and is therefore satisfactory.</p> <p>3. Distillate fuel oil is tested by the supplier prior to delivery into the storage tank according to standard BS 2869:2010 + A2011. The Operator has confirmed that BAT 9 is complied for this fuel through the implementation within the site EMS of the operating techniques described in section 4 of the Joint Environmental Programme (JEP) document 'Characterisation of power plant fuels for compliance with LCP BREF Conclusion BAT 9'.</p> <p>We consider the operating techniques stated by the Operator are compliant with this BAT conclusion.</p>
Fuel(s)	Substances/Parameters subject to characterisation																				
Biomass/peat	— LHV — moisture — Ash — C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn)																				
Coal/lignite	— LHV — Moisture — Volatiles, ash, fixed carbon, C, H, N, O, S — Br, Cl, F — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)																				
HFO	— Ash — C, S, N, Ni, V																				
Gas oil	— Ash — N, C, S																				
Natural gas	— LHV — CH ₄ , C ₂ H ₆ , C ₃ , C ₄₊ , CO ₂ , N ₂ , Wobbe index																				
Process fuels from the chemical industry ⁽²⁷⁾	— Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)																				
Iron and steel process gases	— LHV, CH ₄ (for COG), C _x H _y (for COG), CO ₂ , H ₂ , N ₂ , total sulphur, dust, Wobbe index																				
Waste ⁽²⁸⁾	— LHV — Moisture — Volatiles, ash, Br, C, Cl, F, H, N, O, S																				

BAT C. No.	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the Operator to demonstrate compliance with the BAT Conclusion requirement						
	<table border="1"> <tr> <td data-bbox="280 327 577 402"></td> <td data-bbox="577 327 1180 402">— Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)</td> </tr> </table>		— Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)						
	— Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)								
10	<p>In order to reduce emissions to air and/or to water during other than normal operating conditions (OTNOC), BAT is to set up and implement a management plan as part of the environmental management system (see BAT 1), commensurate with the relevance of potential pollutant releases, that includes the following elements:</p> <ul style="list-style-type: none"> — appropriate design of the systems considered relevant in causing OTNOC that may have an impact on emissions to air, water and/or soil (e.g. low-load design concepts for reducing the minimum start-up and shutdown loads for stable generation in gas turbines), — set-up and implementation of a specific preventive maintenance plan for these relevant systems, — review and recording of emissions caused by OTNOC and associated circumstances and implementation of corrective actions if necessary, — periodic assessment of the overall emissions during OTNOC (e.g. frequency of events, duration, emissions quantification/estimation) and implementation of corrective actions if necessary. 	CC	<p>The Operator has confirmed the following provisions of OTNOC:</p> <ul style="list-style-type: none"> - Low load design concepts in A1 and A2; combustion tuning in A3 + A4 to ensure that the duration of start-up and shut-down periods are minimised during operation. - All site combustion assets are part of a preventative maintenance plan, specifically an Engineering Strategy (VPII-BUP-PR-0031) and a rolling asset care plan is in place for the GT's with the manufacturer (GE). For water treatment assets this is also the case, some of which are with the OEM for proprietary water treatments. - Emissions caused by OTNOC are still recorded on site as mass emissions. These are recorded and reported as per mass emission requirements. For water emissions these are still recorded and reported as required. - Fugitive emissions are calculated on the basis of standardised amounts and number of plant trips / purges of gases are recorded for quantification and inclusion with the site Pollution Inventory return. 						
11	<p>BAT is to appropriately monitor emissions to air and/or to water during OTNOC.</p> <p>Description</p> <p>The monitoring can be carried out by direct measurement of emissions or by monitoring of surrogate parameters if this proves to be of equal or better scientific quality than the direct measurement of emissions. Emissions during start-up and shutdown (SU/SD) may be assessed based on a detailed emission measurement carried out for a typical SU/SD procedure at least once every year, and using the results of this measurement to estimate the emissions for each and every SU/SD throughout the year.</p>	CC	<p>The Operator has confirmed that emissions caused by OTNOC are still recorded. These include emissions recorded by the CEMS during start-up and shut-down (0 load to maximum continuous rate / base load).</p>						
12	<p>In order to increase the energy efficiency of combustion, gasification and/or IGCC units operated $\geq 1\,500$ h/yr, BAT is to use an appropriate combination of the techniques given below.</p> <table border="1" data-bbox="280 1284 1180 1372"> <thead> <tr> <th data-bbox="280 1284 481 1321">Technique</th> <th data-bbox="481 1284 840 1321">Description</th> <th data-bbox="840 1284 1180 1321">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="280 1321 481 1372">a. Combustion optimisation</td> <td data-bbox="481 1321 840 1372">See description in Section 8.2. Optimising the combustion</td> <td data-bbox="840 1321 1180 1372">Generally applicable</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Combustion optimisation	See description in Section 8.2. Optimising the combustion	Generally applicable	CC	<p>The Operator has confirmed that an appropriate combination of techniques is used, as described below:</p> <p>a. Combustion Optimisation: Measures taken to maximise the efficiency of energy conversion, e.g. in the furnace/boiler, while minimising emissions (in particular of CO). This is achieved by a</p>
Technique	Description	Applicability							
a. Combustion optimisation	See description in Section 8.2. Optimising the combustion	Generally applicable							

BAT C. No.	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the Operator to demonstrate compliance with the BAT Conclusion requirement
		minimises the content of unburnt substances in the flue-gases and in solid combustion residues			<p>combination of techniques including good design of the combustion equipment, optimisation of the temperature (e.g. efficient mixing of the fuel and combustion air) and residence time in the combustion zone, and use of an advanced control system.</p> <p>b. Optimisation of the working medium conditions: use of combined cycle - combination of two thermodynamic cycles, i.e. a Brayton cycle (gas turbine/combustion engine) with a Rankine cycle (steam turbine/boiler), to convert heat loss from the flue-gas of the first cycle to useful energy by subsequent cycle(s).</p> <p>c. Optimisation of the steam cycle:</p> <ul style="list-style-type: none"> - Steam Turbine major overhaul as part of outage, (ST1 /2 2017 and ST3 2018) - To increase the vacuum within the steam cycle, periodic air ingress surveys are undertaken to identify leaks. - Overall Cooling Tower and Air Cooling Condenser efficiency improvements to lower the condenser cooling water, therefore increasing the vacuum effect. - Periodic condenser cleaning in accordance with the site maintenance strategy. <p>d. Minimisation of energy consumption: the operator has implemented energy reduction measures, one example is the installation of a 'gale breaker' curtain on the air cooled condenser. This design improves fan efficiency by reducing wind shear and turbulence, therefore minimising energy consumption in this area.</p> <p>e. Preheating of combustion air: Flue Gas Recirculation System on the Auxiliary Boilers, primarily aimed at reducing NOx it does some heating effect on the combustion air entering the boilers.</p> <p>f. Fuel Preheating: Natural gas is preheated prior to being burnt in the gas turbines, the heat provided comes from hot water tapped off from the associated HRSG.</p> <p>g. Advanced control system: The use of a computer-based automatic system to control the combustion efficiency and support</p>
b.	Optimisation of the working medium conditions	Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO _x emissions or the characteristics of energy demanded			
c.	Optimisation of the steam cycle	Operate with lower turbine exhaust pressure by utilisation of the lowest possible temperature of the condenser cooling water, within the design conditions			
d.	Minimisation of energy consumption	Minimising the internal energy consumption (e.g. greater efficiency of the feed-water pump)			
e.	Preheating of combustion air	Reuse of part of the heat recovered from the combustion flue-gas to preheat the air used in combustion	Generally applicable within the constraints related to the need to control NO _x emissions		
f.	Fuel preheating	Preheating of fuel using recovered heat	Generally applicable within the constraints associated with the boiler design and the need to control NO _x emissions		
g.	Advanced control system	See description in Section 8.2. Computerised control of the main combustion parameters enables the combustion efficiency to be improved	Generally applicable to new units. The applicability to old units may be constrained by the need to retrofit the combustion system and/or control command system		
h.	Feed-water preheating using recovered heat	Preheat water coming out of the steam condenser with recovered heat, before reusing it in the boiler	Only applicable to steam circuits and not to hot boilers. Applicability to existing units may be limited due to constraints associated with the plant configuration and the amount of recoverable heat		
i.	Heat recovery	Recovery of heat (mainly from the	Applicable within the constraints		

BAT C. No.	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the Operator to demonstrate compliance with the BAT Conclusion requirement
	by cogeneration (CHP)	steam system) for producing hot water/steam to be used in industrial processes/activities or in a public network for district heating. Additional heat recovery is possible from: — flue-gas — grate cooling — circulating fluidised bed	associated with the local heat and power demand. The applicability may be limited in the case of gas compressors with an unpredictable operational heat profile		<p>the prevention and/or reduction of emissions. This also includes the use of high-performance monitoring on the gas turbines.</p> <p>h. Feed water preheating using recovered heat: feed water is pre heated on both auxiliary boilers by using an economiser transferring heat from the flue gas to the feed water.</p> <p>i. Heat recovery by cogeneration (CHP): the steam produced is used by 2 adjacent oil refineries.</p> <p>r. Steam turbine upgrades: Please see c above.</p>
	j. CHP readiness	See description in Section 8.2.	Only applicable to new units where there is a realistic potential for the future use of heat in the vicinity of the unit		
	k. Flue-gas condenser	See description in Section 8.2.	Generally applicable to CHP units provided there is enough demand for low-temperature heat		
	l. Heat accumulation	Heat accumulation storage in CHP mode	Only applicable to CHP plants. The applicability may be limited in the case of low heat load demand		
	m. Wet stack	See description in Section 8.2.	Generally applicable to new and existing units fitted with wet FGD		
	n. Cooling tower discharge	The release of emissions to air through a cooling tower and not via a dedicated stack	Only applicable to units fitted with wet FGD where reheating of the flue-gas is necessary before release, and where the unit cooling system is a cooling tower		
	o. Fuel pre-drying	The reduction of fuel moisture content before combustion to improve combustion conditions	Applicable to the combustion of biomass and/or peat within the constraints associated with spontaneous combustion risks (e.g. the moisture content of peat is kept above 40 % throughout the delivery chain). The retrofit of existing plants may be restricted by the extra calorific value that can be obtained from the drying operation and by the		

BAT C. No.	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the Operator to demonstrate compliance with the BAT Conclusion requirement
				limited retrofit possibilities offered by some boiler designs or plant configurations	
	p.	Minimisation of heat losses	Minimising residual heat losses, e.g. those that occur via the slag or those that can be reduced by insulating radiating sources	Only applicable to solid-fuel-fired combustion units and to gasification/IGCC units	
	q.	Advanced materials	Use of advanced materials proven to be capable of withstanding high operating temperatures and pressures and thus to achieve increased steam/combustion process efficiencies	Only applicable to new plants	
	r.	Steam turbine upgrades	This includes techniques such as increasing the temperature and pressure of medium-pressure steam, addition of a low-pressure turbine, and modifications to the geometry of the turbine rotor blades	The applicability may be restricted by demand, steam conditions and/or limited plant lifetime	
	s.	Supercritical and ultra-supercritical steam conditions	Use of a steam circuit, including steam reheating systems, in which steam can reach pressures above 220,6 bar and temperatures above 374 °C in the case of supercritical conditions, and above 250 – 300 bar and temperatures above 580 – 600 °C in the case of ultra-supercritical conditions	Only applicable to new units of $\geq 600 \text{ MW}_{\text{th}}$ operated $> 4\,000 \text{ h/yr}$. Not applicable when the purpose of the unit is to produce low steam temperatures and/or pressures in process industries. Not applicable to gas turbines and engines generating steam in CHP mode. For units combusting biomass, the applicability may be constrained by high-temperature corrosion in the case of certain biomasses	
13	In order to reduce water usage and the volume of contaminated waste water discharged, BAT is to use one or both of the techniques given below.			CC	a. Water recycling techniques are applied as follows: treated wastewater that would be discharged to the environment from Phillips 66 Humber Oil Refinery is received and processed to use as make-up water for the wet cooling tower system: the treated effluent from the P66 Humber refineries effluent treatment plant is then
	Technique	Description	Applicability		
	a Water recycling	Residual aqueous streams, including run-off water, from the plant are reused for	Not applicable to waste water from cooling systems when		

BAT C. No.	Summary of BAT Conclusion requirement		Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the Operator to demonstrate compliance with the BAT Conclusion requirement
		other purposes. The degree of recycling is limited by the quality requirements of the recipient water stream and the water balance of the plant	water treatment chemicals and/or high concentrations of salts from seawater are present	<p>blended with cooling tower water (as a form of side stream filtration) and passed through a Zenon Ultra filtration system. The water is further blended with Anglian industrial water and passed through reverse osmosis membranes before being sent to the cooling towers as make up water.</p> <p>There is currently a project being installed to further recycle Demin Reverse osmosis system backwash water through the process described above to offset some of the Anglian industrial water requirement– therefore saving water.</p> <p>Steam sent to Customers (Phillips 66 Humber Oil Refinery and TOTAL Lindsey Oil Refinery) is returned as condensate and processed to produce demineralised water. The remaining techniques are deemed not applicable.</p> <p>b. Dry bottom ash handling: N/A as not solid fuel</p>
	b Dry bottom ash handling	Dry, hot bottom ash falls from the furnace onto a mechanical conveyor system and is cooled down by ambient air. No water is used in the process.	Only applicable to plants combusting solid fuels. There may be technical restrictions that prevent retrofitting to existing combustion plants	
14	<p>In order to prevent the contamination of uncontaminated waste water and to reduce emissions to water, BAT is to segregate waste water streams and to treat them separately, depending on the pollutant content.</p> <p>Description Waste water streams that are typically segregated and treated include surface run-off water, cooling water, and waste water from flue-gas treatment.</p> <p>Applicability The applicability may be restricted in the case of existing plants due to the configuration of the drainage systems.</p>		CC	<p>The operator has addressed compliance with this BAT conclusion, in response to the additional Regulation 61(1) Notice served on 19/11/2019 and responded on 20/12/2019. Segregation of waste water streams is implemented as follows:</p> <ul style="list-style-type: none"> - Surface Water: This is captured within the site drainage system whereby it is routed into the holding pond (M2). Where there is a risk of oil contamination in the collecting areas the drainage system is routed through an oily water separator. - Process Water: The water discharged from the process is predominately blowdown from the cooling water circuit, this is discharged to prevent a build-up of dissolved solids, due to the evaporative losses from the cooling system. This water is held in the M1 holding pond, tested in accordance with the permit and then pumped forward to the M2 holding pond ready for discharge. As LCP 415 utilises an air cooling condenser, there isn't the amount of wasted water so holding pond M3 is much smaller. This holding pond also collects the condensate from the steam cycle of the site. Water is tested in accordance with the permit and then pumped forward to M2. - Final discharge: Water is then released from site at one outfall point (W1).

BAT C. No.	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the Operator to demonstrate compliance with the BAT Conclusion requirement																																										
15	<p>In order to reduce emissions to water from flue-gas treatment, BAT is to use an appropriate combination of the techniques given below, and to use secondary techniques as close as possible to the source in order to avoid dilution.</p> <table border="1" data-bbox="277 411 1173 1370"> <thead> <tr> <th data-bbox="277 411 584 475">Technique</th> <th data-bbox="584 411 815 475">Typical pollutants prevented/abated</th> <th data-bbox="815 411 1173 475">Applicability</th> </tr> </thead> <tbody> <tr> <td colspan="3" data-bbox="277 475 1173 507" style="text-align: center;">Primary techniques</td> </tr> <tr> <td data-bbox="277 507 584 619">a. Optimised combustion (see BAT 6) and flue-gas treatment systems (e.g. SCR/SNCR, see BAT 7)</td> <td data-bbox="584 507 815 619">Organic compounds, ammonia (NH₃)</td> <td data-bbox="815 507 1173 619">Generally applicable</td> </tr> <tr> <td colspan="3" data-bbox="277 619 1173 651" style="text-align: center;">Secondary techniques ⁽²⁹⁾</td> </tr> <tr> <td data-bbox="277 651 584 715">b. Adsorption on activated carbon</td> <td data-bbox="584 651 815 715">Organic compounds, mercury (Hg)</td> <td data-bbox="815 651 1173 715">Generally applicable</td> </tr> <tr> <td data-bbox="277 715 584 895">c. Aerobic biological treatment</td> <td data-bbox="584 715 815 895">Biodegradable organic compounds, ammonium (NH₄⁺)</td> <td data-bbox="815 715 1173 895">Generally applicable for the treatment of organic compounds. Aerobic biological treatment of ammonium (NH₄⁺) may not be applicable in the case of high chloride concentrations (i.e. around 10 g/l)</td> </tr> <tr> <td data-bbox="277 895 584 959">d. Anoxic/anaerobic biological treatment</td> <td data-bbox="584 895 815 959">Mercury (Hg), nitrate (NO₃⁻), nitrite (NO₂⁻)</td> <td data-bbox="815 895 1173 959">Generally applicable</td> </tr> <tr> <td data-bbox="277 959 584 1015">e. Coagulation and flocculation</td> <td data-bbox="584 959 815 1015">Suspended solids</td> <td data-bbox="815 959 1173 1015">Generally applicable</td> </tr> <tr> <td data-bbox="277 1015 584 1094">f. Crystallisation</td> <td data-bbox="584 1015 815 1094">Metals and metalloids, sulphate (SO₄²⁻), fluoride (F⁻)</td> <td data-bbox="815 1015 1173 1094">Generally applicable</td> </tr> <tr> <td data-bbox="277 1094 584 1182">g. Filtration (e.g. sand filtration, microfiltration, ultrafiltration)</td> <td data-bbox="584 1094 815 1182">Suspended solids, metals</td> <td data-bbox="815 1094 1173 1182">Generally applicable</td> </tr> <tr> <td data-bbox="277 1182 584 1238">h. Flotation</td> <td data-bbox="584 1182 815 1238">Suspended solids, free oil</td> <td data-bbox="815 1182 1173 1238">Generally applicable</td> </tr> <tr> <td data-bbox="277 1238 584 1278">i. Ion exchange</td> <td data-bbox="584 1238 815 1278">Metals</td> <td data-bbox="815 1238 1173 1278">Generally applicable</td> </tr> <tr> <td data-bbox="277 1278 584 1310">j. Neutralisation</td> <td data-bbox="584 1278 815 1310">Acids, alkalis</td> <td data-bbox="815 1278 1173 1310">Generally applicable</td> </tr> <tr> <td data-bbox="277 1310 584 1370">k. Oxidation</td> <td data-bbox="584 1310 815 1370">Sulphide (S²⁻), sulphite (SO₃²⁻)</td> <td data-bbox="815 1310 1173 1370">Generally applicable</td> </tr> </tbody> </table>	Technique	Typical pollutants prevented/abated	Applicability	Primary techniques			a. Optimised combustion (see BAT 6) and flue-gas treatment systems (e.g. SCR/SNCR, see BAT 7)	Organic compounds, ammonia (NH ₃)	Generally applicable	Secondary techniques ⁽²⁹⁾			b. Adsorption on activated carbon	Organic compounds, mercury (Hg)	Generally applicable	c. Aerobic biological treatment	Biodegradable organic compounds, ammonium (NH ₄ ⁺)	Generally applicable for the treatment of organic compounds. Aerobic biological treatment of ammonium (NH ₄ ⁺) may not be applicable in the case of high chloride concentrations (i.e. around 10 g/l)	d. Anoxic/anaerobic biological treatment	Mercury (Hg), nitrate (NO ₃ ⁻), nitrite (NO ₂ ⁻)	Generally applicable	e. Coagulation and flocculation	Suspended solids	Generally applicable	f. Crystallisation	Metals and metalloids, sulphate (SO ₄ ²⁻), fluoride (F ⁻)	Generally applicable	g. Filtration (e.g. sand filtration, microfiltration, ultrafiltration)	Suspended solids, metals	Generally applicable	h. Flotation	Suspended solids, free oil	Generally applicable	i. Ion exchange	Metals	Generally applicable	j. Neutralisation	Acids, alkalis	Generally applicable	k. Oxidation	Sulphide (S ²⁻), sulphite (SO ₃ ²⁻)	Generally applicable	NA	Not applicable - there is no flue-gas treatment
Technique	Typical pollutants prevented/abated	Applicability																																											
Primary techniques																																													
a. Optimised combustion (see BAT 6) and flue-gas treatment systems (e.g. SCR/SNCR, see BAT 7)	Organic compounds, ammonia (NH ₃)	Generally applicable																																											
Secondary techniques ⁽²⁹⁾																																													
b. Adsorption on activated carbon	Organic compounds, mercury (Hg)	Generally applicable																																											
c. Aerobic biological treatment	Biodegradable organic compounds, ammonium (NH ₄ ⁺)	Generally applicable for the treatment of organic compounds. Aerobic biological treatment of ammonium (NH ₄ ⁺) may not be applicable in the case of high chloride concentrations (i.e. around 10 g/l)																																											
d. Anoxic/anaerobic biological treatment	Mercury (Hg), nitrate (NO ₃ ⁻), nitrite (NO ₂ ⁻)	Generally applicable																																											
e. Coagulation and flocculation	Suspended solids	Generally applicable																																											
f. Crystallisation	Metals and metalloids, sulphate (SO ₄ ²⁻), fluoride (F ⁻)	Generally applicable																																											
g. Filtration (e.g. sand filtration, microfiltration, ultrafiltration)	Suspended solids, metals	Generally applicable																																											
h. Flotation	Suspended solids, free oil	Generally applicable																																											
i. Ion exchange	Metals	Generally applicable																																											
j. Neutralisation	Acids, alkalis	Generally applicable																																											
k. Oxidation	Sulphide (S ²⁻), sulphite (SO ₃ ²⁻)	Generally applicable																																											

BAT C. No.	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the Operator to demonstrate compliance with the BAT Conclusion requirement
	l. Precipitation	Metals and metalloids, sulphate (SO ₄ ²⁻), fluoride (F ⁻)	Generally applicable		
	m. Sedimentation	Suspended solids	Generally applicable		
	n. Stripping	Ammonia (NH ₃)	Generally applicable		
	The BAT-AELs refer to direct discharges to a receiving water body at the point where the emission leaves the installation.				
	BAT-AELs for direct discharges to a receiving water body from flue-gas treatment				
	Substance/Parameter		BAT-AELs		
			Daily average		
	Total organic carbon (TOC)		20–50 mg/l ⁽³⁰⁾ ₍₃₁₎ ₍₃₂₎		
	Chemical oxygen demand (COD)		60–150 mg/l ⁽³⁰⁾ ₍₃₁₎ ₍₃₂₎		
	Total suspended solids (TSS)		10–30 mg/l		
	Fluoride (F ⁻)		10–25 mg/l ⁽³²⁾		
	Sulphate (SO ₄ ²⁻)		1,3–2,0 g/l ⁽³²⁾ ₍₃₃₎ ₍₃₄₎ ₍₃₅₎		
	Sulphide (S ²⁻), easily released		0,1–0,2 mg/l ⁽³²⁾		
	Sulphite (SO ₃ ²⁻)		1–20 mg/l ⁽³²⁾		
	Metals and metalloids	As	10–50 µg/l		
		Cd	2–5 µg/l		
		Cr	10–50 µg/l		
		Cu	10–50 µg/l		
		Hg	0,2–3 µg/l		
		Ni	10–50 µg/l		
		Pb	10–20 µg/l		
		Zn	50–200 µg/l		
16	In order to reduce the quantity of waste sent for disposal from the combustion and/or gasification process and abatement techniques, BAT is to organise operations so as to maximise, in order of priority and taking into account life-cycle thinking: (a waste prevention, e.g. maximise the proportion of residues which arise as by-products;			NA	Not applicable. There is no waste from the gas fired combustion processes.

BAT C. No.	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the Operator to demonstrate compliance with the BAT Conclusion requirement															
	<p>(b) waste preparation for reuse, e.g. according to the specific requested quality criteria;</p> <p>(c) waste recycling;</p> <p>(d) other waste recovery (e.g. energy recovery),</p> <p>by implementing an appropriate combination of techniques such as:</p> <table border="1" data-bbox="280 504 1180 1299"> <thead> <tr> <th data-bbox="280 504 481 539">Technique</th> <th data-bbox="481 504 866 539">Description</th> <th data-bbox="866 504 1180 539">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="280 539 481 746">a. Generation of gypsum as a by-product</td> <td data-bbox="481 539 866 746">Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g. as raw material in the plasterboard industry). The quality of limestone used in the wet FGD influences the purity of the gypsum produced</td> <td data-bbox="866 539 1180 746">Generally applicable within the constraints associated with the required gypsum quality, the health requirements associated to each specific use, and by the market conditions</td> </tr> <tr> <td data-bbox="280 746 481 954">b. Recycling or recovery of residues in the construction sector</td> <td data-bbox="481 746 866 954">Recycling or recovery of residues (e.g. from semi-dry desulphurisation processes, fly ash, bottom ash) as a construction material (e.g. in road building, to replace sand in concrete production, or in the cement industry)</td> <td data-bbox="866 746 1180 954">Generally applicable within the constraints associated with the required material quality (e.g. physical properties, content of harmful substances) associated to each specific use, and by the market conditions</td> </tr> <tr> <td data-bbox="280 954 481 1090">c. Energy recovery by using waste in the fuel mix</td> <td data-bbox="481 954 866 1090">The residual energy content of carbon-rich ash and sludges generated by the combustion of coal, lignite, heavy fuel oil, peat or biomass can be recovered for example by mixing with the fuel</td> <td data-bbox="866 954 1180 1090">Generally applicable where plants can accept waste in the fuel mix and are technically able to feed the fuels into the combustion chamber</td> </tr> <tr> <td data-bbox="280 1090 481 1299">d. Preparation of spent catalyst for reuse</td> <td data-bbox="481 1090 866 1299">Preparation of catalyst for reuse (e.g. up to four times for SCR catalysts) restores some or all of the original performance, extending the service life of the catalyst to several decades. Preparation of spent catalyst for reuse is integrated in a catalyst management scheme</td> <td data-bbox="866 1090 1180 1299">The applicability may be limited by the mechanical condition of the catalyst and the required performance with respect to controlling NO_x and NH₃ emissions</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Generation of gypsum as a by-product	Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g. as raw material in the plasterboard industry). The quality of limestone used in the wet FGD influences the purity of the gypsum produced	Generally applicable within the constraints associated with the required gypsum quality, the health requirements associated to each specific use, and by the market conditions	b. Recycling or recovery of residues in the construction sector	Recycling or recovery of residues (e.g. from semi-dry desulphurisation processes, fly ash, bottom ash) as a construction material (e.g. in road building, to replace sand in concrete production, or in the cement industry)	Generally applicable within the constraints associated with the required material quality (e.g. physical properties, content of harmful substances) associated to each specific use, and by the market conditions	c. Energy recovery by using waste in the fuel mix	The residual energy content of carbon-rich ash and sludges generated by the combustion of coal, lignite, heavy fuel oil, peat or biomass can be recovered for example by mixing with the fuel	Generally applicable where plants can accept waste in the fuel mix and are technically able to feed the fuels into the combustion chamber	d. Preparation of spent catalyst for reuse	Preparation of catalyst for reuse (e.g. up to four times for SCR catalysts) restores some or all of the original performance, extending the service life of the catalyst to several decades. Preparation of spent catalyst for reuse is integrated in a catalyst management scheme	The applicability may be limited by the mechanical condition of the catalyst and the required performance with respect to controlling NO _x and NH ₃ emissions		
Technique	Description	Applicability																
a. Generation of gypsum as a by-product	Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g. as raw material in the plasterboard industry). The quality of limestone used in the wet FGD influences the purity of the gypsum produced	Generally applicable within the constraints associated with the required gypsum quality, the health requirements associated to each specific use, and by the market conditions																
b. Recycling or recovery of residues in the construction sector	Recycling or recovery of residues (e.g. from semi-dry desulphurisation processes, fly ash, bottom ash) as a construction material (e.g. in road building, to replace sand in concrete production, or in the cement industry)	Generally applicable within the constraints associated with the required material quality (e.g. physical properties, content of harmful substances) associated to each specific use, and by the market conditions																
c. Energy recovery by using waste in the fuel mix	The residual energy content of carbon-rich ash and sludges generated by the combustion of coal, lignite, heavy fuel oil, peat or biomass can be recovered for example by mixing with the fuel	Generally applicable where plants can accept waste in the fuel mix and are technically able to feed the fuels into the combustion chamber																
d. Preparation of spent catalyst for reuse	Preparation of catalyst for reuse (e.g. up to four times for SCR catalysts) restores some or all of the original performance, extending the service life of the catalyst to several decades. Preparation of spent catalyst for reuse is integrated in a catalyst management scheme	The applicability may be limited by the mechanical condition of the catalyst and the required performance with respect to controlling NO _x and NH ₃ emissions																
17	In order to reduce noise emissions, BAT is to use one or a combination of the techniques given below.	CC	The Operator has confirmed that an appropriate combination of noise control techniques are used, as described below:															

BAT C. No.	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the Operator to demonstrate compliance with the BAT Conclusion requirement																							
	<table border="1"> <thead> <tr> <th data-bbox="280 330 315 355"></th> <th data-bbox="315 330 488 355">Technique</th> <th data-bbox="488 330 875 355">Description</th> <th data-bbox="875 330 1178 355">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="280 363 315 703">a.</td> <td data-bbox="315 363 488 703">Operational measures</td> <td data-bbox="488 363 875 703"> These include: <ul style="list-style-type: none"> — improved inspection and maintenance of equipment — closing of doors and windows of enclosed areas, if possible — equipment operated by experienced staff — avoidance of noisy activities at night, if possible — provisions for noise control during maintenance activities </td> <td data-bbox="875 363 1178 703">Generally applicable</td> </tr> <tr> <td data-bbox="280 711 315 762">b.</td> <td data-bbox="315 711 488 762">Low-noise equipment</td> <td data-bbox="488 711 875 762">This potentially includes compressors, pumps and disks</td> <td data-bbox="875 711 1178 762">Generally applicable when the equipment is new or replaced</td> </tr> <tr> <td data-bbox="280 770 315 895">c.</td> <td data-bbox="315 770 488 895">Noise attenuation</td> <td data-bbox="488 770 875 895">Noise propagation can be reduced by inserting obstacles between the emitter and the receiver. Appropriate obstacles include protection walls, embankments and buildings</td> <td data-bbox="875 770 1178 895">Generally applicable to new plants. In the case of existing plants, the insertion of obstacles may be restricted by lack of space</td> </tr> <tr> <td data-bbox="280 903 315 1075">d.</td> <td data-bbox="315 903 488 1075">Noise-control equipment</td> <td data-bbox="488 903 875 1075"> This includes: <ul style="list-style-type: none"> — noise-reducers — equipment insulation — enclosure of noisy equipment — soundproofing of buildings </td> <td data-bbox="875 903 1178 1075">The applicability may be restricted by lack of space</td> </tr> <tr> <td data-bbox="280 1083 315 1187">e.</td> <td data-bbox="315 1083 488 1187">Appropriate location of equipment and buildings</td> <td data-bbox="488 1083 875 1187">Noise levels can be reduced by increasing the distance between the emitter and the receiver and by using buildings as noise screens</td> <td data-bbox="875 1083 1178 1187">Generally applicable to new plant</td> </tr> </tbody> </table>		Technique	Description	Applicability	a.	Operational measures	These include: <ul style="list-style-type: none"> — improved inspection and maintenance of equipment — closing of doors and windows of enclosed areas, if possible — equipment operated by experienced staff — avoidance of noisy activities at night, if possible — provisions for noise control during maintenance activities 	Generally applicable	b.	Low-noise equipment	This potentially includes compressors, pumps and disks	Generally applicable when the equipment is new or replaced	c.	Noise attenuation	Noise propagation can be reduced by inserting obstacles between the emitter and the receiver. Appropriate obstacles include protection walls, embankments and buildings	Generally applicable to new plants. In the case of existing plants, the insertion of obstacles may be restricted by lack of space	d.	Noise-control equipment	This includes: <ul style="list-style-type: none"> — noise-reducers — equipment insulation — enclosure of noisy equipment — soundproofing of buildings 	The applicability may be restricted by lack of space	e.	Appropriate location of equipment and buildings	Noise levels can be reduced by increasing the distance between the emitter and the receiver and by using buildings as noise screens	Generally applicable to new plant			<p>a. Operational measures: Equipment is maintained with a maintenance management system employing preventive measures. The plant is operated by experienced staff. Start-up and shut-down of plant is avoided at night when possible taking into account the commercial requirement for plant operation.</p> <p>b. Low noise equipment: Noise levels are taken into account when replacing legacy equipment.</p> <p>c. Noise attenuation: High noise equipment is contained within acoustic enclosures. High noise maintenance activities are planned to be shielded to reduce noise emissions.</p> <p>d. Noise-control equipment: Equipment is insulated where required and high noise areas have acoustic enclosures.</p> <p>e. Appropriate location of equipment and buildings: There are buildings between the site and the nearest residential location. Noise surveys are carried out every year at the nearest receptor that show the noise emission to be within the required permitted compliance limit.</p>
	Technique	Description	Applicability																									
a.	Operational measures	These include: <ul style="list-style-type: none"> — improved inspection and maintenance of equipment — closing of doors and windows of enclosed areas, if possible — equipment operated by experienced staff — avoidance of noisy activities at night, if possible — provisions for noise control during maintenance activities 	Generally applicable																									
b.	Low-noise equipment	This potentially includes compressors, pumps and disks	Generally applicable when the equipment is new or replaced																									
c.	Noise attenuation	Noise propagation can be reduced by inserting obstacles between the emitter and the receiver. Appropriate obstacles include protection walls, embankments and buildings	Generally applicable to new plants. In the case of existing plants, the insertion of obstacles may be restricted by lack of space																									
d.	Noise-control equipment	This includes: <ul style="list-style-type: none"> — noise-reducers — equipment insulation — enclosure of noisy equipment — soundproofing of buildings 	The applicability may be restricted by lack of space																									
e.	Appropriate location of equipment and buildings	Noise levels can be reduced by increasing the distance between the emitter and the receiver and by using buildings as noise screens	Generally applicable to new plant																									
Combustion of liquid fuels																												
<p>Not applicable. The installation uses distillate fuel oil as back-up fuel in the auxiliary boilers of LCP188, for emergency scenarios when the supply of natural gas is interrupted. This operation is restricted in the permit to 'no more than 500 hours per calendar year with a maximum period of 240 hours', in line with the requirements of Article 30(6) of IED and its interpretation made by the UK Regulators at the time of the IED Chapter III implementation.</p> <p>BAT conclusions 18 to 39 for combustion of liquid fuels are not applicable to scenarios permitted according to Article 30(6) of IED.</p>																												

BAT C. No.	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the Operator to demonstrate compliance with the BAT Conclusion requirement																																			
Combustion of gaseous fuels																																						
40	In order to increase the energy efficiency of natural gas combustion, BAT is to use an appropriate combination of the techniques given in BAT 12 and below.	CC	The installation consists of combined cycle (CCGT), operation in CHP mode.																																			
	<table border="1"> <thead> <tr> <th data-bbox="277 432 421 491">Technique</th> <th data-bbox="421 432 600 491">Description</th> <th data-bbox="600 432 1182 491">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="277 491 421 774">a</td> <td data-bbox="421 491 600 774">Combined cycle See description in Section 8.2</td> <td data-bbox="600 491 1182 774">Generally applicable to new gas turbines and engines except when operated < 1 500 h/yr. Applicable to existing gas turbines and engines within the constraints associated with the steam cycle design and the space availability. Not applicable to existing gas turbines and engines operated < 1 500 h/yr. Not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns. Not applicable to boilers</td> </tr> </tbody> </table>	Technique	Description	Applicability	a	Combined cycle See description in Section 8.2	Generally applicable to new gas turbines and engines except when operated < 1 500 h/yr. Applicable to existing gas turbines and engines within the constraints associated with the steam cycle design and the space availability. Not applicable to existing gas turbines and engines operated < 1 500 h/yr. Not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns. Not applicable to boilers		The Operator has reported a net electrical efficiency of 52% for the combined operation of LCP188 and LCP415 (CHP CCGT, ≥ 600 MWth), which is within the applicable BAT-AEEL range. Refer to section 4.2 of this document for additional details.																													
Technique	Description	Applicability																																				
a	Combined cycle See description in Section 8.2	Generally applicable to new gas turbines and engines except when operated < 1 500 h/yr. Applicable to existing gas turbines and engines within the constraints associated with the steam cycle design and the space availability. Not applicable to existing gas turbines and engines operated < 1 500 h/yr. Not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns. Not applicable to boilers																																				
	BAT-associated energy efficiency levels (BAT-AEELs) for the combustion of natural gas																																					
	<table border="1"> <thead> <tr> <th data-bbox="277 836 488 991" rowspan="3">Type of combustion unit</th> <th colspan="5" data-bbox="488 836 1182 863">BAT-AEELs ⁽¹³⁶⁾ ⁽¹³⁷⁾</th> </tr> <tr> <th colspan="2" data-bbox="488 863 689 927">Net electrical efficiency (%)</th> <th data-bbox="689 863 904 927">Net total fuel utilisation (%) ⁽¹³⁸⁾ ⁽¹³⁹⁾</th> <th colspan="2" data-bbox="904 863 1182 927">Net mechanical energy efficiency (%) ⁽¹³⁹⁾ ⁽¹⁴⁰⁾</th> </tr> <tr> <th data-bbox="488 927 577 991">New unit</th> <th data-bbox="577 927 689 991">Existing unit</th> <th data-bbox="689 927 904 991"></th> <th data-bbox="904 927 1016 991">New unit</th> <th data-bbox="1016 927 1182 991">Existing unit</th> </tr> </thead> <tbody> <tr> <td data-bbox="277 991 488 1050">Gas engine</td> <td data-bbox="488 991 577 1050">39,5–44 ⁽¹⁴¹⁾</td> <td data-bbox="577 991 689 1050">35–44 ⁽¹⁴¹⁾</td> <td data-bbox="689 991 904 1050">56–85 ⁽¹⁴¹⁾</td> <td colspan="2" data-bbox="904 991 1182 1050">No BAT-AEEL.</td> </tr> <tr> <td data-bbox="277 1050 488 1109">Gas-fired boiler</td> <td data-bbox="488 1050 577 1109">39–42,5</td> <td data-bbox="577 1050 689 1109">38–40</td> <td data-bbox="689 1050 904 1109">78–95</td> <td colspan="2" data-bbox="904 1050 1182 1109">No BAT-AEEL.</td> </tr> <tr> <td data-bbox="277 1109 488 1168">Open cycle gas turbine, ≥ 50 MWth</td> <td data-bbox="488 1109 577 1168">36–41,5</td> <td data-bbox="577 1109 689 1168">33–41,5</td> <td data-bbox="689 1109 904 1168">No BAT-AEEL</td> <td data-bbox="904 1109 1016 1168">36,5–41</td> <td data-bbox="1016 1109 1182 1168">33,5–41</td> </tr> </tbody> </table>	Type of combustion unit	BAT-AEELs ⁽¹³⁶⁾ ⁽¹³⁷⁾					Net electrical efficiency (%)		Net total fuel utilisation (%) ⁽¹³⁸⁾ ⁽¹³⁹⁾	Net mechanical energy efficiency (%) ⁽¹³⁹⁾ ⁽¹⁴⁰⁾		New unit	Existing unit		New unit	Existing unit	Gas engine	39,5–44 ⁽¹⁴¹⁾	35–44 ⁽¹⁴¹⁾	56–85 ⁽¹⁴¹⁾	No BAT-AEEL.		Gas-fired boiler	39–42,5	38–40	78–95	No BAT-AEEL.		Open cycle gas turbine, ≥ 50 MWth	36–41,5	33–41,5	No BAT-AEEL	36,5–41	33,5–41			
Type of combustion unit	BAT-AEELs ⁽¹³⁶⁾ ⁽¹³⁷⁾																																					
	Net electrical efficiency (%)		Net total fuel utilisation (%) ⁽¹³⁸⁾ ⁽¹³⁹⁾	Net mechanical energy efficiency (%) ⁽¹³⁹⁾ ⁽¹⁴⁰⁾																																		
	New unit	Existing unit		New unit	Existing unit																																	
Gas engine	39,5–44 ⁽¹⁴¹⁾	35–44 ⁽¹⁴¹⁾	56–85 ⁽¹⁴¹⁾	No BAT-AEEL.																																		
Gas-fired boiler	39–42,5	38–40	78–95	No BAT-AEEL.																																		
Open cycle gas turbine, ≥ 50 MWth	36–41,5	33–41,5	No BAT-AEEL	36,5–41	33,5–41																																	
	<p align="center">Combined cycle gas turbine (CCGT)</p> <table border="1"> <tbody> <tr> <td data-bbox="277 1214 488 1278">CCGT, 50–600 MW_{th}</td> <td data-bbox="488 1214 577 1278">53–58,5</td> <td data-bbox="577 1214 689 1278">46–54</td> <td data-bbox="689 1214 904 1278">No BAT-AEEL</td> <td colspan="2" data-bbox="904 1214 1182 1278">No BAT-AEEL</td> </tr> <tr> <td data-bbox="277 1278 488 1342">CCGT, ≥ 600 MW_{th}</td> <td data-bbox="488 1278 577 1342">57–60,5</td> <td data-bbox="577 1278 689 1342">50–60</td> <td data-bbox="689 1278 904 1342">No BAT-AEEL</td> <td colspan="2" data-bbox="904 1278 1182 1342">No BAT-AEEL</td> </tr> <tr> <td data-bbox="277 1342 488 1372">CHP C.C.G.T. 50–</td> <td data-bbox="488 1342 577 1372">53–</td> <td data-bbox="577 1342 689 1372">46–54</td> <td data-bbox="689 1342 904 1372">65–95</td> <td colspan="2" data-bbox="904 1342 1182 1372">No BAT-AEEL</td> </tr> </tbody> </table>	CCGT, 50–600 MW _{th}	53–58,5	46–54	No BAT-AEEL	No BAT-AEEL		CCGT, ≥ 600 MW _{th}	57–60,5	50–60	No BAT-AEEL	No BAT-AEEL		CHP C.C.G.T. 50–	53–	46–54	65–95	No BAT-AEEL																				
CCGT, 50–600 MW _{th}	53–58,5	46–54	No BAT-AEEL	No BAT-AEEL																																		
CCGT, ≥ 600 MW _{th}	57–60,5	50–60	No BAT-AEEL	No BAT-AEEL																																		
CHP C.C.G.T. 50–	53–	46–54	65–95	No BAT-AEEL																																		

BAT C. No.	Summary of BAT Conclusion requirement					Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the Operator to demonstrate compliance with the BAT Conclusion requirement
	600 MW _{th}	58,5					
	CHP CCGT, ≥ 600 MW _{th}	57–60,5	50–60	65–95	No BAT-AEEL		
41	In order to prevent or reduce NO _x emissions to air from the combustion of natural gas in boilers, BAT is to use one or a combination of the techniques given below.					CC	<p>LCP188 (Auxiliary Boilers 1, 2)</p> <p>The Operator has confirmed that an appropriate combination of techniques is used, as described below:</p> <p>b. Flue-gas recirculation – This is a feature of the auxiliary boilers. Recirculation is an operational function which is armed and enabled when the boiler is released to modulate.</p> <p>d. Advanced Control System – There is an advance control system that meets the description at table 8.1 of the BAT conclusion document. This is a computer based automatic system to control the combustion efficiency and support the prevention and / or reduction of emissions.</p>
Technique		Description		Applicability			
a	Air and/or fuel staging	See descriptions in Section 8.3. Air staging is often associated with low-NO _x burners		Generally applicable			
b	Flue-gas recirculation	See description in Section 8.3					
c	Low-NO _x burners (LNB)						
d	Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr		The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system			
e	Reduction of the combustion air temperature	See description in Section 8.3		Generally applicable within the constraints associated with the process needs			
f	Selective non-catalytic reduction (SNCR)			Not applicable to combustion plants operated < 500 h/yr with highly variable boiler loads. The applicability may be limited in the case of combustion plants operated between 500 h/yr and 1 500 h/yr with highly variable boiler loads			

BAT C. No.	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the Operator to demonstrate compliance with the BAT Conclusion requirement																
	g Selective catalytic reduction (SCR)		Not applicable to combustion plants operated < 500 h/yr. Not generally applicable to combustion plants of < 100 MW _{th} . There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr																		
42	In order to prevent or reduce NO _x emissions to air from the combustion of natural gas in gas turbines, BAT is to use one or a combination of the techniques given below.			CC	<p>LCP188 (GT 1/HRSG 1, GT 2/HRSG 2)</p> <p>The Operator has confirmed that an appropriate combination of techniques is used consisting of:</p> <p>a. Advanced control system, with variable load path; c. Dry low-NO_x burners.</p> <p>LCP415 (GT 3/HRSG 3)</p> <p>The Operator has confirmed that an appropriate combination of techniques is used consisting of:</p> <p>a. Advanced control system; c. Dry low-NO_x burners.</p>																
<table border="1"> <thead> <tr> <th data-bbox="271 635 450 671">Technique</th> <th data-bbox="450 635 869 671">Description</th> <th data-bbox="869 635 1182 671">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="271 671 450 831">a Advanced control system</td> <td data-bbox="450 671 869 831">See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr</td> <td data-bbox="869 671 1182 831">The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> <tr> <td data-bbox="271 831 450 890">b Water/steam addition</td> <td data-bbox="450 831 869 890" rowspan="2">See description in Section 8.3</td> <td data-bbox="869 831 1182 890">The applicability may be limited due to water availability</td> </tr> <tr> <td data-bbox="271 890 450 1023">c Dry low-NO_x burners (DLN)</td> <td data-bbox="869 890 1182 1023">The applicability may be limited in the case of turbines where a retrofit package is not available or when water/steam addition systems are installed</td> </tr> <tr> <td data-bbox="271 1023 450 1209">d Low-load design concept</td> <td data-bbox="450 1023 869 1209">Adaptation of the process control and related equipment to maintain good combustion efficiency when the demand in energy varies, e.g. by improving the inlet airflow control capability or by splitting the combustion process into decoupled combustion stages</td> <td data-bbox="869 1023 1182 1209">The applicability may be limited by the gas turbine design</td> </tr> <tr> <td data-bbox="271 1209 450 1369">e Low-NO_x burners (LNB)</td> <td data-bbox="450 1209 869 1369">See description in Section 8.3</td> <td data-bbox="869 1209 1182 1369">Generally applicable to supplementary firing for heat recovery steam generators (HRSGs) in the case of combined-cycle gas turbine (CCGT) combustion plants</td> </tr> </tbody> </table>			Technique			Description	Applicability	a Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system	b Water/steam addition	See description in Section 8.3	The applicability may be limited due to water availability	c Dry low-NO _x burners (DLN)	The applicability may be limited in the case of turbines where a retrofit package is not available or when water/steam addition systems are installed	d Low-load design concept	Adaptation of the process control and related equipment to maintain good combustion efficiency when the demand in energy varies, e.g. by improving the inlet airflow control capability or by splitting the combustion process into decoupled combustion stages	The applicability may be limited by the gas turbine design	e Low-NO _x burners (LNB)	See description in Section 8.3	Generally applicable to supplementary firing for heat recovery steam generators (HRSGs) in the case of combined-cycle gas turbine (CCGT) combustion plants
Technique	Description	Applicability																			
a Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system																			
b Water/steam addition	See description in Section 8.3	The applicability may be limited due to water availability																			
c Dry low-NO _x burners (DLN)		The applicability may be limited in the case of turbines where a retrofit package is not available or when water/steam addition systems are installed																			
d Low-load design concept	Adaptation of the process control and related equipment to maintain good combustion efficiency when the demand in energy varies, e.g. by improving the inlet airflow control capability or by splitting the combustion process into decoupled combustion stages	The applicability may be limited by the gas turbine design																			
e Low-NO _x burners (LNB)	See description in Section 8.3	Generally applicable to supplementary firing for heat recovery steam generators (HRSGs) in the case of combined-cycle gas turbine (CCGT) combustion plants																			

BAT C. No.	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the Operator to demonstrate compliance with the BAT Conclusion requirement														
	f. Selective catalytic reduction (SCR)		<p>Not applicable in the case of combustion plants operated < 500 h/yr.</p> <p>Not generally applicable to existing combustion plants of < 100 MW_{th}.</p> <p>Retrofitting existing combustion plants may be constrained by the availability of sufficient space.</p> <p>There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr</p>																
43	<p>In order to prevent or reduce NO_x emissions to air from the combustion of natural gas in engines, BAT is to use one or a combination of the techniques given below.</p> <table border="1" data-bbox="271 778 1182 1374"> <thead> <tr> <th data-bbox="271 783 443 815">Technique</th> <th data-bbox="443 783 797 815">Description</th> <th data-bbox="797 783 1182 815">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="271 815 443 975">a. Advanced control system</td> <td data-bbox="443 815 797 975">See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr</td> <td data-bbox="797 815 1182 975">The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> <tr> <td data-bbox="271 975 443 1054">b. Lean-burn concept</td> <td data-bbox="443 975 797 1054">See description in Section 8.3. Generally used in combination with SCR</td> <td data-bbox="797 975 1182 1054">Only applicable to new gas-fired engines</td> </tr> <tr> <td data-bbox="271 1054 443 1134">c. Advanced lean-burn concept</td> <td data-bbox="443 1054 797 1134" rowspan="2">See descriptions in Section 8.3</td> <td data-bbox="797 1054 1182 1134">Only applicable to new spark plug ignited engines</td> </tr> <tr> <td data-bbox="271 1134 443 1374">d. Selective catalytic reduction (SCR)</td> <td data-bbox="797 1134 1182 1374"> <p>Retrofitting existing combustion plants may be constrained by the availability of sufficient space.</p> <p>Not applicable to combustion plants operated < 500 h/yr.</p> <p>There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr</p> </td> </tr> </tbody> </table>			Technique	Description	Applicability	a. Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system	b. Lean-burn concept	See description in Section 8.3. Generally used in combination with SCR	Only applicable to new gas-fired engines	c. Advanced lean-burn concept	See descriptions in Section 8.3	Only applicable to new spark plug ignited engines	d. Selective catalytic reduction (SCR)	<p>Retrofitting existing combustion plants may be constrained by the availability of sufficient space.</p> <p>Not applicable to combustion plants operated < 500 h/yr.</p> <p>There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr</p>	NA	Not applicable as there are no engines at Immingham CHP Power Plant.
Technique	Description	Applicability																	
a. Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system																	
b. Lean-burn concept	See description in Section 8.3. Generally used in combination with SCR	Only applicable to new gas-fired engines																	
c. Advanced lean-burn concept	See descriptions in Section 8.3	Only applicable to new spark plug ignited engines																	
d. Selective catalytic reduction (SCR)		<p>Retrofitting existing combustion plants may be constrained by the availability of sufficient space.</p> <p>Not applicable to combustion plants operated < 500 h/yr.</p> <p>There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr</p>																	

BAT C. No.	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the Operator to demonstrate compliance with the BAT Conclusion requirement																																																						
44	<p>In order to prevent or reduce CO emissions to air from the combustion of natural gas, BAT is to ensure optimised combustion and/or to use oxidation catalysts. Description - See descriptions in Section 8.3. BAT-associated emission levels (BAT-AELs) for NO_x emissions to air from the combustion of natural gas in gas turbines</p> <table border="1" data-bbox="280 467 1176 1374"> <thead> <tr> <th rowspan="2">Type of combustion plant</th> <th rowspan="2">Combustion plant total rated thermal input (MW_{th})</th> <th colspan="2">BAT-AELs (mg/Nm³)⁽¹⁴²⁾ ⁽¹⁴³⁾</th> </tr> <tr> <th>Yearly average⁽¹⁴⁴⁾ ⁽¹⁴⁵⁾</th> <th>Daily average or average over the sampling period</th> </tr> </thead> <tbody> <tr> <td colspan="4" style="text-align: center;">Open-cycle gas turbines (OCGTs)⁽¹⁴⁶⁾ ⁽¹⁴⁷⁾</td> </tr> <tr> <td>New OCGT</td> <td>≥ 50</td> <td>15–35</td> <td>25–50</td> </tr> <tr> <td>Existing OCGT (excluding turbines for mechanical drive applications) — All but plants operated < 500 h/yr</td> <td>≥ 50</td> <td>15–50</td> <td>25–55⁽¹⁴⁸⁾</td> </tr> <tr> <td colspan="4" style="text-align: center;">Combined-cycle gas turbines (CCGTs)⁽¹⁴⁶⁾ ⁽¹⁴⁹⁾</td> </tr> <tr> <td>New CCGT</td> <td>≥ 50</td> <td>10–30</td> <td>15–40</td> </tr> <tr> <td>Existing CCGT with a net total fuel utilisation of < 75 %</td> <td>≥ 600</td> <td>10–40</td> <td>18–50</td> </tr> <tr> <td>Existing CCGT with a net total fuel utilisation of ≥ 75 %</td> <td>≥ 600</td> <td>10–50</td> <td>18–55⁽¹⁵⁰⁾</td> </tr> <tr> <td>Existing CCGT with a net total fuel utilisation of < 75 %</td> <td>50–600</td> <td>10–45</td> <td>35–55</td> </tr> <tr> <td>Existing CCGT with a net total fuel utilisation of ≥ 75 %</td> <td>50–600</td> <td>25–50⁽¹⁵¹⁾</td> <td>35–55⁽¹⁵²⁾</td> </tr> <tr> <td colspan="4" style="text-align: center;">Open- and combined-cycle gas turbines</td> </tr> <tr> <td>Gas turbine put into operation no later than 27 November 2003, or existing gas turbine for emergency use and operated < 500 h/yr</td> <td>≥ 50</td> <td>No BAT-AEL</td> <td>60–140⁽¹⁵³⁾ ⁽¹⁵⁴⁾</td> </tr> <tr> <td>Existing gas turbine for mechanical drive applications — All but plants operated < 500 h/yr</td> <td>≥ 50</td> <td>15–50⁽¹⁵⁵⁾</td> <td>25–55⁽¹⁵⁶⁾</td> </tr> </tbody> </table>	Type of combustion plant	Combustion plant total rated thermal input (MW _{th})	BAT-AELs (mg/Nm ³) ⁽¹⁴²⁾ ⁽¹⁴³⁾		Yearly average ⁽¹⁴⁴⁾ ⁽¹⁴⁵⁾	Daily average or average over the sampling period	Open-cycle gas turbines (OCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁷⁾				New OCGT	≥ 50	15–35	25–50	Existing OCGT (excluding turbines for mechanical drive applications) — All but plants operated < 500 h/yr	≥ 50	15–50	25–55 ⁽¹⁴⁸⁾	Combined-cycle gas turbines (CCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁹⁾				New CCGT	≥ 50	10–30	15–40	Existing CCGT with a net total fuel utilisation of < 75 %	≥ 600	10–40	18–50	Existing CCGT with a net total fuel utilisation of ≥ 75 %	≥ 600	10–50	18–55 ⁽¹⁵⁰⁾	Existing CCGT with a net total fuel utilisation of < 75 %	50–600	10–45	35–55	Existing CCGT with a net total fuel utilisation of ≥ 75 %	50–600	25–50 ⁽¹⁵¹⁾	35–55 ⁽¹⁵²⁾	Open- and combined-cycle gas turbines				Gas turbine put into operation no later than 27 November 2003, or existing gas turbine for emergency use and operated < 500 h/yr	≥ 50	No BAT-AEL	60–140 ⁽¹⁵³⁾ ⁽¹⁵⁴⁾	Existing gas turbine for mechanical drive applications — All but plants operated < 500 h/yr	≥ 50	15–50 ⁽¹⁵⁵⁾	25–55 ⁽¹⁵⁶⁾	CC	<p>Optimised combustion is implemented as a technique to prevent or reduce CO emissions to air from the combustion of natural gas at the installation.</p> <p><u>Gas turbines</u> For the gas turbines at the installation (emission points A1, A2 and A5), we have set BAT-AEL emission limits in the varied and consolidated permit as follows:</p> <p>NO_x yearly average: 40 mg/m³ NO_x daily average: 50 mg/m³ CO annual average: 50 mg/m³ (low load operation)</p> <p>The Operator has confirmed that the installation is currently compliant with these emission limits.</p> <p>Refer to section 4 of this document for additional details on the application of emission limits and BAT-AEL.</p> <p><u>Auxiliary boilers</u> Refer to section 4 of this document for application of emission limits and BAT-AEL to the auxiliary boilers 1, 2 of LCP188.</p> <p>The annual BAT-AEL for NO_x at 100 mg/m³ is the same of the current monthly emission limit for this parameter, specified in the permit according to IED before this variation. Therefore compliance with the current permit monthly emission limit for NO_x ensures that the annual BAT-AEL for this parameter will be met.</p> <p>The Operator has proposed to set the annual emission limit for CO emitted from these boilers at the 40 mg/m³, in line with the indicative BAT-AEL set in the LCP BAT conclusions. We have set the annual emission limit in the varied and consolidated permit according to this.</p>
Type of combustion plant	Combustion plant total rated thermal input (MW _{th})			BAT-AELs (mg/Nm ³) ⁽¹⁴²⁾ ⁽¹⁴³⁾																																																					
		Yearly average ⁽¹⁴⁴⁾ ⁽¹⁴⁵⁾	Daily average or average over the sampling period																																																						
Open-cycle gas turbines (OCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁷⁾																																																									
New OCGT	≥ 50	15–35	25–50																																																						
Existing OCGT (excluding turbines for mechanical drive applications) — All but plants operated < 500 h/yr	≥ 50	15–50	25–55 ⁽¹⁴⁸⁾																																																						
Combined-cycle gas turbines (CCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁹⁾																																																									
New CCGT	≥ 50	10–30	15–40																																																						
Existing CCGT with a net total fuel utilisation of < 75 %	≥ 600	10–40	18–50																																																						
Existing CCGT with a net total fuel utilisation of ≥ 75 %	≥ 600	10–50	18–55 ⁽¹⁵⁰⁾																																																						
Existing CCGT with a net total fuel utilisation of < 75 %	50–600	10–45	35–55																																																						
Existing CCGT with a net total fuel utilisation of ≥ 75 %	50–600	25–50 ⁽¹⁵¹⁾	35–55 ⁽¹⁵²⁾																																																						
Open- and combined-cycle gas turbines																																																									
Gas turbine put into operation no later than 27 November 2003, or existing gas turbine for emergency use and operated < 500 h/yr	≥ 50	No BAT-AEL	60–140 ⁽¹⁵³⁾ ⁽¹⁵⁴⁾																																																						
Existing gas turbine for mechanical drive applications — All but plants operated < 500 h/yr	≥ 50	15–50 ⁽¹⁵⁵⁾	25–55 ⁽¹⁵⁶⁾																																																						

BAT C. No.	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the Operator to demonstrate compliance with the BAT Conclusion requirement																							
	<p>As an indication, the yearly average CO emission levels for each type of existing combustion plant operated $\geq 1\,500$ h/yr and for each type of new combustion plant will generally be as follows:</p> <ul style="list-style-type: none"> — New OCGT of ≥ 50 MW_{th}: $< 5\text{--}40$ mg/Nm³. For plants with a net electrical efficiency (EE) greater than 39 %, a correction factor may be applied to the higher end of this range, corresponding to [higher end] \times EE/39, where EE is the net electrical energy efficiency or net mechanical energy efficiency of the plant determined at ISO baseload conditions. — Existing OCGT of ≥ 50 MW_{th} (excluding turbines for mechanical drive applications): $< 5\text{--}40$ mg/Nm³. The higher end of this range will generally be 80 mg/Nm³ in the case of existing plants that cannot be fitted with dry techniques for NO_x reduction, or 50 mg/Nm³ for plants that operate at low load. — New CCGT of ≥ 50 MW_{th}: $< 5\text{--}30$ mg/Nm³. For plants with a net electrical efficiency (EE) greater than 55 %, a correction factor may be applied to the higher end of the range, corresponding to [higher end] \times EE/55, where EE is the net electrical energy efficiency of the plant determined at ISO baseload conditions. — Existing CCGT of ≥ 50 MW_{th}: $< 5\text{--}30$ mg/Nm³. The higher end of this range will generally be 50 mg/Nm³ for plants that operate at low load. — Existing gas turbines of ≥ 50 MW_{th} for mechanical drive applications: $< 5\text{--}40$ mg/Nm³. The higher end of the range will generally be 50 mg/Nm³ when plants operate at low load. <p>In the case of a gas turbine equipped with DLN burners, these indicative levels correspond to when the DLN operation is effective.</p> <p>BAT-associated emission levels (BAT-AELs) for NO_x emissions to air from the combustion of natural gas in boilers and engines</p> <table border="1" data-bbox="280 978 1176 1201"> <thead> <tr> <th rowspan="3">Type of combustion plant</th> <th colspan="4">BAT-AELs (mg/Nm³)</th> </tr> <tr> <th colspan="2">Yearly average ⁽¹⁵⁷⁾</th> <th colspan="2">Daily average or average over the sampling period</th> </tr> <tr> <th>New plant</th> <th>Existing plant ⁽¹⁵⁸⁾</th> <th>New plant</th> <th>Existing plant ⁽¹⁵⁹⁾</th> </tr> </thead> <tbody> <tr> <td>Boiler</td> <td>10–60</td> <td>50–100</td> <td>30–85</td> <td>85–110</td> </tr> <tr> <td>Engine ⁽¹⁶⁰⁾</td> <td>20–75</td> <td>20–100</td> <td>55–85</td> <td>55–110 ⁽¹⁶¹⁾</td> </tr> </tbody> </table> <p>As an indication, the yearly average CO emission levels will generally be:</p> <ul style="list-style-type: none"> — $< 5\text{--}40$ mg/Nm³ for existing boilers operated $\geq 1\,500$ h/yr, — $< 5\text{--}15$ mg/Nm³ for new boilers, — $30\text{--}100$ mg/Nm³ for existing engines operated $\geq 1\,500$ h/yr and for new engines. 	Type of combustion plant	BAT-AELs (mg/Nm ³)				Yearly average ⁽¹⁵⁷⁾		Daily average or average over the sampling period		New plant	Existing plant ⁽¹⁵⁸⁾	New plant	Existing plant ⁽¹⁵⁹⁾	Boiler	10–60	50–100	30–85	85–110	Engine ⁽¹⁶⁰⁾	20–75	20–100	55–85	55–110 ⁽¹⁶¹⁾		
Type of combustion plant	BAT-AELs (mg/Nm ³)																									
	Yearly average ⁽¹⁵⁷⁾		Daily average or average over the sampling period																							
	New plant	Existing plant ⁽¹⁵⁸⁾	New plant	Existing plant ⁽¹⁵⁹⁾																						
Boiler	10–60	50–100	30–85	85–110																						
Engine ⁽¹⁶⁰⁾	20–75	20–100	55–85	55–110 ⁽¹⁶¹⁾																						

BAT C. No.	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the Operator to demonstrate compliance with the BAT Conclusion requirement																		
45	<p>In order to reduce non-methane volatile organic compounds (NMVOC) and methane (CH₄) emissions to air from the combustion of natural gas in spark-ignited lean-burn gas engines, BAT is to ensure optimised combustion and/or to use oxidation catalysts.</p> <p>Description See descriptions in Section 8.3. Oxidation catalysts are not effective at reducing the emissions of saturated hydrocarbons containing less than four carbon atoms.</p> <p>BAT-associated emission levels (BAT-AELs) for formaldehyde and CH₄ emissions to air from the combustion of natural gas in a spark-ignited lean-burn gas engine</p> <table border="1" data-bbox="280 608 1180 829"> <thead> <tr> <th rowspan="3">Combustion plant total rated thermal input (MW_{th})</th> <th colspan="3">BAT-AELs (mg/Nm³)</th> </tr> <tr> <th>Formaldehyde</th> <th colspan="2">CH₄</th> </tr> <tr> <th colspan="3">Average over the sampling period</th> </tr> <tr> <th></th> <th>New or existing plant</th> <th>New plant</th> <th>Existing plant</th> </tr> </thead> <tbody> <tr> <td>≥ 50</td> <td>5–15 ⁽¹⁶²⁾</td> <td>215–500 ⁽¹⁶³⁾</td> <td>215–560 ⁽¹⁶²⁾ _{⁽¹⁶³⁾}</td> </tr> </tbody> </table>	Combustion plant total rated thermal input (MW _{th})	BAT-AELs (mg/Nm ³)			Formaldehyde	CH ₄		Average over the sampling period				New or existing plant	New plant	Existing plant	≥ 50	5–15 ⁽¹⁶²⁾	215–500 ⁽¹⁶³⁾	215–560 ⁽¹⁶²⁾ _{⁽¹⁶³⁾}	NA	Not applicable as there are no spark-ignited lean-burn gas engines at Immingham CHP Power Plant
Combustion plant total rated thermal input (MW _{th})	BAT-AELs (mg/Nm ³)																				
	Formaldehyde		CH ₄																		
	Average over the sampling period																				
	New or existing plant	New plant	Existing plant																		
≥ 50	5–15 ⁽¹⁶²⁾	215–500 ⁽¹⁶³⁾	215–560 ⁽¹⁶²⁾ _{⁽¹⁶³⁾}																		
46	<p>In order to increase the energy efficiency of the combustion of iron and steel process gases, BAT is to use an appropriate combination of the techniques given in BAT 12 and below.</p> <table border="1" data-bbox="280 932 1180 1034"> <thead> <tr> <th>Technique</th> <th>Description</th> <th>Applicability</th> </tr> </thead> <tbody> <tr> <td>a Process gas management system</td> <td>See description in Section 8.2</td> <td>Only applicable to integrated steelworks</td> </tr> </tbody> </table> <p>BAT-associated energy efficiency levels (BAT-AEELs) for the combustion of iron and steel process gases in boilers</p> <table border="1" data-bbox="280 1118 1180 1334"> <thead> <tr> <th rowspan="2">Type of combustion unit</th> <th colspan="2">BAT-AEELs ⁽¹⁶⁴⁾ ⁽¹⁶⁵⁾</th> </tr> <tr> <th>Net electrical efficiency (%)</th> <th>Net total fuel utilisation (%) ⁽¹⁶⁶⁾</th> </tr> </thead> <tbody> <tr> <td>Existing multi-fuel firing gas boiler</td> <td>30–40</td> <td>50–84</td> </tr> <tr> <td>New multi-fuel firing gas boiler ⁽¹⁶⁷⁾</td> <td>36–42,5</td> <td>50–84</td> </tr> </tbody> </table> <p>BAT-associated energy efficiency levels (BAT-AEELs) for the combustion of</p>	Technique	Description	Applicability	a Process gas management system	See description in Section 8.2	Only applicable to integrated steelworks	Type of combustion unit	BAT-AEELs ⁽¹⁶⁴⁾ ⁽¹⁶⁵⁾		Net electrical efficiency (%)	Net total fuel utilisation (%) ⁽¹⁶⁶⁾	Existing multi-fuel firing gas boiler	30–40	50–84	New multi-fuel firing gas boiler ⁽¹⁶⁷⁾	36–42,5	50–84	NA	Not applicable to Immingham CHP Power Plant	
Technique	Description	Applicability																			
a Process gas management system	See description in Section 8.2	Only applicable to integrated steelworks																			
Type of combustion unit	BAT-AEELs ⁽¹⁶⁴⁾ ⁽¹⁶⁵⁾																				
	Net electrical efficiency (%)	Net total fuel utilisation (%) ⁽¹⁶⁶⁾																			
Existing multi-fuel firing gas boiler	30–40	50–84																			
New multi-fuel firing gas boiler ⁽¹⁶⁷⁾	36–42,5	50–84																			

BAT C. No.	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the Operator to demonstrate compliance with the BAT Conclusion requirement																		
	<p style="text-align: center;">iron and steel process gases in CCGTs</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th data-bbox="280 357 551 507" rowspan="3">Type of combustion unit</th> <th colspan="3" data-bbox="551 357 1180 389" style="text-align: center;">BAT-AEELs ⁽¹⁶⁸⁾ ⁽¹⁶⁹⁾</th> </tr> <tr> <th colspan="2" data-bbox="551 389 844 448" style="text-align: center;">Net electrical efficiency (%)</th> <th data-bbox="844 389 1180 448" style="text-align: center;">Net total fuel utilisation (%) ⁽¹⁷⁰⁾</th> </tr> <tr> <th data-bbox="551 448 680 507" style="text-align: center;">New unit</th> <th data-bbox="680 448 844 507" style="text-align: center;">Existing unit</th> <th data-bbox="844 448 1180 507"></th> </tr> </thead> <tbody> <tr> <td data-bbox="280 507 551 544">CHP CCGT</td> <td data-bbox="551 507 680 544" style="text-align: center;">> 47</td> <td data-bbox="680 507 844 544" style="text-align: center;">40–48</td> <td data-bbox="844 507 1180 544" style="text-align: center;">60–82</td> </tr> <tr> <td data-bbox="280 544 551 580">CCGT</td> <td data-bbox="551 544 680 580" style="text-align: center;">> 47</td> <td data-bbox="680 544 844 580" style="text-align: center;">40–48</td> <td data-bbox="844 544 1180 580" style="text-align: center;">No BAT-AEEL</td> </tr> </tbody> </table>	Type of combustion unit	BAT-AEELs ⁽¹⁶⁸⁾ ⁽¹⁶⁹⁾			Net electrical efficiency (%)		Net total fuel utilisation (%) ⁽¹⁷⁰⁾	New unit	Existing unit		CHP CCGT	> 47	40–48	60–82	CCGT	> 47	40–48	No BAT-AEEL		
Type of combustion unit	BAT-AEELs ⁽¹⁶⁸⁾ ⁽¹⁶⁹⁾																				
	Net electrical efficiency (%)		Net total fuel utilisation (%) ⁽¹⁷⁰⁾																		
	New unit	Existing unit																			
CHP CCGT	> 47	40–48	60–82																		
CCGT	> 47	40–48	No BAT-AEEL																		
Combustion for multi-fuel-fired plants																					
<p>The BAT conclusions presented in section 5 of the LCP BAT Conclusions document are applicable to the combustion of process fuels from the chemical industry. The installation makes use of refinery fuel gas imported from the nearby Philips 66 Humber Oil Refinery. As detailed in section 4 of this decision document, we have determined BAT for the combustion of this fuel according to the requirements of the BAT Conclusions on the refining of mineral oil and gas (EU Commission implementing decision 2014/738/EU) (REF BAT conclusions), which include specific provisions and BAT-AELs for the combustion of this fuel. We have therefore considered the relevant parts of the REF BAT conclusions applicable to this installation, as a comparable process according to the provisions of Article 14(6) of the Industrial Emissions Directive. We consider that Section 5 of the LCP BAT conclusions is not applicable to this installation.</p> <p>Refer to Section 4 of this document for additional details on the determination of BAT according to the REF BAT conclusions.</p>																					

6. Emissions to water

The consolidated permit incorporates one current discharge to controlled waters identified as W1.

There are no BAT AELs specified in the BAT Conclusions for this type of plant. There are also no additional treatment options identified as BAT for the installation. We have therefore not carried out any additional assessment of the emissions to water as part of this review.

7. Additional IED Chapter II requirements

In the event of a black out National Grid would call on combustion plant to operate and may require them to do so outside their permitted conditions. We have dedicated black start plant and they are permitted to run as such but this scenario is relevant to the rest of the large combustion plant which could be called depending on the circumstances.

A risk assessment will be carried out by Energy UK/Joint Environmental Programme on behalf of Large Combustion Plant connected to the National Transmission System. Air emissions modelling will be based on generic black start scenarios to establish whether they have the potential to have local impact on the environment or not (on a national basis). If the modelling demonstrates that no significant impacts are likely, the plant can operate under condition 2.3.9. This conditions allows the hourly ELVs for plants operating under a black start instruction to be discounted for the purpose of reporting. We would also require there to be a procedure in place for minimisation of emissions in the case of a black start event and for reporting in the event of a black start. This modelling and the procedures have not been agreed in advance of the issue of the permit review and therefore a condition linking back to an improvement condition have been included in the permit.

8. Review and assessment of changes that are not part of the BAT Conclusions derived permit review

This document should be read in conjunction with the application, supporting information and notice.

Aspect considered	Decision
Receipt of application	
Confidential information	A claim for commercial or industrial confidentiality has not been made.
Identifying confidential information	We have not identified information provided as part of the application that we consider to be confidential. The decision was taken in accordance with our guidance on confidentiality.
The site	
Biodiversity, heritage, landscape and nature conservation	The application is within the relevant distance criteria of a site of heritage, landscape or nature conservation, and/or protected species or habitat. A full assessment of the application and its potential to affect the site(s)/species/habitat has not been carried out as part of the permit review process. We consider that the review will not affect the features of the site(s)/species/habitat as the conditions will provide at least the same level of protection as those in the previous permit and in some cases will provide a higher level of protection to those in the previous permit. We have not consulted Natural England on the application. The decision was taken in accordance with our guidance.
Operating techniques	
General operating techniques	We have reviewed the techniques used by the Operator where they are relevant to the BAT Conclusions and compared these with the relevant guidance notes. The permit conditions ensure compliance with the relevant BREF, BAT Conclusions. The ELVs deliver compliance with the BAT-AELs.
Permit conditions	
Updating permit conditions during consolidation	We have updated permit conditions to those in the current generic permit template as part of permit consolidation. The conditions will provide at least the same level of protection as those in the previous permit and in some cases will provide a higher level of

Aspect considered	Decision
	protection to those in the previous permit.
Changes to the permit conditions due to an Environment Agency initiated variation	We have varied the permit as stated in the variation notice.
Improvement programme	<p>Based on the information on the application, we consider that we need to impose an improvement programme.</p> <p>We have imposed an improvement programme to ensure that:</p> <ul style="list-style-type: none"> • the Operator will install pressure sensors in the flues of GT 1/HRSG 1 and 2 in line with BAT 3; • the Operator will develop a plan to report and assess compliance of the emissions from the multi-fuel combustion equipment of LCP188 and LCP415 against the multi-fuel weighted emission limits calculated from the limits specified in Tables S3.1 and S3.1a, according to the formulae provided in IED Article 40(2), following the methodologies described in the document titled 'IED Chapter III Protocol for Multi-fuel Firing Refinery Combustion Plants granted a Permit prior to 7th January 2013' <p>We have also removed the completed improvement conditions from the permit.</p>
Emission limits	<p>We have decided that emission limits should be set for the parameters listed in the permit.</p> <p>These are described in Section 4 of this document and in the relevant BAT Conclusions in Section 5 of this document.</p> <p>It is considered that the ELVs/equivalent parameters or technical measures described above will ensure that significant pollution of the environment is prevented and a high level of protection for the environment is secured.</p>
Monitoring	<p>We have decided that monitoring should be carried out for the parameters listed in the permit, using the methods detailed and to the frequencies specified.</p> <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p> <p>Table S3.4 Process monitoring requirements was added to include the requirement to monitor energy efficiency after overhauls on site in line with BAT2.</p>
Reporting	<p>We have specified reporting in the permit for the following parameters:</p> <ul style="list-style-type: none"> • Nitrogen dioxide

Aspect considered	Decision
	<ul style="list-style-type: none"> • Carbon monoxide • Sulphur dioxide • Dust <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p>
Operator competence	
Management system	There is no known reason to consider that the Operator will not have the management system to enable them to comply with the permit conditions.
Growth Duty	
Section 108 Deregulation Act 2015 – Growth duty	<p>We have considered our duty to have regard to the desirability of promoting economic growth set out in section 108(1) of the Deregulation Act 2015 and the guidance issued under section 110 of that Act in deciding whether to grant this permit.</p> <p>Paragraph 1.3 of the guidance says: “The primary role of regulators, in delivering regulation, is to achieve the regulatory outcomes for which they are responsible. For a number of regulators, these regulatory outcomes include an explicit reference to development or growth. The growth duty establishes economic growth as a factor that all specified regulators should have regard to, alongside the delivery of the protections set out in the relevant legislation.”</p> <p>We have addressed the legislative requirements and environmental standards to be set for this operation in the body of the decision document above. The guidance is clear at paragraph 1.5 that the growth duty does not legitimise non-compliance and its purpose is not to achieve or pursue economic growth at the expense of necessary protections.</p> <p>We consider the requirements and standards we have set in this permit are reasonable and necessary to avoid a risk of an unacceptable level of pollution. This also promotes growth amongst legitimate operators because the standards applied to the Operator are consistent across businesses in this sector and have been set to achieve the required legislative standards.</p>