

Environment Agency

Review of an Environmental Permit for an Installation subject to Chapter II of the Industrial Emissions Directive under the Environmental Permitting (England & Wales) Regulations 2016

Decision document recording our decision-making process following review of a permit

The Permit number is: EPR/BP3239LA
The Operator is: RWE KL Limited
The Installation is: King's Lynn Power Station A
This Variation Notice number is: EPR/BP3239LA/V007

What this document is about

Article 21(3) of the Industrial Emissions Directive (IED) requires the Environment Agency to review conditions in permits that it has issued and to ensure that the permit delivers compliance with relevant standards, within four years of the publication of updated decisions on best available techniques (BAT) conclusions.

We have reviewed the permit for this installation against the revised BAT Conclusions for large combustion plant published on 17th August 2017. We have also carried out a name change for the site which has changed operator but under the same company number, from Centrica KL Ltd to RWE KL Ltd. This is our decision document, which explains the reasoning for the consolidated variation notice that we are issuing.

It explains how we have reviewed and considered the techniques used by the Operator in the operation and control of the plant and activities of the installation. This review has been undertaken with reference to the decision made by the European Commission establishing best available techniques (BAT) conclusions ('BAT Conclusions') for large combustion plant as detailed in document reference IEDC-7-1. It is our record of our decision-making process and shows how we have taken into account all relevant factors in reaching our position. It also provides a justification for the inclusion of any specific conditions in the permit that are in addition to those included in our generic permit template.

As well as considering the review of the operating techniques used by the Operator for the operation of the plant and activities of the installation, the consolidated variation notice takes into account and brings together in a

single document all previous variations that relate to the original permit issued. It also modernises the entire permit to reflect the conditions contained in our current generic permit template.

The introduction of new template conditions makes the Permit consistent with our current general approach and philosophy and with other permits issued to installations in this sector. Although the wording of some conditions has changed, while others have been removed because of the new regulatory approach, it does not reduce the level of environmental protection achieved by the Permit in any way. In this document we therefore address only our determination of substantive issues relating to the new BAT Conclusions.

This is our record of our decision-making process and shows how we have taken into account all relevant factors in reaching our position.

Throughout this document we will use a number of expressions. These are as referred to in the glossary and have the same meaning as described in “Schedule 6 Interpretation” of the Permit.

We try to explain our decision as accurately, comprehensively and plainly as possible. We would welcome any feedback as to how we might improve our decision documents in future. A lot of technical terms and acronyms are inevitable in a document of this nature: we provide a glossary of acronyms near the front of the document, for ease of reference.

How this document is structured

Glossary of terms

- 1 Our decision
- 2 How we reached our decision
- 2.1 Requesting information to demonstrate compliance with BAT Conclusions for Large Combustion Plant
- 2.2 Review of our own information in respect to the capability of the installation to meet revised standards included in the BAT Conclusions document
- 2.3 Summary of how we considered the responses from public consultation.
- 3 The legal framework
- 4 Key Issues
- 5 Decision checklist regarding relevant BAT Conclusions
- 6 Emissions to Water
- 7 Review and assessment of changes that are not part of the BAT conclusions derived permit review.

Glossary of acronyms used in this document

(Please note that this glossary is standard for our decision documents and therefore not all these acronyms are necessarily used in this document.)

APC	Air Pollution Control
BAT	Best Available Technique(s)
BAT-AEEL	BAT Associated Energy Efficiency Level
BAT-AEL	BAT Associated Emission Level
BATc	BAT conclusion
BREF	Best available techniques reference document
CCGT	Combined Cycle Gas Turbine
CEM	Continuous emissions monitor
CHP	Combined heat and power
CV	Calorific value
DAA	Directly associated activity – Additional activities necessary to be carried out to allow the principal activity to be carried out
DLN	Dry Low NOx burners
DLN-E	Dry Low NOx effective
EIONET	European environment information and observation network is a partnership network of the European Environment Agency
ELV	Emission limit value derived under BAT or an emission limit value set out in IED
EMS	Environmental Management System
EPR	Environmental Permitting (England and Wales) Regulations 2016 (SI 2016 No. 1154)
EWC	European waste catalogue
FSA	Food Standards Agency
IC	Improvement Condition
IED	Industrial Emissions Directive (2010/75/EU)
IPPCD	Integrated Pollution Prevention and Control Directive (2008/1/EC) – now superseded by IED
LCP	Large Combustion Plant subject to Chapter III of IED
MSUL/MSDL	Minimum start up load/minimum shut-down load
NOx	Oxides of nitrogen (NO plus NO ₂ expressed as NO ₂)
NPV	Net Present Value
PHE	Public Health England
SAC	Special Area of Conservation
SGN	Sector guidance note
TGN	Technical guidance note
TNP	Transitional National Plan
TOC	Total Organic Carbon
WFD	Water Framework Directive (2000/60/EC)

1 Our decision

We have decided to issue the consolidated variation notice to the Operator. This will allow it to continue to operate the Installation, subject to the conditions in the consolidated variation notice.

We consider that, in reaching that decision, we have taken into account all relevant considerations and legal requirements and that the varied permit will ensure that a high level of protection is provided for the environment and human health.

The consolidated variation notice contains many conditions taken from our standard Environmental Permit template including the relevant Annexes. We developed these conditions in consultation with industry, having regard to the legal requirements of the Environmental Permitting Regulations and other relevant legislation. This document does not therefore include an explanation for these standard conditions. Where they are included in the Notice, we have considered the techniques identified by the operator for the operation of their installation, and have accepted that the details are sufficient and satisfactory to make those standard conditions appropriate. This document does, however, provide an explanation of our use of “tailor-made” or installation-specific conditions, or where our Permit template provides two or more options.

2 How we reached our decision

2.1 Requesting information to demonstrate compliance with BAT Conclusions for Large Combustion Plant

We issued a Notice under Regulation 61(1) of the Environmental Permitting (England and Wales) Regulations 2016 (a Regulation 61 Notice) on 1st May 2018 requiring the Operator to provide information to demonstrate how the operation of their installation currently meets, or will subsequently meet, the revised standards described in the large combustion plant BAT Conclusions document. The Notice also required that where the revised standards are not currently met, the operator should provide information that:

- Describes the techniques that will be implemented before 17th August 2021, which will then ensure that operations meet the revised standard, or
- Justifies why standards will not be met by 17th August 2021, and confirmation of the date when the operation of those processes will cease within the installation or an explanation of why the revised BAT standard is not applicable to those processes, or
- Justifies why an alternative technique will achieve the same level of environmental protection equivalent to the revised standard described in the BAT Conclusions.

Where the Operator proposed that they were not intending to meet a BAT standard that also included a BAT Associated Emission Level (BAT AEL) described in the BAT Conclusions Document, the Regulation 61 Notice requested that the Operator make a formal request for derogation from compliance with that AEL (as provisioned by Article 15(4) of IED). In this circumstance, the Notice identified that any such request for derogation must be supported and justified by sufficient technical and commercial information that would enable us to determine acceptability of the derogation request.

The Regulation 61 Notice response from the Operator was received on 12/11/2018.

We considered it was in the correct form and contained sufficient information for us to begin our determination of the permit review but not that it necessarily contained all the information we would need to complete that review: see below.

2.2 Review of our own information in respect to the capability of the installation to meet revised standards included in the BAT Conclusions document

Based on our records and previous regulatory activities with the facility we have no reason to consider that the operator will not be able to comply with the conditions that we include in the permit.

In relation to BAT Conclusion(s) 2,40,42 and 44 we agree with the operator in respect to their current stated capability as recorded in their Regulation 61 Notice response.

We have included improvement conditions IC11, IC12 and IC13 in the consolidated variation notice, which requires the operator to confirm the parameters linked to the upgrade on site to meet the requirements of the BAT Conclusion to be delivered by 17 August 2021. We have also included a condition for Black-start IC14. This is discussed in more detail in the key issues section and/or in the decision checklist regarding relevant BAT Conclusions.

3 The legal framework

The consolidated variation notice will be issued, under Regulation 20 of the EPR. The Environmental Permitting regime is a legal vehicle which delivers most of the relevant legal requirements for activities falling within its scope. In particular, the regulated facility is:

- an *installation* as described by the IED;
- subject to aspects of other relevant legislation which also have to be addressed.

We consider that, the consolidated variation notice will ensure that the operation of the Installation complies with all relevant legal requirements and that a high level of protection will be delivered for the environment and human health.

We explain how we have addressed specific statutory requirements more fully in the rest of this document.

4 The key issues

The key issues arising during this permit review are:

- Emissions to air and the emission limits applied to the plant.
- The energy efficiency levels associated with the Best Available Techniques (BAT-AEELs)
- Keeping IC11 and adding IC12 and IC13.
- Inclusion of black start condition and associated Improvement condition IC14

We therefore describe how we determined these issues in most detail in the relevant sections of this document.

4.1 Emissions to air and the emission limits applied to the plant

A number of general principles were applied during the permit review. These included:

- The upper value of the BAT AELs ranges specified were used unless use of the tighter limit was justified.
- The principle of no backsliding where if existing limits in the permit were already tighter than those specified in the BREF, the existing permit limits were retained.
- Where a limit was specified in both IED Annex V and the BAT Conclusions for a particular reference period, the tighter limit was applied and in the majority of cases this was from the BAT Conclusions.
- Where AELs are indicative in the BAT Conclusions, these were applied unless adequate justification was provided by the operator to demonstrate that an alternative limit was more appropriate.
- For gas turbines where the IED specified that limits applied over 70% load and the BAT Conclusions specified that AELs applied when dry low NO_x is effective (DLN-E), we have used DLN-E as a default across all monitoring requirements for NO_x and CO.

The LCP on site consist of LCP48, 646MWth, Combined Cycle Gas Turbine (CCGT) burning Natural gas.

The plant was put into operation before IED came into force and therefore the existing limits in the permit are from Part 1 of IED Annex V applicable to existing plant.

The ELVs and AELs are based on the following operating regime:

- Unlimited hours operation

The following tables outline the limits that have been incorporated into the permit for LCP48, where these were derived from and the reference periods at which they apply. The emission limits refer to concentrations, expressed as mass of emitted substance per volume of flue-gas under the following standard conditions: dry gas at a temperature of 273,15 K, pressure of 101,3 kPa and 15%, volume reference oxygen concentration if flue gases. The emission limits and monitoring requirements have been incorporated into Schedule 3 of the permit.

By the end of the TNP on 30 June 2020, as a minimum plant must meet the limits set out in Annex V of the Industrial Emission Directive subject to BAT assessment and the principle of no backsliding. From the implementation date of the BAT Conclusion in 2021 the relevant AELs will also apply. The tables below set out the limits that will apply from 17 August 2021.

NOx limits (mg/Nm ³)						
Averaging	IED (Annex V Part 1) - Existing	BREF	Expected permit limits	Basis	Limits apply	Monitoring
Annual	None	40	40	BREF	E-DLN	Continuous
Monthly	50	None	50	IED	E-DLN	
Daily	55	50	50	Existing permit	E-DLN	
95 th %ile of hr means	100	None	100	IED	E-DLN	

CO limits (mg/Nm ³)						
Averaging	IED (Annex V Part 1) - Existing	BREF	Expected permit limits	Basis	Limits apply	Monitoring
Annual	None	30	30	BREF	E-DLN	Continuous
Monthly	100	None	50*	IED	E-DLN	
Daily	110	None	50*	BREF	E-DLN	
95 th %ile of hr means	200	None	200	IED	E-DLN	

* No backsliding principle has been applied – these limits were carried over from the existing permit.

4.2 The energy efficiency levels associated with the Best Available Techniques Conclusions

An energy efficiency level associated with the best available techniques (BAT-AEEL) refers to the ratio between the combustion unit's net energy output(s) and the combustion unit's fuel/feedstock energy input at actual unit design. The net energy output(s) is determined at the combustion unit boundaries, including auxiliary systems (e.g. flue-gas treatment systems), and for the unit operated at full load.

The table below sets out the BAT-AEELs specified in the LCP BAT Conclusions for the large combustion plant on the site and the energy efficiency levels confirmed through the Regulation 61 notice response. The operator has currently been unable to provide us with evidence to demonstrate the AEELs will be met, however this should be possible on completion of IC11, IC12 and IC13. These IC's have been necessary due to the Operator not being able to provide information on the sites energy efficiency, effective-Dry Low NOx and Minimum Start Up Load/Minimum Shut Down Load.

BAT AEELs (%)			Plant efficiency (%)		
Net electrical efficiency	Net total fuel utilisation	Net mechanical efficiency	Net electrical efficiency	Net total fuel utilisation	Net mechanical efficiency
LCP48: unit description from the AEEL table					
50 - 60	None	None	see IC11	NA	NA

5 Decision checklist regarding relevant BAT Conclusions

BAT Conclusions for large combustion plant, were published by the European Commission on 17th August 2017. There are 75 BAT Conclusions. Only the BAT Conclusions relevant to the particular fuel type used on site have been replicated below.

This annex provides a record of decisions made in relation to each relevant BAT Conclusion applicable to the installation. This annex should be read in conjunction with the Consolidated Variation Notice.

The conditions in the permit through which the relevant BAT Conclusions are implemented include but are not limited to the following:

BAT Conclusion requirement topic	Permit condition(s)	Permit table(s)
Environmental Management System	1.1.1	S1.2
BAT AELs	3.1.1 and 3.5.1	S3.1a
Monitoring	2.3, 3.5 and 3.6	S3.1, S31a,
Energy efficiency	1.2 and 2.3	S3.5
Noise	3.4 and 2.3	S1.2
Other operating techniques	1.2	S1.2

The overall status of compliance with the BAT conclusion is indicated in the table as:

- NA Not Applicable
- CC Currently Compliant
- FC Compliant in the future (within 4 years of publication of BAT conclusions)
- NC Not Compliant
- PC Partially Compliant

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
General			
1	<p>In order to improve the overall environmental performance, BAT is to implement and adhere to an environmental management system (EMS) that incorporates all of the following features:</p> <ul style="list-style-type: none"> i. commitment of the management, including senior management; ii. definition of an environmental policy that includes the continuous improvement of the installation by the management; iii. planning and establishing the necessary procedures, objectives and targets, in conjunction with financial planning and investment; iv. implementation of procedures <ul style="list-style-type: none"> (a) Structure and responsibility (b) Training (c) Communication (d) Employee involvement (e) Documentation (f) Efficient process control (g) Maintenance programmes (h) Emergency preparedness and response (i) Safeguarding compliance with environmental legislation v. checking performance and taking corrective action, paying particular attention to: <ul style="list-style-type: none"> (a) monitoring and measurement (see also the Reference Document on the General Principles of Monitoring) (b) corrective and preventive action (c) maintenance of records (d) independent (where practicable) internal and external auditing in order to determine whether or not the EMS conforms to planned arrangements and has been properly implemented and maintained; vi. review of the EMS and its continuing suitability, adequacy and effectiveness by senior management; vii. following the development of cleaner technologies; viii. consideration for the environmental impacts from the eventual decommissioning of the installation at the stage of designing a new plant, and throughout its operating life; viii. consideration for the environmental impacts from the eventual decommissioning of the installation at the stage of designing a new plant, and throughout its operating life; ix. application of sectoral benchmarking on a regular basis. <p>Etc - see BAT Conclusions</p>	CC	<p>The station operates an EMS which is fully integrated and certified to ISO14001: 2015 Certificate No: 246955/2017/AE/GBR/UKAS</p>

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement													
	<p>Applicability. The scope (e.g. level of detail) and nature of the EMS (e.g. standardised or non-standardised) will generally be related to the nature, scale and complexity of the installation, and the range of environmental impacts it may have.</p>															
2	<p>BAT is to determine the net electrical efficiency and/or the net total fuel utilisation and/or the net mechanical energy efficiency of the gasification, IGCC and/or combustion units by carrying out a performance test at full load (1), according to EN standards, after the commissioning of the unit and after each modification that could significantly affect the net electrical efficiency and/or the net total fuel utilisation and/or the net mechanical energy efficiency of the unit. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.</p>	FC	<p>The site has undergone a replant and will soon be entering commissioning. The site has a contractual target of >56.98% net electrical efficiency. The actual efficiency will be calculated from a performance test completed during the commissioning programme. See IC11</p>													
3	<p>BAT is to monitor key process parameters relevant for emissions to air and water including those given below.</p> <table border="1" data-bbox="338 834 1494 1007"> <thead> <tr> <th data-bbox="338 834 698 871">Stream</th> <th data-bbox="698 834 1128 871">Parameter(s)</th> <th data-bbox="1128 834 1494 871">Monitoring</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 871 698 975" rowspan="3">Flue-gas</td> <td data-bbox="698 871 1128 908">Flow</td> <td data-bbox="1128 871 1494 908">Periodic or continuous determination</td> </tr> <tr> <td data-bbox="698 908 1128 944">Oxygen content, temperature, and pressure</td> <td data-bbox="1128 908 1494 944">Periodic or continuous measurement</td> </tr> <tr> <td data-bbox="698 944 1128 975">Water vapour content ⁽³⁾</td> <td data-bbox="1128 944 1494 975"></td> </tr> <tr> <td data-bbox="338 975 698 1007">Waste water from flue-gas treatment</td> <td data-bbox="698 975 1128 1007">Flow, pH, and temperature</td> <td data-bbox="1128 975 1494 1007">Continuous measurement</td> </tr> </tbody> </table>	Stream	Parameter(s)	Monitoring	Flue-gas	Flow	Periodic or continuous determination	Oxygen content, temperature, and pressure	Periodic or continuous measurement	Water vapour content ⁽³⁾		Waste water from flue-gas treatment	Flow, pH, and temperature	Continuous measurement	FC	<p>All testing equipment and personnel used will be in accordance with MCERTs and the IED compliance protocol.</p> <p>Flow will be measured in accordance with EN16911-1 to validate the calculations in accordance with EN16911-2. Flow will then be determined periodically. Only oxygen is required for reporting reference conditions. Oxygen is continually monitored to EN14789. Flue gas is dried before analysis, therefore monitoring of water vapour content is not required. There is no waste water from flue gas treatment. Operations are carried out in compliance with the IED Compliance Protocol (JEP13SGG14: Electricity Supply</p>
Stream	Parameter(s)	Monitoring														
Flue-gas	Flow	Periodic or continuous determination														
	Oxygen content, temperature, and pressure	Periodic or continuous measurement														
	Water vapour content ⁽³⁾															
Waste water from flue-gas treatment	Flow, pH, and temperature	Continuous measurement														

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																														
			Industry - IED Compliance Protocol for Utility Boilers and Gas Turbines (December 2015)).																														
4	<p>BAT is to monitor emissions to air with at least the frequency given below and in accordance with EN standards. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.</p> <table border="1" data-bbox="338 568 1494 1356"> <thead> <tr> <th data-bbox="338 568 490 683">Substance/Parameter</th> <th data-bbox="490 568 799 683">Fuel/Process/Type of combustion plant</th> <th data-bbox="799 568 954 683">Combustion plant total rated thermal input</th> <th data-bbox="954 568 1131 683">Standard(s) ⁽¹⁾</th> <th data-bbox="1131 568 1348 683">Minimum monitoring frequency ⁽²⁾</th> <th data-bbox="1348 568 1494 683">Monitoring associated with</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 683 490 751">NH₃</td> <td data-bbox="490 683 799 751">— When SCR and/or SNCR is used</td> <td data-bbox="799 683 954 751">All sizes</td> <td data-bbox="954 683 1131 751">Generic EN standards</td> <td data-bbox="1131 683 1348 751">Continuous ⁽⁶⁾ ⁽⁷⁾</td> <td data-bbox="1348 683 1494 751">BAT 7</td> </tr> <tr> <td data-bbox="338 751 490 1203">NO_x</td> <td data-bbox="490 751 799 1203"> <ul style="list-style-type: none"> — Coal and/or lignite including waste co-incineration — Solid biomass and/or peat including waste co-incineration — HFO- and/or gas-oil-fired boilers and engines — Gas-oil-fired gas turbines — Natural-gas-fired boilers, engines, and turbines — Iron and steel process gases — Process fuels from the chemical industry — IGCC plants </td> <td data-bbox="799 751 954 1203">All sizes</td> <td data-bbox="954 751 1131 1203">Generic EN standards</td> <td data-bbox="1131 751 1348 1203">Continuous ⁽⁶⁾ ⁽⁸⁾</td> <td data-bbox="1348 751 1494 1203">BAT 20 BAT 24 BAT 28 BAT 32 BAT 37 BAT 41 BAT 42 BAT 43 BAT 47 BAT 48 BAT 56 BAT 64 BAT 65 BAT 73</td> </tr> <tr> <td data-bbox="338 1203 490 1272"></td> <td data-bbox="490 1203 799 1272">— Combustion plants on offshore platforms</td> <td data-bbox="799 1203 954 1272">All sizes</td> <td data-bbox="954 1203 1131 1272">EN 14792</td> <td data-bbox="1131 1203 1348 1272">Once every year ⁽⁹⁾</td> <td data-bbox="1348 1203 1494 1272">BAT 53</td> </tr> <tr> <td data-bbox="338 1272 490 1356">N₂O</td> <td data-bbox="490 1272 799 1356">— Coal and/or lignite in circulating fluidised bed boilers</td> <td data-bbox="799 1272 954 1356">All sizes</td> <td data-bbox="954 1272 1131 1356">EN 21258</td> <td data-bbox="1131 1272 1348 1356">Once every year ⁽¹⁰⁾</td> <td data-bbox="1348 1272 1494 1356">BAT 20 BAT 24</td> </tr> </tbody> </table>	Substance/Parameter	Fuel/Process/Type of combustion plant	Combustion plant total rated thermal input	Standard(s) ⁽¹⁾	Minimum monitoring frequency ⁽²⁾	Monitoring associated with	NH ₃	— When SCR and/or SNCR is used	All sizes	Generic EN standards	Continuous ⁽⁶⁾ ⁽⁷⁾	BAT 7	NO _x	<ul style="list-style-type: none"> — Coal and/or lignite including waste co-incineration — Solid biomass and/or peat including waste co-incineration — HFO- and/or gas-oil-fired boilers and engines — Gas-oil-fired gas turbines — Natural-gas-fired boilers, engines, and turbines — Iron and steel process gases — Process fuels from the chemical industry — IGCC plants 	All sizes	Generic EN standards	Continuous ⁽⁶⁾ ⁽⁸⁾	BAT 20 BAT 24 BAT 28 BAT 32 BAT 37 BAT 41 BAT 42 BAT 43 BAT 47 BAT 48 BAT 56 BAT 64 BAT 65 BAT 73		— Combustion plants on offshore platforms	All sizes	EN 14792	Once every year ⁽⁹⁾	BAT 53	N ₂ O	— Coal and/or lignite in circulating fluidised bed boilers	All sizes	EN 21258	Once every year ⁽¹⁰⁾	BAT 20 BAT 24	FC	Monitoring will be carried out continuously in accordance with EN14181. The site monitors CO and NO _x , as required by BAT 4 for natural gas fired turbines. Monitoring is carried out continuously using MCERTs continuous emissions monitoring system.
Substance/Parameter	Fuel/Process/Type of combustion plant	Combustion plant total rated thermal input	Standard(s) ⁽¹⁾	Minimum monitoring frequency ⁽²⁾	Monitoring associated with																												
NH ₃	— When SCR and/or SNCR is used	All sizes	Generic EN standards	Continuous ⁽⁶⁾ ⁽⁷⁾	BAT 7																												
NO _x	<ul style="list-style-type: none"> — Coal and/or lignite including waste co-incineration — Solid biomass and/or peat including waste co-incineration — HFO- and/or gas-oil-fired boilers and engines — Gas-oil-fired gas turbines — Natural-gas-fired boilers, engines, and turbines — Iron and steel process gases — Process fuels from the chemical industry — IGCC plants 	All sizes	Generic EN standards	Continuous ⁽⁶⁾ ⁽⁸⁾	BAT 20 BAT 24 BAT 28 BAT 32 BAT 37 BAT 41 BAT 42 BAT 43 BAT 47 BAT 48 BAT 56 BAT 64 BAT 65 BAT 73																												
	— Combustion plants on offshore platforms	All sizes	EN 14792	Once every year ⁽⁹⁾	BAT 53																												
N ₂ O	— Coal and/or lignite in circulating fluidised bed boilers	All sizes	EN 21258	Once every year ⁽¹⁰⁾	BAT 20 BAT 24																												

BAT Concn. Number	Summary of BAT Conclusion requirement					Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
		— Solid biomass and/or peat in circulating fluidised bed boilers					
	CO	<ul style="list-style-type: none"> — Coal and/or lignite including waste co-incineration — Solid biomass and/or peat including waste co-incineration — HFO- and/or gas-oil-fired boilers and engines — Gas-oil-fired gas turbines — Natural-gas-fired boilers, engines, and turbines — Iron and steel process gases — Process fuels from the chemical industry — IGCC plants 	All sizes	Generic EN standards	Continuous ₁ (⁸)	BAT 20 BAT 24 BAT 28 BAT 33 BAT 38 BAT 44 BAT 49 BAT 56 BAT 64 BAT 65 BAT 73	
		— Combustion plants on offshore platforms	All sizes	EN 15058	Once every year ₁ (⁹)	BAT 54	
	SO ₂	<ul style="list-style-type: none"> — Coal and/or lignite incl waste co-incineration — Solid biomass and/or peat incl waste co-incineration — HFO- and/or gas-oil-fired boilers — HFO- and/or gas-oil-fired engines — Gas-oil-fired gas turbines — Iron and steel process gases — Process fuels from the chemical industry in boilers 	All sizes	Generic EN standards and EN 14791	Continuous ₁ (¹¹) ₁ (¹²)	BAT 21 BAT 25 BAT 29 BAT 34 BAT 39 BAT 50 BAT 57 BAT 66 BAT 67 BAT 74	

BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
		— IGCC plants						
	SO ₃	— When SCR is used	All sizes	No EN standard available	Once every year	—		
	Gaseous chlorides, expressed as HCl	— Coal and/or lignite — Process fuels from the chemical industry in boilers	All sizes	EN 1911	Once every three months ₍₆₎ (13) (14)	BAT 21 BAT 57		
		— Solid biomass and/or peat	All sizes	Generic EN standards	Continuous ₍₁₅₎ (16)	BAT 25		
		— Waste co-incineration	All sizes	Generic EN standards	Continuous ₍₆₎ (16)	BAT 66 BAT 67		
	HF	— Coal and/or lignite — Process fuels from the chemical industry in boilers	All sizes	No EN standard available	Once every three months ₍₆₎ (13) (14)	BAT 21 BAT 57		
		— Solid biomass and/or peat	All sizes	No EN standard available	Once every year	BAT 25		
		— Waste co-incineration	All sizes	Generic EN standards	Continuous ₍₆₎ (16)	BAT 66 BAT 67		
	Dust	<ul style="list-style-type: none"> — Coal and/or lignite — Solid biomass and/or peat — HFO- and/or gas-oil-fired boilers — Iron and steel process gases — Process fuels from the chemical industry in boilers — IGCC plants — HFO- and/or gas-oil-fired engines — Gas-oil-fired gas turbines 	All sizes	Generic EN standards and EN 13284-1 and EN 13284-2	Continuous ₍₆₎ (17)	BAT 22 BAT 26 BAT 30 BAT 35 BAT 39 BAT 51 BAT 58 BAT 75		

BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	—	Waste co-incineration	All sizes	Generic EN standards and EN 13284-2	Continuous	BAT 68 BAT 69		
	Metals and metalloids except mercury (As, Cd, Co, Cr, Cu, Mn, Ni, Pb, Sb, Se, Ti, V, Zn)	—	Coal and/or lignite Solid biomass and/or peat HFO- and/or gas-oil-fired boilers and engines	All sizes	EN 14385	Once every year ⁽¹⁸⁾		BAT 22 BAT 26 BAT 30
	Hg	—	Waste co-incineration	< 300 MW _{th}	EN 14385	Once every six months ⁽¹⁵⁾		BAT 68 BAT 69
		—	IGCC plants	≥ 300 MW _{th}	EN 14385	Once every three months ⁽¹⁹⁾ ⁽¹³⁾		BAT 75
		—	Coal and/or lignite including waste co-incineration	< 300 MW _{th}	EN 13211	Once every three months ⁽¹³⁾ ⁽²⁰⁾		BAT 23
		—	Solid biomass and/or peat	≥ 300 MW _{th}	Generic EN standards and EN 14884	Continuous ⁽¹⁶⁾ ⁽²¹⁾		BAT 27
		—	Waste co-incineration with solid biomass and/or peat	All sizes	EN 13211	Once every year ⁽²²⁾		BAT 70
		—	IGCC plants	All sizes	EN 13211	Once every three months ⁽¹³⁾		BAT 75
		—	HFO- and/or gas-oil-fired engines	All sizes	EN 12619	Once every year ⁽²³⁾		BAT 33 BAT 59
		—	Process fuels from chemical industry in boilers	All sizes	Generic EN standards	Continuous		BAT 71
		—	Waste co-incineration with coal, lignite, solid biomass and/or peat	All sizes	No EN standard available	Once every year		BAT 45
		—	Natural-gas in spark-ignited lean-burn gas and dual fuel engines	All sizes	EN ISO 25139	Once every year ⁽²⁴⁾		BAT 45
		—	Natural-gas-fired engines	All sizes	EN ISO 25139	Once every year ⁽²⁴⁾		BAT 45

BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																																												
	PCDD/F	<ul style="list-style-type: none"> — Process fuels from chemical industry in boilers — Waste co-incineration 	All sizes	EN 1948-1, EN 1948-2, EN 1948-3	Once every six months ⁽¹⁵⁾ ⁽²⁵⁾	BAT 59 BAT 71																																														
5	<p>BAT is to monitor emissions to water from flue-gas treatment with at least the frequency given below and in accordance with EN standards. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.</p> <table border="1" data-bbox="349 612 1491 1377"> <thead> <tr> <th colspan="2" data-bbox="349 612 678 699">Substance/Parameter</th> <th data-bbox="678 612 1032 699">Standard(s)</th> <th data-bbox="1032 612 1267 699">Minimum monitoring frequency</th> <th data-bbox="1267 612 1491 699">Monitoring associated with</th> </tr> </thead> <tbody> <tr> <td colspan="2" data-bbox="349 699 678 730">Total organic carbon (TOC) ⁽²⁶⁾</td> <td data-bbox="678 699 1032 730">EN 1484</td> <td data-bbox="1032 699 1267 1377" rowspan="9">Once every month</td> <td data-bbox="1267 699 1491 1377" rowspan="9">BAT 15</td> </tr> <tr> <td colspan="2" data-bbox="349 730 678 794">Chemical oxygen demand (COD) ⁽²⁶⁾</td> <td data-bbox="678 730 1032 794">No EN standard available</td> </tr> <tr> <td colspan="2" data-bbox="349 794 678 826">Total suspended solids (TSS)</td> <td data-bbox="678 794 1032 826">EN 872</td> </tr> <tr> <td colspan="2" data-bbox="349 826 678 858">Fluoride (F⁻)</td> <td data-bbox="678 826 1032 858">EN ISO 10304-1</td> </tr> <tr> <td colspan="2" data-bbox="349 858 678 890">Sulphate (SO₄²⁻)</td> <td data-bbox="678 858 1032 890">EN ISO 10304-1</td> </tr> <tr> <td colspan="2" data-bbox="349 890 678 922">Sulphide, easily released (S²⁻)</td> <td data-bbox="678 890 1032 922">No EN standard available</td> </tr> <tr> <td colspan="2" data-bbox="349 922 678 954">Sulphite (SO₃²⁻)</td> <td data-bbox="678 922 1032 954">EN ISO 10304-3</td> </tr> <tr> <td data-bbox="349 954 609 1294" rowspan="7">Metals and metalloids</td> <td data-bbox="609 954 678 994">As</td> <td data-bbox="678 954 1032 994" rowspan="6">Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)</td> </tr> <tr> <td data-bbox="609 994 678 1034">Cd</td> </tr> <tr> <td data-bbox="609 1034 678 1074">Cr</td> </tr> <tr> <td data-bbox="609 1074 678 1114">Cu</td> </tr> <tr> <td data-bbox="609 1114 678 1153">Ni</td> </tr> <tr> <td data-bbox="609 1153 678 1193">Pb</td> </tr> <tr> <td data-bbox="609 1193 678 1233">Zn</td> </tr> <tr> <td data-bbox="609 1233 678 1294">Hg</td> <td data-bbox="678 1233 1032 1294">Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)</td> </tr> <tr> <td colspan="2" data-bbox="349 1294 678 1377">Chloride (Cl⁻)</td> <td data-bbox="678 1294 1032 1377">Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)</td> <td data-bbox="1032 1294 1267 1377"></td> <td data-bbox="1267 1294 1491 1377">—</td> </tr> </tbody> </table>						Substance/Parameter		Standard(s)	Minimum monitoring frequency	Monitoring associated with	Total organic carbon (TOC) ⁽²⁶⁾		EN 1484	Once every month	BAT 15	Chemical oxygen demand (COD) ⁽²⁶⁾		No EN standard available	Total suspended solids (TSS)		EN 872	Fluoride (F ⁻)		EN ISO 10304-1	Sulphate (SO ₄ ²⁻)		EN ISO 10304-1	Sulphide, easily released (S ²⁻)		No EN standard available	Sulphite (SO ₃ ²⁻)		EN ISO 10304-3	Metals and metalloids	As	Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)	Cd	Cr	Cu	Ni	Pb	Zn	Hg	Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)	Chloride (Cl ⁻)		Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)		—	NA	There is no flue gas treatment at this site.
Substance/Parameter		Standard(s)	Minimum monitoring frequency	Monitoring associated with																																																
Total organic carbon (TOC) ⁽²⁶⁾		EN 1484	Once every month	BAT 15																																																
Chemical oxygen demand (COD) ⁽²⁶⁾		No EN standard available																																																		
Total suspended solids (TSS)		EN 872																																																		
Fluoride (F ⁻)		EN ISO 10304-1																																																		
Sulphate (SO ₄ ²⁻)		EN ISO 10304-1																																																		
Sulphide, easily released (S ²⁻)		No EN standard available																																																		
Sulphite (SO ₃ ²⁻)		EN ISO 10304-3																																																		
Metals and metalloids	As	Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)																																																		
	Cd																																																			
	Cr																																																			
	Cu																																																			
	Ni																																																			
	Pb																																																			
	Zn																																																			
Hg	Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)																																																			
Chloride (Cl ⁻)		Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)		—																																																

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																		
	<table border="1"> <tr> <td data-bbox="349 389 674 427">Total nitrogen</td> <td data-bbox="674 389 1032 427">EN 12260</td> <td data-bbox="1032 389 1267 427"></td> <td data-bbox="1267 389 1491 427">—</td> </tr> </table>	Total nitrogen	EN 12260		—																
Total nitrogen	EN 12260		—																		
6	<p>In order to improve the general environmental performance of combustion plants and to reduce emissions to air of CO and unburnt substances, BAT is to ensure optimised combustion and to use an appropriate combination of the techniques given below.</p> <table border="1"> <thead> <tr> <th data-bbox="349 539 568 571">Technique</th> <th data-bbox="568 539 1003 571">Description</th> <th data-bbox="1003 539 1491 571">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="349 571 383 619">a.</td> <td data-bbox="383 571 568 655">Fuel blending and mixing</td> <td data-bbox="568 571 1003 655">Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type</td> </tr> <tr> <td data-bbox="349 655 383 740">b.</td> <td data-bbox="383 655 568 740">Maintenance of the combustion system</td> <td data-bbox="568 655 1003 740">Regular planned maintenance according to suppliers' recommendations</td> </tr> <tr> <td data-bbox="349 740 383 825">c.</td> <td data-bbox="383 740 568 825">Advanced control system</td> <td data-bbox="568 740 1003 825">See description in Section 8.1</td> </tr> <tr> <td data-bbox="349 825 383 909">d.</td> <td data-bbox="383 825 568 909">Good design of the combustion equipment</td> <td data-bbox="568 825 1003 909">Good design of furnace, combustion chambers, burners and associated devices</td> </tr> <tr> <td data-bbox="349 909 383 1163">e.</td> <td data-bbox="383 909 568 1163">Fuel choice</td> <td data-bbox="568 909 1003 1163">Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used</td> </tr> </tbody> </table>	Technique	Description	Applicability	a.	Fuel blending and mixing	Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type	b.	Maintenance of the combustion system	Regular planned maintenance according to suppliers' recommendations	c.	Advanced control system	See description in Section 8.1	d.	Good design of the combustion equipment	Good design of furnace, combustion chambers, burners and associated devices	e.	Fuel choice	Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used	FC	<p>a) The blending and mixing of different qualities of the same fuel types is not appropriate for this site, as the site is supplied through the national transmission system.</p> <p>b) Regular planned maintenance is carried out according to manufacturer's recommendations. Periodic hot gas path inspections and minor and major maintenance outages are based on number of starts.</p> <p>c) The site has an advanced control and monitoring system. This automated control system optimises combustion temperature and efficiency during running. There is also a PI system for high-performance monitoring. The DCS has been upgraded in the recent replant.</p> <p>d) The recent replant has improved the design of the combustion chambers and has improved burner design through the addition of dry low NOx burners.</p> <p>e) Natural gas is the only fuel used on the gas turbine. Natural gas is a low sulphur fuel.</p>
Technique	Description	Applicability																			
a.	Fuel blending and mixing	Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type																			
b.	Maintenance of the combustion system	Regular planned maintenance according to suppliers' recommendations																			
c.	Advanced control system	See description in Section 8.1																			
d.	Good design of the combustion equipment	Good design of furnace, combustion chambers, burners and associated devices																			
e.	Fuel choice	Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used																			

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
7	<p>In order to reduce emissions of ammonia to air from the use of selective catalytic reduction (SCR) and/or selective non-catalytic reduction (SNCR) for the abatement of NO_x emissions, BAT is to optimise the design and/or operation of SCR and/or SNCR (e.g. optimised reagent to NO_x ratio, homogeneous reagent distribution and optimum size of the reagent drops).</p> <p>BAT-associated emission levels</p> <p>The BAT-associated emission level (BAT-AEL) for emissions of NH₃ to air from the use of SCR and/or SNCR is < 3–10 mg/Nm³ as a yearly average or average over the sampling period. The lower end of the range can be achieved when using SCR and the upper end of the range can be achieved when using SNCR without wet abatement techniques. In the case of plants combusting biomass and operating at variable loads as well as in the case of engines combusting HFO and/or gas oil, the higher end of the BAT-AEL range is 15 mg/Nm³.</p>	NA	SCR/SNCR are not used on site
8	<p>In order to prevent or reduce emissions to air during normal operating conditions, BAT is to ensure, by appropriate design, operation and maintenance, that the emission abatement systems are used at optimal capacity and availability.</p>	FC	<p>In order to reduce emissions during normal operating conditions, fuel air mixes are optimised, and maintenance programmes are carried out. The recent replant has improved the design of the combustion chambers and has improved burner design through the addition of dry low NO_x burners. Regular planned maintenance is carried out according to manufacturer's recommendations. Periodic hot gas path inspections and minor and major maintenance outages are based on running hours.</p>
9	<p>In order to improve the general environmental performance of combustion and/or gasification plants and to reduce emissions to air, BAT is to include the following elements in the quality assurance/quality control programmes for all the fuels used, as part of the environmental management system (see BAT 1):</p> <p>(i) Initial full characterisation of the fuel used including at least the parameters listed below and in accordance with EN standards. ISO, national or other international standards may be used provided they ensure the provision of data of an equivalent scientific quality;</p>	NA	<p>The site uses natural gas supplied via the national Transmission System and the fuel supplied is controlled in line with national standards.</p>

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																					
	<p>(ii) Regular testing of the fuel quality to check that it is consistent with the initial characterisation and according to the plant design specifications. The frequency of testing and the parameters chosen from the table below are based on the variability of the fuel and an assessment of the relevance of pollutant releases (e.g. concentration in fuel, flue-gas treatment employed);</p> <p>(iii) Subsequent adjustment of the plant settings as and when needed and practicable (e.g. integration of the fuel characterisation and control in the advanced control system (see description in Section 8.1)).</p> <p>Description Initial characterisation and regular testing of the fuel can be performed by the operator and/or the fuel supplier. If performed by the supplier, the full results are provided to the operator in the form of a product (fuel) supplier specification and/or guarantee.</p> <table border="1" data-bbox="338 667 1494 1369"> <thead> <tr> <th data-bbox="338 667 723 703">Fuel(s)</th> <th data-bbox="723 667 1494 703">Substances/Parameters subject to characterisation</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 703 723 906" rowspan="4">Biomass/peat</td> <td data-bbox="723 703 1494 740">— LHV</td> </tr> <tr> <td data-bbox="723 740 1494 777">— moisture</td> </tr> <tr> <td data-bbox="723 777 1494 813">— Ash</td> </tr> <tr> <td data-bbox="723 813 1494 906">— C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn)</td> </tr> <tr> <td data-bbox="338 906 723 1118" rowspan="4">Coal/lignite</td> <td data-bbox="723 906 1494 943">— LHV</td> </tr> <tr> <td data-bbox="723 943 1494 979">— Moisture</td> </tr> <tr> <td data-bbox="723 979 1494 1016">— Volatiles, ash, fixed carbon, C, H, N, O, S</td> </tr> <tr> <td data-bbox="723 1016 1494 1118">— Br, Cl, F — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)</td> </tr> <tr> <td data-bbox="338 1118 723 1203" rowspan="2">HFO</td> <td data-bbox="723 1118 1494 1155">— Ash</td> </tr> <tr> <td data-bbox="723 1155 1494 1203">— C, S, N, Ni, V</td> </tr> <tr> <td data-bbox="338 1203 723 1287" rowspan="2">Gas oil</td> <td data-bbox="723 1203 1494 1240">— Ash</td> </tr> <tr> <td data-bbox="723 1240 1494 1287">— N, C, S</td> </tr> <tr> <td data-bbox="338 1287 723 1369" rowspan="2">Natural gas</td> <td data-bbox="723 1287 1494 1324">— LHV</td> </tr> <tr> <td data-bbox="723 1324 1494 1369">— CH₄, C₂H₆, C₃, C₄+, CO₂, N₂, Wobbe index</td> </tr> </tbody> </table>	Fuel(s)	Substances/Parameters subject to characterisation	Biomass/peat	— LHV	— moisture	— Ash	— C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn)	Coal/lignite	— LHV	— Moisture	— Volatiles, ash, fixed carbon, C, H, N, O, S	— Br, Cl, F — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)	HFO	— Ash	— C, S, N, Ni, V	Gas oil	— Ash	— N, C, S	Natural gas	— LHV	— CH ₄ , C ₂ H ₆ , C ₃ , C ₄ +, CO ₂ , N ₂ , Wobbe index		
Fuel(s)	Substances/Parameters subject to characterisation																							
Biomass/peat	— LHV																							
	— moisture																							
	— Ash																							
	— C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn)																							
Coal/lignite	— LHV																							
	— Moisture																							
	— Volatiles, ash, fixed carbon, C, H, N, O, S																							
	— Br, Cl, F — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)																							
HFO	— Ash																							
	— C, S, N, Ni, V																							
Gas oil	— Ash																							
	— N, C, S																							
Natural gas	— LHV																							
	— CH ₄ , C ₂ H ₆ , C ₃ , C ₄ +, CO ₂ , N ₂ , Wobbe index																							

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement						
	<table border="1"> <tr> <td data-bbox="338 384 725 469">Process fuels from the chemical industry⁽²⁷⁾</td> <td data-bbox="725 384 1494 469"> <ul style="list-style-type: none"> — Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) </td> </tr> <tr> <td data-bbox="338 469 725 539">Iron and steel process gases</td> <td data-bbox="725 469 1494 539"> <ul style="list-style-type: none"> — LHV, CH₄ (for COG), C_xH_y (for COG), CO₂, H₂, N₂, total sulphur, dust, Wobbe index </td> </tr> <tr> <td data-bbox="338 539 725 695">Waste⁽²⁸⁾</td> <td data-bbox="725 539 1494 695"> <ul style="list-style-type: none"> — LHV — Moisture — Volatiles, ash, Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) </td> </tr> </table>	Process fuels from the chemical industry ⁽²⁷⁾	<ul style="list-style-type: none"> — Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) 	Iron and steel process gases	<ul style="list-style-type: none"> — LHV, CH₄ (for COG), C_xH_y (for COG), CO₂, H₂, N₂, total sulphur, dust, Wobbe index 	Waste ⁽²⁸⁾	<ul style="list-style-type: none"> — LHV — Moisture — Volatiles, ash, Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) 		
Process fuels from the chemical industry ⁽²⁷⁾	<ul style="list-style-type: none"> — Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) 								
Iron and steel process gases	<ul style="list-style-type: none"> — LHV, CH₄ (for COG), C_xH_y (for COG), CO₂, H₂, N₂, total sulphur, dust, Wobbe index 								
Waste ⁽²⁸⁾	<ul style="list-style-type: none"> — LHV — Moisture — Volatiles, ash, Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) 								
10	<p>In order to reduce emissions to air and/or to water during other than normal operating conditions (OTNOC), BAT is to set up and implement a management plan as part of the environmental management system (see BAT 1), commensurate with the relevance of potential pollutant releases, that includes the following elements:</p> <ul style="list-style-type: none"> — appropriate design of the systems considered relevant in causing OTNOC that may have an impact on emissions to air, water and/or soil (e.g. low-load design concepts for reducing the minimum start-up and shutdown loads for stable generation in gas turbines), — set-up and implementation of a specific preventive maintenance plan for these relevant systems, — review and recording of emissions caused by OTNOC and associated circumstances and implementation of corrective actions if necessary, — periodic assessment of the overall emissions during OTNOC (e.g. frequency of events, duration, emissions quantification/estimation) and implementation of corrective actions if necessary. 	FC	<p>This site does not have a specific OTNOC management plan, however the EMS incorporates many of the key aspects of BAT 10 & 11. The site operates a risk based review with the EMS (Aspects and impacts) which includes a review of potential impacts of OTNOC. A) Gas turbine starts are optimised based on plant condition to minimise emissions during start-up. B) All plant components are included within the site specific preventative maintenance programmes, the frequency of maintenance is dependent on operation of the site.</p>						
11	<p>BAT is to appropriately monitor emissions to air and/or to water during OTNOC.</p> <p>Description</p> <p>The monitoring can be carried out by direct measurement of emissions or by monitoring of surrogate parameters if this proves to be of equal or better scientific quality than the direct measurement of emissions. Emissions during start-up and shutdown (SU/SD) may be assessed based on a detailed emission</p>	FC	<p>Emissions during start-up and shutdown operations are monitored and reviewed to identify if corrective actions are required. Emissions to atmosphere are</p>						

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																		
	measurement carried out for a typical SU/SD procedure at least once every year, and using the results of this measurement to estimate the emissions for each and every SU/SD throughout the year.		assessed as part of the annual environmental performance review carried out by sites. In the event of an accident or environmental incident, the operator would review the emissions, cause etc as part of the incident investigation process and ensure any relevant corrective and / or preventive action is implemented.																		
12	<p>In order to increase the energy efficiency of combustion, gasification and/or IGCC units operated $\geq 1\,500$ h/yr, BAT is to use an appropriate combination of the techniques given below.</p> <table border="1" data-bbox="338 762 1494 1374"> <thead> <tr> <th data-bbox="338 762 591 794">Technique</th> <th data-bbox="591 762 1061 794">Description</th> <th data-bbox="1061 762 1494 794">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 794 591 906">a. Combustion optimisation</td> <td data-bbox="591 794 1061 906">See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues</td> <td data-bbox="1061 794 1494 906" rowspan="3">Generally applicable</td> </tr> <tr> <td data-bbox="338 906 591 1038">b. Optimisation of the working medium conditions</td> <td data-bbox="591 906 1061 1038">Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO_x emissions or the characteristics of energy demanded</td> </tr> <tr> <td data-bbox="338 1038 591 1150">c. Optimisation of the steam cycle</td> <td data-bbox="591 1038 1061 1150">Operate with lower turbine exhaust pressure by utilisation of the lowest possible temperature of the condenser cooling water, within the design conditions</td> </tr> <tr> <td data-bbox="338 1150 591 1206">d. Minimisation of energy consumption</td> <td data-bbox="591 1150 1061 1206">Minimising the internal energy consumption (e.g. greater efficiency of the feed-water pump)</td> <td data-bbox="1061 1206 1494 1294" rowspan="2">Generally applicable within the constraints related to the need to control NO_x emissions</td> </tr> <tr> <td data-bbox="338 1206 591 1294">e. Preheating of combustion air</td> <td data-bbox="591 1206 1061 1294">Reuse of part of the heat recovered from the combustion flue-gas to preheat the air used in combustion</td> </tr> <tr> <td data-bbox="338 1294 591 1374">f. Fuel preheating</td> <td data-bbox="591 1294 1061 1374">Preheating of fuel using recovered heat</td> <td data-bbox="1061 1294 1494 1374">Generally applicable within the constraints associated with the boiler design and the need to control NO_xemissions</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Combustion optimisation	See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues	Generally applicable	b. Optimisation of the working medium conditions	Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO _x emissions or the characteristics of energy demanded	c. Optimisation of the steam cycle	Operate with lower turbine exhaust pressure by utilisation of the lowest possible temperature of the condenser cooling water, within the design conditions	d. Minimisation of energy consumption	Minimising the internal energy consumption (e.g. greater efficiency of the feed-water pump)	Generally applicable within the constraints related to the need to control NO _x emissions	e. Preheating of combustion air	Reuse of part of the heat recovered from the combustion flue-gas to preheat the air used in combustion	f. Fuel preheating	Preheating of fuel using recovered heat	Generally applicable within the constraints associated with the boiler design and the need to control NO _x emissions	FC	<p>a) Combustion will be optimised during the commissioning of the plant as per the Original Equipment Manufacturer's (OEM) approved procedure. The temperature and fuel/air mix will also be optimised during this commissioning stage through the DLN burners. The DLN burners mix the air and fuel before combustion to achieve optimal temperature conditions and reduce NO_x emissions.</p> <p>b) Optimisation of the working medium conditions is achieved through operation of the gas turbine at the highest gas pressure allowed within the OEM parameters, and pre-heating of the gas before combustion.</p> <p>c) The plant has been modified to maximise the energy available from the steam turbine by the addition of a new superheater /</p>
Technique	Description	Applicability																			
a. Combustion optimisation	See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues	Generally applicable																			
b. Optimisation of the working medium conditions	Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO _x emissions or the characteristics of energy demanded																				
c. Optimisation of the steam cycle	Operate with lower turbine exhaust pressure by utilisation of the lowest possible temperature of the condenser cooling water, within the design conditions																				
d. Minimisation of energy consumption	Minimising the internal energy consumption (e.g. greater efficiency of the feed-water pump)	Generally applicable within the constraints related to the need to control NO _x emissions																			
e. Preheating of combustion air	Reuse of part of the heat recovered from the combustion flue-gas to preheat the air used in combustion																				
f. Fuel preheating	Preheating of fuel using recovered heat	Generally applicable within the constraints associated with the boiler design and the need to control NO _x emissions																			

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	g.	Advanced control system	See description in Section 8.2. Computerised control of the main combustion parameters enables the combustion efficiency to be improved	Generally applicable to new units. The applicability to old units may be constrained by the need to retrofit the combustion system and/or control command system	reheater module within the HRSG. The plant also optimises steam turbine efficiency through operation at lower exhaust pressures by the additional street of fans on the ACC. d) Fans, pumps and motors have been overhauled to minimise losses, including the installation of variable speed drive ACC fans and feed water pumps. e) Pre-heating of combustion air in accordance with the BAT description, is not technically feasible for a CCGT. f) Fuel gas will be pre-heated using recovered heat. g) The site has an advanced control and monitoring system. This automated control system optimises combustion temperature and efficiency during running. There is also a PI system for high-performance monitoring. The DCS has been upgraded in the recent replant. h) not applicable - the plant is an existing unit. i - l) not applicable (site is not CHP) m,n) not applicable (site is not fitted with FGD) o,p) not applicable (site runs on natural gas) q,s) not applicable as it is an existing plant
h.	Feed-water preheating using recovered heat	Preheat water coming out of the steam condenser with recovered heat, before reusing it in the boiler	Only applicable to steam circuits and not to hot boilers. Applicability to existing units may be limited due to constraints associated with the plant configuration and the amount of recoverable heat		
i.	Heat recovery by cogeneration (CHP)	Recovery of heat (mainly from the steam system) for producing hot water/steam to be used in industrial processes/activities or in a public network for district heating. Additional heat recovery is possible from: — flue-gas — grate cooling — circulating fluidised bed	Applicable within the constraints associated with the local heat and power demand. The applicability may be limited in the case of gas compressors with an unpredictable operational heat profile		
j.	CHP readiness	See description in Section 8.2.	Only applicable to new units where there is a realistic potential for the future use of heat in the vicinity of the unit		
k.	Flue-gas condenser	See description in Section 8.2.	Generally applicable to CHP units provided there is enough demand for low-temperature heat		
l.	Heat accumulation	Heat accumulation storage in CHP mode	Only applicable to CHP plants. The applicability may be limited in the case of low heat load demand		
m.	Wet stack	See description in Section 8.2.	Generally applicable to new and existing units fitted with wet FGD		
n.	Cooling tower discharge	The release of emissions to air through a cooling tower and not via a dedicated stack	Only applicable to units fitted with wet FGD where reheating of the flue-gas is necessary before release, and where the unit cooling system is a cooling tower		
o.	Fuel pre-drying	The reduction of fuel moisture content before combustion to improve combustion conditions	Applicable to the combustion of biomass and/or peat within the constraints		

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	
				<p>associated with spontaneous combustion risks (e.g. the moisture content of peat is kept above 40 % throughout the delivery chain). The retrofit of existing plants may be restricted by the extra calorific value that can be obtained from the drying operation and by the limited retrofit possibilities offered by some boiler designs or plant configurations</p>		<p>r) Kings Lynn operates a high, intermediate and low pressure steam turbine, and the steam turbine has been overhauled and re-sealed to minimise losses.</p>
	p.	Minimisation of heat losses	Minimising residual heat losses, e.g. those that occur via the slag or those that can be reduced by insulating radiating sources	Only applicable to solid-fuel-fired combustion units and to gasification/IGCC units		
	q.	Advanced materials	Use of advanced materials proven to be capable of withstanding high operating temperatures and pressures and thus to achieve increased steam/combustion process efficiencies	Only applicable to new plants		
	r.	Steam turbine upgrades	This includes techniques such as increasing the temperature and pressure of medium-pressure steam, addition of a low-pressure turbine, and modifications to the geometry of the turbine rotor blades	The applicability may be restricted by demand, steam conditions and/or limited plant lifetime		
	s.	Supercritical and ultra-supercritical steam conditions	Use of a steam circuit, including steam reheating systems, in which steam can reach pressures above 220,6 bar and temperatures above 374 °C in the case of supercritical conditions, and above 250 – 300 bar and temperatures above 580 – 600 °C in the case of ultra-supercritical conditions	<p>Only applicable to new units of $\geq 600 \text{ MW}_{th}$ operated $> 4\,000 \text{ h/yr}$. Not applicable when the purpose of the unit is to produce low steam temperatures and/or pressures in process industries. Not applicable to gas turbines and engines generating steam in CHP mode. For units combusting biomass, the applicability may be constrained by high-temperature corrosion in the case of certain biomasses</p>		
13	In order to reduce water usage and the volume of contaminated waste water discharged, BAT is to use one or both of the techniques given below.			FC	Water from the steam cycle is recycled within the system through condensate capture. Water from the steam system, that cannot be	
	Technique	Description		Applicability		

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement						
	a. Water recycling	Residual aqueous streams, including run-off water, from the plant are reused for other purposes. The degree of recycling is limited by the quality requirements of the recipient water stream and the water balance of the plant	Not applicable to waste water from cooling systems when water treatment chemicals and/or high concentrations of salts from seawater are present		re-used in the steam cycle is captured in the clean drains tank, where it is re-processed in the water treatment plant, for re-use.						
	b. Dry bottom ash handling	Dry, hot bottom ash falls from the furnace onto a mechanical conveyor system and is cooled down by ambient air. No water is used in the process.	Only applicable to plants combusting solid fuels. There may be technical restrictions that prevent retrofitting to existing combustion plants								
14	<p>In order to prevent the contamination of uncontaminated waste water and to reduce emissions to water, BAT is to segregate waste water streams and to treat them separately, depending on the pollutant content.</p> <p>Description Waste water streams that are typically segregated and treated include surface run-off water, cooling water, and waste water from flue-gas treatment.</p> <p>Applicability The applicability may be restricted in the case of existing plants due to the configuration of the drainage systems.</p>			CC	Process water and surface water are segregated prior to discharge.						
15	<p>In order to reduce emissions to water from flue-gas treatment, BAT is to use an appropriate combination of the techniques given in BAT 15, and to use secondary techniques as close as possible to the source in order to avoid dilution.</p> <p>The BAT-AELs refer to direct discharges to a receiving water body at the point where the emission leaves the installation.</p>			NA	There is no flue gas treatment at this site.						
16	<p>In order to reduce the quantity of waste sent for disposal from the combustion and/or gasification process and abatement techniques, BAT is to organise operations so as to maximise, in order of priority and taking into account life-cycle thinking:</p> <ul style="list-style-type: none"> (a) waste prevention, e.g. maximise the proportion of residues which arise as by-products; (b) waste preparation for reuse, e.g. according to the specific requested quality criteria; (c) waste recycling; (d) other waste recovery (e.g. energy recovery), <p>by implementing an appropriate combination of techniques such as:</p> <table border="1" data-bbox="338 1334 1496 1375"> <thead> <tr> <th data-bbox="338 1334 584 1375">Technique</th> <th data-bbox="584 1334 1088 1375">Description</th> <th data-bbox="1088 1334 1496 1375">Applicability</th> </tr> </thead> <tbody> <tr> <td> </td> <td> </td> <td> </td> </tr> </tbody> </table>			Technique	Description	Applicability				CC	The waste hierarchy is implemented on site, and steps for waste reduction will be taken where applicable. None of the four techniques in the BAT are relevant to the site. The site uses a clean fuel source and no solid waste is generated from the natural gas.
Technique	Description	Applicability									

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	a.	Generation of gypsum as a by-product	Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g. as raw material in the plasterboard industry). The quality of limestone used in the wet FGD influences the purity of the gypsum produced	Generally applicable within the constraints associated with the required gypsum quality, the health requirements associated to each specific use, and by the market conditions	
	b.	Recycling or recovery of residues in the construction sector	Recycling or recovery of residues (e.g. from semi-dry desulphurisation processes, fly ash, bottom ash) as a construction material (e.g. in road building, to replace sand in concrete production, or in the cement industry)	Generally applicable within the constraints associated with the required material quality (e.g. physical properties, content of harmful substances) associated to each specific use, and by the market conditions	
	c.	Energy recovery by using waste in the fuel mix	The residual energy content of carbon-rich ash and sludges generated by the combustion of coal, lignite, heavy fuel oil, peat or biomass can be recovered for example by mixing with the fuel	Generally applicable where plants can accept waste in the fuel mix and are technically able to feed the fuels into the combustion chamber	
	d.	Preparation of spent catalyst for reuse	Preparation of catalyst for reuse (e.g. up to four times for SCR catalysts) restores some or all of the original performance, extending the service life of the catalyst to several decades. Preparation of spent catalyst for reuse is integrated in a catalyst management scheme	The applicability may be limited by the mechanical condition of the catalyst and the required performance with respect to controlling NO _x and NH ₃ emissions	
17	In order to reduce noise emissions, BAT is to use one or a combination of the techniques given below.			CC	Noise is reduced through operational measures including all those detailed in a). Where possible, low-noise equipment is utilised. High-noise equipment is contained within buildings and equipment insulation is used where applicable. The GT is enclosed within a building designed for noise attenuation and is fitted with silencers in the air intake, the HRSG is enclosed within a building which minimises noise emissions and the HRSG
	a.	Operational measures	These include: <ul style="list-style-type: none"> — improved inspection and maintenance of equipment — closing of doors and windows of enclosed areas, if possible — equipment operated by experienced staff — avoidance of noisy activities at night, if possible — provisions for noise control during maintenance activities 	Generally applicable	

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement											
	b.	Low-noise equipment	This potentially includes compressors, pumps and disks	Generally applicable when the equipment is new or replaced	exhaust stack is fitted with silencers.											
	c.	Noise attenuation	Noise propagation can be reduced by inserting obstacles between the emitter and the receiver. Appropriate obstacles include protection walls, embankments and buildings	Generally applicable to new plants. In the case of existing plants, the insertion of obstacles may be restricted by lack of space												
	d.	Noise-control equipment	This includes: — noise-reducers — equipment insulation — enclosure of noisy equipment — soundproofing of buildings	The applicability may be restricted by lack of space												
	e.	Appropriate location of equipment and buildings	Noise levels can be reduced by increasing the distance between the emitter and the receiver and by using buildings as noise screens	Generally applicable to new plant												
Combustion of gaseous fuels																
40	In order to increase the energy efficiency of natural gas combustion, BAT is to use an appropriate combination of the techniques given in BAT 12 and below.			FC	See IC11											
<table border="1"> <thead> <tr> <th data-bbox="322 979 510 1018">Technique</th> <th data-bbox="510 979 734 1018">Description</th> <th data-bbox="734 979 1509 1018">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 1018 510 1225">a. Combined cycle</td> <td data-bbox="510 1018 734 1225">See description in Section 8.2</td> <td data-bbox="734 1018 1509 1225">Generally applicable to new gas turbines and engines except when operated < 1 500 h/yr. Applicable to existing gas turbines and engines within the constraints associated with the steam cycle design and the space availability. Not applicable to existing gas turbines and engines operated < 1 500 h/yr. Not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns. Not applicable to boilers</td> </tr> </tbody> </table>						Technique	Description	Applicability	a. Combined cycle	See description in Section 8.2	Generally applicable to new gas turbines and engines except when operated < 1 500 h/yr. Applicable to existing gas turbines and engines within the constraints associated with the steam cycle design and the space availability. Not applicable to existing gas turbines and engines operated < 1 500 h/yr. Not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns. Not applicable to boilers					
Technique	Description	Applicability														
a. Combined cycle	See description in Section 8.2	Generally applicable to new gas turbines and engines except when operated < 1 500 h/yr. Applicable to existing gas turbines and engines within the constraints associated with the steam cycle design and the space availability. Not applicable to existing gas turbines and engines operated < 1 500 h/yr. Not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns. Not applicable to boilers														
BAT-associated energy efficiency levels (BAT-AEELs) for the combustion of natural gas																
<table border="1"> <thead> <tr> <th data-bbox="322 1257 607 1358" rowspan="2">Type of combustion unit</th> <th colspan="3" data-bbox="607 1257 1509 1289">BAT-AEELs ⁽¹³⁶⁾ ⁽¹³⁷⁾</th> </tr> <tr> <th data-bbox="607 1289 864 1358">Net electrical efficiency (%)</th> <th data-bbox="864 1289 1144 1358">Net total fuel utilisation (%) ⁽¹³⁸⁾ ⁽¹³⁹⁾</th> <th data-bbox="1144 1289 1509 1358">Net mechanical energy efficiency (%) ⁽¹³⁹⁾ ⁽¹⁴⁰⁾</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 1358 607 1358"></td> <td data-bbox="607 1358 864 1358"></td> <td data-bbox="864 1358 1144 1358"></td> <td data-bbox="1144 1358 1509 1358"></td> </tr> </tbody> </table>						Type of combustion unit	BAT-AEELs ⁽¹³⁶⁾ ⁽¹³⁷⁾			Net electrical efficiency (%)	Net total fuel utilisation (%) ⁽¹³⁸⁾ ⁽¹³⁹⁾	Net mechanical energy efficiency (%) ⁽¹³⁹⁾ ⁽¹⁴⁰⁾				
Type of combustion unit	BAT-AEELs ⁽¹³⁶⁾ ⁽¹³⁷⁾															
	Net electrical efficiency (%)	Net total fuel utilisation (%) ⁽¹³⁸⁾ ⁽¹³⁹⁾	Net mechanical energy efficiency (%) ⁽¹³⁹⁾ ⁽¹⁴⁰⁾													

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																																																						
	<table border="1"> <thead> <tr> <th></th> <th>New unit</th> <th>Existing unit</th> <th></th> <th>New unit</th> <th>Existing unit</th> </tr> </thead> <tbody> <tr> <td>Gas engine</td> <td>39,5–44 ⁽¹⁴¹⁾</td> <td>35–44 ⁽¹⁴¹⁾</td> <td>56–85 ⁽¹⁴¹⁾</td> <td colspan="2">No BAT-AEEL.</td> </tr> <tr> <td>Gas-fired boiler</td> <td>39–42,5</td> <td>38–40</td> <td>78–95</td> <td colspan="2">No BAT-AEEL.</td> </tr> <tr> <td>Open cycle gas turbine, ≥ 50 MW_{th}</td> <td>36–41,5</td> <td>33–41,5</td> <td>No BAT-AEEL</td> <td>36,5–41</td> <td>33,5–41</td> </tr> <tr> <td colspan="6" style="text-align: center;">Combined cycle gas turbine (CCGT)</td> </tr> <tr> <td>CCGT, 50–600 MW_{th}</td> <td>53–58,5</td> <td>46–54</td> <td>No BAT-AEEL</td> <td colspan="2">No BAT-AEEL</td> </tr> <tr> <td>CCGT, ≥ 600 MW_{th}</td> <td>57–60,5</td> <td>50–60</td> <td>No BAT-AEEL</td> <td colspan="2">No BAT-AEEL</td> </tr> <tr> <td>CHP CCGT, 50–600 MW_{th}</td> <td>53–58,5</td> <td>46–54</td> <td>65–95</td> <td colspan="2">No BAT-AEEL</td> </tr> <tr> <td>CHP CCGT, ≥ 600 MW_{th}</td> <td>57–60,5</td> <td>50–60</td> <td>65–95</td> <td colspan="2">No BAT-AEEL</td> </tr> </tbody> </table>		New unit	Existing unit		New unit	Existing unit	Gas engine	39,5–44 ⁽¹⁴¹⁾	35–44 ⁽¹⁴¹⁾	56–85 ⁽¹⁴¹⁾	No BAT-AEEL.		Gas-fired boiler	39–42,5	38–40	78–95	No BAT-AEEL.		Open cycle gas turbine, ≥ 50 MW _{th}	36–41,5	33–41,5	No BAT-AEEL	36,5–41	33,5–41	Combined cycle gas turbine (CCGT)						CCGT, 50–600 MW _{th}	53–58,5	46–54	No BAT-AEEL	No BAT-AEEL		CCGT, ≥ 600 MW _{th}	57–60,5	50–60	No BAT-AEEL	No BAT-AEEL		CHP CCGT, 50–600 MW _{th}	53–58,5	46–54	65–95	No BAT-AEEL		CHP CCGT, ≥ 600 MW _{th}	57–60,5	50–60	65–95	No BAT-AEEL			
	New unit	Existing unit		New unit	Existing unit																																																				
Gas engine	39,5–44 ⁽¹⁴¹⁾	35–44 ⁽¹⁴¹⁾	56–85 ⁽¹⁴¹⁾	No BAT-AEEL.																																																					
Gas-fired boiler	39–42,5	38–40	78–95	No BAT-AEEL.																																																					
Open cycle gas turbine, ≥ 50 MW _{th}	36–41,5	33–41,5	No BAT-AEEL	36,5–41	33,5–41																																																				
Combined cycle gas turbine (CCGT)																																																									
CCGT, 50–600 MW _{th}	53–58,5	46–54	No BAT-AEEL	No BAT-AEEL																																																					
CCGT, ≥ 600 MW _{th}	57–60,5	50–60	No BAT-AEEL	No BAT-AEEL																																																					
CHP CCGT, 50–600 MW _{th}	53–58,5	46–54	65–95	No BAT-AEEL																																																					
CHP CCGT, ≥ 600 MW _{th}	57–60,5	50–60	65–95	No BAT-AEEL																																																					
41	In order to prevent or reduce NO _x emissions to air from the combustion of natural gas in boilers, BAT is to use one or a combination of the techniques given in BAT 41.	NA	As this is not a boiler																																																						
42	<p>In order to prevent or reduce NO_x emissions to air from the combustion of natural gas in gas turbines, BAT is to use one or a combination of the techniques given below.</p> <table border="1"> <thead> <tr> <th>Technique</th> <th>Description</th> <th>Applicability</th> </tr> </thead> <tbody> <tr> <td>a. Advanced control system</td> <td>See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr</td> <td>The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> <tr> <td>b. Water/steam addition</td> <td rowspan="2">See description in Section 8.3</td> <td>The applicability may be limited due to water availability</td> </tr> <tr> <td>c. Dry low-NO_x burners (DLN)</td> <td>The applicability may be limited in the case of turbines where a retrofit package is not available or when water/steam addition systems are installed</td> </tr> <tr> <td>d. Low-load design concept</td> <td>Adaptation of the process control and related equipment to maintain good combustion efficiency when the demand in energy varies, e.g. by improving the inlet</td> <td>The applicability may be limited by the gas turbine design</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system	b. Water/steam addition	See description in Section 8.3	The applicability may be limited due to water availability	c. Dry low-NO _x burners (DLN)	The applicability may be limited in the case of turbines where a retrofit package is not available or when water/steam addition systems are installed	d. Low-load design concept	Adaptation of the process control and related equipment to maintain good combustion efficiency when the demand in energy varies, e.g. by improving the inlet	The applicability may be limited by the gas turbine design	FC	<p>Technique a and c to be employed on site.</p> <p>From table 24: As an existing CCGT plant >600MW_{th} and a net fuel utilisation of <75% the annual limit for NO_x would be 40mg/Nm³, and the daily limit would be 50mg/Nm³. However footnote 8 to the table states "For plants with a net electrical efficiency (EE) greater than 55 %, a correction factor may be applied to the higher end of the BAT-AEL range, corresponding to [higher end] × EE/55, where EE is the net electrical efficiency of the plant determined at ISO baseload</p>																																								
Technique	Description	Applicability																																																							
a. Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system																																																							
b. Water/steam addition	See description in Section 8.3	The applicability may be limited due to water availability																																																							
c. Dry low-NO _x burners (DLN)		The applicability may be limited in the case of turbines where a retrofit package is not available or when water/steam addition systems are installed																																																							
d. Low-load design concept	Adaptation of the process control and related equipment to maintain good combustion efficiency when the demand in energy varies, e.g. by improving the inlet	The applicability may be limited by the gas turbine design																																																							

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement										
	<table border="1"> <tr> <td data-bbox="338 384 371 440"></td> <td data-bbox="371 384 551 440"></td> <td data-bbox="551 384 1099 440">airflow control capability or by splitting the combustion process into decoupled combustion stages</td> <td data-bbox="1099 384 1496 440"></td> </tr> <tr> <td data-bbox="338 440 371 576">e.</td> <td data-bbox="371 440 551 576">Low-NO_x burners (LNB)</td> <td data-bbox="551 440 1099 576" rowspan="2">See description in Section 8.3</td> <td data-bbox="1099 440 1496 576">Generally applicable to supplementary firing for heat recovery steam generators (HRSGs) in the case of combined-cycle gas turbine (CCGT) combustion plants</td> </tr> <tr> <td data-bbox="338 576 371 858">f.</td> <td data-bbox="371 576 551 858">Selective catalytic reduction (SCR)</td> <td data-bbox="1099 576 1496 858">Not applicable in the case of combustion plants operated < 500 h/yr. Not generally applicable to existing combustion plants of < 100 MW_{th}. Retrofitting existing combustion plants may be constrained by the availability of sufficient space. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr</td> </tr> </table>			airflow control capability or by splitting the combustion process into decoupled combustion stages		e.	Low-NO _x burners (LNB)	See description in Section 8.3	Generally applicable to supplementary firing for heat recovery steam generators (HRSGs) in the case of combined-cycle gas turbine (CCGT) combustion plants	f.	Selective catalytic reduction (SCR)	Not applicable in the case of combustion plants operated < 500 h/yr. Not generally applicable to existing combustion plants of < 100 MW _{th} . Retrofitting existing combustion plants may be constrained by the availability of sufficient space. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr			<p>conditions." it is expected that the net electrical efficiency will be greater than 55% as indicated in the response to BAT 2 above. Therefore the applicable BAT-AELs cannot be determined until after commissioning has been completed and the actual energy efficiency determined. it is proposed that the EA will be informed of the results of the performance test once completed. The site has undergone a replant and will be entering commissioning shortly. The daily average NO_x is designed to be compliant, but no equivalent emission guarantees are available related to yearly average NO_x emission concentrations and the site will acquire actual plant data once operational. The yearly average and the load point at which dry low NO_x becomes effective will be determined once commissioning has been completed. It is proposed that the EA will be updated on these matters once data is available. See IC11</p>
		airflow control capability or by splitting the combustion process into decoupled combustion stages													
e.	Low-NO _x burners (LNB)	See description in Section 8.3	Generally applicable to supplementary firing for heat recovery steam generators (HRSGs) in the case of combined-cycle gas turbine (CCGT) combustion plants												
f.	Selective catalytic reduction (SCR)		Not applicable in the case of combustion plants operated < 500 h/yr. Not generally applicable to existing combustion plants of < 100 MW _{th} . Retrofitting existing combustion plants may be constrained by the availability of sufficient space. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr												
43	In order to prevent or reduce NO _x emissions to air from the combustion of natural gas in engines, BAT is to use one or a combination of the techniques given in BAT 43.			NA	This is not an engine										
44	In order to prevent or reduce CO emissions to air from the combustion of natural gas, BAT is to ensure optimised combustion and/or to use oxidation catalysts. Description - See descriptions in Section 8.3.			FC	CO is a product of incomplete combustion. Due to the site being a CCGT, the CO levels are										

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																																																						
	<p>BAT-associated emission levels (BAT-AELs) for NO_x emissions to air from the combustion of natural gas in gas turbines</p> <table border="1" data-bbox="338 440 1494 1251"> <thead> <tr> <th data-bbox="338 440 797 560" rowspan="2">Type of combustion plant</th> <th data-bbox="797 440 1032 560" rowspan="2">Combustion plant total rated thermal input (MW_{th})</th> <th colspan="2" data-bbox="1032 440 1494 475">BAT-AELs (mg/Nm³) ⁽¹⁴²⁾ ⁽¹⁴³⁾</th> </tr> <tr> <th data-bbox="1032 475 1256 560">Yearly average ⁽¹⁴⁴⁾ ⁽¹⁴⁵⁾</th> <th data-bbox="1256 475 1494 560">Daily average or average over the sampling period</th> </tr> </thead> <tbody> <tr> <td colspan="4" data-bbox="338 560 1494 600" style="text-align: center;">Open-cycle gas turbines (OCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁷⁾</td> </tr> <tr> <td data-bbox="338 600 797 639">New OCGT</td> <td data-bbox="797 600 1032 639">≥ 50</td> <td data-bbox="1032 600 1256 639">15–35</td> <td data-bbox="1256 600 1494 639">25–50</td> </tr> <tr> <td data-bbox="338 639 797 722">Existing OCGT (excluding turbines for mechanical drive applications) — All but plants operated < 500 h/yr</td> <td data-bbox="797 639 1032 722">≥ 50</td> <td data-bbox="1032 639 1256 722">15–50</td> <td data-bbox="1256 639 1494 722">25–55 ⁽¹⁴⁸⁾</td> </tr> <tr> <td colspan="4" data-bbox="338 722 1494 762" style="text-align: center;">Combined-cycle gas turbines (CCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁹⁾</td> </tr> <tr> <td data-bbox="338 762 797 802">New CCGT</td> <td data-bbox="797 762 1032 802">≥ 50</td> <td data-bbox="1032 762 1256 802">10–30</td> <td data-bbox="1256 762 1494 802">15–40</td> </tr> <tr> <td data-bbox="338 802 797 858">Existing CCGT with a net total fuel utilisation of < 75 %</td> <td data-bbox="797 802 1032 858">≥ 600</td> <td data-bbox="1032 802 1256 858">10–40</td> <td data-bbox="1256 802 1494 858">18–50</td> </tr> <tr> <td data-bbox="338 858 797 914">Existing CCGT with a net total fuel utilisation of ≥ 75 %</td> <td data-bbox="797 858 1032 914">≥ 600</td> <td data-bbox="1032 858 1256 914">10–50</td> <td data-bbox="1256 858 1494 914">18–55 ⁽¹⁵⁰⁾</td> </tr> <tr> <td data-bbox="338 914 797 970">Existing CCGT with a net total fuel utilisation of < 75 %</td> <td data-bbox="797 914 1032 970">50–600</td> <td data-bbox="1032 914 1256 970">10–45</td> <td data-bbox="1256 914 1494 970">35–55</td> </tr> <tr> <td data-bbox="338 970 797 1037">Existing CCGT with a net total fuel utilisation of ≥ 75 %</td> <td data-bbox="797 970 1032 1037">50–600</td> <td data-bbox="1032 970 1256 1037">25–50 ⁽¹⁵¹⁾</td> <td data-bbox="1256 970 1494 1037">35–55 ⁽¹⁵²⁾</td> </tr> <tr> <td colspan="4" data-bbox="338 1037 1494 1077" style="text-align: center;">Open- and combined-cycle gas turbines</td> </tr> <tr> <td data-bbox="338 1077 797 1166">Gas turbine put into operation no later than 27 November 2003, or existing gas turbine for emergency use and operated < 500 h/yr</td> <td data-bbox="797 1077 1032 1166">≥ 50</td> <td data-bbox="1032 1077 1256 1166">No BAT-AEL</td> <td data-bbox="1256 1077 1494 1166">60–140 ⁽¹⁵³⁾ ⁽¹⁵⁴⁾</td> </tr> <tr> <td data-bbox="338 1166 797 1251">Existing gas turbine for mechanical drive applications — All but plants operated < 500 h/yr</td> <td data-bbox="797 1166 1032 1251">≥ 50</td> <td data-bbox="1032 1166 1256 1251">15–50 ⁽¹⁵⁵⁾</td> <td data-bbox="1256 1166 1494 1251">25–55 ⁽¹⁵⁶⁾</td> </tr> </tbody> </table> <p data-bbox="338 1251 1494 1315">As an indication, the yearly average CO emission levels for each type of existing combustion plant operated ≥ 1 500 h/yr and for each type of new combustion plant will generally be as follows:</p>	Type of combustion plant	Combustion plant total rated thermal input (MW _{th})	BAT-AELs (mg/Nm ³) ⁽¹⁴²⁾ ⁽¹⁴³⁾		Yearly average ⁽¹⁴⁴⁾ ⁽¹⁴⁵⁾	Daily average or average over the sampling period	Open-cycle gas turbines (OCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁷⁾				New OCGT	≥ 50	15–35	25–50	Existing OCGT (excluding turbines for mechanical drive applications) — All but plants operated < 500 h/yr	≥ 50	15–50	25–55 ⁽¹⁴⁸⁾	Combined-cycle gas turbines (CCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁹⁾				New CCGT	≥ 50	10–30	15–40	Existing CCGT with a net total fuel utilisation of < 75 %	≥ 600	10–40	18–50	Existing CCGT with a net total fuel utilisation of ≥ 75 %	≥ 600	10–50	18–55 ⁽¹⁵⁰⁾	Existing CCGT with a net total fuel utilisation of < 75 %	50–600	10–45	35–55	Existing CCGT with a net total fuel utilisation of ≥ 75 %	50–600	25–50 ⁽¹⁵¹⁾	35–55 ⁽¹⁵²⁾	Open- and combined-cycle gas turbines				Gas turbine put into operation no later than 27 November 2003, or existing gas turbine for emergency use and operated < 500 h/yr	≥ 50	No BAT-AEL	60–140 ⁽¹⁵³⁾ ⁽¹⁵⁴⁾	Existing gas turbine for mechanical drive applications — All but plants operated < 500 h/yr	≥ 50	15–50 ⁽¹⁵⁵⁾	25–55 ⁽¹⁵⁶⁾		<p>expected to be low and within the BAT-AEL. However the site will acquire actual plant data after the completion of commissioning and the yearly average CO will be confirmed to the EA once the site is operational. See IC11.</p>
Type of combustion plant	Combustion plant total rated thermal input (MW _{th})			BAT-AELs (mg/Nm ³) ⁽¹⁴²⁾ ⁽¹⁴³⁾																																																					
		Yearly average ⁽¹⁴⁴⁾ ⁽¹⁴⁵⁾	Daily average or average over the sampling period																																																						
Open-cycle gas turbines (OCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁷⁾																																																									
New OCGT	≥ 50	15–35	25–50																																																						
Existing OCGT (excluding turbines for mechanical drive applications) — All but plants operated < 500 h/yr	≥ 50	15–50	25–55 ⁽¹⁴⁸⁾																																																						
Combined-cycle gas turbines (CCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁹⁾																																																									
New CCGT	≥ 50	10–30	15–40																																																						
Existing CCGT with a net total fuel utilisation of < 75 %	≥ 600	10–40	18–50																																																						
Existing CCGT with a net total fuel utilisation of ≥ 75 %	≥ 600	10–50	18–55 ⁽¹⁵⁰⁾																																																						
Existing CCGT with a net total fuel utilisation of < 75 %	50–600	10–45	35–55																																																						
Existing CCGT with a net total fuel utilisation of ≥ 75 %	50–600	25–50 ⁽¹⁵¹⁾	35–55 ⁽¹⁵²⁾																																																						
Open- and combined-cycle gas turbines																																																									
Gas turbine put into operation no later than 27 November 2003, or existing gas turbine for emergency use and operated < 500 h/yr	≥ 50	No BAT-AEL	60–140 ⁽¹⁵³⁾ ⁽¹⁵⁴⁾																																																						
Existing gas turbine for mechanical drive applications — All but plants operated < 500 h/yr	≥ 50	15–50 ⁽¹⁵⁵⁾	25–55 ⁽¹⁵⁶⁾																																																						

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																							
	<p>— New OCGT of $\geq 50 \text{ MW}_{th}$: $< 5\text{--}40 \text{ mg/Nm}^3$. For plants with a net electrical efficiency (EE) greater than 39 %, a correction factor may be applied to the higher end of this range, corresponding to [higher end] \times EE/39, where EE is the net electrical energy efficiency or net mechanical energy efficiency of the plant determined at ISO baseload conditions.</p> <p>— Existing OCGT of $\geq 50 \text{ MW}_{th}$ (excluding turbines for mechanical drive applications): $< 5\text{--}40 \text{ mg/Nm}^3$. The higher end of this range will generally be 80 mg/Nm^3 in the case of existing plants that cannot be fitted with dry techniques for NO_x reduction, or 50 mg/Nm^3 for plants that operate at low load.</p> <p>— New CCGT of $\geq 50 \text{ MW}_{th}$: $< 5\text{--}30 \text{ mg/Nm}^3$. For plants with a net electrical efficiency (EE) greater than 55 %, a correction factor may be applied to the higher end of the range, corresponding to [higher end] \times EE/55, where EE is the net electrical energy efficiency of the plant determined at ISO baseload conditions.</p> <p>— Existing CCGT of $\geq 50 \text{ MW}_{th}$: $< 5\text{--}30 \text{ mg/Nm}^3$. The higher end of this range will generally be 50 mg/Nm^3 for plants that operate at low load.</p> <p>— Existing gas turbines of $\geq 50 \text{ MW}_{th}$ for mechanical drive applications: $< 5\text{--}40 \text{ mg/Nm}^3$. The higher end of the range will generally be 50 mg/Nm^3 when plants operate at low load.</p> <p>In the case of a gas turbine equipped with DLN burners, these indicative levels correspond to when the DLN operation is effective.</p> <p>BAT-associated emission levels (BAT-AELs) for NO_x emissions to air from the combustion of natural gas in boilers and engines</p> <table border="1" data-bbox="338 874 1494 1098"> <thead> <tr> <th rowspan="3">Type of combustion plant</th> <th colspan="4">BAT-AELs (mg/Nm^3)</th> </tr> <tr> <th colspan="2">Yearly average ⁽¹⁵⁷⁾</th> <th colspan="2">Daily average or average over the sampling period</th> </tr> <tr> <th>New plant</th> <th>Existing plant ⁽¹⁵⁸⁾</th> <th>New plant</th> <th>Existing plant ⁽¹⁵⁹⁾</th> </tr> </thead> <tbody> <tr> <td>Boiler</td> <td>10–60</td> <td>50–100</td> <td>30–85</td> <td>85–110</td> </tr> <tr> <td>Engine ⁽¹⁶⁰⁾</td> <td>20–75</td> <td>20–100</td> <td>55–85</td> <td>55–110 ⁽¹⁶¹⁾</td> </tr> </tbody> </table> <p>As an indication, the yearly average CO emission levels will generally be:</p> <ul style="list-style-type: none"> — $< 5\text{--}40 \text{ mg/Nm}^3$ for existing boilers operated $\geq 1\,500 \text{ h/yr}$, — $< 5\text{--}15 \text{ mg/Nm}^3$ for new boilers, — $30\text{--}100 \text{ mg/Nm}^3$ for existing engines operated $\geq 1\,500 \text{ h/yr}$ and for new engines. 	Type of combustion plant	BAT-AELs (mg/Nm^3)				Yearly average ⁽¹⁵⁷⁾		Daily average or average over the sampling period		New plant	Existing plant ⁽¹⁵⁸⁾	New plant	Existing plant ⁽¹⁵⁹⁾	Boiler	10–60	50–100	30–85	85–110	Engine ⁽¹⁶⁰⁾	20–75	20–100	55–85	55–110 ⁽¹⁶¹⁾		
Type of combustion plant	BAT-AELs (mg/Nm^3)																									
	Yearly average ⁽¹⁵⁷⁾		Daily average or average over the sampling period																							
	New plant	Existing plant ⁽¹⁵⁸⁾	New plant	Existing plant ⁽¹⁵⁹⁾																						
Boiler	10–60	50–100	30–85	85–110																						
Engine ⁽¹⁶⁰⁾	20–75	20–100	55–85	55–110 ⁽¹⁶¹⁾																						

6. Emissions to Water

The consolidated permit incorporates one ten current discharges to controlled waters identified as W1.

There are no BAT AELs specified in the BAT Conclusions for this type of plant. There are also no additional treatment options identified as BAT for the installation. We have therefore not carried out any additional assessment of the emissions to water as part of this review.

7 Review and assessment of changes that are not part of the BAT Conclusions derived permit review.

This document should be read in conjunction with the application, supporting information and notice.

Aspect considered	Decision
Receipt of application	
Confidential information	A claim for commercial or industrial confidentiality has not been made.
Identifying confidential information	We have not identified information provided as part of the application that we consider to be confidential. The decision was taken in accordance with our guidance on confidentiality.
The site	
Biodiversity, heritage, landscape and nature conservation	<p>The application is within the relevant distance criteria of a site of heritage, landscape or nature conservation, and/or protected species or habitat.</p> <p>A full assessment of the application and its potential to affect the site(s)/species/habitat has not been carried out as part of the permit review process. We consider that the review will not affect the features of the site(s)/species/habitat as the conditions will provide at least the same level of protection as those in the previous permit and in some cases will provide a higher level of protection to those in the previous permit.</p> <p>We have not consulted Natural England on the application. The decision was taken in accordance with our guidance.</p>
Operating techniques	

Aspect considered	Decision
General operating techniques	<p>We have reviewed the techniques used by the operator where they are relevant to the BAT Conclusions and compared these with the relevant guidance notes.</p> <p>The permit conditions ensure compliance with the relevant BREF, BAT Conclusions. The ELVs deliver compliance with the BAT-AELs.</p>
Permit conditions	
Updating permit conditions during consolidation	<p>We have updated permit conditions to those in the current generic permit template as part of permit consolidation. The conditions will provide at least the same level of protection as those in the previous permit and in some cases will provide a higher level of protection to those in the previous permit.</p>
Changes to the permit conditions due to an Environment Agency initiated variation	<p>We have varied the permit as stated in the variation notice.</p>
Improvement programme	<p>Based on the information on the application, we consider that we need to impose an improvement programme.</p> <p>We have imposed an improvement programme to ensure that: BAT conclusions 2,40,42 and 44 are met. See Key issues.</p> <p>We have also marked all completed improvement conditions as complete in the permit. IC11 is ongoing and 12,13 and 14 have been added for BAT conclusion compliance.</p>
Emission limits	<p>We have decided that emission limits should be set for the parameters listed in the permit.</p> <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p> <p>It is considered that the ELVs/equivalent parameters or technical measures described above will ensure that significant pollution of the environment is prevented and a high level of protection for the environment is secured.</p>
Monitoring	<p>We have decided that monitoring should be carried out for the parameters listed in the permit, using the methods detailed and to the frequencies specified.</p> <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p> <p>Table S3.5 Process monitoring requirements was amended to include the requirement to monitor energy efficiency after overhauls on site in line with BAT2.</p>

Aspect considered	Decision
	Based on the information in the application we are [not fully] satisfied that the operator's techniques, personnel and equipment have either MCERTS certification or MCERTS accreditation as appropriate.
Reporting	<p>We have specified reporting in the permit for the following parameters:</p> <ul style="list-style-type: none"> • Nitrogen dioxide • Carbon monoxide • Sulphur dioxide • Dust <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p>
Operator competence	
Management system	There is no known reason to consider that the operator will not have the management system to enable it to comply with the permit conditions.
Growth Duty	
Section 108 Deregulation Act 2015 – Growth duty	<p>We have considered our duty to have regard to the desirability of promoting economic growth set out in section 108(1) of the Deregulation Act 2015 and the guidance issued under section 110 of that Act in deciding whether to grant this permit.</p> <p>Paragraph 1.3 of the guidance says:</p> <p>“The primary role of regulators, in delivering regulation, is to achieve the regulatory outcomes for which they are responsible. For a number of regulators, these regulatory outcomes include an explicit reference to development or growth. The growth duty establishes economic growth as a factor that all specified regulators should have regard to, alongside the delivery of the protections set out in the relevant legislation.”</p> <p>We have addressed the legislative requirements and environmental standards to be set for this operation in the body of the decision document above. The guidance is clear at paragraph 1.5 that the growth duty does not legitimise non-compliance and its purpose is not to achieve or pursue economic growth at the expense of necessary protections.</p> <p>We consider the requirements and standards we have set in this permit are reasonable and necessary to avoid a risk of an unacceptable level of pollution. This also promotes growth amongst legitimate operators because the standards applied to the operator are consistent across businesses in this sector and have been set to achieve the required legislative standards.</p>