

# Determination of an Application for an Environmental Permit under the Environmental Permitting (England & Wales) Regulations 2016

## Decision document recording our decision-making process

The Permit Number is:                   EPR/CP3836QX/A001  
The Applicant / Operator is:           High Energy Fuels Limited  
The Installation is located at:        Bloomfield Road Pyrolysis Plant  
  Bloomfield Road,  
  Tipton, DY4 9BS

## What this document is about

This is a decision document, which accompanies a permit.

It explains how we have considered the Applicant's Application, and why we have included the specific conditions in the permit we are issuing to the Applicant. It is our record of our decision-making process, to show how we have taken into account all relevant factors in reaching our position. Unless the document explains otherwise, we have accepted the Applicant's proposals.

We try to explain our decision as accurately, comprehensively and plainly as possible. Achieving all three objectives is not always easy, and we would welcome any feedback as to how we might improve our decision documents in future. A lot of technical terms and acronyms are inevitable in a document of this nature: we provide a glossary of acronyms near the front of the document, for ease of reference.

## Preliminary information and use of terms

We gave the application the reference number EPR/CP3836QX/A001. We refer to the application as "the **Application**" in this document in order to be consistent. The number we have given to the permit is EPR/CP3836QX. We refer to the permit as "the **Permit**" in this document.

The Application was duly made on 21 December 2018.

The Applicant is High Energy Fuels Limited. We refer to High Energy Fuels Limited as "the **Applicant**" in this document. Where we are talking about what would happen after the Permit is granted (if that is our final decision), we call High Energy Fuels Limited "the **Operator**".

High Energy Fuels Limited's proposed facility is located at Bloomfield Road Pyrolysis Plant, Bloomfield Road, Tipton, DY4 9BS. We refer to this as "the **Installation**" in this document.

## How this document is structured

- Glossary of acronyms
- Our proposed decision
- How we reached our decision
- The legal framework
- The Installation
  - Description of the Installation and general issues
  - The site and its protection
  - Operation of the Installation – general issues
- Minimising the installation's environmental impact
  - Assessment Methodology
  - Air Quality Assessment
  - Human health risk assessment
  - Impact on Habitats sites, SSSIs, non-statutory conservation sites
  - Impact of abnormal operations
- Application of Best Available Techniques
  - Scope of Consideration
  - BAT and emissions control
  - BAT and global warming potential
  - BAT and POPs
  - Other Emissions to the Environment
  - Setting ELVs and other Permit conditions
  - Monitoring
  - Reporting
- Other legal requirements
  - The EPR 2016 and related Directives
  - National primary legislation
  - National secondary legislation
  - Other relevant legal requirements
- Annexes
  - Application of the Industrial Emissions Directive
  - Pre-Operational Conditions
  - Improvement Conditions
  - Consultation Responses

## Glossary of acronyms used in this document

(Please note that this glossary is standard for our decision documents and therefore not all these acronyms are necessarily used in this document.)

AAD	Ambient Air Directive (2008/50/EC)
APC	Air Pollution Control
AQS	Air Quality Strategy
BAT	Best Available Technique(s)
BAT-AEL	BAT Associated Emission Level
BREF	Best Available Techniques (BAT) Reference Documents for Waste Incineration
BAT C	BAT conclusions
CEM	Continuous emissions monitor
CFD	Computerised fluid dynamics
CHP	Combined heat and power
COMEAP	Committee on the Medical Effects of Air Pollutants
CROW	Countryside and rights of way Act 2000
CV	Calorific value
EAL	Environmental assessment level
ELV	Emission limit value
EMS	Environmental Management System
EPR	Environmental Permitting (England and Wales) Regulations 2016 (SI 2016 No. 1154) as amended
ES	Environmental standard
EWC	European waste catalogue
FGC	Flue gas cleaning
FSA	Food Standards Agency
GWP	Global Warming Potential
HHRAP	Human Health Risk Assessment Protocol
HPA	Health Protection Agency (now PHE – Public Health England)
IBA	Incinerator Bottom Ash
IED	Industrial Emissions Directive (2010/75/EU)
I-TEF	Toxic Equivalent Factors set out in Annex VI Part 2 of IED
I-TEQ	Toxic Equivalent Quotient calculated using I-TEF
LCV	Lower calorific value – also termed net calorific value
LOI	Loss on Ignition

MSW	Municipal Solid Waste
MWI	Municipal waste incinerator
NOx	Oxides of nitrogen (NO plus NO <sub>2</sub> expressed as NO <sub>2</sub> )
OTNOC	Other than normal operating conditions
PAH	Polycyclic aromatic hydrocarbons
PC	Process Contribution
PCB	Polychlorinated biphenyls
PEC	Predicted Environmental Concentration
PHE	Public Health England
POP(s)	Persistent organic pollutant(s)
PPS	Public participation statement
PXDD	Poly-halogenated di-benzo-p-dioxins
PXB	Poly-halogenated biphenyls
PXDF	Poly-halogenated di-benzo furans
RDF	Refuse derived fuel
RGS	Regulatory Guidance Series
SAC	Special Area of Conservation
SCR	Selective catalytic reduction
SGN	Sector guidance note
SNCR	Selective non-catalytic reduction
SPA(s)	Special Protection Area(s)
SSSI(s)	Site(s) of Special Scientific Interest
TWI	Tolerable weekly intake
TEF	Toxic Equivalent Factors
TGN	Technical guidance note
TOC	Total Organic Carbon
UHV	Upper heating value –also termed gross calorific value
US EPA	United States Environmental Protection Agency
WFD	Waste Framework Directive (2008/98/EC)
WHO	World Health Organisation
WID	Waste Incineration Directive (2000/76/EC) – now superseded by IED

# 1 Our decision

We have decided to grant the Permit to the Applicant. This will allow it to operate the Installation, subject to the conditions in the Permit.

We consider that, in reaching that decision, we have taken into account all relevant considerations and legal requirements and that the permit will ensure that a high level of protection is provided for the environment and human health.

This Application is to operate an installation which is subject principally to the Industrial Emissions Directive (IED).

The Permit contains many conditions taken from our standard Environmental Permit template including the relevant Annexes. We developed these conditions in consultation with industry, having regard to the legal requirements of the Environmental Permitting Regulations and other relevant legislation. This document does not therefore include an explanation for these standard conditions. Where they are included in the permit, we have considered the Application and accepted the details are sufficient and satisfactory to make the standard condition appropriate. This document does, however, provide an explanation of our use of “tailor-made” or installation-specific conditions, or where our Permit template provides two or more options.

## 2 How we reached our decision

### 2.1 Receipt of Application

The Application was duly made on 21 December 2018. This means we considered it was in the correct form and contained sufficient information for us to begin our determination but not that it necessarily contained all the information we would need to complete that determination: see below.

The Applicant claimed that certain information was commercially confidential and should be withheld from the public register. We considered this request and determined that: the information was not commercially confidential. Apart from the issues and information just described, we have not received any information in relation to the Application that appears to be confidential in relation to any party.

### 2.2 Consultation on the Application

We carried out consultation on the Application in accordance with the EPR, our statutory PPS and our own internal guidance RGS Note 6 for Determinations involving Sites of High Public Interest. We consider that this process satisfies, and frequently goes beyond the requirements of the Aarhus Convention on Access to Information, Public Participation in Decision-Making and Access to Justice in Environmental Matters, which are directly incorporated into the IED, which applies to the Installation and the Application. We have also taken into account our obligations under the Local Democracy,

Economic Development and Construction Act 2009 (particularly Section 23). This requires us, where we consider it appropriate, to take such steps as we consider appropriate to secure the involvement of representatives of interested persons in the exercise of our functions, by providing them with information, consulting them or involving them in any other way. In this case, our consultation already satisfies the Act's requirements.

We advertised the Application by a notice placed on our website, which contained all the information required by the IED, including telling people where and when they could see a copy of the Application.

We made a copy of the Application and all other documents relevant to our determination (see below) available to view on our Public Register at Environment Agency, Sentential House, 9 Wellington Crescent, Fradley Park, Lichfield, Staffordshire, WS13 8RR. Anyone wishing to see these documents could do so and arrange for copies to be made.

We sent copies of the Application to the following bodies, which includes those with whom we have "Working Together Agreements":

- Public Health England
- The Food Standards Agency
- The Health and Safety Executive
- Environmental Health – Dudley Council
- Local Planning Authority – Dudley Council
- West Midlands Fire and Rescue Service

These are bodies whose expertise, democratic accountability and/or local knowledge make it appropriate for us to seek their views directly. Note under our Working Together Agreement with Natural England, we only inform Natural England of the results of our assessment of the impact of the installation on designated Habitats sites.

Further details along with a summary of consultation comments and our response to the representations we received can be found in Annex 4. We have taken all relevant representations into consideration in reaching our determination.

### 2.3 Requests for Further Information

Although we were able to consider the Application duly made, we did in fact need more information in order to determine it, and issued information notices on 18 June 2019, 19 August 2019 and 09 October 2019. A copy of each information notice was placed on our public register.

In addition to our information notices, we received additional information during the determination from the Applicant on 3 May 2019, 13 May 2019, 20 November 2019 and 15 January 2020. We made a copy of this information available to the public in the same way as the responses to our information notices.

The information received on 3 May 2019 and 13 May 2019 was fundamental to the permit application and therefore we decided to advertise and consult on the application as stated above with the revised documentation.

### 3 The legal framework

The Permit will be granted, under Regulation 13 of the EPR. The Environmental Permitting regime is a legal vehicle which delivers most of the relevant legal requirements for activities falling within its scope. In particular, the regulated facility is:

- an *installation* and a *waste incineration plant* as described by the IED;
- an *operation* covered by the WFD, and
- subject to aspects of other relevant legislation which also have to be addressed.

We address some of the major legal requirements directly where relevant in the body of this document. Other requirements are covered in a section towards the end of this document.

We consider that, in granting the Permit, it will ensure that the operation of the Installation complies with all relevant legal requirements and that a high level of protection will be delivered for the environment and human health.

We explain how we have addressed specific statutory requirements more fully in the rest of this document.

### 4 The Installation

#### 4.1 Description of the Installation and related issues

##### 4.1.1 The permitted activities

The Installation is subject to the EPR because it carries out an activity listed in Part 1 of Schedule 1 to the EPR:

- Section 5.1 Part A(1)(b) – incineration of non-hazardous waste in a waste incineration plant with a capacity of 3 tonnes or more per hour.

The IED definition of “waste incineration plants” and “waste co-incineration plants” says that it includes:

*“all incineration lines or co-incineration lines, waste reception, storage, on-site pre-treatment facilities, waste, fuel and air supply systems, boilers, facilities for the treatment of waste gases, on-site facilities for treatment or storage of residues and waste water, stacks, devices for controlling incineration or co-incineration operations, recording and monitoring incineration or co-incineration conditions.”*

Many activities which would normally be categorised as “directly associated activities” for EPR purposes (see below), such as air pollution control plant, and the ash storage and the associated gas engine are therefore included in the listed activity description. There is no treatment of incineration bottom ash on site.

Therefore there are no directly associated activities.

#### 4.1.2 The Site

The installation will be situated on the edge of an industrial area in Tipton, and is approximately 2.7km northeast of Dudley. The National Grid Reference for the site is SO 94847 93114.

The nearest sensitive residential properties are located approximately 150m to the west of the site. Fens Pool Special Area of Conservation (SAC) is the only European designated site within 10km of the installation. Wren’s Nest Site of Special Scientific Interest (SSSI) is within 5km of the installation.

The Applicant submitted a plan which we consider is satisfactory, showing the site of the Installation and its extent. A plan is included in Schedule 7 to the Permit, and the Operator is required to carry on the permitted activities within the site boundary.

Further information on the site is addressed below at 4.2.

#### 4.1.3 What the Installation does

Although the process used to thermally treat the waste is pyrolysis, for the process not to be considered to be a waste incineration plant, the resultant gases from the pyrolysis process must be purified to such an extent that they are no longer a waste prior to their combustion and can cause emissions no higher than those from the burning of natural gas. The Applicant has not demonstrated that the gases have passed the ‘end of waste’ test as referred to in the Waste Framework Directive; therefore the whole process is considered to be a waste incineration plant and therefore subject to the requirements of Chapter IV of the IED.

The installation will pyrolyse non-hazardous Refuse Derived Fuel (RDF) and waste wood to produce a torrefied solid output. The pyrolysis plant will also produce synthetic gas (syngas) which will be cleaned and utilised in both a cyclone furnace to generate heat for the pyrolysis process and also a gas engine to produce electricity. The Facility will typically receive about 180,000 tonnes per annum (tpa) of RDF and Grades A to C waste wood. It will not take hazardous waste or clinical waste, and there will be no sorting or pre-treatment of waste on the site. The facility will have the following features:

Waste will feed the cyclone furnace and once the required temperature is achieved, a feedstock of biomass/RDF will be introduced to the pyrolysis plant. Hot gases produced by the combustion of the waste in the cyclone furnace will be subjected to a temperature of at least 850°C for at least 2



seconds to ensure complete destruction of organic pollutants as required by Chapter IV of IED. The cyclone furnace is fitted with an auxiliary dual fuel 5MW burner utilising syngas and/or diesel as an auxiliary fuel for start-up, shut-down and maintenance of combustion chamber temperature if required. The resultant hot flue gases from the cyclone furnace are used to heat the pyrolysis plant.

Waste is fed into each of the pyrolysis lines from hoppers by two feed systems. Each line then comprises a four-stage pyrolysis process comprising of heating in a retort drum to thermally treat the waste, passage through a cyclone to remove solids from the syngas, thermal cracking of syngas at 1100°C to break down tars, oils and heavy components and a final passage through a further cyclone to remove particulates in the form of soot. As the solid torrefied fuel exit the pyrolysis units, they are cooled via a set of auger systems before discharge. The torrefied fuel will be pelletised using a pellet mill prior to bagging and storage pending dispatch from site.

Once the syngas exits the pyrolysis process it is passed through a venturi scrubber, packed tower scrubber and carbon filter to cool and further polish the syngas. Once polished, it is then passed through to one gas-fired engine and the dual-fuel burner serving the cyclone furnace. Exhaust gases from the engine will be discharged via a 9m stack with continuous emissions monitoring systems (CEMS) and ports for periodic monitoring purposes.

A proportion of the syngas will be used to generate 2.2MW of electricity for either the site parasitic load or for export to the local electricity distribution network.

The burning of syngas in the engine and as an auxiliary fuel is considered burning of waste and therefore Chapter IV applies to both of these processes. Article 51 of Chapter IV does allow for a derogation away from the requirement of the waste reaching a temperature of 850°C for a residence time of at least 2 seconds. This can be for certain categories of waste or for certain thermal processes but in both instances the change in operating conditions is not permitted to cause more residues or residues with a higher content of organic polluting substances compared to the standard conditions required by Article 50.

For this plant we have decided to permit alternative operating techniques for the combustion of syngas. This is because it is cleaned to a standard that ensures that the emission limit values in Chapter IV are met and because the technology that would be appropriate for burning syngas is not designed to achieve a temperature of 850°C and requiring this would not enable the plant to operate at parameters optimal for both the burning of the syngas or the production of electricity. We have specified through preoperational condition PO8 that for the burning of syngas in the engine, the operator will document the process to be followed to ensure that once started up the temperature of the engine is continuously optimised for the burning of waste and production of electricity, and describe how these objectives correlate. The PO also

requires the operator to define triggers for the process parameters below which the waste shall cease to be fired to the pyrolysis units.

In the event of an emergency only, a flare is available to combust the syngas to atmosphere. We have not specified a residence time or temperature for the burning of syngas in the flare because the technology is not set up to allow either of these. There should be minimal operation of the flare in emergency situations only.

A nitrogen purge system will be in place for extinguishing fires.

There will be no storage or processing of waste feedstock on site. Waste feedstocks will be delivered on a 'just in time' basis. Prior to delivery to the hoppers, feedstock materials will be subject to waste acceptance procedures and a final inspection in a waste inspection area prior to acceptance and delivery into the hoppers.

The operator has stated that they intend that the torrefied fuel will meet End of Waste status but this has not been applied for at the time of application. Up to 500 tonnes of torrefied fuel will be stored on site at any one time.

Flue gases from the cyclone furnace are passed through a heat recovery boiler. The boiler's purpose is to supply heat for future heat load opportunities and to remove residual heat within the flue gases such that they are lowered to a suitable temperature for subsequent flue gas treatment.

A Selective Non-Catalytic Reduction (SNCR) system will be in place to reduce oxides of nitrogen (NO<sub>x</sub>) emissions, a cyclone to remove particulates and metals and a wet scrubbing system to reduce acid gas emissions. A carbon filter will remove dioxins and furans. The flue gases will then pass into the atmosphere via a single 29m tall chimney stack.

A system of continuous emissions monitoring equipment and periodic manual sampling provisions will be in place to characterise emissions from the process to atmosphere.

Air Pollution Control residues are collected by the cyclone post-combustion in the furnace combustion chamber and are removed by an auger system for storage prior to removal off-site.

A cyclone will collect entrained ash from the furnace which will drop out to a container for removal from and further treatment off site. No bottom ash treatment will occur on site.

There will be no process water emissions to sewer or controlled waters, with contaminated water being tankered off site for suitable treatment. Run-off from external surfaces will be captured by the drainage system prior to discharge to public sewer. Clean surface water from roof run-off will be captured for reuse on the site. Surface water runoff off not reused will be passed through an interceptor prior to discharge. The plant will recycle boiler blow down water for use in the wet scrubbing systems and recycle waste

water from the wet scrubbers to minimise the production of aqueous emissions.

A plant control and monitoring system will be in place.

The key features of the Installation can be summarised in the table below.

Waste throughput, Tonnes/line	180,000 tonnes/annum for the whole installation	Cyclone furnace: 5 tonnes/hour Pyrolysis lines: 7 tonnes/hour/line
Waste processed	RDF and Waste biomass in the cyclone furnace and pyrolysis units Syngas in the engine and cyclone furnace at start-up, shut-down, and for maintenance of combustion chamber temperature	
Number of lines	1 Cyclone Furnace, 2 Pyrolysis lines, 1 engine	
Furnace technology	Cyclone furnace and Pyrolysis units	
Auxiliary Fuel	Gas Oil and syngas for the cyclone furnace	
Acid gas abatement	Wet	
NOx abatement for cyclone furnace	SNCR	Ammonia
Flue gas recirculation	Yes - see waste heat section below.	
Dioxin abatement	Activated carbon to treat the syngas and carbon filter treating emissions from the cyclone furnace	
Cyclone furnace stack	Height, 29.4 m	Diameter, 0.9 m
Flue gas from the cyclone furnace	Flow, 10.52 Nm <sup>3</sup> /s	Velocity, 21.08 m/s
	Temperature, 46°C	
Engine stack	Height, 9 m	Diameter, 0.5 m
Flue gas from the engine	Flow, 1.82 Nm <sup>3</sup> /s	Velocity, 31.96 m/s
	Temperature, 600°C	
Electricity generated	2.2 MWe	
Electricity exported	1 MWe	
Waste heat use	The application states that as present no suitable heat load is available for the provision of heat recovered from the flue gases other than for pre-heating of primary air to the cyclone furnace. The boiler does include connections for a heat exchange network should an economically viable heat load become available for supply.	

#### 4.1.4 Key Issues in the Determination

The key issues arising during this determination were emissions to air and the best available techniques (BAT) assessment and we therefore describe how we determined these issues in most detail in this document.

#### 4.2 The site and its protection

#### 4.2.1 Site setting, layout and history

The site is approximately 0.96 hectares in area and square in shape. The site's southeastern border is immediately adjacent to the Stour Valley Line of the London and North Western Railway. The site is a subsection of a larger recycling depot, which is being redeveloped. The site contains hardstanding comprising concrete, with a series of surrounding bunds.

#### 4.2.2 Proposed site design: potentially polluting substances and prevention measures

The main raw materials used at the site are identified in the table below. A Control of Substances Hazardous to Health (COSHH) assessment will be undertaken prior to the use of chemicals, and if the chemical is found to present a hazard to health, it will be added to the COSHH inventory. Material Safety Data Sheets (MSDS) for any potentially hazardous materials or chemicals will be kept on site together with the COSHH register. The MSDS will include information on how chemicals should be handled, stored and disposed of, and what to do in the event of an accident.

Material	Consumption	Site Storage
Nitrogen	5,096 m <sup>3</sup> /annum	20 x 9.8m <sup>3</sup> 230 bar cylinders
Diesel	50,000 litres / annum	2 x 5000 litre double skin plastic tanks
Sodium Hydroxide	24,000 litres / annum	2 x 1000 litre Intermediate Bulk Containers (IBC)
Hydrogen Peroxide	24,000 litres / annum	2 x 1000 litre IBCs
Ammonia	12,000 litres / annum	2 x 1000 litre IBCs

Operational areas of the site will have an engineered containment system comprising an impermeable concrete surface.

The locations of subsurface drains, pipework and interceptors will be established and recorded and relevant documentation maintained in the site office. An inspection and maintenance programme for subsurface structures will be followed and records will be maintained by the site manager.

Bunds and/or double skinned walls will be provided for all tanks containing liquids whose spillage could be harmful to the environment. Containment bunds or double skinned walls will be provided to make sure that any leaks/spillages will be contained in the event of a leak of the primary containment. As such, containment measures will be:

- capable of containing at least 110% of the volume of the largest tank within the bund;
- constructed of materials which are impermeable and resistant to the stored materials in accordance with relevant material safety data sheets (MSDS);
- constructed to the appropriate British Standard and Health and Safety Executive (HSE) guidance;

- of a type suitable for the containment of the materials in the event of leak or spill;
- pipework will be routed within bunded areas so that no penetration of walls or base of the bund takes place; and
- connection points will be located within the bund.

Based on the information contained in the application and Site Condition Report we consider that the potential pollution of land or groundwater is unlikely.

Under Article 22(2) of the IED the Applicant is required to provide a baseline report containing at least the information set out in paragraphs (a) and (b) of the Article before starting operation.

The Applicant submitted a baseline report that we have reviewed and we consider that sufficient information has been supplied to describe the condition of the site at permit issue and pollution of land and water is unlikely.

The baseline report is an important reference document in the assessment of contamination that might arise during the operational lifetime of the installation and at cessation of activities at the installation

#### 4.2.3 Closure and decommissioning

Pre-operational condition PO1 requires the Operator to have an Environmental Management System in place before the Installation is operational, and this will include a site closure plan.

At the definitive cessation of activities, the Operator has to satisfy us that the necessary measures have been taken so that the site ceases to pose a risk to soil or groundwater, taking into accounts both the baseline conditions and the site's current or approved future use. To do this, the Operator will apply to us for surrender of the permit, which we will not grant unless and until we are satisfied that these requirements have been met.

### 4.3 Operation of the Installation – general issues

#### 4.3.1 Administrative issues

The Applicant is the sole Operator of the Installation. We are satisfied that the Applicant is the person who will have control over the operation of the Installation after the granting of the Permit; and that the Applicant will be able to operate the Installation so as to comply with the conditions included in the Permit.

#### 4.3.2 Management

The Applicant has stated in the Application that they will implement an Environmental Management System (EMS) that will be certified under ISO14001. A pre-operational condition (PO1) is included requiring the Operator to provide a summary of the EMS prior to commissioning of the plant and to make available for inspection all EMS documentation. The

Environment Agency recognises that certification of the EMS cannot take place until the Installation is operational. An improvement condition (IC1) is included requiring the Operator to report progress towards gaining certification of its EMS.

We are satisfied that appropriate management systems and management structures will be in place for this Installation, and that sufficient resources are available to the Operator to ensure compliance with all the Permit conditions.

#### 4.3.3 Site security

Having considered the information submitted in the Application, we are satisfied that appropriate infrastructure and procedures will be in place to ensure that the site remains secure.

#### 4.3.4 Accident management

The Applicant has submitted an Accident Management Plan. Having considered the Plan and other information submitted in the Application, we are satisfied that appropriate measures will be in place to ensure that accidents that may cause pollution are prevented but that, if they should occur, their consequences are minimised. An Accident Management Plan will form part of the Environmental Management System and must be in place prior to commissioning as required by a pre-operational condition (PO1).

The Applicant submitted a Fire Prevention Plan and we have approved this plan and it is incorporated into the operating techniques table S1.2.

#### 4.3.5 Off-site conditions

We do not consider that any off-site conditions are necessary.

#### 4.3.6 Operating techniques

We have specified that the Applicant must operate the Installation in accordance with the following documents contained in the Application:

Description	Parts
Application EPR/CP3836QX/A001	Application forms B2 and B3 and supporting information including: Non-technical summary, dated December 2018 Best Available Techniques & Operating Techniques, dated December 2018 Site Condition Report, dated December 2018 Soil and Groundwater Monitoring Protocol, dated October 2018 Fire Prevention Plan, dated December 2018 Amenity and Accident Risk Assessment.

Description	Parts
Additional information received	Revised documents: Air emissions risk assessment, dated May 2019
Additional information received	Revised documents: Revised site layout plan, dated January 2019
Response to Schedule 5 Notice dated 18/06/19	Revised noise impact assessment and revised noise management plan, dated July 2019.
Response to Schedule 5 Notice dated 19/08/19	Clarification on air quality impacts and best available techniques assessment.
Response to Schedule 5 Notice dated 09/10/19	Clarifications relating to fire prevention plan and operating parameters of gas engine.
Additional information received	Clarifications relating to stack height and BAT 30 cyclone furnace abatement.

The details set out above describe the techniques that will be used for the operation of the Installation that have been assessed by the Environment Agency as BAT; they form part of the Permit through Permit condition 2.3.1 and Table S1.2 in the Permit Schedules.

We have also specified the following limits and controls on the use of raw materials and fuels:

Raw Material or Fuel	Specifications	Justification
Gas Oil	< 0.1% sulphur content	As required by Sulphur Content of Liquid Fuels Regulations.

Article 45(1) of the IED requires that the Permit must include a list of all types of waste which may be treated using at least the types of waste set out in the European Waste List established by Decision 2005/532/EC, EC, if possible, and containing information on the quantity of each type of waste, where appropriate. The Application contains a list of those wastes: refuse derived fuel (RDF) and waste wood, coded by the European Waste Catalogue (EWC) number, which the Applicant will accept in the waste streams entering the plant and which the plant is capable of burning in an environmentally acceptable way. We have specified the permitted waste types, descriptions and where appropriate quantities which can be accepted at the installation in Table S2.2. The original application specified that the cyclone furnace and pyrolysers would take only RDF and grade A waste wood, however during the determination the Applicant confirmed that the waste wood would be grades A to C.

The Applicant has confirmed that for the purposes of batch traceability and consistency, RDF and wood will not be mixed prior to feeding into either of the pyrolysis units or the cyclone furnace.

We are satisfied that the Applicant can accept the wastes contained in Table S2.2 of the Permit because:

- (i) the wastes are all categorised as non-hazardous in the European Waste Catalogue and are capable of being safely burnt at the installation.

- (ii) these wastes are likely to be within the design calorific value (CV) range for the plant;
- (iii) these wastes are unlikely to contain harmful components that cannot be safely processed at the Installation.

We have limited the capacity of the Installation to 180,000 tonnes per annum.

The Applicant has proposed that no waste will be stored on site and a 'just in time' approach for receipt of waste will be taken. The waste for input to the site will be from the adjacent waste management site and so we accept this approach.

The Installation will be designed, constructed and operated using BAT for the incineration of the permitted wastes. We are satisfied that the operating and abatement techniques are BAT for incinerating these types of waste. Our assessment of BAT is set out later in this document.

#### 4.3.7 Energy efficiency

##### (i) Consideration of energy efficiency

We have considered the issue of energy efficiency in the following ways:

1. The use of energy within, and generated by, the Installation which are normal aspects of all EPR permit determinations. This issue is dealt with in this section.
2. The extent to which the Installation meets the requirements of Article 50(5) of the IED, which requires "*the heat generated during the incineration and co-incineration process is recovered as far as practicable through the generation of heat, steam or power*". This issue is covered in this section.
3. The combustion efficiency and energy utilisation of different design options for the Installation are relevant considerations in the determination of BAT for the Installation, including the Global Warming Potential of the different options. This aspect is covered in the BAT assessment in section 6 of this Decision Document.
4. The extent to which the Installation meets the requirement of Article 14(5) of the Energy Efficiency Directive which requires new thermal electricity generation installations with a total thermal input exceeding 20 MW to carry out a cost-benefit assessment to "*assess the cost and benefits of providing for the operation of the installation as a high-efficiency cogeneration installation*".

**Cogeneration** means the simultaneous generation in one process of thermal energy and electrical or mechanical energy and is also known as combined heat and power (CHP).

**High-efficiency co-generation** is cogeneration which achieves at least 10% savings in primary energy usage compared to the separate generation of heat and power – see Annex II of the Energy Efficiency Directive for detail on how to calculate this.



(ii) Use of energy within the Installation

Having considered the information submitted in the Application, we are satisfied that appropriate measures will be in place to ensure that energy is used efficiently within the Installation.

The Application details a number of measures that will be implemented at the Installation in order to increase its energy efficiency.

Flue gases from the cyclone furnace are passed through a heat recovery boiler. The boiler's purpose is to supply heat for future heat load opportunities and to remove residual heat within the flue gases such that they are lowered to a suitable temperature for subsequent flue gas treatment.

The facility is designed to use heat from combustion in the cyclone furnace to heat the retort drums for torrefaction. This system has been designed to optimise heat transfer from the ducts into the drums via convection bundles. The cyclone furnace combustion chamber and ducting are insulated to minimise heat losses. The convection bundles will be cleaned in accordance with the site's Planned Preventative Maintenance schedule to ensure their continuing effectiveness.

The Application states that the specific energy consumption, a measure of total energy consumed per unit of waste processed, will be 202.8 kWh/tonne. The installation capacity is 180,000 t/a.

The BREF says that electricity consumption is typically between 60 kWh/t and 190 kWh/t depending on the LCV of the waste. This however, relates specifically to conventional incineration where the primary purposes are to dispose of waste and generation of electricity which is not the case on this installation where the primary purpose is the torrefaction of fuel.

(iii) Generation of energy within the Installation - Compliance with Article 50(5) of the IED

Article 50(5) of the IED requires that *"the heat generated during the incineration and co-incineration process is recovered as far as practicable"*.

Our CHP Ready Guidance - February 2013 considers that BAT for energy efficiency for Energy from Waste (EfW) plant is the use of CHP in circumstances where there are technically and economically viable opportunities for the supply of heat from the outset.

The term CHP in this context represents a plant which also provides a supply of heat from the electrical power generation process to either a district heating network or to an industrial / commercial building or process. However, it is recognised that opportunities for the supply of heat do not always exist from the outset (i.e. when a plant is first consented, constructed and commissioned).

In cases where there are no immediate opportunities for the supply of heat from the outset, the Environment Agency considers that BAT is to build the plant to be CHP Ready (CHP-R) to a degree which is dictated by the likely

future opportunities which are technically viable and which may, in time, also become economically viable.

The BREF says that 0.4 – 0.8 MWh of electricity can be generated per tonne of waste. However, as outlined in the section above, the primary purpose of this plant is not to produce electricity. The main proportion of energy generated is within the torrefied fuel. We therefore do not consider this value appropriate to apply to this plant.

Our technical guidance note, SGN EPR S5.01, states that where electricity only is generated, 5-9 MW of electricity should be recoverable per 100,000 tonnes/annum of waste, however as this plant is designed primarily to produce a torrefied solid output, this figure is not applicable to the plant.

The Applicant carried out a CHP-R assessment. In summary, the plant will not be CHP from the outset. However, the design incorporates the potential for heat extraction in the future should a viable heat load become available.

The plant does not generate electricity using a condensing turbine or using a back pressure turbine and therefore the BAT-AEELs (BAT-Associated Energy Efficiency / Electrical Efficiency Level) set out in table 2 of BAT 20 of the Waste Incineration BAT Conclusions are not applicable to this plant.

The SGN and Chapter IV of the IED both require that, as well as maximising the primary use of heat to generate electricity; waste heat should be recovered as far as practicable. In this instance, the primary use of the heat is to produce a torrefied solid output.

The CHP Ready Assessment submitted with the Application concluded that whilst there is the potential to supply heat a number of nearby premises; this is reliant on agreement being reached with third parties, which will be difficult to achieve until the facility has proven its reliability and ability to provide heat as required by any potential user.

The site design means that it will be ready to supply heat in the future to the identified heat loads or other potential heat supply opportunities which present with minimum modification of the original plant/equipment. Opportunities to utilise CHP will be reviewed on a regulator basis.

Our CHP-R guidance states that opportunities to maximise the potential for heat recovery should be considered at the early planning stage, when sites are being identified for incineration facilities. In our role as a statutory consultee on the planning application, we ensured that the issue of energy utilisation was brought to the planning authority's attention.

We consider that, within the constraints of the Installation explained above, the Installation will recover heat as far as practicable, and therefore that the requirements of Article 50(5) are met.

(iv) R1 Calculation

The R1 calculation does not form part of the matters relevant to our determination. It is however a general indicator that the installation is achieving a high level of energy recovery.

The Applicant has not presented an R1 calculation with this application, nor have we received a separate application for a determination on whether the installation is a recovery or disposal facility.

Note that the availability or non-availability of financial incentives for renewable energy such as the ROC and RHI schemes is not a consideration in determining this application.

(vii) Compliance with Article 14(5) of the Energy Efficiency Directive

The operator has submitted a cost-benefit assessment of opportunities for high efficiency co-generation in which they calculated net present value. If the NPV is positive (i.e. any number more than zero) it means that the investors will make a rate of return that makes the scheme commercially viable. A negative NPV means that the project will not be commercially viable. The Applicant's assessment showed a positive net present value for several nearby industrial areas which demonstrates that operating as a high-efficiency cogeneration installation would be financially viable.

The Applicant has confirmed that the viability of these areas is because they have a significant thermal load arising from 'Large Industry' identified in the BEIS national heat map. The Applicant has confirmed that they will need to carry out further investigation into the heat load to establish if the heat demand is of a grade and type which is compatible with the output from the pyrolysis plant. They have stated that there is the potential that the heat requirement may be of a higher temperature than is produced by the plant. In this instance a heat network connection may not be viable.

(viii) Permit conditions concerning energy efficiency

A pre-operational condition is usually included requiring the Operator to carry out a comprehensive review of the available heat recovery options prior to commissioning, in order to ensure that waste heat from the plant is recovered as far as possible. However, in this instance the operator has confirmed they will begin commissioning soon after permit issue and therefore we accept that the review of options submitted with the application is adequate.

Conditions 1.2.2 and 1.2.3 have also been included in the Permit, which require the Operator to review the options available for heat recovery on an ongoing basis, and to provide and maintain the proposed steam/hot water pass-outs.

The Operator is required to report energy usage and energy generated under condition 4.2 and Schedule 5. The following parameters are required to be reported: total electrical energy generated; electrical energy exported; total energy usage and energy exported as heat (if any). Together with the total waste burned per year, this will enable the Environment Agency to monitor

energy recovery efficiency at the Installation and take action if at any stage the energy recovery efficiency is less than proposed.

There are no site-specific considerations that require the imposition of standards beyond indicative BAT, and so the Environment Agency accepts that the Applicant's proposals represent BAT for this Installation.

#### 4.3.8 Efficient use of raw materials

Having considered the information submitted in the Application, we are satisfied that the appropriate measures will be in place to ensure the efficient use of raw materials and water.

The Operator is required to report with respect to raw material usage under condition 4.2 and Schedule 5, including consumption of activated carbon and ammonia used per tonne of waste burned. This will enable the Environment Agency to assess whether there have been any changes in the efficiency of the air pollution control plant, and the operation of the SNCR to abate NO<sub>x</sub>. These are the most significant raw materials that will be used at the Installation, other than the waste feed itself (addressed elsewhere). The efficiency of the use of auxiliary fuel will be tracked separately as part of the energy reporting requirement under condition 4.2.1. Optimising reagent dosage for air abatement systems and minimising the use of auxiliary fuels is further considered in the section on BAT.

#### 4.3.9 Avoidance, recovery or disposal with minimal environmental impact of wastes produced by the activities

This requirement addresses wastes produced at the Installation and does not apply to the waste being treated there. The principal waste streams the Installation will produce are bottom ash and air pollution control residues.

The first objective is to avoid producing waste at all. Waste production will be avoided by achieving a high degree of burnout of the ash in the furnace, which results in a material that is both reduced in volume and in chemical reactivity. Condition 3.1.3 and associated Table S3.4 specify limits for total organic carbon (TOC) of <3% in bottom ash. Compliance with this limit will demonstrate that good combustion control and waste burnout is being achieved in the furnaces and waste generation is being avoided where practicable.

Incinerator bottom ash (IBA) will normally be classified as non-hazardous waste. However, IBA is classified on the European List of Wastes as a "mirror entry", which means IBA is a hazardous waste if it possesses a hazardous property relating to the content of dangerous substances. Monitoring of incinerator ash will be carried out in accordance with the requirements of Article 53(3) of IED. Classification of IBA for its subsequent use or disposal is controlled by other legislation and so is not duplicated within the permit.

Air pollution control (APC) residues from flue gas treatment are hazardous waste and therefore must be sent for disposal to a landfill site permitted to accept hazardous waste, or to an appropriately permitted facility for

hazardous waste treatment. The amount of APC residues is minimised through optimising the performance of the air emissions abatement plant.

In order to ensure that the IBA residues are adequately characterised, pre-operational condition PO2 requires the Operator to provide a written plan for approval detailing the ash sampling protocols. Table S3.4 requires the Operator to carry out an ongoing programme of monitoring.

Having considered the information submitted in the Application, we are satisfied that the waste hierarchy referred to in Article 4 of the WFD will be applied to the generation of waste and that any waste generated will be treated in accordance with this Article.

We are satisfied that waste from the Installation that cannot be recovered will be disposed of using a method that minimises any impact on the environment. Standard condition 1.4.1 will ensure that this position is maintained.

## **5. Minimising the Installation's environmental impact**

Regulated activities can present different types of risk to the environment, these include odour, noise and vibration; accidents, fugitive emissions to air and water; as well as point source releases to air, discharges to ground or groundwater, global warming potential and generation of waste and other environmental impacts. Consideration may also have to be given to the effect of emissions being subsequently deposited onto land (where there are ecological receptors). All these factors are discussed in this and other sections of this document.

For an installation of this kind, the principal emissions are those to air, although we also consider those to land and water.

The next sections of this document explain how we have approached the critical issue of assessing the likely impact of the emissions to air from the Installation on human health and the environment and what measures we are requiring to ensure a high level of protection.

### **5.1 Assessment Methodology**

#### **5.1.1 Application of Environment Agency guidance 'risk assessments for your environmental permit'**

A methodology for risk assessment of point source emissions to air, which we use to assess the risk of applications we receive for permits, is set out in our guidance 'Air emissions risk assessment for your environmental permit' and has the following steps:

- Describe emissions and receptors
- Calculate process contributions
- Screen out insignificant emissions that do not warrant further investigation

- Decide if detailed air modelling is needed
- Assess emissions against relevant standards
- Summarise the effects of emissions

The methodology uses a concept of “process contribution (PC)”, which is the estimated concentration of emitted substances after dispersion into the receiving environmental media at the point where the magnitude of the concentration is greatest. The methodology provides a simple method of calculating PC primarily for screening purposes and for estimating process contributions where environmental consequences are relatively low. It is based on using dispersion factors. These factors assume worst case dispersion conditions with no allowance made for thermal or momentum plume rise and so the process contributions calculated are likely to be an overestimate of the actual maximum concentrations. More accurate calculation of process contributions can be achieved by mathematical dispersion models, which take into account relevant parameters of the release and surrounding conditions, including local meteorology – these techniques are expensive but normally lead to a lower prediction of PC.

#### 5.1.2 Use of Air Dispersion Modelling

For incineration applications, we normally require the Applicant to submit a full air dispersion model as part of their application. Air dispersion modelling enables the process contribution to be predicted at any environmental receptor that might be impacted by the plant.

Once short-term and long-term PCs have been calculated in this way, they are compared with Environmental Standards (ES). ES are described in our web guide ‘Air emissions risk assessment for your environmental permit’.

Our web guide sets out the relevant ES as:

- Ambient Air Directive Limit Values
- Ambient Air Directive and 4th Daughter Directive Target Values
- UK Air Quality Strategy Objectives
- Environmental Assessment Levels

Where an Ambient Air Directive (AAD) Limit Value exists, the relevant standard is the AAD Limit Value. Where an AAD Limit Value does not exist, AAD target values, UK Air Quality Strategy (AQS) Objectives or Environmental Assessment Levels (EALs) are used. Our web guide sets out EALs which have been derived to provide a similar level of protection to Human Health and the Environment as the AAD limit values, AAD target and AQS objectives. In a very small number of cases, e.g. for emissions of lead, the AQS objective is more stringent than the AAD value. In such cases, we use the AQS objective for our assessment.

AAD target values, AQS objectives and EALs do not have the same legal status as AAD limit values, and there is no explicit requirement to impose stricter conditions than BAT in order to comply with them. However, they are a

standard for harm and any significant contribution to a breach is likely to be unacceptable.

PCs are screened out as **Insignificant** if:

- the **long-term** process contribution is less than **1%** of the relevant ES; and
- the **short-term** process contribution is less than **10%** of the relevant ES.

The **long term** 1% process contribution insignificance threshold is based on the judgements that:

- It is unlikely that an emission at this level will make a significant contribution to air quality;
- The threshold provides a substantial safety margin to protect health and the environment.

The **short term** 10% process contribution insignificance threshold is based on the judgements that:

- spatial and temporal conditions mean that short term process contributions are transient and limited in comparison with long term process contributions;
- the threshold provides a substantial safety margin to protect health and the environment.

Where an emission is screened out in this way, we would normally consider that the Applicant's proposals for the prevention and control of the emission to be BAT. That is because if the impact of the emission is already insignificant, it follows that any further reduction in this emission will also be insignificant.

**However, where an emission cannot be screened out as insignificant, it does not mean it will necessarily be significant.**

For those pollutants which do not screen out as insignificant, we determine whether exceedences of the relevant ES are likely. This is done through detailed audit and review of the Applicant's air dispersion modelling taking background concentrations and modelling uncertainties into account. Where an exceedance of an AAD limit value is identified, we may require the Applicant to go beyond what would normally be considered BAT for the Installation or we may refuse the application if the applicant is unable to provide suitable proposals. Whether or not exceedences are considered likely, the application is subject to the requirement to operate in accordance with BAT.

This is not the end of the risk assessment, because we also take into account local factors (for example, particularly sensitive receptors nearby such as a SSSIs, SACs or SPAs). These additional factors may also lead us to include more stringent conditions than BAT.

If, as a result of reviewing of the risk assessment and taking account of any additional techniques that could be applied to limit emissions, we consider

that emissions **would cause significant pollution**, we would refuse the Application.

## **5.2 Assessment of Impact on Air Quality**

The Applicant's assessment of the impact of air quality is set out in document 'Air Emissions Risk Assessment, May 2019' of the Application. The assessment comprises:

- Dispersion modelling of emissions to air from the operation of the incinerator.
- A study of the impact of emissions on nearby sensitive habitat / conservation sites.

This section of the decision document deals primarily with the dispersion modelling of emissions to air from the incinerator chimney and its impact on local air quality. The impact on conservation sites is considered in section 5.4.

The Applicant has assessed the Installation's potential emissions to air against the relevant air quality standards, and the potential impact upon local conservation and habitat sites and human health. These assessments predict the potential effects on local air quality from the Installation's stack emissions using the AERMOD dispersion model, which is a commonly used computer model for regulatory dispersion modelling. The model used 5 years of meteorological data collected from the weather station at Birmingham Airport between 2012 and 2016. The impact of the terrain surrounding the site upon plume dispersion was considered in the dispersion modelling.

The air impact assessments, and the dispersion modelling upon which they were based, employed the following assumptions.

- First, they assumed that the ELVs in the Permit would be the maximum permitted by Article 15(3), Article 46(2) and Annex VI of the IED. These substances are:
  - Oxides of nitrogen (NO<sub>x</sub>), expressed as NO<sub>2</sub>
  - Total dust
  - Carbon monoxide (CO)
  - Sulphur dioxide (SO<sub>2</sub>)
  - Hydrogen chloride (HCl)
  - Hydrogen fluoride (HF)
  - Metals Cadmium, Thallium, Mercury, Antimony, Arsenic, Lead, Chromium, Cobalt, Copper, Manganese, Nickel and Vanadium
  - Polychlorinated dibenzo-para-dioxins and polychlorinated dibenzo furans (referred to as dioxins and furans)
  - Gaseous and vaporous organic substances, expressed as Total Organic Carbon (TOC)
  - Ammonia (NH<sub>3</sub>) (applicable to the cyclone furnace emissions with SNCR but not to the gas engine as no SCR).



- Second, they assumed that the Installation operates continuously at the relevant long-term or short-term ELVs, i.e. the maximum permitted emission rate (except for emissions of arsenic, chromium and nickel, which are considered in section 5.2.3 of this decision document).
- Third, the model also considered emissions of pollutants not covered by Annex VI of IED, specifically, polycyclic aromatic hydrocarbons (PAH) and Polychlorinated biphenyls (PCBs). Emission rates used in the modelling have been drawn from data in the Waste Incineration BREF and are considered further in section 5.2.5.

We are in agreement with this approach. The assumptions underpinning the model have been checked and are reasonably precautionary.

As well as calculating the peak ground level concentration, the Applicant has modelled the concentration of key pollutants at a number of specified locations within the surrounding area.

The way in which the Applicant used dispersion models, its selection of input data, use of background data and the assumptions it made have been reviewed by the Environment Agency's modelling specialists to establish the robustness of the Applicant's air impact assessment. The output from the model has then been used to inform further assessment of health impacts and impact on habitats and conservation sites.

Our review of the Applicant's assessment leads us to agree with the Applicant's conclusions. We have also audited the air quality and human health impact assessment and similarly agree that the conclusions drawn in the reports were acceptable.

The Applicant's modelling predictions are summarised in the following sections.

#### 5.2.1 Assessment of Air Dispersion Modelling Outputs

The Applicant's modelling predictions are summarised in the tables below.

The Applicant's modelling predicted peak ground level exposure to pollutants in ambient air and at discreet receptors for nitrogen dioxide only. The tables below show the ground level concentrations at the most impacted receptor for nitrogen dioxide and the maximum peak ground levels for other pollutants.

Whilst we have used the Applicant's modelling predictions in the table below, we have made our own simple verification calculation of the percentage process contribution and predicted environmental concentration. These are the numbers shown in the tables below and so may be very slightly different to those shown in the Application. Any such minor discrepancies do not materially impact on our conclusions.

### **Air Emissions Impact Assessment of Non-metals Emissions – long term and short term impacts at maximum on the grid except NO<sub>2</sub> which is maximum at the most impacted receptor**

Pollutant	EQS / EAL		Back-ground	Process Contribution (PC)		Predicted Environmental Concentration (PEC)	
	µg/m <sup>3</sup>			µg/m <sup>3</sup>	µg/m <sup>3</sup>	% of EAL	µg/m <sup>3</sup>
NO <sub>2</sub>	40	1	25.6	2.29	5.73	27.9	69.7
	200	2	51.2	11.5	5.8	62.7	31.4
PM <sub>10</sub>	40	1	17	0.24	0.60	17.2	43.1
	50	3	34	0.78	1.56	34.78	69.6
PM <sub>2.5</sub>	25	1	10.6	0.24	0.96	10.84	43.4
SO <sub>2</sub>	266	4	1.14	17.7	6.7	18.84	7.1
	350	5	1.14	12.8	3.66	13.94	4.0
	125	6	1.14	8.24	6.6	9.38	7.5
HCl	750	7	0.48	3.53	0.4706667	4.0	0.53
HF	16	8	3.5	0.08	0.50	3.580	22.38
	160	7	7	0.59	0.36875	7.59	4.7
CO	10000	9	371	103.6	1.04	475	4.7
	30000	10	742	29.5	0.10	772	2.6
TOC	2.25	1	1.4	0.26	11.56	1.660	73.78
PAHs (as BaP)	0.00025	1	0.0003	0.0002615	104.60	0.000562	224.6
NH <sub>3</sub>	180	1	1.59	0.26	0.14	1.85	1.03
	2500	10	3.18	5.89	0.24	9.07	0.4
PCBs	0.2	1	0.0001	0.00014	0.07	0.00024	0.12
	6	10	0.0002	0.003	0.05	0.00320	0.1
Dioxins			1.05E-09	1.40E-09		2.45E-09	

TOC as 1,3 butadiene

PAH as

benzo[a]pyrene

- 1 Annual Mean
- 2 99.79<sup>th</sup> %ile of 1-hour means
- 3 90.41<sup>st</sup> %ile of 24-hour means
- 4 99.9<sup>th</sup> ile of 15-min means
- 5 99.73<sup>rd</sup> %ile of 1-hour means
- 6 99.18<sup>th</sup> %ile of 24-hour means
- 7 1-hour average
- 8 Monthly average
- Maximum daily running 8-hour
- 9 mean

### Air Emissions Impact Assessment of Metals Emissions – long term and short term impacts at maximum on the grid

Pollutant	EQS / EAL		Back-ground	Process Contribution		Predicted Environmental Concentration	
	$\mu\text{g}/\text{m}^3$			$\mu\text{g}/\text{m}^3$	% of EAL	$\mu\text{g}/\text{m}^3$	% of EAL
Cd	0.005	1	0.00088	0.000525	10.5	0.00141	28.1
Hg	0.25	1	0.0023	0.0013	0.52	0.00360	1.44
	7.5	2	0.0046	0.02925	0.39	0.03385	0.451
Sb	5	1	0	0.0005	0.01	0.0005	0.01
	150	2	0	0.015	0.01	0.01500	0.010
Pb	0.25	1	0.02208	0.001325	0.53	0.02341	9.36
Cu	10	1	0.02336	0.001	0.01	0.02436	0.244
	200	2	0.04672	0.02	0.01	0.06672	0.033
Mn	0.15	1	0.00937	0.00157	1.05	0.01094	7.29
	1500	2	0.01874	0.15	0.01	0.16874	0.0112
V	5	1	0.00088	0	0.00	0.00088	0.02
	1	3	0.00176	0.0035	0.35	0.00526	0.53
As	0.003	1	0.00112	0.000654	21.80	0.00177	59.1
Cr (II)(III)	5	1	0.00437	0.0025	0.05	0.00687	0.137
	150	2	0.00437	0.06	0.04	0.06437	0.0429
Cr (VI)	0.0002	1	0.00175	0.0000034	1.70	0.00175	876.7
Ni	0.02	1	0.0015	0.01	28.80	0.00726	36.3

- 1 Annual Mean  
2 1-hr Maximum  
3 24-hr Maximum

(i) Screening out emissions which are insignificant

From the tables above the following emissions can be screened out as insignificant in that the process contribution is < 1% of the long term ES and <10% of the short term ES. These are:

- Non-metals: PM<sub>10</sub>, PM<sub>2.5</sub>, SO<sub>2</sub>, HCl, HF, NH<sub>3</sub>, PCBs
- Metals: Mercury (Hg), antimony (Sb), lead (Pb), copper (Cu), vanadium (V), chromium (II)(III).

Therefore we consider the Applicant's proposals for preventing and minimising the emissions of these substances to be BAT for the Installation subject to the detailed audit referred to below.

(ii) Emissions unlikely to give rise to significant pollution

Also from the tables above the following emissions (which were not screened out as insignificant) have been assessed as being unlikely to give rise to significant pollution in that the predicted environmental concentration is less than 100% (taking expected modelling uncertainties into account) of both the long term and short term ES.

- NO<sub>2</sub>, CO, TOC, cadmium (Cd), manganese (Mn), arsenic (As), nickel (Ni)

For these emissions, we have carefully scrutinised the Applicant's proposals to ensure that they are applying the Best Available Techniques to prevent and minimise emissions of these substances. This is reported in section 6 of this document.

(iii) Emissions requiring further assessment

Finally from the tables above the following emissions are considered to have the potential to give rise to pollution in that the Predicted Environmental Concentration exceeds 100% of the long term or short term ES.

- Polycyclic aromatic hydrocarbons (PAH) and Chromium VI – see sections below for further information and assessment of these emissions.

With respect to these pollutants, we have carefully scrutinised the Applicant's proposals to ensure that they are applying the Best Available Techniques to prevent and minimise emissions of these substances. This is reported in section 6 of this document.

We have also carefully considered whether additional measures are required above what would normally be considered BAT in order to prevent significant pollution. Consideration of any additional measures to address the pollution risk from these substances is set out in section 5.2.4.

## 5.2.2 Consideration of key pollutants

(i) Nitrogen dioxide (NO<sub>2</sub>)

The impact on air quality from NO<sub>2</sub> emissions has been assessed against the ES of 40 µg/m<sup>3</sup> as a long term annual average and a short term hourly average of 200 µg/m<sup>3</sup>. The model assumes a 70% NO<sub>x</sub> to NO<sub>2</sub> conversion for the long term and 35% for the short term assessment in line with Environment Agency guidance on the use of air dispersion modelling.

The above tables show that the short term PC is less than 10% of the ES and so can be screened out as insignificant. They show that the long term PC is greater than 1% of the ES and therefore cannot be screened out as insignificant. Even so, from the table above, the emission is not expected to result in the ES being exceeded.

## **Impact on Air Quality Management Areas (AQMA)**

The proposed site is located in Sandwell AQMA and on the border of Dudley AQMA, both designated for annual NO<sub>2</sub>. An AQMA encompasses the whole borough. Recent monitoring by the council indicates that the primary source of NO<sub>2</sub> is road traffic. The Applicant considered a range of background NO<sub>2</sub> data within the Application.

The latest DEFRA produced background maps indicate that the background for the 1km grid is a concentration of 26.6 µg/m<sup>3</sup>.

Automatic monitoring of NO<sub>2</sub> is undertaken at several locations by local councils. The closest automatic monitoring site to the facility is Central Dudley (2.6 km south-southwest). The monitor is classified as an 'Urban Background' site. A summary of background NO<sub>2</sub> concentrations measured at the locations from 2014 to 2016 is presented in the application, the maximum value being 23 µg/m<sup>3</sup>.

Council Diffusion Tube Monitoring (Bloomfield Road 2014) was also considered as an indicator for background. There is a range of values recorded, the highest of which is 31.4 µg/m<sup>3</sup>. The closest diffusion tube at Bloomfield Road, 215m to the east recorded a level of 25.6 µg/m<sup>3</sup> and this is the value selected for use by the Applicant.

The Application presented a background level of NO<sub>2</sub> as 25.6 µg/m<sup>3</sup> for the long term and 51.2 µg/m<sup>3</sup> for the short term. We have carried out sensitivity analysis using more conservative background levels. Taking this into account we do not consider that the predicated NO<sub>2</sub> levels are likely to cause an exceedance of the AQS within the AQMA.

### **BAT for stack height**

We requested that the operator submit information to demonstrate how the stack height had been chosen to ensure that the PCs of emissions to air, especially NO<sub>2</sub>, were minimised. The operator provided information to demonstrate that an appropriate stack height has been selected for the cyclone furnace.

### Stack Sensitivity Assessment Results

A1 Stack Height (m)	Long-term (annual mean)				Short-term (1-hr 99.79%ile)			
	Annual Mean PC ( $\mu\text{g}/\text{m}^3$ )	% Objective <sup>(a)</sup>	Annual Mean PEC <sup>(b)</sup> ( $\mu\text{g}/\text{m}^3$ )	% Obj.	Hourly Mean PC ( $\mu\text{g}/\text{m}^3$ )	% Objective <sup>(c)</sup>	Hourly Mean PEC <sup>(b)</sup> ( $\mu\text{g}/\text{m}^3$ )	% Obj.
19	1.8	4.5%	27.4	68.5%	25.8	12.9%	77.0	38.5%
22	1.0	2.4%	26.6	66.4%	17.0	8.5%	68.2	34.1%
25	0.8	1.9%	26.4	65.9%	11.3	5.7%	62.5	31.3%
28	0.6	1.6%	26.2	65.6%	9.7	4.9%	60.9	30.5%
29.4	0.6	1.5%	26.2	65.5%	9.2	4.6%	60.4	30.2%
31	0.5	1.3%	26.1	65.3%	8.6	4.3%	59.8	29.9%
34	0.5	1.2%	26.1	65.2%	7.6	3.8%	58.8	29.4%
37	0.4	1.0%	26.0	65.0%	6.8	3.4%	58.0	29.0%

We consider that this assessment demonstrated that a significant proportion of the PC is generated by the engine. The operator did not confirm how the engine stack height of 9m was selected or demonstrate that it is BAT for stack height. We have therefore included preoperational condition PO9.

(ii) Particulate matter PM<sub>10</sub> and PM<sub>2.5</sub>

The impact on air quality from particulate emissions has been assessed against the ES for PM<sub>10</sub> (particles of 10 microns and smaller) and PM<sub>2.5</sub> (particles of 2.5 microns and smaller). For PM<sub>10</sub>, the ES are a long term annual average of 40  $\mu\text{g}/\text{m}^3$  and a short term daily average of 50  $\mu\text{g}/\text{m}^3$ . For PM<sub>2.5</sub> the ES of 25  $\mu\text{g}/\text{m}^3$  as a long-term annual average to be achieved by 2010 as a Target Value and by 2015 as a Limit Value has been used.

The Applicant's predicted impact of the Installation against these ESs is shown in the tables above. The assessment assumes that **all** particulate emissions are present as PM<sub>10</sub> for the PM<sub>10</sub> assessment and that **all** particulate emissions are present as PM<sub>2.5</sub> for the PM<sub>2.5</sub> assessment.

The above assessment is considered to represent a worst case assessment in that: -

- It assumes all particulates emitted are below either 10 microns (PM<sub>10</sub>) or 2.5 microns (PM<sub>2.5</sub>), when some are expected to be larger.

We have reviewed the Applicant's particulate matter impact assessment and are satisfied in the robustness of the Applicant's conclusions.

The above assessment shows that the predicted process contribution for emissions of PM<sub>10</sub> is below 1% of the long term ES and below 10% of the short term ES and so can be screened out as insignificant. Therefore we consider the Applicant's proposals for preventing and minimising the emissions of particulates to be BAT for the Installation.

The above assessment also shows that the predicted process contribution for emissions of PM<sub>2.5</sub> is also below 1% of the ES. Therefore the Environment Agency concludes that particulate emissions from the installation, including emissions of PM<sub>10</sub> or PM<sub>2.5</sub>, will not give rise to significant pollution.

There is currently no emission limit prescribed nor any continuous emissions monitor for particulate matter specifically in the PM<sub>10</sub> or PM<sub>2.5</sub> fraction. Whilst the Environment Agency is confident that current monitoring techniques will capture the fine particle fraction (PM<sub>2.5</sub>) for inclusion in the measurement of total particulate matter, an improvement condition (IC2) has been included that will require a full analysis of particle size distribution in the flue gas, and hence determine the ratio of fine to coarse particles. In the light of current knowledge and available data however the Environment Agency is satisfied that the health of the public would not be put at risk by such emissions, as explained in section 5.3.3.

(iii) Acid gases, SO<sub>2</sub>, HCl and HF

From the tables above, emissions of HCl and HF can be screened out as insignificant in that the process contribution is <10% of the short term ES. There is no long term ES for HCl. HF has 2 assessment criteria – a 1-hr ES and a monthly EAL – the process contribution is <1% of the monthly EAL and so the emission screens out as insignificant if the monthly ES is interpreted as representing a long term ES.

There is no long term EAL for SO<sub>2</sub> for the protection of human health. Protection of ecological receptors from SO<sub>2</sub> for which there is a long term ES is considered in section 5.4.

Emissions of SO<sub>2</sub> can also be screened out as insignificant in that the short term process contribution is also <10% of each of the three short term ES values. Therefore we consider the Applicant's proposals for preventing and minimising the emissions of these substances to be BAT for the Installation.

(iv) Emissions to Air of CO, VOCs, PAHs, PCBs and NH<sub>3</sub>

The above tables show that for CO and VOC emissions, the peak long term PC is greater than 1% of the ES and therefore cannot be screened out as insignificant. Even so, from the table above, the emission is not expected to result in the ES being exceeded. The peak short term PC for CO is marginally above the level that would screen out as insignificant (>10% of the ES). However it is not expected to result in the ES being exceeded.

The Applicant has used the ES for 1,3 butadiene for their assessment of the impact of VOC. This is based on 1,3 butadiene having the lowest ES of organic species likely to be present in VOC (other than PAH, PCBs, dioxins and furans).

The above tables show that for PCB emissions, the peak long term PC is less than 1% of the ES and the peak short term PC is less than 10% of the ES for and so can be screened out as insignificant. Therefore we consider the

Applicant's proposals for preventing and minimising the emissions of these substances to be BAT for the Installation.

The above tables show that for PAH, the peak long term PC is greater than 1% of the ES and therefore cannot be screened out as insignificant.

For PAH the applicant states that the PEC exceeds the environmental standard due to making a conservative assumption that all PAHs are made up of Benzo(a)pyrene (BaP). The above levels of predicted impact note that the exceedance occurs at the point of maximum impact on the grid and the predicted impacts at relevant receptor locations are 31% of the environmental standard. At these levels we consider it unlikely that this PC would result in an exceedance of an EAL.

The Applicant has also used the ES for benzo[a]pyrene (BaP) for their assessment of the impact of PAH. We agree that the use of the BaP ES is sufficiently precautionary.

The Applicant is required to prevent, minimise and control PAH and VOC emissions using BAT, this is considered further in Section 6. We are satisfied that PAH and VOC emissions will not result in significant pollution.

There is no ES for dioxins and furans as the principal exposure route for these substances is by ingestion and the risk to human health is through the accumulation of these substances in the body over an extended period of time. This issue is considered in more detail in section 5.3.

From the tables above ammonia emissions can be screened out as insignificant in that the process contribution is <1% of the long term ES and <10% of the short term ES.

The ammonia emission is based on a release concentration of 10 mg/m<sup>3</sup>. We are satisfied that this level of emission is consistent with the operation of a well controlled SNCR NO<sub>x</sub> abatement system.

The Applicant has also used the ES for benzo[a]pyrene (BaP) for their assessment of the impact of PAH. We agree that the use of the BaP ES is sufficiently precautionary.

#### (V) Summary

For the above emissions to air, for those emissions that do not screen out, we have carefully scrutinised the Applicant's proposals to ensure that they are applying the BAT to prevent and minimise emissions of these substances. This is reported in section 6 of this document. Therefore we consider the Applicant's proposals for preventing and minimising emissions to be BAT for the Installation. Dioxins and furans are considered further in section 5.3.2.

#### 5.2.3 Assessment of Emission of Metals

The Applicant has assessed the impact of metal emissions to air, as previously described.



There are three sets of BAT AELs for metal emissions:

- An emission limit value of 0.02 mg/m<sup>3</sup> for mercury and its compounds (formerly WID group 1 metals).
- An aggregate emission limit value of 0.02 mg/m<sup>3</sup> for cadmium and thallium and their compounds (formerly WID group 2 metals).
- An aggregate emission limit of 0.3 mg/m<sup>3</sup> for antimony, arsenic, lead, chromium, cobalt, copper, manganese, nickel and vanadium and their compounds (formerly WID group 3 metals).

In addition the UK is a Party to the Heavy Metals Protocol within the framework of the UN-ECE Convention on long-range trans-boundary air pollution. Compliance with the IED Annex VI emission limits for metals along with the Application of BAT also ensures that these requirements are met.

In section 5.2.1 above, the following emissions of metals were screened out as insignificant

- Mercury (Hg), antimony (Sb), lead (Pb), copper (Cu), vanadium (V), chromium (II)(III).

Also in section 5.2.1, the following emissions of metals whilst not screened out as insignificant were assessed as being unlikely to give rise to significant pollution:

- cadmium (Cd), manganese (Mn), arsenic (As), nickel (Ni)

This left emissions of chromium VI requiring further assessment. For all other metals, the Applicant has concluded that exceedences of the EAL for all metals are not likely to occur.

### **Emissions of chromium VI**

For Chromium (VI) the applicant states that the PEC exceeds the environmental standard due to existing elevated background concentration. However, we note that their long term PC is 1.7% which is above the insignificance threshold of 1%.

Our Air Quality and Modelling Assessment Unit have carried out further audit and sensitivity check on the potential for pollution from Chromium VI. This investigation indicated that the Chromium VI PC at human receptors using the maximum measured emission concentration from table A1 of the latest version of our Metals guidance <sup>[1]</sup> demonstrates that we can consider contributions from the facility to be insignificant at human receptors.

We believe the applicant used the mean measured Chromium concentrations shown in table A1 of the guidance. We have used the maximum concentration as a conservative approach, however, this assumption might also be conservative when considering the following aspects:

- The nature of the refuse derive fuel might not necessarily contain Chromium (VI)
- The proposed cleaning systems to upgrade the waste gas to feed the engine may result in lower emissions of Chromium VI.

[1] Releases from waste incinerators – Guidance on assessing group 3 metal stack emissions from incinerators, Version 4.

<https://www.gov.uk/government/publications/waste-incinerators-guidance-on-impact-assessment-for-group-3-metals-stack>

Based on the conclusions of this assessment, we consider it unlikely that chromium VI would cause an exceedance of the EAL at the sensitive receptors.

The installation has been assessed as meeting BAT for control of metal emissions to air. See section 6 of this document.

### **5.3 Human health risk assessment**

#### **5.3.1 Our role in preventing harm to human health**

The Environment Agency has a statutory role to protect the environment and human health from all processes and activities it regulates. We assessed the effects on human health for this application in the following ways:

##### **i) Applying Statutory Controls**

The plant will be regulated under EPR. These regulations include the requirements of relevant EU Directives, notably, the industrial emissions directive (IED), the waste framework directive (WFD), and ambient air directive (AAD).

The main conditions in an EfW permit are based on the requirements of the IED. Specific conditions have been introduced to specifically ensure compliance with the requirements of Chapter IV. The aim of the IED is to prevent or, where that is not practicable, to reduce emissions to air, water and land and prevent the generation of waste, in order to achieve a high level of protection of the environment taken as a whole. IED achieves this aim by setting operational conditions, technical requirements and emission limit values to meet the requirements set out in Articles 11 and 18 of the IED. These requirements may in some circumstances dictate tighter emission limits and controls than those set out in the BAT conclusions or Chapter IV of IED on waste incineration and co-incineration plants. The assessment of BAT for this installation is detailed in section 6 of this document.

##### **ii) Environmental Impact Assessment**

Industrial activities can give rise to odour, noise and vibration, accidents, fugitive emissions to air and water, releases to air (including the impact on Photochemical Ozone Creation Potential (POCP)), discharges to ground or groundwater, global warming potential and generation of waste. For an installation of this kind, the principal environmental effects are through emissions to air, although we also consider all of the other impacts listed. Section 5.1 and 5.2 above explain how we have approached the critical issue of assessing the likely impact of the emissions to air from the Installation on human health and the environment and any measures we are requiring to ensure a high level of protection.

### iii) Expert Scientific Opinion

We take account of the views of national and international expert bodies. The gathering of evidence is a continuing process. Although gathering evidence is not our role we keep the available evidence under review. The following is a summary of some of the publications which we have considered (in no particular order).

An independent review of evidence on the health effects of municipal waste incinerators was published by **DEFRA** in 2004. It concluded that there was no convincing link between the emissions from MSW incinerators and adverse effects on public health in terms of cancer, respiratory disease or birth defects. On air quality effects, the report concluded “Waste incinerators contribute to local air pollution. This contribution, however, is usually a small proportion of existing background levels which is not detectable through environmental monitoring (for example, by comparing upwind and downwind levels of airborne pollutants or substances deposited to land). In some cases, waste incinerator facilities may make a more detectable contribution to air pollution. Because current MSW incinerators are located predominantly in urban areas, effects on air quality are likely to be so small as to be undetectable in practice.”

**HPA** (now PHE) in 2009 stated that “The Health Protection Agency has reviewed research undertaken to examine the suggested links between emissions from municipal waste incinerators and effects on health. While it is not possible to rule out adverse health effects from modern, well regulated municipal waste incinerators with complete certainty, any potential damage to the health of those living close-by is likely to be very small, if detectable”.

In 2012 the UK Small Area Health Statistics Unit (SAHSU) at Imperial College was commissioned by Public Health England (PHE) to carry out a study to extend the evidence base and to provide further information to the public about any potential reproductive and infant health risks from municipal waste incineration (MWIs).

A number of papers have been published by SAHSU since 2012 which show no effect on birth outcomes. One paper in the study looked at exposure to emissions from MWIs in the UK and concluded that exposure was low. Subsequent papers found no increased risk of a range of birth outcomes (including stillbirth and infant mortality) in relation to exposure to PM10 emissions and proximity to MWIs, and no association with MWIs opening on changes in risks of infant mortality or sex ratio.

The final part of the study, published on 21/06/19, found no evidence of increased risk of congenital anomalies from exposure to MWI chimney emissions, but a small potential increase in risk of congenital anomalies for children born within ten kilometres of MWIs. The paper does not demonstrate a causal effect, and it acknowledges that the observed results may well be down to not fully adjusting the study for factors such as other sources of pollution around MWIs or deprivation.

PHE have stated that 'While the conclusions of the study state that a causal effect cannot be excluded, the study does not demonstrate a causal association and makes clear that the results may well reflect incomplete control for confounding i.e. insufficiently accounting for other factors that can cause congenital anomalies, including other sources of local pollution. This possible explanation is supported by the fact no increased risk of congenital anomalies was observed as a result of exposure to emissions from an incinerator.'

Following this study, PHE have further stated that 'PHE's position remains that modern, well run and regulated municipal waste incinerators are not a significant risk to public health, and as such our advice to you [i.e. the Environment Agency] on incinerators is unchanged.'

The **Committee on Carcinogenicity of Chemicals in Food, Consumer Products and the Environment (CoC)** issued a statement in 2000 which said that "any potential risk of cancer due to residency (for periods in excess of 10 years) near to municipal solid waste incinerators was exceedingly low and probably not measurable by the most modern epidemiological techniques." In 2009, CoC considered six further relevant epidemiological papers that had been published since the 2000 statement, and concluded that "there is no need to change the advice given in the previous statement in 2000 but that the situation should be kept under review".

**Republic of Ireland Health Research Board** report stated that "It is hard to separate the influences of other sources of pollutants, and other causes of cancer and, as a result, the evidence for a link between cancer and proximity to an incinerator is not conclusive".

The **Food Safety Authority of Ireland (FSAI) (2003)** investigated possible implications on health associated with food contamination from waste incineration and concluded: "In relation to the possible impact of introduction of waste incineration in Ireland, as part of a national waste management strategy, on this currently largely satisfactory situation, the FSAI considers that such incineration facilities, if properly managed, will not contribute to dioxin levels in the food supply to any significant extent. The risks to health and sustainable development presented by the continued dependency on landfill as a method of waste disposal far outweigh any possible effects on food safety and quality."

**Health Protection Scotland (2009)** considered scientific studies on health effects associated with the incineration of waste particularly those published after the Defra review discussed earlier. The main conclusions of this report were: "(a) For waste incineration as a whole topic, the body of evidence for an association with (non-occupational) adverse health effects is both inconsistent and inconclusive. However, more recent work suggests, more strongly, that there may have been an association between emissions (particularly dioxins) in the past from industrial, clinical and municipal waste incinerators and some forms of cancer, before more stringent regulatory requirements were

implemented. (b) For individual waste streams, the evidence for an association with (non-occupational) adverse health effects is inconclusive. (c) The magnitude of any past health effects on residential populations living near incinerators that did occur is likely to have been small. (d) Levels of airborne emissions from individual incinerators should be lower now than in the past, due to stricter legislative controls and improved technology. Hence, any risk to the health of a local population living near an incinerator, associated with its emissions, should also now be lower.”

The **US National Research Council Committee on Health Effects of Waste Incineration (NRC) (NRC 2000)** reviewed evidence as part of a wide ranging report. The Committee view of the published evidence was summarised in a key conclusion: “Few epidemiological studies have attempted to assess whether adverse health effects have actually occurred near individual incinerators, and most of them have been unable to detect any effects. The studies of which the committee is aware that did report finding health effects had shortcomings and failed to provide convincing evidence. That result is not surprising given the small populations typically available for study and the fact that such effects, if any, might occur only infrequently or take many years to appear. Also, factors such as emissions from other pollution sources and variations in human activity patterns often decrease the likelihood of determining a relationship between small contributions of pollutants from incinerators and observed health effects. Lack of evidence of such relationships might mean that adverse health effects did not occur, but it could mean that such relationships might not be detectable using available methods and sources.”

The **British Society for Ecological Medicine (BSEM) published a report in 2005** on the health effects associated with incineration and concluded that “Large studies have shown higher rates of adult and childhood cancer and also birth defects around municipal waste incinerators: the results are consistent with the associations being causal. A number of smaller epidemiological studies support this interpretation and suggest that the range of illnesses produced by incinerators may be much wider. Incinerator emissions are a major source of fine particulates, of toxic metals and of more than 200 organic chemicals, including known carcinogens, mutagens, and hormone disrupters. Emissions also contain other unidentified compounds whose potential for harm is as yet unknown, as was once the case with dioxins. Abatement equipment in modern incinerators merely transfers the toxic load, notably that of dioxins and heavy metals, from airborne emissions to the fly ash. This fly ash is light, readily windborne and mostly of low particle size. It represents a considerable and poorly understood health hazard.”

The BSEM report was reviewed by the HPA and they concluded that “Having considered the BSEM report the HPA maintains its position that contemporary and effectively managed and regulated waste incineration processes contribute little to the concentrations of monitored pollutants in ambient air and that the emissions from such plants have little effect on health.” The BSEM report was also commented on by the consultants who produced the Defra 2004 report referred to above. They said that “It fails to consider the

significance of incineration as a source of the substances of concern. It does not consider the possible significance of the dose of pollutants that could result from incinerators. It does not fairly consider the adverse effects that could be associated with alternatives to incineration. It relies on inaccurate and outdated material. In view of these shortcomings, the report's conclusions with regard to the health effects of incineration are not reliable.”

A **Greenpeace** review on incineration and human health concluded that a broad range of health effects have been associated with living near to incinerators as well as with working at these installations. Such effects include cancer (among both children and adults), adverse impacts on the respiratory system, heart disease, immune system effects, increased allergies and congenital abnormalities. Some studies, particularly those on cancer, relate to old rather than modern incinerators. However, modern incinerators operating in the last few years have also been associated with adverse health effects.”

The Health Protection Scotland report referred to above says that “the authors of the Greenpeace review do not explain the basis for their conclusion that there is an association between incineration and adverse effects in terms of criteria used to assess the strength of evidence. The weighting factors used to derive the assessment are not detailed. The objectivity of the conclusion cannot therefore be easily tested.”

From this published body of scientific opinion, we take the view stated by the HPA that “While it is not possible to rule out adverse health effects from modern, well regulated municipal waste incinerators with complete certainty, any potential damage to the health of those living close-by is likely to be very small, if detectable”. We therefore ensure that permits contain conditions which require the installation to be well-run and regulate the installation to ensure compliance with such permit conditions.

#### **iv) Health Risk Models**

Comparing the results of air dispersion modelling as part of the Environmental Impact assessment against European and national air quality standards effectively makes a health risk assessment for those pollutants for which a standard has been derived. These air quality standards have been developed primarily in order to protect human health via known intake mechanisms, such as inhalation and ingestion. Some pollutants, such as dioxins, furans and dioxin like PCBs, have human health impacts at lower ingestion levels than lend themselves to setting an air quality standard to control against. For these pollutants, a different human health risk model is required which better reflects the level of dioxin intake.

Models are available to predict the dioxin, furan and dioxin like PCBs intake for comparison with the Tolerable Weekly Intake (TWI) recommended by the Committee on Toxicity of Chemicals in Food, Consumer Products and the Environment, known as COT. These include the HHRAP model.

HHRAP has been developed by the US EPA to calculate the human body intake of a range of carcinogenic pollutants and to determine the mathematic

quantitative risk in probabilistic terms. In the UK, in common with other European Countries, we consider a threshold dose below which the likelihood of an adverse effect is regarded as being very low or effectively zero.

The TWI is the amount of a substance that can be ingested daily over a lifetime without appreciable health risk. It is expressed in relation to bodyweight in order to allow for different body size, such as for children of different ages. In the UK, the COT has set a TWI for dioxins, furans and dioxin like PCB's of 2 picograms I-TEQ/Kg-body weight/week (N.B. a picogram is a millionth of a millionth (10<sup>-12</sup>) of a gram).

In addition to an assessment of risk from dioxins, furans and dioxin like PCB's, the HHRAP model enables a risk assessment from human intake of a range of heavy metals. In principle, the respective ES for these metals are protective of human health. It is not therefore necessary to model the human body intake.

COMEAP developed a methodology based on the results of time series epidemiological studies which allows calculation of the public health impact of exposure to the classical air pollutants (NO<sub>2</sub>, SO<sub>2</sub> and particulates) in terms of the numbers of "deaths brought forward" and the "number of hospital admissions for respiratory disease brought forward or additional". COMEAP has issued a statement expressing some reservations about the applicability of applying its methodology to small affected areas. Those concerns generally relate to the fact that the exposure-response coefficients used in the COMEAP report derive from studies of whole urban populations where the air pollution climate may differ from that around a new industrial installation. COMEAP identified a number of factors and assumptions that would contribute to the uncertainty of the estimates. These were summarised in the Defra review as below:

- Assumption that the spatial distribution of the air pollutants considered is the same in the area under study as in those areas, usually cities or large towns, in which the studies which generated the coefficients were undertaken.
- Assumption that the temporal pattern of pollutant concentrations in the area under study is similar to that in the areas in which the studies which generated the coefficients were undertaken (i.e. urban areas).
- It should be recognised that a difference in the pattern of socio-economic conditions between the areas to be studied and the reference areas could lead to inaccuracy in the predicted level of effects.
- In the same way, a difference in the pattern of personal exposures between the areas to be studied and the reference areas will affect the accuracy of the predictions of effects.

The use of the COMEAP methodology is not generally recommended for modelling the human health impacts of individual installations. However it may have limited applicability where emissions of NO<sub>x</sub>, SO<sub>2</sub> and particulates cannot be screened out as insignificant in the Environmental Impact

assessment, there are high ambient background levels of these pollutants and we are advised that its use was appropriate by our public health consultees.

Our recommended approach is therefore the use of the methodology set out in our guidance for comparison for most pollutants (including metals) and dioxin intake model using the HHRAP model as described above for dioxins, furans and dioxin like PCBs. Where an alternative approach is adopted for dioxins, we check the predictions ourselves.

#### **v) Consultations**

As part of our normal procedures for the determination of a permit application, we consult with Local Authorities, Local Authority Directors of Public Health, FSA and PHE. We also consult the local communities who may raise health related issues. All issues raised by these consultations are considered in determining the application as described in Annex 4 of this document.

#### **5.3.2 Assessment of Intake of Dioxins, Furans and Dioxin like PCBs**

For dioxins, furans and dioxin like PCBs, the principal exposure route is through ingestion, usually through the food chain, and the main risk to health is through accumulation in the body over a period of time.

The human health risk assessment calculates the dose of dioxins and furans that would be received by local receptors if their food and water were sourced from the locality where the deposition of dioxins, furans and dioxin like PCBs is predicted to be the highest.

We reviewed the results of the Applicant's assessment of dioxin intake taking into account the lower TDI of approximately 0.9 picograms I-TEQ / Kg bodyweight/day, which would be reflective of the new TWI. The results showed that the predicted daily intake of dioxins, furans and dioxin like PCBs at all receptors, resulting from emissions from the proposed facility, were significantly below the recommended TWI levels.

The applicant's predicted maximum intake PC at receptor (farmer adult) is 0.0018 pgTEQ/kg(BW)/day, which is 0.63% of a TDI of 0.29 pgTEQ/kg(BW)/day and the predicted maximum intake PC at receptor (farmer child) is 0.0058 pgTEQ/kg(BW)/day which is 2.28% of 0.29 pgTEQ/kg(BW)/day. However, this is likely to be a significant overestimation of the impacts due to an overly-conservative dry deposition velocity assumption.

Our HHRA screening checks indicated that the PC is likely to be less than 10% of a TDI of 0.29 pgTEQ/kg(BW)/day for the most sensitive receptors, and is therefore not considered to be significant.

Based on a paper by the European Food Safety Authority (EFSA) the COT have recently revised their advice on dioxin/dioxin like PCBs. This has resulted in a change from a tolerable daily intake (TDI) of 2pg I-TEQ/Kg-body weight to a tolerable weekly intake (TWI) of 2pg I-TEQ/Kg-body weight. We have checked the Applicant's assessment taking the revised tolerable intake



into account and we are satisfied that the conclusions of the assessment are not affected and that impacts will not be significant.

The FSA has reported that dietary studies have shown that estimated total dietary intakes of dioxins and dioxin-like PCBs from all sources by all age groups fell by around 50% between 1997 and 2001, and are expected to continue to fall. A report in 2012 showed that Dioxin and PCB levels in food have fallen slightly since 2001. In 2001, the average daily intake by adults in the UK from diet was 0.9 pg WHO-TEQ/kg bodyweight. The additional daily intake predicted by the modelling as shown in the table above is substantially below this figure.

In 2010, FSA studied the levels of chlorinated, brominated and mixed (chlorinated-brominated) dioxins and dioxin-like PCBs in fish, shellfish, meat and eggs consumed in UK. It asked COT to consider the results and to advise on whether the measured levels of these PXDDs, PXDFs and PXBs indicated a health concern ('X' means a halogen). COT issued a statement in December 2010 and concluded that "The major contribution to the total dioxin toxic activity in the foods measured came from chlorinated compounds. Brominated compounds made a much smaller contribution, and mixed halogenated compounds contributed even less (1% or less of Tolerable Daily Intake: NB: now Tolerable Weekly Intake as of 2019). Measured levels of PXDDs, PXDFs and dioxin-like PXBs do not indicate a health concern". COT recognised the lack of quantified TEFs for these compounds but said that "even if the TEFs for PXDDs, PXDFs and dioxin-like PXBs were up to four fold higher than assumed, their contribution to the total TEQ in the diet would still be small. Thus, further research on PXDDs, PXDFs and dioxin-like PXBs is not considered a priority."

In the light of this statement, we assess the impact of chlorinated compounds as representing the impact of all chlorinated, brominated and mixed dioxins / furans and dioxin like PCBs.

Based on a paper by the European Food Safety Authority (EFSA) the COT have recently revised their advice on dioxin/dioxin like PCBs. This has resulted in a change from a tolerable daily intake (TDI) of 2pg I-TEQ/Kg-body weight to a tolerable weekly intake (TWI) of 2pg I-TEQ/Kg-body weight. We have checked the Applicant's assessment taking the revised tolerable intake into account and we are satisfied that the conclusions of the assessment are not affected and that impacts will not be significant.

### 5.3.3 Particulates smaller than 2.5 microns

The Operator will be required to monitor particulate emissions using the method set out in Table S3.1 of Schedule 3 of the Permit. This method requires that the filter efficiency must be at least 99.5 % on a test aerosol with a mean particle diameter of 0.3 µm, at the maximum flow rate anticipated. The filter efficiency for larger particles will be at least as high as this. This means that particulate monitoring data effectively captures everything above 0.3 µm and much of what is smaller. It is not expected that particles smaller

than 0.3 µm will contribute significantly to the mass release rate / concentration of particulates because of their very small mass, even if present. This means that emissions monitoring data can be relied upon to measure the true mass emission rate of particulates.

Nano-particles are considered to refer to those particulates less than 0.1 µm in diameter (PM<sub>0.1</sub>). Questions are often raised about the effect of nano-particles on human health, in particular on children's health, because of their high surface to volume ratio, making them more reactive, and their very small size, giving them the potential to penetrate cell walls of living organisms. The small size also means there will be a larger number of small particles for a given mass concentration. However the HPA statement (referenced below) says that due to the small effects of incinerators on local concentration of particles, it is highly unlikely that there will be detectable effects of any particular incinerator on local infant mortality.

The HPA (now PHE) addresses the issue of the health effects of particulates in their September 2009 statement 'The Impact on Health of Emissions to Air from Municipal Incinerators'. It refers to the coefficients linking PM<sub>10</sub> and PM<sub>2.5</sub> with effects on health derived by COMEAP and goes on to say that if these coefficients are applied to small increases in concentrations produced, locally, by incinerators; the estimated effects on health are likely to be small. PHE note that the coefficients that allow the use of number concentrations in impact calculations have not yet been defined because the national experts have not judged that the evidence is sufficient to do so. This is an area being kept under review by COMEAP.

In December 2010, COMEAP published a report on The Mortality Effects of Long-Term Exposure to Particulate Air Pollution in the United Kingdom. It says that "a policy which aims to reduce the annual average concentration of PM<sub>2.5</sub> by 1 µg/m<sup>3</sup> would result in an increase in life expectancy of 20 days for people born in 2008." However, "The Committee stresses the need for careful interpretation of these metrics to avoid incorrect inferences being drawn – they are valid representations of population aggregate or average effects, but they can be misleading when interpreted as reflecting the experience of individuals."

PHE also point out that in 2007 incinerators contributed 0.02% to ambient ground level PM<sub>10</sub> levels compared with 18% for road traffic and 22% for industry in general. PHE noted that in a sample collected in a day at a typical urban area the proportion of PM<sub>0.1</sub> is around 5-10% of PM<sub>10</sub>. It goes on to say that PM<sub>10</sub> includes and exceeds PM<sub>2.5</sub> which in turn includes and exceeds PM<sub>0.1</sub>. The National Atmospheric Emissions Inventory (NAEI) figures show that in 2016 municipal waste incineration contributed 0.03% to ambient ground level PM<sub>10</sub> levels and 0.05% to ambient ground level PM<sub>2.5</sub> levels. The 2016 data also shows that road traffic contributed to 5.35% of PM<sub>10</sub> and 4.96% of PM<sub>2.5</sub> and that domestic wood burning contributed 22.4% to PM<sub>10</sub> and 34.3% of PM<sub>2.5</sub> levels.

This is consistent with the assessment of this application which shows emissions of PM<sub>10</sub> to air to be insignificant.

A 2016 a paper by Jones and Harrison concluded that ‘ultrafine particles (<100nm) in flue gases from incinerators are broadly similar to those in urban air and that after dispersion with ambient air ultrafine particle concentrations are typically indistinguishable from those that would occur in the absence of the incinerator.

We take the view, based on the foregoing evidence, that techniques which control the release of particulates to levels which will not cause harm to human health will also control the release of fine particulate matter to a level which will not cause harm to human health.

#### 5.3.4 Assessment of Health Effects from the Installation

We have assessed the health effects from the operation of this installation in relation to the above (sections 5.3.1 to 5.3.3). We have applied the relevant requirements of the national and European legislation in imposing the permit conditions. We are satisfied that compliance with these conditions will ensure protection of the environment and human health.

Taking into account all of the expert opinion available, we agree with the conclusion reached by PHE that “While it is not possible to rule out adverse health effects from modern, well regulated municipal waste incinerators with complete certainty, any potential damage to the health of those living close-by is likely to be very small, if detectable.”

In carrying out air dispersion modelling as part of the Environmental Impact assessment and comparing the predicted environmental concentrations with European and national air quality standards, the Applicant has effectively made a health risk assessment for many pollutants. These air quality standards have been developed primarily in order to protect human health.

The Applicant’s assessment of the impact from emissions to air indicated that the Installation emissions screen out as insignificant; where the impact of emissions have not been screened out as insignificant, the assessment, or our audit of the assessment still showed that the predicted environmental concentrations are well within air quality standards.

The Environment Agency has reviewed the methodology employed by the Applicant to carry out the health impact assessment. We were unable to replicate the consultants emission rates presented in the ‘Human Health Risk Assessment’ report. However, we have conducted our own HHRA screening checks using the worst case congener profile for the UK and agree with the consultants conclusions.

The assessment methodology has deliberately used assumptions to generate scenarios that will lead to overestimations of the risk to human health. We agree that this is an appropriate and conservative approach. We have

conducted our own HHRA screening checks using the US EPA HHRAP method and our own dispersion modelling checks.

Overall, taking into account the conservative nature of the impact assessment (i.e. that it is based upon an individual exposed for a life-time to the effects of the highest predicted relevant airborne concentrations and consuming mostly locally grown food), it was concluded that the operation of the proposed facility will not pose a significant carcinogenic or non-carcinogenic risk to human health.

Public Health England and the Local Authority Director of Public Health were consulted on the Application and concluded that they had no significant concerns regarding the risk to the health of humans from the installation. The Food Standards Agency was also consulted during the permit determination process and it concluded that it is unlikely that there will be any unacceptable effects on the human food chain as a result of the operations at the Installation. Details of any responses provided by Public Health England, the Local Authority Director of Public Health and the FSA to the consultation on this Application can be found in Annex 4.

The Environment Agency is therefore satisfied that the Applicant's conclusions presented above are soundly based and we conclude that the potential emissions of pollutants including dioxins, furans and metals from the proposed facility are unlikely to have an impact upon human health.

#### **5.4 Impact on Habitats sites, SSSIs, non-statutory conservation sites etc.**

##### 5.4.1 Sites Considered

The following Habitats (i.e. Special Areas of Conservation, Special Protection Areas and Ramsar) sites are located within 10km of the Installation:

- Fens Pool Special Area of Conservation (SAC) at 4729m from the installation.

The following Site of Special Scientific Interest (SSSI) is located within 2km of the Installation:

- Wren's Nest SSSI located 1270m from the installation.

There are 32 non-statutory local wildlife and conservation sites located within 2km of the Installation the closest of which are:

- Birmingham Canal Local Wildlife Site (LWS) at 52m from the installation
- Princes End Triangle LWS at 423m from the installation
- Princes End Disused Railway LWS at 542m from the installation
- Coseley Canal Cutting LWS at 585m from the installation

##### 5.4.2 Habitats Assessment

The Applicant's Habitats assessment was reviewed by the Environment Agency's technical specialists for modelling, air quality, conservation and ecology technical services, who agreed with the assessment's conclusions, that there would be no likely significant effect on the interest features of the protected site.

### Predicted impact on Fens Pool Special Area of Conservation

Pollutant	ES / EAL ( $\mu\text{g}/\text{m}^3$ )	Back-ground ( $\mu\text{g}/\text{m}^3$ )	Process Contribution (PC) ( $\mu\text{g}/\text{m}^3$ )	PC as % of ES	Predicted Environmental Concentration (PEC) ( $\mu\text{g}/\text{m}^3$ ) <sup>(3)</sup>	PEC as % ES
<b>Direct Impacts<sup>2</sup></b>						
NO <sub>x</sub> Annual	30	-	0.09	0.30	-	-
NO <sub>x</sub> Daily Mean	75	-	1.60	2.13	-	-
SO <sub>2</sub>	20 <sup>(1)</sup>	-	0.01	0.05	-	-
Ammonia	3 <sup>(1)</sup>	-	0.01	0.33	-	-
HF Weekly Mean	0.5	0	0.01	2.00	0.01	2.00
HF Daily Mean	5	-	0.01	0.18	-	-
<b>Deposition Impacts<sup>2</sup></b>						
N Deposition (kg N/ha/yr)	10	-	0.055	0.55	-	-
Acidification (Keq/ha/yr)	2.65	-	0.009	0.33	-	-
<p>(1) The lichen and bryophyte sensitivity standards for ammonia are based on information contained in APIS in January 2020.</p> <p>(2) Direct impact units are <math>\mu\text{g}/\text{m}^3</math> and deposition impact units are kg N/ha/yr or Keq/ha/yr.</p> <p>(3) Where the long term PC screens out at &lt;1% of the long term standard and the short term PC screens out at &lt;10% of the short term standard, the impact itself is considered insignificant and therefore the background is not considered in the assessment.</p>						

The PC for all parameters with the exception of long term HF are less than <1% of the long term and <10% of the short term critical loads or levels and therefore can be considered insignificant. We can therefore conclude no likely significant effect.

The PC is above 1% of the Critical Level for long term HF at 2% but when taking into account the background, it can be concluded that there will be no likely significant effect as the PEC is 2% of the Critical Level. There is significant headroom between the PEC and the Critical Level.

The Applicant did refer to background levels from an Air Quality Standards (EPAQS) draft report entitled 'Guidelines for halogen and hydrogen halides in ambient air for protecting human health against acute irritancy effects' when proposing a background level. Only a small number of measurements of ambient concentrations of HF have been made in the UK which were all in the vicinity of three industrial plants. Many samples were below the limit of

detection. Measurable values were in the range 0.05 to 3.5µg/m<sup>3</sup>. We do not consider based on the location of the habitats sites that there are likely sources of HF in the area and therefore we have assumed a background level of zero for the purpose of this assessment.

#### 5.4.3 SSSI Assessment

The Applicant's assessment of SSSIs was reviewed by the Environment Agency's technical specialists for modelling, air quality, conservation and ecology technical services, who agreed with the assessment's conclusions, that the proposal does not damage the special features of the SSSI.

#### **Predicted impact on Wren's Nest SSSI**

Pollutant	ES (µg/m <sup>3</sup> )	Back-ground (µg/m <sup>3</sup> )	Process Contribution (PC) (µg/m <sup>3</sup> )	PC as % of ES	Predicted Environmental Concentration (PEC) (µg/m <sup>3</sup> )	PEC as % ES
<b>Direct Impacts<sup>2</sup></b>						
NO <sub>x</sub> Annual	30	-	0.29	0.97	-	-
NO <sub>x</sub> Daily Mean	75	-	7.15	9.53	-	-
SO <sub>2</sub>	20 <sup>(1)</sup>	-	0.05	0.25	-	-
Ammonia	3 <sup>(1)</sup>	-	0.02	0.66	-	-
HF Weekly Mean	0.5	0	0.03	6.00	0.03	6.00
HF Daily Mean	5	-	0.04	0.79	-	-
<b>Deposition Impacts<sup>2</sup></b>						
N Deposition (kg N/ha/yr)	10	-	0.184	0.55	-	-
Acidification (Keq/ha/yr)	10.96	-	0.029	0.26	-	-
<p>(1) The lichen and bryophyte sensitivity standards for ammonia are based on information contained in APIS in January 2020.</p> <p>(2) Direct impact units are µg/m<sup>3</sup> and deposition impact units are kg N/ha/yr or Keq/ha/yr.</p> <p>(3) Where the long term PC screens out at &lt;1% of the long term standard and the short term PC screens out at &lt;10% of the short term standard, the impact itself is considered insignificant and therefore the background is not considered in the assessment.</p>						

The PC for all parameters with the exception of long term HF are less than <1% of the long term and <10% of the short term critical loads or levels and therefore can be considered insignificant. We can therefore conclude no likely damage.

The PC is above 1% of the Critical Level for long term HF at 6% but when taking into account the background, it can be concluded that there will be no likely significant effect as the PEC is 6% of the Critical Level. There is significant headroom between the PEC and the Critical Level.

See section 5.4.2 for additional information on background value for HF.

#### 5.4.4 Assessment of other conservation sites

Conservation sites are protected in law by legislation. The Habitats Directive provides the highest level of protection for SACs and SPAs, domestic legislation provides a lower but important level of protection for SSSIs. Finally the Environment Act provides more generalised protection for flora and fauna rather than for specifically named conservation designations. It is under the Environment Act that we assess other sites (such as local wildlife sites) which prevents us from permitting something that will result in significant pollution; and which offers levels of protection proportionate with other European and national legislation. However, it should not be assumed that because levels of protection are less stringent for these other sites that they are not of considerable importance. Local sites link and support EU and national nature conservation sites together and hence help to maintain the UK's biodiversity resilience.

For SACs SPAs, Ramsars and SSSIs we consider the contribution PC and the background levels in making an assessment of impact. In assessing these other sites under the Environment Act we look at the impact from the Installation alone in order to determine whether it would cause significant pollution. This is a proportionate approach, in line with the levels of protection offered by the conservation legislation to protect these other sites (which are generally more numerous than Natura 2000 or SSSIs) whilst ensuring that we do not restrict development.

Critical levels and loads are set to protect the most vulnerable habitat types. Thresholds change in accordance with the levels of protection afforded by the legislation. Therefore the thresholds for SAC, SPA and SSSI features are more stringent than those for other nature conservation sites.

The predicted impacts on locally designated sensitive habitats are not considered to be significant in accordance with Environment Agency guidance.

## **5.5 Impact of abnormal operations**

Article 50(4)(c) of IED requires that waste incineration and co-incineration plants shall operate an automatic system to prevent waste feed whenever any of the continuous emission monitors show that an emission limit value (ELV) is exceeded due to disturbances or failures of the purification devices. Notwithstanding this, Article 46(6) allows for the continued incineration and co-incineration of waste under such conditions provided that this period does not (in any circumstances) exceed 4 hours uninterrupted continuous operation or the cumulative period of operation does not exceed 60 hours in a calendar year. This is a recognition that the emissions during transient states (e.g. start-up and shut-down) are higher than during steady-state operation, and the overall environmental impact of continued operation with a limited exceedance of an ELV may be less than that of a partial shut-down and re-start.

For incineration plant, IED sets backstop limits for particulates, CO and TOC which must continue to be met at all times. The CO and TOC limits are the

same as for normal operation, and are intended to ensure that good combustion conditions are maintained. The backstop limit for particulates is 150 mg/m<sup>3</sup> (as a half hourly average) which is five times the limit in normal operation.

Article 45(1)(f) requires that the permit shall specify the maximum permissible period of any technically unavoidable stoppages, disturbances, or failures of the purification devices or the measurement devices, during which the concentrations in the discharges into the air may exceed the prescribed emission limit values. In this case we have decided to set the time limit at 4 hours, which is the maximum period prescribed by Article 46(6) of the IED.

These abnormal operations are limited to no more than a period of 4 hours continuous operation and no more than 60 hour aggregated operation in any calendar year. This is less than 1% of total operating hours and so abnormal operating conditions are not expected to have any significant long term environmental impact unless the background conditions were already close to, or exceeding, an ES. For the most part therefore consideration of abnormal operations is limited to consideration of its impact on short term ESs.

In making an assessment of abnormal operations the following worst case scenario has been assumed:

- Dioxin emissions of 10 ng/m<sup>3</sup> (100 x normal)
- Mercury emissions are 15 times those of normal operation
- NO<sub>x</sub> emissions of 500 mg/m<sup>3</sup> (2.5 x normal)
- Particulate emissions of 150 mg/m<sup>3</sup> (5 x normal)
- Metal emissions other than mercury are 15 times those of normal operation
- SO<sub>2</sub> emissions of 200 mg/m<sup>3</sup> (4 x normal)
- HCl emissions of 600 mg/m<sup>3</sup> (60 x normal)
- PCBs (100 x normal)

This is a worst case scenario in that these abnormal conditions include a number of different equipment failures not all of which will necessarily result in an adverse impact on the environment (e.g. a failure of a monitoring instrument does not necessarily mean that the incinerator or abatement plant is malfunctioning). This analysis assumes that any failure of any equipment results in all the negative impacts set out above occurring simultaneously.

The result on the Applicant's short-term environmental impact from abnormal operations is summarised in the table below.

Pollutant	EQS / EAL		Back-ground	Process Contribution (PC)		Predicted Environmental Concentration (PEC)	
	µg/m <sup>3</sup>			µg/m <sup>3</sup>	% of EAL	µg/m <sup>3</sup>	% of EAL
NO <sub>2</sub>	200	2	51.2	68.7	34.4	119.9	60.0



PM <sub>10</sub>	50	3	34	3.44	6.88	37.44	74.9
SO <sub>2</sub>	266	4	1.14	118.2	44.4	119.34	44.9
	350	5	1.14	85.2	24.34	86.34	24.7
HCl	750	6	0.48	353.5	47.133333	354.0	47.20
HF	160	6	7	53	33.125	60.00	37.5
Hg	7.5	1	0.0046	2.95	39.33	2.95460	39.395
Sb	150	1	0	0.1	0.07	0.10000	0.067
Cu	200	1	0.04672	0.26	0.13	0.30672	0.153
Mn	1500	1	0.01874	0.53	0.04	0.54874	0.0366
PCBs	6	1	0.0002	0.29	4.83	0.29020	4.8367
Cr (II)(III)	150	1	0.00437	0.81	0.54	0.81437	0.5429
Dioxins			1.05E-09	1.75E+00		1.75E+00	

- 1 1-hr Maximum
- 2 99.79<sup>th</sup> %ile of 1-hour means
- 3 90.41<sup>st</sup> %ile of 24-hour means
- 4 99.9<sup>th</sup> ile of 15-min means
- 5 99.73<sup>rd</sup> %ile of 1-hour means
- 6 1-hour average

From the table above the emissions of the following substances can still be considered insignificant, in that the PC is still <10% of the short-term ES.

- PM<sub>10</sub>, Sb, Cu, Mn, PCBs and Cr(II)(III)

Also from the table above emissions of the following emissions (which were not screened out as insignificant) have been assessed as being unlikely to give rise to significant pollution in that the predicted environmental concentration is less than 100% of short term ES.

- NO<sub>2</sub>, SO<sub>2</sub>, HCl, HF and Hg

We are therefore satisfied that it is not necessary to further constrain the conditions and duration of the periods of abnormal operation beyond those permitted under Chapter IV of the IED.

We have not assessed the impact of abnormal operations against long term ESs for the reasons set out above. Except that if dioxin emissions were at 10 ng/m<sup>3</sup> for the maximum period of abnormal operation, this would result in an increase of approximately 50% of the PC reported in section 5.3.3. In these circumstances the TWI would be less than 20% of the COT TWI. At this level, emissions of dioxins will still not pose a risk to human health.

## 5.6 Impact of emissions during OTNOC

IED article 14 (3) states that BAT conclusions shall be the reference for setting the permit conditions. Article 14 (3) states that the competent authority

shall set emission limit values that, under normal operating conditions, do not exceed the emission levels associated with the best available techniques as laid down in the decisions on BAT conclusions. These limits are set in Table S3.1. In addition, the IED also sets maximum limits for certain emissions that should not be exceeded and would still apply outside normal operating conditions. These limits are set in Tale S3.1(b) and are normally higher than the BAT AELs

The IED and BAT conclusions therefore make provision for plants to have short term fluctuations where BAT AELs could be exceeded but the IED limits are not other than under abnormal operation. These periods are called 'Other than normal operation.' (OTNOC). Although the BAT AELs can be exceeded during OTNOC setting BAT AELs as emission limits is controlling emissions because plants will need to ensure that the plant is capable of meeting the BAT AELs during normal operation which will apply for most of the time the plant is operational.

Although BAT AELs do not apply during periods of OTNOC the IED annex VI emission limits do still apply.

Periods of OTNOC will be of short duration and limited in nature. The Applicant used the IED annex VI half hour average limits to assess short term impacts, therefore no further specific assessment of the impacts during OTNOC was required.

Pre-operational condition PO1 requires the Operator to have an EMS and that the EMS will include an OTNOC management plan in line with BAT conclusions 1 and 18. The Operator will be required to identify potential OTNOC scenarios and any required monitoring in their management plan and will require our approval of scenarios before they can be classed as OTNOC. We may impose further monitoring and limits, through tale S3.1(b) of the Permit, once we have approved the OTNOC scenarios.

## **6. Application of Best Available Techniques**

### **6.1 Scope of Consideration**

In this section, we explain how we have determined whether the Applicant's proposals are the Best Available Techniques for this Installation.

- The first issue we address is the fundamental choice of incineration technology. There are a number of alternatives, and the Applicant has explained why it has chosen one particular kind for this Installation.
- We then consider in particular control measures for the emissions which were not screened out as insignificant in the previous section.
- We also have to consider the combustion efficiency and energy utilisation of different design options for the Installation, which are relevant

considerations in the determination of BAT for the Installation, including the Global Warming Potential of the different options.

- Finally, the prevention and minimisation of Persistent Organic Pollutants (POPs) must be considered, as we explain below.

Chapter IV of the IED specifies a set of maximum emission limit values. Although these limits are designed to be stringent, and to provide a high level of environmental protection, they do not necessarily reflect what can be achieved by new plant. Article 14(3) of the IED says that BAT Conclusions shall be the reference for setting the permit conditions, so it may be possible and desirable to achieve emissions below the limits referenced in Chapter IV. The BAT conclusions were published on 03 December 2019.

Even if the Chapter IV limits are appropriate, operational controls complement the emission limits and should generally result in emissions below the maximum allowed; whilst the limits themselves provide headroom to allow for unavoidable process fluctuations. Actual emissions are therefore almost certain to be below emission limits in practice, because any Operator who sought to operate its installation continually at the maximum permitted level would almost inevitably breach those limits regularly, simply by virtue of normal fluctuations in plant performance, resulting in enforcement action (including potentially prosecution) being taken. Assessments based on, say, Chapter IV limits are therefore “worst-case” scenarios.

Should the Installation, once in operation, emit at rates significantly below the limits included in the Permit, we will consider tightening ELVs appropriately. We are, however, satisfied that emissions at the permitted limits would ensure a high level of protection for human health and the environment in any event.

#### 6.1.1 Consideration of Furnace Type

The prime function of the furnace is to achieve maximum combustion of the waste. Chapter IV of the IED requires that the plant (furnace in this context) should be designed to deliver its requirements. The main requirements of Chapter IV in relation to the choice of a furnace are compliance with air emission limits for CO and TOC and achieving a low TOC/LOI level in the bottom ash.

The BREF describes process such as gasification and pyrolysis. The BREF notes that some of the processes have encountered technical and economic problems when scaled up to commercial, industrial sizes. Some are used on a commercial basis in Japan and are being tested in demonstration plants in Europe but still only have a small share of overall capacity.

The Applicant has selected use of a cyclone furnace, which is not specifically listed in the BREF and a pyrolysis process. The BAT assessment for these types of technology is included later on in this section of the decision document.

Section 4.3 of the BREF provides a comparison of combustion and thermal treatment technologies, used in Europe and factors affecting their applicability

and operational suitability for various waste types. There is also some information on the comparative costs. The table below has been extracted from the BREF tables. This table is also in line with the Guidance Note “The Incineration of Waste (EPR 5.01)). However, it should not be taken as an exhaustive list nor that all technologies listed have found equal application across Europe.

Overall, any of the furnace technologies listed below would be considered as BAT provided the Applicant has justified it in terms of:

- nature/physical state of the waste and its variability
- proposed plant throughput which may affect the number of incineration lines
- preference and experience of chosen technology including plant availability
- nature and quantity/quality of residues produced.
- emissions to air – usually NO<sub>x</sub> as the furnace choice could have an effect on the amount of unabated NO<sub>x</sub> produced
- energy consumption – whole plant, waste preparation, effect on GWP
- Need, if any, for further processing of residues to comply with TOC
- Costs

## Summary comparison of thermal treatment technologies (reproduced from the Waste Incineration BREF)

Technique	Key waste characteristics and suitability	Throughput per line	Advantages	Disadvantages / Limitations of use	Bottom Ash Quality	Cost
Moving grate (air-cooled)	<ul style="list-style-type: none"> <li>• Low to medium heat values (LCV 5 – 16.5 GJ/t)</li> <li>• Municipal and other heterogeneous solid wastes</li> <li>• Can accept a proportion of sewage sludge and/or medical waste with municipal waste</li> <li>• Applied at most modern MSW installations</li> </ul>	<ul style="list-style-type: none"> <li>• 1 to 50 t/h with most projects 5 to 30 t/h.</li> <li>• Most industrial applications not below 2.5 or 3 t/h.</li> </ul>	<ul style="list-style-type: none"> <li>• Widely proven at large scales.</li> <li>• Robust</li> <li>• Low maintenance cost</li> <li>• Long operational history</li> <li>• Can take heterogeneous wastes without special preparation</li> </ul>	<ul style="list-style-type: none"> <li>• Generally not suited to powders, liquids or materials that melt through the grate</li> </ul>	TOC 0.5% to 3%	High capacity reduces specific cost per tonne of waste
Moving grate (liquid Cooled)	Same as air-cooled grates except: LCV 10 – 20 GJ/t	Same as air-cooled grates	As air-cooled grates but: <ul style="list-style-type: none"> <li>• higher heat value waste is treatable</li> <li>• Better combustion control possible.</li> </ul>	As air-cooled grates but: <ul style="list-style-type: none"> <li>• risk of grate damage/ leaks</li> <li>• more complex</li> </ul>	TOC 0.5% to 3%	Slightly higher capital cost than air-cooled
Rotary Kiln	Can accept liquids and pastes as well as gases Solid feeds more limited than grate (due to refractory damage) often applied to hazardous Wastes	<16 t/h	<ul style="list-style-type: none"> <li>• Very well proven</li> <li>• Broad range of wastes</li> <li>• Good burn out even of HW</li> </ul>	Throughputs lower than grates	TOC <3 %	Higher specific cost due to reduced capacity
Fluid bed - bubbling	<ul style="list-style-type: none"> <li>• Wide range of CV (5-25 MJ/kg)</li> <li>• Only finely divided consistent wastes.</li> <li>• Limited use for raw MSW</li> <li>• Often applied to sludges co fired with RDF, shredded MSW, sludges, poultry manure</li> </ul>	Up to 25 t/h	<ul style="list-style-type: none"> <li>• Good mixing</li> <li>• Fly ashes of good leaching quality</li> </ul>	<ul style="list-style-type: none"> <li>• Careful operation required to avoid clogging bed.</li> <li>• Higher fly ash quantities.</li> </ul>	TOC <1%	FGT cost may be lower.  Costs of waste preparation
Fluid bed - circulating	<ul style="list-style-type: none"> <li>• Wide range of CV (6-25 MJ/kg)</li> <li>• Only finely divided consistent wastes.</li> <li>• Limited use for raw MSW</li> <li>• Often applied to sludges co-fired with RDF, coal, wood</li> </ul>	Up to 70 t/h	<ul style="list-style-type: none"> <li>• Good mixing</li> <li>• High steam parameters</li> <li>• Greater fuel flexibility than BFB</li> <li>• Good leaching quality fly ash</li> </ul>	<ul style="list-style-type: none"> <li>• Cyclone required to conserve bed material</li> <li>• Higher fly ash quantities</li> </ul>	TOC <1%	<ul style="list-style-type: none"> <li>• FGT cost may be lower.</li> <li>• Costs of waste preparation</li> </ul>

Technique	Key waste characteristics and suitability	Throughput per line	Advantages	Disadvantages / Limitations of use	Bottom Ash Quality	Cost
Spreader - stoker combustor	<ul style="list-style-type: none"> <li>• RDF and other particle feeds</li> <li>• Poultry manure</li> <li>• Wood wastes</li> </ul>	No information	<ul style="list-style-type: none"> <li>• Simple grate construction</li> <li>• Less sensitive to particle size than FB</li> </ul>	Only for well defined mono-streams	No information	No information
Gasification - fixed bed	<ul style="list-style-type: none"> <li>• Mixed plastic wastes</li> <li>• Other similar consistent streams</li> <li>• Gasification less widely used/proven than incineration</li> </ul>	Up to 20 t/h	<ul style="list-style-type: none"> <li>• Low leaching residue</li> <li>• Good burnout</li> <li>• Syngas available</li> <li>• Reduced oxidation of recyclable metals</li> </ul>	<ul style="list-style-type: none"> <li>• Limited waste feed</li> <li>• Not full combustion</li> <li>• High skill level</li> <li>• Tar in raw gas</li> <li>• Less widely proven</li> </ul>	<ul style="list-style-type: none"> <li>• Low leaching bottom ash</li> <li>• Good burnout with oxygen</li> </ul>	High operating/ maintenance costs
Gasification - entrained flow	<ul style="list-style-type: none"> <li>• Mixed plastic wastes</li> <li>• Other similar consistent streams</li> <li>• Not suited to untreated MSW</li> <li>• Gasification less widely used/proven than incineration</li> </ul>	Up to 10 t/h	<ul style="list-style-type: none"> <li>• Low leaching slag</li> <li>• Reduced oxidation of recyclable metals</li> </ul>	<ul style="list-style-type: none"> <li>• Limited waste feed</li> <li>• Not full combustion</li> <li>• High skill level</li> <li>• Less widely proven</li> </ul>	low leaching slag	<ul style="list-style-type: none"> <li>• High operation/ maintenance costs</li> <li>• High pre-treatment costs</li> </ul>
Gasification - fluidised bed	<ul style="list-style-type: none"> <li>• Mixed plastic wastes</li> <li>• Shredded MSW</li> <li>• Shredder residues</li> <li>• Sludges</li> <li>• Metal rich wastes</li> <li>• Other similar consistent streams</li> <li>• Gasification less widely used/proven than incineration</li> </ul>	5 – 20 t/h	<ul style="list-style-type: none"> <li>• Can use low reactor temperatures</li> <li>• Separation of main non combustibles</li> <li>• Can be combined with ash melting</li> <li>• Reduced oxidation of recyclable metals</li> </ul>	<ul style="list-style-type: none"> <li>• Limited waste size (&lt;30cm)</li> <li>• Tar in raw gas</li> <li>• Higher UHV raw gas</li> <li>• Less widely proven</li> </ul>	If combined with ash melting chamber ash is vitrified	Lower than other gasifiers
Pyrolysis	<ul style="list-style-type: none"> <li>• Pre-treated MSW</li> <li>• High metal inert streams</li> <li>• Shredder residues/plastics</li> <li>• Pyrolysis is less widely used/proven than incineration</li> </ul>	~ 5 t/h (short drum) 5 – 10 t/h (medium drum)	<ul style="list-style-type: none"> <li>• No oxidation of metals</li> <li>• No combustion energy for metals/inert</li> <li>• In reactor acid neutralisation possible</li> <li>• Syngas available</li> </ul>	<ul style="list-style-type: none"> <li>• Limited wastes</li> <li>• Process control and engineering critical</li> <li>• High skill level</li> <li>• Not widely proven</li> <li>• Need market for syngas</li> </ul>	<ul style="list-style-type: none"> <li>• Dependent on process temperature</li> <li>• Residue produced requires further processing and sometimes combustion</li> </ul>	High pre-treatment, operation and capital costs

The Applicant has proposed to use a furnace technology comprising a cyclone furnace and pyrolysis plant. We did not consider that adequate information was included in the application and therefore requested additional information on whether the proposed technology was BAT via a Schedule 5 notice dated 19 August 2019. The Applicant provided additional information on 18 September 2019.

The Applicant justified that the cyclone furnace represents BAT for the installation for the following reasons:

- Cyclone furnaces achieve high levels of combustion. CFD modelling has been used to predict combustion rates of 99.95% for the plant.
- The efficiency of the furnace is maximised and the amount of uncombusted material in the ash is minimised.
- Cyclone furnaces enable the temperature within the furnace to be controlled to the optimum required.
- The reaction time to changes by the control system are fast.
- Cyclone furnaces are more flexible in their feedstock requirements compared to a conventional furnace type.
- Cyclone furnaces are small in nature in comparison to counterparts. Given the compact nature of the site, a cyclone furnace is suited to maximise space efficiency.

The Applicant has justified that pyrolysis is BAT for the installation because the plant is intended to produce torrefied fuel products, not dispose of waste or recover energy from it (although the latter is a by-product). As pyrolysis is the only technique available for the production of torrefied fuel from biomass, it is considered to comprise BAT.

The Applicant proposes to use syngas and gasoil as auxiliary fuels for the cyclone furnace burner. The choice of support fuel is based on the following points presented in the application:

- High adiabatic flame temperatures (1600<sup>0</sup>C) can be achieved by the burner when fuelled on diesel and syngas to ensure fast heat up time and furnace de-slugging when required during maintenance periods.
- As stated within the Global Warming Potential Assessment, the emissions of carbon dioxide released if natural gas were used would be 91 tonnes per annum rather than 120 tonnes per annum using diesel, resulting in a saving of 29 tonnes. However, this represents only a 1.3% saving in the positive GWP contributions for the Site and is therefore not considered a significant saving. It should also be borne in mind that once the production of syngas has been established, that this will be used as an auxiliary fuel in place of diesel and therefore the absolute saving will be smaller in practice.
- Diesel is readily available with regular deliveries already being made to the site, meaning fewer lorry movements are required to the area than if natural gas needed to be imported in.

- The use of syngas as an auxiliary fuel is the most efficient way of using a by-product produced by the pyrolysis plant.

### Boiler Design

In accordance with BAT 30 of the BAT C and our Technical Guidance Note, EPR 5.01, the Applicant has confirmed that the cyclone furnace design will include the following features to minimise the potential for reformation of dioxins within the de-novo synthesis range:

- ensuring that the steam/metal heat transfer surface temperature is a minimum where the exhaust gases are within the de-novo synthesis range;
- design of the boilers using CFD to ensure no pockets of stagnant or low velocity gas;
- boiler passes are progressively decreased in volume so that the gas velocity increases through the boiler; and
- Design of boiler surfaces to prevent boundary layers of slow moving gas.

### 6.2 BAT and emissions control

The prime function of flue gas treatment is to reduce the concentration of pollutants in the exhaust gas as far as practicable. The techniques which are described as BAT individually are targeted to remove specific pollutants, but the BREF notes that there is benefit from considering the Flue Gas Cleaning System (FGC) system as a whole unit. Individual units often interact, providing a primary abatement for some pollutants and an additional effect on others.

The BREF lists the general factors requiring consideration when selecting flue-gas treatment (FGC) systems as:

- type of waste, its composition and variation
- type of combustion process, and its size
- flue-gas flow and temperature
- flue-gas content, including magnitude and rate of composition fluctuations
- target emission limit values
- restrictions on discharge of aqueous effluents
- plume visibility requirements
- land and space availability
- availability and cost of outlets for residues accumulated/recovered
- compatibility with any existing process components (existing plants)
- availability and cost of water and other reagents
- energy supply possibilities (e.g. supply of heat from condensing scrubbers)
- reduction of emissions by primary methods
- noise
- arrangement of different flue-gas cleaning devices if possible with decreasing flue-gas temperatures from boiler to stack

Taking these factors into account the Technical Guidance Note points to a range of technologies being BAT subject to circumstances of the Installation.



### 6.2.1 Particulate Matter

<b>Particulate matter</b>				
<b>Technique</b>	<b>Advantages</b>	<b>Disadvantages</b>	<b>Optimisation</b>	<b>Defined as BAT in BREF or TGN for:</b>
<b>Bag / Fabric filters (BF)</b>	Reliable abatement of particulate matter to below 5mg/m <sup>3</sup>	Max temp 250°C Higher energy use than ESP Sensitive to condensation and corrosion	Multiple compartments  Bag burst detectors	Most plants
<b>Wet scrubbing</b>	May reduce acid gases simultaneously.	Not normally BAT.  Liquid effluent produced	Require reheat to prevent visible plume and dew point problems.	Where scrubbing required for other pollutants
<b>Ceramic filters</b>	High temperature applications  Smaller plant.	May "blind" more than fabric filters		Small plant.  High temperature gas cleaning required.
<b>Electrostatic precipitators</b>	Low pressure gradient. Use with BF may reduce the energy consumption of the induced draft fan.	Not normally BAT by itself Risk of dioxin formation if used in 200-400°C range		When used with other particulate abatement plant

The Applicant proposes not to use fabric filters for the abatement of particulate matter and proposes to use a combination of a cyclone and wet scrubbing for removal of particulates. The Applicant has justified this by through the following points:

- The proposed is required to achieve the quality of syngas that has to be reached before it is combusted in the engines.
- Cyclones are an integral part of the cyclone furnace and a bag filter can't be used as an alternative due to the location of the plant. The particulate removal is required prior to the heat recovery boiler and the heat transfer manifolds and therefore the gases would be too hot at this point for a bag filter.

Emissions of particulate matter have been previously screened out as insignificant, and so the Environment Agency agrees that the Applicant's proposed technique is BAT for the installation.

### 6.2.2 Oxides of Nitrogen

<b>Oxides of Nitrogen : Primary Measures</b>				
<b>Technique</b>	<b>Advantages</b>	<b>Disadvantages</b>	<b>Optimisation</b>	<b>Defined as BAT in BREF or TGN for:</b>

<b>Low NOx burners</b>	Reduces NOx at source		Start-up, supplementary firing.	Where auxiliary burners required.
<b>Starved air systems</b>	Reduce CO simultaneously.			Pyrolysis, Gasification systems.
<b>Optimise primary and secondary air injection</b>				All plant.
<b>Flue Gas Recirculation (FGR)</b>	Reduces the consumption of reagents used for secondary NOx control.  May increase overall energy recovery	Some applications experience corrosion problems.  Can result in elevated CO and other products of incomplete combustion		Justify if not used

<b>Oxides of Nitrogen : Secondary Measures (BAT is to apply Primary Measures first)</b>				
<b>Technique</b>	<b>Advantages</b>	<b>Disadvantages</b>	<b>Optimisation</b>	<b>Defined as BAT in BREF or TGN for:</b>
<b>Selective catalytic reduction (SCR)</b>	NOx emissions 40-150mg/ m <sup>3</sup> Reduces CO, VOC, dioxins	Expensive. Re-heat required – reduces plant efficiency		All plant
<b>SCR by catalytic filter bags</b>	50-120 mg/m <sup>3</sup>			Applicable to new and existing plants with or without existing SNCR.  Can be used with NH <sub>3</sub> as slip catalyst - SNCR
<b>Selective non-catalytic reduction (SNCR)</b>	NOx emissions 80 -180 mg/m <sup>3</sup> Lower energy consumption than SCR Lower costs than SCR	Relies on an optimum temperature around 900 °C, and sufficient retention time for reduction  May lead to Ammonia slip	Port injection locations	All plant unless lower NOx release required for local environmental protection.
<b>Reagent Type: Ammonia</b>	Likely to be BAT	More difficult to handle Lower nitrous oxide formation Narrower temperature window		All plant
<b>Reagent Type: Urea</b>	Likely to be BAT	Higher N <sub>2</sub> O emissions than ammonia, optimisation particularly important		All plant

The Applicant proposes to implement the following primary measures:

- Low NO<sub>x</sub> burners for auxiliary firing for the cyclone furnace – this technique reduces NO<sub>x</sub> at source and is defined as BAT where auxiliary burners are required.
- Optimise primary and secondary air injection.

There are three recognised secondary techniques for secondary measures to reduce NO<sub>x</sub>. These are Selective Catalytic Reduction (SCR), SCR by catalytic filter bags and Selective Non-Catalytic Reduction (SNCR) with or without catalytic filter bags. For each technique, there is a choice of urea or ammonia reagent.

SCR can reduce NO<sub>x</sub> levels to below 50 mg/m<sup>3</sup> and can be applied to all plant, it is generally more expensive than SNCR and requires reheating of the waste gas stream which reduces energy efficiency, periodic replacement of the catalysts also produces a hazardous waste. The use of SCR by catalytic filter bags can reduce emissions to 50 -120 mg/m<sup>3</sup> with low investment costs. SNCR can typically reduce NO<sub>x</sub> levels to between 80 and 180 mg/m<sup>3</sup>, it relies on an optimum temperature of around 900 °C and sufficient retention time for reduction. SNCR is more likely to have higher levels of ammonia slip. The technique can be applied to all plant unless lower NO<sub>x</sub> releases are required for local environmental protection. Urea or ammonia can be used as the reagent with either technique, urea is somewhat easier to handle than ammonia and has a wider operating temperature window, but tends to result in higher emissions of N<sub>2</sub>O. Both reagents are BAT, and the use of one over the other is not normally significant in environmental terms.

The Applicant proposes to use SNCR with ammonia as the reagent.

Emissions of NO<sub>x</sub> cannot be screened out as insignificant. Therefore the Applicant has carried out a cost / benefit study of the alternative techniques. The cost per tonne of NO<sub>x</sub> abated over the projected life of the plant has been calculated and compared with the environmental impact as shown in the table below.

	Cost of NO <sub>x</sub> removal £/tonne	PC (long term)
SCR (cyclone furnace)	£1958	1.73
SNCR (cyclone furnace)	£1160	2.59
SCR (gas engines)	£12,875	1.71

Based on the figures above the Applicant considers that the additional cost of SCR over SNCR is not justified by the reduction in environmental impact. Thus SCR is not BAT in this case, and SNCR is BAT for the Installation. The Environment Agency agrees with this assessment.

The amount of ammonia used for NO<sub>x</sub> abatement will need to be optimised to maximise NO<sub>x</sub> reduction and minimise NH<sub>3</sub> slip. Improvement condition IC6 requires the Operator to report to the Environment Agency on optimising the

performance of the NO<sub>x</sub> abatement system. The BAT AEL for ammonia has been set.

### 6.2.3 Acid Gases, SO<sub>x</sub>, HCl and HF

<b>Acid gases and halogens : Primary Measures</b>				
<b>Technique</b>	<b>Advantages</b>	<b>Disadvantages</b>	<b>Optimisation</b>	<b>Defined as BAT in BREF or TGN for:</b>
<b>Low sulphur fuel, (&lt; 0.1%S gasoil or natural gas)</b>	Reduces SO <sub>x</sub> at source		Start-up, supplementary firing.	Where auxiliary fuel required.
<b>Management of waste streams</b>	Disperses sources of acid gases (e.g. PVC) through feed.	Requires closer control of waste management		All plant with heterogeneous waste feed

<b>Acid gases and halogens : Secondary Measures (BAT is to apply Primary Measures first)</b>				
<b>Technique</b>	<b>Advantages</b>	<b>Disadvantages</b>	<b>Optimisation</b>	<b>Defined as BAT in BREF or TGN for:</b>
<b>Wet</b>	High reaction rates  Low solid residues production  Reagent delivery may be optimised by concentration and flow rate	Large effluent disposal and water consumption if not fully treated for re-cycle  Effluent treatment plant required  May result in wet plume  Energy required for effluent treatment and plume reheat		Used for wide range of waste types  Can be used as polishing step after other techniques where emissions are high or variable
<b>Dry</b>	Low water use  Higher reagent consumption to achieve emissions of other FGC techniques but may be reduced by recycling in plant  Lower energy use  Higher reliability  Lowest visible plume potential	Higher solid residue production  Reagent consumption controlled only by input rate		All plant

<b>Semi-dry (also described as semi-wet in the Bref)</b>	Medium reaction rates Reagent delivery may be varied by concentration and input rate	Higher solid waste residues than wet but lower than dry system		All plant
<b>Direct injection into boiler</b>	Reduced acid loading to subsequent cleaning stages. Reduced peak emissions and reduced reagent usage			Generally applicable to grate and rotary kiln plants.
<b>Direction desulphurisation</b>	Reduced boiler corrosion	Does not improve overall performance. Can affect bottom ash quality. Corrosion problems in flue gas cleaning system.		Partial abatement upstream of other techniques in fluidised beds
<b>Reagent Type: Sodium Hydroxide</b>	Highest removal rates Low solid waste production	Corrosive material ETP sludge for disposal		Hazardous Waste Incinerators
<b>Reagent Type: Lime</b>	Very good removal rates Low leaching solid residue Temperature of reaction well suited to use with bag filters	Corrosive material May give greater residue volume if no in-plant recycle	Wide range of uses	MWIs, CWIs
<b>Reagent Type: Sodium Bicarbonate</b>	Good removal rates Easiest to handle Dry recycle systems proven	Efficient temperature range may be at upper end for use with bag filters Leachable solid residues Bicarbonate more expensive	Not proven at large plant	CWIs

The Applicant proposes to implement the following primary measures:

- Management of heterogeneous wastes – this will disperse problem wastes such as PVC by ensuring a homogeneous waste feed.

There are five recognised techniques for secondary measures to reduce acid gases, all of which can be BAT. These are wet, dry, semi-dry, boiler sorbent injection and direct desulphurisation. Wet scrubbing produces an effluent for treatment and disposal in compliance with Article 46(3) of IED. It will also require reheat of the exhaust to avoid a visible plume.

The Operator has proposed a packed tower wet scrubbing system to clean the cyclone furnace's combustion flue gases and a venturi scrubber and packed tower scrubber to remove acid gas forming compounds in the syngas prior to combustion in the CHP engines. A sodium hydroxide reagent will be used for both.

The Applicant has stated that given acid gas forming compounds and particulate material must be removed from the syngas prior to combustion to prevent corrosion and erosion of the CHP engines, a wet scrubbing system is the only viable technology for achieving this. The BAT assessment for choice of acid gas abatement in the Application therefore primarily focused on the cyclone furnace.

The following conclusions were reached by the Applicant:

- All abatement options are considered to meet the mandatory emission limits.
- Simple ranking in terms of the quantitative assessments carried out indicates that wet scrubbing is the best in terms of environmental performance.
- A qualitative assessment of the impact of visible plume and releases to sewer, which only apply to the wet scrubbing option, indicates that these are likely to be insignificant.
- Semi-dry and dry lime processes use significantly more reagent than wet scrubbing, and generate significantly more waste residues. This means that the annual operating costs are higher than for wet scrubbing.
- Although the capital cost of wet scrubbing systems are higher than for semi-dry and dry processes, the lower operating costs mean that annualised cost and cost per treatment of acid gas is the most cost effective for wet scrubbing.

The preferred technique selected for this site is a wet scrubbing packed tower system using sodium hydroxide. The Applicant concluded that this was BAT for the facility, due to the overall environmental performance and cost-effectiveness.

#### 6.2.4 Carbon monoxide and volatile organic compounds (VOCs)

The prevention and minimisation of emissions of carbon monoxide and volatile organic compounds is through the optimisation of combustion controls, where all measures will increase the oxidation of these species.

<b>Carbon monoxide and volatile organic compounds (VOCs)</b>				
<b>Technique</b>	<b>Advantages</b>	<b>Disadvantages</b>	<b>Optimisation</b>	<b>Defined as BAT in BREF or TGN for:</b>
<b>Optimise combustion control</b>	All measures will increase oxidation of these species.		Covered in section on furnace selection	All plants

### 6.2.5 Dioxins and furans (and Other POPs)

<b>Dioxins and furans</b>				
<b>Technique</b>	<b>Advantages</b>	<b>Disadvantages</b>	<b>Optimisation</b>	<b>Defined as BAT in BREF or TGN for:</b>
<b>Optimise combustion control</b>	All measures will increase oxidation of these species.		Covered in section on furnace selection	All plants
<b>Avoid <i>de novo</i> synthesis</b>			Covered in boiler design	All plant
<b>Effective Particulate matter removal</b>			Covered in section on particulate matter	All plant
<b>Activated Carbon injection</b>	Can be combined with acid gas absorber or fed separately. Metallic mercury is also absorbed.	Combined feed rate usually controlled by acid gas content.		All plant.  Separate feed normally BAT unless feed is constant and acid gas control also controls dioxin release.
<b>Catalytic filter bags</b>	High destruction efficiency	Does not remove mercury. Higher cost than non-catalytic filter bags		

The prevention and minimisation of emissions of dioxins and furans is achieved through:

- optimisation of combustion control including the maintenance of permit conditions on combustion temperature and residence time, which has been considered in 6.1.1 above;
- avoidance of *de novo* synthesis, which has been covered in the consideration of boiler design;
- the effective removal of particulate matter, which has been considered in 6.2.1 above;
- injection of activated carbon. This can be combined with the acid gas reagent or dosed separately. Where the feed is combined, the combined feed rate will be controlled by the acid gas concentration in the exhaust. Therefore, separate feed of activated carbon would normally be considered BAT unless the feed was relatively constant. Effective control of acid gas emissions also assists in the control of dioxin releases.

The Applicant has proposed carbon filters and wet scrubbing systems for both the exhaust gases from the cyclone furnace and for the syngas clean up. We consider this BAT for this plant based on its site specific set up.

### 6.2.6 Metals

<b>Metals</b>
---------------

Technique	Advantages	Disadvantages	Optimisation	Defined as BAT in BREF or TGN for:
<b>Effective Particulate matter removal</b>			Covered in section on particulate matter	All plant
<b>Activated Carbon injection for mercury recovery</b>	Can be combined with acid gas absorber or fed separately.  Can be impregnated with bromine or sulphur to enhance reactivity, for use during peak emissions.	Combined feed rate usually controlled by acid gas content.		All plant.  Separate feed normally BAT unless feed is constant and acid gas control also controls dioxin release.
<b>Fixed or moving bed adsorption</b>	Mainly for mercury and other metals, as well as organic compounds			Limited applicability due to pressure drop
<b>Boiler bromine injection</b>	Injection during mercury peaks. Oxidation of mercury leading to improved removal in downstream removal method.	Consumption of aqueous bromine. Can lead to formation of polybrominated dioxins. Can damage bag filter. Effects can be limited use is restricted to dealing with peak emissions		Not suitable for pyrolysis or gasification. Can deal with mercury peaks.

The prevention and minimisation of metal emissions is achieved through the effective removal of particulate matter, and this has been considered in 6.2.1 above.

Unlike other metals however, mercury if present will be in the vapour phase. BAT for mercury removal is one or a combination of the techniques listed above. The Applicant has proposed carbon filters and wet scrubbing systems for both the exhaust gases from the cyclone furnace and for the syngas clean up. We consider this BAT for this plant based on its site specific set up.

### 6.3 BAT and global warming potential

This section summarises the assessment of greenhouse gas impacts which has been made in the determination of this Permit. Emissions of carbon dioxide (CO<sub>2</sub>) and other greenhouse gases differ from those of other pollutants in that, except at gross levels, they have no localised environmental impact. Their impact is at a global level and in terms of climate change. Nonetheless, CO<sub>2</sub> is clearly a pollutant for IED purposes.



The principal greenhouse gas emitted is CO<sub>2</sub>, but the plant also emits small amounts of N<sub>2</sub>O arising from the operation of secondary NO<sub>x</sub> abatement. N<sub>2</sub>O has a global warming potential 310 times that of CO<sub>2</sub>. The Applicant will therefore be required to optimise the performance of the secondary NO<sub>x</sub> abatement system to ensure its GWP impact is minimised.

The major source of greenhouse gas emissions from the installation is however CO<sub>2</sub> from the combustion of waste. There will also be CO<sub>2</sub> emissions from the burning of support fuels at start up, shut down and should it be necessary to maintain combustion temperatures. BAT for greenhouse gas emissions is to maximise energy recovery and efficiency.

The electricity that is generated by the Installation will displace emissions of CO<sub>2</sub> elsewhere in the UK, as virgin fossil fuels will not be burnt to create the same electricity.

The Installation is not subject to the Greenhouse Gas Emissions Trading Scheme Regulations 2012 therefore it is a requirement of IED to investigate how emissions of greenhouse gases emitted from the installation might be prevented or minimised.

Factors influencing GWP and CO<sub>2</sub> emissions from the Installation are:

On the debit side

- CO<sub>2</sub> emissions from the burning of the waste;
- CO<sub>2</sub> emissions from burning auxiliary or supplementary fuels;
- CO<sub>2</sub> emissions associated with electrical energy used;
- N<sub>2</sub>O from the de-NO<sub>x</sub> process.

On the credit side

- CO<sub>2</sub> saved from the export of electricity to the public supply by displacement of burning of virgin fuels;

The GWP of the plant will be dominated by the emissions of carbon dioxide that are released as a result of waste combustion. This will constant for all options considered in the BAT assessment. Any differences in the GWP of the options in the BAT appraisal will therefore arise from small differences in energy recovery and in the amount of N<sub>2</sub>O emitted. The Applicant considered energy efficiency and BAT for the de-NO<sub>x</sub> process.

Note: avoidance of methane which would be formed if the waste was landfilled has not been included in this assessment. If it were included due to its avoidance it would be included on the credit side. Ammonia has no direct GWP effect.

Taking all these factors into account, the Applicant's assessment shows that the difference in global warming potential between the best option in terms of GWP and the Applicant's preferred option is minor. The purpose of a BAT appraisal is to determine which option minimises the impact on the environment as a whole. In this context the small benefit in terms of GWP of

the other options is considered to be more than offset by the other benefits of the preferred option.

The Environment Agency agrees with this assessment and that the chosen option is BAT for the installation.

#### 6.4 BAT and POPs

International action on Persistent Organic pollutants (POPs) is required under the UN's Stockholm Convention, which entered into force in 2004. The EU implemented the Convention through the POPs Regulation (2019/1021), which is directly applicable in UK law. The Environment Agency is required by national POPs Regulations (SI 2007 No 3106) to give effect to Article 6(3) of the EC POPs Regulation when determining applications for environmental Permits.

However, it needs to be borne in mind that this application is for a particular type of installation, namely a waste incinerator. The Stockholm Convention distinguishes between intentionally-produced and unintentionally-produced POPs. Intentionally-produced POPs are those used deliberately (mainly in the past) in agriculture (primarily as pesticides) and industry. Those intentionally-produced POPs are not relevant where waste incineration is concerned, as in fact high-temperature incineration is one of the prescribed methods for destroying POPs.

The unintentionally-produced POPs addressed by the Convention are:

- dioxins and furans;
- HCB (hexachlorobenzene)
- PCBs (polychlorobiphenyls) and
- PeCB (pentachlorobenzene)

The UK's national implementation plan for the Stockholm Convention, published in 2007, makes explicit that the relevant controls for unintentionally-produced POPs, such as might be produced by waste incineration, are delivered through the requirements of IED. That would include an examination of BAT, including potential alternative techniques, with a view to preventing or minimising harmful emissions. These have been applied as explained in this document, which explicitly addresses alternative techniques and BAT for the minimisation of emissions of dioxins.

Our legal obligation, under regulation 4(b) of the POPs Regulations, is, when considering an application for an environmental permit, to comply with article 6(3) of the POPs Regulation:

“Member States shall, when considering proposals to construct new facilities or to significantly modify existing facilities using processes that release chemicals listed in Annex III, give priority consideration to alternative processes, techniques or practices that have similar usefulness but which avoid the formation and release of substances listed in Annex III, without prejudice to Directive 2010/75/EU of the European Parliament and of the Council”

The 1998 Protocol to the Convention recommended that unintentionally produced should be controlled by imposing emission limits (e.g. 0.1 ng/m<sup>3</sup> for MWIs) and using BAT for incineration. UN Economic Commission for Europe (Executive Body for the Convention) (ECE-EB) produced BAT guidance for the parties to the Convention in 2009. This document considers various control techniques and concludes that primary measures involving management of feed material by reducing halogenated substances are not technically effective. This is not surprising because halogenated wastes still need to be disposed of and because POPs can be generated from relatively low concentrations of halogens. In summary, the successful control techniques for waste incinerators listed in the ECE-EB BAT are:

- maintaining furnace temperature of 850°C and a combustion gas residence time of at least 2 seconds
- rapid cooling of flue gases to avoid the *de novo* reformation temperature range of 250-450°C
- use of bag filters and the injection of activated carbon or coke to adsorb residual POPs components.

Using the methods listed above, the UN-ECE BAT document concludes that incinerators can achieve an emission concentration of 0.1 ng TEQ/m<sup>3</sup>.

We believe that the Permit ensures that the formation and release of POPs will be prevented or minimised. As we explain above, high-temperature incineration is one of the prescribed methods for destroying POPs. Permit conditions are based on the use of BAT and Chapter IV of IED and incorporate all the above requirements of the UN-ECE BAT guidance and deliver the requirements of the Stockholm Convention in relation to unintentionally produced POPs.

The release of **dioxins and furans** to air is required by the IED to be assessed against the I-TEQ (International Toxic Equivalence) limit of 0.1 ng/m<sup>3</sup>. Further development of the understanding of the harm caused by dioxins has resulted in the World Health Organisation (WHO) producing updated factors to calculate the WHO-TEQ value. Certain **PCBs** have structures which make them behave like dioxins (dioxin-like PCBs), and these also have toxic equivalence factors defined by WHO to make them capable of being considered together with dioxins. The UK's independent health advisory committee, the Committee on Toxicity of Chemicals in Food, Consumer Products and the Environment (COT) has adopted WHO-TEQ values for both dioxins and dioxin-like PCBs in their review of Tolerable Daily Intake (TDI) criteria. The Permit requires that, in addition to the requirements of the IED, the WHO-TEQ values for both dioxins and dioxin-like PCBs should be monitored for reporting purposes, to enable evaluation of exposure to dioxins and dioxin-like PCBs to be made using the revised TDI recommended by COT. The release of dioxin-like PCBs and PAHs is expected to be low where measures have been taken to control dioxin releases. The Permit also requires monitoring of a range of PAHs and dioxin-like PCBs at the same frequency as dioxins are monitored. We have included a requirement to

monitor and report against these WHO-TEQ values for dioxins and dioxin-like PCBs and the range of PAHs as listed in the Permit. We are confident that the measures taken to control the release of dioxins will also control the releases of dioxin-like PCBs and PAHs. Section 5.2.1 of this document details the assessment of emissions to air, which includes dioxins and concludes that there will be no adverse effect on human health from either normal or abnormal operation.

**Hexachlorobenzene (HCB)** is released into the atmosphere as an accidental product from the combustion of coal, waste incineration and certain metal processes. It has also been used as a fungicide, especially for seed treatment although this use has been banned in the UK since 1975. Natural fires and volcanoes may serve as natural sources. Releases of (HCB) are addressed by the European Environment Agency (EEA), which advises that:

*"due to comparatively low levels in emissions from most (combustion) processes special measures for HCB control are usually not proposed. HCB emissions can be controlled generally like other chlorinated organic compounds in emissions, for instance dioxins/furans and PCBs: regulation of time of combustion, combustion temperature, temperature in cleaning devices, sorbents application for waste gases cleaning etc."* [reference [http://www.eea.europa.eu/publications/EMEPCORINAIR4/sources\\_of\\_HCB.pdf](http://www.eea.europa.eu/publications/EMEPCORINAIR4/sources_of_HCB.pdf)]

Pentachlorobenzene (PeCB) is another of the POPs list to be considered under incineration. PeCB has been used as a fungicide or flame retardant, there is no data available however on production, recent or past, outside the UN-ECE region. PeCBs can be emitted from the same sources as for PCDD/F: waste incineration, thermal metallurgic processes and combustion plants providing energy. As discussed above, the control techniques described in the UN-ECE BAT guidance and included in the permit, are effective in controlling the emissions of all relevant POPs including PeCB.

We have assessed the control techniques proposed for dioxins by the Applicant and have concluded that they are appropriate for dioxin control. We are confident that these controls are in line with the UN-ECE BAT guidance and will minimise the release of HCB, PCB and PeCB.

We are therefore satisfied that the substantive requirements of the Convention and the POPs Regulation have been addressed and complied with.

## 6.5 Other Emissions to the Environment

### 6.5.1 Emissions to water

There are no emissions to surface water from the site.

### 6.5.2 Emissions to sewer

No process emissions will go to sewer, only run off from the site via an interceptor.

Based upon the information in the application we are satisfied that appropriate measures will be in place to prevent and /or minimise emissions to sewer.

### 6.5.3 Fugitive emissions

The IED specifies that plants must be able to demonstrate that the plant is designed in such a way as to prevent the unauthorised and accidental release of polluting substances into soil, surface water and groundwater. In addition storage requirements for waste and for contaminated water of Article 46(5) must be arranged.

Based upon the information in the application we are satisfied that appropriate measures will be in place to prevent and /or minimise fugitive emissions. See section 4.2.2 for further information.

### 6.5.4 Odour

Based upon the information in the application we are satisfied that the appropriate measures will be in place to prevent or where that is not practicable to minimise odour and to prevent pollution from odour.

Waste acceptance checks including an assessment of odour will be undertaken prior to acceptance of any waste on to site.

Only small amounts (less than 20 tonnes) of waste feedstock will be stored on site (within the externally located hoppers) at any one time. The waste stored within the hoppers will be limited to the time taken (less than an hour) for it to be fed into the system. Once fed into the process, the combustion and pyrolysis processes are undertaken within air tight chambers enclosed within the building.

Char, ash and torrefied fuel produced by the process will not be odorous.

For planned and unplanned outages, all waste will be diverted from the facility.

We agree with the operator that risks associated with odour from the facility are unlikely to be significant.

### 6.5.5 Noise and vibration

Based upon the information in the application we are satisfied that the appropriate measures will be in place to prevent or where that is not practicable to minimise noise and vibration and to prevent pollution from noise and vibration outside the site.

The application contained a noise impact assessment which identified local noise-sensitive receptors, potential sources of noise at the proposed plant and noise attenuation measures. Measurements were taken of the prevailing ambient noise levels to produce a baseline noise survey and an impact assessment (including noise modelling) was carried out in accordance with

BS 4142:2014 to compare the predicted plant rating noise levels with the established background levels.

We did not consider that the original noise assessment submitted with the application contained sufficient evidence to demonstrate that noise would not cause pollution outside of the site. We issued a Schedule 5 request for further information, requiring the Applicant to review their proposals and submit a new noise impact assessment. The Applicant submitted a revised impact assessment which included the following proposed mitigation measures:

- the construction of a 4m bund to north of site and other bunds as indicated on the new site layout
- the enclosure of the following plant:
  - a. 2 Pellet Mill Auger Motors;
  - b. Cyclone associated with the Pellet Mill;
  - c. 2 Pellet Mills;
  - d. 2 Pellet Mill Motors; and
  - e. Stack exhaust fan.

We reviewed the Applicant's revised noise impact assessment and as a result of our checks, we agree that impacts from the facility are likely to be low, provided the plant design includes the mitigation measures described in the Applicant's Schedule 5 response as listed above.

Based on the results of the noise assessment and the proposed mitigation measures, we are satisfied that the Applicant has implemented BAT to manage the risk of noise emissions from the facility.

## 6.6 Setting ELVs and other Permit conditions

### 6.6.1 Translating BAT into Permit conditions

Article 14(3) of IED states that BAT conclusions shall be the reference for permit conditions. Article 15(3) further requires that under normal operating conditions; emissions do not exceed the emission levels associated with the best available techniques as laid down in the decisions on BAT conclusions. BAT conclusions for waste incineration or co-incineration were published on 03 December 2019.

The use of BAT AELs and IED Chapter IV emission limits for air dispersion modelling sets the worst case scenario. If this shows emissions are insignificant then we have accepted that the Applicant's proposals are BAT, and that there is no justification to reduce ELVs below the BAT AELs and Chapter IV limits.

Below we consider whether, for those emission not screened out as insignificant, different conditions are required as a result of consideration of local or other factors, so that no significant pollution is caused (Article 11(c)) or to comply with environmental quality standards (Article 18).

### (iii) Global Warming

CO<sub>2</sub> is an inevitable product of the combustion of waste. The amount of CO<sub>2</sub> emitted will be essentially determined by the quantity and characteristics of waste being incinerated, which are already subject to conditions in the Permit. It is therefore inappropriate to set an emission limit value for CO<sub>2</sub>, which could do no more than recognise what is going to be emitted. The gas is not therefore targeted as a key pollutant under Annex II of IED, which lists the main polluting substances that are to be considered when setting emission limit values (ELVs) in Permits.

We have therefore considered setting equivalent parameters or technical measures for CO<sub>2</sub>. However, provided energy is recovered efficiently (see section 4.3.7 above), there are no additional equivalent technical measures (beyond those relating to the quantity and characteristics of the waste) that can be imposed that do not run counter to the primary purpose of the plant, which is the recovery of torrefied fuels. Controls in the form of restrictions on the volume and type of waste that can be accepted at the Installation and permit conditions relating to energy efficiency effectively apply equivalent technical measures to limit CO<sub>2</sub> emissions.

## 6.7 Monitoring

### 6.7.1 Monitoring during normal operations

We have decided that monitoring should be carried out for the parameters listed in Schedule 3 using the methods and to the frequencies specified in those tables. These monitoring requirements have been imposed in order to demonstrate compliance with emission limit values and to enable correction of measured concentration of substances to the appropriate reference conditions; to gather information about the performance of the SNCR system; to establish data on the release of dioxin-like PCBs and PAHs from the incineration process and to deliver the requirements of Chapter IV of IED for monitoring of residues and temperature in the combustion chamber.

For emissions to air, the methods for continuous and periodic monitoring are in accordance with the Environment Agency's Guidance M2 for monitoring of stack emissions to air.

Based on the information in the Application and the requirements set in the conditions of the permit we are satisfied that the Operator's techniques, personnel and equipment will have either MCERTS certification or MCERTS accreditation as appropriate.

### 6.7.2 Monitoring under abnormal operations arising from the failure of the installed CEMs

The Operator has stated that they will provide back-up CEMS working in parallel to the operating CEMS. These will be switched into full operation immediately in the event that there is any failure in the regular monitoring equipment. The back-up CEMS measure the same parameters as the operating CEMS. In the unlikely event that the back-up CEMS also fail Condition 2.3.12 of the permit requires that the abnormal operating conditions apply.

### 6.7.3 Continuous emissions monitoring for dioxins and heavy metals

The BAT conclusions specify either manual extractive monitoring or long term monitoring for dioxins. For mercury either continuous or long term monitoring is specified, manual extractive monitoring is specified for other metals.

For dioxins long term monitoring does not apply if emissions are stable, and for mercury long term monitoring can be used instead of continuous if the mercury content of the waste is low and stable.

Based on the waste types and control measures proposed in the Application we expect that emissions of dioxins will be stable and that the mercury content of the waste will be low and stable. We have therefore set manual extractive monitoring in the Permit. However the Permit requires the stable and low criteria to be demonstrated through improvement conditions IC9 and IC10 and we can require long term monitoring for dioxins and continuous monitoring for mercury if required.

### 6.7.4 Monitoring during periods of 'other than normal operation' (OTNOC)

BAT AELs (daily averages) do not apply during period of OTNOC. However IED chapter IV limits will apply during these periods. Permit table S3.1(b) contains appropriate limits and monitoring requirements during OTNOC. Pre-operational condition PO1 will ensure OTNOC scenarios are defined.

## 6.8 Reporting

We have specified the reporting requirements in Schedule 5 of the Permit either to meet the reporting requirements set out in the IED, or to ensure data is reported to enable timely review by the Environment Agency to ensure compliance with permit conditions and to monitor the efficiency of material use and energy recovery at the installation.

# 7 **Other legal requirements**

In this section we explain how we have addressed other relevant legal requirements, to the extent that we have not addressed them elsewhere in this document.

## 7.1 The EPR 2016 and related Directives

The EPR delivers the requirements of a number of European and national laws.

### 7.1.1 Schedules 1 and 7 to the EPR 2016 – IED Directive

We address the requirements of the IED in the body of this document above and the specific requirements of Chapter IV in Annex 1 of this document.

There is one requirement not addressed above, which is that contained in Article 5(3) IED. Article 5(3) requires that “In the case of a new installation or a substantial change where Article 4 of Directive 85/337/EC (now Directive 2011/92/EU) (the EIA Directive) applies, any relevant information obtained or



conclusion arrived at pursuant to articles 5, 6 and 7 of that Directive shall be examined and used for the purposes of granting the permit.”

- Article 5 of EIA Directive relates to the obligation on developers to supply the information set out in Annex IV of the Directive when making an application for development consent.
- Article 6(1) requires Member States to ensure that the authorities likely to be concerned by a development by reason of their specific environmental responsibilities are consulted on the Environmental Statement and the request for development consent.
- Article 6(2)-6(6) makes provision for public consultation on applications for development consent.
- Article 7 relates to projects with transboundary effects and consequential obligations to consult with affected Member States.

The grant or refusal of development consent is a matter for the relevant local planning authority. The Environment Agency’s obligation is therefore to examine and use any relevant information obtained or conclusion arrived at by the local planning authorities pursuant to those EIA Directive articles.

In determining the Application we have considered the following documents: -

- The Environmental Statement submitted with the planning application (which also formed part of the Environmental Permit Application).

From consideration of all the documents above, the Environment Agency considers that no additional or different conditions are necessary.

The Environment Agency has also carried out its own consultation on the Environmental Permitting Application which includes the Environmental Statement submitted to the local planning authority. The results of our consultation are described elsewhere in this decision document.

#### 7.1.2 Schedule 9 to the EPR 2016 – Waste Framework Directive

As the Installation involves the treatment of waste, it is carrying out a *waste operation* for the purposes of the EPR 2016, and the requirements of Schedule 9 therefore apply. This means that we must exercise our functions so as to ensure implementation of certain articles of the WFD.

We must exercise our relevant functions for the purposes of ensuring that the waste hierarchy referred to in Article 4 of the Waste Framework Directive is applied to the generation of waste and that any waste generated is treated in accordance with Article 4 of the Waste Framework Directive. (See also section 4.3.9)

The conditions of the permit ensure that waste generation from the facility is minimised. Where the production of waste cannot be prevented it will be recovered wherever possible or otherwise disposed of in a manner that minimises its impact on the environment. This is in accordance with Article 4.

We must also exercise our relevant functions for the purposes of implementing Article 13 of the Waste Framework Directive; ensuring that the

requirements in the second paragraph of Article 23(1) of the Waste Framework Directive are met; and ensuring compliance with Articles 18(2)(b), 18(2)(c), 23(3), 23(4) and 35(1) of the Waste Framework Directive.

Article 13 relates to the protection of human health and the environment. These objectives are addressed elsewhere in this document.

Article 23(1) requires the permit to specify:

- the types and quantities of waste that may be treated;
- for each type of operation permitted, the technical and any other requirements relevant to the site concerned;
- the safety and precautionary measures to be taken;
- the method to be used for each type of operation;
- such monitoring and control operations as may be necessary;
- such closure and after-care provisions as may be necessary.

These are all covered by permit conditions.

We consider that the intended method of waste treatment is acceptable from the point of view of environmental protection so Article 23(3) does not apply. Energy efficiency is dealt with elsewhere in this document but we consider the conditions of the permit ensure that the recovery of energy take place with a high level of energy efficiency in accordance with Article 23(4).

Article 35(1) relates to record keeping and its requirements are delivered through permit conditions.

#### **7.1.3 Schedule 22 to the EPR 2016 – Water Framework and Groundwater Directives**

To the extent that it might lead to a discharge of pollutants to groundwater (a “groundwater activity” under the EPR 2016), the Permit is subject to the requirements of Schedule 22, which delivers the requirements of EU Directives relating to pollution of groundwater. The Permit will require the taking of all necessary measures to prevent the input of any hazardous substances to groundwater, and to limit the input of non-hazardous pollutants into groundwater so as to ensure such pollutants do not cause pollution, and satisfies the requirements of Schedule 22.

No releases to groundwater from the Installation are permitted. The Permit also requires material storage areas to be designed and maintained to a high standard to prevent accidental releases.

#### **7.1.4 Directive 2003/35/EC – The Public Participation Directive**

Regulation 60 of the EPR 2016 requires the Environment Agency to prepare and publish a statement of its policies for complying with its public participation duties. We have published our public participation statement.

This Application has been consulted upon in line with this statement, as well as with our guidance RGS6 on Sites of High Public Interest, which addresses

specifically extended consultation arrangements for determinations where public interest is particularly high. This satisfies the requirements of the Public Participation Directive.

Our decision in this case has been reached following a programme of public consultation, on the original application. A summary of the responses received to our consultations and our consideration of them is set out in Annex 4.

## 7.2 National primary legislation

### 7.2.1 **Environment Act 1995**

#### (i) Section 4 (Pursuit of Sustainable Development)

We are required to contribute towards achieving sustainable development, as considered appropriate by Ministers and set out in guidance issued to us. The Secretary of State for Environment, Food and Rural Affairs has issued *The Environment Agency's Objectives and Contribution to Sustainable Development: Statutory Guidance (December 2002)*. This document:

*“provides guidance to the Agency on such matters as the formulation of approaches that the Agency should take to its work, decisions about priorities for the Agency and the allocation of resources. It is not directly applicable to individual regulatory decisions of the Agency”.*

In respect of regulation of industrial pollution through the EPR, the Guidance refers in particular to the objective of setting permit conditions *“in a consistent and proportionate fashion based on Best Available Techniques and taking into account all relevant matters...”*. The Environment Agency considers that it has pursued the objectives set out in the Government's guidance, where relevant, and that there are no additional conditions that should be included in this Permit to take account of the Section 4 duty.

#### (ii) Section 5 (Preventing or Minimising Effects of Pollution of the Environment)

We are satisfied that our pollution control powers have been exercised for the purpose of preventing or minimising, remedying or mitigating the effects of pollution.

#### (iii) Section 7 (Pursuit of Conservation Objectives)

This places a duty on us, when considering any proposal relating to our functions, to have regard amongst other things to any effect which the proposals would have on sites of archaeological, architectural, or historic interest; the economic and social well-being of local communities in rural areas; and to take into account any effect which the proposals would have on the beauty or amenity of any rural area.

We considered whether we should impose any additional or different requirements in terms of our duty to have regard to the various conservation objectives set out in Section 7, but concluded that we should not.

#### (vi) Section 39 (Costs and Benefits)

We have a duty to take into account the likely costs and benefits of our decisions on the applications ('costs' being defined as including costs to the environment as well as any person). This duty, however, does not affect our obligation to discharge any duties imposed upon us in other legislative provisions.

In so far as relevant we consider that the costs that the permit may impose on the applicant are reasonable and proportionate in terms of the benefits it provides.

(vii) Section 81 (National Air Quality Strategy)

We have had regard to the National Air Quality Strategy and consider that our decision complies with the Strategy, and that no additional or different conditions are appropriate for this Permit.

We have also had regard to the clean air strategy 2019 and consider that our decision complies with the Strategy, and that no additional or different conditions are appropriate for this Permit.

(viii) National Emissions Ceiling Regulations 2018

We have had regard to the National Air Pollution Control Programme and consider that our decision complies with the Strategy, and that no additional or different conditions are appropriate for this Permit.

**7.2.2 Section 108 Deregulation Act 2015 – Growth duty**

We have considered our duty to have regard to the desirability of promoting economic growth set out in section 108(1) of the Deregulation Act 2015 and the guidance issued under section 110 of that Act in deciding whether to grant this permit.

Paragraph 1.3 of the guidance says:

“The primary role of regulators, in delivering regulation, is to achieve the regulatory outcomes for which they are responsible. For a number of regulators, these regulatory outcomes include an explicit reference to development or growth. The growth duty establishes economic growth as a factor that all specified regulators should have regard to, alongside the delivery of the protections set out in the relevant legislation.”

We have addressed the legislative requirements and environmental standards to be set for this operation in the body of the decision document above. The guidance is clear at paragraph 1.5 that the growth duty does not legitimise non-compliance and its purpose is not to achieve or pursue economic growth at the expense of necessary protections.

We consider the requirements and standards we have set in this permit are reasonable and necessary to avoid a risk of an unacceptable level of pollution. This also promotes growth amongst legitimate operators because the standards applied to the operator are consistent across businesses in this sector and have been set to achieve the required legislative standards.

### **7.2.3 Human Rights Act 1998**

We have considered potential interference with rights addressed by the European Convention on Human Rights in reaching our decision and consider that our decision is compatible with our duties under the Human Rights Act 1998. In particular, we have considered the right to life (Article 2), the right to a fair trial (Article 6), the right to respect for private and family life (Article 8) and the right to protection of property (Article 1, First Protocol). We do not believe that Convention rights are engaged in relation to this determination.

### **7.2.4 Countryside and Rights of Way Act 2000 (CROW 2000)**

Section 85 of this Act imposes a duty on Environment Agency to have regard to the purpose of conserving and enhancing the natural beauty of the area of outstanding natural beauty (AONB). There is no AONB which could be affected by the Installation.

### **7.2.5 Wildlife and Countryside Act 1981**

Under section 28G of the Wildlife and Countryside Act 1981 the Environment Agency has a duty to take reasonable steps to further the conservation and enhancement of the flora, fauna or geological or physiographical features by reason of which a site is of special scientific interest. Under section 28I the Environment Agency has a duty to consult Natural England in relation to any permit that is likely to damage SSSIs.

We assessed the Application and concluded that the Installation will not damage the special features of any SSSI. No consultation with Natural England was required.

The CROW assessment is summarised in greater detail in section 5.4.2 of this document. A copy of the Appendix 4 Assessment can be found on the public register.

### **7.2.6 Natural Environment and Rural Communities Act 2006**

Section 40 of this Act requires us to have regard, so far as is consistent with the proper exercise of our functions, to the purpose of conserving biodiversity. We have done so and consider that no different or additional conditions in the Permit are required.

### **7.2.8 Countryside Act 1968**

Section 11 imposes a duty on the Environment Agency to exercise its functions relating to any land, having regard to the desirability of conserving the natural beauty and amenity of the countryside including wildlife. We have done so and consider that no different or additional conditions in the Permit are required.

## **7.3 National secondary legislation**

### **7.3.1 Conservation of Habitats and Species Regulations 2017**

The habitat assessment is summarised in greater detail in section 5.4.2 of this document. We sent an HRA01 assessment to Natural England for information

only on 14/02/2020. A copy of the full HRA01 assessment can be found on the public register.

### **7.3.2 Water Environment (Water Framework Directive) Regulations 2017 2003**

There are no emissions to surface water from the installation.

### **7.3.3 The Persistent Organic Pollutants Regulations 2019**

We have explained our approach to these Regulations, which give effect to the Stockholm Convention on POPs and the EU's POPs Regulation, above.

## **7.4 Other relevant legal requirements**

### **7.4.1 Duty to Involve**

S23 of the Local Democracy, Economic Development and Construction Act 2009 require us where we consider it appropriate to take such steps as we consider appropriate to secure the involvement of interested persons in the exercise of our functions by providing them with information, consulting them or involving them in any other way. S24 requires us to have regard to any Secretary of State guidance as to how we should do that.

The way in which the Environment Agency has consulted with the public and other interested parties is set out in Section 2 of this document. The way in which we have taken account of the representations we have received is set out in Annex 4. Our public consultation duties are also set out in the EP Regulations, and our statutory Public Participation Statement, which implement the requirements of the Public Participation Directive. In addition to meeting our consultation responsibilities, we have also taken account of our guidance in Environment Agency Guidance Note RGS6 and the Environment Agency's Building Trust with Communities toolkit.

## ANNEX 1A: APPLICATION OF CHAPTER IV OF THE INDUSTRIAL EMISSIONS DIRECTIVE

IED Article	Requirement	Delivered by
45(1)(a)	The permit shall include a list of all types of waste which may be treated using at least the types of waste set out in the European Waste List established by Decision 2000/532/EC, if possible, and containing information on the quantity of each type of waste, where appropriate.	Condition 2.3.3(a) and Table S2.2 in Schedule 2 of the Permit.
45(1)(b)	The permit shall include the total waste incinerating or co-incinerating capacity of the plant.	Condition 2.3.3(a) and Table S2.2 in Schedule 2 of the Permit.
45(1)(c)	The permit shall include the limit values for emissions into air and water.	Conditions 3.1.1 and 3.1.2 and Tables S3.1 and S3.1(a) in Schedule 3 of the Permit.
45(1)(d)	The permit shall include the requirements for pH, temperature and flow of waste water discharges.	Not Applicable
45(1)(e)	The permit shall include the sampling and measurement procedures and frequencies to be used to comply with the conditions set for emissions monitoring.	Conditions 3.5.1 to 3.5.5 and Tables S3.1, S3.1(a), S3.3 and S3.4 in Schedule 3 of the Permit.
45(1)(f)	The permit shall include the maximum permissible period of unavoidable stoppages, disturbances or failures of the purification devices or the measurement devices, during which the emissions into the air and the discharges of waste water may exceed the prescribed emission limit values.	Conditions 2.3.12 and 2.3.13.
45(2)(a)	The permit shall include a list of the quantities of the different categories of hazardous waste which may be treated.	Not Applicable
45(2)(b)	The permit shall include the minimum and maximum mass flows of those hazardous waste, their lowest and maximum calorific values and the maximum contents of polychlorinated biphenyls, pentachlorophenol, chlorine, fluorine, sulphur, heavy metals and other polluting substances.	Not Applicable
46(1)	Waste gases shall be discharged in a controlled way by means of a stack the height of which is calculated in such a way as to safeguard human health and the environment.	Condition 2.3.1(a) and Table S1.2 of Schedule 1 of the Permit.
46(2)	Emissions into air shall not exceed the emission limit values set out in part 3 of Annex VI.	Conditions 3.1.1 and 3.1.2 and Tables S3.1 and S3.1a.
46(2)	Emission into air shall not exceed the emission limit values set out in parts 4 or determined in accordance with part 4 of Annex VI.	NA - applicable to co-incinerators only
46(3)	Relates to conditions for water discharges from the cleaning of exhaust gases.	There are no such discharges as condition 3.1.1 prohibits this.
46(4)	Relates to conditions for water discharges from the cleaning of exhaust gases.	There are no such discharges as condition 3.1.1 prohibits this.
46(5)	Prevention of unauthorised and accidental release of any polluting substances into soil, surface water or groundwater. Adequate storage capacity for contaminated	The application explains the measures to be in place for achieving the directive requirements.

<b>IED Article</b>	<b>Requirement</b>	<b>Delivered by</b>
	rainwater run-off from the site or for contaminated water from spillage or fire-fighting.	The permit requires that these measures are used. Various permit conditions address this and when taken as a whole they ensure compliance with this requirement.
46(6)	Limits the maximum period of operation when an ELV is exceeded to 4 hours uninterrupted duration in any one instance, and with a maximum cumulative limit of 60 hours per year. Limits on dust (150 mg/m <sup>3</sup> ), CO and TOC not to be exceeded during this period.	Conditions 2.3.12 and 2.3.13
47	In the event of breakdown, reduce or close down operations as soon as practicable. Limits on dust (150 mg/m <sup>3</sup> ), CO and TOC not to be exceeded during this period.	condition 2.3.12
48(1)	Monitoring of emissions is carried out in accordance with Parts 6 and 7 of Annex VI.	Conditions 3.5.1 to 3.5.5. Reference conditions are defined in Schedule 6 of the Permit.
48(2)	Installation and functioning of the automated measurement systems shall be subject to control and to annual surveillance tests as set out in point 1 of Part 6 of Annex VI.	condition 3.5.3, and tables S3.1, S3.1(a), and S3.4
48(3)	The competent authority shall determine the location of sampling or measurement points to be used for monitoring of emissions.	conditions 3.5.3 and 3.5.4
48(4)	All monitoring results shall be recorded, processed and presented in such a way as to enable the competent authority to verify compliance with the operating conditions and emission limit values which are included in the permit.	Conditions 4.1.1 and 4.1.2, and Tables S4.1 and S4.4
49	The emission limit values for air shall be regarded as being complied with if the conditions described in Part 8 of Annex VI are fulfilled.	conditions 3.1.1 and 3.1.2 and 3.5.5
50(1)	Slag and bottom ash to have Total Organic Carbon (TOC) < 3% or loss on ignition (LOI) < 5%.	Conditions 3.5.1 and Table S3.5
50(2)	Flue gas to be raised to a temperature of 850°C for two seconds, as measured at representative point of the combustion chamber.	Condition 2.3.9, Pre-operational conditions PO5 and Improvement condition IC4, IC13 and Table S3.3
50(3)	At least one auxiliary burner which must not be fed with fuels which can cause higher emissions than those resulting from the burning of gas oil liquefied gas or natural gas.	Condition 2.3.8
50(4)(a)	Automatic shut to prevent waste feed if at start up until the specified temperature has been reached.	Condition 2.3.9
50(4)(b)	Automatic shut to prevent waste feed if the combustion temperature is not maintained.	Condition 2.3.9
50(4)(c)	Automatic shut to prevent waste feed if the CEMs show that ELVs are exceeded due to disturbances or failure of waste cleaning devices.	Condition 2.3.9
50(5)	Any heat generated from the process shall be	(a) The plant will generate



<b>IED Article</b>	<b>Requirement</b>	<b>Delivered by</b>
	recovered as far as practicable.	electricity (b)Operator to review the available heat recovery options every 2 years (Conditions 1.2.1 to 1.2.3)
50(6)	Relates to the feeding of infectious clinical waste into the furnace.	No clinical waste will be burnt
50(7)	Management of the Installation to be in the hands of a natural person who is competent to manage it.	Conditions 1.1.1 to 1.1.3 and 2.3.1 of the Permit.
51(1)	Different conditions than those laid down in Article 50(1), (2) and (3) and, as regards the temperature Article 50(4) may be authorised, provided the other requirements of this chapter are met.	No such conditions Have been allowed
51(2)	Changes in operating conditions do not cause more residues or residues with a higher content of organic polluting substances compared to those residues which could be expected under the conditions laid down in Articles 50(1), (2) and (3).	No such conditions Have been allowed
51(3)	Changes in operating conditions shall include emission limit values for CO and TOC set out in Part 3 of Annex VI.	No such conditions Have been allowed
52(1)	Take all necessary precautions concerning delivery and reception of Wastes, to prevent or minimise pollution.	Conditions 2.3.1, 2.3.3, 3.2, 3.3, 3.4 and 3.6.
52(2)	Determine the mass of each category of wastes, if possible according to the EWC, prior to accepting the waste.	Condition 2.3.3(a) and Table S2.2 in Schedule 3 of the Permit.
52(3)	Prior to accepting hazardous waste, the operator shall collect available information about the waste for the purpose of compliance with the permit requirements specified in Article 45(2).	Not applicable
52(4)	Prior to accepting hazardous waste, the operator shall carry out the procedures set out in Article 52(4).	Not applicable
52(5)	Granting of exemptions from Article 52(2), (3) and (4).	Not applicable
53(1)	Residues to be minimised in their amount and harmfulness, and recycled where appropriate.	Conditions 1.4.1, 1.4.2 and 3.5.1 with Table S3.xx
53(2)	Prevent dispersal of dry residues and dust during transport and storage.	Conditions 1.4.1 2.3.1, 2.3.2 and 3.2.1.
53(3)	Test residues for their physical and chemical characteristics and polluting potential including heavy metal content (soluble fraction).	Condition 3.5.1 and Table S3.4 and pre-operational condition PO2.
55(1)	Application, decision and permit to be publicly available.	All documents are accessible from the Environment Agency Public Register.
55(2)	An annual report on plant operation and monitoring for all plants burning more than 2 tonne/hour waste.	Condition 4.2.2 and 4.2.3.

## ANNEX 1B: COMPLIANCE WITH BAT CONCLUSIONS

BAT conclusion	Criteria	Delivered by
1	Implement environmental management system	Condition 1.1 and Pre-operational condition PO1
2	Determine gross electrical efficiency	Permit table S3.3
3	Monitor key process parameters	Condition 3.5.1 and table S3.3
4	Monitoring emissions to air	Condition 3.5.1 and table S3.1
5	Monitoring emissions to air during OTNOC	Condition 3.5.1 and table S3.1(b)
6	Monitoring emissions to water from flue gas treatment and/or bottom ash treatment	There are no such emissions from the installation
7	Monitor unburnt substances in slags and bottom ashes	Conditions 3.1.5 and 3.5.1, and table S3.4
8	Analysis of hazardous waste	Not applicable
9	Waste stream management techniques	The Application explains the measures that will be used and pre-operational condition PO4.
10	Quality management system for bottom ash treatment plant	Not applicable – no treatment on site
11	Monitor waste deliveries as part of waste acceptance procedures	The Application explains the measures that will be used and pre-operational condition PO4.
12	Reception, handling and storage of waste	Measures are described in the Application
13	Storage and handling of clinical waste	Not applicable
14	Improve overall performance of plant including BAT-AELs for TOC or LOI	Techniques described in the Application. Conditions 3.1.5, 3.5.1 and table S3.4
15	Procedures to adjust plant settings to control performance	Measures described in the Application
16	Procedures to minimise start-up and shut down	Measures described in the Application
17	Appropriate design, operation and maintenance of FGC system	FGC measures described in Application. Operation and maintenance procedures will form part of the EMS
18	OTNOC management plan	Pre-operational condition PO1
19	Use of heat recovery boiler	Described in the Application
20	Measures to increase energy efficiency and BAT AEEL	Measures described in the Application. AEELs not applicable to the plant.
21	Measures to prevent or reduce diffuse emissions including odour	Measures described in the Application.
22	Handling of gaseous and liquid wastes	Not applicable
23	Management system to prevent or reduce dust emissions from treatment of slags and ashes	Not applicable – no treatment on site
24	Techniques to prevent or reduce diffuse emissions to air from treatment of slags and ashes	Note applicable – no treatment on site.

<b>BAT conclusion</b>	<b>Criteria</b>	<b>Delivered by</b>
25	Minimisation of dust and metal emissions and compliance with BAT AEL	Permit conditions 3.1.1 and 3.1.2 and table S3.1
26	Techniques and BAT AEL for dust emissions from enclosed slags and ashes treatment	Not applicable – no treatment included in the permit.
27	Techniques to reduce emissions of HCl, HF and SO <sub>2</sub>	Measures described in the Application.
28	Techniques to reduce peak emissions of HCl, HF and SO <sub>2</sub> , optimise reagent use and BAT AELs	Measures described in the Application. Permit conditions 3.1.1 and 3.1.2 and table S3.1
29	Techniques to reduce emissions of NO <sub>2</sub> , N <sub>2</sub> O, CO and NH <sub>3</sub> and BAT AELs	Measures described in the Application. Permit conditions 3.1.1 and 3.1.2 and table S3.1
30	Reduce emissions of organic compounds including dioxins/furans and PCBs. BAT AELs	Measures described in the Application. Permit conditions 3.1.1 and 3.1.2 and table S3.1
31	Reduce emissions of mercury. BAT AEL	Measures described in the Application. Permit conditions 3.1.1 and 3.1.2 and table S3.1
32	Segregate waste water streams to prevent contamination	Measures described in the Application. Permit conditions 3.1.1, 3.1.2 and table S3.2
33	Techniques to reduce water usage and prevent or reduce waste water	Measures described in the Application.
34	Reduce emissions to water from FGC and/or from treatment or storage of bottom ashes. BAT AELs	Not applicable
35	Handle and treat bottom ashes separately from FGC residues	Permit condition 2.3.14
36	Techniques for treatment of slags and bottom ashes	No treatment carried out on site
37	Techniques to prevent or reduce noise emissions.	Measures are described in the Application.

## ANNEX 2: Pre-Operational Conditions

Based on the information on the Application, we consider that we do need to impose pre-operational conditions. These conditions are set out below and referred to, where applicable, in the text of the decision document. We are using these conditions to require the Operator to confirm that the details and measures proposed in the Application have been adopted or implemented prior to the operation of the Installation.

<b>Table S1.4 Pre-operational measures</b>	
<b>Reference</b>	<b>Pre-operational measures</b>
<b>PO1</b>	<p>Prior to the commencement of commissioning, the Operator shall send:</p> <ul style="list-style-type: none"> <li>• A summary of the site Environment Management System (EMS);and</li> <li>• A copy of the full OTNOC management plan which shall be prepared in accordance with BAT 18 of the BAT conclusions to the Environment Agency and obtain the Environment Agency's written approval to the EMS summary and the full OTNOC management plan.</li> </ul> <p>The Operator shall make available for inspection all documents and procedures which form part of the EMS. The EMS shall be developed in line with the requirements set out in Environment Agency web guide on developing a management system for environmental permits (found on <a href="http://www.gov.uk">www.gov.uk</a>) and BAT 1 of the incineration BAT conclusions. The EMS shall include the approved OTNOC management plan.</p> <p>The documents and procedures set out in the EMS shall form the written management system referenced in condition 1.1.1 (a) of the permit.</p>
<b>PO2</b>	<p>Prior to the commencement of commissioning, the Operator shall submit to the Environment Agency, and obtain the Environment Agency's written approval to it, a protocol for the sampling and testing of cyclone furnace ash for the purposes of assessing its hazard status. Sampling and testing shall be carried out in accordance with the protocol as approved.</p>
<b>PO3</b>	<p>Prior to the commencement of commissioning, the Operator shall submit to the Environment Agency, and obtain the Environment Agency's written approval to it, a written commissioning plan, including timelines for completion, for approval by the Environment Agency. The commissioning plan shall include the expected emissions to the environment during the different stages of commissioning, the expected durations of commissioning activities and the actions to be taken to protect the environment and report to the Environment Agency in the event that actual emissions exceed expected emissions. Commissioning shall be carried out in accordance with the commissioning plan as approved.</p>
<b>PO4</b>	<p>Prior to the commencement of commissioning, the Operator shall submit a written report to the Agency, and obtain the Environment Agency's written approval to it, detailing the waste acceptance procedure to be used at the site. The waste acceptance procedure shall include the process and systems by which wastes unsuitable for incineration at the site will be controlled.</p> <p>The procedure shall be implemented in accordance with the written approval from the Environment Agency.</p>
<b>PO5</b>	<p>No later than one month after the final design of the cyclone furnace, the operator shall submit a written report to the Environment Agency, and obtain the Environment Agency's written approval to it, of the details of the computational fluid dynamic (CFD) modelling. The report shall explain how the cyclone furnace has been designed to comply with the residence time and temperature requirements as defined by Chapter IV and Annex VI of</p>

<b>Table S1.4 Pre-operational measures</b>	
<b>Reference</b>	<b>Pre-operational measures</b>
	the IED whilst operating under normal load and the most unfavourable operating conditions (including minimum turn down and overload conditions), and that the design includes sufficient monitoring ports to support subsequent validation of these requirements during commissioning.
<b>PO6</b>	<p>At least three months before (or other date agreed in writing with the Environment Agency) the commencement of commissioning, the Operator shall submit a written report to the Environment Agency, and obtain the Environment Agency's written approval to it, specifying arrangements for continuous and periodic monitoring of emissions to air to comply with Environment Agency guidance notes M1, M2 and M20. The report shall include the following:</p> <ul style="list-style-type: none"> <li>• Plant and equipment details, including accreditation to MCERTS</li> <li>• Methods and standards for sampling and analysis</li> <li>• Details of monitoring locations, access and working platforms.</li> </ul>
<b>PO7</b>	At least 3 months before the commencement of commissioning (or other date agreed in writing with the Environment Agency) the Operator shall submit, for approval by the Environment Agency, a methodology (having regard to Technical Report P4-100/TR Part 2 Validation of Combustion Conditions) to verify the residence time, minimum temperature and oxygen content of the gases in the cyclone furnace whilst operating under normal load, minimum turn down and overload conditions.
<b>PO8</b>	<p>The operator shall submit a report in writing to the Environment Agency for approval detailing the following points which should be established during commissioning:</p> <ul style="list-style-type: none"> <li>• Definitions of start-up and shutdown for the gas engine and details of the parameters used to indicate that start-up has been completed with justification for use;</li> <li>• The process for ensuring that upon completion of start-up, the operation of the engine, including the temperature is optimised for the combustion of syngas and production of electricity; including details of how these operational objectives correlate and will be managed;</li> <li>• Proposals for monitoring the engines process parameters and any triggers which would indicate that the process is not operating as required, and an associated 'triggers' which would indicate that waste should cease to be charged to the pyrolysis units; and</li> <li>• Location of process parameter monitoring points.</li> </ul>
<b>PO9</b>	<p>The operator shall submit a review of the selected stack height of the gas engine and determine if it is BAT. This shall include but is not limited to:</p> <ul style="list-style-type: none"> <li>• Evidence to show whether the process contribution of annual NO<sub>2</sub> is significantly reduced by a higher stack;</li> <li>• Use of the above information to inform what is BAT for stack height and to propose changes in stack height if appropriate; and</li> <li>• Proposal of an appropriate timescale for improvements.</li> </ul> <p>The review and timescale for improvement shall be submitted to the Environment Agency in writing for approval.</p>

### ANNEX 3: Improvement Conditions

Based in the information in the Application we consider that we need to set improvement conditions. These conditions are set out below - justifications for these is provided at the relevant section of the decision document. We are using these conditions to require the Operator to provide the Environment Agency with details that need to be established or confirmed during and/or after commissioning.

<b>Table S1.3 Improvement programme requirements</b>		
<b>Reference</b>	<b>Requirement</b>	<b>Date</b>
<b>IC1</b>	The Operator shall submit a written report to the Environment Agency on the implementation of its Environmental Management System (EMS) and the progress made in the certification of the system by an external body or if appropriate submit a schedule by which the EMS will be certified.	Within 12 months of the completion of commissioning.
<b>IC2</b>	The Operator shall submit a written proposal to the Environment Agency to carry out tests to determine the size distribution of the particulate matter in the exhaust gas emissions to air from emission point A1, identifying the fractions within the PM <sub>10</sub> , and PM <sub>2.5</sub> ranges. On receipt of written approval from the Environment Agency to the proposal and the timetable, the Operator shall carry out the tests and submit to the Environment Agency a report on the results.	Within 6 months of the completion of commissioning.
<b>IC3</b>	The Operator shall submit a written report to the Environment Agency on the commissioning of the installation. The report shall summarise the environmental performance of the plant as installed against the design parameters set out in the Application. The report shall also include a review of the performance of the facility against the conditions of this permit and details of procedures developed during commissioning for achieving and demonstrating compliance with permit conditions and confirm that the Environmental Management System (EMS) has been updated accordingly.	Within 4 months of the completion of commissioning.
<b>IC4</b>	The operator shall notify the Environment Agency of the proposed date(s) that validation testing is planned for.	Notification at least 3 weeks prior to validation testing
	During commissioning the operator shall carry out validation testing to validate the residence time, minimum temperature and oxygen content of the gases in the cyclone furnace whilst operating under normal load and most unfavourable operating conditions. The validation shall be to the methodology as approved through pre-operational condition PO7.	Validation tests completed before the end of commissioning
<b>IC6</b>	The Operator shall submit a written report to the Environment Agency describing the performance and optimisation of: <ul style="list-style-type: none"> <li>The Selective Non Catalytic Reduction (SNCR) system and combustion settings to minimise oxides of nitrogen (NO<sub>x</sub>).The report shall include an assessment of the level of NO<sub>x</sub>, N<sub>2</sub>O and NH<sub>3</sub> emissions that can be achieved under optimum</li> </ul>	Within 4 months of the completion of commissioning.

<b>Table S1.3 Improvement programme requirements</b>		
<b>Reference</b>	<b>Requirement</b>	<b>Date</b>
	<p>operating conditions.</p> <ul style="list-style-type: none"> <li>• The wet scrubbing systems for minimisation of acid gas emissions.</li> <li>• The carbon abatement system for minimisation of dioxin and heavy metal emissions.</li> </ul>	
<b>IC7</b>	<p>The Operator shall carry out an assessment of the impact of emissions to air of the following component metals subject to emission limit values: Cd, As, Cr, Mn and Ni</p> <p>A report on the assessment shall be made to the Environment Agency.</p> <p>Emissions monitoring data obtained during the first year of operation shall be used to compare the actual emissions with those assumed in the impact assessment submitted with the Application. An assessment shall be made of the impact of each metal against the relevant ES. In the event that the assessment shows that an environmental standard can be exceeded, the report shall include proposals for further investigative work.</p>	15 months from the completion of commissioning
<b>IC8</b>	<p>The Operator shall submit a written summary report to the Environment Agency to confirm that the performance of Continuous Emission Monitors for parameters as specified in Table S3.1 and Table S3.1(a) complies with the requirements of BS EN 14181, specifically the requirements of QAL1, QAL2 and QAL3. The report shall include the results of calibration and verification testing,</p>	<p>Initial calibration report to be submitted to the Agency within 3 months of completion of commissioning.</p> <p>Full summary evidence compliance report to be submitted within 18 months of completion of commissioning.</p>
<b>IC9</b>	<p>The operator shall carry out a programme of dioxin and dioxin like PCB monitoring over a period and frequency agreed with the Environment Agency. The operator shall submit a report to the Environment Agency with an analysis of whether dioxin emissions can be considered to be stable.</p>	<p>Within 3 months of completion of commissioning or as agreed in writing with the Environment Agency</p>
<b>IC10</b>	<p>The operator shall carry out a programme of mercury monitoring over a period and frequency agreed with the Environment Agency. The operator shall submit a report to the Environment Agency with an analysis of whether the waste feed to the plant can be proven to have a low and stable mercury content.</p>	<p>Within 3 months of completion of commissioning or as agreed in writing with the Environment Agency</p>

<b>Table S1.3 Improvement programme requirements</b>		
<b>Reference</b>	<b>Requirement</b>	<b>Date</b>
<b>IC11</b>	The Operator shall submit a report to the Environment Agency for approval on start-up and shut-down conditions for the cyclone furnace and the pyrolysis plant over the first 12 months of operation. The report shall identify any amendments to the start-up and shut-down definitions that were described in the application.	Within 15 months of completion of commissioning or as agreed in writing with the Environment Agency



## **ANNEX 4: Consultation Responses**

### **A) Advertising and Consultation on the Application**

The Application has been advertised and consulted upon in accordance with the Environment Agency's Public Participation Statement. The way in which this has been carried out along with the results of our consultation and how we have taken consultation responses into account in reaching our draft decision is summarised in this Annex. Copies of all consultation responses have been placed on the Environment Agency public register.

The Application was first advertised on the Environment Agency website from 25 March 2019 to 24 April 2019. As a result of additional information received during the determination, the Application was advertised again with the new information from 07 August 2019 to 05 September 2019. The Application was made available to view at the Environment Public Register at Environment Agency, Sentential House, 9 Wellington Crescent, Fradley Park, Lichfield, Staffordshire, WS13 8RR

The following statutory and non-statutory bodies were consulted: -

- Public Health England
- The Food Standards Agency
- The Health and Safety Executive
- Environmental Health – Dudley Council
- Local Planning Authority – Dudley Council
- West Midlands Fire and Rescue Service

#### **1) Consultation Responses from Statutory and Non-Statutory Bodies**

Response Received from Public Health England on 30 August 2019	
Brief summary of issues raised:	Summary of action taken / how this has been covered
Based on the information contained in the application, Public Health England has no significant concerns regarding the risk to the health of the local population from the installation.	No action required.

Response Received from Local Planning Authority, Dudley Council on 16 April 2019	
Brief summary of issues raised:	Summary of action taken / how this has been covered
The Local Authority are not currently aware of any noise or other amenity issues at the site and there are no outstanding enforcement issues or enforcement action in relation to the site.	No action required.

We received no responses from the other consultees listed above.

**2) Consultation Responses from Members of the Public and Community Organisations**

a) Representations from Local MP, Councillors and Parish / Town / Councils

No representations received.

b) Representations from Community and Other Organisations

Representations were received from UK Without Incineration Network (UKWIN) who raised the following points:

<b>Point raised</b>	<b>Our response</b>	<b>Corresponding condition / decision document section</b>
The Air Emissions Risk Assessment does not give the locations of the 4 stacks so it is not possible to cross check the emissions modelling.	The Applicant revised the layout of the site and resubmitted an air quality impact assessment to reflect the changes. We re-consulted on the revised assessment which showed the revised layout.  Our Air Quality Modelling and Assessment Unit (AQMAU) has audited the air quality modelling in line with the relevant guidance.	Section 5.3 of the decision document
The applicant proposes to rely on 'just in time' deliveries of feedstock. This is unrealistic.	The site will receive waste from the waste management site next door and therefore we consider the 'just in time' approach viable and acceptable.	Section 4.3.6 of the decision document.
The technology is complex and brings safety and environmental risk implications.	The details of the process engineering of the site is outside of our remit, however we would expect the Operator to ensure that the technology is	Section 6 of the decision document.  Condition 2.3 and table S1.2 of the permit.

	<p>installed and maintained to a high safety standard.</p> <p>We have consulted with the Health and Safety Executive on this application.</p> <p>A best available techniques (BAT) assessment was submitted by the Applicant and we have assessed this.</p>	
--	---	--

c) Representations from Individual Members of the Public

One response was received from individual members of the public and the key points are outlined in the following table.

<b>Point raised</b>	<b>Our response</b>	<b>Corresponding condition / decision document section</b>
The Air Emissions Risk Assessment does not give the locations of the 4 stacks so it is not possible to cross check the emissions modelling.	<p>The Applicant revised the layout of the site and resubmitted an air quality impact assessment to reflect the changes. We re-consulted on the revised assessment which showed the revised layout.</p> <p>Our Air Quality Modelling and Assessment Unit (AQMAU) has audited the air quality modelling in line with the relevant guidance.</p>	Section 5.3 of the decision document
The Application Documents do not provide any specific detail on the engineering and safety standards incorporated into the design.	A best available techniques (BAT) assessment was submitted by the Applicant and we have assessed this. We requested additional information via	<p>Section 6 of the decision document.</p> <p>Condition 2.3 and table S1.2 of the permit.</p>

	Schedule 5 notices and assessed all additional information received. We have consulted with the Health and Safety Executive on this application.	
Concern that the proposed plant will create significant VOC / odour emissions from the cooling of the syngas using open cycle evaporative cooling towers.	A best available techniques (BAT) assessment was submitted by the Applicant and we have assessed this. We requested additional information via Schedule 5 notices and assessed all additional information received.	
Based on a review of the planning portal, an application has been made for the site, but to date has not been granted.	The Environment Agency doesn't require a site to have planning permission in order to grant a permit for the site.	Section 7 of the decision document.