

Environment Agency

Review of an Environmental Permit for an Installation subject to Chapter II of the Industrial Emissions Directive under the Environmental Permitting (England & Wales) Regulations 2016

Decision document recording our decision-making process following review of a permit

The Permit number is: EPR/ZP3231AE
The Operator is: Cramlington Renewable Energy
 Developments Limited
The Installation is: Cramlington Biomass CHP Plant
This Variation Notice number is: EPR/ZP3231AE/V002

What this document is about

Article 21(3) of the Industrial Emissions Directive (IED) requires the Environment Agency to review conditions in permits that it has issued and to ensure that the permit delivers compliance with relevant standards, within four years of the publication of updated decisions on best available techniques (BAT) conclusions.

We have reviewed the permit for this installation against the revised BAT Conclusions for large combustion plant published on 17th August 2017. This is our decision document, which explains the reasoning for the consolidated variation notice that we are issuing.

It explains how we have reviewed and considered the techniques used by the Operator in the operation and control of the plant and activities of the installation. This review has been undertaken with reference to the decision made by the European Commission establishing best available techniques (BAT) conclusions ('BAT Conclusions') for large combustion plant as detailed in document reference IEDC-7-1. It is our record of our decision-making process and shows how we have taken into account all relevant factors in reaching our position. It also provides a justification for the inclusion of any specific conditions in the permit that are in addition to those included in our generic permit template.

As well as considering the review of the operating techniques used by the Operator for the operation of the plant and activities of the installation, the consolidated variation notice takes into account and brings together in a

single document all previous variations that relate to the original permit issued. It also modernises the entire permit to reflect the conditions contained in our current generic permit template.

The introduction of new template conditions makes the Permit consistent with our current general approach and philosophy and with other permits issued to installations in this sector. Although the wording of some conditions has changed, while others have been removed because of the new regulatory approach, it does not reduce the level of environmental protection achieved by the Permit in any way. In this document we therefore address only our determination of substantive issues relating to the new BAT Conclusions.

Throughout this document we will use a number of expressions. These are as referred to in the glossary and have the same meaning as described in “Schedule 6 Interpretation” of the Permit.

We try to explain our decision as accurately, comprehensively and plainly as possible. We would welcome any feedback as to how we might improve our decision documents in future. A lot of technical terms and acronyms are inevitable in a document of this nature: we provide a glossary of acronyms near the front of the document, for ease of reference.

How this document is structured

Glossary of terms

- 1 Our decision
- 2 How we reached our decision
- 2.1 Requesting information to demonstrate compliance with BAT Conclusions for Large Combustion Plant
- 2.2 Review of our own information in respect to the capability of the installation to meet revised standards included in the BAT Conclusions document
- 3 The legal framework
- 4 Key Issues
- 4.1 Emissions to air and emissions limits applied to the plant
- 4.2 The energy efficiency levels associated with Best Available Techniques
- 4.3 Environment Management System
- 4.4 Fuel Characterisation
- 4.5 Waste Management
- 5 Decision checklist regarding relevant BAT Conclusions
- 6 Review and assessment of derogation requests made by the operator in relation to BAT Conclusions which include an associated emission level (AEL) value
- 7 Emissions to Water
- 8 Additional IED Chapter II requirements
- 9 Review and assessment of changes that are not part of the BAT Conclusions derived permit review.

Glossary of acronyms used in this document

(Please note that this glossary is standard for our decision documents and therefore not all these acronyms are necessarily used in this document.)

APC	Air Pollution Control
BAT	Best Available Technique(s)
BAT-AEEL	BAT Associated Energy Efficiency Level
BAT-AEL	BAT Associated Emission Level
BATc	BAT conclusion
BREF	Best available techniques reference document
CEM	Continuous emissions monitor
CHP	Combined heat and power
CV	Calorific value
DAA	Directly associated activity – Additional activities necessary to be carried out to allow the principal activity to be carried out
EIONET	European environment information and observation network is a partnership network of the European Environment Agency
ELV	Emission limit value derived under BAT or an emission limit value set out in IED
EMS	Environmental Management System
EPR	Environmental Permitting (England and Wales) Regulations 2016 (SI 2016 No. 1154)
EWC	European waste catalogue
FSA	Food Standards Agency
IC	Improvement Condition
IED	Industrial Emissions Directive (2010/75/EU)
IPPCD	Integrated Pollution Prevention and Control Directive (2008/1/EC) – now superseded by IED
LCP	Large Combustion Plant subject to Chapter III of IED
MSUL/MSDL	Minimum start up load/minimum shut-down load
NO _x	Oxides of nitrogen (NO plus NO ₂ expressed as NO ₂)
NPV	Net Present Value
PHE	Public Health England
SAC	Special Area of Conservation
SGN	Sector guidance note
TGN	Technical guidance note
TOC	Total Organic Carbon
WFD	Water Framework Directive (2000/60/EC)

1 Our decision

We have decided to issue the consolidated variation notice to the Operator. This will allow it to continue to operate the Installation, subject to the conditions in the consolidated variation notice.

We consider that, in reaching that decision, we have taken into account all relevant considerations and legal requirements and that the varied permit will ensure that a high level of protection is provided for the environment and human health.

The consolidated variation notice contains many conditions taken from our standard Environmental Permit template including the relevant Annexes. We developed these conditions in consultation with industry, having regard to the legal requirements of the Environmental Permitting Regulations and other relevant legislation. This document does not therefore include an explanation for these standard conditions. Where they are included in the Notice, we have considered the techniques identified by the operator for the operation of their installation, and have accepted that the details are sufficient and satisfactory to make those standard conditions appropriate. This document does, however, provide an explanation of our use of “tailor-made” or installation-specific conditions, or where our Permit template provides two or more options.

2 How we reached our decision

2.1 Requesting information to demonstrate compliance with BAT Conclusions for Large Combustion Plant

We issued a Notice under Regulation 61(1) of the Environmental Permitting (England and Wales) Regulations 2016 (a Regulation 61 Notice) on 1st May 2018 requiring the Operator to provide information to demonstrate how the operation of their installation currently meets, or will subsequently meet, the revised standards described in the large combustion plant BAT Conclusions document. The Notice also required that where the revised standards are not currently met, the operator should provide information that:

- Describes the techniques that will be implemented before 17th August 2021, which will then ensure that operations meet the revised standard, or
- Justifies why standards will not be met by 17th August 2021, and confirmation of the date when the operation of those processes will cease within the installation or an explanation of why the revised BAT standard is not applicable to those processes, or
- Justifies why an alternative technique will achieve the same level of environmental protection equivalent to the revised standard described in the BAT Conclusions.

Where the Operator proposed that they were not intending to meet a BAT standard that also included a BAT Associated Emission Level (BAT AEL) described in the BAT Conclusions Document, the Regulation 61 Notice requested that the Operator make a formal request for derogation from compliance with that AEL (as provisioned by Article 15(4) of IED). In this circumstance, the Notice identified that any such request for derogation must be supported and justified by sufficient technical and commercial information that would enable us to determine acceptability of the derogation request.

The Regulation 61 Notice response from the Operator was received on 01/11/18.

We considered that the response did not contain sufficient information for us to commence the permit review. We therefore issued a further information request to the Operator on 09/09/19. Suitable further information was provided by the Operator on 04/10/19.

We considered it was in the correct form and contained sufficient information for us to begin our determination of the permit review but not that it necessarily contained all the information we would need to complete that review: see below.

2.2 Review of our own information in respect to the capability of the installation to meet revised standards included in the BAT Conclusions document

Based on our records and previous regulatory activities with the facility we have no reason to consider that the operator will not be able to comply with the conditions that we include in the permit.

In relation to BAT Conclusion(s) 1, 9 and 16 we agree with the operator in respect to their current stated capability as recorded in their Regulation 61 Notice response that improvements are required.

We have therefore included an improvement conditions IC5, IC9 and IC16 in the consolidated variation notice, which requires them to upgrade their operational techniques so that the requirements of the BAT Conclusion are delivered by 17 August 2021. This is discussed in more detail in the key issues section and/or in the decision checklist regarding relevant BAT Conclusions.

3 The legal framework

The consolidated variation notice will be issued under Regulation 20 of the EPR. The Environmental Permitting regime is a legal vehicle which delivers most of the relevant legal requirements for activities falling within its scope. In particular, the regulated facility is:

- an *installation* as described by the IED;
- subject to aspects of other relevant legislation which also have to be addressed.

We consider that the consolidated variation notice will ensure that the operation of the Installation complies with all relevant legal requirements and that a high level of protection will be delivered for the environment and human health.

We explain how we have addressed specific statutory requirements more fully in the rest of this document.

4 The key issues

The key issues arising during this permit review are:

- Emissions to air and the emission limits applied to the plant.
- The energy efficiency levels associated with the Best Available Techniques (BAT-AEELs)
- BAT 9 characterisation of fuel

We therefore describe how we determined these issues in most detail in the relevant sections of this document.

4.1 Emissions to air and the emission limits applied to the plant

A number of general principles were applied during the permit review. These included:

- The upper value of the BAT AELs ranges specified were used unless use of the tighter limit was justified.
- The principle of no backsliding where if existing limits in the permit were already tighter than those specified in the BREF, the existing permit limits were retained.
- Where a limit was specified in both IED Annex V and the BAT Conclusions for a particular reference period, the tighter limit was applied and in the majority of cases this was from the BAT Conclusions.
- Where AELs are indicative in the BAT Conclusions, these were applied unless adequate justification was provided by the operator to demonstrate that an alternative limit was more appropriate.

The one LCP on site is referenced as LCP 649 and is a biomass fired boiler which has a thermal input of 75 MW.

The plant was put into operation after IED came into force and therefore the existing limits in the permit are from Part 2 of IED Annex V applicable to new plant.

The ELVs and AELs are based on the following operating regime:

- Unlimited hours operation

The following tables outline the limits that have been incorporated into the permit for LCP 649, where these were derived from and the reference periods at which they apply. The emission limits refer to concentrations, expressed as mass of emitted substance per volume of flue-gas under the following standard conditions: dry gas at a temperature of 273,15 K, pressure of 101,3 kPa and 6% select correct oxygen reference value for plant volume reference

oxygen concentration if flue gases. The emission limits and monitoring requirements have been incorporated into Schedule 3 of the permit.

NOx limits (mg/Nm ³)						
Averaging	IED (Annex V Part 2) – New	BREF (Table 9 BAT-c)	Expected permit limits	Basis	Limits apply	Monitoring
Annual	None	225	225	BREF	MSUL/MSDL to baseload	Continuous
Monthly	250	None	250	IED	MSUL/MSDL to baseload	
Daily	275	275	275	IED	MSUL/MSDL to baseload	
95 th %ile of hr means	500	None	500	IED	MSUL/MSDL to baseload	

CO limits (mg/Nm ³)						
Averaging	IED (Annex V Part 2) - New	BREF (Table 9 BAT-c)	Expected permit limits	Basis	Limits apply	Monitoring
Annual	None	250	250	BREF	MSUL/MSDL to baseload	Continuous

SO ₂ limits (mg/Nm ³)						
Averaging	IED (Annex V Part 2) - New	BREF (Table 10 BAT-c)	Expected permit limits	Basis	Limits apply	Monitoring
Annual	None	100	100	BREF	MSUL/MSDL to baseload	Continuous
Monthly	200	None	100	Existing Permit	MSUL/MSDL to baseload	
Daily	220	215	110	Existing Permit	MSUL/MSDL to baseload	
95 th %ile of hr means	400	None	200	Existing Permit	MSUL/MSDL to baseload	

Under the no backsliding rule the Monthly, Daily and Hourly limits will be 100 mg/Nm³, 110 mg/Nm³ and 200 mg/Nm³ respectively, as specified in the existing permit.

HCl limits (mg/Nm ³)						
Averaging	IED (Annex V Part 2) - New	BREF (Table 11 BAT-c)	Expected permit limits	Basis	Limits apply	Monitoring
Annual	None	15	15	BREF	MSUL/MSDL to baseload	Continuous
Daily	None	35	35	BREF	MSUL/MSDL to baseload	

HF limits (mg/Nm ³)						
Averaging	IED (Annex V Part 2) - New	BREF (Table 11 BAT-c)	Expected permit limits	Basis	Limits apply	Monitoring
Average over sampling period	None	< 1.5	< 1.5	BREF	MSUL/MSDL to baseload	Once per year

Dust limits (mg/Nm ³)						
Averaging	IED (Annex V Part 2) - New	BREF (Table 12 BAT-c)	Expected permit limits	Basis	Limits apply	Monitoring
Annual	None	15	15	BREF	MSUL/MSDL to baseload	Continuous
Monthly	20	None	20	IED	MSUL/MSDL to baseload	
Daily	22	22	22	IED	MSUL/MSDL to baseload	
95 th %ile of hr means	40	None	40	IED	MSUL/MSDL to baseload	

NH ₃ limits (mg/Nm ³)						
Averaging	IED (Annex V Part 2) - New	BREF (BAT conclusion 7)	Expected permit limits	Basis	Limits apply	Monitoring
Yearly	None	15	15	BREF	MSUL/MSDL to baseload	Continuous

Hg limits (mg/Nm ³)						
Averaging	IED (Annex V Part 2) - New	BREF (BAT conclusion 27)	Expected permit limits	Basis	Limits apply	Monitoring
Average over sampling period	None	5	5	BREF	MSUL/MSDL to baseload	Once per year

4.2 The energy efficiency levels associated with the Best Available Techniques Conclusions

An energy efficiency level associated with the best available techniques (BAT-AEEL) refers to the ratio between the combustion unit's net energy output(s) and the combustion unit's fuel/feedstock energy input at actual unit design. The net energy output(s) is determined at the combustion unit boundaries, including auxiliary systems (e.g. flue-gas treatment systems), and for the unit operated at full load.

The table below sets out the BAT-AEELs specified in the LCP BAT Conclusions for the large combustion plant on the site and the energy efficiency levels confirmed through the Regulation 61 notice response. The evidence provided to demonstrate that the AEELs are met was specified in their regulation 61 response. We consider that the figure provide for the plant is BAT in relation to the AEELs.

BAT AEELs (%)			Plant efficiency (%)		
Net electrical efficiency	Net total fuel utilisation	Net mechanical efficiency	Net electrical efficiency	Net total fuel utilisation	Net mechanical efficiency
LCP 649 – condensing mode: unit description from the AEEL table					
28 - 38	None	None	36.42%	NA	NA
LCP 649– heat export mode: unit description from the AEEL table					
28 - 38	None	None	34.04%	NA	NA

4.3 Environment Management System

BAT 1 requires the operator to have an environment management system (EMS) in place that addresses all relevant points (i) – (xvi) as specified under this BAT conclusion. The operator has identified that points (vii), (viii), (ix) and (xi) have not covered in the EMS.

We have therefore included an improvement condition (IC) 5 requiring the operator to update the EMS to include procedures that cover the requirements of points (vii), (viii), (ix) and (xi), as specified under BAT 1.

4.4 Fuel characterisation

BAT 9 requires the operator to carry out fuel characterisation. The commissioning of the plant had not yet been completed. As a result the fuel has not yet been characterised as required under point i) of this BAT conclusion. Criteria ii) in relation to the regular testing of fuels and iii) in relation to incorporating the fuel characterisation changes identified as a result of regular testing back into the control system to improve performance have not been developed.

We have therefore included an improvement condition (IC) in the consolidated variation notice IC3 requiring the operator to submit a plan outlining how this will be carried out for approval prior to the implementation date for the BAT Conclusions.

4.5 Waste Management

BAT 16 requires the operator to reduce the quantity of waste sent for disposal from the combustion plant by taking into account life-cycle thinking, considering measures such as waste prevention, Waste preparation for reuse, Waste recycling and waste recovery. The disposal/recovery route for fly ash and bottom ash has not yet been defined.

We have therefore included an improvement condition (IC) in the consolidated variation notice IC4 requiring the operator to submit a plan outlining how this

will be carried out for approval prior to the implementation date for the BAT Conclusions.

5 Decision checklist regarding relevant BAT Conclusions

BAT Conclusions for large combustion plant, were published by the European Commission on 17th August 2017. There are 75 BAT Conclusions. Only the BAT Conclusions relevant to the particular fuel type used on site have been replicated below.

This annex provides a record of decisions made in relation to each relevant BAT Conclusion applicable to the installation. This annex should be read in conjunction with the Consolidated Variation Notice.

The conditions in the permit through which the relevant BAT Conclusions are implemented include but are not limited to the following:

BAT Conclusion requirement topic	Permit condition(s)	Permit table(s)
Environmental Management System	1.1.1	S1.2
BAT AELs	3.1.1 and 3.5.1	S3.1a
Monitoring	2.3, 3.5 and 3.6	S3.1, S3.1a, S3.2
Energy efficiency	1.2 and 2.3	S3.3
Noise	3.4 and 2.3	S1.2
Other operating techniques	1.2	S1.2

The overall status of compliance with the BAT conclusion is indicated in the table as:

- NA Not Applicable
- CC Currently Compliant
- FC Compliant in the future (within 4 years of publication of BAT conclusions)
- NC Not Compliant
- PC Partially Compliant

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
General			
1	<p>In order to improve the overall environmental performance, BAT is to implement and adhere to an environmental management system (EMS) that incorporates all of the following features:</p> <ul style="list-style-type: none"> i. commitment of the management, including senior management; ii. definition of an environmental policy that includes the continuous improvement of the installation by the management; iii. planning and establishing the necessary procedures, objectives and targets, in conjunction with financial planning and investment; iv. implementation of procedures <ul style="list-style-type: none"> (a) Structure and responsibility (b) Training (c) Communication (d) Employee involvement (e) Documentation (f) Efficient process control (g) Maintenance programmes (h) Emergency preparedness and response (i) Safeguarding compliance with environmental legislation v. checking performance and taking corrective action, paying particular attention to: <ul style="list-style-type: none"> (a) monitoring and measurement (see also the Reference Document on the General Principles of Monitoring) (b) corrective and preventive action (c) maintenance of records (d) independent (where practicable) internal and external auditing in order to determine whether or not the EMS conforms to planned arrangements and has been properly implemented and maintained; vi. review of the EMS and its continuing suitability, adequacy and effectiveness by senior management; vii. following the development of cleaner technologies; viii. consideration for the environmental impacts from the eventual decommissioning of the installation at the stage of designing a new plant, and throughout its operating life; viii. consideration for the environmental impacts from the eventual decommissioning of the installation at the stage of designing a new plant, and throughout its operating life; ix. application of sectoral benchmarking on a regular basis. <p>Etc - see BAT Conclusions</p>	FC	<p>A site specific Environment Management System (EMS) is in place. Further information needs to be incorporated into the EMS in order for it to be in compliance. The information required relates to points (vii), (viii), (ix) and (xi). Improvement condition 5 has been included requesting that the EMS is updated to include procedures relating to these points.</p>

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement												
	Applicability. The scope (e.g. level of detail) and nature of the EMS (e.g. standardised or non-standardised) will generally be related to the nature, scale and complexity of the installation, and the range of environmental impacts it may have.														
2	BAT is to determine the net electrical efficiency and/or the net total fuel utilisation and/or the net mechanical energy efficiency of the gasification, IGCC and/or combustion units by carrying out a performance test at full load (1), according to EN standards, after the commissioning of the unit and after each modification that could significantly affect the net electrical efficiency and/or the net total fuel utilisation and/or the net mechanical energy efficiency of the unit. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.	CC	The net electrical efficiency has been calculated by carrying out a performance test at full load in both condensing (36.42%) and heat export mode (34.04%).												
3	<p>BAT is to monitor key process parameters relevant for emissions to air and water including those given below.</p> <table border="1" data-bbox="322 722 1491 895"> <thead> <tr> <th data-bbox="322 722 687 759">Stream</th> <th data-bbox="687 722 1124 759">Parameter(s)</th> <th data-bbox="1124 722 1491 759">Monitoring</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 759 687 863" rowspan="3">Flue-gas</td> <td data-bbox="687 759 1124 796">Flow</td> <td data-bbox="1124 759 1491 796">Periodic or continuous determination</td> </tr> <tr> <td data-bbox="687 796 1124 833">Oxygen content, temperature, and pressure</td> <td data-bbox="1124 796 1491 833" rowspan="2">Periodic or continuous measurement</td> </tr> <tr> <td data-bbox="687 833 1124 863">Water vapour content⁽³⁾</td> </tr> <tr> <td data-bbox="322 863 687 895">Waste water from flue-gas treatment</td> <td data-bbox="687 863 1124 895">Flow, pH, and temperature</td> <td data-bbox="1124 863 1491 895">Continuous measurement</td> </tr> </tbody> </table>	Stream	Parameter(s)	Monitoring	Flue-gas	Flow	Periodic or continuous determination	Oxygen content, temperature, and pressure	Periodic or continuous measurement	Water vapour content ⁽³⁾	Waste water from flue-gas treatment	Flow, pH, and temperature	Continuous measurement	CC	<p>Flow, temperature, oxygen, pressure and water vapour content are monitored continuously from the CEMS platform on the emissions stack.</p> <p>Temperature is also monitored just above the secondary combustion zone to determine if wood firing is in operation.</p> <p>Monitoring oxygen content allows control of air/fuel firing ratio of the firing.</p> <p>Pressure is also monitored in the furnace to ensure entire flue gas pass is under negative pressure.</p>
Stream	Parameter(s)	Monitoring													
Flue-gas	Flow	Periodic or continuous determination													
	Oxygen content, temperature, and pressure	Periodic or continuous measurement													
	Water vapour content ⁽³⁾														
Waste water from flue-gas treatment	Flow, pH, and temperature	Continuous measurement													
4	<p>BAT is to monitor emissions to air with at least the frequency given below and in accordance with EN standards. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.</p> <table border="1" data-bbox="322 1265 1491 1340"> <thead> <tr> <th data-bbox="322 1265 477 1340">Substance/Parameter</th> <th data-bbox="477 1265 790 1340">Fuel/Process/Type of combustion plant</th> <th data-bbox="790 1265 947 1340">Combustion plant total rated</th> <th data-bbox="947 1265 1124 1340">Standard(s)⁽⁴⁾</th> <th data-bbox="1124 1265 1346 1340">Minimum monitoring frequency⁽⁵⁾</th> <th data-bbox="1346 1265 1491 1340">Monitoring associated with</th> </tr> </thead> <tbody> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> </tbody> </table>	Substance/Parameter	Fuel/Process/Type of combustion plant	Combustion plant total rated	Standard(s) ⁽⁴⁾	Minimum monitoring frequency ⁽⁵⁾	Monitoring associated with							FC	<p>The operator has confirmed the following.</p> <p>Monitoring of the following parameters for emissions to air</p>
Substance/Parameter	Fuel/Process/Type of combustion plant	Combustion plant total rated	Standard(s) ⁽⁴⁾	Minimum monitoring frequency ⁽⁵⁾	Monitoring associated with										

BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
			thermal input				<p>apply to solid biomass combustion plant.</p> <p>NH₃ – Continuous – BS EN 14181</p> <p>NO_x – Continuous – BS EN 14181</p> <p>CO - Continuous – BS 14181</p> <p>SO₂ – Continuous – BS 14181</p> <p>HCl – Continuous – BS14181</p> <p>HF – Continuous – BS14181</p> <p>Dust – Continuous – BS14181</p> <p>Metals and Metalloids – Periodic (once per year) – EN14385. The operator has confirmed that the installation will be compliant with this monitoring requirement by 31st July 2021, which is the date by which full compliance with BAT conclusions is required.</p> <p>Hg – Periodic (once per year) – EN 13211. The operator has confirmed that the installation will be compliant with this monitoring requirement by 31st July 2021, which is the date by which full compliance with BAT conclusions is required.</p>	
NH ₃	— When SCR and/or SNCR is used	All sizes	Generic EN standards	Continuous ⁽⁶⁾ (7)	BAT 7			
NO _x	<ul style="list-style-type: none"> — Coal and/or lignite including waste co-incineration — Solid biomass and/or peat including waste co-incineration — HFO- and/or gas-oil-fired boilers and engines — Gas-oil-fired gas turbines — Natural-gas-fired boilers, engines, and turbines — Iron and steel process gases — Process fuels from the chemical industry — IGCC plants 	All sizes	Generic EN standards	Continuous ⁽⁶⁾ (8)	BAT 20 BAT 24 BAT 28 BAT 32 BAT 37 BAT 41 BAT 42 BAT 43 BAT 47 BAT 48 BAT 56 BAT 64 BAT 65 BAT 73			
	— Combustion plants on offshore platforms	All sizes	EN 14792	Once every year ⁽⁹⁾	BAT 53			
N ₂ O	<ul style="list-style-type: none"> — Coal and/or lignite in circulating fluidised bed boilers — Solid biomass and/or peat in circulating fluidised bed boilers 	All sizes	EN 21258	Once every year ⁽¹⁰⁾	BAT 20 BAT 24			
CO	<ul style="list-style-type: none"> — Coal and/or lignite including waste co-incineration — Solid biomass and/or peat including waste co-incineration 	All sizes	Generic EN standards	Continuous ⁽⁶⁾ (8)	BAT 20 BAT 24 BAT 28 BAT 33 BAT 38 BAT 44 BAT 49			

BAT Concn. Numbe r	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
		<ul style="list-style-type: none"> — HFO- and/or gas-oil-fired boilers and engines — Gas-oil-fired gas turbines — Natural-gas-fired boilers, engines, and turbines — Iron and steel process gases — Process fuels from the chemical industry — IGCC plants 				BAT 56 BAT 64 BAT 65 BAT 73	We agree that the operator is in compliance with the monitoring requirements of this BAT conclusion.	
	<ul style="list-style-type: none"> — Combustion plants on offshore platforms 	All sizes	EN 15058	Once every year ⁽⁹⁾	BAT 54			
SO ₂	<ul style="list-style-type: none"> — Coal and/or lignite incl waste co-incineration — Solid biomass and/or peat incl waste co-incineration — HFO- and/or gas-oil-fired boilers — HFO- and/or gas-oil-fired engines — Gas-oil-fired gas turbines — Iron and steel process gases — Process fuels from the chemical industry in boilers — IGCC plants 	All sizes	Generic EN standards and EN 14791	Continuous ⁽⁶⁾ ⁽¹¹⁾ ⁽¹²⁾	BAT 21 BAT 25 BAT 29 BAT 34 BAT 39 BAT 50 BAT 57 BAT 66 BAT 67 BAT 74			
SO ₃	<ul style="list-style-type: none"> — When SCR is used 	All sizes	No EN standard available	Once every year	—			
Gaseous chlorides, expressed as HCl	<ul style="list-style-type: none"> — Coal and/or lignite — Process fuels from the chemical industry in boilers 	All sizes	EN 1911	Once every three months ⁽⁶⁾ ⁽¹³⁾ ⁽¹⁴⁾	BAT 21 BAT 57			

BAT Concn. Numbe r	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
		— Solid biomass and/or peat	All sizes	Generic EN standards	Continuous ⁽¹⁵⁾ ₍₁₆₎	BAT 25		
		— Waste co-incineration	All sizes	Generic EN standards	Continuous ⁽⁶⁾ ₍₁₆₎	BAT 66 BAT 67		
HF		— Coal and/or lignite — Process fuels from the chemical industry in boilers	All sizes	No EN standard available	Once every three months ⁽⁶⁾ ₍₁₃₎ ₍₁₄₎	BAT 21 BAT 57		
		— Solid biomass and/or peat	All sizes	No EN standard available	Once every year	BAT 25		
		— Waste co-incineration	All sizes	Generic EN standards	Continuous ⁽⁶⁾ ₍₁₆₎	BAT 66 BAT 67		
Dust		— Coal and/or lignite — Solid biomass and/or peat — HFO- and/or gas-oil-fired boilers — Iron and steel process gases — Process fuels from the chemical industry in boilers — IGCC plants — HFO- and/or gas-oil-fired engines — Gas-oil-fired gas turbines	All sizes	Generic EN standards and EN 13284-1 and EN 13284-2	Continuous ⁽⁶⁾ ₍₁₇₎	BAT 22 BAT 26 BAT 30 BAT 35 BAT 39 BAT 51 BAT 58 BAT 75		
		— Waste co-incineration	All sizes	Generic EN standards and EN 13284-2	Continuous	BAT 68 BAT 69		
Metals and metalloids except mercury (As, Cd, Co, Cr, Cu, Mn, Ni, Pb,		— Coal and/or lignite — Solid biomass and/or peat — HFO- and/or gas-oil-fired boilers and engines	All sizes	EN 14385	Once every year ₍₁₈₎	BAT 22 BAT 26 BAT 30		

BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	Sb, Se, Tl, V, Zn)	— Waste co-incineration	< 300 MW _{th}	EN 14385	Once every six months ₍₁₃₎	BAT 68 BAT 69		
			≥ 300 MW _{th}	EN 14385	Once every three months ₍₁₉₎₍₁₃₎			
		— IGCC plants	≥ 100 MW _{th}	EN 14385	Once every year ₍₁₈₎	BAT 75		
	Hg	— Coal and/or lignite including waste co- incineration	< 300 MW _{th}	EN 13211	Once every three months ₍₁₃₎₍₂₀₎	BAT 23		
			≥ 300 MW _{th}	Generic EN standards and EN 14884	Continuous ₍₁₆₎₍₂₁₎			
		— Solid biomass and/or peat	All sizes	EN 13211	Once every year ₍₂₂₎	BAT 27		
		— Waste co-incineration with solid biomass and/or peat	All sizes	EN 13211	Once every three months ₍₁₃₎	BAT 70		
		— IGCC plants	≥ 100 MW _{th}	EN 13211	Once every year ₍₂₃₎	BAT 75		
	TVOC	— HFO- and/or gas-oil-fired engines	All sizes	EN 12619	Once every six months ₍₁₃₎	BAT 33 BAT 59		
		— Process fuels from chemical industry in boilers						
		— Waste co-incineration with coal, lignite, solid biomass and/or peat	All sizes	Generic EN standards	Continuous	BAT 71		
	Formaldehyde	— Natural-gas in spark- ignited lean-burn gas and dual fuel engines	All sizes	No EN standard available	Once every year	BAT 45		
	CH ₄	— Natural-gas-fired engines	All sizes	EN ISO 25139	Once every year ₍₂₄₎	BAT 45		
	PCDD/F	— Process fuels from chemical industry in boilers	All sizes	EN 1948-1, EN 1948-2, EN 1948-3	Once every six months ₍₁₃₎₍₂₅₎	BAT 59 BAT 71		
		— Waste co-incineration						

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																																								
5	<p>BAT is to monitor emissions to water from flue-gas treatment with at least the frequency given below and in accordance with EN standards. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.</p> <table border="1" data-bbox="331 475 1489 1225"> <thead> <tr> <th data-bbox="331 475 667 560">Substance/Parameter</th> <th data-bbox="667 475 1025 560">Standard(s)</th> <th data-bbox="1025 475 1265 560">Minimum monitoring frequency</th> <th data-bbox="1265 475 1489 560">Monitoring associated with</th> </tr> </thead> <tbody> <tr> <td data-bbox="331 560 667 592">Total organic carbon (TOC)₍₂₆₎</td> <td data-bbox="667 560 1025 592">EN 1484</td> <td data-bbox="1025 560 1265 1225" rowspan="10">Once every month</td> <td data-bbox="1265 560 1489 1225" rowspan="10">BAT 15</td> </tr> <tr> <td data-bbox="331 592 667 651">Chemical oxygen demand (COD)₍₂₆₎</td> <td data-bbox="667 592 1025 651">No EN standard available</td> </tr> <tr> <td data-bbox="331 651 667 683">Total suspended solids (TSS)</td> <td data-bbox="667 651 1025 683">EN 872</td> </tr> <tr> <td data-bbox="331 683 667 715">Fluoride (F⁻)</td> <td data-bbox="667 683 1025 715">EN ISO 10304-1</td> </tr> <tr> <td data-bbox="331 715 667 746">Sulphate (SO₄²⁻)</td> <td data-bbox="667 715 1025 746">EN ISO 10304-1</td> </tr> <tr> <td data-bbox="331 746 667 778">Sulphide, easily released (S²⁻)</td> <td data-bbox="667 746 1025 778">No EN standard available</td> </tr> <tr> <td data-bbox="331 778 667 810">Sulphite (SO₃²⁻)</td> <td data-bbox="667 778 1025 810">EN ISO 10304-3</td> </tr> <tr> <td data-bbox="331 810 667 1129" rowspan="7">Metals and metalloids</td> <td data-bbox="667 810 1025 842">As</td> <td data-bbox="1025 810 1265 1225" rowspan="10">Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)</td> <td data-bbox="1265 810 1489 1225" rowspan="10"></td> </tr> <tr> <td data-bbox="667 842 1025 874">Cd</td> </tr> <tr> <td data-bbox="667 874 1025 906">Cr</td> </tr> <tr> <td data-bbox="667 906 1025 938">Cu</td> </tr> <tr> <td data-bbox="667 938 1025 970">Ni</td> </tr> <tr> <td data-bbox="667 970 1025 1002">Pb</td> </tr> <tr> <td data-bbox="667 1002 1025 1034">Zn</td> </tr> <tr> <td data-bbox="667 1034 1025 1129">Hg</td> <td data-bbox="1025 1034 1265 1129">Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)</td> </tr> <tr> <td data-bbox="331 1129 667 1189">Chloride (Cl⁻)</td> <td data-bbox="667 1129 1025 1189">Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)</td> <td data-bbox="1025 1129 1265 1189"></td> <td data-bbox="1265 1129 1489 1189">—</td> </tr> <tr> <td data-bbox="331 1189 667 1225">Total nitrogen</td> <td data-bbox="667 1189 1025 1225">EN 12260</td> <td data-bbox="1025 1189 1265 1225"></td> <td data-bbox="1265 1189 1489 1225">—</td> </tr> </tbody> </table>	Substance/Parameter	Standard(s)	Minimum monitoring frequency	Monitoring associated with	Total organic carbon (TOC) ₍₂₆₎	EN 1484	Once every month	BAT 15	Chemical oxygen demand (COD) ₍₂₆₎	No EN standard available	Total suspended solids (TSS)	EN 872	Fluoride (F ⁻)	EN ISO 10304-1	Sulphate (SO ₄ ²⁻)	EN ISO 10304-1	Sulphide, easily released (S ²⁻)	No EN standard available	Sulphite (SO ₃ ²⁻)	EN ISO 10304-3	Metals and metalloids	As	Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)		Cd	Cr	Cu	Ni	Pb	Zn	Hg	Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)	Chloride (Cl ⁻)	Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)		—	Total nitrogen	EN 12260		—	NA	Flue gas treatment is a dry process, therefore, no waste water is generated from the process. This BAT conclusion is thus not applicable.
Substance/Parameter	Standard(s)	Minimum monitoring frequency	Monitoring associated with																																								
Total organic carbon (TOC) ₍₂₆₎	EN 1484	Once every month	BAT 15																																								
Chemical oxygen demand (COD) ₍₂₆₎	No EN standard available																																										
Total suspended solids (TSS)	EN 872																																										
Fluoride (F ⁻)	EN ISO 10304-1																																										
Sulphate (SO ₄ ²⁻)	EN ISO 10304-1																																										
Sulphide, easily released (S ²⁻)	No EN standard available																																										
Sulphite (SO ₃ ²⁻)	EN ISO 10304-3																																										
Metals and metalloids	As			Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)																																							
	Cd																																										
	Cr																																										
	Cu																																										
	Ni																																										
	Pb																																										
	Zn																																										
Hg	Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)																																										
Chloride (Cl ⁻)	Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)		—																																								
Total nitrogen	EN 12260		—																																								
6	In order to improve the general environmental performance of combustion plants and to reduce emissions to air of CO and unburnt substances, BAT is to ensure optimised combustion and to use an appropriate combination of the techniques given below.	CC	The operator has confirmed the following:																																								

BAT Concn. Numbe r	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																							
	<table border="1"> <thead> <tr> <th data-bbox="331 392 367 418"></th> <th data-bbox="367 392 555 418">Technique</th> <th data-bbox="555 392 994 418">Description</th> <th data-bbox="994 392 1491 418">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="331 418 367 507">a.</td> <td data-bbox="367 418 555 507">Fuel blending and mixing</td> <td data-bbox="555 418 994 507">Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type</td> <td data-bbox="994 418 1491 507" rowspan="2">Generally applicable</td> </tr> <tr> <td data-bbox="331 507 367 596">b.</td> <td data-bbox="367 507 555 596">Maintenance of the combustion system</td> <td data-bbox="555 507 994 596">Regular planned maintenance according to suppliers' recommendations</td> </tr> <tr> <td data-bbox="331 596 367 676">c.</td> <td data-bbox="367 596 555 676">Advanced control system</td> <td data-bbox="555 596 994 676">See description in Section 8.1</td> <td data-bbox="994 596 1491 676">The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> <tr> <td data-bbox="331 676 367 756">d.</td> <td data-bbox="367 676 555 756">Good design of the combustion equipment</td> <td data-bbox="555 676 994 756">Good design of furnace, combustion chambers, burners and associated devices</td> <td data-bbox="994 676 1491 756">Generally applicable to new combustion plants</td> </tr> <tr> <td data-bbox="331 756 367 995">e.</td> <td data-bbox="367 756 555 995">Fuel choice</td> <td data-bbox="555 756 994 995">Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used</td> <td data-bbox="994 756 1491 995">Applicable within the constraints associated with the availability of suitable types of fuel with a better environmental profile as a whole, which may be impacted by the energy policy of the Member State, or by the integrated site's fuel balance in the case of combustion of industrial process fuels. For existing combustion plants, the type of fuel chosen may be limited by the configuration and the design of the plant</td> </tr> </tbody> </table>				Technique	Description	Applicability	a.	Fuel blending and mixing	Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type	Generally applicable	b.	Maintenance of the combustion system	Regular planned maintenance according to suppliers' recommendations	c.	Advanced control system	See description in Section 8.1	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system	d.	Good design of the combustion equipment	Good design of furnace, combustion chambers, burners and associated devices	Generally applicable to new combustion plants	e.	Fuel choice	Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used	Applicable within the constraints associated with the availability of suitable types of fuel with a better environmental profile as a whole, which may be impacted by the energy policy of the Member State, or by the integrated site's fuel balance in the case of combustion of industrial process fuels. For existing combustion plants, the type of fuel chosen may be limited by the configuration and the design of the plant		<p>That they are compliant with the requirements through a combination of techniques as set out below:</p> <p>a) Fuel blending and mixing – Wood chips are blended prior to being received at the boiler.</p> <p>b) Maintenance of the combustion system – Regular planned maintenance is undertaken in accordance with the manufacturer's recommendations.</p> <p>c) Advanced control system – An advanced control system is installed, which controls the process to ensure operations: maximise fuel burnout, minimise emissions, achieve a constant level of steam production and maintain operation within the specified range.</p> <p>d) Good design of the combustion equipment – The furnace is new and is currently undergoing commissioning. -The combustion unit employs staged combustion optimized for drying, combustion and burn-out. Primary air is supplied through the grate, secondary and over fire air</p>
	Technique	Description	Applicability																									
a.	Fuel blending and mixing	Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type	Generally applicable																									
b.	Maintenance of the combustion system	Regular planned maintenance according to suppliers' recommendations																										
c.	Advanced control system	See description in Section 8.1	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system																									
d.	Good design of the combustion equipment	Good design of furnace, combustion chambers, burners and associated devices	Generally applicable to new combustion plants																									
e.	Fuel choice	Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used	Applicable within the constraints associated with the availability of suitable types of fuel with a better environmental profile as a whole, which may be impacted by the energy policy of the Member State, or by the integrated site's fuel balance in the case of combustion of industrial process fuels. For existing combustion plants, the type of fuel chosen may be limited by the configuration and the design of the plant																									

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
			<p>is injected through nozzles above the grate.</p> <ul style="list-style-type: none"> - The burner is a single, light fuel oil start up burner and is only used for start-up. - The system incorporates additional devices which reduce emissions such as SNCR, a bag filter and over fire air. <p>e) Fuel Choice – The fuel has a low sulphur content (average 0.01 – 0.03%) and low chlorine content (0.01 – 0.05%)</p>
7	<p>In order to reduce emissions of ammonia to air from the use of selective catalytic reduction (SCR) and/or selective non-catalytic reduction (SNCR) for the abatement of NO_x emissions, BAT is to optimise the design and/or operation of SCR and/or SNCR (e.g. optimised reagent to NO_x ratio, homogeneous reagent distribution and optimum size of the reagent drops).</p> <p>BAT-associated emission levels</p> <p>The BAT-associated emission level (BAT-AEL) for emissions of NH₃ to air from the use of SCR and/or SNCR is < 3–10 mg/Nm³ as a yearly average or average over the sampling period. The lower end of the range can be achieved when using SCR and the upper end of the range can be achieved when using SNCR without wet abatement techniques. In the case of plants combusting biomass and operating at variable loads as well as in the case of engines combusting HFO and/or gas oil, the higher end of the BAT-AEL range is 15 mg/Nm³.</p>	CC	<p>The operator has confirmed the following:</p> <p>SNCR has been installed at the installation. It will only be used if further NO_x abatement is required. A NO_x trigger point is set using the advanced control system for when SNCR would become active. Based on testing undertaken during commissioning it is expected that only intermittent operation would be necessary.</p> <p>We agree that the operator is in compliance with the requirements of this BAT conclusion.</p>
8	<p>In order to prevent or reduce emissions to air during normal operating conditions, BAT is to ensure, by appropriate design, operation and maintenance, that the emission abatement systems are used at optimal capacity and availability.</p>	CC	<p>The operator has confirmed that the following abatement systems are in place:</p>

BAT Concn. Numbe r	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
			<ul style="list-style-type: none"> - Primary NO_x abatement through controlling combustion process to minimise NO_x formation. - Secondary NO_x abatement through used of SNCR as required. System is maintained in line with planned maintenance routines. - Bag filter to control particulate emissions. A dust detector is fitted to indicate when there is bag failure. An inline cleaning system is in place to periodically remove the dust cake. - CO emissions are not anticipated to be significant as the furnace has been designed to optimise combustion. - SO₂ emissions although unlikely to be significant are controlled through the use of hydrated lime. - CEMs allows for real time monitoring and problems to be identified and repaired. <p>We agree with the Operator's stated compliance.</p>
9	<p>In order to improve the general environmental performance of combustion and/or gasification plants and to reduce emissions to air, BAT is to include the following elements in the quality assurance/quality control programmes for all the fuels used, as part of the environmental management system (see BAT 1):</p> <p>(i) Initial full characterisation of the fuel used including at least the parameters listed below and in accordance with EN standards. ISO, national or other international standards may be used provided they ensure the provision of data of an equivalent scientific quality;</p>	FC	<p>The operator has confirmed the following:</p> <p>(i) Full characterisation of the fuel used including at least the parameters listed in BAT 9 and in</p>

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																				
	<p>(ii) Regular testing of the fuel quality to check that it is consistent with the initial characterisation and according to the plant design specifications. The frequency of testing and the parameters chosen from the table below are based on the variability of the fuel and an assessment of the relevance of pollutant releases (e.g. concentration in fuel, flue-gas treatment employed);</p> <p>(iii) Subsequent adjustment of the plant settings as and when needed and practicable (e.g. integration of the fuel characterisation and control in the advanced control system (see description in Section 8.1)).</p> <p>Description Initial characterisation and regular testing of the fuel can be performed by the operator and/or the fuel supplier. If performed by the supplier, the full results are provided to the operator in the form of a product (fuel) supplier specification and/or guarantee.</p> <table border="1" data-bbox="324 667 1496 1332"> <thead> <tr> <th data-bbox="324 667 712 703">Fuel(s)</th> <th data-bbox="723 667 1496 703">Substances/Parameters subject to characterisation</th> </tr> </thead> <tbody> <tr> <td data-bbox="324 703 712 906" rowspan="4">Biomass/peat</td> <td data-bbox="723 703 1496 740">— LHV</td> </tr> <tr> <td data-bbox="723 740 1496 777">— moisture</td> </tr> <tr> <td data-bbox="723 777 1496 813">— Ash</td> </tr> <tr> <td data-bbox="723 813 1496 906">— C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn)</td> </tr> <tr> <td data-bbox="324 906 712 1118" rowspan="4">Coal/lignite</td> <td data-bbox="723 906 1496 943">— LHV</td> </tr> <tr> <td data-bbox="723 943 1496 979">— Moisture</td> </tr> <tr> <td data-bbox="723 979 1496 1016">— Volatiles, ash, fixed carbon, C, H, N, O, S</td> </tr> <tr> <td data-bbox="723 1016 1496 1118">— Br, Cl, F — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)</td> </tr> <tr> <td data-bbox="324 1118 712 1203" rowspan="2">HFO</td> <td data-bbox="723 1118 1496 1155">— Ash</td> </tr> <tr> <td data-bbox="723 1155 1496 1203">— C, S, N, Ni, V</td> </tr> <tr> <td data-bbox="324 1203 712 1287" rowspan="2">Gas oil</td> <td data-bbox="723 1203 1496 1240">— Ash</td> </tr> <tr> <td data-bbox="723 1240 1496 1287">— N, C, S</td> </tr> <tr> <td data-bbox="324 1287 712 1332">Natural gas</td> <td data-bbox="723 1287 1496 1332">— LHV</td> </tr> </tbody> </table>	Fuel(s)	Substances/Parameters subject to characterisation	Biomass/peat	— LHV	— moisture	— Ash	— C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn)	Coal/lignite	— LHV	— Moisture	— Volatiles, ash, fixed carbon, C, H, N, O, S	— Br, Cl, F — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)	HFO	— Ash	— C, S, N, Ni, V	Gas oil	— Ash	— N, C, S	Natural gas	— LHV		<p>accordance with EN standards – Initial fuel characterisation has been undertaken in accordance with the required standards. Full characterisation will be provided before 31st July 2021, improvement condition 3 has been included specifying this requirement.</p> <p>(ii) Regular testing of the fuel quality to check that it is consistent with initial characterisation and according to the plant specification. – Full details will be provided in accordance with the requirements of improvement condition 3.</p> <p>(iii) Subsequent adjustment of plant settings as and when needed and practicable - Full details will be provided in accordance with the requirements of improvement condition 3.</p>
Fuel(s)	Substances/Parameters subject to characterisation																						
Biomass/peat	— LHV																						
	— moisture																						
	— Ash																						
	— C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn)																						
Coal/lignite	— LHV																						
	— Moisture																						
	— Volatiles, ash, fixed carbon, C, H, N, O, S																						
	— Br, Cl, F — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)																						
HFO	— Ash																						
	— C, S, N, Ni, V																						
Gas oil	— Ash																						
	— N, C, S																						
Natural gas	— LHV																						

BAT Concn. Numbe r	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement								
	<table border="1"> <tr> <td data-bbox="322 384 712 432"></td> <td data-bbox="712 384 1491 432">— CH₄, C₂H₆, C₃, C₄₊, CO₂, N₂, Wobbe index</td> </tr> <tr> <td data-bbox="322 432 712 512">Process fuels from the chemical industry⁽²⁷⁾</td> <td data-bbox="712 432 1491 512">— Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)</td> </tr> <tr> <td data-bbox="322 512 712 584">Iron and steel process gases</td> <td data-bbox="712 512 1491 584">— LHV, CH₄ (for COG), C_xH_y (for COG), CO₂, H₂, N₂, total sulphur, dust, Wobbe index</td> </tr> <tr> <td data-bbox="322 584 712 743">Waste⁽²⁸⁾</td> <td data-bbox="712 584 1491 743">— LHV — Moisture — Volatiles, ash, Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)</td> </tr> </table>		— CH ₄ , C ₂ H ₆ , C ₃ , C ₄₊ , CO ₂ , N ₂ , Wobbe index	Process fuels from the chemical industry ⁽²⁷⁾	— Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)	Iron and steel process gases	— LHV, CH ₄ (for COG), C _x H _y (for COG), CO ₂ , H ₂ , N ₂ , total sulphur, dust, Wobbe index	Waste ⁽²⁸⁾	— LHV — Moisture — Volatiles, ash, Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)		
	— CH ₄ , C ₂ H ₆ , C ₃ , C ₄₊ , CO ₂ , N ₂ , Wobbe index										
Process fuels from the chemical industry ⁽²⁷⁾	— Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)										
Iron and steel process gases	— LHV, CH ₄ (for COG), C _x H _y (for COG), CO ₂ , H ₂ , N ₂ , total sulphur, dust, Wobbe index										
Waste ⁽²⁸⁾	— LHV — Moisture — Volatiles, ash, Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)										
10	<p>In order to reduce emissions to air and/or to water during other than normal operating conditions (OTNOC), BAT is to set up and implement a management plan as part of the environmental management system (see BAT 1), commensurate with the relevance of potential pollutant releases, that includes the following elements:</p> <ul style="list-style-type: none"> — appropriate design of the systems considered relevant in causing OTNOC that may have an impact on emissions to air, water and/or soil (e.g. low-load design concepts for reducing the minimum start-up and shutdown loads for stable generation in gas turbines), — set-up and implementation of a specific preventive maintenance plan for these relevant systems, — review and recording of emissions caused by OTNOC and associated circumstances and implementation of corrective actions if necessary, — periodic assessment of the overall emissions during OTNOC (e.g. frequency of events, duration, emissions quantification/estimation) and implementation of corrective actions if necessary. 	CC	<p>The operator has confirmed that:</p> <p>Operating instructions are in place for plant start-up and shut-down which ensure plant is started up and shut down efficiently.</p> <p>Preventative maintenance procedures for part of the EMS including:</p> <ul style="list-style-type: none"> - Plant modification procedure - Management of major outages - Adding and deleting outage work scope - Load injection leak sealing - Management of pressure system <p>CEMS remains on line during start up and shut down which allows for reviewing of emissions in real time. Any significant events would</p>								

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement											
			<p>be noted and reported to the Environment Agency.</p> <p>Periodic assessment of overall emissions takes place as part of annual environmental reviews and improvements that can be made will be assessed for feasibility.</p> <p>We agree with the Operator's stated compliance.</p>											
11	<p>BAT is to appropriately monitor emissions to air and/or to water during OTNOC.</p> <p>Description</p> <p>The monitoring can be carried out by direct measurement of emissions or by monitoring of surrogate parameters if this proves to be of equal or better scientific quality than the direct measurement of emissions. Emissions during start-up and shutdown (SU/SD) may be assessed based on a detailed emission measurement carried out for a typical SU/SD procedure at least once every year, and using the results of this measurement to estimate the emissions for each and every SU/SD throughout the year.</p>	CC	<p>The operator has confirmed the following:</p> <p>CEMS remains on line during start up and shut down which allows for reviewing of emissions in real time. Any significant events would be noted and reported to the Environment Agency.</p> <p>We agree with the Operator's stated compliance.</p>											
12	<p>In order to increase the energy efficiency of combustion, gasification and/or IGCC units operated $\geq 1\,500$ h/yr, BAT is to use an appropriate combination of the techniques given below.</p> <table border="1" data-bbox="322 1114 1491 1342"> <thead> <tr> <th data-bbox="322 1114 367 1145"></th> <th data-bbox="367 1114 577 1145">Technique</th> <th data-bbox="577 1114 1057 1145">Description</th> <th data-bbox="1057 1114 1491 1145">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 1145 367 1257">a.</td> <td data-bbox="367 1145 577 1257">Combustion optimisation</td> <td data-bbox="577 1145 1057 1257">See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues</td> <td data-bbox="1057 1145 1491 1342" rowspan="2">Generally applicable</td> </tr> <tr> <td data-bbox="322 1257 367 1342">b.</td> <td data-bbox="367 1257 577 1342">Optimisation of the working medium conditions</td> <td data-bbox="577 1257 1057 1342">Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for</td> </tr> </tbody> </table>		Technique	Description	Applicability	a.	Combustion optimisation	See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues	Generally applicable	b.	Optimisation of the working medium conditions	Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for		<p>The operator has confirmed the following:</p> <p>That they are compliant with the requirements through a combination of techniques as set out below:</p> <p>a) Combustion optimisation – This is achieved through the use of an advanced control system that</p>
	Technique	Description	Applicability											
a.	Combustion optimisation	See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues	Generally applicable											
b.	Optimisation of the working medium conditions	Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for												

BAT Concn. Numbe r	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
			example, the control of NO _x emissions or the characteristics of energy demanded		<p>maximises efficiency and reduces emissions by a number of techniques, as described under BAT 6 d).</p> <p>b) Optimisation of the working medium conditions – super heaters are used at the installation. Temperature and pressure are increased resulting in more thermal energy in the steam which is converted by the steam turbine into electrical energy.</p> <p>c) Optimisation of the steam cycle – The installation uses an air cooled system. The lowest possible temperature that can be used is ambient, hence it is considered that this is being complied with.</p> <p>d) Minimisation of energy consumption – The start-up burner is retracted from the furnace during normal operations. Insulation is used to minimise heat loss. Energy efficient lighting is used where feasible. A high efficiency turbine used.</p> <p>e) Preheating of Combustion Air – Hot feed water is used to pre-heat incoming combustion air by</p>
c.	Optimisation of the steam cycle	Operate with lower turbine exhaust pressure by utilisation of the lowest possible temperature of the condenser cooling water, within the design conditions			
d.	Minimisation of energy consumption	Minimising the internal energy consumption (e.g. greater efficiency of the feed-water pump)			
e.	Preheating of combustion air	Reuse of part of the heat recovered from the combustion flue-gas to preheat the air used in combustion	Generally applicable within the constraints related to the need to control NO _x emissions		
f.	Fuel preheating	Preheating of fuel using recovered heat	Generally applicable within the constraints associated with the boiler design and the need to control NO _x emissions		
g.	Advanced control system	See description in Section 8.2. Computerised control of the main combustion parameters enables the combustion efficiency to be improved	Generally applicable to new units. The applicability to old units may be constrained by the need to retrofit the combustion system and/or control command system		
h.	Feed-water preheating using recovered heat	Preheat water coming out of the steam condenser with recovered heat, before reusing it in the boiler	Only applicable to steam circuits and not to hot boilers. Applicability to existing units may be limited due to constraints associated with the plant configuration and the amount of recoverable heat		
i.	Heat recovery by cogeneration (CHP)	Recovery of heat (mainly from the steam system) for producing hot water/steam to be used in industrial processes/activities or in a public network for district heating. Additional heat recovery is possible from: <ul style="list-style-type: none"> — flue-gas — grate cooling — circulating fluidised bed 	Applicable within the constraints associated with the local heat and power demand. The applicability may be limited in the case of gas compressors with an unpredictable operational heat profile		

BAT Concn. Number	Summary of BAT Conclusion requirement				Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	j.	CHP readiness	See description in Section 8.2.	Only applicable to new units where there is a realistic potential for the future use of heat in the vicinity of the unit		<p>flowing through a High Pressure Air Pre Heater (HPAPH). After the feed water has passed through the HPAPH and has been cooled it is heated up again using hot flue gases.</p> <p>g) Advanced control system - An advanced control system is used on the site to control the main combustion parameters.</p> <p>h) Feed-water preheating using recovered heat - The feed water is heated in the economiser using the hot flue gases.</p> <p>i) Heat recovery by cogeneration (CHP) – steam is exported off site to two customers. There is the capacity to export more heat if required.</p> <p>j) CHP readiness – a CHP system is already in place at the installation.</p> <p>k) Flue gas condenser – one is installed on the CHP system.</p> <p>p) Minimisation of heat loss – the CHP plant in insulated where appropriate, including pipework to minimise heat loss.</p>
k.	Flue-gas condenser	See description in Section 8.2.	Generally applicable to CHP units provided there is enough demand for low-temperature heat			
l.	Heat accumulation	Heat accumulation storage in CHP mode	Only applicable to CHP plants. The applicability may be limited in the case of low heat load demand			
m.	Wet stack	See description in Section 8.2.	Generally applicable to new and existing units fitted with wet FGD			
n.	Cooling tower discharge	The release of emissions to air through a cooling tower and not via a dedicated stack	Only applicable to units fitted with wet FGD where reheating of the flue-gas is necessary before release, and where the unit cooling system is a cooling tower			
o.	Fuel pre-drying	The reduction of fuel moisture content before combustion to improve combustion conditions	Applicable to the combustion of biomass and/or peat within the constraints associated with spontaneous combustion risks (e.g. the moisture content of peat is kept above 40 % throughout the delivery chain). The retrofit of existing plants may be restricted by the extra calorific value that can be obtained from the drying operation and by the limited retrofit possibilities offered by some boiler designs or plant configurations			
p.	Minimisation of heat losses	Minimising residual heat losses, e.g. those that occur via the slag or those that can be reduced by insulating radiating sources	Only applicable to solid-fuel-fired combustion units and to gasification/IGCC units			
q.	Advanced materials	Use of advanced materials proven to be capable of withstanding high operating temperatures and pressures and thus to achieve increased steam/combustion process efficiencies	Only applicable to new plants			
r.	Steam turbine upgrades	This includes techniques such as increasing the temperature and pressure of medium-pressure steam, addition of a low-pressure turbine, and	The applicability may be restricted by demand, steam conditions and/or limited plant lifetime			

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	
	s.	Supercritical and ultra-supercritical steam conditions	<p>modifications to the geometry of the turbine rotor blades</p> <p>Use of a steam circuit, including steam reheating systems, in which steam can reach pressures above 220,6 bar and temperatures above 374 °C in the case of supercritical conditions, and above 250 – 300 bar and temperatures above 580 – 600 °C in the case of ultra-supercritical conditions</p>	<p>Only applicable to new units of $\geq 600 \text{ MW}_{\text{th}}$ operated $> 4\,000 \text{ h/yr}$. Not applicable when the purpose of the unit is to produce low steam temperatures and/or pressures in process industries. Not applicable to gas turbines and engines generating steam in CHP mode. For units combusting biomass, the applicability may be constrained by high-temperature corrosion in the case of certain biomasses</p>		<p>q) Advanced material – the installation is still undergoing commissioning. As a new plant it is built using materials capable of withstanding high operating temperatures and pressures, allowing for increased process efficiencies.</p> <p>r) Steam turbine upgrades – the installation is still undergoing commissioning as such steam turbine upgrades are not necessary at this stage. The plant incorporates ‘reheat’ within the steam cycle. This increases efficiency from approximately 30% to 35%.</p> <p>We agree with the Operator’s stated compliance.</p>
13	In order to reduce water usage and the volume of contaminated waste water discharged, BAT is to use one or both of the techniques given below.			CC	<p>The operator has confirmed the following:</p> <p>a. Water recycling – after passing through the steam turbine the steam is condensed via the air cooled condenser and recovered water is feed back into the CHP process, reducing demineralised water usage.</p>	
		Technique	Description			
a.	Water recycling	Residual aqueous streams, including run-off water, from the plant are reused for other purposes. The degree of recycling is limited by the quality requirements of the recipient water stream and the water balance of the plant	Not applicable to waste water from cooling systems when water treatment chemicals and/or high concentrations of salts from seawater are present			
b.	Dry bottom ash handling	Dry, hot bottom ash falls from the furnace onto a mechanical conveyor system and is cooled down by ambient air. No water is used in the process.	Only applicable to plants combusting solid fuels.			

BAT Concn. Numbe r	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement						
	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 10%;"></td> <td style="width: 10%;"></td> <td style="width: 10%;"></td> <td style="width: 70%;">There may be technical restrictions that prevent retrofitting to existing combustion plants</td> </tr> </table>						There may be technical restrictions that prevent retrofitting to existing combustion plants		<p>Rainwater is collected and used to clean the air cooled condensers.</p> <p>Boiler blowdown water and effluent from the demineralisation plant are used for ash quenching and in water cannons used for boiler cleaning.</p> <p>b. dry bottom ash – a wet bottom ash system is used. This is not applicable to this plant.</p> <p>We agree with the operators stated compliance.</p>		
			There may be technical restrictions that prevent retrofitting to existing combustion plants								
14	<p>In order to prevent the contamination of uncontaminated waste water and to reduce emissions to water, BAT is to segregate waste water streams and to treat them separately, depending on the pollutant content.</p> <p>Description Waste water streams that are typically segregated and treated include surface run-off water, cooling water, and waste water from flue-gas treatment.</p> <p>Applicability The applicability may be restricted in the case of existing plants due to the configuration of the drainage systems.</p>			CC	<p>Surface water from roadways and roofs is discharge to the surface water sewer.</p> <p>Process water that cannot be reused within the CHP plant are sent to the waste water treatment plant on site prior discharge to the foul sewer.</p> <p>We agree with the operators stated compliance.</p>						
15	<p>In order to reduce emissions to water from flue-gas treatment, BAT is to use an appropriate combination of the techniques given below, and to use secondary techniques as close as possible to the source in order to avoid dilution.</p> <table border="1" style="width: 100%; border-collapse: collapse; margin-top: 10px;"> <thead> <tr> <th style="width: 30%;">Technique</th> <th style="width: 30%;">Typical pollutants prevented/abated</th> <th style="width: 40%;">Applicability</th> </tr> </thead> <tbody> <tr> <td colspan="3" style="text-align: center;">Primary techniques</td> </tr> </tbody> </table>			Technique	Typical pollutants prevented/abated	Applicability	Primary techniques			NA	<p>The flue gas treatment at the installation uses dry abatement. Therefore, BAT 15 is not applicable.</p>
Technique	Typical pollutants prevented/abated	Applicability									
Primary techniques											

BAT Concn. Numbe r	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	a.	Optimised combustion (see BAT 6) and flue-gas treatment systems (e.g. SCR/SNCR, see BAT 7)	Organic compounds, ammonia (NH ₃)	Generally applicable	
Secondary techniques ⁽²⁹⁾					
	b.	Adsorption on activated carbon	Organic compounds, mercury (Hg)	Generally applicable	
	c.	Aerobic biological treatment	Biodegradable organic compounds, ammonium (NH ₄ ⁺)	Generally applicable for the treatment of organic compounds. Aerobic biological treatment of ammonium (NH ₄ ⁺) may not be applicable in the case of high chloride concentrations (i.e. around 10 g/l)	
	d.	Anoxic/anaerobic biological treatment	Mercury (Hg), nitrate (NO ₃ ⁻), nitrite (NO ₂ ⁻)	Generally applicable	
	e.	Coagulation and flocculation	Suspended solids	Generally applicable	
	f.	Crystallisation	Metals and metalloids, sulphate (SO ₄ ²⁻), fluoride (F ⁻)	Generally applicable	
	g.	Filtration (e.g. sand filtration, microfiltration, ultrafiltration)	Suspended solids, metals	Generally applicable	
	h.	Flotation	Suspended solids, free oil	Generally applicable	
	i.	Ion exchange	Metals	Generally applicable	
	j.	Neutralisation	Acids, alkalis	Generally applicable	
	k.	Oxidation	Sulphide (S ²⁻), sulphite (SO ₃ ²⁻)	Generally applicable	
	l.	Precipitation	Metals and metalloids, sulphate (SO ₄ ²⁻), fluoride (F ⁻)	Generally applicable	
	m.	Sedimentation	Suspended solids	Generally applicable	
	n.	Stripping	Ammonia (NH ₃)	Generally applicable	
The BAT-AELs refer to direct discharges to a receiving water body at the point where the emission leaves the installation.					
BAT-AELs for direct discharges to a receiving water body from flue-gas treatment					
Substance/Parameter			BAT-AELs		
			Daily average		

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																																
	<table border="1"> <tr> <td>Total organic carbon (TOC)</td> <td>20–50 mg/l ⁽³⁰⁾ ⁽³¹⁾ ⁽³²⁾</td> </tr> <tr> <td>Chemical oxygen demand (COD)</td> <td>60–150 mg/l ⁽³⁰⁾ ⁽³¹⁾ ⁽³²⁾</td> </tr> <tr> <td>Total suspended solids (TSS)</td> <td>10–30 mg/l</td> </tr> <tr> <td>Fluoride (F⁻)</td> <td>10–25 mg/l ⁽³²⁾</td> </tr> <tr> <td>Sulphate (SO₄²⁻)</td> <td>1,3–2,0 g/l ⁽³²⁾ ⁽³³⁾ ⁽³⁴⁾ ⁽³⁵⁾</td> </tr> <tr> <td>Sulphide (S²⁻), easily released</td> <td>0,1–0,2 mg/l ⁽³²⁾</td> </tr> <tr> <td>Sulphite (SO₃²⁻)</td> <td>1–20 mg/l ⁽³²⁾</td> </tr> <tr> <td>Metals and metalloids</td> <td></td> </tr> <tr> <td>As</td> <td>10–50 µg/l</td> </tr> <tr> <td>Cd</td> <td>2–5 µg/l</td> </tr> <tr> <td>Cr</td> <td>10–50 µg/l</td> </tr> <tr> <td>Cu</td> <td>10–50 µg/l</td> </tr> <tr> <td>Hg</td> <td>0,2–3 µg/l</td> </tr> <tr> <td>Ni</td> <td>10–50 µg/l</td> </tr> <tr> <td>Pb</td> <td>10–20 µg/l</td> </tr> <tr> <td>Zn</td> <td>50–200 µg/l</td> </tr> </table>	Total organic carbon (TOC)	20–50 mg/l ⁽³⁰⁾ ⁽³¹⁾ ⁽³²⁾	Chemical oxygen demand (COD)	60–150 mg/l ⁽³⁰⁾ ⁽³¹⁾ ⁽³²⁾	Total suspended solids (TSS)	10–30 mg/l	Fluoride (F ⁻)	10–25 mg/l ⁽³²⁾	Sulphate (SO ₄ ²⁻)	1,3–2,0 g/l ⁽³²⁾ ⁽³³⁾ ⁽³⁴⁾ ⁽³⁵⁾	Sulphide (S ²⁻), easily released	0,1–0,2 mg/l ⁽³²⁾	Sulphite (SO ₃ ²⁻)	1–20 mg/l ⁽³²⁾	Metals and metalloids		As	10–50 µg/l	Cd	2–5 µg/l	Cr	10–50 µg/l	Cu	10–50 µg/l	Hg	0,2–3 µg/l	Ni	10–50 µg/l	Pb	10–20 µg/l	Zn	50–200 µg/l		
Total organic carbon (TOC)	20–50 mg/l ⁽³⁰⁾ ⁽³¹⁾ ⁽³²⁾																																		
Chemical oxygen demand (COD)	60–150 mg/l ⁽³⁰⁾ ⁽³¹⁾ ⁽³²⁾																																		
Total suspended solids (TSS)	10–30 mg/l																																		
Fluoride (F ⁻)	10–25 mg/l ⁽³²⁾																																		
Sulphate (SO ₄ ²⁻)	1,3–2,0 g/l ⁽³²⁾ ⁽³³⁾ ⁽³⁴⁾ ⁽³⁵⁾																																		
Sulphide (S ²⁻), easily released	0,1–0,2 mg/l ⁽³²⁾																																		
Sulphite (SO ₃ ²⁻)	1–20 mg/l ⁽³²⁾																																		
Metals and metalloids																																			
As	10–50 µg/l																																		
Cd	2–5 µg/l																																		
Cr	10–50 µg/l																																		
Cu	10–50 µg/l																																		
Hg	0,2–3 µg/l																																		
Ni	10–50 µg/l																																		
Pb	10–20 µg/l																																		
Zn	50–200 µg/l																																		
16	<p>In order to reduce the quantity of waste sent for disposal from the combustion and/or gasification process and abatement techniques, BAT is to organise operations so as to maximise, in order of priority and taking into account life-cycle thinking:</p> <p>(a) waste prevention, e.g. maximise the proportion of residues which arise as by-products;</p> <p>(b) waste preparation for reuse, e.g. according to the specific requested quality criteria;</p> <p>(c) waste recycling;</p> <p>(d) other waste recovery (e.g. energy recovery),</p> <p>by implementing an appropriate combination of techniques such as:</p> <table border="1"> <thead> <tr> <th>Technique</th> <th>Description</th> <th>Applicability</th> </tr> </thead> <tbody> <tr> <td>a. Generation of gypsum as a by-product</td> <td>Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g. as raw material in the plasterboard industry). The</td> <td>Generally applicable within the constraints associated with the required gypsum quality, the health requirements</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Generation of gypsum as a by-product	Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g. as raw material in the plasterboard industry). The	Generally applicable within the constraints associated with the required gypsum quality, the health requirements	FC	<p>The operator has confirmed that the following is in place:</p> <p>a) Generation of gypsum as a by-product - wet flue gas treatment is not utilised at this installation and so this is not applicable.</p> <p>b) Recycling or recovery of residues in the construction sector – the intention for bottom ash and fly ash is for it to be reused as a fertiliser. The suitability of this material will be confirmed after commissioning once the process</p>																										
Technique	Description	Applicability																																	
a. Generation of gypsum as a by-product	Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g. as raw material in the plasterboard industry). The	Generally applicable within the constraints associated with the required gypsum quality, the health requirements																																	

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement				
			quality of limestone used in the wet FGD influences the purity of the gypsum produced	associated to each specific use, and by the market conditions	<p>is fully established. The results of testing and opportunities for the use of this material will be presented to the EA prior to 31st July 2021.</p> <p>-Metals found within the incoming biomass are removed and sent for recycling.</p> <p>-Empty drums and containers are collected and sent off site for recycling.</p> <p>d) Preparation of spent catalyst for reuse – SNCR rather than SCR is used. Therefore, this technique is not applicable.</p> <p>We agree with the operators stated compliance.</p>				
b.	Recycling or recovery of residues in the construction sector	Recycling or recovery of residues (e.g. from semi-dry desulphurisation processes, fly ash, bottom ash) as a construction material (e.g. in road building, to replace sand in concrete production, or in the cement industry)	Generally applicable within the constraints associated with the required material quality (e.g. physical properties, content of harmful substances) associated to each specific use, and by the market conditions						
c.	Energy recovery by using waste in the fuel mix	The residual energy content of carbon-rich ash and sludges generated by the combustion of coal, lignite, heavy fuel oil, peat or biomass can be recovered for example by mixing with the fuel	Generally applicable where plants can accept waste in the fuel mix and are technically able to feed the fuels into the combustion chamber						
d.	Preparation of spent catalyst for reuse	Preparation of catalyst for reuse (e.g. up to four times for SCR catalysts) restores some or all of the original performance, extending the service life of the catalyst to several decades. Preparation of spent catalyst for reuse is integrated in a catalyst management scheme	The applicability may be limited by the mechanical condition of the catalyst and the required performance with respect to controlling NO _x and NH ₃ emissions						
Descradopted17	In order to reduce noise emissions, BAT is to use one or a combination of the techniques given below.			CC	<p>The operator has confirmed the following:</p> <p>a) Operational measures – Regular inspections and maintenance is undertaken, noisy activities are not undertaken at night, staff are appropriately trained and skilled in relation to noise minimisation.</p>				
	<table border="1"> <thead> <tr> <th data-bbox="371 1042 573 1074">Technique</th> <th data-bbox="584 1042 1077 1074">Description</th> <th data-bbox="1088 1042 1503 1074">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="371 1082 573 1335">a. Operational measures</td> <td data-bbox="584 1082 1077 1335"> These include: <ul style="list-style-type: none"> — improved inspection and maintenance of equipment — closing of doors and windows of enclosed areas, if possible — equipment operated by experienced staff — avoidance of noisy activities at night, if possible </td> <td data-bbox="1088 1082 1503 1335">Generally applicable</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Operational measures	These include: <ul style="list-style-type: none"> — improved inspection and maintenance of equipment — closing of doors and windows of enclosed areas, if possible — equipment operated by experienced staff — avoidance of noisy activities at night, if possible 	Generally applicable		
Technique	Description	Applicability							
a. Operational measures	These include: <ul style="list-style-type: none"> — improved inspection and maintenance of equipment — closing of doors and windows of enclosed areas, if possible — equipment operated by experienced staff — avoidance of noisy activities at night, if possible 	Generally applicable							

BAT Concn. Number	Summary of BAT Conclusion requirement				Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
		— provisions for noise control during maintenance activities			b) Low noise equipment – low noise equipment has been installed wherever practicable. c) Noise attenuation – noisy equipment is housed within buildings e.g. log chopper, resizing chippers and steam turbine generator). The emergency generator is situated within an enclosed space to minimise noise. d) Noise control-equipment – The following equipment is installed: - the ID fan is equipped with a silencer and noise insulation. - Air compressors are equipped with inlet air silences. - The emergency generator is equipped with an exhaust silencer. - hogging ejectors are equipped with silencers. We agree with the operators stated compliance.	
	b. Low-noise equipment	This potentially includes compressors, pumps and disks	Generally applicable when the equipment is new or replaced			
	c. Noise attenuation	Noise propagation can be reduced by inserting obstacles between the emitter and the receiver. Appropriate obstacles include protection walls, embankments and buildings	Generally applicable to new plants. In the case of existing plants, the insertion of obstacles may be restricted by lack of space			
	d. Noise-control equipment	This includes: — noise-reducers — equipment insulation — enclosure of noisy equipment — soundproofing of buildings	The applicability may be restricted by lack of space			
	e. Appropriate location of equipment and buildings	Noise levels can be reduced by increasing the distance between the emitter and the receiver and by using buildings as noise screens	Generally applicable to new plant			
Combustion of solid fuels only						
Combustion of solid fuels only BAT Conclusions 18 to 23 applicable to coal and/or lignite Deleted from the table as they are not applicable to the activities carried out at the installation. 100% biomass-firing.						

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																		
2.2.1 Table 8	<p>BAT-associated energy efficiency levels (BAT-AEELs) for the combustion of solid biomass and/or peat</p> <table border="1"> <thead> <tr> <th data-bbox="324 411 600 555" rowspan="3">Type of combustion unit</th> <th colspan="4" data-bbox="607 411 1496 448">BAT-AEELs ⁽⁷³⁾ ⁽⁷⁴⁾</th> </tr> <tr> <th colspan="2" data-bbox="607 453 1093 512">Net electrical efficiency (%) ⁽⁷⁵⁾</th> <th colspan="2" data-bbox="1099 453 1496 512">Net total fuel utilisation (%) ⁽⁷⁶⁾ ⁽⁷⁷⁾</th> </tr> <tr> <th data-bbox="607 517 846 555">New unit ⁽⁷⁸⁾</th> <th data-bbox="853 517 1093 555">Existing unit</th> <th data-bbox="1099 517 1294 555">New unit</th> <th data-bbox="1301 517 1496 555">Existing unit</th> </tr> </thead> <tbody> <tr> <td data-bbox="324 560 600 619">Solid biomass and/or peat boiler</td> <td data-bbox="607 560 846 619">33,5–to > 38</td> <td data-bbox="853 560 1093 619">28–38</td> <td data-bbox="1099 560 1294 619">73–99</td> <td data-bbox="1301 560 1496 619">73–99</td> </tr> </tbody> </table>	Type of combustion unit	BAT-AEELs ⁽⁷³⁾ ⁽⁷⁴⁾				Net electrical efficiency (%) ⁽⁷⁵⁾		Net total fuel utilisation (%) ⁽⁷⁶⁾ ⁽⁷⁷⁾		New unit ⁽⁷⁸⁾	Existing unit	New unit	Existing unit	Solid biomass and/or peat boiler	33,5–to > 38	28–38	73–99	73–99	CC	<p>The operator confirmed the following:</p> <p>The net electrical efficiency during performance tests indicates that in heat export mode the CHP plant had an electrical efficiency of 34.04%. In condensing mode It was 36.42%. Overall performance test value of 34.04%.</p> <p>This is within the BAT-AEEL range of 28 – 38%.</p> <p>We agree with the operators stated compliance.</p>
Type of combustion unit	BAT-AEELs ⁽⁷³⁾ ⁽⁷⁴⁾																				
	Net electrical efficiency (%) ⁽⁷⁵⁾		Net total fuel utilisation (%) ⁽⁷⁶⁾ ⁽⁷⁷⁾																		
	New unit ⁽⁷⁸⁾	Existing unit	New unit	Existing unit																	
Solid biomass and/or peat boiler	33,5–to > 38	28–38	73–99	73–99																	
24	<p>In order to prevent or reduce NO_x emissions to air while limiting CO and N₂O emissions to air from the combustion of solid biomass and/or peat, BAT is to use one or a combination of the techniques given below.</p> <table border="1"> <thead> <tr> <th data-bbox="324 900 651 938">Technique</th> <th data-bbox="658 900 981 938">Description</th> <th data-bbox="987 900 1496 938">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="324 943 651 981">a. Combustion optimisation</td> <td data-bbox="658 943 981 981" rowspan="5">See descriptions in Section 8.3</td> <td data-bbox="987 943 1496 981" rowspan="5">Generally applicable</td> </tr> <tr> <td data-bbox="324 986 651 1024">b. Low-NO_x burners (LNB)</td> </tr> <tr> <td data-bbox="324 1029 651 1067">c. Air staging</td> </tr> <tr> <td data-bbox="324 1072 651 1110">d. Fuel staging</td> </tr> <tr> <td data-bbox="324 1115 651 1153">e. Flue-gas recirculation</td> </tr> <tr> <td data-bbox="324 1158 651 1331">f. Selective non-catalytic reduction (SNCR)</td> <td data-bbox="658 1158 981 1331">See description in Section 8.3. Can be applied with 'slip' SCR</td> <td data-bbox="987 1158 1496 1331">Not applicable to combustion plants operated < 500 h/yr with highly variable boiler loads. The applicability may be limited in the case of combustion plants operated between 500 h/yr and 1 500 h/yr with highly variable boiler loads. For existing combustion plants, applicable within the constraints associated with the</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Combustion optimisation	See descriptions in Section 8.3	Generally applicable	b. Low-NO _x burners (LNB)	c. Air staging	d. Fuel staging	e. Flue-gas recirculation	f. Selective non-catalytic reduction (SNCR)	See description in Section 8.3. Can be applied with 'slip' SCR	Not applicable to combustion plants operated < 500 h/yr with highly variable boiler loads. The applicability may be limited in the case of combustion plants operated between 500 h/yr and 1 500 h/yr with highly variable boiler loads. For existing combustion plants, applicable within the constraints associated with the	FC	<p>The operator confirmed the following:</p> <p>a) combustion optimisation – an advanced control system is used to control the plant maximising energy efficiency and reducing emissions. Further details are included under BAT6.</p> <p>c) Air Staging – This is used at the installation to distribute combustion air. There are five different zones to ensure proper combustion: primary air, spreader air, ignition air, secondary air and over fire air.</p>					
Technique	Description	Applicability																			
a. Combustion optimisation	See descriptions in Section 8.3	Generally applicable																			
b. Low-NO _x burners (LNB)																					
c. Air staging																					
d. Fuel staging																					
e. Flue-gas recirculation																					
f. Selective non-catalytic reduction (SNCR)	See description in Section 8.3. Can be applied with 'slip' SCR	Not applicable to combustion plants operated < 500 h/yr with highly variable boiler loads. The applicability may be limited in the case of combustion plants operated between 500 h/yr and 1 500 h/yr with highly variable boiler loads. For existing combustion plants, applicable within the constraints associated with the																			

BAT Concn. Number	Summary of BAT Conclusion requirement				Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement		
				required temperature window and residence time for the injected reactants		<p>f) SNCR – is used on the installation.</p> <p>The relevant BAT-AELs for NO_x and CO have been incorporated into the permit.</p> <p>Based upon performance tests, which have been provided with the reg61 notice, it is expected that the installation will be able to comply with the BAT-AELs.</p> <p>A full years operational data is not yet available and the combustion plant has not operated on the full range of fuels. A full data set will be provided to the Environment Agency to confirm BAT-AEL compliance before 31st July 2021.</p>		
	g.	Selective catalytic reduction (SCR)	See description in Section 8.3. The use of high-alkali fuels (e.g. straw) may require the SCR to be installed downstream of the dust abatement system	Not applicable to combustion plants operated < 500 h/yr. There may be economic restrictions for retrofitting existing combustion plants of < 300 MW _{th} . Not generally applicable to existing combustion plants of < 100 MW _{th}				
	BAT-associated emission levels (BAT-AELs) for NO_x emissions to air from the combustion of solid biomass and/or peat							
	Combustion plant total rated thermal input (MW_{th})		BAT-AELs (mg/Nm³)					
			Yearly average		Daily average or average over the sampling period			
	New plant	Existing plant ⁽⁷⁹⁾	New plant	Existing plant ⁽⁸⁰⁾				
	50–100	70–150 ⁽⁸¹⁾	70–225 ⁽⁸²⁾	120–200 ⁽⁸³⁾	120–275 ⁽⁸⁴⁾			
	100–300	50–140	50–180	100–200	100–220			
	≥ 300	40–140	40–150 ⁽⁸⁵⁾	65–150	95–165 ⁽⁸⁶⁾			
	<p>As an indication, the yearly average CO emission levels will generally be:</p> <ul style="list-style-type: none"> — < 30–250 mg/Nm³ for existing combustion plants of 50–100 MW_{th} operated ≥ 1 500 h/yr, or new combustion plants of 50–100 MW_{th}, — < 30–160 mg/Nm³ for existing combustion plants of 100–300 MW_{th} operated ≥ 1 500 h/yr, or new combustion plants of 100–300 MW_{th}, — < 30–80 mg/Nm³ for existing combustion plants of ≥ 300 MW_{th} operated ≥ 1 500 h/yr, or new combustion plants of ≥ 300 MW_{th}. 							
25	In order to prevent or reduce SO _x , HCl and HF emissions to air from the combustion of solid biomass and/or peat, BAT is to use one or a combination of the techniques given below.				FC	The operator has confirmed the following:		

BAT Concn. Numbe r	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																												
	<table border="1"> <thead> <tr> <th>Technique</th> <th>Description</th> <th>Applicability</th> </tr> </thead> <tbody> <tr> <td>a. Boiler sorbent injection (in-furnace or in-bed)</td> <td rowspan="7">See descriptions in Section 8.4</td> <td rowspan="6">Generally applicable</td> </tr> <tr> <td>b. Duct sorbent injection (DSI)</td> </tr> <tr> <td>c. Spray dry absorber (SDA)</td> </tr> <tr> <td>d. Circulating fluidised bed (CFB) dry scrubber</td> </tr> <tr> <td>e. Wet scrubbing</td> </tr> <tr> <td>f. Flue-gas condenser</td> </tr> <tr> <td>g. Wet flue-gas desulphurisation (wet FGD)</td> <td>Not applicable to combustion plants operated < 500 h/yr. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr</td> </tr> <tr> <td>h. Fuel choice</td> <td>Applicable within the constraints associated with the availability of different types of fuel, which may be impacted by the energy policy of the Member State</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Boiler sorbent injection (in-furnace or in-bed)	See descriptions in Section 8.4	Generally applicable	b. Duct sorbent injection (DSI)	c. Spray dry absorber (SDA)	d. Circulating fluidised bed (CFB) dry scrubber	e. Wet scrubbing	f. Flue-gas condenser	g. Wet flue-gas desulphurisation (wet FGD)	Not applicable to combustion plants operated < 500 h/yr. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr	h. Fuel choice	Applicable within the constraints associated with the availability of different types of fuel, which may be impacted by the energy policy of the Member State			<p>b) Duct Sorbent Injection (DSI) – hydrated lime is added to the flue gas upstream of the bag filter to reduce SO_x and HCl.</p> <p>f) Flue gas condenser (FGC) – FGC is installed in the CHP plant system. Hot feed water flows through the air pre-heater where it heats up the combustion air. The then cooled feed water passes through the FGS where it is heated up again by hot flue gases, It then passes to the economiser for further heating before entering the boiler.</p> <p>h) Fuel choice – The wood biomass has a low sulphur content (average 0.01 – 0.03%) and low chlorine content (0.01 – 0.05%).</p> <p>The relevant BAT-AELs for SO₂, HCl and HF have been incorporated into the permit.</p> <p>Based upon performance tests, which have been provided with the reg61 notice, it is expected that the installation will be able to comply with the BAT-AELs.</p>														
Technique	Description	Applicability																															
a. Boiler sorbent injection (in-furnace or in-bed)	See descriptions in Section 8.4	Generally applicable																															
b. Duct sorbent injection (DSI)																																	
c. Spray dry absorber (SDA)																																	
d. Circulating fluidised bed (CFB) dry scrubber																																	
e. Wet scrubbing																																	
f. Flue-gas condenser																																	
g. Wet flue-gas desulphurisation (wet FGD)		Not applicable to combustion plants operated < 500 h/yr. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr																															
h. Fuel choice	Applicable within the constraints associated with the availability of different types of fuel, which may be impacted by the energy policy of the Member State																																
BAT-associated emission levels (BAT-AELs) for SO₂ emissions to air from the combustion of solid biomass and/or peat																																	
<table border="1"> <thead> <tr> <th rowspan="3">Combustion plant total rated thermal input (MW_{th})</th> <th colspan="4">BAT-AELs for SO₂ (mg/Nm³)</th> </tr> <tr> <th colspan="2">Yearly average</th> <th colspan="2">Daily average or average over the sampling period</th> </tr> <tr> <th>New plant</th> <th>Existing plant ⁽⁸⁷⁾</th> <th>New plant</th> <th>Existing plant ⁽⁸⁸⁾</th> </tr> </thead> <tbody> <tr> <td>< 100</td> <td>15–70</td> <td>15–100</td> <td>30–175</td> <td>30–215</td> </tr> <tr> <td>100–300</td> <td>< 10–50</td> <td>< 10–70 ⁽⁸⁹⁾</td> <td>< 20–85</td> <td>< 20–175 ⁽⁹⁰⁾</td> </tr> <tr> <td>≥ 300</td> <td>< 10–35</td> <td>< 10–50 ⁽⁸⁹⁾</td> <td>< 20–70</td> <td>< 20–85 ⁽⁹¹⁾</td> </tr> </tbody> </table>						Combustion plant total rated thermal input (MW _{th})	BAT-AELs for SO ₂ (mg/Nm ³)				Yearly average		Daily average or average over the sampling period		New plant	Existing plant ⁽⁸⁷⁾	New plant	Existing plant ⁽⁸⁸⁾	< 100	15–70	15–100	30–175	30–215	100–300	< 10–50	< 10–70 ⁽⁸⁹⁾	< 20–85	< 20–175 ⁽⁹⁰⁾	≥ 300	< 10–35	< 10–50 ⁽⁸⁹⁾	< 20–70	< 20–85 ⁽⁹¹⁾
Combustion plant total rated thermal input (MW _{th})	BAT-AELs for SO ₂ (mg/Nm ³)																																
	Yearly average		Daily average or average over the sampling period																														
	New plant	Existing plant ⁽⁸⁷⁾	New plant	Existing plant ⁽⁸⁸⁾																													
< 100	15–70	15–100	30–175	30–215																													
100–300	< 10–50	< 10–70 ⁽⁸⁹⁾	< 20–85	< 20–175 ⁽⁹⁰⁾																													
≥ 300	< 10–35	< 10–50 ⁽⁸⁹⁾	< 20–70	< 20–85 ⁽⁹¹⁾																													

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																																								
	<p align="center">BAT-associated emission levels (BAT-AELs) for HCl and HF emissions to air from the combustion of solid biomass and/or peat</p> <table border="1"> <thead> <tr> <th rowspan="3">Combustion plant total rated thermal input (MW_{th})</th> <th colspan="4">BAT-AELs for HCl (mg/Nm³) ⁽⁹²⁾ ⁽⁹³⁾</th> <th colspan="2">BAT-AELs for HF (mg/Nm³)</th> </tr> <tr> <th colspan="2">Yearly average or average of samples obtained during one year</th> <th colspan="2">Daily average or average over the sampling period</th> <th colspan="2">Average over the sampling period</th> </tr> <tr> <th>New plant</th> <th>Existing plant ⁽⁹⁴⁾ ⁽⁹⁵⁾</th> <th>New plant</th> <th>Existing plant ⁽⁹⁶⁾</th> <th>New plant</th> <th>Existing plant ⁽⁹⁶⁾</th> </tr> </thead> <tbody> <tr> <td>< 100</td> <td>1–7</td> <td>1–15</td> <td>1–12</td> <td>1–35</td> <td>< 1</td> <td>< 1,5</td> </tr> <tr> <td>100–300</td> <td>1–5</td> <td>1–9</td> <td>1–12</td> <td>1–12</td> <td>< 1</td> <td>< 1</td> </tr> <tr> <td>≥ 300</td> <td>1–5</td> <td>1–5</td> <td>1–12</td> <td>1–12</td> <td>< 1</td> <td>< 1</td> </tr> </tbody> </table>	Combustion plant total rated thermal input (MW _{th})	BAT-AELs for HCl (mg/Nm ³) ⁽⁹²⁾ ⁽⁹³⁾				BAT-AELs for HF (mg/Nm ³)		Yearly average or average of samples obtained during one year		Daily average or average over the sampling period		Average over the sampling period		New plant	Existing plant ⁽⁹⁴⁾ ⁽⁹⁵⁾	New plant	Existing plant ⁽⁹⁶⁾	New plant	Existing plant ⁽⁹⁶⁾	< 100	1–7	1–15	1–12	1–35	< 1	< 1,5	100–300	1–5	1–9	1–12	1–12	< 1	< 1	≥ 300	1–5	1–5	1–12	1–12	< 1	< 1		<p>A full years operational data is not yet available and the combustion plant has not operated on the full range of fuels. A full data set will be provided to the Environment Agency to confirm BAT-AEL compliance before 31st July 2021.</p>
Combustion plant total rated thermal input (MW _{th})	BAT-AELs for HCl (mg/Nm ³) ⁽⁹²⁾ ⁽⁹³⁾				BAT-AELs for HF (mg/Nm ³)																																						
	Yearly average or average of samples obtained during one year		Daily average or average over the sampling period		Average over the sampling period																																						
	New plant	Existing plant ⁽⁹⁴⁾ ⁽⁹⁵⁾	New plant	Existing plant ⁽⁹⁶⁾	New plant	Existing plant ⁽⁹⁶⁾																																					
< 100	1–7	1–15	1–12	1–35	< 1	< 1,5																																					
100–300	1–5	1–9	1–12	1–12	< 1	< 1																																					
≥ 300	1–5	1–5	1–12	1–12	< 1	< 1																																					
26	<p>In order to reduce dust and particulate-bound metal emissions to air from the combustion of solid biomass and/or peat, BAT is to use one or a combination of the techniques given below.</p> <table border="1"> <thead> <tr> <th>Technique</th> <th>Description</th> <th>Applicability</th> </tr> </thead> <tbody> <tr> <td>a. Electrostatic precipitator (ESP)</td> <td rowspan="2">See description in Section 8.5</td> <td rowspan="2">Generally applicable</td> </tr> <tr> <td>b. Bag filter</td> </tr> <tr> <td>c. Dry or semi-dry FGD system</td> <td>See descriptions in Section 8.5</td> <td rowspan="2">See applicability in BAT 25</td> </tr> <tr> <td>d. Wet flue-gas desulphurisation (wet FGD)</td> <td>The techniques are mainly used for SO_x, HCl and/or HF control</td> </tr> <tr> <td>e. Fuel choice</td> <td>See description in Section 8.5</td> <td>Applicable within the constraints associated with the availability of different types of fuel, which may be impacted by the energy policy of the Member State</td> </tr> </tbody> </table> <p align="center">BAT-associated emission levels (BAT-AELs) for dust emissions to air from the combustion of solid biomass and/or peat</p>	Technique	Description	Applicability	a. Electrostatic precipitator (ESP)	See description in Section 8.5	Generally applicable	b. Bag filter	c. Dry or semi-dry FGD system	See descriptions in Section 8.5	See applicability in BAT 25	d. Wet flue-gas desulphurisation (wet FGD)	The techniques are mainly used for SO _x , HCl and/or HF control	e. Fuel choice	See description in Section 8.5	Applicable within the constraints associated with the availability of different types of fuel, which may be impacted by the energy policy of the Member State	FC	<p>The operator has confirmed the following:</p> <p>b) Bag filter – A bag filter is installed at the installation.</p> <p>d) Fuel choice - The wood biomass has a low sulphur content (average 0.01 – 0.03%) and low chlorine content (0.01 – 0.05%).</p> <p>The relevant BAT-AELs for Dust have been incorporated into the permit.</p> <p>Based upon performance tests, which have been provided with the reg61 notice, it is expected</p>																									
Technique	Description	Applicability																																									
a. Electrostatic precipitator (ESP)	See description in Section 8.5	Generally applicable																																									
b. Bag filter																																											
c. Dry or semi-dry FGD system	See descriptions in Section 8.5	See applicability in BAT 25																																									
d. Wet flue-gas desulphurisation (wet FGD)	The techniques are mainly used for SO _x , HCl and/or HF control																																										
e. Fuel choice	See description in Section 8.5	Applicable within the constraints associated with the availability of different types of fuel, which may be impacted by the energy policy of the Member State																																									

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																												
	<table border="1"> <thead> <tr> <th data-bbox="318 386 719 555" rowspan="3">Combustion plant total rated thermal input (MW_{th})</th> <th colspan="4" data-bbox="719 386 1496 424">BAT-AELs for dust (mg/Nm³)</th> </tr> <tr> <th colspan="2" data-bbox="719 424 1032 488">Yearly average</th> <th colspan="2" data-bbox="1032 424 1496 488">Daily average or average over the sampling period</th> </tr> <tr> <th data-bbox="719 488 842 555">New plant</th> <th data-bbox="842 488 1032 555">Existing plant ⁽⁹⁷⁾</th> <th data-bbox="1032 488 1223 555">New plant</th> <th data-bbox="1223 488 1496 555">Existing plant ⁽⁹⁸⁾</th> </tr> </thead> <tbody> <tr> <td data-bbox="318 555 719 593">< 100</td> <td data-bbox="719 555 842 593">2-5</td> <td data-bbox="842 555 1032 593">2-15</td> <td data-bbox="1032 555 1223 593">2-10</td> <td data-bbox="1223 555 1496 593">2-22</td> </tr> <tr> <td data-bbox="318 593 719 632">100-300</td> <td data-bbox="719 593 842 632">2-5</td> <td data-bbox="842 593 1032 632">2-12</td> <td data-bbox="1032 593 1223 632">2-10</td> <td data-bbox="1223 593 1496 632">2-18</td> </tr> <tr> <td data-bbox="318 632 719 670">≥ 300</td> <td data-bbox="719 632 842 670">2-5</td> <td data-bbox="842 632 1032 670">2-10</td> <td data-bbox="1032 632 1223 670">2-10</td> <td data-bbox="1223 632 1496 670">2-16</td> </tr> </tbody> </table>	Combustion plant total rated thermal input (MW _{th})	BAT-AELs for dust (mg/Nm ³)				Yearly average		Daily average or average over the sampling period		New plant	Existing plant ⁽⁹⁷⁾	New plant	Existing plant ⁽⁹⁸⁾	< 100	2-5	2-15	2-10	2-22	100-300	2-5	2-12	2-10	2-18	≥ 300	2-5	2-10	2-10	2-16		<p>that the installation will be able to comply with the BAT-AELs.</p> <p>A full years operational data is not yet available and the combustion plant has not operated on the full range of fuels. A full data set will be provided to the Environment Agency to confirm BAT-AEL compliance before 31st July 2021.</p>
Combustion plant total rated thermal input (MW _{th})	BAT-AELs for dust (mg/Nm ³)																														
	Yearly average		Daily average or average over the sampling period																												
	New plant	Existing plant ⁽⁹⁷⁾	New plant	Existing plant ⁽⁹⁸⁾																											
< 100	2-5	2-15	2-10	2-22																											
100-300	2-5	2-12	2-10	2-18																											
≥ 300	2-5	2-10	2-10	2-16																											
27	<p>In order to prevent or reduce mercury emissions to air from the combustion of solid biomass and/or peat, BAT is to use one or a combination of the techniques given below.</p> <table border="1"> <thead> <tr> <th data-bbox="318 759 730 798">Technique</th> <th data-bbox="730 759 999 798">Description</th> <th data-bbox="999 759 1496 798">Applicability</th> </tr> </thead> <tbody> <tr> <td colspan="3" data-bbox="318 798 1496 836" style="text-align: center;">Specific techniques to reduce mercury emissions</td> </tr> <tr> <td data-bbox="318 836 360 938">a.</td> <td data-bbox="360 836 730 938">Carbon sorbent (e.g. activated carbon or halogenated activated carbon) injection in the flue-gas</td> <td data-bbox="730 836 1496 938" rowspan="3">Generally applicable</td> </tr> <tr> <td data-bbox="318 938 360 1008">b.</td> <td data-bbox="360 938 730 1008">Use of halogenated additives in the fuel or injected in the furnace</td> </tr> <tr> <td data-bbox="318 1008 360 1129">c.</td> <td data-bbox="360 1008 730 1129">Fuel choice</td> </tr> <tr> <td colspan="3" data-bbox="318 1129 1496 1168" style="text-align: center;">Co-benefit from techniques primarily used to reduce emissions of other pollutants</td> </tr> <tr> <td data-bbox="318 1168 360 1212">d.</td> <td data-bbox="360 1168 730 1212">Electrostatic precipitator (ESP)</td> <td data-bbox="730 1168 1496 1212" rowspan="3">Generally applicable</td> </tr> <tr> <td data-bbox="318 1212 360 1327">e.</td> <td data-bbox="360 1212 730 1327">Bag filter</td> </tr> <tr> <td data-bbox="318 1327 360 1366">f.</td> <td data-bbox="360 1327 730 1366">Dry or semi-dry FGD system</td> </tr> </tbody> </table>	Technique	Description	Applicability	Specific techniques to reduce mercury emissions			a.	Carbon sorbent (e.g. activated carbon or halogenated activated carbon) injection in the flue-gas	Generally applicable	b.	Use of halogenated additives in the fuel or injected in the furnace	c.	Fuel choice	Co-benefit from techniques primarily used to reduce emissions of other pollutants			d.	Electrostatic precipitator (ESP)	Generally applicable	e.	Bag filter	f.	Dry or semi-dry FGD system	FC	<p>The operator has confirmed the following:</p> <p>c) Fuel choice - the wood biomass has a low sulphur content (average 0.01 – 0.03%) and low chlorine content (0.01 – 0.05%).</p> <p>e) Bag filter – a bag filter is installed at the installation.</p> <p>The relevant BAT-AEL for mercury has been incorporated into the permit.</p> <p>To date no performance testing has been undertaken in relation to mercury. However in accordance with BAT 4 testing is proposed to be undertaken.</p>					
Technique	Description	Applicability																													
Specific techniques to reduce mercury emissions																															
a.	Carbon sorbent (e.g. activated carbon or halogenated activated carbon) injection in the flue-gas	Generally applicable																													
b.	Use of halogenated additives in the fuel or injected in the furnace																														
c.	Fuel choice																														
Co-benefit from techniques primarily used to reduce emissions of other pollutants																															
d.	Electrostatic precipitator (ESP)	Generally applicable																													
e.	Bag filter																														
f.	Dry or semi-dry FGD system																														

BAT Concn. Numbe r	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	g. Wet flue-gas desulphurisation (wet FGD)	See descriptions in Section 8.5. The techniques are mainly used for SO _x , HCl and/or HF control	See applicability in BAT 25		
The BAT-associated emission level (BAT-AEL) for mercury emissions to air from the combustion of solid biomass and/or peat is < 1–5 µg/Nm ³ as average over the sampling period.					

6 Review and assessment of derogation requests made by the operator in relation to BAT Conclusions which include an associated emission level (AEL) value

The IED enables a competent authority to allow derogations from BAT AELs stated in BAT Conclusions under specific circumstances as detailed under Article 15(4):

By way of derogation from paragraph 3, and without prejudice to Article 18, the competent authority may, in specific cases, set less strict emission limit values. Such a derogation may apply only where an assessment shows that the achievement of emission levels associated with the best available techniques as described in BAT conclusions would lead to disproportionately higher costs compared to the environmental benefits due to:

(a) the geographical location or the local environmental conditions of the installation concerned; or

(b) the technical characteristics of the installation concerned.

As part of their Regulation 61 Note response, the operator has not requested a derogation from compliance with any AEL values.

7 Emissions to Water

The consolidated permit incorporates two current discharges to sewer identified as S1 and S2. There are no limits set by the existing permit.

As part of our delivery of the Water Framework Directive (WFD) requirements, we need to identify and assess the impact of sources of hazardous pollutants to surface waters from regulated industry. This is relevant to discharges to surface water and/or sewer where there are flue gas treatment activities to which BAT Conclusion 15 applies.

BAT Conclusion 15 requires a reduction in emissions to water from flue-gas treatment. The Operator confirmed that this is not applicable as there is no wet flue-gas treatment at the installation. We agree with the applicability of this BAT Conclusion, refer to Section 6 of this document.

There are no BAT AELs specified in the BAT Conclusions for this type of plant. We have therefore not carried out any additional assessment of the emissions to water as part of this review.

The operator has submitted a H1 assessment of their discharge from the onsite water treatment plant to foul sewer. The treatment plant processes boiler blowdown water and water from the demineralisation plant that cannot be reused for ash-quenching. The submission of a H1 assessment was not required as part of the regulation 61 notice. All of the parameters considered screened out at either step 1 or 2 of the H1 screening. Therefore, we do not consider that the site will have a significant impact on the receiving water. No BAT-AELs apply to the discharge.

8 Additional IED Chapter II requirements:

In the event of a black out National Grid would call on combustion plant to operate and may require them to do so outside their permitted conditions. We have dedicated black start plant and they are permitted to run as such but this scenario is relevant to the rest of the large combustion plant which could be called depending on the circumstances.

A risk assessment will be carried out by Energy UK/Joint Environmental Programme on behalf of Large Combustion Plant connected to the National Transmission System. Air emissions modelling will be based on generic black start scenarios to establish whether they have the potential to have local impact on the environment or not (on a national basis). If the modelling demonstrates that no significant impacts are likely, the plant can operate under condition 2.3.7. This conditions allows the hourly ELVs for plants operating under a black start instruction to be discounted for the purpose of reporting. We would also require there to be a procedure in place for minimisation of emissions in the case of a black start event and for reporting in the event of a black start. This modelling and the procedures have not been agreed in advance of the issue of the permit review and therefore a condition linking back to an improvement condition have been included in the permit.

9 Review and assessment of changes that are not part of the BAT Conclusions derived permit review.

This document should be read in conjunction with the application, supporting information and notice.

Aspect considered	Decision
Receipt of application	
Confidential information	A claim for commercial or industrial confidentiality has not been made.
Identifying confidential information	We have not identified information provided as part of the application that we consider to be confidential.
The site	
Biodiversity, heritage, landscape and nature conservation	<p>The application is within the relevant distance criteria of a site of heritage, landscape or nature conservation, and/or protected species or habitat.</p> <p>A full assessment of the application and its potential to affect the site(s)/species/habitat has not been carried out as part of the permit review process. We consider that the review will not affect the features of the site(s)/species/habitat as the conditions will provide at least the same level of protection as those in the previous permit and in some cases will provide a higher level of protection to those in the previous permit.</p> <p>We have not consulted Natural England on the application. The decision was taken in accordance with our guidance.</p>
Operating techniques	
General operating techniques	<p>We have reviewed the techniques used by the operator where they are relevant to the BAT Conclusions and compared these with the relevant guidance notes.</p> <p>The permit conditions ensure compliance with the relevant BREF, BAT Conclusions. The ELVs deliver compliance with the BAT-AELs.</p>
Permit conditions	
Updating permit conditions during consolidation	We have updated permit conditions to those in the current generic permit template as part of permit consolidation. The conditions will provide at least the same level of protection as those in the previous permit and in some cases will provide a higher level of protection to those in the previous permit.

Aspect considered	Decision
Changes to the permit conditions due to an Environment Agency initiated variation	We have varied the permit as stated in the variation notice.
Improvement programme	<p>Based on the information on the application, we consider that we need to impose an improvement programme.</p> <p>We have imposed an improvement programme to ensure that:</p> <ul style="list-style-type: none"> • the Environment Management System contains all procedures specified under BAT 1 • the operator will have a plan in place to ensure that the fuel is characterised in line with BAT 9. • A suitable disposal route for fly ash is in place.
Emission limits	<p>We have decided that emission limits should be set for the parameters listed in the permit.</p> <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p> <p>It is considered that the ELVs/equivalent parameters or technical measures described above will ensure that significant pollution of the environment is prevented and a high level of protection for the environment is secured.</p>
Monitoring	<p>We have decided that monitoring should be carried out for the parameters listed in the permit, using the methods detailed and to the frequencies specified.</p> <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p> <p>Table S3.3 Process monitoring requirements was amended to include the requirement to monitor energy efficiency after overhauls on site in line with BAT2.</p>
Reporting	<p>We have specified reporting in the permit for the following parameters:</p> <ul style="list-style-type: none"> • Nitrogen dioxide • Carbon monoxide • Sulphur dioxide • Hydrogen Chloride • Hydrogen Fluoride • Dust • Mercury • Ammonia

Aspect considered	Decision
	These are described in the relevant BAT Conclusions in Section 5 of this document.
Operator competence	
Management system	There is no known reason to consider that the operator will not have the management system to enable it to comply with the permit conditions.
Growth Duty	
Section 108 Deregulation Act 2015 – Growth duty	<p>We have considered our duty to have regard to the desirability of promoting economic growth set out in section 108(1) of the Deregulation Act 2015 and the guidance issued under section 110 of that Act in deciding whether to grant this permit.</p> <p>Paragraph 1.3 of the guidance says:</p> <p>“The primary role of regulators, in delivering regulation, is to achieve the regulatory outcomes for which they are responsible. For a number of regulators, these regulatory outcomes include an explicit reference to development or growth. The growth duty establishes economic growth as a factor that all specified regulators should have regard to, alongside the delivery of the protections set out in the relevant legislation.”</p> <p>We have addressed the legislative requirements and environmental standards to be set for this operation in the body of the decision document above. The guidance is clear at paragraph 1.5 that the growth duty does not legitimise non-compliance and its purpose is not to achieve or pursue economic growth at the expense of necessary protections.</p> <p>We consider the requirements and standards we have set in this permit are reasonable and necessary to avoid a risk of an unacceptable level of pollution. This also promotes growth amongst legitimate operators because the standards applied to the operator are consistent across businesses in this sector and have been set to achieve the required legislative standards.</p>