

Environment Agency

Review of an Environmental Permit for an Installation subject to Chapter II of the Industrial Emissions Directive under the Environmental Permitting (England & Wales) Regulations 2016

Decision document recording our decision-making process following review of a permit

The Permit number is: EPR/YP3133LL
The Operator is: Keadby Generation Limited
The Installation is: Keadby Power Station
This Variation Notice number is: EPR/YP3133LL/V009

What this document is about

Article 21(3) of the Industrial Emissions Directive (IED) requires the Environment Agency to review conditions in permits that it has issued and to ensure that the permit delivers compliance with relevant standards, within four years of the publication of updated decisions on best available techniques (BAT) conclusions.

We have reviewed the permit for this installation against the revised BAT Conclusions for large combustion plant published on 17th August 2017. This is our decision document, which explains the reasoning for the consolidated variation notice that we are issuing.

It explains how we have reviewed and considered the techniques used by the Operator in the operation and control of the plant and activities of the installation. This review has been undertaken with reference to the decision made by the European Commission establishing best available techniques (BAT) conclusions ('BAT Conclusions') for large combustion plant as detailed in document reference IEDC-7-1. It is our record of our decision-making process and shows how we have taken into account all relevant factors in reaching our position. It also provides a justification for the inclusion of any specific conditions in the permit that are in addition to those included in our generic permit template.

As well as considering the review of the operating techniques used by the Operator for the operation of the plant and activities of the installation, the consolidated variation notice takes into account and brings together in a single document all previous variations that relate to the original permit

issued. It also modernises the entire permit to reflect the conditions contained in our current generic permit template.

The introduction of new template conditions makes the Permit consistent with our current general approach and philosophy and with other permits issued to installations in this sector. Although the wording of some conditions has changed, while others have been removed because of the new regulatory approach, it does not reduce the level of environmental protection achieved by the Permit in any way. In this document we therefore address only our determination of substantive issues relating to the new BAT Conclusions.

This is our record of our decision-making process and shows how we have taken into account all relevant factors in reaching our position.

Throughout this document we will use a number of expressions. These are as referred to in the glossary and have the same meaning as described in “Schedule 6 Interpretation” of the Permit.

We try to explain our decision as accurately, comprehensively and plainly as possible. We would welcome any feedback as to how we might improve our decision documents in future. A lot of technical terms and acronyms are inevitable in a document of this nature: we provide a glossary of acronyms near the front of the document, for ease of reference.

How this document is structured

Glossary of terms

- 1 Our decision
- 2 How we reached our decision
- 2.1 Requesting information to demonstrate compliance with BAT
Conclusions for Large Combustion Plant
- 2.2 Review of our own information in respect to the capability of the
installation to meet revised standards included in the BAT Conclusions
document
- 2.3 Summary of how we considered the responses from public consultation.
- 3 The legal framework
- 4 Key Issues
- 5 Decision checklist regarding relevant BAT Conclusions
- 6 Emissions to Water
- 7 Additional IED Chapter II requirements

Glossary of acronyms used in this document

(Please note that this glossary is standard for our decision documents and therefore not all these acronyms are necessarily used in this document.)

APC	Air Pollution Control
BAT	Best Available Technique(s)
BAT-AEEL	BAT Associated Energy Efficiency Level
BAT-AEL	BAT Associated Emission Level
BATc	BAT conclusion
BREF	Best available techniques reference document
CCGT	Combined Cycle Gas Turbine
CEM	Continuous emissions monitor
CHP	Combined heat and power
CV	Calorific value
DAA	Directly associated activity – Additional activities necessary to be carried out to allow the principal activity to be carried out
DLN	Dry Low NOx burners
DLN-E	Dry Low NOx effective
EIONET	European environment information and observation network is a partnership network of the European Environment Agency
ELV	Emission limit value derived under BAT or an emission limit value set out in IED
EMS	Environmental Management System
EPR	Environmental Permitting (England and Wales) Regulations 2016 (SI 2016 No. 1154)
EWC	European waste catalogue
FSA	Food Standards Agency
IC	Improvement Condition
IED	Industrial Emissions Directive (2010/75/EU)
IPPCD	Integrated Pollution Prevention and Control Directive (2008/1/EC) – now superseded by IED
LCP	Large Combustion Plant subject to Chapter III of IED
MSUL/MSDL	Minimum start up load/minimum shut-down load
NOx	Oxides of nitrogen (NO plus NO ₂ expressed as NO ₂)
NPV	Net Present Value
OCGT	Open Cycle Gas Turbine
PHE	Public Health England
SAC	Special Area of Conservation
SGN	Sector guidance note
TGN	Technical guidance note
TNP	Transitional National Plan
TOC	Total Organic Carbon
WFD	Water Framework Directive (2000/60/EC)

1 Our decision

We have decided to issue the consolidated variation notice to the Operator. This will allow it to continue to operate the Installation, subject to the conditions in the consolidated variation notice.

We consider that, in reaching that decision, we have taken into account all relevant considerations and legal requirements and that the varied permit will ensure that a high level of protection is provided for the environment and human health.

The consolidated variation notice contains many conditions taken from our standard Environmental Permit template including the relevant Annexes. We developed these conditions in consultation with industry, having regard to the legal requirements of the Environmental Permitting Regulations and other relevant legislation. This document does not therefore include an explanation for these standard conditions. Where they are included in the Notice, we have considered the techniques identified by the operator for the operation of their installation, and have accepted that the details are sufficient and satisfactory to make those standard conditions appropriate. This document does, however, provide an explanation of our use of “tailor-made” or installation-specific conditions, or where our Permit template provides two or more options.

2 How we reached our decision

2.1 Requesting information to demonstrate compliance with BAT Conclusions for Large Combustion Plant

We issued a Notice under Regulation 61(1) of the Environmental Permitting (England and Wales) Regulations 2016 (a Regulation 61 Notice) on 1st May 2018 requiring the Operator to provide information to demonstrate how the operation of their installation currently meets, or will subsequently meet, the revised standards described in the large combustion plant BAT Conclusions document. The Notice also required that where the revised standards are not currently met, the operator should provide information that:

- Describes the techniques that will be implemented before 17th August 2021, which will then ensure that operations meet the revised standard, or
- Justifies why standards will not be met by 17th August 2021, and confirmation of the date when the operation of those processes will cease within the installation or an explanation of why the revised BAT standard is not applicable to those processes, or
- Justifies why an alternative technique will achieve the same level of environmental protection equivalent to the revised standard described in the BAT Conclusions.

Where the Operator proposed that they were not intending to meet a BAT standard that also included a BAT Associated Emission Level (BAT AEL) described in the BAT Conclusions Document, the Regulation 61 Notice requested that the Operator make a formal request for derogation from compliance with that AEL (as provisioned by Article 15(4) of IED). In this circumstance, the Notice identified that any such request for derogation must be supported and justified by sufficient technical and commercial information that would enable us to determine acceptability of the derogation request.

The Regulation 61 Notice response from the Operator was received on 30/10/2018 and an amended version with new operating hours and modes was received 19/09/2019..

We considered the amended version was in the correct form and contained sufficient information for us to begin our determination of the permit review.

2.2 Review of our own information in respect to the capability of the installation to meet revised standards included in the BAT Conclusions document

Based on our records and previous regulatory activities with the facility we have no reason to consider that the operator will not be able to comply with the conditions that we include in the permit.

3 The legal framework

The consolidated variation notice will be issued, under Regulation 20 of the EPR. The Environmental Permitting regime is a legal vehicle which delivers most of the relevant legal requirements for activities falling within its scope. In particular, the regulated facility is:

- an *installation* as described by the IED;
- subject to aspects of other relevant legislation which also have to be addressed.

We consider that, the consolidated variation notice will ensure that the operation of the Installation complies with all relevant legal requirements and that a high level of protection will be delivered for the environment and human health.

We explain how we have addressed specific statutory requirements more fully in the rest of this document.

4 The key issues

The key issues arising during this permit review are:

- Emissions to air and the emission limits applied to the plant.
- The energy efficiency levels associated with the Best Available Techniques (BAT-AEELs)
- The review and assessment of the availability of BAT for gas turbines operating <500 hours per year
- Inclusion of black start condition and associated Improvement condition IC9

We therefore describe how we determined these issues in most detail in the relevant sections of this document.

4.1 Emissions to air and the emission limits applied to the plant

A number of general principles were applied during the permit review. These included:

- The upper value of the BAT AELs ranges specified were used unless use of the tighter limit was justified.
- The principle of no backsliding where if existing limits in the permit were already tighter than those specified in the BREF, the existing permit limits were retained.
- Where a limit was specified in both IED Annex V and the BAT Conclusions for a particular reference period, the tighter limit was applied and in the majority of cases this was from the BAT Conclusions.
- Where AELs are indicative in the BAT Conclusions, these were applied unless adequate justification was provided by the operator to demonstrate that an alternative limit was more appropriate.
- For gas turbines where the IED specified that limits applied over 70% load and the BAT Conclusions specified that AELs applied when dry low NOx is effective (DLN-E), we have used DLN-E as a default across all monitoring requirements for NOx and CO.

The LCP(s) on site consist of

LCP Number	Plant type	Fuel	Proposed operating hours
LCP202	CCGT	Natural Gas	>1500 hours
LCP203	CCGT	Natural Gas	>1500 hours
LCP202	OCGT	Natural Gas	<1500 hours
LCP203	OCGT	Natural Gas	<1500 hours
LCP204	OCGT	Natural Gas	<1500 hours
LCP204	OCGT	Gas Oil	<500 Hours

The plant was put into operation before IED came into force and therefore the existing limits in the permit are from Part 1 of IED Annex V applicable to existing plant.

The ELVs and AELs are based on the operating regimes in the above table:

- LCP202 and LCP203 in CCGT burning natural gas - unlimited hours
- LCP202, LCP203 and LCP204 in OCGT burning natural gas <1500 hours operation
- LCP204 in OCGT burning gas oil - <500 hours operation

The following tables outline the limits that have been incorporated into the permit for LCP202, LCP203 and LCP204, where these were derived from, where the backsliding principle has been followed, and the reference periods at which they apply. The emission limits refer to concentrations, expressed as mass of emitted substance per volume of flue-gas under the following standard conditions: dry gas at a temperature of 273,15 K, pressure of 101,3 kPa and 15% oxygen concentration in flue gases. The emission limits and monitoring requirements have been incorporated into Schedule 3 of the permit.

For gas turbines operating <500 hours/year:

Under Chapter III gas turbines and gas engines operating for less than 500 hours per year are considered to be emergency plant and therefore were not covered by the emission limits set out in IED Annex V. However, for the purposes of the LCP BAT review, plants operated for emergency use may only be defined as plants which operate for the sole purpose of providing power at a site during an onsite emergency and/or during a black start and which do not provide balancing services or demand side response services. As this site runs commercially on an intermittent basis to support the Grid, it is not considered emergency plant and therefore indicative BAT applies.

We have set the indicative limits requiring validation through emission factors based on the principle that we will not require plant to fire up with the sole purpose of performing an emission measurement, as set out the UK Regulators Interpretation Document.

Where standby fuel is used on site <10 days:

Where a natural gas fired plant uses gas oil as a standby fuel for less than 10 days, we have not assessed the site against the BAT Conclusions applicable to that fuel as the use is not considered significant. We expect the site to have demonstrated that the site will be operated in a manner such that use of the standby fuel is minimised.

For plant in the TNP:

By the end of the TNP on 30 June 2020, as a minimum plant must meet the limits set out in Annex V of the Industrial Emission Directive subject to BAT assessment and the principle of no backsliding. From the implementation date of the BAT Conclusion in 2021 the relevant AELs will also apply.

LCP202 and LCP203

The tables below reflect the limits set out in the BREF to be applied from 17/08/2021.

Type	Combined Cycle Gas Turbine
Age	Permitted before publication of the LCP BREF
Operating Hours	Unlimited
Fuel	Natural gas
P	

NOx limits (mg/Nm ³)						
Averaging	IED (Annex V Part 1) - existing	BREF (Table 24 BAT-c)	Expected permit limits	Basis	Limits apply	Monitoring
Annual	None	40	40	BREF	E-DLN	Continuous
Monthly	50	None	50	IED	E-DLN	
Daily	55	50	50	BREF	E-DLN	
95 th %ile of hr means	100	None	75* (No back sliding)	IED	E-DLN	

* already in current permit, have applied the principal of no back sliding

CO limits (mg/Nm ³)						
Averaging	IED (Annex V Part 1) - existing	BREF (Table 24 BAT-c)	Expected permit limits	Basis	Limits apply	Monitoring
Annual	None	30	100 * (Indicative BAT)	BREF	E-DLN	Continuous
Monthly	100	None	100	IED	E-DLN	
Daily	100	None	100	BREF	E-DLN	
95 th %ile of hr means	200	None	200	IED	E-DLN	

*Indicative BAT, the operator has supplied evidence to show CO increases exponentially as the gas turbine approaches the emission compliance boundary defined by the combustion system. For this reason, hourly CO emissions are often close to the current 100mg/m³ ELV when the plant is operating at its stable operating limit (SEL) and gas turbine load is at its minimum (see data in BAT 44 evidence). A reduction in the current ELV would therefore necessitate raising SEL which in turn would impact on the commercial viability of the plant remaining operational at night. A potential consequence would be increased "two-shifting" and hence an increase in the total annual emissions of both CO and NOx attributable to the greater number of plant starts. From a holistic perspective, it is believed therefore that reducing the existing ELV for CO to 30mg/m³ could actually have a negative environmental impact.

The applicable top-of-range indicative CO Annual BAT-AEL is 30 mg/m³. The proposed ELV increases the indicative BAT-AEL to 100 mg/m³ to allow for the combustion characteristics of this gas turbine and potential combustor degradation relating to combustor air in-leakage.

LCP202 and LCP203 and LCP204

The tables below reflect the limits set out in the BREF to be applied from 17/08/2021.

Type	Open Cycle Gas Turbine
Age	Permitted before publication of the LCP BREF but operational after 27 November 2003
Operating Hours	Less than 1,500 hours/year
Fuel	Natural gas

NOx limits (mg/Nm ³)						
Averaging	IED (Annex V Part 1) - existing	BREF (Table 24 BAT-c)	Expected permit limits	Basis	Limits apply	Monitoring
Annual	None	None	None	-	-	-
Monthly	50	None	None	-	-	-
Daily	55	55	55	BREF	E-DLN	Continuous
95 th %ile of hr means	100	None	50	IED	E-DLN	Continuous

CO limits (mg/Nm ³)						
Averaging	IED (Annex V Part 1) - existing	BREF (Table 24 BAT-c)	Expected permit limits	Basis	Limits apply	Monitoring
Annual	None	None	None	BREF	E-DLN	Continuous
Monthly	100	None	None	IED	E-DLN	
Daily	110	None	None	BREF	E-DLN	
95 th %ile of hr means	200	None	None	IED	E-DLN	

Note, LCP204, is <100MWth and operates <1500hr/yr hence only requires periodic monitoring and a daily limit.

LCP204

Type	Open Cycle Gas Turbine
Age	Permitted before publication of the LCP BREF but operational after 27 November 2003
Operating Hours	Less than 500 hours/year
Fuel	Gas Oil

We have reviewed the monitoring requirements included in the existing permit. We consider that in line with the Joint Emissions Protocol document '*BAT for existing Gas and Liquid fuel fired OCGTs, CCGTs, and Dual Fuel GTs with a Thermal Input Rating of 50MWth or more operating <500 Hours Per Year*', we will not require <500 hour plant to run solely for the purpose of monitoring. We have taken the fact that gas oil will only be used in emergencies and for <500 hours per year to indicate that it is equivalent in risk to gas turbines running on gas oil for <500 hour plant. *We have therefore removed the periodic monitoring requirement.* In some instances we have specified the monitoring requirements after the implementation date for the LCP BAT Conclusions in 2021 to be determined through 'concentration by calculation', however, this is usually where the plant itself doesn't run over >500 hours and we want to ensure that the plant is maintained with the emission limit in mind. For this particular plant the overall turbine runs more frequently and will be monitored and reported against existing limits for operation on natural gas which will ensure that it is maintained. We have not therefore included ELVs to be measured through concentration by calculation for operation on standby fuel for <500 hours.

4.2 The energy efficiency levels associated with the Best Available Techniques Conclusions

An energy efficiency level associated with the best available techniques (BAT-AEEL) refers to the ratio between the combustion unit's net energy output(s) and the combustion unit's fuel/feedstock energy input at actual unit design. The net energy output(s) is determined at the combustion unit boundaries, including auxiliary systems (e.g. flue-gas treatment systems), and for the unit operated at full load.

LCP204 <500hrs/yr when burning gas oil.

Table 21 of the LCP BAT Conclusions specifies that the BAT-AEELs for this type of plant are not applicable to plant operating less than 1500 hours per year. We have therefore not assessed this operational aspect of the plant. We have however included a process monitoring requirement in table S3.4 of the consolidated variation notice. This is required to demonstrate that efficiency levels are maintained following any significant overhauls of equipment in order to fulfil the requirement of BAT Conclusion 2. For <500 hour plant we have specified that the assessment of efficiency can be based on calculation. This is because we will not require plant to fire up with the sole purpose of carrying out an assessment of efficiency.

LCP202, LCP203 Unlimited hours/year burning natural gas

The table 23 below sets out the BAT-AEELs specified in the LCP BAT Conclusions for the large combustion plant on the site and the energy efficiency levels confirmed through the Regulation 61 notice response. The evidence provided to demonstrate that the AEELs are met was in the form of

Keadby PS BATC LCP returns spreadsheet V6 amended, 18/09/19. We consider this plant is BAT in relation to the AEELs.

BAT AEELs (%)			Plant efficiency (%)		
Net electrical efficiency	Net total fuel utilisation	Net mechanical efficiency	Net electrical efficiency	Net total fuel utilisation	Net mechanical efficiency
LCP202 and LCP203: CCGT ≥600MWth, unlimited hours burning natural gas					
50-60	None	None	55%	NA	NA
LCP202 and LCP203: OCGT ≥50MWth, <1500hours burning natural gas					
33-41.5	None	None	36.2	NA	NA

4.3 The review and assessment of BAT for gas turbines operating < 500 hours per year

Joint Environmental Programme (JEP) produced a document ‘BAT Assessment for Existing Gas and Liquid Fuel Fired OCGTs, CCGTs and Dual-fuel GTs with a Thermal Input Rating of 50MWth or Greater Operating <500 Hours Per Year’ dated October 2018. The content of this document has been agreed in principle by the Environment Agency and we have therefore taken the document into account during our determination of this variation.

BAT 37 identifies for gas oil fuelled OCGTs operated <500hrs Water / Steam Addition and Low NOx Burners are the only potentially applicable techniques. SCR is not applicable for <500hrs.

Water injection is the process used at site to reduce NOx emissions when utilising Gas Oil. Low-NOx burner are not available on the market for the gas turbines at site. Retrofitting of a selective catalytic reduction system is not applicable to combustion plant operated <500 h/yr.

BAT 38 identifies for gas oil fuelled OCGTs operated <500hrs combustion optimisation, which is generally applicable and Oxidation catalysts. The combustion system is maintained according to original equipment manufacturers recommendations. Retrofitting of a oxidation catalyst system is not applicable to combustion plant operated <500 h/yr.

The site will operate an appropriate maintenance regime to ensure that emissions performance does not degrade beyond the range appropriate to the generation technology, the fired fuel and, where present, the emission control technology

4.4 Fuel characterisation

BAT 9 requires the operator to carry out fuel characterisation. This also applies to standby fuel.

We consider that for plants which burn natural gas from the National Grid as a fuel that it is not necessary for the operator to replicate the testing carried out by the National Grid.

This plant also burns gas oil as standby fuel and has confirmed by email on the 16/01/2020 that they will comply with the Joint Environmental Programme (JEP) report – ‘Characterisation of power plant fuels for compliance with LCP BREF Conclusion BAT 9’ issued October 2019, this has been incorporated into table S1.2 of the permit.

5 Decision checklist regarding relevant BAT Conclusions

BAT Conclusions for large combustion plant, were published by the European Commission on 17th August 2017. There are 75 BAT Conclusions. Only the BAT Conclusions relevant to the particular fuel type used on site have been replicated below.

This annex provides a record of decisions made in relation to each relevant BAT Conclusion applicable to the installation. This annex should be read in conjunction with the Consolidated Variation Notice.

The conditions in the permit through which the relevant BAT Conclusions are implemented include but are not limited to the following:

BAT Conclusion requirement topic	Permit conditions	Permit tables
Environmental Management System	1.1.1	S1.2
BAT AELs	3.1.1 and 3.5.1	S3.1, S3.1a and S3.1b
Monitoring	2.3, 3.5 and 3.6	S1.2, S1.4, S1.5 and S3.1b
Energy efficiency	1.2 and 2.3	S3.4
Noise	3.4 and 2.3	S2.1
Other operating techniques	2.3	S1.2

The overall status of compliance with the BAT conclusion is indicated in the table as:

- NA Not Applicable
- CC Currently Compliant
- FC Compliant in the future (within 4 years of publication of BAT conclusions)
- NC Not Compliant
- PC Partially Compliant

The Table below has been compiled to include all operating modes/fuels used on site assuming CCGT unlimited hours unless otherwise specified. See appropriate headings within the assessment column. (Other plant and fuels which are not used on site but are included in the BAT conclusions have been removed from the table below).

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
General			
1	<p>In order to improve the overall environmental performance, BAT is to implement and adhere to an environmental management system (EMS) that incorporates all of the following features:</p> <ul style="list-style-type: none"> i. commitment of the management, including senior management; ii. definition of an environmental policy that includes the continuous improvement of the installation by the management; iii. planning and establishing the necessary procedures, objectives and targets, in conjunction with financial planning and investment; iv. implementation of procedures <ul style="list-style-type: none"> (a) Structure and responsibility (b) Training (c) Communication (d) Employee involvement (e) Documentation (f) Efficient process control (g) Maintenance programmes (h) Emergency preparedness and response (i) Safeguarding compliance with environmental legislation v. checking performance and taking corrective action, paying particular attention to: <ul style="list-style-type: none"> (a) monitoring and measurement (see also the Reference Document on the General Principles of Monitoring) (b) corrective and preventive action (c) maintenance of records (d) independent (where practicable) internal and external auditing in order to determine whether or not the EMS conforms to planned arrangements and has been properly implemented and maintained; vi. review of the EMS and its continuing suitability, adequacy and effectiveness by senior management; vii. following the development of cleaner technologies; viii. consideration for the environmental impacts from the eventual decommissioning of the installation at the stage of designing a new plant, and throughout its operating life; viii. consideration for the environmental impacts from the eventual decommissioning of the installation at the stage of designing a new plant, and throughout its operating life; ix. application of sectoral benchmarking on a regular basis. etc - see BAT Conclusions 	CC	<p>The station operates an EMS which is fully integrated and certified to ISO14001:2015 Certificate No: GB17/873624.03. The EMS incorporates all the features described in BAT1 (i to Xiii), and the station has specific procedures and systems in place to address relevant topics listed in BAT1 x to xvi were practicable to do so. In relation to xi, xiv & xvi we would note the following: 1) xvi - It is not considered necessary to have an odour management plan as the LCP's operations do not involve the combustion of malodorous substances, therefore this is not considered to be an environmental risk. However, there are procedures in place to review any complaints received which could include those related to odour. 2) xiv - It is not considered necessary to have an dust management plan as the LCP's operations do not involve the handling of dust producing substances, therefore this is not considered to be an environmental risk. However, there are procedures in place to review any complaints received which could include those related</p>

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement												
	Applicability. The scope (e.g. level of detail) and nature of the EMS (e.g. standardised or non-standardised) will generally be related to the nature, scale and complexity of the installation, and the range of environmental impacts it may have.		to dust 3) xi. - see response to BAT 10/11. (See BAT 1 Evidence)												
2	BAT is to determine the net electrical efficiency and/or the net total fuel utilisation and/or the net mechanical energy efficiency of the gasification, IGCC and/or combustion units by carrying out a performance test at full load (1), according to EN standards, after the commissioning of the unit and after each modification that could significantly affect the net electrical efficiency and/or the net total fuel utilisation and/or the net mechanical energy efficiency of the unit. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.	CC	Performance tests are completed to the required EN/ISO standards as detailed within BAT 2. Performance tests were completed during commissioning of the LCP and after each modification which could significantly affect performance (See BAT 2 Evidence)												
3	<p>BAT is to monitor key process parameters relevant for emissions to air and water including those given below.</p> <table border="1" data-bbox="338 831 1496 1007"> <thead> <tr> <th>Stream</th> <th>Parameter(s)</th> <th>Monitoring</th> </tr> </thead> <tbody> <tr> <td rowspan="3">Flue-gas</td> <td>Flow</td> <td>Periodic or continuous determination</td> </tr> <tr> <td>Oxygen content, temperature, and pressure</td> <td rowspan="2">Periodic or continuous measurement</td> </tr> <tr> <td>Water vapour content ⁽³⁾</td> </tr> <tr> <td>Waste water from flue-gas treatment</td> <td>Flow, pH, and temperature</td> <td>Continuous measurement</td> </tr> </tbody> </table>	Stream	Parameter(s)	Monitoring	Flue-gas	Flow	Periodic or continuous determination	Oxygen content, temperature, and pressure	Periodic or continuous measurement	Water vapour content ⁽³⁾	Waste water from flue-gas treatment	Flow, pH, and temperature	Continuous measurement	CC	The monitoring of the specified parameters identified with in BAT 3 are conducted as follows; Flow - Continuous Determination Oxygen Content, Temperature & Pressure - Continuous Measurement Water Vapour - The sampled flue gas is dried before analysis therefore not required.
Stream	Parameter(s)	Monitoring													
Flue-gas	Flow	Periodic or continuous determination													
	Oxygen content, temperature, and pressure	Periodic or continuous measurement													
	Water vapour content ⁽³⁾														
Waste water from flue-gas treatment	Flow, pH, and temperature	Continuous measurement													
4	<p>BAT is to monitor emissions to air with at least the frequency given below and in accordance with EN standards. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.</p> <table border="1" data-bbox="338 1155 1496 1342"> <thead> <tr> <th>Substance/Parameter</th> <th>Fuel/Process/Type of combustion plant</th> <th>Combustion plant total rated thermal input</th> <th>Standard(s) ⁽⁴⁾</th> <th>Minimum monitoring frequency ⁽⁵⁾</th> <th>Monitoring associated with</th> </tr> </thead> <tbody> <tr> <td>NH₃</td> <td>— When SCR and/or SNCR is used</td> <td>All sizes</td> <td>Generic EN standards</td> <td>Continuous ⁽⁶⁾ ⁽⁷⁾</td> <td>BAT 7</td> </tr> </tbody> </table>	Substance/Parameter	Fuel/Process/Type of combustion plant	Combustion plant total rated thermal input	Standard(s) ⁽⁴⁾	Minimum monitoring frequency ⁽⁵⁾	Monitoring associated with	NH ₃	— When SCR and/or SNCR is used	All sizes	Generic EN standards	Continuous ⁽⁶⁾ ⁽⁷⁾	BAT 7	FC	The site monitors CO and NOX as required by BAT 4 for dual fired turbines. Monitoring is carried out continuously in accordance with EN14181, Local site procedures give specific details of the monitors used. IED Annex V Part 3 (2) (1) Continuous monitoring of SO2 is not required for plants firing
Substance/Parameter	Fuel/Process/Type of combustion plant	Combustion plant total rated thermal input	Standard(s) ⁽⁴⁾	Minimum monitoring frequency ⁽⁵⁾	Monitoring associated with										
NH ₃	— When SCR and/or SNCR is used	All sizes	Generic EN standards	Continuous ⁽⁶⁾ ⁽⁷⁾	BAT 7										

BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	NO _x	<ul style="list-style-type: none"> — Coal and/or lignite including waste co-incineration — Solid biomass and/or peat including waste co-incineration — HFO- and/or gas-oil-fired boilers and engines — Gas-oil-fired gas turbines — Natural-gas-fired boilers, engines, and turbines — Iron and steel process gases — Process fuels from the chemical industry — IGCC plants 	All sizes	Generic EN standards	Continuous ⁽⁶⁾ ⁽⁸⁾	BAT 20 BAT 24 BAT 28 BAT 32 BAT 37 BAT 41 BAT 42 BAT 43 BAT 47 BAT 48 BAT 56 BAT 64 BAT 65 BAT 73	Natural gas and for unabated plants firing oil with a known sulphur content. BAT 4 Item 8 As an alternative to the continuous measurement in the case of plants combusting oil with a known sulphur content and where there is no flue- gas desulphurisation system, periodic measurements at least once every three months and/or other procedures ensuring the provision of data of an equivalent scientific quality may be used to determine the SO ₂ emissions. Therefore, Gas oil not to exceed 0.1% w/w sulphur content. Natural Gas SO ₂ concentration by calculation as agreed in writing with the Environment Agency (JEP Compliance Protocol).	
	— Combustion plants on offshore platforms	All sizes	EN 14792	Once every year ⁽⁹⁾	BAT 53			
N ₂ O	<ul style="list-style-type: none"> — Coal and/or lignite in circulating fluidised bed boilers — Solid biomass and/or peat in circulating fluidised bed boilers 	All sizes	EN 21258	Once every year ⁽¹⁰⁾	BAT 20 BAT 24			
CO	<ul style="list-style-type: none"> — Coal and/or lignite including waste co-incineration — Solid biomass and/or peat including waste co-incineration — HFO- and/or gas-oil-fired boilers and engines — Gas-oil-fired gas turbines — Natural-gas-fired boilers, engines, and turbines 	All sizes	Generic EN standards	Continuous ⁽⁶⁾ ⁽⁸⁾	BAT 20 BAT 24 BAT 28 BAT 33 BAT 38 BAT 44 BAT 49 BAT 56 BAT 64 BAT 65 BAT 73			

BAT Concn. Number	Summary of BAT Conclusion requirement					Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	<ul style="list-style-type: none"> — Iron and steel process gases — Process fuels from the chemical industry — IGCC plants 						
	<ul style="list-style-type: none"> — Combustion plants on offshore platforms 	All sizes	EN 15058	Once every year ⁽⁹⁾	BAT 54		
SO ₂	<ul style="list-style-type: none"> — Coal and/or lignite incl waste co-incineration — Solid biomass and/or peat incl waste co-incineration — HFO- and/or gas-oil-fired boilers — HFO- and/or gas-oil-fired engines — Gas-oil-fired gas turbines — Iron and steel process gases — Process fuels from the chemical industry in boilers — IGCC plants 	All sizes	Generic EN standards and EN 14791	Continuous ⁽⁶⁾ ₍₁₁₎ ₍₁₂₎	BAT 21 BAT 25 BAT 29 BAT 34 BAT 39 BAT 50 BAT 57 BAT 66 BAT 67 BAT 74		
SO ₃	<ul style="list-style-type: none"> — When SCR is used 	All sizes	No EN standard available	Once every year	—		
Gaseous chlorides, expressed as HCl	<ul style="list-style-type: none"> — Coal and/or lignite — Process fuels from the chemical industry in boilers 	All sizes	EN 1911	Once every three months ⁽⁶⁾ ₍₁₃₎ ₍₁₄₎	BAT 21 BAT 57		
	<ul style="list-style-type: none"> — Solid biomass and/or peat 	All sizes	Generic EN standards	Continuous ⁽¹⁵⁾ ₍₁₆₎	BAT 25		
	<ul style="list-style-type: none"> — Waste co-incineration 	All sizes	Generic EN standards	Continuous ⁽⁶⁾ ₍₁₆₎	BAT 66 BAT 67		
HF	<ul style="list-style-type: none"> — Coal and/or lignite 	All sizes	No EN standard available	Once every three months ⁽⁶⁾ ₍₁₃₎ ₍₁₄₎	BAT 21 BAT 57		

BAT Concn. Number	Summary of BAT Conclusion requirement					Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	— Process fuels from the chemical industry in boilers						
	— Solid biomass and/or peat	All sizes	No EN standard available	Once every year	BAT 25		
	— Waste co-incineration	All sizes	Generic EN standards	Continuous ⁽⁶⁾ ₍₁₆₎	BAT 66 BAT 67		
Dust	— Coal and/or lignite — Solid biomass and/or peat — HFO- and/or gas-oil-fired boilers — Iron and steel process gases — Process fuels from the chemical industry in boilers — IGCC plants — HFO- and/or gas-oil-fired engines — Gas-oil-fired gas turbines	All sizes	Generic EN standards and EN 13284-1 and EN 13284-2	Continuous ⁽⁶⁾ ₍₁₇₎	BAT 22 BAT 26 BAT 30 BAT 35 BAT 39 BAT 51 BAT 58 BAT 75		
	— Waste co-incineration	All sizes	Generic EN standards and EN 13284-2	Continuous	BAT 68 BAT 69		
Metals and metalloids except mercury (As, Cd, Co, Cr, Cu, Mn, Ni, Pb, Sb, Se, Ti, V, Zn)	— Coal and/or lignite — Solid biomass and/or peat — HFO- and/or gas-oil-fired boilers and engines	All sizes	EN 14385	Once every year ₍₁₈₎	BAT 22 BAT 26 BAT 30		
	— Waste co-incineration	< 300 MW _{th}	EN 14385	Once every six months ₍₁₅₎	BAT 68 BAT 69		
		≥ 300 MW _{th}	EN 14385	Once every three months ₍₁₅₎ ₍₁₃₎			
	— IGCC plants	≥ 100 MW _{th}	EN 14385	Once every year ₍₁₈₎	BAT 75		
Hg		< 300 MW _{th}	EN 13211	Once every three months ₍₁₅₎ ₍₂₀₎	BAT 23		

BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement								
		— Coal and/or lignite including waste co-incineration	≥ 300 MW _{th}	Generic EN standards and EN 14884	Continuous ⁽¹⁶⁾ ₍₂₁₎											
		— Solid biomass and/or peat	All sizes	EN 13211	Once every year ⁽²²⁾	BAT 27										
		— Waste co-incineration with solid biomass and/or peat	All sizes	EN 13211	Once every three months ⁽¹³⁾	BAT 70										
		— IGCC plants	≥ 100 MW _{th}	EN 13211	Once every year ⁽²³⁾	BAT 75										
	TVOC	— HFO- and/or gas-oil-fired engines — Process fuels from chemical industry in boilers	All sizes	EN 12619	Once every six months ⁽¹⁵⁾	BAT 33 BAT 59										
		— Waste co-incineration with coal, lignite, solid biomass and/or peat	All sizes	Generic EN standards	Continuous	BAT 71										
	Formaldehyde	— Natural-gas in spark-ignited lean-burn gas and dual fuel engines	All sizes	No EN standard available	Once every year	BAT 45										
	CH ₄	— Natural-gas-fired engines	All sizes	EN ISO 25139	Once every year ⁽²⁴⁾	BAT 45										
	PCDD/F	— Process fuels from chemical industry in boilers — Waste co-incineration	All sizes	EN 1948-1, EN 1948-2, EN 1948-3	Once every six months ⁽¹³⁾ ₍₂₅₎	BAT 59 BAT 71										
5	<p>BAT is to monitor emissions to water from flue-gas treatment with at least the frequency given below and in accordance with EN standards. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.</p> <table border="1" data-bbox="349 1209 1489 1331"> <thead> <tr> <th data-bbox="349 1209 678 1294">Substance/Parameter</th> <th data-bbox="678 1209 1032 1294">Standard(s)</th> <th data-bbox="1032 1209 1272 1294">Minimum monitoring frequency</th> <th data-bbox="1272 1209 1489 1294">Monitoring associated with</th> </tr> </thead> <tbody> <tr> <td data-bbox="349 1294 678 1331">Total organic carbon (TOC) ⁽²⁶⁾</td> <td data-bbox="678 1294 1032 1331">EN 1484</td> <td data-bbox="1032 1294 1272 1331">Once every month</td> <td data-bbox="1272 1294 1489 1331">BAT 15</td> </tr> </tbody> </table>						Substance/Parameter	Standard(s)	Minimum monitoring frequency	Monitoring associated with	Total organic carbon (TOC) ⁽²⁶⁾	EN 1484	Once every month	BAT 15	NA	The LCP does not operate a flue-gas treatment system
Substance/Parameter	Standard(s)	Minimum monitoring frequency	Monitoring associated with													
Total organic carbon (TOC) ⁽²⁶⁾	EN 1484	Once every month	BAT 15													

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																																														
	<table border="1"> <tr> <td>Chemical oxygen demand (COD)₍₂₆₎</td> <td>No EN standard available</td> <td></td> <td></td> </tr> <tr> <td>Total suspended solids (TSS)</td> <td>EN 872</td> <td></td> <td></td> </tr> <tr> <td>Fluoride (F⁻)</td> <td>EN ISO 10304-1</td> <td></td> <td></td> </tr> <tr> <td>Sulphate (SO₄²⁻)</td> <td>EN ISO 10304-1</td> <td></td> <td></td> </tr> <tr> <td>Sulphide, easily released (S²⁻)</td> <td>No EN standard available</td> <td></td> <td></td> </tr> <tr> <td>Sulphite (SO₃²⁻)</td> <td>EN ISO 10304-3</td> <td></td> <td></td> </tr> <tr> <td>Metals and metalloids</td> <td> <table border="1"> <tr> <td>As</td> <td rowspan="7">Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)</td> </tr> <tr><td>Cd</td></tr> <tr><td>Cr</td></tr> <tr><td>Cu</td></tr> <tr><td>Ni</td></tr> <tr><td>Pb</td></tr> <tr><td>Zn</td></tr> <tr> <td>Hg</td> <td>Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)</td> </tr> </table> </td> <td></td> <td></td> </tr> <tr> <td>Chloride (Cl⁻)</td> <td>Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)</td> <td></td> <td>—</td> </tr> <tr> <td>Total nitrogen</td> <td>EN 12260</td> <td></td> <td>—</td> </tr> </table>	Chemical oxygen demand (COD) ₍₂₆₎	No EN standard available			Total suspended solids (TSS)	EN 872			Fluoride (F ⁻)	EN ISO 10304-1			Sulphate (SO ₄ ²⁻)	EN ISO 10304-1			Sulphide, easily released (S ²⁻)	No EN standard available			Sulphite (SO ₃ ²⁻)	EN ISO 10304-3			Metals and metalloids	<table border="1"> <tr> <td>As</td> <td rowspan="7">Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)</td> </tr> <tr><td>Cd</td></tr> <tr><td>Cr</td></tr> <tr><td>Cu</td></tr> <tr><td>Ni</td></tr> <tr><td>Pb</td></tr> <tr><td>Zn</td></tr> <tr> <td>Hg</td> <td>Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)</td> </tr> </table>	As	Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)	Cd	Cr	Cu	Ni	Pb	Zn	Hg	Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)			Chloride (Cl ⁻)	Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)		—	Total nitrogen	EN 12260		—		
Chemical oxygen demand (COD) ₍₂₆₎	No EN standard available																																																
Total suspended solids (TSS)	EN 872																																																
Fluoride (F ⁻)	EN ISO 10304-1																																																
Sulphate (SO ₄ ²⁻)	EN ISO 10304-1																																																
Sulphide, easily released (S ²⁻)	No EN standard available																																																
Sulphite (SO ₃ ²⁻)	EN ISO 10304-3																																																
Metals and metalloids	<table border="1"> <tr> <td>As</td> <td rowspan="7">Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)</td> </tr> <tr><td>Cd</td></tr> <tr><td>Cr</td></tr> <tr><td>Cu</td></tr> <tr><td>Ni</td></tr> <tr><td>Pb</td></tr> <tr><td>Zn</td></tr> <tr> <td>Hg</td> <td>Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)</td> </tr> </table>	As	Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)	Cd	Cr	Cu	Ni	Pb	Zn	Hg	Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)																																						
As	Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)																																																
Cd																																																	
Cr																																																	
Cu																																																	
Ni																																																	
Pb																																																	
Zn																																																	
Hg	Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)																																																
Chloride (Cl ⁻)	Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)		—																																														
Total nitrogen	EN 12260		—																																														
6	<p>In order to improve the general environmental performance of combustion plants and to reduce emissions to air of CO and unburnt substances, BAT is to ensure optimised combustion and to use an appropriate combination of the techniques given below.</p> <table border="1"> <thead> <tr> <th>Technique</th> <th>Description</th> <th>Applicability</th> </tr> </thead> <tbody> <tr> <td>a. Fuel blending and mixing</td> <td>Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type</td> <td>Generally applicable</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Fuel blending and mixing	Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type	Generally applicable	CC	The site is a CCGT and utilises the combination of two or more thermodynamic cycles, e.g. a Brayton cycle (gas turbine/combustion engine) with a Rankine cycle (steam turbine/boiler), to convert heat loss from the flue-gas of the first cycle to useful energy by subsequent cycle(s). The																																								
Technique	Description	Applicability																																															
a. Fuel blending and mixing	Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type	Generally applicable																																															

BAT Concn. Number	Summary of BAT Conclusion requirement				Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	b.	Maintenance of the combustion system	Regular planned maintenance according to suppliers' recommendations			combustion system is maintained according to original equipment manufacturers recommendations and fitted with an advanced computer based control system to control the combustion efficiency and support the prevention and/or reduction of emissions.
	c.	Advanced control system	See description in Section 8.1	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system		
	d.	Good design of the combustion equipment	Good design of furnace, combustion chambers, burners and associated devices	Generally applicable to new combustion plants		
	e.	Fuel choice	Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used	Applicable within the constraints associated with the availability of suitable types of fuel with a better environmental profile as a whole, which may be impacted by the energy policy of the Member State, or by the integrated site's fuel balance in the case of combustion of industrial process fuels. For existing combustion plants, the type of fuel chosen may be limited by the configuration and the design of the plant		
7	<p>In order to reduce emissions of ammonia to air from the use of selective catalytic reduction (SCR) and/or selective non-catalytic reduction (SNCR) for the abatement of NO_x emissions, BAT is to optimise the design and/or operation of SCR and/or SNCR (e.g. optimised reagent to NO_x ratio, homogeneous reagent distribution and optimum size of the reagent drops).</p> <p>BAT-associated emission levels</p> <p>The BAT-associated emission level (BAT-AEL) for emissions of NH₃ to air from the use of SCR and/or SNCR is < 3–10 mg/Nm³ as a yearly average or average over the sampling period. The lower end of the range can be achieved when using SCR and the upper end of the range can be achieved when using SNCR without wet abatement techniques. In the case of plants combusting biomass and operating at variable loads as well as in the case of engines combusting HFO and/or gas oil, the higher end of the BAT-AEL range is 15 mg/Nm³.</p>				NA	The LCP does not operate a SCR or SNCR
8	<p>In order to prevent or reduce emissions to air during normal operating conditions, BAT is to ensure, by appropriate design, operation and maintenance, that the emission abatement systems are used at optimal capacity and availability.</p>				NA	The LCP does not operate an emissions abatement system.

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement														
9	<p>In order to improve the general environmental performance of combustion and/or gasification plants and to reduce emissions to air, BAT is to include the following elements in the quality assurance/quality control programmes for all the fuels used, as part of the environmental management system (see BAT 1):</p> <ul style="list-style-type: none"> (i) Initial full characterisation of the fuel used including at least the parameters listed below and in accordance with EN standards. ISO, national or other international standards may be used provided they ensure the provision of data of an equivalent scientific quality; (ii) Regular testing of the fuel quality to check that it is consistent with the initial characterisation and according to the plant design specifications. The frequency of testing and the parameters chosen from the table below are based on the variability of the fuel and an assessment of the relevance of pollutant releases (e.g. concentration in fuel, flue-gas treatment employed); (iii) Subsequent adjustment of the plant settings as and when needed and practicable (e.g. integration of the fuel characterisation and control in the advanced control system (see description in Section 8.1)). <p>Description Initial characterisation and regular testing of the fuel can be performed by the operator and/or the fuel supplier. If performed by the supplier, the full results are provided to the operator in the form of a product (fuel) supplier specification and/or guarantee.</p> <table border="1" data-bbox="338 836 1494 1372"> <thead> <tr> <th data-bbox="338 836 723 874">Fuel(s)</th> <th data-bbox="723 836 1494 874">Substances/Parameters subject to characterisation</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 874 723 1075" rowspan="3">Biomass/peat</td> <td data-bbox="723 874 1494 912">— LHV</td> </tr> <tr> <td data-bbox="723 912 1494 951">— moisture</td> </tr> <tr> <td data-bbox="723 951 1494 1075">— Ash — C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn)</td> </tr> <tr> <td data-bbox="338 1075 723 1289" rowspan="4">Coal/lignite</td> <td data-bbox="723 1075 1494 1114">— LHV</td> </tr> <tr> <td data-bbox="723 1114 1494 1152">— Moisture</td> </tr> <tr> <td data-bbox="723 1152 1494 1190">— Volatiles, ash, fixed carbon, C, H, N, O, S</td> </tr> <tr> <td data-bbox="723 1190 1494 1289">— Br, Cl, F — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)</td> </tr> <tr> <td data-bbox="338 1289 723 1372" rowspan="2">HFO</td> <td data-bbox="723 1289 1494 1327">— Ash</td> </tr> <tr> <td data-bbox="723 1327 1494 1372">— C, S, N, Ni, V</td> </tr> </tbody> </table>	Fuel(s)	Substances/Parameters subject to characterisation	Biomass/peat	— LHV	— moisture	— Ash — C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn)	Coal/lignite	— LHV	— Moisture	— Volatiles, ash, fixed carbon, C, H, N, O, S	— Br, Cl, F — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)	HFO	— Ash	— C, S, N, Ni, V	CC	<p>The fuel gas supplied to the site has been assessed in accordance with technique (i) and is continuously monitored in accordance with technique (ii) Measurement of LHV, CH₄, C₂H₆, C₃, C₄+, CO₂ and Wobbe index is carried out continuously using an online gas chromatograph which carries out calculations in accordance with ISO6976. The gas chromatograph is calibrated annually in accordance with ISO17025. The data supplied from the gas monitoring system is used to assess the performance of the plant in accordance with technique (iii).</p> <p>The Gas Oil supplied to site is tested by the supplier and the results provided for Ash, N, C & S in the form of supplier specification.</p>
Fuel(s)	Substances/Parameters subject to characterisation																
Biomass/peat	— LHV																
	— moisture																
	— Ash — C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn)																
Coal/lignite	— LHV																
	— Moisture																
	— Volatiles, ash, fixed carbon, C, H, N, O, S																
	— Br, Cl, F — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)																
HFO	— Ash																
	— C, S, N, Ni, V																

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement										
	<table border="1"> <tr> <td data-bbox="338 384 725 469">Gas oil</td> <td data-bbox="725 384 1494 469"> <ul style="list-style-type: none"> — Ash — N, C, S </td> </tr> <tr> <td data-bbox="338 469 725 553">Natural gas</td> <td data-bbox="725 469 1494 553"> <ul style="list-style-type: none"> — LHV — CH₄, C₂H₆, C₃, C₄+, CO₂, N₂, Wobbe index </td> </tr> <tr> <td data-bbox="338 553 725 638">Process fuels from the chemical industry⁽²⁷⁾</td> <td data-bbox="725 553 1494 638"> <ul style="list-style-type: none"> — Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) </td> </tr> <tr> <td data-bbox="338 638 725 707">Iron and steel process gases</td> <td data-bbox="725 638 1494 707"> <ul style="list-style-type: none"> — LHV, CH₄ (for COG), C_xH_y (for COG), CO₂, H₂, N₂, total sulphur, dust, Wobbe index </td> </tr> <tr> <td data-bbox="338 707 725 866">Waste⁽²⁸⁾</td> <td data-bbox="725 707 1494 866"> <ul style="list-style-type: none"> — LHV — Moisture — Volatiles, ash, Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) </td> </tr> </table>	Gas oil	<ul style="list-style-type: none"> — Ash — N, C, S 	Natural gas	<ul style="list-style-type: none"> — LHV — CH₄, C₂H₆, C₃, C₄+, CO₂, N₂, Wobbe index 	Process fuels from the chemical industry ⁽²⁷⁾	<ul style="list-style-type: none"> — Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) 	Iron and steel process gases	<ul style="list-style-type: none"> — LHV, CH₄ (for COG), C_xH_y (for COG), CO₂, H₂, N₂, total sulphur, dust, Wobbe index 	Waste ⁽²⁸⁾	<ul style="list-style-type: none"> — LHV — Moisture — Volatiles, ash, Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) 		
Gas oil	<ul style="list-style-type: none"> — Ash — N, C, S 												
Natural gas	<ul style="list-style-type: none"> — LHV — CH₄, C₂H₆, C₃, C₄+, CO₂, N₂, Wobbe index 												
Process fuels from the chemical industry ⁽²⁷⁾	<ul style="list-style-type: none"> — Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) 												
Iron and steel process gases	<ul style="list-style-type: none"> — LHV, CH₄ (for COG), C_xH_y (for COG), CO₂, H₂, N₂, total sulphur, dust, Wobbe index 												
Waste ⁽²⁸⁾	<ul style="list-style-type: none"> — LHV — Moisture — Volatiles, ash, Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) 												
10	<p>In order to reduce emissions to air and/or to water during other than normal operating conditions (OTNOC), BAT is to set up and implement a management plan as part of the environmental management system (see BAT 1), commensurate with the relevance of potential pollutant releases, that includes the following elements:</p> <ul style="list-style-type: none"> — appropriate design of the systems considered relevant in causing OTNOC that may have an impact on emissions to air, water and/or soil (e.g. low-load design concepts for reducing the minimum start-up and shutdown loads for stable generation in gas turbines), — set-up and implementation of a specific preventive maintenance plan for these relevant systems, — review and recording of emissions caused by OTNOC and associated circumstances and implementation of corrective actions if necessary, — periodic assessment of the overall emissions during OTNOC (e.g. frequency of events, duration, emissions quantification/estimation) and implementation of corrective actions if necessary. 	CC	<p>Sites do not have a specific OTNOC management plan, however the EMS incorporates many of the key aspects of BAT 10 & 11. The site operates a risk based review with the EMS (Aspects and impacts) which includes a review of potential impacts of OTNOC. A) Gas turbine starts are optimised based on plant condition (i.e. warmth category) along with advanced control systems (Auto tune and LVE) which enable DLN in the early stages of the firing sequence to minimise emissions during start-up. B) All plant components are included within the site</p>										

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
			<p>specific preventative maintenance programmes, the frequency of maintenance is dependent on operation of the site. BAT 11: Emissions during start-up and shutdown operations are monitored and reviewed to identify if corrective actions are required. Emissions to atmosphere are assessed as part of the annual environmental performance review carried out by sites. In the event of an accident or environmental incident, we would review the emissions, cause etc. as part of our incident investigation process and ensure any relevant corrective and / or preventive action is implemented. Start-up emissions are atypical during plant commissioning since there is a requirement to deviate from normal gas turbine load and/or exhaust temperature profiles in order to complete essential testing and/or control system tuning activities. In such cases, commissions plans are arranged to minimise additional emissions so far as is reasonable practicable.</p>
11	<p>BAT is to appropriately monitor emissions to air and/or to water during OTNOC.</p> <p>Description The monitoring can be carried out by direct measurement of emissions or by monitoring of surrogate parameters if this proves to be of equal or better scientific quality than the direct measurement of emissions.</p>	FC	<p>The site monitors CO and NOX as required. Monitoring is carried out continuously in accordance with EN14181, Local site procedures</p>

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																					
	Emissions during start-up and shutdown (SU/SD) may be assessed based on a detailed emission measurement carried out for a typical SU/SD procedure at least once every year, and using the results of this measurement to estimate the emissions for each and every SU/SD throughout the year.		<p>give specific details of the monitors used.</p> <p>SO2 concentration by calculation as agreed in writing with the Environment Agency.</p>																					
12	<p>In order to increase the energy efficiency of combustion, gasification and/or IGCC units operated $\geq 1\,500$ h/yr, BAT is to use an appropriate combination of the techniques given below.</p> <table border="1" data-bbox="338 679 1494 1350"> <thead> <tr> <th data-bbox="338 679 591 715">Technique</th> <th data-bbox="591 679 1061 715">Description</th> <th data-bbox="1061 679 1494 715">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 715 591 823">a. Combustion optimisation</td> <td data-bbox="591 715 1061 823">See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues</td> <td data-bbox="1061 715 1494 823" rowspan="4">Generally applicable</td> </tr> <tr> <td data-bbox="338 823 591 959">b. Optimisation of the working medium conditions</td> <td data-bbox="591 823 1061 959">Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO_x emissions or the characteristics of energy demanded</td> </tr> <tr> <td data-bbox="338 959 591 1067">c. Optimisation of the steam cycle</td> <td data-bbox="591 959 1061 1067">Operate with lower turbine exhaust pressure by utilisation of the lowest possible temperature of the condenser cooling water, within the design conditions</td> </tr> <tr> <td data-bbox="338 1067 591 1126">d. Minimisation of energy consumption</td> <td data-bbox="591 1067 1061 1126">Minimising the internal energy consumption (e.g. greater efficiency of the feed-water pump)</td> </tr> <tr> <td data-bbox="338 1126 591 1209">e. Preheating of combustion air</td> <td data-bbox="591 1126 1061 1209">Reuse of part of the heat recovered from the combustion flue-gas to preheat the air used in combustion</td> <td data-bbox="1061 1126 1494 1209">Generally applicable within the constraints related to the need to control NO_x emissions</td> </tr> <tr> <td data-bbox="338 1209 591 1292">f. Fuel preheating</td> <td data-bbox="591 1209 1061 1292">Preheating of fuel using recovered heat</td> <td data-bbox="1061 1209 1494 1292">Generally applicable within the constraints associated with the boiler design and the need to control NO_x emissions</td> </tr> <tr> <td data-bbox="338 1292 591 1350">g. Advanced control system</td> <td data-bbox="591 1292 1061 1350">See description in Section 8.2.</td> <td data-bbox="1061 1292 1494 1350">Generally applicable to new units. The applicability to old units may be constrained</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Combustion optimisation	See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues	Generally applicable	b. Optimisation of the working medium conditions	Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO _x emissions or the characteristics of energy demanded	c. Optimisation of the steam cycle	Operate with lower turbine exhaust pressure by utilisation of the lowest possible temperature of the condenser cooling water, within the design conditions	d. Minimisation of energy consumption	Minimising the internal energy consumption (e.g. greater efficiency of the feed-water pump)	e. Preheating of combustion air	Reuse of part of the heat recovered from the combustion flue-gas to preheat the air used in combustion	Generally applicable within the constraints related to the need to control NO _x emissions	f. Fuel preheating	Preheating of fuel using recovered heat	Generally applicable within the constraints associated with the boiler design and the need to control NO _x emissions	g. Advanced control system	See description in Section 8.2.	Generally applicable to new units. The applicability to old units may be constrained	CC	<p>Operator employs techniques a,b,c,d, and h, none of the other techniques are applicable to the technology/plant on site.</p> <p>Please note when operating under 1500hrs/yr. BAT 12 does not apply.</p>
Technique	Description	Applicability																						
a. Combustion optimisation	See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues	Generally applicable																						
b. Optimisation of the working medium conditions	Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO _x emissions or the characteristics of energy demanded																							
c. Optimisation of the steam cycle	Operate with lower turbine exhaust pressure by utilisation of the lowest possible temperature of the condenser cooling water, within the design conditions																							
d. Minimisation of energy consumption	Minimising the internal energy consumption (e.g. greater efficiency of the feed-water pump)																							
e. Preheating of combustion air	Reuse of part of the heat recovered from the combustion flue-gas to preheat the air used in combustion	Generally applicable within the constraints related to the need to control NO _x emissions																						
f. Fuel preheating	Preheating of fuel using recovered heat	Generally applicable within the constraints associated with the boiler design and the need to control NO _x emissions																						
g. Advanced control system	See description in Section 8.2.	Generally applicable to new units. The applicability to old units may be constrained																						

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
			Computerised control of the main combustion parameters enables the combustion efficiency to be improved	by the need to retrofit the combustion system and/or control command system	
	h.	Feed-water preheating using recovered heat	Preheat water coming out of the steam condenser with recovered heat, before reusing it in the boiler	Only applicable to steam circuits and not to hot boilers. Applicability to existing units may be limited due to constraints associated with the plant configuration and the amount of recoverable heat	
	i.	Heat recovery by cogeneration (CHP)	Recovery of heat (mainly from the steam system) for producing hot water/steam to be used in industrial processes/activities or in a public network for district heating. Additional heat recovery is possible from: — flue-gas — grate cooling — circulating fluidised bed	Applicable within the constraints associated with the local heat and power demand. The applicability may be limited in the case of gas compressors with an unpredictable operational heat profile	
	j.	CHP readiness	See description in Section 8.2.	Only applicable to new units where there is a realistic potential for the future use of heat in the vicinity of the unit	
	k.	Flue-gas condenser	See description in Section 8.2.	Generally applicable to CHP units provided there is enough demand for low-temperature heat	
	l.	Heat accumulation	Heat accumulation storage in CHP mode	Only applicable to CHP plants. The applicability may be limited in the case of low heat load demand	
	m.	Wet stack	See description in Section 8.2.	Generally applicable to new and existing units fitted with wet FGD	
	n.	Cooling tower discharge	The release of emissions to air through a cooling tower and not via a dedicated stack	Only applicable to units fitted with wet FGD where reheating of the flue-gas is necessary before release, and where the unit cooling system is a cooling tower	
	o.	Fuel pre-drying	The reduction of fuel moisture content before combustion to improve combustion conditions	Applicable to the combustion of biomass and/or peat within the constraints associated with spontaneous combustion	

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
				risks (e.g. the moisture content of peat is kept above 40 % throughout the delivery chain). The retrofit of existing plants may be restricted by the extra calorific value that can be obtained from the drying operation and by the limited retrofit possibilities offered by some boiler designs or plant configurations	
	p.	Minimisation of heat losses	Minimising residual heat losses, e.g. those that occur via the slag or those that can be reduced by insulating radiating sources	Only applicable to solid-fuel-fired combustion units and to gasification/IGCC units	
	q.	Advanced materials	Use of advanced materials proven to be capable of withstanding high operating temperatures and pressures and thus to achieve increased steam/combustion process efficiencies	Only applicable to new plants	
	r.	Steam turbine upgrades	This includes techniques such as increasing the temperature and pressure of medium-pressure steam, addition of a low-pressure turbine, and modifications to the geometry of the turbine rotor blades	The applicability may be restricted by demand, steam conditions and/or limited plant lifetime	
	s.	Supercritical and ultra-supercritical steam conditions	Use of a steam circuit, including steam reheating systems, in which steam can reach pressures above 220,6 bar and temperatures above 374 °C in the case of supercritical conditions, and above 250 – 300 bar and temperatures above 580 – 600 °C in the case of ultra-supercritical conditions	Only applicable to new units of $\geq 600 \text{ MW}_{th}$ operated $> 4\,000 \text{ h/yr}$. Not applicable when the purpose of the unit is to produce low steam temperatures and/or pressures in process industries. Not applicable to gas turbines and engines generating steam in CHP mode. For units combusting biomass, the applicability may be constrained by high-temperature corrosion in the case of certain biomasses	
13	In order to reduce water usage and the volume of contaminated waste water discharged, BAT is to use one or both of the techniques given below.			CC	Water usage is optimised and minimised where plant design allows. The site is fitted with a once through cooling system resulting in excellent condenser
	Technique	Description		Applicability	

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement								
	<table border="1"> <tr> <td data-bbox="338 387 376 520">a.</td> <td data-bbox="376 387 535 520">Water recycling</td> <td data-bbox="535 387 1072 520">Residual aqueous streams, including run-off water, from the plant are reused for other purposes. The degree of recycling is limited by the quality requirements of the recipient water stream and the water balance of the plant</td> <td data-bbox="1072 387 1496 520">Not applicable to waste water from cooling systems when water treatment chemicals and/or high concentrations of salts from seawater are present</td> </tr> <tr> <td data-bbox="338 520 376 652">b.</td> <td data-bbox="376 520 535 652">Dry bottom ash handling</td> <td data-bbox="535 520 1072 652">Dry, hot bottom ash falls from the furnace onto a mechanical conveyor system and is cooled down by ambient air. No water is used in the process.</td> <td data-bbox="1072 520 1496 652">Only applicable to plants combusting solid fuels. There may be technical restrictions that prevent retrofitting to existing combustion plants</td> </tr> </table>	a.	Water recycling	Residual aqueous streams, including run-off water, from the plant are reused for other purposes. The degree of recycling is limited by the quality requirements of the recipient water stream and the water balance of the plant	Not applicable to waste water from cooling systems when water treatment chemicals and/or high concentrations of salts from seawater are present	b.	Dry bottom ash handling	Dry, hot bottom ash falls from the furnace onto a mechanical conveyor system and is cooled down by ambient air. No water is used in the process.	Only applicable to plants combusting solid fuels. There may be technical restrictions that prevent retrofitting to existing combustion plants				<p>efficiency and minimal water usage (losses). The water used within the cooling water system is not of suitable quality to be re-used in other processes on site.</p> <p>Process water usage including boiler feedwater is optimised through minimisation of blowdown from the water steam cycle. The water recovered from this process (when quality allows) is reused within the water treatment plant reducing water usage.</p>
a.	Water recycling	Residual aqueous streams, including run-off water, from the plant are reused for other purposes. The degree of recycling is limited by the quality requirements of the recipient water stream and the water balance of the plant	Not applicable to waste water from cooling systems when water treatment chemicals and/or high concentrations of salts from seawater are present										
b.	Dry bottom ash handling	Dry, hot bottom ash falls from the furnace onto a mechanical conveyor system and is cooled down by ambient air. No water is used in the process.	Only applicable to plants combusting solid fuels. There may be technical restrictions that prevent retrofitting to existing combustion plants										
14	<p>In order to prevent the contamination of uncontaminated waste water and to reduce emissions to water, BAT is to segregate waste water streams and to treat them separately, depending on the pollutant content.</p> <p>Description Waste water streams that are typically segregated and treated include surface run-off water, cooling water, and waste water from flue-gas treatment.</p> <p>Applicability The applicability may be restricted in the case of existing plants due to the configuration of the drainage systems.</p>			CC	<p>All waste water streams are separated physically, in addition, waste water drains are colour coded to prevent accidental cross contamination of clean water runoff. Surface water run off from possible oil contaminated areas are protected by oil/water separators.</p>								
15	<p>In order to reduce emissions to water from flue-gas treatment, BAT is to use an appropriate combination of the techniques given in BAT 15, and to use secondary techniques as close as possible to the source in order to avoid dilution.</p>			NA	<p>The LCP does not operate a flue-gas treatment system.</p>								
16	<p>In order to reduce the quantity of waste sent for disposal from the combustion and/or gasification process and abatement techniques, BAT is to organise operations so as to maximise, in order of priority and taking into account life-cycle thinking:</p> <ul style="list-style-type: none"> (a) waste prevention, e.g. maximise the proportion of residues which arise as by-products; (b) waste preparation for reuse, e.g. according to the specific requested quality criteria; (c) waste recycling; 			CC	<p>The BAT techniques detailed within BAT 16 are not directly applicable. However, the site follows the principles of the waste hierarchy; Reduce, Reuse, Recycle, Recover and finally disposal for all waste generated at the site. The process for waste</p>								

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement															
	<p>(d) other waste recovery (e.g. energy recovery), by implementing an appropriate combination of techniques such as:</p> <table border="1" data-bbox="338 453 1494 1070"> <thead> <tr> <th data-bbox="338 453 584 488">Technique</th> <th data-bbox="584 453 1088 488">Description</th> <th data-bbox="1088 453 1494 488">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 488 584 644">a. Generation of gypsum as a by-product</td> <td data-bbox="584 488 1088 644">Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g. as raw material in the plasterboard industry). The quality of limestone used in the wet FGD influences the purity of the gypsum produced</td> <td data-bbox="1088 488 1494 644">Generally applicable within the constraints associated with the required gypsum quality, the health requirements associated to each specific use, and by the market conditions</td> </tr> <tr> <td data-bbox="338 644 584 801">b. Recycling or recovery of residues in the construction sector</td> <td data-bbox="584 644 1088 801">Recycling or recovery of residues (e.g. from semi-dry desulphurisation processes, fly ash, bottom ash) as a construction material (e.g. in road building, to replace sand in concrete production, or in the cement industry)</td> <td data-bbox="1088 644 1494 801">Generally applicable within the constraints associated with the required material quality (e.g. physical properties, content of harmful substances) associated to each specific use, and by the market conditions</td> </tr> <tr> <td data-bbox="338 801 584 911">c. Energy recovery by using waste in the fuel mix</td> <td data-bbox="584 801 1088 911">The residual energy content of carbon-rich ash and sludges generated by the combustion of coal, lignite, heavy fuel oil, peat or biomass can be recovered for example by mixing with the fuel</td> <td data-bbox="1088 801 1494 911">Generally applicable where plants can accept waste in the fuel mix and are technically able to feed the fuels into the combustion chamber</td> </tr> <tr> <td data-bbox="338 911 584 1070">d. Preparation of spent catalyst for reuse</td> <td data-bbox="584 911 1088 1070">Preparation of catalyst for reuse (e.g. up to four times for SCR catalysts) restores some or all of the original performance, extending the service life of the catalyst to several decades. Preparation of spent catalyst for reuse is integrated in a catalyst management scheme</td> <td data-bbox="1088 911 1494 1070">The applicability may be limited by the mechanical condition of the catalyst and the required performance with respect to controlling NO_x and NH₃ emissions</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Generation of gypsum as a by-product	Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g. as raw material in the plasterboard industry). The quality of limestone used in the wet FGD influences the purity of the gypsum produced	Generally applicable within the constraints associated with the required gypsum quality, the health requirements associated to each specific use, and by the market conditions	b. Recycling or recovery of residues in the construction sector	Recycling or recovery of residues (e.g. from semi-dry desulphurisation processes, fly ash, bottom ash) as a construction material (e.g. in road building, to replace sand in concrete production, or in the cement industry)	Generally applicable within the constraints associated with the required material quality (e.g. physical properties, content of harmful substances) associated to each specific use, and by the market conditions	c. Energy recovery by using waste in the fuel mix	The residual energy content of carbon-rich ash and sludges generated by the combustion of coal, lignite, heavy fuel oil, peat or biomass can be recovered for example by mixing with the fuel	Generally applicable where plants can accept waste in the fuel mix and are technically able to feed the fuels into the combustion chamber	d. Preparation of spent catalyst for reuse	Preparation of catalyst for reuse (e.g. up to four times for SCR catalysts) restores some or all of the original performance, extending the service life of the catalyst to several decades. Preparation of spent catalyst for reuse is integrated in a catalyst management scheme	The applicability may be limited by the mechanical condition of the catalyst and the required performance with respect to controlling NO _x and NH ₃ emissions		disposal is detailed within a local approved procedure.
Technique	Description	Applicability																
a. Generation of gypsum as a by-product	Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g. as raw material in the plasterboard industry). The quality of limestone used in the wet FGD influences the purity of the gypsum produced	Generally applicable within the constraints associated with the required gypsum quality, the health requirements associated to each specific use, and by the market conditions																
b. Recycling or recovery of residues in the construction sector	Recycling or recovery of residues (e.g. from semi-dry desulphurisation processes, fly ash, bottom ash) as a construction material (e.g. in road building, to replace sand in concrete production, or in the cement industry)	Generally applicable within the constraints associated with the required material quality (e.g. physical properties, content of harmful substances) associated to each specific use, and by the market conditions																
c. Energy recovery by using waste in the fuel mix	The residual energy content of carbon-rich ash and sludges generated by the combustion of coal, lignite, heavy fuel oil, peat or biomass can be recovered for example by mixing with the fuel	Generally applicable where plants can accept waste in the fuel mix and are technically able to feed the fuels into the combustion chamber																
d. Preparation of spent catalyst for reuse	Preparation of catalyst for reuse (e.g. up to four times for SCR catalysts) restores some or all of the original performance, extending the service life of the catalyst to several decades. Preparation of spent catalyst for reuse is integrated in a catalyst management scheme	The applicability may be limited by the mechanical condition of the catalyst and the required performance with respect to controlling NO _x and NH ₃ emissions																
17	<p>In order to reduce noise emissions, BAT is to use one or a combination of the techniques given below.</p> <table border="1" data-bbox="338 1115 1494 1345"> <thead> <tr> <th data-bbox="338 1115 584 1150">Technique</th> <th data-bbox="584 1115 1088 1150">Description</th> <th data-bbox="1088 1115 1494 1150">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 1150 584 1345">a. Operational measures</td> <td data-bbox="584 1150 1088 1345"> These include: <ul style="list-style-type: none"> — improved inspection and maintenance of equipment — closing of doors and windows of enclosed areas, if possible — equipment operated by experienced staff </td> <td data-bbox="1088 1150 1494 1345">Generally applicable</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Operational measures	These include: <ul style="list-style-type: none"> — improved inspection and maintenance of equipment — closing of doors and windows of enclosed areas, if possible — equipment operated by experienced staff 	Generally applicable	CC	<p>The following noise control measures are currently in place at the site.</p> <ul style="list-style-type: none"> • Detailed Inspection and Maintenance regime including any plant or equipment whose deterioration may give rise to increase in noise. 									
Technique	Description	Applicability																
a. Operational measures	These include: <ul style="list-style-type: none"> — improved inspection and maintenance of equipment — closing of doors and windows of enclosed areas, if possible — equipment operated by experienced staff 	Generally applicable																

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
		<ul style="list-style-type: none"> — avoidance of noisy activities at night, if possible — provisions for noise control during maintenance activities 			<ul style="list-style-type: none"> • Scheduled vibration monitoring to indicate potential failures, reducing potential noise sources. • The structure of the waste heat recovery boiler (WHRB) building plays an important part in the overall noise attenuation scheme. Both boilers are located within a single boiler house, which also encloses the feed pumps and chemical dosing sets and sampling points. Anti-vibration lattice baffles and de-tuning baffles are fitted to the tube banks in various positions within the gas passes to prevent boiler tube vibration. The de-tuning baffles streamline the gas flow preventing the “Tuning Fork effect”. Each WHRB is fitted with a high-performance attenuator in the exhaust duct directly above each unit to reduce stack outlet generated noise. • Thermal and acoustic insulation is fitted along the gas ductwork to the base of the stack. Above this level thermal insulation and cladding are applied to the main stack to protect the stack for acid dew point corrosion particularly when firing on distillate oil. The insulation is attached to the external surfaces of the casing and protected by metal cladding, which is virtually maintenance
b.	Low-noise equipment	This potentially includes compressors, pumps and disks	Generally applicable when the equipment is new or replaced		
c.	Noise attenuation	Noise propagation can be reduced by inserting obstacles between the emitter and the receiver. Appropriate obstacles include protection walls, embankments and buildings	Generally applicable to new plants. In the case of existing plants, the insertion of obstacles may be restricted by lack of space		
d.	Noise-control equipment	This includes: <ul style="list-style-type: none"> — noise-reducers — equipment insulation — enclosure of noisy equipment — soundproofing of buildings 	The applicability may be restricted by lack of space		
e.	Appropriate location of equipment and buildings	Noise levels can be reduced by increasing the distance between the emitter and the receiver and by using buildings as noise screens	Generally applicable to new plant		

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
			<p>free. In areas of casing where there is a requirement for noise attenuation, there is a thick slab of dense material approximately 300mm, then clad in layer of steel sheeting.</p> <ul style="list-style-type: none"> • Heavy weight composite acoustic cladding (double skinned) is present on the gas and steam turbine buildings. The gas turbines are fitted with a double skin acoustic enclosure to reduce noise levels inside the gas turbine building. • The gas turbine and steam turbine buildings were designed to reduce environmental noise. The perforated metal inner lining of the buildings was designed to expose an absorptive lining to further moderate room noise levels by controlling reverberation within the building. • Most doors in the power house buildings are fitted with high performance acoustic door sets and are kept closed except for access and egress. All ventilation openings are fitted with high performance attenuators to reduce noise breakout from the buildings. • High performance noise attenuators are fitted to the main stacks.

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																			
			<ul style="list-style-type: none"> • Acoustic enclosures are present on the demineralisation water pumps in the water treatment plant and the distillate tank transfer pumps (outdoor pump units). • Heavy weight composite acoustic cladding is present on the cooling water pump house. • Suitably trained and experienced staff are employed for plant operations. • Inspections and Maintenance activities are subject to rigorous planning where all environmental issues are considered and managed appropriately. 																			
Combustion of liquid fuels																						
36	<p>In order to increase the energy efficiency of gas oil combustion in gas turbines, BAT is to use an appropriate combination of the techniques given in BAT 12 and below.</p> <table border="1" data-bbox="338 970 1494 1117"> <thead> <tr> <th data-bbox="338 970 519 1007">Technique</th> <th data-bbox="519 970 763 1007">Description</th> <th data-bbox="763 970 1494 1007">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 1007 519 1114">a. Combined cycle</td> <td data-bbox="519 1007 763 1114">See description in Section 8.2</td> <td data-bbox="763 1007 1494 1114">Generally applicable to new units operated $\geq 1\,500$ h/yr. Applicable to existing units within the constraints associated with the steam cycle design and the space availability. Not applicable to existing units operated $< 1\,500$ h/yr</td> </tr> </tbody> </table> <p style="text-align: center;">BAT-associated energy efficiency levels (BAT-AEELs) for gas-oil-fired gas turbines</p> <table border="1" data-bbox="338 1171 1494 1347"> <thead> <tr> <th data-bbox="338 1171 981 1208" rowspan="3">Type of combustion unit</th> <th colspan="2" data-bbox="981 1171 1494 1208">BAT-AEELs ⁽¹³²⁾</th> </tr> <tr> <th colspan="2" data-bbox="981 1208 1494 1244">Net electrical efficiency (%) ⁽¹³³⁾</th> </tr> <tr> <th data-bbox="981 1244 1205 1281">New unit</th> <th data-bbox="1205 1244 1494 1281">Existing unit</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 1281 981 1318">Gas-oil-fired open-cycle gas turbine</td> <td data-bbox="981 1281 1205 1318">> 33</td> <td data-bbox="1205 1281 1494 1318">25–35,7</td> </tr> <tr> <td data-bbox="338 1318 981 1347">Gas-oil-fired combined cycle gas turbine</td> <td data-bbox="981 1318 1205 1347">> 40</td> <td data-bbox="1205 1318 1494 1347">33–44</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Combined cycle	See description in Section 8.2	Generally applicable to new units operated $\geq 1\,500$ h/yr. Applicable to existing units within the constraints associated with the steam cycle design and the space availability. Not applicable to existing units operated $< 1\,500$ h/yr	Type of combustion unit	BAT-AEELs ⁽¹³²⁾		Net electrical efficiency (%) ⁽¹³³⁾		New unit	Existing unit	Gas-oil-fired open-cycle gas turbine	> 33	25–35,7	Gas-oil-fired combined cycle gas turbine	> 40	33–44	NA	<p>LCP204 burning gas oil <500hrs/yr - Not applicable to existing gas turbines operated <1500 h/yr</p>
Technique	Description	Applicability																				
a. Combined cycle	See description in Section 8.2	Generally applicable to new units operated $\geq 1\,500$ h/yr. Applicable to existing units within the constraints associated with the steam cycle design and the space availability. Not applicable to existing units operated $< 1\,500$ h/yr																				
Type of combustion unit	BAT-AEELs ⁽¹³²⁾																					
	Net electrical efficiency (%) ⁽¹³³⁾																					
	New unit	Existing unit																				
Gas-oil-fired open-cycle gas turbine	> 33	25–35,7																				
Gas-oil-fired combined cycle gas turbine	> 40	33–44																				

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement										
37	<p>In order to prevent or reduce NO_x emissions to air from the combustion of gas oil in gas turbines, BAT is to use one or a combination of the techniques given below.</p> <table border="1" data-bbox="338 440 1494 727"> <thead> <tr> <th data-bbox="338 440 602 475">Technique</th> <th data-bbox="602 440 824 475">Description</th> <th data-bbox="824 440 1494 475">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 475 602 510">a. Water/steam addition</td> <td data-bbox="602 475 824 510" rowspan="3">See description in Section 8.3</td> <td data-bbox="824 475 1494 510">The applicability may be limited due to water availability</td> </tr> <tr> <td data-bbox="338 510 602 568">b. Low-NO_x burners (LNB)</td> <td data-bbox="824 510 1494 568">Only applicable to turbine models for which low-NO_x burners are available on the market</td> </tr> <tr> <td data-bbox="338 568 602 727">c. Selective catalytic reduction (SCR)</td> <td data-bbox="824 568 1494 727">Not applicable to combustion plants operated < 500 h/yr. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr. Retrofitting existing combustion plants may be constrained by the availability of sufficient space</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Water/steam addition	See description in Section 8.3	The applicability may be limited due to water availability	b. Low-NO _x burners (LNB)	Only applicable to turbine models for which low-NO _x burners are available on the market	c. Selective catalytic reduction (SCR)	Not applicable to combustion plants operated < 500 h/yr. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr. Retrofitting existing combustion plants may be constrained by the availability of sufficient space	CC	<p>LCP204 burning gas oil <500hrs/yr - In response to BAT 37 the Electricity Supply Industry Joint Environmental Programme prepared a BAT assessment methodology that was agreed with the EA and completed an industry BAT assessment using plant data from the JEP members. A copy of this methodology and assessment are provided as Appendix 3. BAT 37 identifies for gas oil fueled OCGTs operated <500hrs Water / Steam Addition and Low NO_x Burners are the only potentially applicable techniques. SCR is not applicable for <500hrs.</p> <p>Water injection is the process used at site to reduce No_x emissions when utilising Gas Oil. Low-No_x burner are not available on the market for the gas turbines at site. Retrofitting of a selective catalytic reduction system is not applicable to combustion plant operated <500 h/yr</p> <p>In addition to the BAT Assessment a study was completed by the Joint Environmental Programme to characterise the emissions performance of OCGTs and demonstrate that the emissions remain stable and under control.</p>
Technique	Description	Applicability											
a. Water/steam addition	See description in Section 8.3	The applicability may be limited due to water availability											
b. Low-NO _x burners (LNB)		Only applicable to turbine models for which low-NO _x burners are available on the market											
c. Selective catalytic reduction (SCR)		Not applicable to combustion plants operated < 500 h/yr. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr. Retrofitting existing combustion plants may be constrained by the availability of sufficient space											

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement									
			<p>This report ('Maintaining the Emissions Performance of Open Cycle Gas Turbines that operate for less than 500 hours per year') is presented as Appendix 4.</p> <p>The site will operate an appropriate maintenance regime to ensure that emissions performance does not degrade beyond the range appropriate to the generation technology, the fired fuel and, where present, the emission control technology</p> <p>Further information on appropriate maintenance regimes can be found within a separate report "GRAHAM D P and DUNCAN S (2018) Maintaining the Emissions Performance of Open Cycle Gas Turbines that operate for less than 500 hours per year. JEP Report UTG/18/ERG/CT/773/R, October 2018."</p>									
38	<p>In order to prevent or reduce CO emissions to air from the combustion of gas oil in gas turbines, BAT is to use one or a combination of the techniques given below.</p> <table border="1" data-bbox="349 1157 1487 1337"> <thead> <tr> <th data-bbox="349 1157 600 1193">Technique</th> <th data-bbox="600 1157 846 1193">Description</th> <th data-bbox="846 1157 1487 1193">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="349 1193 600 1249">a. Combustion optimisation</td> <td data-bbox="600 1193 846 1249">See description in Section 8.3</td> <td data-bbox="846 1193 1487 1249">Generally applicable</td> </tr> <tr> <td data-bbox="349 1249 600 1337">b. Oxidation catalysts</td> <td data-bbox="600 1249 846 1337"></td> <td data-bbox="846 1249 1487 1337">Not applicable to combustion plants operated < 500 h/yr. Retrofitting existing combustion plants may be constrained by the availability of sufficient space</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Combustion optimisation	See description in Section 8.3	Generally applicable	b. Oxidation catalysts		Not applicable to combustion plants operated < 500 h/yr. Retrofitting existing combustion plants may be constrained by the availability of sufficient space	CC	<p>LCP204 burning gas oil <500hrs/yr - the combustion system is maintained according to original equipment manufacturers recommendations. Retrofitting of a oxidation catalyst system is not applicable to combustion plant operated <500 h/yr</p>
Technique	Description	Applicability										
a. Combustion optimisation	See description in Section 8.3	Generally applicable										
b. Oxidation catalysts		Not applicable to combustion plants operated < 500 h/yr. Retrofitting existing combustion plants may be constrained by the availability of sufficient space										

BAT Conc. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																								
	As an indication, the emission level for NO _x emissions to air from the combustion of gas oil in dual fuel gas turbines for emergency use operated < 500 h/yr will generally be 145–250 mg/Nm ³ as a daily average or average over the sampling period.																										
39	<p>In order to prevent or reduce SO_x and dust emissions to air from the combustion of gas oil in gas turbines, BAT is to use the technique given below.</p> <table border="1" data-bbox="338 539 1494 635"> <thead> <tr> <th data-bbox="338 539 490 576">Technique</th> <th data-bbox="490 539 719 576">Description</th> <th data-bbox="719 539 1494 576">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 576 490 635">a. Fuel choice</td> <td data-bbox="490 576 719 635">See description in Section 8.4</td> <td data-bbox="719 576 1494 635">Applicable within the constraints associated with the availability of different types of fuel, which may be impacted by the energy policy of the Member State</td> </tr> </tbody> </table> <p>BAT-associated emission levels for SO₂ and dust emissions to air from the combustion of gas oil in gas turbines, including dual fuel gas turbines</p> <table border="1" data-bbox="338 691 1494 906"> <thead> <tr> <th data-bbox="338 691 544 847" rowspan="3">Type of combustion plant</th> <th colspan="4" data-bbox="544 691 1494 727">BAT-AELs (mg/Nm³)</th> </tr> <tr> <th colspan="2" data-bbox="544 727 1016 764">SO₂</th> <th colspan="2" data-bbox="1016 727 1494 764">Dust</th> </tr> <tr> <th data-bbox="544 764 719 847">Yearly average ⁽¹³⁴⁾</th> <th data-bbox="719 764 1016 847">Daily average or average over the sampling period ⁽¹³⁵⁾</th> <th data-bbox="1016 764 1196 847">Yearly average ⁽¹³⁴⁾</th> <th data-bbox="1196 764 1494 847">Daily average or average over the sampling period ⁽¹³⁵⁾</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 847 544 906">New and existing plants</td> <td data-bbox="544 847 719 906">35–60</td> <td data-bbox="719 847 1016 906">50–66</td> <td data-bbox="1016 847 1196 906">2–5</td> <td data-bbox="1196 847 1494 906">2–10</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Fuel choice	See description in Section 8.4	Applicable within the constraints associated with the availability of different types of fuel, which may be impacted by the energy policy of the Member State	Type of combustion plant	BAT-AELs (mg/Nm ³)				SO ₂		Dust		Yearly average ⁽¹³⁴⁾	Daily average or average over the sampling period ⁽¹³⁵⁾	Yearly average ⁽¹³⁴⁾	Daily average or average over the sampling period ⁽¹³⁵⁾	New and existing plants	35–60	50–66	2–5	2–10	CC	<p>LCP204 burning gas oil <500hrs/yr - IED Annex V Part 3 (2) (1) Continuous monitoring of SO₂ is not required for plants firing Natural gas and for unabated plants firing oil with a known sulphur content. BAT 4 Item 8 As an alternative to the continuous measurement in the case of plants combusting oil with a known sulphur content and where there is no flue- gas desulphurisation system, periodic measurements at least once every six months and/or other procedures ensuring the provision of data of an equivalent scientific quality may be used to determine the SO₂ emissions. Therefore, Gas oil not to exceed 0.1% w/w sulphur content. Natural Gas SO₂ concentration by calculation as agreed in writing with the Environment Agency (JEP Compliance Protocol).</p> <p>The site has no historical data for dust emissions to be able gauge the correct level of ELV. Therefore the site is requesting the top of the banding for Dust. SO_x would be managed by the agency setting</p>
Technique	Description	Applicability																									
a. Fuel choice	See description in Section 8.4	Applicable within the constraints associated with the availability of different types of fuel, which may be impacted by the energy policy of the Member State																									
Type of combustion plant	BAT-AELs (mg/Nm ³)																										
	SO ₂		Dust																								
	Yearly average ⁽¹³⁴⁾	Daily average or average over the sampling period ⁽¹³⁵⁾	Yearly average ⁽¹³⁴⁾	Daily average or average over the sampling period ⁽¹³⁵⁾																							
New and existing plants	35–60	50–66	2–5	2–10																							

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																																																															
			maximum sulphur content within Gas Oil purchased.																																																															
Combustion of gaseous fuels																																																																		
40	<p>In order to increase the energy efficiency of natural gas combustion, BAT is to use an appropriate combination of the techniques given in BAT 12 and below.</p> <table border="1" data-bbox="338 555 1494 799"> <thead> <tr> <th data-bbox="338 555 512 592">Technique</th> <th data-bbox="512 555 736 592">Description</th> <th data-bbox="736 555 1494 592">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 592 512 799">a. Combined cycle</td> <td data-bbox="512 592 736 799">See description in Section 8.2</td> <td data-bbox="736 592 1494 799">Generally applicable to new gas turbines and engines except when operated < 1 500 h/yr. Applicable to existing gas turbines and engines within the constraints associated with the steam cycle design and the space availability. Not applicable to existing gas turbines and engines operated < 1 500 h/yr. Not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns. Not applicable to boilers</td> </tr> </tbody> </table> <p>BAT-associated energy efficiency levels (BAT-AEELs) for the combustion of natural gas</p> <table border="1" data-bbox="338 826 1494 1139"> <thead> <tr> <th data-bbox="338 826 607 986" rowspan="3">Type of combustion unit</th> <th colspan="5" data-bbox="607 826 1494 863">BAT-AEELs ⁽¹³⁶⁾ ⁽¹³⁷⁾</th> </tr> <tr> <th colspan="2" data-bbox="607 863 864 922">Net electrical efficiency (%)</th> <th data-bbox="864 863 1140 922" rowspan="2">Net total fuel utilisation (%) ⁽¹³⁸⁾ ⁽¹³⁹⁾</th> <th colspan="2" data-bbox="1140 863 1494 922">Net mechanical energy efficiency (%) ⁽¹³⁹⁾ ⁽¹⁴⁰⁾</th> </tr> <tr> <th data-bbox="607 922 719 986">New unit</th> <th data-bbox="719 922 864 986">Existing unit</th> <th data-bbox="1140 922 1294 986">New unit</th> <th data-bbox="1294 922 1494 986">Existing unit</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 986 607 1045">Gas engine</td> <td data-bbox="607 986 719 1045">39,5–44 ⁽¹⁴¹⁾</td> <td data-bbox="719 986 864 1045">35–44 ⁽¹⁴¹⁾</td> <td data-bbox="864 986 1140 1045">56–85 ⁽¹⁴¹⁾</td> <td colspan="2" data-bbox="1140 986 1494 1045">No BAT-AEEL.</td> </tr> <tr> <td data-bbox="338 1045 607 1082">Gas-fired boiler</td> <td data-bbox="607 1045 719 1082">39–42,5</td> <td data-bbox="719 1045 864 1082">38–40</td> <td data-bbox="864 1045 1140 1082">78–95</td> <td colspan="2" data-bbox="1140 1045 1494 1082">No BAT-AEEL.</td> </tr> <tr> <td data-bbox="338 1082 607 1139">Open cycle gas turbine, ≥ 50 MW_{th}</td> <td data-bbox="607 1082 719 1139">36–41,5</td> <td data-bbox="719 1082 864 1139">33–41,5</td> <td data-bbox="864 1082 1140 1139">No BAT-AEEL</td> <td data-bbox="1140 1082 1294 1139">36,5–41</td> <td data-bbox="1294 1082 1494 1139">33,5–41</td> </tr> </tbody> </table> <p>Combined cycle gas turbine (CCGT)</p> <table border="1" data-bbox="338 1182 1494 1326"> <tbody> <tr> <td data-bbox="338 1182 607 1219">CCGT, 50–600 MW_{th}</td> <td data-bbox="607 1182 719 1219">53–58,5</td> <td data-bbox="719 1182 864 1219">46–54</td> <td data-bbox="864 1182 1140 1219">No BAT-AEEL</td> <td colspan="2" data-bbox="1140 1182 1494 1219">No BAT-AEEL</td> </tr> <tr> <td data-bbox="338 1219 607 1256">CCGT, ≥ 600 MW_{th}</td> <td data-bbox="607 1219 719 1256">57–60,5</td> <td data-bbox="719 1219 864 1256">50–60</td> <td data-bbox="864 1219 1140 1256">No BAT-AEEL</td> <td colspan="2" data-bbox="1140 1219 1494 1256">No BAT-AEEL</td> </tr> <tr> <td data-bbox="338 1256 607 1292">CHP CCGT, 50–600 MW_{th}</td> <td data-bbox="607 1256 719 1292">53–58,5</td> <td data-bbox="719 1256 864 1292">46–54</td> <td data-bbox="864 1256 1140 1292">65–95</td> <td colspan="2" data-bbox="1140 1256 1494 1292">No BAT-AEEL</td> </tr> <tr> <td data-bbox="338 1292 607 1326">CHP CCGT, ≥ 600 MW_{th}</td> <td data-bbox="607 1292 719 1326">57–60,5</td> <td data-bbox="719 1292 864 1326">50–60</td> <td data-bbox="864 1292 1140 1326">65–95</td> <td colspan="2" data-bbox="1140 1292 1494 1326">No BAT-AEEL</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Combined cycle	See description in Section 8.2	Generally applicable to new gas turbines and engines except when operated < 1 500 h/yr. Applicable to existing gas turbines and engines within the constraints associated with the steam cycle design and the space availability. Not applicable to existing gas turbines and engines operated < 1 500 h/yr. Not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns. Not applicable to boilers	Type of combustion unit	BAT-AEELs ⁽¹³⁶⁾ ⁽¹³⁷⁾					Net electrical efficiency (%)		Net total fuel utilisation (%) ⁽¹³⁸⁾ ⁽¹³⁹⁾	Net mechanical energy efficiency (%) ⁽¹³⁹⁾ ⁽¹⁴⁰⁾		New unit	Existing unit	New unit	Existing unit	Gas engine	39,5–44 ⁽¹⁴¹⁾	35–44 ⁽¹⁴¹⁾	56–85 ⁽¹⁴¹⁾	No BAT-AEEL.		Gas-fired boiler	39–42,5	38–40	78–95	No BAT-AEEL.		Open cycle gas turbine, ≥ 50 MW _{th}	36–41,5	33–41,5	No BAT-AEEL	36,5–41	33,5–41	CCGT, 50–600 MW _{th}	53–58,5	46–54	No BAT-AEEL	No BAT-AEEL		CCGT, ≥ 600 MW _{th}	57–60,5	50–60	No BAT-AEEL	No BAT-AEEL		CHP CCGT, 50–600 MW _{th}	53–58,5	46–54	65–95	No BAT-AEEL		CHP CCGT, ≥ 600 MW _{th}	57–60,5	50–60	65–95	No BAT-AEEL		CC	<p>LCP's 202 & 203 operating >1500hrs/yr in CCGT mode are the power units for the CCGT station. Last performance data shows a Station Net Efficiency LHV of 55% (see performance data TN-GEN-AM-COMM-477-011 (BAT 2 Evidence). The bottom-of-range BAT-AEEL values are appropriate.</p> <p>LCPs 202 & 203 could operate <1500hrs/year in OCGT where the BAT-AEEL's would not be applicable.</p>
Technique	Description	Applicability																																																																
a. Combined cycle	See description in Section 8.2	Generally applicable to new gas turbines and engines except when operated < 1 500 h/yr. Applicable to existing gas turbines and engines within the constraints associated with the steam cycle design and the space availability. Not applicable to existing gas turbines and engines operated < 1 500 h/yr. Not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns. Not applicable to boilers																																																																
Type of combustion unit	BAT-AEELs ⁽¹³⁶⁾ ⁽¹³⁷⁾																																																																	
	Net electrical efficiency (%)		Net total fuel utilisation (%) ⁽¹³⁸⁾ ⁽¹³⁹⁾	Net mechanical energy efficiency (%) ⁽¹³⁹⁾ ⁽¹⁴⁰⁾																																																														
	New unit	Existing unit		New unit	Existing unit																																																													
Gas engine	39,5–44 ⁽¹⁴¹⁾	35–44 ⁽¹⁴¹⁾	56–85 ⁽¹⁴¹⁾	No BAT-AEEL.																																																														
Gas-fired boiler	39–42,5	38–40	78–95	No BAT-AEEL.																																																														
Open cycle gas turbine, ≥ 50 MW _{th}	36–41,5	33–41,5	No BAT-AEEL	36,5–41	33,5–41																																																													
CCGT, 50–600 MW _{th}	53–58,5	46–54	No BAT-AEEL	No BAT-AEEL																																																														
CCGT, ≥ 600 MW _{th}	57–60,5	50–60	No BAT-AEEL	No BAT-AEEL																																																														
CHP CCGT, 50–600 MW _{th}	53–58,5	46–54	65–95	No BAT-AEEL																																																														
CHP CCGT, ≥ 600 MW _{th}	57–60,5	50–60	65–95	No BAT-AEEL																																																														

BAT Conc. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																						
41	<p>In order to prevent or reduce NO_x emissions to air from the combustion of natural gas in boilers, BAT is to use one or a combination of the techniques given below.</p> <table border="1" data-bbox="338 440 1494 1187"> <thead> <tr> <th data-bbox="338 440 591 475">Technique</th> <th data-bbox="591 440 1028 475">Description</th> <th data-bbox="1028 440 1494 475">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 475 591 560">a. Air and/or fuel staging</td> <td data-bbox="591 475 1028 560">See descriptions in Section 8.3. Air staging is often associated with low-NO_x burners</td> <td data-bbox="1028 475 1494 560" rowspan="3">Generally applicable</td> </tr> <tr> <td data-bbox="338 560 591 595">b. Flue-gas recirculation</td> <td data-bbox="591 560 1028 595">See description in Section 8.3</td> </tr> <tr> <td data-bbox="338 595 591 655">c. Low-NO_x burners (LNB)</td> <td data-bbox="591 595 1028 655"></td> </tr> <tr> <td data-bbox="338 655 591 762">d. Advanced control system</td> <td data-bbox="591 655 1028 762">See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr</td> <td data-bbox="1028 655 1494 762">The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> <tr> <td data-bbox="338 762 591 847">e. Reduction of the combustion air temperature</td> <td data-bbox="591 762 1028 847">See description in Section 8.3</td> <td data-bbox="1028 762 1494 847">Generally applicable within the constraints associated with the process needs</td> </tr> <tr> <td data-bbox="338 847 591 979">f. Selective non-catalytic reduction (SNCR)</td> <td data-bbox="591 847 1028 979"></td> <td data-bbox="1028 847 1494 979">Not applicable to combustion plants operated < 500 h/yr with highly variable boiler loads. The applicability may be limited in the case of combustion plants operated between 500 h/yr and 1 500 h/yr with highly variable boiler loads</td> </tr> <tr> <td data-bbox="338 979 591 1187">g. Selective catalytic reduction (SCR)</td> <td data-bbox="591 979 1028 1187"></td> <td data-bbox="1028 979 1494 1187">Not applicable to combustion plants operated < 500 h/yr. Not generally applicable to combustion plants of < 100 MW_{th}. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Air and/or fuel staging	See descriptions in Section 8.3. Air staging is often associated with low-NO _x burners	Generally applicable	b. Flue-gas recirculation	See description in Section 8.3	c. Low-NO _x burners (LNB)		d. Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system	e. Reduction of the combustion air temperature	See description in Section 8.3	Generally applicable within the constraints associated with the process needs	f. Selective non-catalytic reduction (SNCR)		Not applicable to combustion plants operated < 500 h/yr with highly variable boiler loads. The applicability may be limited in the case of combustion plants operated between 500 h/yr and 1 500 h/yr with highly variable boiler loads	g. Selective catalytic reduction (SCR)		Not applicable to combustion plants operated < 500 h/yr. Not generally applicable to combustion plants of < 100 MW _{th} . There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr	Narrative	NA for the site, no combustion of natural gas in the boilers
Technique	Description	Applicability																							
a. Air and/or fuel staging	See descriptions in Section 8.3. Air staging is often associated with low-NO _x burners	Generally applicable																							
b. Flue-gas recirculation	See description in Section 8.3																								
c. Low-NO _x burners (LNB)																									
d. Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system																							
e. Reduction of the combustion air temperature	See description in Section 8.3	Generally applicable within the constraints associated with the process needs																							
f. Selective non-catalytic reduction (SNCR)		Not applicable to combustion plants operated < 500 h/yr with highly variable boiler loads. The applicability may be limited in the case of combustion plants operated between 500 h/yr and 1 500 h/yr with highly variable boiler loads																							
g. Selective catalytic reduction (SCR)		Not applicable to combustion plants operated < 500 h/yr. Not generally applicable to combustion plants of < 100 MW _{th} . There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr																							
42	<p>In order to prevent or reduce NO_x emissions to air from the combustion of natural gas in gas turbines, BAT is to use one or a combination of the techniques given below.</p> <table border="1" data-bbox="338 1257 1494 1358"> <thead> <tr> <th data-bbox="338 1257 551 1292">Technique</th> <th data-bbox="551 1257 1099 1292">Description</th> <th data-bbox="1099 1257 1494 1292">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 1292 551 1358">a. Advanced control system</td> <td data-bbox="551 1292 1099 1358">See description in Section 8.3.</td> <td data-bbox="1099 1292 1494 1358">The applicability to old combustion plants may be constrained by the need</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Advanced control system	See description in Section 8.3.	The applicability to old combustion plants may be constrained by the need	CC	The combustion system is maintained according to original equipment manufacturers recommendations and fitted with an advanced computer based control system to control the																
Technique	Description	Applicability																							
a. Advanced control system	See description in Section 8.3.	The applicability to old combustion plants may be constrained by the need																							

BAT Concn. Number	Summary of BAT Conclusion requirement		Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
		This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	to retrofit the combustion system and/or control command system	<p>combustion efficiency and support the prevention and/or reduction of emissions. This also includes the use of high performance monitoring. The Gas turbines are fitted with dry low NO_x burners that include the premixing of the air and fuel before entering the combustion zone. By mixing air and fuel before combustion, a homogeneous temperature distribution and a lower flame temperature are achieved, resulting in lower NO_x emissions. Retrofitting of selective catalytic reduction (SCR) is constrained by the availability of sufficient space.</p> <p>The ISO Base Load Combined Cycle Gas Turbine (CCGT) Plant Efficiency, when firing on Natural Gas, is 55% based on historic performance testing, as declared previously. The associated Plant Net Thermal Input is 1339 MWth.</p> <p>The applicable top-of-range NO_x BAT-AELs for this Natural Gas fired, Dry Low NO_x (DLN), combustion system are: Annual 40 mg/m³ and Daily 50 mg/m³ at 15% O₂, dry. These BAT-AELs are the proposed Emission Limit Values (ELVs), applicable only when the DLN system is fully effective.</p>
b.	Water/steam addition	See description in Section 8.3	The applicability may be limited due to water availability	
c.	Dry low-NO _x burners (DLN)		The applicability may be limited in the case of turbines where a retrofit package is not available or when water/steam addition systems are installed	
d.	Low-load design concept	Adaptation of the process control and related equipment to maintain good combustion efficiency when the demand in energy varies, e.g. by improving the inlet airflow control capability or by splitting the combustion process into decoupled combustion stages	The applicability may be limited by the gas turbine design	
e.	Low-NO _x burners (LNB)	See description in Section 8.3	Generally applicable to supplementary firing for heat recovery steam generators (HRSGs) in the case of combined-cycle gas turbine (CCGT) combustion plants	
f.	Selective catalytic reduction (SCR)		<p>Not applicable in the case of combustion plants operated < 500 h/yr. Not generally applicable to existing combustion plants of < 100 MW_{th}. Retrofitting existing combustion plants may be constrained by the availability of sufficient space.</p> <p>There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr</p>	

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
			<p>The DLN system premixes the fuel with a large excess of combustion air, upstream of the combustor. The lean premix combustion system is much more complex, and more dependent on precision engineered components, than conventional diffusion flame systems and the NOx can increase over time, across outage cycles, due to degradation of the fuel injection system, air leakage into the combustor and/or instrumentation issues. The NOx emissions are also more sensitive to fluctuations in fuel quality and ambient conditions. For all of these reasons, the top-of-range BAT-AEL values are appropriate. The data supplied within BAT 42 NOx Evidence clearly supports the above summary. The raw data supplied is the hourly and daily emissions when in compliance mode 6.3.</p> <p>The site environmental permit also specifies additional Monthly ELVs of 50 mg/m3 for NOx. Also Annual Hourly Percentile ELVs of 75 mg/m3 for NOx.</p> <p><u>OCGT Operation - as above except for</u></p>

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement														
			<p>The ISO Base Load Gas Turbine (OCGT) Plant Efficiency, when firing on Natural Gas is; GT1 36.2% at 244MW, GT2 36.4% at 244 MW based on historic performance testing. The associated Plant Net Thermal Input is 1339 MWth.</p> <p>The applicable top-of-range NO_x BAT-AELs for this Natural Gas fired, Dry Low NO_x (DLN), combustion system are: Daily 50 mg/m³ at 15% O₂, dry. These BAT-AELs are the proposed Emission Limit Values (ELVs), applicable only when the DLN system is fully effective.</p>														
43	<p>In order to prevent or reduce NO_x emissions to air from the combustion of natural gas in engines, BAT is to use one or a combination of the techniques given below.</p> <table border="1" data-bbox="338 983 1494 1356"> <thead> <tr> <th data-bbox="338 983 546 1023">Technique</th> <th data-bbox="546 983 1005 1023">Description</th> <th data-bbox="1005 983 1494 1023">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 1023 546 1129">a. Advanced control system</td> <td data-bbox="546 1023 1005 1129">See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr</td> <td data-bbox="1005 1023 1494 1129">The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> <tr> <td data-bbox="338 1129 546 1187">b. Lean-burn concept</td> <td data-bbox="546 1129 1005 1187">See description in Section 8.3. Generally used in combination with SCR</td> <td data-bbox="1005 1129 1494 1187">Only applicable to new gas-fired engines</td> </tr> <tr> <td data-bbox="338 1187 546 1244">c. Advanced lean-burn concept</td> <td data-bbox="546 1187 1005 1244" rowspan="2">See descriptions in Section 8.3</td> <td data-bbox="1005 1187 1494 1244">Only applicable to new spark plug ignited engines</td> </tr> <tr> <td data-bbox="338 1244 546 1356">d. Selective catalytic reduction (SCR)</td> <td data-bbox="1005 1244 1494 1356">Retrofitting existing combustion plants may be constrained by the availability of sufficient space. Not applicable to combustion plants operated < 500 h/yr.</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system	b. Lean-burn concept	See description in Section 8.3. Generally used in combination with SCR	Only applicable to new gas-fired engines	c. Advanced lean-burn concept	See descriptions in Section 8.3	Only applicable to new spark plug ignited engines	d. Selective catalytic reduction (SCR)	Retrofitting existing combustion plants may be constrained by the availability of sufficient space. Not applicable to combustion plants operated < 500 h/yr.	NA	No natural gas fired engines on site.
Technique	Description	Applicability															
a. Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system															
b. Lean-burn concept	See description in Section 8.3. Generally used in combination with SCR	Only applicable to new gas-fired engines															
c. Advanced lean-burn concept	See descriptions in Section 8.3	Only applicable to new spark plug ignited engines															
d. Selective catalytic reduction (SCR)		Retrofitting existing combustion plants may be constrained by the availability of sufficient space. Not applicable to combustion plants operated < 500 h/yr.															

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																																																		
	<table border="1"> <tr> <td data-bbox="338 387 546 470"></td> <td data-bbox="546 387 1010 470"></td> <td data-bbox="1010 387 1494 470">There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr</td> </tr> </table>			There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr																																																	
		There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr																																																			
44	<p>In order to prevent or reduce CO emissions to air from the combustion of natural gas, BAT is to ensure optimised combustion and/or to use oxidation catalysts.</p> <p>Description - See descriptions in Section 8.3.</p> <p>BAT-associated emission levels (BAT-AELs) for NO_x emissions to air from the combustion of natural gas in gas turbines</p> <table border="1"> <thead> <tr> <th data-bbox="338 627 797 746" rowspan="2">Type of combustion plant</th> <th data-bbox="797 627 1032 746" rowspan="2">Combustion plant total rated thermal input (MW_{th})</th> <th colspan="2" data-bbox="1032 627 1494 659">BAT-AELs (mg/Nm³) ⁽¹⁴²⁾ ⁽¹⁴³⁾</th> </tr> <tr> <th data-bbox="1032 659 1256 746">Yearly average ⁽¹⁴⁴⁾ ⁽¹⁴⁵⁾</th> <th data-bbox="1256 659 1494 746">Daily average or average over the sampling period</th> </tr> </thead> <tbody> <tr> <td colspan="4" data-bbox="338 746 1494 786" style="text-align: center;">Open-cycle gas turbines (OCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁷⁾</td> </tr> <tr> <td data-bbox="338 786 797 826">New OCGT</td> <td data-bbox="797 786 1032 826">≥ 50</td> <td data-bbox="1032 786 1256 826">15–35</td> <td data-bbox="1256 786 1494 826">25–50</td> </tr> <tr> <td data-bbox="338 826 797 906">Existing OCGT (excluding turbines for mechanical drive applications) — All but plants operated < 500 h/yr</td> <td data-bbox="797 826 1032 906">≥ 50</td> <td data-bbox="1032 826 1256 906">15–50</td> <td data-bbox="1256 826 1494 906">25–55 ⁽¹⁴⁸⁾</td> </tr> <tr> <td colspan="4" data-bbox="338 906 1494 946" style="text-align: center;">Combined-cycle gas turbines (CCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁹⁾</td> </tr> <tr> <td data-bbox="338 946 797 986">New CCGT</td> <td data-bbox="797 946 1032 986">≥ 50</td> <td data-bbox="1032 946 1256 986">10–30</td> <td data-bbox="1256 946 1494 986">15–40</td> </tr> <tr> <td data-bbox="338 986 797 1042">Existing CCGT with a net total fuel utilisation of < 75 %</td> <td data-bbox="797 986 1032 1042">≥ 600</td> <td data-bbox="1032 986 1256 1042">10–40</td> <td data-bbox="1256 986 1494 1042">18–50</td> </tr> <tr> <td data-bbox="338 1042 797 1098">Existing CCGT with a net total fuel utilisation of ≥ 75 %</td> <td data-bbox="797 1042 1032 1098">≥ 600</td> <td data-bbox="1032 1042 1256 1098">10–50</td> <td data-bbox="1256 1042 1494 1098">18–55 ⁽¹⁵⁰⁾</td> </tr> <tr> <td data-bbox="338 1098 797 1153">Existing CCGT with a net total fuel utilisation of < 75 %</td> <td data-bbox="797 1098 1032 1153">50–600</td> <td data-bbox="1032 1098 1256 1153">10–45</td> <td data-bbox="1256 1098 1494 1153">35–55</td> </tr> <tr> <td data-bbox="338 1153 797 1225">Existing CCGT with a net total fuel utilisation of ≥ 75 %</td> <td data-bbox="797 1153 1032 1225">50–600</td> <td data-bbox="1032 1153 1256 1225">25–50 ⁽¹⁵¹⁾</td> <td data-bbox="1256 1153 1494 1225">35–55 ⁽¹⁵²⁾</td> </tr> <tr> <td colspan="4" data-bbox="338 1225 1494 1265" style="text-align: center;">Open- and combined-cycle gas turbines</td> </tr> <tr> <td data-bbox="338 1265 797 1353">Gas turbine put into operation no later than 27 November 2003, or existing gas turbine for emergency use and operated < 500 h/yr</td> <td data-bbox="797 1265 1032 1353">≥ 50</td> <td data-bbox="1032 1265 1256 1353">No BAT-AEL</td> <td data-bbox="1256 1265 1494 1353">60–140 ⁽¹⁵³⁾ ⁽¹⁵⁴⁾</td> </tr> </tbody> </table>	Type of combustion plant	Combustion plant total rated thermal input (MW _{th})	BAT-AELs (mg/Nm ³) ⁽¹⁴²⁾ ⁽¹⁴³⁾		Yearly average ⁽¹⁴⁴⁾ ⁽¹⁴⁵⁾	Daily average or average over the sampling period	Open-cycle gas turbines (OCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁷⁾				New OCGT	≥ 50	15–35	25–50	Existing OCGT (excluding turbines for mechanical drive applications) — All but plants operated < 500 h/yr	≥ 50	15–50	25–55 ⁽¹⁴⁸⁾	Combined-cycle gas turbines (CCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁹⁾				New CCGT	≥ 50	10–30	15–40	Existing CCGT with a net total fuel utilisation of < 75 %	≥ 600	10–40	18–50	Existing CCGT with a net total fuel utilisation of ≥ 75 %	≥ 600	10–50	18–55 ⁽¹⁵⁰⁾	Existing CCGT with a net total fuel utilisation of < 75 %	50–600	10–45	35–55	Existing CCGT with a net total fuel utilisation of ≥ 75 %	50–600	25–50 ⁽¹⁵¹⁾	35–55 ⁽¹⁵²⁾	Open- and combined-cycle gas turbines				Gas turbine put into operation no later than 27 November 2003, or existing gas turbine for emergency use and operated < 500 h/yr	≥ 50	No BAT-AEL	60–140 ⁽¹⁵³⁾ ⁽¹⁵⁴⁾	CC	<p>The combustion system is maintained according to original equipment manufacturers recommendations and fitted with an advanced computer based control system to control the combustion efficiency and support the prevention and/or reduction of emissions. This also includes the use of high performance monitoring. Oxidation catalysts is constrained by the availability of sufficient space.</p> <p>Unlike NO_x, CO increases exponentially as the gas turbine approaches the emission compliance boundary defined by the combustion system. For this reason, hourly CO emissions are often close to the current 100mg/m³ ELV when the plant is operating at its stable operating limit (SEL) and gas turbine load is at its minimum (see data in BAT 44 evidence). A reduction in the current ELV would therefore necessitate raising SEL which in turn would impact on the commercial viability of the plant remaining operational at night. A potential consequence would be increased "two-shifting" and</p>
Type of combustion plant	Combustion plant total rated thermal input (MW _{th})			BAT-AELs (mg/Nm ³) ⁽¹⁴²⁾ ⁽¹⁴³⁾																																																	
		Yearly average ⁽¹⁴⁴⁾ ⁽¹⁴⁵⁾	Daily average or average over the sampling period																																																		
Open-cycle gas turbines (OCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁷⁾																																																					
New OCGT	≥ 50	15–35	25–50																																																		
Existing OCGT (excluding turbines for mechanical drive applications) — All but plants operated < 500 h/yr	≥ 50	15–50	25–55 ⁽¹⁴⁸⁾																																																		
Combined-cycle gas turbines (CCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁹⁾																																																					
New CCGT	≥ 50	10–30	15–40																																																		
Existing CCGT with a net total fuel utilisation of < 75 %	≥ 600	10–40	18–50																																																		
Existing CCGT with a net total fuel utilisation of ≥ 75 %	≥ 600	10–50	18–55 ⁽¹⁵⁰⁾																																																		
Existing CCGT with a net total fuel utilisation of < 75 %	50–600	10–45	35–55																																																		
Existing CCGT with a net total fuel utilisation of ≥ 75 %	50–600	25–50 ⁽¹⁵¹⁾	35–55 ⁽¹⁵²⁾																																																		
Open- and combined-cycle gas turbines																																																					
Gas turbine put into operation no later than 27 November 2003, or existing gas turbine for emergency use and operated < 500 h/yr	≥ 50	No BAT-AEL	60–140 ⁽¹⁵³⁾ ⁽¹⁵⁴⁾																																																		

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																											
	<table border="1" data-bbox="338 384 1494 469"> <tr> <td data-bbox="338 384 792 469">Existing gas turbine for mechanical drive applications — All but plants operated < 500 h/yr</td> <td data-bbox="792 384 1032 469">≥ 50</td> <td data-bbox="1032 384 1256 469">15–50 ⁽¹⁵⁵⁾</td> <td data-bbox="1256 384 1494 469">25–55 ⁽¹⁵⁶⁾</td> </tr> </table> <p data-bbox="338 472 1494 523">As an indication, the yearly average CO emission levels for each type of existing combustion plant operated ≥ 1 500 h/yr and for each type of new combustion plant will generally be as follows:</p> <ul data-bbox="338 528 1494 900" style="list-style-type: none"> — New OCGT of ≥ 50 MW_{th}: < 5–40 mg/Nm³. For plants with a net electrical efficiency (EE) greater than 39 %, a correction factor may be applied to the higher end of this range, corresponding to [higher end] × EE/39, where EE is the net electrical energy efficiency or net mechanical energy efficiency of the plant determined at ISO baseload conditions. — Existing OCGT of ≥ 50 MW_{th} (excluding turbines for mechanical drive applications): < 5–40 mg/Nm³. The higher end of this range will generally be 80 mg/Nm³ in the case of existing plants that cannot be fitted with dry techniques for NO_x reduction, or 50 mg/Nm³ for plants that operate at low load. — New CCGT of ≥ 50 MW_{th}: < 5–30 mg/Nm³. For plants with a net electrical efficiency (EE) greater than 55 %, a correction factor may be applied to the higher end of the range, corresponding to [higher end] × EE/55, where EE is the net electrical energy efficiency of the plant determined at ISO baseload conditions. — Existing CCGT of ≥ 50 MW_{th}: < 5–30 mg/Nm³. The higher end of this range will generally be 50 mg/Nm³ for plants that operate at low load. — Existing gas turbines of ≥ 50 MW_{th} for mechanical drive applications: < 5–40 mg/Nm³. The higher end of the range will generally be 50 mg/Nm³ when plants operate at low load. <p data-bbox="338 904 1494 957">In the case of a gas turbine equipped with DLN burners, these indicative levels correspond to when the DLN operation is effective.</p> <p data-bbox="338 962 1494 1015">BAT-associated emission levels (BAT-AELs) for NO_x emissions to air from the combustion of natural gas in boilers and engines</p> <table border="1" data-bbox="338 1019 1494 1241"> <thead> <tr> <th data-bbox="338 1019 622 1171" rowspan="3">Type of combustion plant</th> <th colspan="4" data-bbox="622 1019 1494 1050">BAT-AELs (mg/Nm³)</th> </tr> <tr> <th colspan="2" data-bbox="622 1050 972 1112">Yearly average ⁽¹⁵⁷⁾</th> <th colspan="2" data-bbox="972 1050 1494 1112">Daily average or average over the sampling period</th> </tr> <tr> <th data-bbox="622 1112 763 1171">New plant</th> <th data-bbox="763 1112 972 1171">Existing plant ⁽¹⁵⁸⁾</th> <th data-bbox="972 1112 1180 1171">New plant</th> <th data-bbox="1180 1112 1494 1171">Existing plant ⁽¹⁵⁹⁾</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 1171 622 1201">Boiler</td> <td data-bbox="622 1171 763 1201">10–60</td> <td data-bbox="763 1171 972 1201">50–100</td> <td data-bbox="972 1171 1180 1201">30–85</td> <td data-bbox="1180 1171 1494 1201">85–110</td> </tr> <tr> <td data-bbox="338 1201 622 1241">Engine ⁽¹⁶⁰⁾</td> <td data-bbox="622 1201 763 1241">20–75</td> <td data-bbox="763 1201 972 1241">20–100</td> <td data-bbox="972 1201 1180 1241">55–85</td> <td data-bbox="1180 1201 1494 1241">55–110 ⁽¹⁶¹⁾</td> </tr> </tbody> </table> <p data-bbox="338 1246 1494 1297">As an indication, the yearly average CO emission levels will generally be:</p> <ul data-bbox="338 1302 1494 1382" style="list-style-type: none"> — < 5–40 mg/Nm³ for existing boilers operated ≥ 1 500 h/yr, — < 5–15 mg/Nm³ for new boilers, — 30–100 mg/Nm³ for existing engines operated ≥ 1 500 h/yr and for new engines. 	Existing gas turbine for mechanical drive applications — All but plants operated < 500 h/yr	≥ 50	15–50 ⁽¹⁵⁵⁾	25–55 ⁽¹⁵⁶⁾	Type of combustion plant	BAT-AELs (mg/Nm ³)				Yearly average ⁽¹⁵⁷⁾		Daily average or average over the sampling period		New plant	Existing plant ⁽¹⁵⁸⁾	New plant	Existing plant ⁽¹⁵⁹⁾	Boiler	10–60	50–100	30–85	85–110	Engine ⁽¹⁶⁰⁾	20–75	20–100	55–85	55–110 ⁽¹⁶¹⁾		<p data-bbox="1639 384 2033 632">hence an increase in the total annual emissions of both CO and NO_x attributable to the greater number of plant starts. From a holistic perspective, it is believed therefore that reducing the existing ELV for CO to 30mg/m³ could actually have a negative environmental impact.</p> <p data-bbox="1639 660 2033 909">The applicable top-of-range indicative CO Annual BAT-AEL is 30 mg/m³. The proposed ELV increases the indicative BAT-AEL to 100 mg/m³ to allow for the combustion characteristics of this gas turbine and potential combustor degradation relating to combustor air in-leakage.</p> <p data-bbox="1639 938 2033 1353">The site environmental permit also specifies additional Monthly ELVs of 100 mg/m³ for CO. Also Annual Hourly Percentile ELVs of 100 mg/m³ for CO. Effective-DLN (E-DLN) is defined as the operating point above which compliance with the above Annual NO_x and CO ELVs can be achieved with the DLN combustion system. Effective-DLN (E-DLN) also requires compliance with the above Monthly, Daily and Hourly Percentile ELV requirements.</p>
Existing gas turbine for mechanical drive applications — All but plants operated < 500 h/yr	≥ 50	15–50 ⁽¹⁵⁵⁾	25–55 ⁽¹⁵⁶⁾																											
Type of combustion plant	BAT-AELs (mg/Nm ³)																													
	Yearly average ⁽¹⁵⁷⁾		Daily average or average over the sampling period																											
	New plant	Existing plant ⁽¹⁵⁸⁾	New plant	Existing plant ⁽¹⁵⁹⁾																										
Boiler	10–60	50–100	30–85	85–110																										
Engine ⁽¹⁶⁰⁾	20–75	20–100	55–85	55–110 ⁽¹⁶¹⁾																										

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
			<p>The proposed E-DLN operating point is defined by the following DLN operational mode/parameter(s): Emissions Compliance Mode (6.3) with 166 MWe (equivalent to 70% of ISO Base Load) as a fail-safe, back-stop E-DLN reporting threshold</p> <p>Both E-DLN and MSUL are defined in relation to the current combustion and emissions characteristics whilst also taking into account potential future mechanical degradation of the gas turbine and the, as yet unknown, post-2021 operating regimes.</p> <p>OCGT operation</p> <p>The combustion system is maintained according to original equipment manufacturer's recommendations and fitted with an advanced computer based control system to control the combustion efficiency and support the prevention and/or reduction of emissions. This also includes the use of high performance monitoring. Oxidation catalysts is constrained by the availability of sufficient space.</p> <p>Unlike NO_x, CO increases exponentially as the gas turbine</p>

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
			<p>approaches the emission compliance boundary defined by the combustion system. For this reason, hourly CO emissions are often close to the current 100mg/m3 ELV when the plant is operating at its stable operating limit (SEL) and gas turbine load is at its minimum (see data in BAT 44 evidence). A reduction in the current ELV would therefore necessitate raising SEL which in turn would impact on the commercial viability of the plant remaining operational at night. A potential consequence would be increased "two-shifting" and hence an increase in the total annual emissions of both CO and NOx attributable to the greater number of plant starts. BRef is silent on this but from a holistic perspective, it is believed therefore that reducing the existing ELV could actually have a negative environmental impact.</p> <p>The site environmental permit also specifies additional Monthly ELVs of 100 mg/m3 for CO. Also Annual Hourly Percentile ELVs of 100 mg/m3 for CO.</p> <p>Effective-DLN (E-DLN) is defined as the operating point above which compliance with the above</p>

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
			<p>Annual NOx and CO ELVs can be achieved with the DLN combustion system. Effective-DLN (E-DLN) also requires compliance with the above Monthly, Daily and Hourly Percentile ELV requirements.</p> <p>The proposed E-DLN operating point is defined by the following DLN operational mode/parameter(s): Emissions Compliance Mode (6.3) with 166 MWe (equivalent to 70% of ISO Base Load) as a fail-safe, back-stop E-DLN reporting threshold</p> <p>Both E-DLN and MSUL are defined in relation to the current combustion and emissions characteristics whilst also taking into account potential future mechanical degradation of the gas turbine and the, as yet unknown, post-2021 operating regimes.</p>

6. Emissions to Water

The consolidated permit incorporates the eight current discharges to controlled waters identified as W1-W3 and W5-W9 (W4 removed via partial surrender) .

There are no BAT AELs specified in the BAT Conclusions for this type of plant. There are also no additional treatment options identified as BAT for the installation. We have therefore not carried out any additional assessment of the emissions to water as part of this review.

7 Additional IED Chapter II requirements:

In the event of a black out National Grid would call on combustion plant to operate and may require them to do so outside their permitted conditions. We have dedicated black start plant and they are permitted to run as such but this scenario is relevant to the rest of the large combustion plant which could be called depending on the circumstances.

A risk assessment will be carried out by Energy UK/Joint Environmental Programme on behalf of Large Combustion Plant connected to the National Transmission System. Air emissions modelling will be based on generic black start scenarios to establish whether they have the potential to have local impact on the environment or not (on a national basis). If the modelling demonstrates that no significant impacts are likely, the plant can operate under condition 2.3.9. This conditions allows the hourly ELVs for plants operating under a black start instruction to be discounted for the purpose of reporting. We would also require there to be a procedure in place for minimisation of emissions in the case of a black start event and for reporting in the event of a black start. This modelling and the procedures have not been agreed in advance of the issue of the permit review and therefore a condition linking back to an improvement condition have been included in the permit.

9 Review and assessment of changes that are not part of the BAT Conclusions derived permit review.

This document should be read in conjunction with the application, supporting information and notice.

Aspect considered	Decision
Receipt of application	
Confidential information	A claim for commercial or industrial confidentiality has not been made.
Identifying confidential information	We have not identified information provided as part of the application that we consider to be confidential. The decision was taken in accordance with our guidance on confidentiality.
The site	
Biodiversity, heritage, landscape and nature conservation	<p>The application is within the relevant distance criteria of a site of heritage, landscape or nature conservation, and/or protected species or habitat.</p> <p>A full assessment of the application and its potential to affect the site(s)/species/habitat has not been carried out as part of the permit review process. We consider that the review will not affect the features of the site(s)/species/habitat as the conditions will provide at least the same level of protection as those in the previous permit and in some cases will provide a higher level of protection to those in the previous permit.</p> <p>We have not consulted Natural England on the application. The decision was taken in accordance with our guidance.</p>
Operating techniques	
General operating techniques	<p>We have reviewed the techniques used by the operator where they are relevant to the BAT Conclusions and compared these with the relevant guidance notes.</p> <p>The permit conditions ensure compliance with the relevant BREF, BAT Conclusions. The ELVs deliver compliance with the BAT-AELs.</p>
Permit conditions	
Updating permit conditions during consolidation	We have updated permit conditions to those in the current generic permit template as part of permit consolidation. The conditions will provide at least the same level of protection as those in the previous permit and in some cases will provide a higher level of protection to those in the previous permit.

Aspect considered	Decision
Changes to the permit conditions due to an Environment Agency initiated variation	We have varied the permit as stated in the variation notice.
Improvement programme	<p>Based on the information on the application, we consider that we need to impose an improvement programme.</p> <p>We have imposed an improvement condition (IC9) to ensure that: there is no significant environmental risk associated with black start operations. A written report shall be submitted to the Environment Agency for approval.</p> <p>See section 7 of this document for further detail.</p>
Emission limits	<p>We have decided that emission limits should be set for the parameters listed in the permit.</p> <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p> <p>It is considered that the ELVs/equivalent parameters or technical measures described above will ensure that significant pollution of the environment is prevented and a high level of protection for the environment is secured.</p>
Monitoring	<p>We have decided that monitoring should be carried out for the parameters listed in the permit, using the methods detailed and to the frequencies specified.</p> <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p> <p>Table S3.4 Process monitoring requirements was amended to include the requirement to monitor energy efficiency after overhauls on site in line with BAT2.</p> <p>Based on the information in the application we are [not fully] satisfied that the operator's techniques, personnel and equipment have either MCERTS certification or MCERTS accreditation as appropriate.</p>
Reporting	<p>We have specified reporting in the permit for the following parameters:</p> <ul style="list-style-type: none"> • Nitrogen dioxide • Carbon monoxide • Sulphur dioxide • Dust <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p>

Aspect considered	Decision
Operator competence	
Management system	There is no known reason to consider that the operator will not have the management system to enable it to comply with the permit conditions.
Growth Duty	
Section 108 Deregulation Act 2015 – Growth duty	<p>We have considered our duty to have regard to the desirability of promoting economic growth set out in section 108(1) of the Deregulation Act 2015 and the guidance issued under section 110 of that Act in deciding whether to grant this permit.</p> <p>Paragraph 1.3 of the guidance says:</p> <p>“The primary role of regulators, in delivering regulation, is to achieve the regulatory outcomes for which they are responsible. For a number of regulators, these regulatory outcomes include an explicit reference to development or growth. The growth duty establishes economic growth as a factor that all specified regulators should have regard to, alongside the delivery of the protections set out in the relevant legislation.”</p> <p>We have addressed the legislative requirements and environmental standards to be set for this operation in the body of the decision document above. The guidance is clear at paragraph 1.5 that the growth duty does not legitimise non-compliance and its purpose is not to achieve or pursue economic growth at the expense of necessary protections.</p> <p>We consider the requirements and standards we have set in this permit are reasonable and necessary to avoid a risk of an unacceptable level of pollution. This also promotes growth amongst legitimate operators because the standards applied to the operator are consistent across businesses in this sector and have been set to achieve the required legislative standards.</p>