

Environment Agency

Review of an Environmental Permit for an Installation subject to Chapter II of the Industrial Emissions Directive under the Environmental Permitting (England & Wales) Regulations 2016

Decision document recording our decision-making process following review of a permit

The Permit number is: [EPR/BK0701IW](#)
The Operator is: [Spalding Energy Company Limited](#)
The Installation is: [Spalding Power Station](#)
This Variation Notice number is: [EPR/BK0701IW/V005](#)

What this document is about

Article 21(3) of the Industrial Emissions Directive (IED) requires the Environment Agency to review conditions in permits that it has issued and to ensure that the permit delivers compliance with relevant standards, within four years of the publication of updated decisions on best available techniques (BAT) conclusions.

We have reviewed the permit for this installation against the revised BAT Conclusions for large combustion plant published on 17th August 2017. This is our decision document, which explains the reasoning for the consolidated variation notice that we are issuing.

It explains how we have reviewed and considered the techniques used by the Operator in the operation and control of the plant and activities of the installation. This review has been undertaken with reference to the decision made by the European Commission establishing best available techniques (BAT) conclusions ('BAT Conclusions') for large combustion plant as detailed in document reference IEDC-7-1. It is our record of our decision-making process and shows how we have taken into account all relevant factors in reaching our position. It also provides a justification for the inclusion of any specific conditions in the permit that are in addition to those included in our generic permit template.

As well as considering the review of the operating techniques used by the Operator for the operation of the plant and activities of the installation, the consolidated variation notice takes into account and brings together in a single document all previous variations that relate to the original permit

issued. It also modernises the entire permit to reflect the conditions contained in our current generic permit template.

The introduction of new template conditions makes the Permit consistent with our current general approach and philosophy and with other permits issued to installations in this sector. Although the wording of some conditions has changed, while others have been removed because of the new regulatory approach, it does not reduce the level of environmental protection achieved by the Permit in any way. In this document we therefore address only our determination of substantive issues relating to the new BAT Conclusions.

Throughout this document we will use a number of expressions. These are as referred to in the glossary and have the same meaning as described in “Schedule 6 Interpretation” of the Permit.

We try to explain our decision as accurately, comprehensively and plainly as possible. We would welcome any feedback as to how we might improve our decision documents in future. A lot of technical terms and acronyms are inevitable in a document of this nature: we provide a glossary of acronyms near the front of the document, for ease of reference.

How this document is structured

Glossary of terms

- 1 Our decision
- 2 How we reached our decision
- 2.1 Requesting information to demonstrate compliance with BAT Conclusions for Large Combustion Plant
- 2.2 Review of our own information in respect to the capability of the installation to meet revised standards included in the BAT Conclusions document
- 3 The legal framework
- 4 Key Issues
- 5 Decision checklist regarding relevant BAT Conclusions
- 6 Review and assessment of derogation requests made by the operator in relation to BAT Conclusions which include an associated emission level (AEL) value
- 7 Emissions to Water
- 8 Additional IED Chapter II requirements
- 9 Review and assessment of changes that are not part of the BAT Conclusions derived permit review.

Glossary of acronyms used in this document

(Please note that this glossary is standard for our decision documents and therefore not all these acronyms are necessarily used in this document.)

APC	Air Pollution Control
BAT	Best Available Technique(s)
BAT-AEEL	BAT Associated Energy Efficiency Level
BAT-AEL	BAT Associated Emission Level
BATc	BAT conclusion
BREF	Best available techniques reference document
CCGT	Combined Cycle Gas Turbine
CEM	Continuous emissions monitor
CHP	Combined heat and power
CV	Calorific value
DAA	Directly associated activity – Additional activities necessary to be carried out to allow the principal activity to be carried out
DLN	Dry Low NOx burners
DLN-E	Dry Low NOx effective
EIONET	European environment information and observation network is a partnership network of the European Environment Agency
ELV	Emission limit value derived under BAT or an emission limit value set out in IED
EMS	Environmental Management System
EPR	Environmental Permitting (England and Wales) Regulations 2016 (SI 2016 No. 1154)
EWC	European waste catalogue
FSA	Food Standards Agency
IC	Improvement Condition
IED	Industrial Emissions Directive (2010/75/EU)
IPPCD	Integrated Pollution Prevention and Control Directive (2008/1/EC) – now superseded by IED
LCP	Large Combustion Plant subject to Chapter III of IED
MSUL/MSDL	Minimum start up load/minimum shut-down load
NOx	Oxides of nitrogen (NO plus NO ₂ expressed as NO ₂)
NPV	Net Present Value
PHE	Public Health England
SAC	Special Area of Conservation
SGN	Sector guidance note
TGN	Technical guidance note
TOC	Total Organic Carbon
WFD	Water Framework Directive (2000/60/EC)

1 Our decision

We have decided to issue the consolidated variation notice to the Operator. This will allow it to continue to operate the Installation, subject to the conditions in the consolidated variation notice.

We consider that, in reaching that decision, we have taken into account all relevant considerations and legal requirements and that the varied permit will ensure that a high level of protection is provided for the environment and human health.

The consolidated variation notice contains many conditions taken from our standard Environmental Permit template including the relevant Annexes. We developed these conditions in consultation with industry, having regard to the legal requirements of the Environmental Permitting Regulations and other relevant legislation. This document does not therefore include an explanation for these standard conditions. Where they are included in the Notice, we have considered the techniques identified by the operator for the operation of their installation, and have accepted that the details are sufficient and satisfactory to make those standard conditions appropriate. This document does, however, provide an explanation of our use of “tailor-made” or installation-specific conditions, or where our Permit template provides two or more options.

2 How we reached our decision

2.1 Requesting information to demonstrate compliance with BAT Conclusions for Large Combustion Plant

We issued a Notice under Regulation 61(1) of the Environmental Permitting (England and Wales) Regulations 2016 (a Regulation 61 Notice) on 1st May 2018 requiring the Operator to provide information to demonstrate how the operation of their installation currently meets, or will subsequently meet, the revised standards described in the large combustion plant BAT Conclusions document. The Notice also required that where the revised standards are not currently met, the operator should provide information that:

- Describes the techniques that will be implemented before 17th August 2021, which will then ensure that operations meet the revised standard, or
- Justifies why standards will not be met by 17th August 2021, and confirmation of the date when the operation of those processes will cease within the installation or an explanation of why the revised BAT standard is not applicable to those processes, or
- Justifies why an alternative technique will achieve the same level of environmental protection equivalent to the revised standard described in the BAT Conclusions.

Where the Operator proposed that they were not intending to meet a BAT standard that also included a BAT Associated Emission Level (BAT AEL) described in the BAT Conclusions Document, the Regulation 61 Notice requested that the Operator make a formal request for derogation from compliance with that AEL (as provisioned by Article 15(4) of IED). In this circumstance, the Notice identified that any such request for derogation must be supported and justified by sufficient technical and commercial information that would enable us to determine acceptability of the derogation request.

The Regulation 61 Notice response from the Operator was received on 13th October 2018.

We considered it was in the correct form and contained sufficient information for us to begin our determination of the permit review but not that it necessarily contained all the information we would need to complete that review.

2.2 Review of our own information in respect to the capability of the installation to meet revised standards included in the BAT Conclusions document

Based on our records and previous regulatory activities with the facility we have no reason to consider that the operator will not be able to comply with the conditions that we include in the permit.

3 The legal framework

The consolidated variation notice will be issued under Regulation 20 of the EPR. The Environmental Permitting regime is a legal vehicle which delivers most of the relevant legal requirements for activities falling within its scope. In particular, the regulated facility is:

- an *installation* as described by the IED;
- subject to aspects of other relevant legislation which also have to be addressed.

We consider that the consolidated variation notice will ensure that the operation of the Installation complies with all relevant legal requirements and that a high level of protection will be delivered for the environment and human health.

We explain how we have addressed specific statutory requirements more fully in the rest of this document.

4 The key issues

The key issues arising during this permit review are:

- Emissions to air and the emission limits applied to the plant.
- The energy efficiency levels associated with the Best Available Techniques (BAT-AEELs)

We therefore describe how we determined these issues in most detail in the relevant sections of this document.

4.1 Emissions to air and the emission limits applied to the plant

A number of general principles were applied during the permit review. These included:

- The upper value of the BAT AELs ranges specified were used unless use of the tighter limit was justified.
- The principle of no backsliding where if existing limits in the permit were already tighter than those specified in the BREF, the existing permit limits were retained.
- Where a limit was specified in both IED Annex V and the BAT Conclusions for a particular reference period, the tighter limit was applied and in the majority of cases this was from the BAT Conclusions.
- Where AELs are indicative in the BAT Conclusions, these were applied unless adequate justification was provided by the operator to demonstrate that an alternative limit was more appropriate.
- For gas turbines where the IED specified that limits applied over 70% load and the BAT Conclusions specified that AELs applied when dry low NO_x is effective (DLN-E), we have used DLN-E as a default across all monitoring requirements for NO_x and CO.

The LCPs on site are referenced LCP331 and LCP332.

Recent upgrade works on site resulted in the thermal input for each gas turbine increasing from 783.6MW_{th} to 838MW_{th} and the electrical output increasing from 860MW to 920MW which has been reflected in the permit. Both gas turbines were modified so that they can operated in low part load (LPL). The start up and shut down thresholds have also been updated to reflect these changes.

This is a combined cycle gas turbine (CCGT) combustion installation with the primary purpose of generating electricity for local use and the National Grid through combustion of natural gas. The plant has a nominal capacity of 920 MWe for export. The CCGT comprises two gas turbines with heat recovery steam generators that supply one steam turbine. Each Gas Turbine (GT) has

a net thermal input of 838MW_{th}. Two auxiliary boilers are installed to facilitate start up. These do not operate together but release through the same release point.

The plant was put into operation before IED came into force and therefore the existing limits in the permit are from Part 1 of IED Annex V applicable to existing plant.

The ELVs and AELs are based on the following operating regime:

- Unlimited hours operation

The following tables outline the limits that have been incorporated into the permit for LCP331 and LCP332, where these were derived from and the reference periods at which they apply. The emission limits refer to concentrations, expressed as mass of emitted substance per volume of flue-gas under the following standard conditions: dry gas at a temperature of 273,15 K, pressure of 101,3 kPa and 15% volume reference oxygen concentration if flue gases. The emission limits and monitoring requirements have been incorporated into Schedule 3 of the permit.

NOx limits (mg/Nm ³)						
Averaging	IED (Annex V Part 1) - Existing	BREF (Table 24 BAT-c)	Expected permit limits	Basis	Limits apply	Monitoring
Annual	None	40	40	BREF	DLN effective to baseload	Continuous
Monthly	50	None	50	IED	DLN effective to baseload	
Daily	55	50	50	BREF	DLN effective to baseload	
95 th %ile of hr means	100	None	90 (existing limit in permit)	Existing limit tighter than IED	DLN effective to baseload	

CO limits (mg/Nm ³)						
Averaging	IED (Annex V Part 1) - Existing	BREF	Expected permit limits	Basis	Limits apply	Monitoring
Annual	None	30	30	BREF	DLN effective to baseload	Continuous
Monthly	100	None	45 (existing permit limit)	Existing limit tighter than IED	DLN effective to baseload	
Daily	110	50	50	BREF	DLN effective to baseload	
95 th %ile of hr means	200	None	50 (existing permit limit)	Existing limit tighter than IED	DLN effective to baseload	

An additional daily limit from start up/shut down to baseload has been added to the limits in table S3.1a. Although this is not a regulatory requirement, it was requested by the Emissions Methodology Working Group of the Joint Environmental Protocol to ensure consistency across the sites. We have included a corresponding footnote.

4.2 The energy efficiency levels associated with the Best Available Techniques Conclusions

An energy efficiency level associated with the best available techniques (BAT-AEEL) refers to the ratio between the combustion unit's net energy output(s) and the combustion unit's fuel/feedstock energy input at actual unit design. The net energy output(s) is determined at the combustion unit boundaries, including auxiliary systems (e.g. flue-gas treatment systems), and for the unit operated at full load.

The table below sets out the BAT-AEELs specified in the LCP BAT Conclusions for the large combustion plant on the site and the energy efficiency levels confirmed through the Regulation 61 notice response. The operator confirmed that a performance test was undertaken in February 2019 on completion of a major outage, giving an efficiency of 50.6%. The test was done in accordance with 'ASME PTC 46 test code Performance Test Code on Overall Plant Performance'. We consider this plant is BAT in relation to the AEELs.

BAT AEELs (%)			Plant efficiency (%)		
Net electrical efficiency	Net total fuel utilisation	Net mechanical efficiency	Net electrical efficiency	Net total fuel utilisation	Net mechanical efficiency
LCP331: Combined Cycle Gas Turbine ≥600MWth					
50 - 60	None	None	50.6	NA	NA
LCP332: Combined Cycle Gas Turbine ≥600MWth					
50 - 60	None	None	50.6	NA	NA

5 Decision checklist regarding relevant BAT Conclusions

BAT Conclusions for large combustion plant, were published by the European Commission on 17th August 2017. There are 75 BAT Conclusions. Only the BAT Conclusions relevant to the particular fuel type used on site have been replicated below.

This annex provides a record of decisions made in relation to each relevant BAT Conclusion applicable to the installation. This annex should be read in conjunction with the Consolidated Variation Notice.

The conditions in the permit through which the relevant BAT Conclusions are implemented include but are not limited to the following:

BAT Conclusion requirement topic	Permit condition(s)	Permit table(s)
Environmental Management System	1.1.1	S1.2
BAT AELs	3.1.1 and 3.5.1	S3.1a
Monitoring	2.3, 3.5 and 3.6	S1.4, S1.5, S1.2, S3.1a
Energy efficiency	1.2 and 2.3	S3.4
Noise	3.4 and 2.3	S1.2
Other operating techniques	2.3	S1.2

The overall status of compliance with the BAT conclusion is indicated in the table as:

- NA Not Applicable
- CC Currently Compliant
- FC Compliant in the future (within 4 years of publication of BAT conclusions)
- NC Not Compliant
- PC Partially Compliant

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
General			
1	<p>In order to improve the overall environmental performance, BAT is to implement and adhere to an environmental management system (EMS) that incorporates all of the following features:</p> <ul style="list-style-type: none"> i. commitment of the management, including senior management; ii. definition of an environmental policy that includes the continuous improvement of the installation by the management; iii. planning and establishing the necessary procedures, objectives and targets, in conjunction with financial planning and investment; iv. implementation of procedures <ul style="list-style-type: none"> (a) Structure and responsibility (b) Training (c) Communication (d) Employee involvement (e) Documentation (f) Efficient process control (g) Maintenance programmes (h) Emergency preparedness and response (i) Safeguarding compliance with environmental legislation v. checking performance and taking corrective action, paying particular attention to: <ul style="list-style-type: none"> (a) monitoring and measurement (see also the Reference Document on the General Principles of Monitoring) (b) corrective and preventive action (c) maintenance of records (d) independent (where practicable) internal and external auditing in order to determine whether or not the EMS conforms to planned arrangements and has been properly implemented and maintained; vi. review of the EMS and its continuing suitability, adequacy and effectiveness by senior management; vii. following the development of cleaner technologies; viii. consideration for the environmental impacts from the eventual decommissioning of the installation at the stage of designing a new plant, and throughout its operating life; viii. consideration for the environmental impacts from the eventual decommissioning of the installation at the stage of designing a new plant, and throughout its operating life; ix. application of sectoral benchmarking on a regular basis. <p>Etc - see BAT Conclusions</p>	CC	There is an EMS operated in accordance with the requirements of ISO 14001 standard in place and it meets requirements (i) through to (xvi) set out in the BAT Conclusion

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement															
	<p>Applicability. The scope (e.g. level of detail) and nature of the EMS (e.g. standardised or non-standardised) will generally be related to the nature, scale and complexity of the installation, and the range of environmental impacts it may have.</p>																	
2	<p>BAT is to determine the net electrical efficiency and/or the net total fuel utilisation and/or the net mechanical energy efficiency of the gasification, IGCC and/or combustion units by carrying out a performance test at full load (1), according to EN standards, after the commissioning of the unit and after each modification that could significantly affect the net electrical efficiency and/or the net total fuel utilisation and/or the net mechanical energy efficiency of the unit. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.</p>	CC	<p>Performance tests are carried out by an InterGen Performance Engineer following every major overhaul or plant upgrade in line with an InterGen corporate procedure.</p> <p>A performance test was undertaken in February 2019 on completion of the major outage, giving an efficiency of 50.6%. The test was done in accordance with 'ASME PTC 46 test code Performance Test Code on Overall Plant Performance'.</p>															
3	<p>BAT is to monitor key process parameters relevant for emissions to air and water including those given below.</p> <table border="1" data-bbox="322 946 1496 1121"> <thead> <tr> <th data-bbox="322 946 687 979">Stream</th> <th data-bbox="687 946 1124 979">Parameter(s)</th> <th data-bbox="1124 946 1496 979">Monitoring</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 979 687 1013">Flue-gas</td> <td data-bbox="687 979 1124 1013">Flow</td> <td data-bbox="1124 979 1496 1013">Periodic or continuous determination</td> </tr> <tr> <td data-bbox="322 1013 687 1046"></td> <td data-bbox="687 1013 1124 1046">Oxygen content, temperature, and pressure</td> <td data-bbox="1124 1013 1496 1046">Periodic or continuous measurement</td> </tr> <tr> <td data-bbox="322 1046 687 1080"></td> <td data-bbox="687 1046 1124 1080">Water vapour content (%)</td> <td data-bbox="1124 1046 1496 1080"></td> </tr> <tr> <td data-bbox="322 1080 687 1114">Waste water from flue-gastreatment</td> <td data-bbox="687 1080 1124 1114">Flow, pH, and temperature</td> <td data-bbox="1124 1080 1496 1114">Continuous measurement</td> </tr> </tbody> </table>	Stream	Parameter(s)	Monitoring	Flue-gas	Flow	Periodic or continuous determination		Oxygen content, temperature, and pressure	Periodic or continuous measurement		Water vapour content (%)		Waste water from flue-gastreatment	Flow, pH, and temperature	Continuous measurement	CC	<p>All relevant flue gas parameters are monitored/calculated continuously. There is no flue gas treatment.</p>
Stream	Parameter(s)	Monitoring																
Flue-gas	Flow	Periodic or continuous determination																
	Oxygen content, temperature, and pressure	Periodic or continuous measurement																
	Water vapour content (%)																	
Waste water from flue-gastreatment	Flow, pH, and temperature	Continuous measurement																
4	<p>BAT is to monitor emissions to air with at least the frequency given below and in accordance with EN standards. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.</p> <table border="1" data-bbox="322 1222 1496 1342"> <thead> <tr> <th data-bbox="322 1222 474 1342">Substance/Parameter</th> <th data-bbox="474 1222 790 1342">Fuel/Process/Type of combustion plant</th> <th data-bbox="790 1222 947 1342">Combustion plant total rated thermal input</th> <th data-bbox="947 1222 1124 1342">Standard(s) (1)</th> <th data-bbox="1124 1222 1344 1342">Minimum monitoring frequency (2)</th> <th data-bbox="1344 1222 1496 1342">Monitoring associated with</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 1342 474 1347"></td> <td data-bbox="474 1342 790 1347"></td> <td data-bbox="790 1342 947 1347"></td> <td data-bbox="947 1342 1124 1347"></td> <td data-bbox="1124 1342 1344 1347"></td> <td data-bbox="1344 1342 1496 1347"></td> </tr> </tbody> </table>	Substance/Parameter	Fuel/Process/Type of combustion plant	Combustion plant total rated thermal input	Standard(s) (1)	Minimum monitoring frequency (2)	Monitoring associated with							CC	<p>For each unit NOx and CO are continuously monitored. The monitoring frequency and standard utilised meet those required by, BAT 4, BAT 42 and BAT 44.</p>			
Substance/Parameter	Fuel/Process/Type of combustion plant	Combustion plant total rated thermal input	Standard(s) (1)	Minimum monitoring frequency (2)	Monitoring associated with													

BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	NH ₃	— When SCR and/or SNCR is used	All sizes	Generic EN standards	Continuous <u>(⁽⁶⁾)</u> <u>(⁽⁷⁾)</u>	BAT 7		
	NO _x	<ul style="list-style-type: none"> — Coal and/or lignite including waste co-incineration — Solid biomass and/or peat including waste co-incineration — HFO- and/or gas-oil-fired boilers and engines — Gas-oil-fired gas turbines — Natural-gas-fired boilers, engines, and turbines — Iron and steel process gases — Process fuels from the chemical industry — IGCC plants 	All sizes	Generic EN standards	Continuous <u>(⁽⁶⁾)</u> <u>(⁽⁸⁾)</u>	BAT 20 BAT 24 BAT 28 BAT 32 BAT 37 BAT 41 BAT 42 BAT 43 BAT 47 BAT 48 BAT 56 BAT 64 BAT 65 BAT 73		
		— Combustion plants on offshore platforms	All sizes	EN 14792	Once every year <u>(⁽⁶⁾)</u>	BAT 53		
	CO	<ul style="list-style-type: none"> — Coal and/or lignite including waste co-incineration — Solid biomass and/or peat including waste co-incineration — HFO- and/or gas-oil-fired boilers and engines — Gas-oil-fired gas turbines — Natural-gas-fired boilers, engines, and turbines — Iron and steel process gases — Process fuels from the chemical industry 	All sizes	Generic EN standards	Continuous <u>(⁽⁶⁾)</u> <u>(⁽⁸⁾)</u>	BAT 20 BAT 24 BAT 28 BAT 33 BAT 38 BAT 44 BAT 49 BAT 56 BAT 64 BAT 65 BAT 73		

BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement						
		— IGCC plants												
		— Combustion plants on offshore platforms	All sizes	EN 15058	Once every year ⁽¹⁾	BAT 54								
	SO ₂	<ul style="list-style-type: none"> — Coal and/or lignite incl waste co-incineration — Solid biomass and/or peat incl waste co-incineration — HFO- and/or gas-oil-fired boilers — HFO- and/or gas-oil-fired engines — Gas-oil-fired gas turbines — Iron and steel process gases — Process fuels from the chemical industry in boilers — IGCC plants 	All sizes	Generic EN standards and EN 14791	Continuous ⁽¹⁾ ⁽¹¹⁾ ⁽¹²⁾	BAT 21 BAT 25 BAT 29 BAT 34 BAT 39 BAT 50 BAT 57 BAT 66 BAT 67 BAT 74								
	SO ₃	— When SCR is used	All sizes	No EN standard available	Once every year	—								
5	BAT is to monitor emissions to water from flue-gas treatment with at least the frequency given in BAT 5 and in accordance with EN standards. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.						NA	Not Applicable, no flue gas treatment						
6	In order to improve the general environmental performance of combustion plants and to reduce emissions to air of CO and unburnt substances, BAT is to ensure optimised combustion and to use an appropriate combination of the techniques given below.						CC	The following techniques from BAT 6 are applied: b - maintenance of the combustion system c - advanced control system d - combustion equipment design e - low sulphur natural gas						
		<table border="1"> <thead> <tr> <th data-bbox="555 1193 792 1230">Technique</th> <th data-bbox="792 1193 999 1230">Description</th> <th data-bbox="999 1193 1509 1230">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="555 1230 792 1329">a. Fuel blending and mixing</td> <td data-bbox="792 1230 999 1329">Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type</td> <td data-bbox="999 1230 1509 1329">Generally applicable</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Fuel blending and mixing	Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type	Generally applicable						
Technique	Description	Applicability												
a. Fuel blending and mixing	Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type	Generally applicable												

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement															
	<table border="1"> <tr> <td data-bbox="338 392 371 480">b.</td> <td data-bbox="371 392 557 480">Maintenance of the combustion system</td> <td data-bbox="557 392 996 480">Regular planned maintenance according to suppliers' recommendations</td> <td data-bbox="996 392 1491 480"></td> </tr> <tr> <td data-bbox="338 480 371 560">c.</td> <td data-bbox="371 480 557 560">Advanced control system</td> <td data-bbox="557 480 996 560">See description in Section 8.1</td> <td data-bbox="996 480 1491 560">The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> <tr> <td data-bbox="338 560 371 639">d.</td> <td data-bbox="371 560 557 639">Good design of the combustion equipment</td> <td data-bbox="557 560 996 639">Good design of furnace, combustion chambers, burners and associated devices</td> <td data-bbox="996 560 1491 639">Generally applicable to new combustion plants</td> </tr> <tr> <td data-bbox="338 639 371 882">e.</td> <td data-bbox="371 639 557 882">Fuel choice</td> <td data-bbox="557 639 996 882">Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used</td> <td data-bbox="996 639 1491 882">Applicable within the constraints associated with the availability of suitable types of fuel with a better environmental profile as a whole, which may be impacted by the energy policy of the Member State, or by the integrated site's fuel balance in the case of combustion of industrial process fuels. For existing combustion plants, the type of fuel chosen may be limited by the configuration and the design of the plant</td> </tr> </table>	b.	Maintenance of the combustion system	Regular planned maintenance according to suppliers' recommendations		c.	Advanced control system	See description in Section 8.1	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system	d.	Good design of the combustion equipment	Good design of furnace, combustion chambers, burners and associated devices	Generally applicable to new combustion plants	e.	Fuel choice	Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used	Applicable within the constraints associated with the availability of suitable types of fuel with a better environmental profile as a whole, which may be impacted by the energy policy of the Member State, or by the integrated site's fuel balance in the case of combustion of industrial process fuels. For existing combustion plants, the type of fuel chosen may be limited by the configuration and the design of the plant			
b.	Maintenance of the combustion system	Regular planned maintenance according to suppliers' recommendations																		
c.	Advanced control system	See description in Section 8.1	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system																	
d.	Good design of the combustion equipment	Good design of furnace, combustion chambers, burners and associated devices	Generally applicable to new combustion plants																	
e.	Fuel choice	Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used	Applicable within the constraints associated with the availability of suitable types of fuel with a better environmental profile as a whole, which may be impacted by the energy policy of the Member State, or by the integrated site's fuel balance in the case of combustion of industrial process fuels. For existing combustion plants, the type of fuel chosen may be limited by the configuration and the design of the plant																	
7	<p>In order to reduce emissions of ammonia to air from the use of selective catalytic reduction (SCR) and/or selective non-catalytic reduction (SNCR) for the abatement of NO_x emissions, BAT is to optimise the design and/or operation of SCR and/or SNCR (e.g. optimised reagent to NO_x ratio, homogeneous reagent distribution and optimum size of the reagent drops).</p> <p>BAT-associated emission levels</p> <p>The BAT-associated emission level (BAT-AEL) for emissions of NH₃ to air from the use of SCR and/or SNCR is < 3–10 mg/Nm³ as a yearly average or average over the sampling period. The lower end of the range can be achieved when using SCR and the upper end of the range can be achieved when using SNCR without wet abatement techniques. In the case of plants combusting biomass and operating at variable loads as well as in the case of engines combusting HFO and/or gas oil, the higher end of the BAT-AEL range is 15 mg/Nm³.</p>			NA	Not Applicable, no SCR or SNCR fitted.															
8	<p>In order to prevent or reduce emissions to air during normal operating conditions, BAT is to ensure, by appropriate design, operation and maintenance, that the emission abatement systems are used at optimal capacity and availability.</p>			CC	Design of gas turbine utilises DLN burners to ensure that emissions to air are maintained within permit requirements. Maintenance is undertaken in accordance with OEM (original equipment															

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement				
			manufacturer) guidelines to ensure that turbine efficiency and emissions limits are maintained.				
9	<p>In order to improve the general environmental performance of combustion and/or gasification plants and to reduce emissions to air, BAT is to include the following elements in the quality assurance/quality control programmes for all the fuels used, as part of the environmental management system (see BAT 1):</p> <ul style="list-style-type: none"> (i) Initial full characterisation of the fuel used including at least the parameters listed below and in accordance with EN standards. ISO, national or other international standards may be used provided they ensure the provision of data of an equivalent scientific quality; (ii) Regular testing of the fuel quality to check that it is consistent with the initial characterisation and according to the plant design specifications. The frequency of testing and the parameters chosen from the table below are based on the variability of the fuel and an assessment of the relevance of pollutant releases (e.g. concentration in fuel, flue-gas treatment employed); (iii) Subsequent adjustment of the plant settings as and when needed and practicable (e.g. integration of the fuel characterisation and control in the advanced control system (see description in Section 8.1)). <p>Description Initial characterisation and regular testing of the fuel can be performed by the operator and/or the fuel supplier. If performed by the supplier, the full results are provided to the operator in the form of a product (fuel) supplier specification and/or guarantee.</p> <table border="1" data-bbox="322 938 1496 1056"> <thead> <tr> <th data-bbox="322 938 712 973">Fuel(s)</th> <th data-bbox="712 938 1496 973">Substances/Parameters subject to characterisation</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 973 712 1056">Natural gas</td> <td data-bbox="712 973 1496 1056"> <ul style="list-style-type: none"> — LHV — CH₄, C₂H₆, C₃, C₄₊, CO₂, N₂, Wobbe index </td> </tr> </tbody> </table>	Fuel(s)	Substances/Parameters subject to characterisation	Natural gas	<ul style="list-style-type: none"> — LHV — CH₄, C₂H₆, C₃, C₄₊, CO₂, N₂, Wobbe index 	CC	<p>We consider that for plants which burn natural gas from the National Grid as a fuel that it is not necessary for the operator to replicate the testing carried out by the National Grid.</p> <p>However, the operator did provide the following as part of their Regulation 61 response: The site has an online gas chromatograph which monitors all relevant constituents of the gas. Tuning of the advanced control system is carried out as required</p>
Fuel(s)	Substances/Parameters subject to characterisation						
Natural gas	<ul style="list-style-type: none"> — LHV — CH₄, C₂H₆, C₃, C₄₊, CO₂, N₂, Wobbe index 						
10	<p>In order to reduce emissions to air and/or to water during other than normal operating conditions (OTNOC), BAT is to set up and implement a management plan as part of the environmental management system (see BAT 1), commensurate with the relevance of potential pollutant releases, that includes the following elements:</p> <ul style="list-style-type: none"> — appropriate design of the systems considered relevant in causing OTNOC that may have an impact on emissions to air, water and/or soil (e.g. low-load design concepts for reducing the minimum start-up and shutdown loads for stable generation in gas turbines), — set-up and implementation of a specific preventive maintenance plan for these relevant systems, — review and recording of emissions caused by OTNOC and associated circumstances and implementation of corrective actions if necessary, 	CC	A Low part load upgrade fitted to both units during the 2018 major outage enables the turbines to be operated at lower loads without any adverse impact on emissions to air. Emissions to water/soil are not impacted during periods of operation OTNOC				

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																					
	— periodic assessment of the overall emissions during OTNOC (e.g. frequency of events, duration, emissions quantification/estimation) and implementation of corrective actions if necessary.																							
11	<p>BAT is to appropriately monitor emissions to air and/or to water during OTNOC.</p> <p>Description The monitoring can be carried out by direct measurement of emissions or by monitoring of surrogate parameters if this proves to be of equal or better scientific quality than the direct measurement of emissions. Emissions during start-up and shutdown (SU/SD) may be assessed based on a detailed emission measurement carried out for a typical SU/SD procedure at least once every year, and using the results of this measurement to estimate the emissions for each and every SU/SD throughout the year.</p>	CC	All flue gas relevant parameters are monitored/ determined continuously during periods of operation OTNOC including start ups/ shut downs																					
12	<p>In order to increase the energy efficiency of combustion, gasification and/or IGCC units operated $\geq 1\,500$ h/yr, BAT is to use an appropriate combination of the techniques given below.</p> <table border="1" data-bbox="322 730 1496 1342"> <thead> <tr> <th data-bbox="322 730 577 762">Technique</th> <th data-bbox="577 730 1057 762">Description</th> <th data-bbox="1057 730 1496 762">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 762 367 874">a.</td> <td data-bbox="367 762 577 874">Combustion optimisation</td> <td data-bbox="577 762 1057 874">See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues</td> </tr> <tr> <td data-bbox="322 874 367 1007">b.</td> <td data-bbox="367 874 577 1007">Optimisation of the working medium conditions</td> <td data-bbox="577 874 1057 1007">Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO_x emissions or the characteristics of energy demanded</td> </tr> <tr> <td data-bbox="322 1007 367 1118">c.</td> <td data-bbox="367 1007 577 1118">Optimisation of the steam cycle</td> <td data-bbox="577 1007 1057 1118">Operate with lower turbine exhaust pressure by utilisation of the lowest possible temperature of the condenser cooling water, within the design conditions</td> </tr> <tr> <td data-bbox="322 1118 367 1177">d.</td> <td data-bbox="367 1118 577 1177">Minimisation of energy consumption</td> <td data-bbox="577 1118 1057 1177">Minimising the internal energy consumption (e.g. greater efficiency of the feed-water pump)</td> </tr> <tr> <td data-bbox="322 1177 367 1262">e.</td> <td data-bbox="367 1177 577 1262">Preheating of combustion air</td> <td data-bbox="577 1177 1057 1262">Reuse of part of the heat recovered from the combustion flue-gas to preheat the air used in combustion</td> </tr> <tr> <td data-bbox="322 1262 367 1342">f.</td> <td data-bbox="367 1262 577 1342">Fuel preheating</td> <td data-bbox="577 1262 1057 1342">Preheating of fuel using recovered heat</td> </tr> </tbody> </table>	Technique	Description	Applicability	a.	Combustion optimisation	See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues	b.	Optimisation of the working medium conditions	Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO _x emissions or the characteristics of energy demanded	c.	Optimisation of the steam cycle	Operate with lower turbine exhaust pressure by utilisation of the lowest possible temperature of the condenser cooling water, within the design conditions	d.	Minimisation of energy consumption	Minimising the internal energy consumption (e.g. greater efficiency of the feed-water pump)	e.	Preheating of combustion air	Reuse of part of the heat recovered from the combustion flue-gas to preheat the air used in combustion	f.	Fuel preheating	Preheating of fuel using recovered heat	CC	<p>A. Use of a high performance monitoring and an advanced combustion optimisation system.</p> <p>B. Operation at the highest possible temperatures & pressures giving due regard to NO_x emissions.</p> <p>C. Equipment utilises an air cooled condenser under vacuum to optimise steam turbine efficiency</p> <p>D. Utilisation of variable speed drives where feasible.</p> <p>E. Not Applicable to Gas Turbine Plant</p> <p>F. Preheating with heat recovered from feed water/steam is utilised</p> <p>G. GT utilises a computer based control system incorporating high performance monitoring</p> <p>H. HRSG is fitted with feed water heaters/economisers.</p> <p>I. CHP Not Applicable due to age of plant and local constraints</p>
Technique	Description	Applicability																						
a.	Combustion optimisation	See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues																						
b.	Optimisation of the working medium conditions	Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO _x emissions or the characteristics of energy demanded																						
c.	Optimisation of the steam cycle	Operate with lower turbine exhaust pressure by utilisation of the lowest possible temperature of the condenser cooling water, within the design conditions																						
d.	Minimisation of energy consumption	Minimising the internal energy consumption (e.g. greater efficiency of the feed-water pump)																						
e.	Preheating of combustion air	Reuse of part of the heat recovered from the combustion flue-gas to preheat the air used in combustion																						
f.	Fuel preheating	Preheating of fuel using recovered heat																						

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	g.	Advanced control system	See description in Section 8.2. Computerised control of the main combustion parameters enables the combustion efficiency to be improved	Generally applicable to new units. The applicability to old units may be constrained by the need to retrofit the combustion system and/or control command system	<p>J. CHP Not Applicable due to age of plant and local constraints</p> <p>K. CHP Not Applicable due to age of plant and local constraints.</p> <p>L. CHP Not Applicable due to age of plant and local constraints.</p> <p>M. Not Applicable no FGD.</p> <p>N. Not Applicable no FGD</p> <p>O. Not Applicable Natural Gas Fuelled</p> <p>P. Not Applicable Natural Gas Fuelled</p> <p>Q. 'F' Class GT utilising high temperature materials</p> <p>R. High Temperature (565C) and Pressure (1600 psi) steam used</p> <p>S. Not Applicable to Gas Turbine</p>
h.	Feed-water preheating using recovered heat	Preheat water coming out of the steam condenser with recovered heat, before reusing it in the boiler	Only applicable to steam circuits and not to hot boilers. Applicability to existing units may be limited due to constraints associated with the plant configuration and the amount of recoverable heat		
i.	Heat recovery by cogeneration (CHP)	Recovery of heat (mainly from the steam system) for producing hot water/steam to be used in industrial processes/activities or in a public network for district heating. Additional heat recovery is possible from: <ul style="list-style-type: none"> — flue-gas — grate cooling — circulating fluidised bed 	Applicable within the constraints associated with the local heat and power demand. The applicability may be limited in the case of gas compressors with an unpredictable operational heat profile		
j.	CHP readiness	See description in Section 8.2.	Only applicable to new units where there is a realistic potential for the future use of heat in the vicinity of the unit		
k.	Flue-gas condenser	See description in Section 8.2.	Generally applicable to CHP units provided there is enough demand for low-temperature heat		
l.	Heat accumulation	Heat accumulation storage in CHP mode	Only applicable to CHP plants. The applicability may be limited in the case of low heat load demand		
m.	Wet stack	See description in Section 8.2.	Generally applicable to new and existing units fitted with wet FGD		
n.	Cooling tower discharge	The release of emissions to air through a cooling tower and not via a dedicated stack	Only applicable to units fitted with wet FGD where reheating of the flue-gas is necessary before release, and where the unit cooling system is a cooling tower		
o.	Fuel pre-drying	The reduction of fuel moisture content before combustion to improve combustion conditions	Applicable to the combustion of biomass and/or peat within the constraints associated		

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	
				<p>with spontaneous combustion risks (e.g. the moisture content of peat is kept above 40 % throughout the delivery chain). The retrofit of existing plants may be restricted by the extra calorific value that can be obtained from the drying operation and by the limited retrofit possibilities offered by some boiler designs or plant configurations</p>		
	p.	Minimisation of heat losses	Minimising residual heat losses, e.g. those that occur via the slag or those that can be reduced by insulating radiating sources	Only applicable to solid-fuel-fired combustion units and to gasification/IGCC units		
	q.	Advanced materials	Use of advanced materials proven to be capable of withstanding high operating temperatures and pressures and thus to achieve increased steam/combustion process efficiencies	Only applicable to new plants		
	r.	Steam turbine upgrades	This includes techniques such as increasing the temperature and pressure of medium-pressure steam, addition of a low-pressure turbine, and modifications to the geometry of the turbine rotor blades	The applicability may be restricted by demand, steam conditions and/or limited plant lifetime		
	s.	Supercritical and ultra-supercritical steam conditions	Use of a steam circuit, including steam reheating systems, in which steam can reach pressures above 220,6 bar and temperatures above 374 °C in the case of supercritical conditions, and above 250 – 300 bar and temperatures above 580 – 600 °C in the case of ultra-supercritical conditions	Only applicable to new units of $\geq 600 \text{ MW}_{\text{th}}$ operated $> 4\,000 \text{ h/yr}$. Not applicable when the purpose of the unit is to produce low steam temperatures and/or pressures in process industries. Not applicable to gas turbines and engines generating steam in CHP mode. For units combusting biomass, the applicability may be constrained by high-temperature corrosion in the case of certain biomasses		
13	In order to reduce water usage and the volume of contaminated wastewater discharged, BAT is to use one or both of the techniques given below.			CC	Process waste to sewer and surface water to water course – streams kept separate to minimise volumes of contaminated water. No bottom ash.	
Technique		Description				Applicability
a.	Water recycling	Residual aqueous streams, including run-off water, from the plant are reused for other purposes. The degree of				Not applicable to waste water from cooling systems when water treatment chemicals

BAT Concn. Number	Summary of BAT Conclusion requirement				Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement						
		recycling is limited by the quality requirements of the recipient water stream and the water balance of the plant	and/or high concentrations of salts from seawater are present									
	b. Dry bottom ash handling	Dry, hot bottom ash falls from the furnace onto a mechanical conveyor system and is cooled down by ambient air. No water is used in the process.	Only applicable to plants combusting solid fuels. There may be technical restrictions that prevent retrofitting to existing combustion plants									
14	<p>In order to prevent the contamination of uncontaminated waste water and to reduce emissions to water, BAT is to segregate waste water streams and to treat them separately, depending on the pollutant content.</p> <p>Description Waste water streams that are typically segregated and treated include surface run-off water, cooling water, and waste water from flue-gas treatment.</p> <p>Applicability The applicability may be restricted in the case of existing plants due to the configuration of the drainage systems.</p>				CC	See BAT 13 above.						
15	<p>In order to reduce emissions to water from flue-gas treatment, BAT is to use an appropriate combination of the techniques given in BAT 15, and to use secondary techniques as close as possible to the source in order to avoid dilution.</p> <p>The BAT-AELs are listed in BAT 15 and refer to direct discharges to a receiving water body at the point where the emission leaves the installation.</p>				NA	No flue gas treatment.						
16	<p>In order to reduce the quantity of waste sent for disposal from the combustion and/or gasification process and abatement techniques, BAT is to organise operations so as to maximise, in order of priority and taking into account life-cycle thinking:</p> <p>(a) waste prevention, e.g. maximise the proportion of residues which arise as by-products;</p> <p>(b) waste preparation for reuse, e.g. according to the specific requested quality criteria;</p> <p>(c) waste recycling;</p> <p>(d) other waste recovery (e.g. energy recovery),</p> <p>by implementing an appropriate combination of techniques such as:</p> <table border="1" data-bbox="322 1257 1503 1377"> <thead> <tr> <th data-bbox="322 1257 573 1294">Technique</th> <th data-bbox="580 1257 1084 1294">Description</th> <th data-bbox="1090 1257 1503 1294">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 1299 573 1377">a. Generation of gypsum as a by-product</td> <td data-bbox="580 1299 1084 1377">Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g. as</td> <td data-bbox="1090 1299 1503 1377">Generally applicable within the constraints associated with the required gypsum quality, the health requirements</td> </tr> </tbody> </table>				Technique	Description	Applicability	a. Generation of gypsum as a by-product	Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g. as	Generally applicable within the constraints associated with the required gypsum quality, the health requirements	CC	No option for use of techniques a – d. Very little waste produced on site. Permit already specifies condition to ensure waste hierarchy is followed.
Technique	Description	Applicability										
a. Generation of gypsum as a by-product	Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g. as	Generally applicable within the constraints associated with the required gypsum quality, the health requirements										

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
		raw material in the plasterboard industry). The quality of limestone used in the wet FGD influences the purity of the gypsum produced	associated to each specific use, and by the market conditions		
	b. Recycling or recovery of residues in the construction sector	Recycling or recovery of residues (e.g. from semi-dry desulphurisation processes, fly ash, bottom ash) as a construction material (e.g. in road building, to replace sand in concrete production, or in the cement industry)	Generally applicable within the constraints associated with the required material quality (e.g. physical properties, content of harmful substances) associated to each specific use, and by the market conditions		
	c. Energy recovery by using waste in the fuel mix	The residual energy content of carbon-rich ash and sludges generated by the combustion of coal, lignite, heavy fuel oil, peat or biomass can be recovered for example by mixing with the fuel	Generally applicable where plants can accept waste in the fuel mix and are technically able to feed the fuels into the combustion chamber		
	d. Preparation of spent catalyst for reuse	Preparation of catalyst for reuse (e.g. up to four times for SCR catalysts) restores some or all of the original performance, extending the service life of the catalyst to several decades. Preparation of spent catalyst for reuse is integrated in a catalyst management scheme	The applicability may be limited by the mechanical condition of the catalyst and the required performance with respect to controlling NO _x and NH ₃ emissions		
17	In order to reduce noise emissions, BAT is to use one or a combination of the techniques given below .			CC	a. routine maintenance carried out in line with OEM requirements, closing doors and windows, equipment operated by experience staff. b. low noise fans installed on external equipment c. main part of site is inside a building. Embankments on parts of site d. main part of site is inside a building e. main part of site is inside a building
	Technique	Description			
a.	Operational measures	These include: <ul style="list-style-type: none"> — improved inspection and maintenance of equipment — closing of doors and windows of enclosed areas, if possible — equipment operated by experienced staff — avoidance of noisy activities at night, if possible — provisions for noise control during maintenance activities 	Generally applicable		
b.	Low-noise equipment	This potentially includes compressors, pumps and disks	Generally applicable when the equipment is new or replaced		
c.	Noise attenuation	Noise propagation can be reduced by inserting obstacles between the emitter and the receiver.	Generally applicable to new plants. In the case of existing plants, the insertion		

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																										
		Appropriate obstacles include protection walls, embankments and buildings	of obstacles may be restricted by lack of space																												
	d. Noise-control equipment	This includes: — noise-reducers — equipment insulation — enclosure of noisy equipment — soundproofing of buildings	The applicability may be restricted by lack of space																												
	e. Appropriate location of equipment and buildings	Noise levels can be reduced by increasing the distance between the emitter and the receiver and by using buildings as noise screens	Generally applicable to new plant																												
Combustion of gaseous fuels																															
40	In order to increase the energy efficiency of natural gas combustion, BAT is to use an appropriate combination of the techniques given in BAT 12 and below.			CC	Methods identified in BAT 12 utilised on a Combined Cycle Power Station, 2 gas turbine units with HRSGs to convert flue gas heat into steam for use in a steam turbine. Electrical efficiency has been confirmed to be 50.6% by the operator, this is within the BAT-AEEL range for this type of plant.																										
<table border="1"> <thead> <tr> <th data-bbox="322 826 501 863">Technique</th> <th data-bbox="501 826 725 863">Description</th> <th data-bbox="725 826 1496 863">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 863 501 1075">a. Combined cycle</td> <td data-bbox="501 863 725 1075">See description in Section 8.2</td> <td data-bbox="725 863 1496 1075">Generally applicable to new gas turbines and engines except when operated < 1 500 h/yr. Applicable to existing gas turbines and engines within the constraints associated with the steam cycle design and the space availability. Not applicable to existing gas turbines and engines operated < 1 500 h/yr. Not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns. Not applicable to boilers</td> </tr> </tbody> </table>						Technique	Description	Applicability	a. Combined cycle	See description in Section 8.2	Generally applicable to new gas turbines and engines except when operated < 1 500 h/yr. Applicable to existing gas turbines and engines within the constraints associated with the steam cycle design and the space availability. Not applicable to existing gas turbines and engines operated < 1 500 h/yr. Not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns. Not applicable to boilers																				
Technique	Description	Applicability																													
a. Combined cycle	See description in Section 8.2	Generally applicable to new gas turbines and engines except when operated < 1 500 h/yr. Applicable to existing gas turbines and engines within the constraints associated with the steam cycle design and the space availability. Not applicable to existing gas turbines and engines operated < 1 500 h/yr. Not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns. Not applicable to boilers																													
<p>BAT-associated energy efficiency levels (BAT-AEELs) for the combustion of natural gas</p> <table border="1"> <thead> <tr> <th data-bbox="322 1102 591 1139" rowspan="3">Type of combustion unit</th> <th colspan="4" data-bbox="591 1102 1496 1139">BAT-AEELs ⁽¹³⁶⁾ ⁽¹³⁷⁾</th> </tr> <tr> <th colspan="2" data-bbox="591 1139 853 1198">Net electrical efficiency (%)</th> <th data-bbox="853 1139 1137 1198" rowspan="2">Net total fuel utilisation (%) ⁽¹³⁸⁾ ⁽¹³⁹⁾</th> <th colspan="2" data-bbox="1137 1139 1496 1198">Net mechanical energy efficiency (%) ⁽¹³⁹⁾ ⁽¹⁴⁰⁾</th> </tr> <tr> <th data-bbox="591 1198 707 1257">New unit</th> <th data-bbox="707 1198 853 1257">Existing unit</th> <th data-bbox="1137 1198 1290 1257">New unit</th> <th data-bbox="1290 1198 1496 1257">Existing unit</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 1257 591 1316">Gas engine</td> <td data-bbox="591 1257 707 1316">39,5–44 ⁽¹⁴¹⁾</td> <td data-bbox="707 1257 853 1316">35–44 ⁽¹⁴¹⁾</td> <td data-bbox="853 1257 1137 1316">56–85 ⁽¹⁴¹⁾</td> <td colspan="2" data-bbox="1137 1257 1496 1316">No BAT-AEEL.</td> </tr> <tr> <td data-bbox="322 1316 591 1358">Gas-fired boiler</td> <td data-bbox="591 1316 707 1358">39–42,5</td> <td data-bbox="707 1316 853 1358">38–40</td> <td data-bbox="853 1316 1137 1358">78–95</td> <td colspan="2" data-bbox="1137 1316 1496 1358">No BAT-AEEL.</td> </tr> </tbody> </table>						Type of combustion unit	BAT-AEELs ⁽¹³⁶⁾ ⁽¹³⁷⁾				Net electrical efficiency (%)		Net total fuel utilisation (%) ⁽¹³⁸⁾ ⁽¹³⁹⁾	Net mechanical energy efficiency (%) ⁽¹³⁹⁾ ⁽¹⁴⁰⁾		New unit	Existing unit	New unit	Existing unit	Gas engine	39,5–44 ⁽¹⁴¹⁾	35–44 ⁽¹⁴¹⁾	56–85 ⁽¹⁴¹⁾	No BAT-AEEL.		Gas-fired boiler	39–42,5	38–40	78–95	No BAT-AEEL.	
Type of combustion unit	BAT-AEELs ⁽¹³⁶⁾ ⁽¹³⁷⁾																														
	Net electrical efficiency (%)		Net total fuel utilisation (%) ⁽¹³⁸⁾ ⁽¹³⁹⁾	Net mechanical energy efficiency (%) ⁽¹³⁹⁾ ⁽¹⁴⁰⁾																											
	New unit	Existing unit		New unit	Existing unit																										
Gas engine	39,5–44 ⁽¹⁴¹⁾	35–44 ⁽¹⁴¹⁾	56–85 ⁽¹⁴¹⁾	No BAT-AEEL.																											
Gas-fired boiler	39–42,5	38–40	78–95	No BAT-AEEL.																											

BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																											
	Open cycle gasturbine, ≥ 50 MW _{th}	36–41,5	33–41,5	No BAT-AEEL	36,5–41	33,5–41																													
	Combined cycle gas turbine (CCGT)																																		
	CCGT, 50–600 MW _{th}	53–58,5	46–54	No BAT-AEEL	No BAT-AEEL																														
	CCGT, ≥ 600 MW _{th}	57–60,5	50–60	No BAT-AEEL	No BAT-AEEL																														
	CHP CCGT, 50–600 MW _{th}	53–58,5	46–54	65–95	No BAT-AEEL																														
	CHP CCGT, ≥ 600 MW _{th}	57–60,5	50–60	65–95	No BAT-AEEL																														
41	In order to prevent or reduce NO _x emissions to air from the combustion of natural gas in boilers, BAT is to use one or a combination of the techniques given below .						NA	No LCP boilers on site.																											
	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 10%;"></th> <th style="width: 15%;">Technique</th> <th style="width: 35%;">Description</th> <th style="width: 40%;">Applicability</th> </tr> </thead> <tbody> <tr> <td>a.</td> <td>Air and/or fuel staging</td> <td>See descriptions in Section 8.3. Air staging is often associated with low-NO_x burners</td> <td rowspan="3">Generally applicable</td> </tr> <tr> <td>b.</td> <td>Flue-gas recirculation</td> <td>See description in Section 8.3</td> </tr> <tr> <td>c.</td> <td>Low-NO_x burners (LNB)</td> <td></td> </tr> <tr> <td>d.</td> <td>Advanced control system</td> <td>See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr</td> <td>The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> <tr> <td>e.</td> <td>Reduction of the combustion air temperature</td> <td rowspan="3">See description in Section 8.3</td> <td>Generally applicable within the constraints associated with the process needs</td> </tr> <tr> <td>f.</td> <td>Selective non-catalytic reduction (SNCR)</td> <td>Not applicable to combustion plants operated < 500 h/yr with highly variable boiler loads. The applicability may be limited in the case of combustion plants operated between 500 h/yr and 1 500 h/yr with highly variable boiler loads</td> </tr> <tr> <td>g.</td> <td>Selective catalytic reduction (SCR)</td> <td>Not applicable to combustion plants operated < 500 h/yr. Not generally applicable to combustion plants of < 100 MW_{th}.</td> </tr> </tbody> </table>								Technique	Description	Applicability	a.	Air and/or fuel staging	See descriptions in Section 8.3. Air staging is often associated with low-NO _x burners	Generally applicable	b.	Flue-gas recirculation	See description in Section 8.3	c.	Low-NO _x burners (LNB)		d.	Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system	e.	Reduction of the combustion air temperature	See description in Section 8.3	Generally applicable within the constraints associated with the process needs	f.	Selective non-catalytic reduction (SNCR)	Not applicable to combustion plants operated < 500 h/yr with highly variable boiler loads. The applicability may be limited in the case of combustion plants operated between 500 h/yr and 1 500 h/yr with highly variable boiler loads	g.	Selective catalytic reduction (SCR)	Not applicable to combustion plants operated < 500 h/yr. Not generally applicable to combustion plants of < 100 MW _{th} .
	Technique	Description	Applicability																																
a.	Air and/or fuel staging	See descriptions in Section 8.3. Air staging is often associated with low-NO _x burners	Generally applicable																																
b.	Flue-gas recirculation	See description in Section 8.3																																	
c.	Low-NO _x burners (LNB)																																		
d.	Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system																																
e.	Reduction of the combustion air temperature	See description in Section 8.3	Generally applicable within the constraints associated with the process needs																																
f.	Selective non-catalytic reduction (SNCR)		Not applicable to combustion plants operated < 500 h/yr with highly variable boiler loads. The applicability may be limited in the case of combustion plants operated between 500 h/yr and 1 500 h/yr with highly variable boiler loads																																
g.	Selective catalytic reduction (SCR)		Not applicable to combustion plants operated < 500 h/yr. Not generally applicable to combustion plants of < 100 MW _{th} .																																

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																		
			There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr																				
42	In order to prevent or reduce NO _x emissions to air from the combustion of natural gas in gas turbines, BAT is to use one or a combination of the techniques given below .			CC	<p>A. Use of a high performance monitoring and an advanced combustion optimisation system. B. Not Applicable (C installed) C. Dry Low NO_x burners Installed D. Installed during 2018 upgrade E. Standard Duct burners installed F. Not installed, unable to retrofit due to availability of space</p> <p>DLN Effective was confirmed in an email dated 01/05/2020 at: i. 90 MWe ii. 27% of rated power output DLN effective is equivalent to MSUL and below the 70% of load above which ELVs apply in accordance with Chapter III and therefore we agree that this value is appropriate. This superseded the DLN effective definition specified in the initial Regulation 61 response.</p>																		
<table border="1"> <thead> <tr> <th data-bbox="322 568 535 600">Technique</th> <th data-bbox="535 568 1093 600">Description</th> <th data-bbox="1093 568 1509 600">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 600 535 711">a. Advanced control system</td> <td data-bbox="535 600 1093 711">See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr</td> <td data-bbox="1093 600 1509 711">The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> <tr> <td data-bbox="322 711 535 767">b. Water/steam addition</td> <td data-bbox="535 711 1093 767" rowspan="2">See description in Section 8.3</td> <td data-bbox="1093 711 1509 767">The applicability may be limited due to water availability</td> </tr> <tr> <td data-bbox="322 767 535 879">c. Dry low-NO_x burners (DLN)</td> <td data-bbox="1093 767 1509 879">The applicability may be limited in the case of turbines where a retrofit package is not available or when water/steam addition systems are installed</td> </tr> <tr> <td data-bbox="322 879 535 1015">d. Low-load design concept</td> <td data-bbox="535 879 1093 1015">Adaptation of the process control and related equipment to maintain good combustion efficiency when the demand in energy varies, e.g. by improving the inlet airflow control capability or by splitting the combustion process into decoupled combustion stages</td> <td data-bbox="1093 879 1509 1015">The applicability may be limited by the gas turbine design</td> </tr> <tr> <td data-bbox="322 1015 535 1126">e. Low-NO_x burners (LNB)</td> <td data-bbox="535 1015 1093 1126" rowspan="2">See description in Section 8.3</td> <td data-bbox="1093 1015 1509 1126">Generally applicable to supplementary firing for heat recovery steam generators (HRSGs) in the case of combined-cycle gas turbine (CCGT) combustion plants</td> </tr> <tr> <td data-bbox="322 1126 535 1359">f. Selective catalytic reduction (SCR)</td> <td data-bbox="1093 1126 1509 1359">Not applicable in the case of combustion plants operated < 500 h/yr. Not generally applicable to existing combustion plants of < 100 MW_{th}. Retrofitting existing combustion plants may be constrained by the availability of sufficient space. There may be technical and economic restrictions for retrofitting existing</td> </tr> </tbody> </table>			Technique			Description	Applicability	a. Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system	b. Water/steam addition	See description in Section 8.3	The applicability may be limited due to water availability	c. Dry low-NO _x burners (DLN)	The applicability may be limited in the case of turbines where a retrofit package is not available or when water/steam addition systems are installed	d. Low-load design concept	Adaptation of the process control and related equipment to maintain good combustion efficiency when the demand in energy varies, e.g. by improving the inlet airflow control capability or by splitting the combustion process into decoupled combustion stages	The applicability may be limited by the gas turbine design	e. Low-NO _x burners (LNB)	See description in Section 8.3	Generally applicable to supplementary firing for heat recovery steam generators (HRSGs) in the case of combined-cycle gas turbine (CCGT) combustion plants	f. Selective catalytic reduction (SCR)	Not applicable in the case of combustion plants operated < 500 h/yr. Not generally applicable to existing combustion plants of < 100 MW _{th} . Retrofitting existing combustion plants may be constrained by the availability of sufficient space. There may be technical and economic restrictions for retrofitting existing
Technique	Description	Applicability																					
a. Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system																					
b. Water/steam addition	See description in Section 8.3	The applicability may be limited due to water availability																					
c. Dry low-NO _x burners (DLN)		The applicability may be limited in the case of turbines where a retrofit package is not available or when water/steam addition systems are installed																					
d. Low-load design concept	Adaptation of the process control and related equipment to maintain good combustion efficiency when the demand in energy varies, e.g. by improving the inlet airflow control capability or by splitting the combustion process into decoupled combustion stages	The applicability may be limited by the gas turbine design																					
e. Low-NO _x burners (LNB)	See description in Section 8.3	Generally applicable to supplementary firing for heat recovery steam generators (HRSGs) in the case of combined-cycle gas turbine (CCGT) combustion plants																					
f. Selective catalytic reduction (SCR)		Not applicable in the case of combustion plants operated < 500 h/yr. Not generally applicable to existing combustion plants of < 100 MW _{th} . Retrofitting existing combustion plants may be constrained by the availability of sufficient space. There may be technical and economic restrictions for retrofitting existing																					

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement															
	<table border="1"> <tr> <td data-bbox="322 386 353 443"></td> <td data-bbox="353 386 1093 443"></td> <td data-bbox="1093 386 1496 443">combustion plants operated between 500 h/yr and 1 500 h/yr</td> </tr> </table>			combustion plants operated between 500 h/yr and 1 500 h/yr														
		combustion plants operated between 500 h/yr and 1 500 h/yr																
43	<p>In order to prevent or reduce NO_x emissions to air from the combustion of natural gas in engines, BAT is to use one or a combination of the techniques given below .</p> <table border="1"> <thead> <tr> <th data-bbox="322 520 353 552">Technique</th> <th data-bbox="353 520 999 552">Description</th> <th data-bbox="999 520 1496 552">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 552 353 663">a. Advanced control system</td> <td data-bbox="353 552 999 663">See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr</td> <td data-bbox="999 552 1496 663">The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> <tr> <td data-bbox="322 663 353 721">b. Lean-burn concept</td> <td data-bbox="353 663 999 721">See description in Section 8.3. Generally used in combination with SCR</td> <td data-bbox="999 663 1496 721">Only applicable to new gas-fired engines</td> </tr> <tr> <td data-bbox="322 721 353 778">c. Advanced lean-burn concept</td> <td data-bbox="353 721 999 778">See descriptions in Section 8.3</td> <td data-bbox="999 721 1496 778">Only applicable to new spark plug ignited engines</td> </tr> <tr> <td data-bbox="322 778 353 963">d. Selective catalytic reduction (SCR)</td> <td data-bbox="353 778 999 963"></td> <td data-bbox="999 778 1496 963">Retrofitting existing combustion plants may be constrained by the availability of sufficient space. Not applicable to combustion plants operated < 500 h/yr. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system	b. Lean-burn concept	See description in Section 8.3. Generally used in combination with SCR	Only applicable to new gas-fired engines	c. Advanced lean-burn concept	See descriptions in Section 8.3	Only applicable to new spark plug ignited engines	d. Selective catalytic reduction (SCR)		Retrofitting existing combustion plants may be constrained by the availability of sufficient space. Not applicable to combustion plants operated < 500 h/yr. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr	NA	No gas engines on site.
Technique	Description	Applicability																
a. Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system																
b. Lean-burn concept	See description in Section 8.3. Generally used in combination with SCR	Only applicable to new gas-fired engines																
c. Advanced lean-burn concept	See descriptions in Section 8.3	Only applicable to new spark plug ignited engines																
d. Selective catalytic reduction (SCR)		Retrofitting existing combustion plants may be constrained by the availability of sufficient space. Not applicable to combustion plants operated < 500 h/yr. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr																
44	<p>In order to prevent or reduce CO emissions to air from the combustion of natural gas, BAT is to ensure optimised combustion and/or to use oxidation catalysts. Description - See descriptions in Section 8.3. BAT-associated emission levels (BAT-AELs) for NO_x emissions to air from the combustion of natural gas in gas turbines</p> <table border="1"> <thead> <tr> <th data-bbox="322 1123 784 1241" rowspan="2">Type of combustion plant</th> <th data-bbox="784 1123 1025 1241" rowspan="2">Combustion plant total rated thermal input (MW_{th})</th> <th colspan="2" data-bbox="1025 1123 1496 1155">BAT-AELs (mg/Nm³) ⁽¹⁴²⁾ ⁽¹⁴³⁾</th> </tr> <tr> <th data-bbox="1025 1155 1249 1241">Yearly average ⁽¹⁴⁴⁾ ⁽¹⁴⁵⁾</th> <th data-bbox="1249 1155 1496 1241">Daily average or average over the sampling period</th> </tr> </thead> <tbody> <tr> <td colspan="4" data-bbox="322 1241 1496 1283" style="text-align: center;">Open-cycle gas turbines (OCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁷⁾</td> </tr> <tr> <td data-bbox="322 1283 784 1319">New OCGT</td> <td data-bbox="784 1283 1025 1319">≥ 50</td> <td data-bbox="1025 1283 1249 1319">15–35</td> <td data-bbox="1249 1283 1496 1319">25–50</td> </tr> </tbody> </table>	Type of combustion plant	Combustion plant total rated thermal input (MW _{th})	BAT-AELs (mg/Nm ³) ⁽¹⁴²⁾ ⁽¹⁴³⁾		Yearly average ⁽¹⁴⁴⁾ ⁽¹⁴⁵⁾	Daily average or average over the sampling period	Open-cycle gas turbines (OCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁷⁾				New OCGT	≥ 50	15–35	25–50	CC	Operator has confirmed compliance with both NO _x and CO values and these have been incorporated into the permit as set out in section 4.1 of this document.	
Type of combustion plant	Combustion plant total rated thermal input (MW _{th})			BAT-AELs (mg/Nm ³) ⁽¹⁴²⁾ ⁽¹⁴³⁾														
		Yearly average ⁽¹⁴⁴⁾ ⁽¹⁴⁵⁾	Daily average or average over the sampling period															
Open-cycle gas turbines (OCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁷⁾																		
New OCGT	≥ 50	15–35	25–50															

BAT Concn. Numbe r	Summary of BAT Conclusion requirement				Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	Existing OCGT (excluding turbines for mechanical drive applications) — All but plants operated < 500 h/yr	≥ 50	15–50	25–55 ⁽¹⁴⁸⁾		
Combined-cycle gas turbines (CCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁹⁾						
	New CCGT	≥ 50	10–30	15–40		
	Existing CCGT with a net total fuel utilisation of < 75 %	≥ 600	10–40	18–50		
	Existing CCGT with a net total fuel utilisation of ≥ 75 %	≥ 600	10–50	18–55 ⁽¹⁵⁰⁾		
	Existing CCGT with a net total fuel utilisation of < 75 %	50–600	10–45	35–55		
	Existing CCGT with a net total fuel utilisation of ≥ 75 %	50–600	25–50 ⁽¹⁵¹⁾	35–55 ⁽¹⁵²⁾		
Open- and combined-cycle gas turbines						
	Gas turbine put into operation no later than 27 November 2003, or existing gas turbine for emergency use and operated < 500 h/yr	≥ 50	No BAT-AEL	60–140 ⁽¹⁵³⁾ ⁽¹⁵⁴⁾		
	Existing gas turbine for mechanical drive applications — All but plants operated < 500 h/yr	≥ 50	15–50 ⁽¹⁵⁵⁾	25–55 ⁽¹⁵⁶⁾		
<p>As an indication, the yearly average CO emission levels for each type of existing combustion plant operated ≥ 1 500 h/yr and for each type of new combustion plant will generally be as follows:</p> <ul style="list-style-type: none"> — New OCGT of ≥ 50 MW_{th}: < 5–40 mg/Nm³. For plants with a net electrical efficiency (EE) greater than 39 %, a correction factor may be applied to the higher end of this range, corresponding to [higher end] × EE/39, where EE is the net electrical energy efficiency or net mechanical energy efficiency of the plant determined at ISO baseload conditions. — Existing OCGT of ≥ 50 MW_{th} (excluding turbines for mechanical drive applications): < 5–40 mg/Nm³. The higher end of this range will generally be 80 mg/Nm³ in the case of existing plants that cannot be fitted with dry techniques for NO_x reduction, or 50 mg/Nm³ for plants that operate at low load. — New CCGT of ≥ 50 MW_{th}: < 5–30 mg/Nm³. For plants with a net electrical efficiency (EE) greater than 55 %, a correction factor may be applied to the higher end of the range, corresponding to [higher end] × EE/55, where EE is the net electrical energy efficiency of the plant determined at ISO baseload conditions. — Existing CCGT of ≥ 50 MW_{th}: < 5–30 mg/Nm³. The higher end of this range will generally be 50 mg/Nm³ for plants that operate at low load. 						

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																							
	<p>— Existing gas turbines of $\geq 50 \text{ MW}_{th}$ for mechanical drive applications: $< 5\text{--}40 \text{ mg/Nm}^3$. The higher end of the range will generally be 50 mg/Nm^3 when plants operate at low load.</p> <p>In the case of a gas turbine equipped with DLN burners, these indicative levels correspond to when the DLN operation is effective.</p> <p>BAT-associated emission levels (BAT-AELs) for NO_x emissions to air from the combustion of natural gas in boilers and engines</p> <table border="1" data-bbox="322 555 1496 783"> <thead> <tr> <th rowspan="3">Type of combustion plant</th> <th colspan="4">BAT-AELs (mg/Nm³)</th> </tr> <tr> <th colspan="2">Yearly average ⁽¹⁵⁷⁾</th> <th colspan="2">Daily average or average over the sampling period</th> </tr> <tr> <th>New plant</th> <th>Existing plant ⁽¹⁵⁸⁾</th> <th>New plant</th> <th>Existing plant ⁽¹⁵⁹⁾</th> </tr> </thead> <tbody> <tr> <td>Boiler</td> <td>10–60</td> <td>50–100</td> <td>30–85</td> <td>85–110</td> </tr> <tr> <td>Engine ⁽¹⁶⁰⁾</td> <td>20–75</td> <td>20–100</td> <td>55–85</td> <td>55–110 ⁽¹⁶¹⁾</td> </tr> </tbody> </table> <p>As an indication, the yearly average CO emission levels will generally be:</p> <ul style="list-style-type: none"> — $< 5\text{--}40 \text{ mg/Nm}^3$ for existing boilers operated $\geq 1\,500 \text{ h/yr}$, — $< 5\text{--}15 \text{ mg/Nm}^3$ for new boilers, — $30\text{--}100 \text{ mg/Nm}^3$ for existing engines operated $\geq 1\,500 \text{ h/yr}$ and for new engines. 	Type of combustion plant	BAT-AELs (mg/Nm ³)				Yearly average ⁽¹⁵⁷⁾		Daily average or average over the sampling period		New plant	Existing plant ⁽¹⁵⁸⁾	New plant	Existing plant ⁽¹⁵⁹⁾	Boiler	10–60	50–100	30–85	85–110	Engine ⁽¹⁶⁰⁾	20–75	20–100	55–85	55–110 ⁽¹⁶¹⁾		
Type of combustion plant	BAT-AELs (mg/Nm ³)																									
	Yearly average ⁽¹⁵⁷⁾		Daily average or average over the sampling period																							
	New plant	Existing plant ⁽¹⁵⁸⁾	New plant	Existing plant ⁽¹⁵⁹⁾																						
Boiler	10–60	50–100	30–85	85–110																						
Engine ⁽¹⁶⁰⁾	20–75	20–100	55–85	55–110 ⁽¹⁶¹⁾																						
45	<p>In order to reduce non-methane volatile organic compounds (NMVOC) and methane (CH₄) emissions to air from the combustion of natural gas in spark-ignited lean-burn gas engines, BAT is to ensure optimised combustion and/or to use oxidation catalysts.</p> <p>Description</p> <p>See descriptions in Section 8.3. Oxidation catalysts are not effective at reducing the emissions of saturated hydrocarbons containing less than four carbon atoms.</p>	NA	No gas engines on site.																							

6. Review and assessment of derogation requests made by the operator in relation to BAT Conclusions which include an associated emission level (AEL) value

The IED enables a competent authority to allow derogations from BAT AELs stated in BAT Conclusions under specific circumstances as detailed under Article 15(4):

By way of derogation from paragraph 3, and without prejudice to Article 18, the competent authority may, in specific cases, set less strict emission limit values. Such a derogation may apply only where an assessment shows that the achievement of emission levels associated with the best available techniques as described in BAT conclusions would lead to disproportionately higher costs compared to the environmental benefits due to:

(a) the geographical location or the local environmental conditions of the installation concerned; or

(b) the technical characteristics of the installation concerned.

As part of their Regulation 61 Note response, the operator has not requested a derogation from compliance with any AEL values.

7. Emissions to Water

The consolidated permit incorporates the one current discharge to controlled waters identified as W1.

There are no BAT AELs for emissions to water specified in the BAT Conclusions for this type of plant. There are also no additional treatment options identified as BAT for the installation. We have therefore not carried out any additional assessment of the emissions to water as part of this review.

8. Additional IED Chapter II requirements:

Black start operation

In the event of a black out National Grid would call on combustion plant to operate and may require them to do so outside their permitted conditions. We have dedicated black start plant and they are permitted to run as such but this scenario is relevant to the rest of the large combustion plant which could be called depending on the circumstances.

A risk assessment will be carried out by Energy UK/Joint Environmental Programme on behalf of Large Combustion Plant connected to the National Transmission System. Air emissions modelling will be based on generic black start scenarios to establish whether they have the potential to have local impact on the environment or not (on a national basis). If the modelling demonstrates that no significant impacts are likely, the plant can operate under condition 2.3.7. This conditions allows the hourly ELVs for plants operating under a black start instruction to be discounted for the purpose of reporting. We would also require there to be a procedure in place for minimisation of emissions in the case of a black start event and for reporting in the event of a black start. This modelling and the procedures have not been agreed in advance of the issue of the permit review and therefore a condition linking back to an improvement condition have been included in the permit.

Surface water drainage

The permit has been amended to reflect that this site takes the surface water run off from neighbouring site Spalding Energy Expansion Limited PR/AP3732KC. This uncontaminated surface water will discharge through the same emission point to surface water.

Amendment to reflect upgrade works on site

Upgrade works on site resulted in the thermal input increasing from 783.6MWth to 838MWth and the electrical output increasing from 860MW to 920MW which has been reflected in the permit. Both gas turbines were modified so that they can operated in low part load (LPL). The start up and shut down thresholds have been updated in the permit to reflect these changes.

Monitoring requirements to auxiliary boilers

During the review we also amended the monitoring requirement for the auxiliary boilers on site (not classified as LCP). This was previously specified as requiring continuous monitoring but after review against the requirements of the Medium Combustion Plant Directive, this has been amended to periodic.

9. Review and assessment of changes that are not part of the BAT Conclusions derived permit review.

This document should be read in conjunction with the application, supporting information and notice.

Aspect considered	Decision
Receipt of application	
Confidential information	A claim for commercial or industrial confidentiality has not been made.
Identifying confidential information	We have not identified information provided as part of the application that we consider to be confidential.
The site	
Biodiversity, heritage, landscape and nature conservation	<p>The application is within the relevant distance criteria of a site of heritage, landscape or nature conservation, and/or protected species or habitat.</p> <p>A full assessment of the application and its potential to affect the site(s)/species/habitat has not been carried out as part of the permit review process. We consider that the review will not affect the features of the site(s)/species/habitat as the conditions will provide at least the same level of protection as those in the previous permit and in some cases will provide a higher level of protection to those in the previous permit.</p> <p>We have not consulted Natural England on the application. The decision was taken in accordance with our guidance.</p>
Operating techniques	
General operating techniques	<p>We have reviewed the techniques used by the operator where they are relevant to the BAT Conclusions and compared these with the relevant guidance notes.</p> <p>The permit conditions ensure compliance with the relevant BREF, BAT Conclusions. The ELVs deliver compliance with the BAT-AELs.</p>
Permit conditions	
Updating permit conditions during consolidation	We have updated permit conditions to those in the current generic permit template as part of permit consolidation. The conditions will provide at least the same level of protection as those in the previous permit and in some cases will provide a higher level of protection to those in the previous permit.

Aspect considered	Decision
Changes to the permit conditions due to an Environment Agency initiated variation	We have varied the permit as stated in the variation notice.
Emission limits	<p>We have decided that emission limits should be set for the parameters listed in the permit.</p> <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p> <p>It is considered that the ELVs/equivalent parameters or technical measures described above will ensure that significant pollution of the environment is prevented and a high level of protection for the environment is secured.</p>
Monitoring	<p>We have decided that monitoring should be carried out for the parameters listed in the permit, using the methods detailed and to the frequencies specified.</p> <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p> <p>Table S3.4 Process monitoring requirements was amended to include the requirement to monitor energy efficiency after overhauls on site in line with BAT2.</p> <p>Based on the information in the application we are satisfied that the operator's techniques, personnel and equipment have either MCERTS certification or MCERTS accreditation as appropriate.</p>
Reporting	<p>We have specified reporting in the permit.</p> <p>This is described in the relevant BAT Conclusions in Section 5 of this document.</p>
Operator competence	
Management system	There is no known reason to consider that the operator will not have the management system to enable it to comply with the permit conditions.
Growth Duty	
Section 108 Deregulation Act 2015 – Growth duty	<p>We have considered our duty to have regard to the desirability of promoting economic growth set out in section 108(1) of the Deregulation Act 2015 and the guidance issued under section 110 of that Act in deciding whether to grant this permit.</p> <p>Paragraph 1.3 of the guidance says:</p> <p>“The primary role of regulators, in delivering regulation, is to achieve the regulatory outcomes for which they are responsible. For a number of regulators, these regulatory outcomes include an explicit reference to development or growth. The growth duty establishes economic growth as a</p>

Aspect considered	Decision
	<p>factor that all specified regulators should have regard to, alongside the delivery of the protections set out in the relevant legislation.”</p> <p>We have addressed the legislative requirements and environmental standards to be set for this operation in the body of the decision document above. The guidance is clear at paragraph 1.5 that the growth duty does not legitimise non-compliance and its purpose is not to achieve or pursue economic growth at the expense of necessary protections.</p> <p>We consider the requirements and standards we have set in this permit are reasonable and necessary to avoid a risk of an unacceptable level of pollution. This also promotes growth amongst legitimate operators because the standards applied to the operator are consistent across businesses in this sector and have been set to achieve the required legislative standards.</p>