

Environment Agency

Review of an Environmental Permit for an Installation subject to Chapter II of the Industrial Emissions Directive under the Environmental Permitting (England & Wales) Regulations 2016

Decision document recording our decision-making process following review of a permit

The Permit number is: EPR/BT0596IS
The Operator is: National Grid Gas PLC
The Installation is: Wooler Gas Compressor Station
This Variation Notice number is: EPR/BT0596IS/V004

What this document is about

Article 21(3) of the Industrial Emissions Directive (IED) requires the Environment Agency to review conditions in permits that it has issued and to ensure that the permit delivers compliance with relevant standards, within four years of the publication of updated decisions on best available techniques (BAT) conclusions.

We have reviewed the permit for this installation against the revised BAT Conclusions for large combustion plant published on 17th August 2017. This is our decision document, which explains the reasoning for the consolidated variation notice that we are issuing.

It explains how we have reviewed and considered the techniques used by the Operator in the operation and control of the plant and activities of the installation. This review has been undertaken with reference to the decision made by the European Commission establishing best available techniques (BAT) conclusions ('BAT Conclusions') for large combustion plant as detailed in document reference IEDC-7-1. It is our record of our decision-making process and shows how we have taken into account all relevant factors in reaching our position. It also provides a justification for the inclusion of any specific conditions in the permit that are in addition to those included in our generic permit template.

As well as considering the review of the operating techniques used by the Operator for the operation of the plant and activities of the installation, the consolidated variation notice takes into account and brings together in a single document all previous variations that relate to the original permit

issued. It also modernises the entire permit to reflect the conditions contained in our current generic permit template.

The introduction of new template conditions makes the Permit consistent with our current general approach and philosophy and with other permits issued to installations in this sector. Although the wording of some conditions has changed, while others have been removed because of the new regulatory approach, it does not reduce the level of environmental protection achieved by the Permit in any way. In this document we therefore address only our determination of substantive issues relating to the new BAT Conclusions.

Throughout this document we will use a number of expressions. These are as referred to in the glossary and have the same meaning as described in “Schedule 6 Interpretation” of the Permit.

We try to explain our decision as accurately, comprehensively and plainly as possible. We would welcome any feedback as to how we might improve our decision documents in future. A lot of technical terms and acronyms are inevitable in a document of this nature: we provide a glossary of acronyms near the front of the document, for ease of reference.

How this document is structured

Glossary of terms

- 1 Our decision
- 2 How we reached our decision
- 2.1 Requesting information to demonstrate compliance with BAT Conclusions for Large Combustion Plant
- 2.2 Review of our own information in respect to the capability of the installation to meet revised standards included in the BAT Conclusions document
- 2.3 Summary of how we considered the responses from public consultation.
- 3 The legal framework
- 4 Key Issues
- 5 Decision checklist regarding relevant BAT Conclusions
- 6 Review and assessment of derogation requests made by the operator in relation to BAT Conclusions which include an associated emission level (AEL) value
- 7 Emissions to Water
- 8 Additional IED Chapter II requirements
- 9 Review and assessment of changes that are not part of the BAT Conclusions derived permit review.

Glossary of acronyms used in this document

(Please note that this glossary is standard for our decision documents and therefore not all these acronyms are necessarily used in this document.)

| | |
|-----------|--|
| APC | Air Pollution Control |
| BAT | Best Available Technique(s) |
| BAT-AEEL | BAT Associated Energy Efficiency Level |
| BAT-AEL | BAT Associated Emission Level |
| BATc | BAT conclusion |
| BREF | Best available techniques reference document |
| CEM | Continuous emissions monitor |
| CHP | Combined heat and power |
| CV | Calorific value |
| DAA | Directly associated activity – Additional activities necessary to be carried out to allow the principal activity to be carried out |
| DLN | Dry Low NOx burners |
| DLN-E | Dry Low NOx effective |
| EIONET | European environment information and observation network is a partnership network of the European Environment Agency |
| ELV | Emission limit value derived under BAT or an emission limit value set out in IED |
| EMS | Environmental Management System |
| EPR | Environmental Permitting (England and Wales) Regulations 2016 (SI 2016 No. 1154) |
| EWC | European waste catalogue |
| FSA | Food Standards Agency |
| IC | Improvement Condition |
| IED | Industrial Emissions Directive (2010/75/EU) |
| IPPCD | Integrated Pollution Prevention and Control Directive (2008/1/EC) – now superseded by IED |
| LCP | Large Combustion Plant subject to Chapter III of IED |
| MSUL/MSDL | Minimum start up load/minimum shut-down load |
| NOx | Oxides of nitrogen (NO plus NO ₂ expressed as NO ₂) |
| NPV | Net Present Value |
| OCGT | Open Cycle Gas Turbine |
| PHE | Public Health England |
| SAC | Special Area of Conservation |
| SGN | Sector guidance note |
| TGN | Technical guidance note |
| TOC | Total Organic Carbon |
| WFD | Water Framework Directive (2000/60/EC) |

1 Our decision

We have decided to issue the consolidated variation notice to the Operator. This will allow it to continue to operate the Installation, subject to the conditions in the consolidated variation notice.

We consider that, in reaching that decision, we have taken into account all relevant considerations and legal requirements and that the varied permit will ensure that a high level of protection is provided for the environment and human health.

The consolidated variation notice contains many conditions taken from our standard Environmental Permit template including the relevant Annexes. We developed these conditions in consultation with industry, having regard to the legal requirements of the Environmental Permitting Regulations and other relevant legislation. This document does not therefore include an explanation for these standard conditions. Where they are included in the Notice, we have considered the techniques identified by the operator for the operation of their installation, and have accepted that the details are sufficient and satisfactory to make those standard conditions appropriate. This document does, however, provide an explanation of our use of “tailor-made” or installation-specific conditions, or where our Permit template provides two or more options.

2 How we reached our decision

2.1 Requesting information to demonstrate compliance with BAT Conclusions for Large Combustion Plant

We issued a Notice under Regulation 61(1) of the Environmental Permitting (England and Wales) Regulations 2016 (a Regulation 61 Notice) on 1st May 2018 requiring the Operator to provide information to demonstrate how the operation of their installation currently meets, or will subsequently meet, the revised standards described in the large combustion plant BAT Conclusions document. The Notice also required that where the revised standards are not currently met, the operator should provide information that:

- Describes the techniques that will be implemented before 17th August 2021, which will then ensure that operations meet the revised standard, or
- Justifies why standards will not be met by 17th August 2021, and confirmation of the date when the operation of those processes will cease within the installation or an explanation of why the revised BAT standard is not applicable to those processes, or
- Justifies why an alternative technique will achieve the same level of environmental protection equivalent to the revised standard described in the BAT Conclusions.

Where the Operator proposed that they were not intending to meet a BAT standard that also included a BAT Associated Emission Level (BAT AEL) described in the BAT Conclusions Document, the Regulation 61 Notice requested that the Operator make a formal request for derogation from compliance with that AEL (as provisioned by Article 15(4) of IED). In this circumstance, the Notice identified that any such request for derogation must be supported and justified by sufficient technical and commercial information that would enable us to determine acceptability of the derogation request.

The Regulation 61 Notice response from the Operator was received on 30th November 2018.

We considered it was in the correct form and contained sufficient information for us to begin our determination of the permit review but not that it necessarily contained all the information we would need to complete that review.

2.2 Review of our own information in respect to the capability of the installation to meet revised standards included in the BAT Conclusions document

Based on our records and previous regulatory activities with the facility we have no reason to consider that the operator will not be able to comply with the conditions that we include in the permit.

3 The legal framework

The consolidated variation notice will be issued under Regulation 20 of the EPR. The Environmental Permitting regime is a legal vehicle which delivers most of the relevant legal requirements for activities falling within its scope. In particular, the regulated facility is:

- an *installation* as described by the IED;
- subject to aspects of other relevant legislation which also have to be addressed.

We consider that the consolidated variation notice will ensure that the operation of the Installation complies with all relevant legal requirements and that a high level of protection will be delivered for the environment and human health.

We explain how we have addressed specific statutory requirements more fully in the rest of this document.

4 The key issues

The key issues arising during this permit review are:

- Emissions to air and the emission limits applied to the plant.
- The energy efficiency levels associated with the Best Available Techniques (BAT-AEELs)

We therefore describe how we determined these issues in most detail in the relevant sections of this document.

4.1 Emissions to air and the emission limits applied to the plant

A number of general principles were applied during the permit review. These included:

- The upper value of the BAT AELs ranges specified were used unless use of the tighter limit was justified.
- The principle of no backsliding where if existing limits in the permit were already tighter than those specified in the BREF, the existing permit limits were retained.
- Where a limit was specified in both IED Annex V and the BAT Conclusions for a particular reference period, the tighter limit was applied and in the majority of cases this was from the BAT Conclusions.
- Where AELs are indicative in the BAT Conclusions, these were applied unless adequate justification was provided by the operator to demonstrate that an alternative limit was more appropriate.

The LCP(s) on site consist of:

LCP245: 1 x 52.3 MWth OCGT which vents at emission point A1. The unit burns natural gas only.

LCP246: 1 x 58.2 MWth OCGT which vents at emission point A2. The unit burns natural gas only.

The plant was put into operation before IED came into force and therefore the existing limits in the permit are from Part 1 of IED Annex V applicable to existing plant.

The ELVs and AELs are based on the following operating regime:

- Unlimited hours operation

The Operator submitted the operational performance emissions data for NO_x and CO for each individual turbine as part of the original permit application in 2006. This excluded any data collected when the plant was operating at <55% Maximum Continuous Rating (MCR). These figures provided the realistic

emission values that individual turbines could achieve at >55% MCR and were the basis on which emission limit values for Carbon Monoxide (CO) and NOx were set. The Limits in the previous permit did not apply during start up, shut down or during operation at loads <55% of MCR.

On this site the plant is required by the gas grid to operate at low load for usually only short periods of time. In order to ensure that emissions between MSUL and 55% are monitored we have the option of either setting additional ELVs or recording the hours below 55% operation and retaining the note that the limits are excluded at operation <55%.

We have agreed to retain the current approach of recording hours of operation below 55% MCR. This is because the ELVs would have to be set very high which would not reflect environmental risk. This would further complicate an already complex system where more than one ELV is set. The environmental risk associated with this approach is low and we have decided to maintain monitoring using the number of operating hours in this mode as a proxy.

We have included a note in tables S3.1 and S3.1a for all Nation Grid Gas sites that states 'excluding start up, shut down and operation at loads <55% of MCR'. A requirement for the hours of operation below 55% to be recorded is included in Schedule 4 of the permit.

IED specified that limits apply over 70% load and the BAT Conclusions specify that AELs apply when dry low NOx is effective (DLN-E). For NGG permits 55% MCR is used as a proxy for DLN-E. We have used 55% MCR as a default across all monitoring requirements for NOx and CO.

The following tables outline the limits that have been incorporated into the permit for LCP245 and LCP246, where these were derived from and the reference periods at which they apply. The emission limits refer to concentrations, expressed as mass of emitted substance per volume of flue-gas under the following standard conditions: dry gas at a temperature of 273,15 K, pressure of 101,3 kPa and 15% volume reference oxygen concentration if flue gases. The emission limits and monitoring requirements have been incorporated into Schedule 3 of the permit.

| NOx limits (mg/Nm ³) | | | | | | |
|-----------------------------------|---------------------------------|-----------------------|------------------------|--------|-------------------------------|---|
| Averaging | IED (Annex V Part 1) - Existing | BREF (Table 24 BAT-c) | Expected permit limits | Basis | Limits apply | Monitoring |
| Annual | None | 60 ^{Note 1} | 60 | BREF | >55% of MCR ^{Note 3} | Continuous (Predicative Emission Monitoring System) |
| Monthly | 75 | None | 65 ^{Note 2} | Note 2 | >55% of MCR ^{Note 3} | |
| Daily | 82 | 65 ^{Note 1} | 65 | BREF | >55% of MCR ^{Note 3} | |
| 95 th %ile of hr means | 150 | None | 150 | IED | >55% of MCR ^{Note 3} | |

Note 1: As an existing OCGT Mechanical Drive plant put into operation no later than 7 January 2014, footnotes 14 and 15 to Table 24 of the BAT Conclusions apply, these footnote specify the applicable BAT-AELs.

Note 2: This limit is tighter than the IED annex V limit (75mg/m³) which was previously set in the permit. The monthly limit cannot be higher than the daily limit, therefore we have set a monthly limit which matches the daily limit given in the BAT Conclusions.

Note 3: The BAT Conclusions specify that AELs apply when dry low NOx is effective (DLN-E). For NGG permits, 55% MCR is used as a proxy for DLN-E.

| CO limits (mg/Nm ³) | | | | | | | |
|-----------------------------------|-----------------------------|---------------------------------|------|------------------------|--------|-------------------------------|---|
| Averaging | Permit – Non-IED - Existing | IED (Annex V Part 1) - Existing | BREF | Expected permit limits | Basis | Limits apply | Monitoring |
| Annual | None | None | 40 | 40 | BREF | >55% of MCR ^{Note 1} | Continuous (Predicative Emission Monitoring System) |
| Monthly | None | 100 | None | 100 | IED | >55% of MCR ^{Note 1} | |
| Daily | 100 | 110 | None | 100 | Permit | >55% of MCR ^{Note 1} | |
| 95 th %ile of hr means | 100 | 200 | None | 100 | Permit | >55% of MCR ^{Note 1} | |

Note 1: The BAT Conclusions specify that AELs apply when dry low NOx is effective (DLN-E). For NGG permits, 55% MCR is used as a proxy for DLN-E.

4.2 The energy efficiency levels associated with the Best Available Techniques Conclusions

An energy efficiency level associated with the best available techniques (BAT-AEEL) refers to the ratio between the combustion unit's net energy output(s) and the combustion unit's fuel/feedstock energy input at actual unit design. The net energy output(s) is determined at the combustion unit boundaries, including auxiliary systems (e.g. flue-gas treatment systems), and for the unit operated at full load.

The table below sets out the BAT-AEELs specified in the LCP BAT Conclusions for the large combustion plant on the site and the energy efficiency levels confirmed through the Regulation 61 notice response. The Operator confirmed that the original equipment manufacturer provided a calculation based on their internal product data for the equipment installed in order to determine the net mechanical efficiency. We consider this plant is BAT in relation to the AEELs.

| BAT AEELs (%) | | | Plant efficiency (%) | | |
|---|----------------------------|---------------------------|---------------------------|----------------------------|---------------------------|
| Net electrical efficiency | Net total fuel utilisation | Net mechanical efficiency | Net electrical efficiency | Net total fuel utilisation | Net mechanical efficiency |
| LCP245: Open cycle gas turbine, ≥ 50 MWth, Existing unit, Mechanical Drive | | | | | |
| None | None | 33.5-41 | NA | NA | 39.1 |
| LCP246: Open cycle gas turbine, ≥ 50 MWth, Existing unit, Mechanical Drive | | | | | |
| None | None | 33.5-41 | NA | NA | 39.1 |

5 Decision checklist regarding relevant BAT Conclusions

BAT Conclusions for large combustion plant, were published by the European Commission on 17th August 2017. There are 75 BAT Conclusions. Only the BAT Conclusions relevant to the particular fuel type used on site have been replicated below.

This annex provides a record of decisions made in relation to each relevant BAT Conclusion applicable to the installation. This annex should be read in conjunction with the Consolidated Variation Notice.

The conditions in the permit through which the relevant BAT Conclusions are implemented include but are not limited to the following:

| BAT Conclusion requirement topic | Permit condition(s) | Permit table(s) |
|----------------------------------|---------------------|-------------------------|
| Environmental Management System | 1.1.1 | S1.2 |
| BAT AELs | 3.1.1 and 3.5.1 | S3.1a |
| Monitoring | 2.3, 3.5 and 3.6 | S1.2, S1.4, S1.5, S3.1a |
| Energy efficiency | 1.2 and 2.3 | S3.3 |
| Noise | 3.4 and 2.3 | S1.2 |
| Other operating techniques | 2.3 | S1.2 |

The overall status of compliance with the BAT conclusion is indicated in the table as:

- NA Not Applicable
- CC Currently Compliant
- FC Compliant in the future (within 4 years of publication of BAT conclusions)
- NC Not Compliant
- PC Partially Compliant

| BAT Concn. Number | Summary of BAT Conclusion requirement | Status NA/ CC / FC / NC | Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement |
|-------------------|---|-------------------------|---|
| General | | | |
| 1 | <p>In order to improve the overall environmental performance, BAT is to implement and adhere to an environmental management system (EMS) that incorporates all of the following features:</p> <ul style="list-style-type: none"> i. commitment of the management, including senior management; ii. definition of an environmental policy that includes the continuous improvement of the installation by the management; iii. planning and establishing the necessary procedures, objectives and targets, in conjunction with financial planning and investment; iv. implementation of procedures <ul style="list-style-type: none"> (a) Structure and responsibility (b) Training (c) Communication (d) Employee involvement (e) Documentation (f) Efficient process control (g) Maintenance programmes (h) Emergency preparedness and response (i) Safeguarding compliance with environmental legislation v. checking performance and taking corrective action, paying particular attention to: <ul style="list-style-type: none"> (a) monitoring and measurement (see also the Reference Document on the General Principles of Monitoring) (b) corrective and preventive action (c) maintenance of records (d) independent (where practicable) internal and external auditing in order to determine whether or not the EMS conforms to planned arrangements and has been properly implemented and maintained; vi. review of the EMS and its continuing suitability, adequacy and effectiveness by senior management; vii. following the development of cleaner technologies; viii. consideration for the environmental impacts from the eventual decommissioning of the installation at the stage of designing a new plant, and throughout its operating life; viii. consideration for the environmental impacts from the eventual decommissioning of the installation at the stage of designing a new plant, and throughout its operating life; ix. application of sectoral benchmarking on a regular basis. <p>Etc - see BAT Conclusions</p> | CC | <p>National Grid operates an ISO14001 certified EMS.</p> <p>The operator has confirmed that National Grid Plc operates a corporate EMS for all it's business units. National Grid Gas (Gas Transmission) has management procedures of its own to implement the requirements of the corporate EMS which are common to all installations. Each installation has its own site specific aspects and impacts register.</p> |

| BAT Concn. Number | Summary of BAT Conclusion requirement | Status NA/ CC / FC / NC | Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement | | | | | | | | | | | | | |
|-------------------------------------|---|--------------------------------------|---|------------|----------|------|--------------------------------------|---|------------------------------------|--------------------------|--|-------------------------------------|---------------------------|------------------------|----|--|
| | <p>Applicability. The scope (e.g. level of detail) and nature of the EMS (e.g. standardised or non-standardised) will generally be related to the nature, scale and complexity of the installation, and the range of environmental impacts it may have.</p> | | | | | | | | | | | | | | | |
| 2 | <p>BAT is to determine the net electrical efficiency and/or the net total fuel utilisation and/or the net mechanical energy efficiency of the gasification, IGCC and/or combustion units by carrying out a performance test at full load (1), according to EN standards, after the commissioning of the unit and after each modification that could significantly affect the net electrical efficiency and/or the net total fuel utilisation and/or the net mechanical energy efficiency of the unit. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.</p> | CC | <p>The net mechanical efficiency of LCP245 and LCP246 is 39.1%. This is based on product data from the original equipment manufacturer.</p> <p>A process monitoring requirement has been set in table S3.3 which requires energy efficiency monitoring after an overhaul.</p> | | | | | | | | | | | | | |
| 3 | <p>BAT is to monitor key process parameters relevant for emissions to air and water including those given below.</p> <table border="1" data-bbox="322 890 1491 1062"> <thead> <tr> <th data-bbox="322 890 685 922">Stream</th> <th data-bbox="685 890 1122 922">Parameter(s)</th> <th data-bbox="1122 890 1491 922">Monitoring</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 922 685 1031" rowspan="3">Flue-gas</td> <td data-bbox="685 922 1122 959">Flow</td> <td data-bbox="1122 922 1491 959">Periodic or continuous determination</td> </tr> <tr> <td data-bbox="685 959 1122 995">Oxygen content, temperature, and pressure</td> <td data-bbox="1122 959 1491 995">Periodic or continuous measurement</td> </tr> <tr> <td data-bbox="685 995 1122 1031">Water vapour content (%)</td> <td data-bbox="1122 995 1491 1031"></td> </tr> <tr> <td data-bbox="322 1031 685 1062">Waste water from flue-gas treatment</td> <td data-bbox="685 1031 1122 1062">Flow, pH, and temperature</td> <td data-bbox="1122 1031 1491 1062">Continuous measurement</td> </tr> </tbody> </table> | Stream | Parameter(s) | Monitoring | Flue-gas | Flow | Periodic or continuous determination | Oxygen content, temperature, and pressure | Periodic or continuous measurement | Water vapour content (%) | | Waste water from flue-gas treatment | Flow, pH, and temperature | Continuous measurement | CC | <p>Flow - Fuel gas usage is measured and flue-gas flow is determined by stoichiometric calculations.</p> <p>Oxygen content, temperature and pressure - NO_x, CO and O₂ concentration content is measured via periodic measurements, conducted by UKAS ISO17025 laboratory to EN standards. Emissions measurements taken in this way are not affected by changes in temperature and pressure and these parameters are not required for correction to reference conditions. We are satisfied with the Operators justification of why temperature and pressure are not measured.</p> |
| Stream | Parameter(s) | Monitoring | | | | | | | | | | | | | | |
| Flue-gas | Flow | Periodic or continuous determination | | | | | | | | | | | | | | |
| | Oxygen content, temperature, and pressure | Periodic or continuous measurement | | | | | | | | | | | | | | |
| | Water vapour content (%) | | | | | | | | | | | | | | | |
| Waste water from flue-gas treatment | Flow, pH, and temperature | Continuous measurement | | | | | | | | | | | | | | |

| BAT Concn. Number | Summary of BAT Conclusion requirement | Status NA/ CC / FC / NC | Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement | | | | | | | | | | | | | | | | | | |
|---------------------|--|--|--|---|--|---|----------------------------|-----------------|--------------------------------|-----------|----------------------|--|-------|-----------------|---|-----------|----------------------|--|--|----|---|
| | | | <p>Water vapour content - Flue gas water vapour content is not measured as the flue gas is dried prior to measurement for periodic monitoring. This is in accordance with footnote one on the table under BAT 3.</p> <p>Waste water from flue-gas treatment - no waste water is generated from flue-gas treatment.</p> | | | | | | | | | | | | | | | | | | |
| 4 | <p>BAT is to monitor emissions to air with at least the frequency given below and in accordance with EN standards. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.</p> <table border="1" data-bbox="320 842 1494 1390"> <thead> <tr> <th data-bbox="320 842 477 962">Substance/Parameter</th> <th data-bbox="477 842 790 962">Fuel/Process/Type of combustion plant</th> <th data-bbox="790 842 947 962">Combustion plant total rated thermal input</th> <th data-bbox="947 842 1126 962">Standard(s)⁽⁴⁾</th> <th data-bbox="1126 842 1350 962">Minimum monitoring frequency⁽⁵⁾</th> <th data-bbox="1350 842 1494 962">Monitoring associated with</th> </tr> </thead> <tbody> <tr> <td data-bbox="320 962 477 1026">NH₃</td> <td data-bbox="477 962 790 1026">— When SCR and/or SNCR is used</td> <td data-bbox="790 962 947 1026">All sizes</td> <td data-bbox="947 962 1126 1026">Generic EN standards</td> <td data-bbox="1126 962 1350 1026">Continuous⁽⁶⁾₍₇₎</td> <td data-bbox="1350 962 1494 1026">BAT 7</td> </tr> <tr> <td data-bbox="320 1026 477 1390">NO_x</td> <td data-bbox="477 1026 790 1390"> <ul style="list-style-type: none"> — Coal and/or lignite including waste co-incineration — Solid biomass and/or peat including waste co-incineration — HFO- and/or gas-oil-fired boilers and engines — Gas-oil-fired gas turbines — Natural-gas-fired boilers, engines, and turbines — Iron and steel process gases </td> <td data-bbox="790 1026 947 1390">All sizes</td> <td data-bbox="947 1026 1126 1390">Generic EN standards</td> <td data-bbox="1126 1026 1350 1390">Continuous⁽⁶⁾₍₈₎</td> <td data-bbox="1350 1026 1494 1390"> BAT 20 BAT 24 BAT 28 BAT 32 BAT 37 BAT 41 BAT 42 BAT 43 BAT 47 BAT 48 BAT 56 BAT 64 BAT 65 BAT 73 </td> </tr> </tbody> </table> | Substance/Parameter | Fuel/Process/Type of combustion plant | Combustion plant total rated thermal input | Standard(s) ⁽⁴⁾ | Minimum monitoring frequency ⁽⁵⁾ | Monitoring associated with | NH ₃ | — When SCR and/or SNCR is used | All sizes | Generic EN standards | Continuous ⁽⁶⁾ ₍₇₎ | BAT 7 | NO _x | <ul style="list-style-type: none"> — Coal and/or lignite including waste co-incineration — Solid biomass and/or peat including waste co-incineration — HFO- and/or gas-oil-fired boilers and engines — Gas-oil-fired gas turbines — Natural-gas-fired boilers, engines, and turbines — Iron and steel process gases | All sizes | Generic EN standards | Continuous ⁽⁶⁾ ₍₈₎ | BAT 20 BAT 24 BAT 28 BAT 32 BAT 37 BAT 41 BAT 42 BAT 43 BAT 47 BAT 48 BAT 56 BAT 64 BAT 65 BAT 73 | CC | <p>A Predictive Emission Monitoring System (PEMS) is used for monitoring of NO_x and CO validated by periodic measurement. Footnote 5 to BAT 4 confirms that PEMS may be used for existing OCGTs.</p> |
| Substance/Parameter | Fuel/Process/Type of combustion plant | Combustion plant total rated thermal input | Standard(s) ⁽⁴⁾ | Minimum monitoring frequency ⁽⁵⁾ | Monitoring associated with | | | | | | | | | | | | | | | | |
| NH ₃ | — When SCR and/or SNCR is used | All sizes | Generic EN standards | Continuous ⁽⁶⁾ ₍₇₎ | BAT 7 | | | | | | | | | | | | | | | | |
| NO _x | <ul style="list-style-type: none"> — Coal and/or lignite including waste co-incineration — Solid biomass and/or peat including waste co-incineration — HFO- and/or gas-oil-fired boilers and engines — Gas-oil-fired gas turbines — Natural-gas-fired boilers, engines, and turbines — Iron and steel process gases | All sizes | Generic EN standards | Continuous ⁽⁶⁾ ₍₈₎ | BAT 20 BAT 24 BAT 28 BAT 32 BAT 37 BAT 41 BAT 42 BAT 43 BAT 47 BAT 48 BAT 56 BAT 64 BAT 65 BAT 73 | | | | | | | | | | | | | | | | |

| BAT Concn. Numbe r | Summary of BAT Conclusion requirement | | | | | Status NA/ CC / FC / NC | Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement |
|-----------------------------|--|-----------|-----------------------------------|---|--|-------------------------------|--|
| | <ul style="list-style-type: none"> — Process fuels from the chemical industry — IGCC plants | | | | | | |
| | <ul style="list-style-type: none"> — Combustion plants on offshore platforms | All sizes | EN 14792 | Once every year ⁽⁹⁾ | BAT 53 | | |
| N ₂ O | <ul style="list-style-type: none"> — Coal and/or lignite in circulating fluidised bed boilers — Solid biomass and/or peat in circulating fluidised bed boilers | All sizes | EN 21258 | Once every year ⁽¹⁰⁾ | BAT 20 BAT 24 | | |
| CO | <ul style="list-style-type: none"> — Coal and/or lignite including waste co-incineration — Solid biomass and/or peat including waste co-incineration — HFO- and/or gas-oil-fired boilers and engines — Gas-oil-fired gas turbines — Natural-gas-fired boilers, engines, and turbines — Iron and steel process gases — Process fuels from the chemical industry — IGCC plants | All sizes | Generic EN standards | Continuous ⁽⁶⁾ ⁽⁸⁾ | BAT 20 BAT 24 BAT 28 BAT 33 BAT 38 BAT 44 BAT 49 BAT 56 BAT 64 BAT 65 BAT 73 | | |
| | <ul style="list-style-type: none"> — Combustion plants on offshore platforms | All sizes | EN 15058 | Once every year ⁽⁹⁾ | BAT 54 | | |
| SO ₂ | <ul style="list-style-type: none"> — Coal and/or lignite incl waste co-incineration — Solid biomass and/or peat incl waste co-incineration | All sizes | Generic EN standards and EN 14791 | Continuous ⁽⁶⁾ ⁽¹¹⁾ ⁽¹²⁾ | BAT 21 BAT 25 BAT 29 BAT 34 BAT 39 BAT 50 BAT 57 | | |

| BAT Concn. Number | Summary of BAT Conclusion requirement | | | | | | Status NA/ CC / FC / NC | Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement |
|-------------------------|---------------------------------------|--|-----------|--|--|--|-------------------------------|--|
| | | <ul style="list-style-type: none"> — HFO- and/or gas-oil-fired boilers — HFO- and/or gas-oil-fired engines — Gas-oil-fired gas turbines — Iron and steel process gases — Process fuels from the chemical industry in boilers — IGCC plants | | | | BAT 66 BAT 67 BAT 74 | | |
| | SO ₃ | — When SCR is used | All sizes | No EN standard available | Once every year | — | | |
| | Gaseous chlorides, expressed as HCl | <ul style="list-style-type: none"> — Coal and/or lignite — Process fuels from the chemical industry in boilers | All sizes | EN 1911 | Once every three months ⁽⁶⁾ ⁽¹³⁾ ⁽¹⁴⁾ | BAT 21 BAT 57 | | |
| | | — Solid biomass and/or peat | All sizes | Generic EN standards | Continuous ⁽¹⁵⁾ ⁽¹⁶⁾ | BAT 25 | | |
| | | — Waste co-incineration | All sizes | Generic EN standards | Continuous ⁽⁶⁾ ⁽¹⁶⁾ | BAT 66 BAT 67 | | |
| | HF | <ul style="list-style-type: none"> — Coal and/or lignite — Process fuels from the chemical industry in boilers | All sizes | No EN standard available | Once every three months ⁽⁶⁾ ⁽¹³⁾ ⁽¹⁴⁾ | BAT 21 BAT 57 | | |
| | | — Solid biomass and/or peat | All sizes | No EN standard available | Once every year | BAT 25 | | |
| | | — Waste co-incineration | All sizes | Generic EN standards | Continuous ⁽⁶⁾ ⁽¹⁶⁾ | BAT 66 BAT 67 | | |
| | Dust | <ul style="list-style-type: none"> — Coal and/or lignite — Solid biomass and/or peat — HFO- and/or gas-oil-fired boilers | All sizes | Generic EN standards and EN 13284-1 and EN 13284-2 | Continuous ⁽⁶⁾ ⁽¹⁷⁾ | BAT 22 BAT 26 BAT 30 BAT 35 BAT 39 BAT 51 BAT 58 | | |

| BAT Concn. Number | Summary of BAT Conclusion requirement | | | | | Status NA/ CC / FC / NC | Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement |
|--|---|------------------------|-------------------------------------|---|--|----------------------------|---|
| | <ul style="list-style-type: none"> — Iron and steel process gases — Process fuels from the chemical industry in boilers — IGCC plants — HFO- and/or gas-oil-fired engines — Gas-oil-fired gas turbines | | | | | BAT 75 | |
| | <ul style="list-style-type: none"> — Waste co-incineration | All sizes | Generic EN standards and EN 13284-2 | Continuous | | BAT 68 BAT 69 | |
| Metals and metalloids except mercury (As, Cd, Co, Cr, Cu, Mn, Ni, Pb, Sb, Se, Ti, V, Zn) | <ul style="list-style-type: none"> — Coal and/or lignite — Solid biomass and/or peat — HFO- and/or gas-oil-fired boilers and engines | All sizes | EN 14385 | Once every year ₍₁₈₎ | | BAT 22 BAT 26 BAT 30 | |
| | <ul style="list-style-type: none"> — Waste co-incineration | < 300 MW _{th} | EN 14385 | Once every six months ₍₁₃₎ | | BAT 68 BAT 69 | |
| | | ≥ 300 MW _{th} | EN 14385 | Once every three months ₍₁₉₎ ₍₁₃₎ | | | |
| | <ul style="list-style-type: none"> — IGCC plants | ≥ 100 MW _{th} | EN 14385 | Once every year ₍₁₈₎ | | BAT 75 | |
| Hg | <ul style="list-style-type: none"> — Coal and/or lignite including waste co-incineration | < 300 MW _{th} | EN 13211 | Once every three months ₍₁₃₎ ₍₂₀₎ | | BAT 23 | |
| | | ≥ 300 MW _{th} | Generic EN standards and EN 14884 | Continuous ₍₁₆₎ ₍₂₁₎ | | | |
| | <ul style="list-style-type: none"> — Solid biomass and/or peat | All sizes | EN 13211 | Once every year ₍₂₂₎ | | BAT 27 | |
| | <ul style="list-style-type: none"> — Waste co-incineration with solid biomass and/or peat | All sizes | EN 13211 | Once every three months ₍₁₃₎ | | BAT 70 | |
| | <ul style="list-style-type: none"> — IGCC plants | ≥ 100 MW _{th} | EN 13211 | Once every year ₍₂₃₎ | | BAT 75 | |
| TVOC | <ul style="list-style-type: none"> — HFO- and/or gas-oil-fired engines | All sizes | EN 12619 | Once every six months ₍₁₃₎ | | BAT 33 BAT 59 | |

| BAT Concn. Number | Summary of BAT Conclusion requirement | | | | | | Status NA/ CC / FC / NC | Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement | | |
|--|--|--|--------------------|---------------------------------|---|-----------------------------------|-------------------------|---|--|--|
| | | — Process fuels from chemical industry in boilers | | | | | | | | |
| | | — Waste co-incineration with coal, lignite, solid biomass and/or peat | All sizes | Generic EN standards | Continuous | BAT 71 | | | | |
| Formaldehyde | | — Natural-gas in spark-ignited lean-burn gas and dual fuel engines | All sizes | No EN standard available | Once every year | BAT 45 | | | | |
| CH ₄ | | — Natural-gas-fired engines | All sizes | EN ISO 25139 | Once every year ⁽²⁴⁾ | BAT 45 | | | | |
| PCDD/F | | — Process fuels from chemical industry in boilers — Waste co-incineration | All sizes | EN 1948-1, EN 1948-2, EN 1948-3 | Once every six months ⁽¹³⁾ ⁽²⁵⁾ | BAT 59 BAT 71 | | | | |
| 5 | BAT is to monitor emissions to water from flue-gas treatment with at least the frequency given below and in accordance with EN standards. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality. | | | | | | NA | No flue-gas treatment. | | |
| | Substance/Parameter | | Standard(s) | | Minimum monitoring frequency | Monitoring associated with | | | | |
| Total organic carbon (TOC) ⁽²⁶⁾ | EN 1484 | | | | Once every month | BAT 15 | | | | |
| Chemical oxygen demand (COD) ⁽²⁶⁾ | No EN standard available | | | | | | | | | |
| Total suspended solids (TSS) | EN 872 | | | | | | | | | |
| Fluoride (F ⁻) | EN ISO 10304-1 | | | | | | | | | |
| Sulphate (SO ₄ ²⁻) | EN ISO 10304-1 | | | | | | | | | |
| Sulphide, easily released (S ²⁻) | No EN standard available | | | | | | | | | |
| Sulphite (SO ₃ ²⁻) | EN ISO 10304-3 | | | | | | | | | |
| Metals and metalloids | As | Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2) | | | | | | | | |
| | Cd | | | | | | | | | |
| | Cr | | | | | | | | | |

| BAT Concn. Number | Summary of BAT Conclusion requirement | Status NA/ CC / FC / NC | Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
|--|--|--|---|---------------|-----------------------------|--|----------------------|---|---|----------------------------|--------------------------------|---|--|---|---|----------------|--|--|----|--|--|-----------------------------|--|--|---|----------------|--|----------|---|--|--|
| | <table border="1"> <tr> <td data-bbox="331 389 595 531"></td> <td data-bbox="595 389 663 416">Cu</td> <td data-bbox="663 389 1025 531"></td> <td data-bbox="1025 389 1267 531"></td> </tr> <tr> <td></td> <td data-bbox="595 416 663 443">Ni</td> <td></td> <td></td> </tr> <tr> <td></td> <td data-bbox="595 443 663 470">Pb</td> <td></td> <td></td> </tr> <tr> <td></td> <td data-bbox="595 470 663 497">Zn</td> <td></td> <td></td> </tr> <tr> <td></td> <td data-bbox="595 497 663 531">Hg</td> <td data-bbox="663 497 1025 531">Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)</td> <td></td> </tr> <tr> <td data-bbox="331 531 595 587">Chloride (Cl⁻)</td> <td></td> <td data-bbox="663 531 1025 587">Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)</td> <td data-bbox="1025 531 1267 587">—</td> </tr> <tr> <td data-bbox="331 587 595 683">Total nitrogen</td> <td></td> <td data-bbox="663 587 1025 683">EN 12260</td> <td data-bbox="1025 587 1267 683">—</td> </tr> </table> | | Cu | | | | Ni | | | | Pb | | | | Zn | | | | Hg | Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852) | | Chloride (Cl ⁻) | | Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682) | — | Total nitrogen | | EN 12260 | — | | |
| | Cu | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | Ni | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | Pb | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | Zn | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | Hg | Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852) | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Chloride (Cl ⁻) | | Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682) | — | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Total nitrogen | | EN 12260 | — | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 6 | <p>In order to improve the general environmental performance of combustion plants and to reduce emissions to air of CO and unburnt substances, BAT is to ensure optimised combustion and to use an appropriate combination of the techniques given below.</p> <table border="1"> <thead> <tr> <th data-bbox="331 794 555 821">Technique</th> <th data-bbox="555 794 994 821">Description</th> <th data-bbox="994 794 1491 821">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="331 821 555 917">a. Fuel blending and mixing</td> <td data-bbox="555 821 994 917">Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type</td> <td data-bbox="994 821 1491 917" rowspan="2">Generally applicable</td> </tr> <tr> <td data-bbox="331 917 555 997">b. Maintenance of the combustion system</td> <td data-bbox="555 917 994 997">Regular planned maintenance according to suppliers' recommendations</td> </tr> <tr> <td data-bbox="331 997 555 1077">c. Advanced control system</td> <td data-bbox="555 997 994 1077">See description in Section 8.1</td> <td data-bbox="994 997 1491 1077">The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> <tr> <td data-bbox="331 1077 555 1157">d. Good design of the combustion equipment</td> <td data-bbox="555 1077 994 1157">Good design of furnace, combustion chambers, burners and associated devices</td> <td data-bbox="994 1077 1491 1157">Generally applicable to new combustion plants</td> </tr> <tr> <td data-bbox="331 1157 555 1324">e. Fuel choice</td> <td data-bbox="555 1157 994 1324">Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used</td> <td data-bbox="994 1157 1491 1324">Applicable within the constraints associated with the availability of suitable types of fuel with a better environmental profile as a whole, which may be impacted by the energy policy of the Member State, or by the integrated site's fuel balance in the case of combustion of industrial process fuels.</td> </tr> </tbody> </table> | Technique | Description | Applicability | a. Fuel blending and mixing | Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type | Generally applicable | b. Maintenance of the combustion system | Regular planned maintenance according to suppliers' recommendations | c. Advanced control system | See description in Section 8.1 | The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system | d. Good design of the combustion equipment | Good design of furnace, combustion chambers, burners and associated devices | Generally applicable to new combustion plants | e. Fuel choice | Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used | Applicable within the constraints associated with the availability of suitable types of fuel with a better environmental profile as a whole, which may be impacted by the energy policy of the Member State, or by the integrated site's fuel balance in the case of combustion of industrial process fuels. | CC | <p>Fuel blending and mixing - the LCPs are run on natural gas, there are no backup or start up fuels. There is no requirement to blend or mix fuels.</p> <p>Maintenance of the combustion system - National Grid operates a preventative maintenance management system which is certified to both PAS 55 and ISO 55001. The maintenance system identifies all site plant and equipment and details the frequency and requirements for the maintenance set by the manufacturer, British and international standards and input from incidents and failures.</p> <p>Advanced Control Systems – The control system controls parameters on the combustion</p> | | | | | | | | | | | |
| Technique | Description | Applicability | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| a. Fuel blending and mixing | Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type | Generally applicable | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| b. Maintenance of the combustion system | Regular planned maintenance according to suppliers' recommendations | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| c. Advanced control system | See description in Section 8.1 | The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| d. Good design of the combustion equipment | Good design of furnace, combustion chambers, burners and associated devices | Generally applicable to new combustion plants | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| e. Fuel choice | Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used | Applicable within the constraints associated with the availability of suitable types of fuel with a better environmental profile as a whole, which may be impacted by the energy policy of the Member State, or by the integrated site's fuel balance in the case of combustion of industrial process fuels. | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

| BAT Concn. Numbe r | Summary of BAT Conclusion requirement | Status NA/ CC / FC / NC | Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement | | | |
|-----------------------------|---|---|--|---|--|--|
| | <table border="1" data-bbox="331 392 1491 475"> <tr> <td data-bbox="331 392 367 475"></td> <td data-bbox="367 392 555 475"></td> <td data-bbox="555 392 1491 475">For existing combustion plants, the type of fuel chosen may be limited by the configuration and the design of the plant</td> </tr> </table> | | | For existing combustion plants, the type of fuel chosen may be limited by the configuration and the design of the plant | | <p>system to reduce emissions to within the required limits.</p> <p>Good design of the combustion equipment – All units are more than 20 years old and of a design that maximises the combustion system. The operator confirms that the units are able to achieve the relevant emission limits.</p> <p>Fuel Choice – The LCPs are operated using natural gas, there are no backup or start up fuels. Natural gas quality is determined by the Gas Supply and Management Regulations (GSMR) and requires the gas to be controlled with in tight limits for quality, contents (low sulphur) and combustion characteristics. Natural gas is considered to represent the fuel with the best environmental profile for this installation.</p> |
| | | For existing combustion plants, the type of fuel chosen may be limited by the configuration and the design of the plant | | | | |

| BAT Concn. Number | Summary of BAT Conclusion requirement | Status NA/ CC / FC / NC | Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement | | | | | | |
|-------------------|---|-------------------------|---|--------------|-------|--|------------|----|---|
| 7 | <p>In order to reduce emissions of ammonia to air from the use of selective catalytic reduction (SCR) and/or selective non-catalytic reduction (SNCR) for the abatement of NO_x emissions, BAT is to optimise the design and/or operation of SCR and/or SNCR (e.g. optimised reagent to NO_x ratio, homogeneous reagent distribution and optimum size of the reagent drops).</p> <p>BAT-associated emission levels</p> <p>The BAT-associated emission level (BAT-AEL) for emissions of NH₃ to air from the use of SCR and/or SNCR is < 3–10 mg/Nm³ as a yearly average or average over the sampling period. The lower end of the range can be achieved when using SCR and the upper end of the range can be achieved when using SNCR without wet abatement techniques. In the case of plants combusting biomass and operating at variable loads as well as in the case of engines combusting HFO and/or gas oil, the higher end of the BAT-AEL range is 15 mg/Nm³.</p> | NA | Not applicable - no SCR or SNCR on site. | | | | | | |
| 8 | <p>In order to prevent or reduce emissions to air during normal operating conditions, BAT is to ensure, by appropriate design, operation and maintenance, that the emission abatement systems are used at optimal capacity and availability.</p> | NA | Not applicable as there is no emission abatement systems in operation at the installation. | | | | | | |
| 9 | <p>In order to improve the general environmental performance of combustion and/or gasification plants and to reduce emissions to air, BAT is to include the following elements in the quality assurance/quality control programmes for all the fuels used, as part of the environmental management system (see BAT 1):</p> <ul style="list-style-type: none"> (i) Initial full characterisation of the fuel used including at least the parameters listed below and in accordance with EN standards. ISO, national or other international standards may be used provided they ensure the provision of data of an equivalent scientific quality; (ii) Regular testing of the fuel quality to check that it is consistent with the initial characterisation and according to the plant design specifications. The frequency of testing and the parameters chosen from the table below are based on the variability of the fuel and an assessment of the relevance of pollutant releases (e.g. concentration in fuel, flue-gas treatment employed); (iii) Subsequent adjustment of the plant settings as and when needed and practicable (e.g. integration of the fuel characterisation and control in the advanced control system (see description in Section 8.1)). <p>Description</p> <p>Initial characterisation and regular testing of the fuel can be performed by the operator and/or the fuel supplier. If performed by the supplier, the full results are provided to the operator in the form of a product (fuel) supplier specification and/or guarantee.</p> <table border="1" data-bbox="322 1254 1494 1372"> <thead> <tr> <th data-bbox="322 1254 712 1289">Fuel(s)</th> <th data-bbox="712 1254 1494 1289">Substances/Parameters subject to characterisation</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 1289 712 1324">Biomass/peat</td> <td data-bbox="712 1289 1494 1324">— LHV</td> </tr> <tr> <td data-bbox="322 1324 712 1372"></td> <td data-bbox="712 1324 1494 1372">— moisture</td> </tr> </tbody> </table> | Fuel(s) | Substances/Parameters subject to characterisation | Biomass/peat | — LHV | | — moisture | CC | LCPs are fired on Natural Gas only. This gas has to meet a nationally agreed specification for all the parameters listed. We consider that for plants which burn natural gas from the National Grid as a fuel that it is not necessary for the operator to replicate the testing carried out by the National Grid |
| Fuel(s) | Substances/Parameters subject to characterisation | | | | | | | | |
| Biomass/peat | — LHV | | | | | | | | |
| | — moisture | | | | | | | | |

| BAT Concn. Number | Summary of BAT Conclusion requirement | Status NA/ CC / FC / NC | Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement | | | | | | | | | | | | | | | | |
|--|--|-------------------------|---|--------------|--|-----|---|---------|--|-------------|--|--|---|------------------------------|---|-----------------------|--|--|--|
| | <table border="1"> <tr> <td data-bbox="322 384 712 507"></td> <td data-bbox="712 384 1491 507"> <ul style="list-style-type: none"> — Ash — C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn) </td> </tr> <tr> <td data-bbox="322 507 712 719">Coal/lignite</td> <td data-bbox="712 507 1491 719"> <ul style="list-style-type: none"> — LHV — Moisture — Volatiles, ash, fixed carbon, C, H, N, O, S — Br, Cl, F — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) </td> </tr> <tr> <td data-bbox="322 719 712 804">HFO</td> <td data-bbox="712 719 1491 804"> <ul style="list-style-type: none"> — Ash — C, S, N, Ni, V </td> </tr> <tr> <td data-bbox="322 804 712 888">Gas oil</td> <td data-bbox="712 804 1491 888"> <ul style="list-style-type: none"> — Ash — N, C, S </td> </tr> <tr> <td data-bbox="322 888 712 971">Natural gas</td> <td data-bbox="712 888 1491 971"> <ul style="list-style-type: none"> — LHV — CH₄, C₂H₆, C₃, C₄₊, CO₂, N₂, Wobbe index </td> </tr> <tr> <td data-bbox="322 971 712 1056">Process fuels from the chemical industry⁽²⁷⁾</td> <td data-bbox="712 971 1491 1056"> <ul style="list-style-type: none"> — Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) </td> </tr> <tr> <td data-bbox="322 1056 712 1125">Iron and steel process gases</td> <td data-bbox="712 1056 1491 1125"> <ul style="list-style-type: none"> — LHV, CH₄ (for COG), C_xH_y (for COG), CO₂, H₂, N₂, total sulphur, dust, Wobbe index </td> </tr> <tr> <td data-bbox="322 1125 712 1283">Waste⁽²⁸⁾</td> <td data-bbox="712 1125 1491 1283"> <ul style="list-style-type: none"> — LHV — Moisture — Volatiles, ash, Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) </td> </tr> </table> | | <ul style="list-style-type: none"> — Ash — C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn) | Coal/lignite | <ul style="list-style-type: none"> — LHV — Moisture — Volatiles, ash, fixed carbon, C, H, N, O, S — Br, Cl, F — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) | HFO | <ul style="list-style-type: none"> — Ash — C, S, N, Ni, V | Gas oil | <ul style="list-style-type: none"> — Ash — N, C, S | Natural gas | <ul style="list-style-type: none"> — LHV — CH₄, C₂H₆, C₃, C₄₊, CO₂, N₂, Wobbe index | Process fuels from the chemical industry ⁽²⁷⁾ | <ul style="list-style-type: none"> — Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) | Iron and steel process gases | <ul style="list-style-type: none"> — LHV, CH₄ (for COG), C_xH_y (for COG), CO₂, H₂, N₂, total sulphur, dust, Wobbe index | Waste ⁽²⁸⁾ | <ul style="list-style-type: none"> — LHV — Moisture — Volatiles, ash, Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) | | |
| | <ul style="list-style-type: none"> — Ash — C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn) | | | | | | | | | | | | | | | | | | |
| Coal/lignite | <ul style="list-style-type: none"> — LHV — Moisture — Volatiles, ash, fixed carbon, C, H, N, O, S — Br, Cl, F — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) | | | | | | | | | | | | | | | | | | |
| HFO | <ul style="list-style-type: none"> — Ash — C, S, N, Ni, V | | | | | | | | | | | | | | | | | | |
| Gas oil | <ul style="list-style-type: none"> — Ash — N, C, S | | | | | | | | | | | | | | | | | | |
| Natural gas | <ul style="list-style-type: none"> — LHV — CH₄, C₂H₆, C₃, C₄₊, CO₂, N₂, Wobbe index | | | | | | | | | | | | | | | | | | |
| Process fuels from the chemical industry ⁽²⁷⁾ | <ul style="list-style-type: none"> — Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) | | | | | | | | | | | | | | | | | | |
| Iron and steel process gases | <ul style="list-style-type: none"> — LHV, CH₄ (for COG), C_xH_y (for COG), CO₂, H₂, N₂, total sulphur, dust, Wobbe index | | | | | | | | | | | | | | | | | | |
| Waste ⁽²⁸⁾ | <ul style="list-style-type: none"> — LHV — Moisture — Volatiles, ash, Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) | | | | | | | | | | | | | | | | | | |
| 10 | In order to reduce emissions to air and/or to water during other than normal operating conditions (OTNOC), BAT is to set up and implement a management plan as part of the environmental management system (see BAT 1), commensurate with the relevance of potential pollutant releases, that includes the following elements: | CC | The LCPs control systems monitor critical gas turbine running | | | | | | | | | | | | | | | | |

| BAT Concn. Number | Summary of BAT Conclusion requirement | Status NA/ CC / FC / NC | Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement | | | | | | | | | | | | | | | |
|-------------------|--|--|---|---------------|----|-------------------------|--|----|---|--|----|---------------------------------|--|----|------------------------------------|---|----|---|
| | <ul style="list-style-type: none"> — appropriate design of the systems considered relevant in causing OTNOC that may have an impact on emissions to air, water and/or soil (e.g. low-load design concepts for reducing the minimum start-up and shutdown loads for stable generation in gas turbines), — set-up and implementation of a specific preventive maintenance plan for these relevant systems, — review and recording of emissions caused by OTNOC and associated circumstances and implementation of corrective actions if necessary, — periodic assessment of the overall emissions during OTNOC (e.g. frequency of events, duration, emissions quantification/estimation) and implementation of corrective actions if necessary. | | parameters and shut down in case of malfunction and OTNOC. | | | | | | | | | | | | | | | |
| 11 | <p>BAT is to appropriately monitor emissions to air and/or to water during OTNOC.</p> <p>Description The monitoring can be carried out by direct measurement of emissions or by monitoring of surrogate parameters if this proves to be of equal or better scientific quality than the direct measurement of emissions. Emissions during start-up and shutdown (SU/SD) may be assessed based on a detailed emission measurement carried out for a typical SU/SD procedure at least once every year, and using the results of this measurement to estimate the emissions for each and every SU/SD throughout the year.</p> | CC | The LCPs control systems monitor critical gas turbine running parameters and shut down in case of malfunction and OTNOC. | | | | | | | | | | | | | | | |
| 12 | <p>In order to increase the energy efficiency of combustion, gasification and/or IGCC units operated $\geq 1\,500$ h/yr, BAT is to use an appropriate combination of the techniques given below.</p> <table border="1" data-bbox="322 911 1494 1358"> <thead> <tr> <th data-bbox="322 911 577 951">Technique</th> <th data-bbox="577 911 1059 951">Description</th> <th data-bbox="1059 911 1494 951">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 951 367 1054">a.</td> <td data-bbox="367 951 577 1054">Combustion optimisation</td> <td data-bbox="577 951 1059 1054">See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues</td> </tr> <tr> <td data-bbox="322 1054 367 1190">b.</td> <td data-bbox="367 1054 577 1190">Optimisation of the working medium conditions</td> <td data-bbox="577 1054 1059 1190">Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO_x emissions or the characteristics of energy demanded</td> </tr> <tr> <td data-bbox="322 1190 367 1294">c.</td> <td data-bbox="367 1190 577 1294">Optimisation of the steam cycle</td> <td data-bbox="577 1190 1059 1294">Operate with lower turbine exhaust pressure by utilisation of the lowest possible temperature of the condenser cooling water, within the design conditions</td> </tr> <tr> <td data-bbox="322 1294 367 1358">d.</td> <td data-bbox="367 1294 577 1358">Minimisation of energy consumption</td> <td data-bbox="577 1294 1059 1358">Minimising the internal energy consumption (e.g. greater efficiency of the feed-water pump)</td> </tr> </tbody> </table> | Technique | Description | Applicability | a. | Combustion optimisation | See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues | b. | Optimisation of the working medium conditions | Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO _x emissions or the characteristics of energy demanded | c. | Optimisation of the steam cycle | Operate with lower turbine exhaust pressure by utilisation of the lowest possible temperature of the condenser cooling water, within the design conditions | d. | Minimisation of energy consumption | Minimising the internal energy consumption (e.g. greater efficiency of the feed-water pump) | CC | <p>Combustion optimisation -Dry Low Emission (DLE) lean burn pre-mixed combustion system ensures that fuel and air are pre-mixed prior to combustion to give a more homogenous reaction (flame) temperature below the temperatures at which thermal NO_x production rates are elevated</p> <p>Optimisation of the working medium conditions - Operation of compressor units are aimed to be at optimum efficiency with the constraints of the system and supply/demand gas patterns, all medium used is pre-defined in the Gas Safety management Regulations (GSMR)</p> |
| Technique | Description | Applicability | | | | | | | | | | | | | | | | |
| a. | Combustion optimisation | See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues | | | | | | | | | | | | | | | | |
| b. | Optimisation of the working medium conditions | Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO _x emissions or the characteristics of energy demanded | | | | | | | | | | | | | | | | |
| c. | Optimisation of the steam cycle | Operate with lower turbine exhaust pressure by utilisation of the lowest possible temperature of the condenser cooling water, within the design conditions | | | | | | | | | | | | | | | | |
| d. | Minimisation of energy consumption | Minimising the internal energy consumption (e.g. greater efficiency of the feed-water pump) | | | | | | | | | | | | | | | | |

| BAT Concn. Numbe r | Summary of BAT Conclusion requirement | | | | Status NA/ CC / FC / NC | Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement |
|-----------------------------|--|--|--|--|-------------------------------|--|
| | e. | Preheating of combustion air | Reuse of part of the heat recovered from the combustion flue-gas to preheat the air used in combustion | Generally applicable within the constraints related to the need to control NO _x emissions | | <p>Minimisation of energy consumption - Gas turbine, Power Turbine, and Gas Compressor are sized and optimised for the duty required</p> <p>Pre-heating of combustion air - Only used where anti-icing techniques are employed at low ambient temperatures.</p> <p>Fuel pre-heating - preheating by natural gas boilers and oil to gas heat exchanger.</p> <p>Advanced control system - The DLE system is governed by the overall automatic combustion control system, which is controlled and monitored by programmable logic controllers (PLC)</p> |
| f. | Fuel preheating | Preheating of fuel using recovered heat | Generally applicable within the constraints associated with the boiler design and the need to control NO _x emissions | | | |
| g. | Advanced control system | See description in Section 8.2. Computerised control of the main combustion parameters enables the combustion efficiency to be improved | Generally applicable to new units. The applicability to old units may be constrained by the need to retrofit the combustion system and/or control command system | | | |
| h. | Feed-water preheating using recovered heat | Preheat water coming out of the steam condenser with recovered heat, before reusing it in the boiler | Only applicable to steam circuits and not to hot boilers. Applicability to existing units may be limited due to constraints associated with the plant configuration and the amount of recoverable heat | | | |
| i. | Heat recovery by cogeneration (CHP) | Recovery of heat (mainly from the steam system) for producing hot water/steam to be used in industrial processes/activities or in a public network for district heating. Additional heat recovery is possible from: <ul style="list-style-type: none"> — flue-gas — grate cooling — circulating fluidised bed | Applicable within the constraints associated with the local heat and power demand. The applicability may be limited in the case of gas compressors with an unpredictable operational heat profile | | | |
| j. | CHP readiness | See description in Section 8.2. | Only applicable to new units where there is a realistic potential for the future use of heat in the vicinity of the unit | | | |
| k. | Flue-gas condenser | See description in Section 8.2. | Generally applicable to CHP units provided there is enough demand for low-temperature heat | | | |
| l. | Heat accumulation | Heat accumulation storage in CHP mode | Only applicable to CHP plants. The applicability may be limited in the case of low heat load demand | | | |
| m. | Wet stack | See description in Section 8.2. | Generally applicable to new and existing units fitted with wet FGD | | | |

| BAT Concn. Number | Summary of BAT Conclusion requirement | | | | Status NA/ CC / FC / NC | Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement |
|-------------------|---------------------------------------|--|--|---|-------------------------|---|
| | n. | Cooling tower discharge | The release of emissions to air through a cooling tower and not via a dedicated stack | Only applicable to units fitted with wet FGD where reheating of the flue-gas is necessary before release, and where the unit cooling system is a cooling tower | | |
| | o. | Fuel pre-drying | The reduction of fuel moisture content before combustion to improve combustion conditions | Applicable to the combustion of biomass and/or peat within the constraints associated with spontaneous combustion risks (e.g. the moisture content of peat is kept above 40 % throughout the delivery chain). The retrofit of existing plants may be restricted by the extra calorific value that can be obtained from the drying operation and by the limited retrofit possibilities offered by some boiler designs or plant configurations | | |
| | p. | Minimisation of heat losses | Minimising residual heat losses, e.g. those that occur via the slag or those that can be reduced by insulating radiating sources | Only applicable to solid-fuel-fired combustion units and to gasification/IGCC units | | |
| | q. | Advanced materials | Use of advanced materials proven to be capable of withstanding high operating temperatures and pressures and thus to achieve increased steam/combustion process efficiencies | Only applicable to new plants | | |
| | r. | Steam turbine upgrades | This includes techniques such as increasing the temperature and pressure of medium-pressure steam, addition of a low-pressure turbine, and modifications to the geometry of the turbine rotor blades | The applicability may be restricted by demand, steam conditions and/or limited plant lifetime | | |
| | s. | Supercritical and ultra-supercritical steam conditions | Use of a steam circuit, including steam reheating systems, in which steam can reach pressures above 220,6 bar and temperatures above 374 °C in the case of supercritical conditions, and above 250 – 300 bar and temperatures above 580 – 600 °C in the case of ultra-supercritical conditions | Only applicable to new units of $\geq 600 \text{ MW}_{\text{th}}$ operated $> 4\,000 \text{ h/yr}$. Not applicable when the purpose of the unit is to produce low steam temperatures and/or pressures in process industries. Not applicable to gas turbines and engines generating steam in CHP mode. For units combusting biomass, the applicability may be constrained by high-temperature corrosion in the case of certain biomasses | | |

| BAT Concn. Number | Summary of BAT Conclusion requirement | Status NA/ CC / FC / NC | Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement | | | | | | | | | |
|----------------------------|---|---|---|---------------|--------------------|--|---|----------------------------|--|---|----|---|
| 13 | <p>In order to reduce water usage and the volume of contaminated waste water discharged, BAT is to use one or both of the techniques given below.</p> <table border="1" data-bbox="322 440 1491 743"> <thead> <tr> <th data-bbox="322 440 521 475">Technique</th> <th data-bbox="521 440 1066 475">Description</th> <th data-bbox="1066 440 1491 475">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 475 521 608">a. Water recycling</td> <td data-bbox="521 475 1066 608">Residual aqueous streams, including run-off water, from the plant are reused for other purposes. The degree of recycling is limited by the quality requirements of the recipient water stream and the water balance of the plant</td> <td data-bbox="1066 475 1491 608">Not applicable to waste water from cooling systems when water treatment chemicals and/or high concentrations of salts from seawater are present</td> </tr> <tr> <td data-bbox="322 608 521 743">b. Dry bottom ash handling</td> <td data-bbox="521 608 1066 743">Dry, hot bottom ash falls from the furnace onto a mechanical conveyor system and is cooled down by ambient air. No water is used in the process.</td> <td data-bbox="1066 608 1491 743">Only applicable to plants combusting solid fuels. There may be technical restrictions that prevent retrofitting to existing combustion plants</td> </tr> </tbody> </table> | Technique | Description | Applicability | a. Water recycling | Residual aqueous streams, including run-off water, from the plant are reused for other purposes. The degree of recycling is limited by the quality requirements of the recipient water stream and the water balance of the plant | Not applicable to waste water from cooling systems when water treatment chemicals and/or high concentrations of salts from seawater are present | b. Dry bottom ash handling | Dry, hot bottom ash falls from the furnace onto a mechanical conveyor system and is cooled down by ambient air. No water is used in the process. | Only applicable to plants combusting solid fuels. There may be technical restrictions that prevent retrofitting to existing combustion plants | NA | Water is not used in the process of gas turbine driven mechanical drive gas compression in operation at the installation. |
| Technique | Description | Applicability | | | | | | | | | | |
| a. Water recycling | Residual aqueous streams, including run-off water, from the plant are reused for other purposes. The degree of recycling is limited by the quality requirements of the recipient water stream and the water balance of the plant | Not applicable to waste water from cooling systems when water treatment chemicals and/or high concentrations of salts from seawater are present | | | | | | | | | | |
| b. Dry bottom ash handling | Dry, hot bottom ash falls from the furnace onto a mechanical conveyor system and is cooled down by ambient air. No water is used in the process. | Only applicable to plants combusting solid fuels. There may be technical restrictions that prevent retrofitting to existing combustion plants | | | | | | | | | | |
| 14 | <p>In order to prevent the contamination of uncontaminated waste water and to reduce emissions to water, BAT is to segregate waste water streams and to treat them separately, depending on the pollutant content.</p> <p>Description Waste water streams that are typically segregated and treated include surface run-off water, cooling water, and waste water from flue-gas treatment.</p> <p>Applicability The applicability may be restricted in the case of existing plants due to the configuration of the drainage systems.</p> | CC | <p>Water is not used in the process and there is no direct water based effluent from the operation of the gas turbines on site.</p> <p>A small amount of water (20 to 50 litres) is used with detergent to complete a "wash" of the gas turbine, to clean out combustion and airborne debris from the turbine internals. This is done on a monitored condition basis and frequency is determined by the run time of the plant. All of the water used to complete washing is contaminated. It is collected, segregated and disposed of as hazardous waste.</p> <p>There are no discharges to sewer from the installation. Domestic discharges from the facilities in</p> | | | | | | | | | |

| BAT Concn. Number | Summary of BAT Conclusion requirement | Status NA/ CC / FC / NC | Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement | | | | | | | | | | | | | | | | | | |
|---|--|---|---|---------------|---------------------------|--|--|----|--|---|---|--|--|----|--------------------------------|---|----|------------------------------|---|----|---|
| | | | <p>the control building are directed to a domestic effluent holding tank. The contents of the tank are pumped out, by a third-party contractor, on a regular basis.</p> <p>No process effluent is discharged from emission point W1. All surface water passes through the installation's main interceptor to remove any residual oil collected from site run-off, prior to being discharged to W1.</p> <p>A programme of visual inspection of the discharge, for oil and grease, is in place to ensure efficiency of the oil interceptor.</p> | | | | | | | | | | | | | | | | | | |
| 15 | <p>In order to reduce emissions to water from flue-gas treatment, BAT is to use an appropriate combination of the techniques given below, and to use secondary techniques as close as possible to the source in order to avoid dilution.</p> <table border="1" data-bbox="322 1011 1491 1370"> <thead> <tr> <th data-bbox="322 1011 712 1070">Technique</th> <th data-bbox="712 1011 1025 1070">Typical pollutants prevented/abated</th> <th data-bbox="1025 1011 1491 1070">Applicability</th> </tr> </thead> <tbody> <tr> <td colspan="3" data-bbox="322 1070 1491 1107" style="text-align: center;">Primary techniques</td> </tr> <tr> <td data-bbox="322 1107 367 1193">a.</td> <td data-bbox="367 1107 712 1193">Optimised combustion (see BAT 6) and flue-gas treatment systems (e.g. SCR/SNCR, see BAT 7)</td> <td data-bbox="712 1107 1491 1193">Organic compounds, ammonia (NH₃) Generally applicable</td> </tr> <tr> <td colspan="3" data-bbox="322 1193 1491 1230" style="text-align: center;">Secondary techniques ⁽²⁹⁾</td> </tr> <tr> <td data-bbox="322 1230 367 1289">b.</td> <td data-bbox="367 1230 712 1289">Adsorption on activated carbon</td> <td data-bbox="712 1230 1491 1289">Organic compounds, mercury (Hg) Generally applicable</td> </tr> <tr> <td data-bbox="322 1289 367 1370">c.</td> <td data-bbox="367 1289 712 1370">Aerobic biological treatment</td> <td data-bbox="712 1289 1491 1370">Biodegradable organic compounds, ammonium (NH₄⁺) Generally applicable for the treatment of organic compounds. Aerobic biological treatment of ammonium (NH₄⁺) may not be applicable in the</td> </tr> </tbody> </table> | Technique | Typical pollutants prevented/abated | Applicability | Primary techniques | | | a. | Optimised combustion (see BAT 6) and flue-gas treatment systems (e.g. SCR/SNCR, see BAT 7) | Organic compounds, ammonia (NH ₃) Generally applicable | Secondary techniques ⁽²⁹⁾ | | | b. | Adsorption on activated carbon | Organic compounds, mercury (Hg) Generally applicable | c. | Aerobic biological treatment | Biodegradable organic compounds, ammonium (NH ₄ ⁺) Generally applicable for the treatment of organic compounds. Aerobic biological treatment of ammonium (NH ₄ ⁺) may not be applicable in the | NA | The plant does not have flue-gas treatment installed. |
| Technique | Typical pollutants prevented/abated | Applicability | | | | | | | | | | | | | | | | | | | |
| Primary techniques | | | | | | | | | | | | | | | | | | | | | |
| a. | Optimised combustion (see BAT 6) and flue-gas treatment systems (e.g. SCR/SNCR, see BAT 7) | Organic compounds, ammonia (NH ₃) Generally applicable | | | | | | | | | | | | | | | | | | | |
| Secondary techniques ⁽²⁹⁾ | | | | | | | | | | | | | | | | | | | | | |
| b. | Adsorption on activated carbon | Organic compounds, mercury (Hg) Generally applicable | | | | | | | | | | | | | | | | | | | |
| c. | Aerobic biological treatment | Biodegradable organic compounds, ammonium (NH ₄ ⁺) Generally applicable for the treatment of organic compounds. Aerobic biological treatment of ammonium (NH ₄ ⁺) may not be applicable in the | | | | | | | | | | | | | | | | | | | |

| BAT Concn. Number | Summary of BAT Conclusion requirement | | | Status NA/ CC / FC / NC | Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement |
|-------------------------|--|---|--|-------------------------------|--|
| | | | case of high chloride concentrations (i.e. around 10 g/l) | | |
| | d. | Anoxic/anaerobic biological treatment | Mercury (Hg), nitrate (NO ₃ ⁻), nitrite (NO ₂ ⁻) | Generally applicable | |
| | e. | Coagulation and flocculation | Suspended solids | Generally applicable | |
| | f. | Crystallisation | Metals and metalloids, sulphate (SO ₄ ²⁻), fluoride (F ⁻) | Generally applicable | |
| | g. | Filtration (e.g. sand filtration, microfiltration, ultrafiltration) | Suspended solids, metals | Generally applicable | |
| | h. | Flotation | Suspended solids, free oil | Generally applicable | |
| | i. | Ion exchange | Metals | Generally applicable | |
| | j. | Neutralisation | Acids, alkalis | Generally applicable | |
| | k. | Oxidation | Sulphide (S ²⁻), sulphite (SO ₃ ²⁻) | Generally applicable | |
| | l. | Precipitation | Metals and metalloids, sulphate (SO ₄ ²⁻), fluoride (F ⁻) | Generally applicable | |
| | m. | Sedimentation | Suspended solids | Generally applicable | |
| | n. | Stripping | Ammonia (NH ₃) | Generally applicable | |
| | The BAT-AELs refer to direct discharges to a receiving water body at the point where the emission leaves the installation. | | | | |
| | BAT-AELs for direct discharges to a receiving water body from flue-gas treatment | | | | |
| | Substance/Parameter | | BAT-AELs | | |
| | | | Daily average | | |
| | Total organic carbon (TOC) | | 20–50 mg/l ⁽³⁰⁾ ⁽³¹⁾ ⁽³²⁾ | | |
| | Chemical oxygen demand (COD) | | 60–150 mg/l ⁽³⁰⁾ ⁽³¹⁾ ⁽³²⁾ | | |
| | Total suspended solids (TSS) | | 10–30 mg/l | | |
| | Fluoride (F ⁻) | | 10–25 mg/l ⁽³²⁾ | | |
| | Sulphate (SO ₄ ²⁻) | | 1,3–2,0 g/l ⁽³²⁾ ⁽³³⁾ ⁽³⁴⁾ ⁽³⁵⁾ | | |
| | Sulphide (S ²⁻), easily released | | 0,1–0,2 mg/l ⁽³²⁾ | | |
| | Sulphite (SO ₃ ²⁻) | | 1–20 mg/l ⁽³²⁾ | | |
| | Metals and metalloids | As | 10–50 µg/l | | |

| BAT Concn. Number | Summary of BAT Conclusion requirement | Status NA/ CC / FC / NC | Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement | | | | | | | | | | | | | | | | | | | | | |
|---|---|---|---|---------------|---|---|--|---|--|---|---|---|---|----|--|------------|--|----|------------|--|----|-------------|--|--|
| | <table border="1"> <tr><td></td><td>Cd</td><td>2–5 µg/l</td></tr> <tr><td></td><td>Cr</td><td>10–50 µg/l</td></tr> <tr><td></td><td>Cu</td><td>10–50 µg/l</td></tr> <tr><td></td><td>Hg</td><td>0,2–3 µg/l</td></tr> <tr><td></td><td>Ni</td><td>10–50 µg/l</td></tr> <tr><td></td><td>Pb</td><td>10–20 µg/l</td></tr> <tr><td></td><td>Zn</td><td>50–200 µg/l</td></tr> </table> | | Cd | 2–5 µg/l | | Cr | 10–50 µg/l | | Cu | 10–50 µg/l | | Hg | 0,2–3 µg/l | | Ni | 10–50 µg/l | | Pb | 10–20 µg/l | | Zn | 50–200 µg/l | | |
| | Cd | 2–5 µg/l | | | | | | | | | | | | | | | | | | | | | | |
| | Cr | 10–50 µg/l | | | | | | | | | | | | | | | | | | | | | | |
| | Cu | 10–50 µg/l | | | | | | | | | | | | | | | | | | | | | | |
| | Hg | 0,2–3 µg/l | | | | | | | | | | | | | | | | | | | | | | |
| | Ni | 10–50 µg/l | | | | | | | | | | | | | | | | | | | | | | |
| | Pb | 10–20 µg/l | | | | | | | | | | | | | | | | | | | | | | |
| | Zn | 50–200 µg/l | | | | | | | | | | | | | | | | | | | | | | |
| 16 | <p>In order to reduce the quantity of waste sent for disposal from the combustion and/or gasification process and abatement techniques, BAT is to organise operations so as to maximise, in order of priority and taking into account life-cycle thinking:</p> <p>(a) waste prevention, e.g. maximise the proportion of residues which arise as by-products;</p> <p>(b) waste preparation for reuse, e.g. according to the specific requested quality criteria;</p> <p>(c) waste recycling;</p> <p>(d) other waste recovery (e.g. energy recovery),</p> <p>by implementing an appropriate combination of techniques such as:</p> <table border="1"> <thead> <tr> <th data-bbox="322 919 573 951">Technique</th> <th data-bbox="573 919 1079 951">Description</th> <th data-bbox="1079 919 1496 951">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 951 573 1110">a. Generation of gypsum as a by-product</td> <td data-bbox="573 951 1079 1110">Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g. as raw material in the plasterboard industry). The quality of limestone used in the wet FGD influences the purity of the gypsum produced</td> <td data-bbox="1079 951 1496 1110">Generally applicable within the constraints associated with the required gypsum quality, the health requirements associated to each specific use, and by the market conditions</td> </tr> <tr> <td data-bbox="322 1110 573 1246">b. Recycling or recovery of residues in the construction sector</td> <td data-bbox="573 1110 1079 1246">Recycling or recovery of residues (e.g. from semi-dry desulphurisation processes, fly ash, bottom ash) as a construction material (e.g. in road building, to replace sand in concrete production, or in the cement industry)</td> <td data-bbox="1079 1110 1496 1246">Generally applicable within the constraints associated with the required material quality (e.g. physical properties, content of harmful substances) associated to each specific use, and by the market conditions</td> </tr> <tr> <td data-bbox="322 1246 573 1350">c. Energy recovery by using waste in the fuel mix</td> <td data-bbox="573 1246 1079 1350">The residual energy content of carbon-rich ash and sludges generated by the combustion of coal, lignite, heavy fuel oil, peat or biomass can be recovered for example by mixing with the fuel</td> <td data-bbox="1079 1246 1496 1350">Generally applicable where plants can accept waste in the fuel mix and are technically able to feed the fuels into the combustion chamber</td> </tr> </tbody> </table> | Technique | Description | Applicability | a. Generation of gypsum as a by-product | Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g. as raw material in the plasterboard industry). The quality of limestone used in the wet FGD influences the purity of the gypsum produced | Generally applicable within the constraints associated with the required gypsum quality, the health requirements associated to each specific use, and by the market conditions | b. Recycling or recovery of residues in the construction sector | Recycling or recovery of residues (e.g. from semi-dry desulphurisation processes, fly ash, bottom ash) as a construction material (e.g. in road building, to replace sand in concrete production, or in the cement industry) | Generally applicable within the constraints associated with the required material quality (e.g. physical properties, content of harmful substances) associated to each specific use, and by the market conditions | c. Energy recovery by using waste in the fuel mix | The residual energy content of carbon-rich ash and sludges generated by the combustion of coal, lignite, heavy fuel oil, peat or biomass can be recovered for example by mixing with the fuel | Generally applicable where plants can accept waste in the fuel mix and are technically able to feed the fuels into the combustion chamber | CC | There is no waste generated from combustion process and no abatement systems in operation at the installation. | | | | | | | | | |
| Technique | Description | Applicability | | | | | | | | | | | | | | | | | | | | | | |
| a. Generation of gypsum as a by-product | Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g. as raw material in the plasterboard industry). The quality of limestone used in the wet FGD influences the purity of the gypsum produced | Generally applicable within the constraints associated with the required gypsum quality, the health requirements associated to each specific use, and by the market conditions | | | | | | | | | | | | | | | | | | | | | | |
| b. Recycling or recovery of residues in the construction sector | Recycling or recovery of residues (e.g. from semi-dry desulphurisation processes, fly ash, bottom ash) as a construction material (e.g. in road building, to replace sand in concrete production, or in the cement industry) | Generally applicable within the constraints associated with the required material quality (e.g. physical properties, content of harmful substances) associated to each specific use, and by the market conditions | | | | | | | | | | | | | | | | | | | | | | |
| c. Energy recovery by using waste in the fuel mix | The residual energy content of carbon-rich ash and sludges generated by the combustion of coal, lignite, heavy fuel oil, peat or biomass can be recovered for example by mixing with the fuel | Generally applicable where plants can accept waste in the fuel mix and are technically able to feed the fuels into the combustion chamber | | | | | | | | | | | | | | | | | | | | | | |

| BAT Concn. Number | Summary of BAT Conclusion requirement | | | Status NA/ CC / FC / NC | Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement | | | | | | | | | | | | | | | | | | |
|---|--|--|---|-------------------------|--|-------------|---------------|-------------------------|--|----------------------|------------------------|--|--|----------------------|---|---|----------------------------|---|--|--|---|-----------------------------------|--|
| | d. Preparation of spent catalyst for reuse | Preparation of catalyst for reuse (e.g. up to four times for SCR catalysts) restores some or all of the original performance, extending the service life of the catalyst to several decades. Preparation of spent catalyst for reuse is integrated in a catalyst management scheme | The applicability may be limited by the mechanical condition of the catalyst and the required performance with respect to controlling NO _x and NH ₃ emissions | | | | | | | | | | | | | | | | | | | | |
| 17 | In order to reduce noise emissions, BAT is to use one or a combination of the techniques given below. | | | CC | <p>Equipment is operated by experienced staff and scheduled preventative maintenance is in place.</p> <p>The gas turbine intake and exhaust systems are housed in an acoustically insulated building. Compressors are in the same building as gas turbine with acoustically lagged compressor pipework.</p> <p>Depressurisation valves and vents; high velocity vents are required for atmospheric dispersion (safety requirement). However their use, including running for maintenance, is infrequent.</p> | | | | | | | | | | | | | | | | | | |
| <table border="1"> <thead> <tr> <th data-bbox="315 596 573 624">Technique</th> <th data-bbox="580 596 1081 624">Description</th> <th data-bbox="1088 596 1503 624">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="315 628 573 943">a. Operational measures</td> <td data-bbox="580 628 1081 943"> These include: <ul style="list-style-type: none"> — improved inspection and maintenance of equipment — closing of doors and windows of enclosed areas, if possible — equipment operated by experienced staff — avoidance of noisy activities at night, if possible — provisions for noise control during maintenance activities </td> <td data-bbox="1088 628 1503 943">Generally applicable</td> </tr> <tr> <td data-bbox="315 948 573 1002">b. Low-noise equipment</td> <td data-bbox="580 948 1081 1002">This potentially includes compressors, pumps and disks</td> <td data-bbox="1088 948 1503 1002">Generally applicable when the equipment is new or replaced</td> </tr> <tr> <td data-bbox="315 1007 573 1109">c. Noise attenuation</td> <td data-bbox="580 1007 1081 1109">Noise propagation can be reduced by inserting obstacles between the emitter and the receiver. Appropriate obstacles include protection walls, embankments and buildings</td> <td data-bbox="1088 1007 1503 1109">Generally applicable to new plants. In the case of existing plants, the insertion of obstacles may be restricted by lack of space</td> </tr> <tr> <td data-bbox="315 1114 573 1289">d. Noise-control equipment</td> <td data-bbox="580 1114 1081 1289"> This includes: <ul style="list-style-type: none"> — noise-reducers — equipment insulation — enclosure of noisy equipment — soundproofing of buildings </td> <td data-bbox="1088 1114 1503 1289">The applicability may be restricted by lack of space</td> </tr> <tr> <td data-bbox="315 1294 573 1375">e. Appropriate location of equipment and buildings</td> <td data-bbox="580 1294 1081 1375">Noise levels can be reduced by increasing the distance between the emitter and the receiver and by using buildings as noise screens</td> <td data-bbox="1088 1294 1503 1375">Generally applicable to new plant</td> </tr> </tbody> </table> | | | Technique | | | Description | Applicability | a. Operational measures | These include: <ul style="list-style-type: none"> — improved inspection and maintenance of equipment — closing of doors and windows of enclosed areas, if possible — equipment operated by experienced staff — avoidance of noisy activities at night, if possible — provisions for noise control during maintenance activities | Generally applicable | b. Low-noise equipment | This potentially includes compressors, pumps and disks | Generally applicable when the equipment is new or replaced | c. Noise attenuation | Noise propagation can be reduced by inserting obstacles between the emitter and the receiver. Appropriate obstacles include protection walls, embankments and buildings | Generally applicable to new plants. In the case of existing plants, the insertion of obstacles may be restricted by lack of space | d. Noise-control equipment | This includes: <ul style="list-style-type: none"> — noise-reducers — equipment insulation — enclosure of noisy equipment — soundproofing of buildings | The applicability may be restricted by lack of space | e. Appropriate location of equipment and buildings | Noise levels can be reduced by increasing the distance between the emitter and the receiver and by using buildings as noise screens | Generally applicable to new plant | |
| Technique | Description | Applicability | | | | | | | | | | | | | | | | | | | | | |
| a. Operational measures | These include: <ul style="list-style-type: none"> — improved inspection and maintenance of equipment — closing of doors and windows of enclosed areas, if possible — equipment operated by experienced staff — avoidance of noisy activities at night, if possible — provisions for noise control during maintenance activities | Generally applicable | | | | | | | | | | | | | | | | | | | | | |
| b. Low-noise equipment | This potentially includes compressors, pumps and disks | Generally applicable when the equipment is new or replaced | | | | | | | | | | | | | | | | | | | | | |
| c. Noise attenuation | Noise propagation can be reduced by inserting obstacles between the emitter and the receiver. Appropriate obstacles include protection walls, embankments and buildings | Generally applicable to new plants. In the case of existing plants, the insertion of obstacles may be restricted by lack of space | | | | | | | | | | | | | | | | | | | | | |
| d. Noise-control equipment | This includes: <ul style="list-style-type: none"> — noise-reducers — equipment insulation — enclosure of noisy equipment — soundproofing of buildings | The applicability may be restricted by lack of space | | | | | | | | | | | | | | | | | | | | | |
| e. Appropriate location of equipment and buildings | Noise levels can be reduced by increasing the distance between the emitter and the receiver and by using buildings as noise screens | Generally applicable to new plant | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | |

| BAT Concn. Number | Summary of BAT Conclusion requirement | Status NA/ CC / FC / NC | Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
|---|---|---|---|--|-------------------|--------------------------------|---|-------------------------|---|--|--|--|--|-------------------------------|--|--|--|--|----------|---------------|----------|---------------|------------|--------------------------|------------------------|------------------------|--------------|--|------------------|---------|-------|-------|--------------|--|---|---------|---------|-------------|---------|---------|-------------------------------|---------|-------|-------------|-------------|--|------------------------------|---------|-------|-------------|-------------|--|-----------------------------------|---------|-------|-------|-------------|--|----------------------------------|---------|-------|-------|-------------|--|----|---|
| Combustion of gaseous fuels | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 40 | <p>In order to increase the energy efficiency of natural gas combustion, BAT is to use an appropriate combination of the techniques given in BAT 12 and below.</p> <table border="1" data-bbox="322 485 1496 730"> <thead> <tr> <th data-bbox="322 485 353 523">Technique</th> <th data-bbox="353 485 501 523">Description</th> <th data-bbox="501 485 1496 523">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 523 353 730">a. Combined cycle</td> <td data-bbox="353 523 501 730">See description in Section 8.2</td> <td data-bbox="501 523 1496 730">Generally applicable to new gas turbines and engines except when operated < 1 500 h/yr. Applicable to existing gas turbines and engines within the constraints associated with the steam cycle design and the space availability. Not applicable to existing gas turbines and engines operated < 1 500 h/yr. Not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns. Not applicable to boilers</td> </tr> </tbody> </table> <p>BAT-associated energy efficiency levels (BAT-AEELs) for the combustion of natural gas</p> <table border="1" data-bbox="322 756 1496 1066"> <thead> <tr> <th data-bbox="322 756 595 911" rowspan="3">Type of combustion unit</th> <th colspan="5" data-bbox="595 756 1496 794">BAT-AEELs ⁽¹³⁶⁾ ⁽¹³⁷⁾</th> </tr> <tr> <th colspan="2" data-bbox="595 794 855 852">Net electrical efficiency (%)</th> <th data-bbox="855 794 1137 852" rowspan="2">Net total fuel utilisation (%) ⁽¹³⁸⁾ ⁽¹³⁹⁾</th> <th colspan="2" data-bbox="1137 794 1496 852">Net mechanical energy efficiency (%) ⁽¹³⁹⁾ ⁽¹⁴⁰⁾</th> </tr> <tr> <th data-bbox="595 852 712 911">New unit</th> <th data-bbox="712 852 855 911">Existing unit</th> <th data-bbox="1137 852 1290 911">New unit</th> <th data-bbox="1290 852 1496 911">Existing unit</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 911 595 968">Gas engine</td> <td data-bbox="595 911 712 968">39,5–44 ⁽¹⁴¹⁾</td> <td data-bbox="712 911 855 968">35–44 ⁽¹⁴¹⁾</td> <td data-bbox="855 911 1137 968">56–85 ⁽¹⁴¹⁾</td> <td colspan="2" data-bbox="1137 911 1496 968">No BAT-AEEL.</td> </tr> <tr> <td data-bbox="322 968 595 1007">Gas-fired boiler</td> <td data-bbox="595 968 712 1007">39–42,5</td> <td data-bbox="712 968 855 1007">38–40</td> <td data-bbox="855 968 1137 1007">78–95</td> <td colspan="2" data-bbox="1137 968 1496 1007">No BAT-AEEL.</td> </tr> <tr> <td data-bbox="322 1007 595 1066">Open cycle gas turbine, ≥ 50 MW_{th}</td> <td data-bbox="595 1007 712 1066">36–41,5</td> <td data-bbox="712 1007 855 1066">33–41,5</td> <td data-bbox="855 1007 1137 1066">No BAT-AEEL</td> <td data-bbox="1137 1007 1290 1066">36,5–41</td> <td data-bbox="1290 1007 1496 1066">33,5–41</td> </tr> </tbody> </table> <p>Combined cycle gas turbine (CCGT)</p> <table border="1" data-bbox="322 1114 1496 1257"> <tbody> <tr> <td data-bbox="322 1114 595 1152">CCGT, 50–600 MW_{th}</td> <td data-bbox="595 1114 712 1152">53–58,5</td> <td data-bbox="712 1114 855 1152">46–54</td> <td data-bbox="855 1114 1137 1152">No BAT-AEEL</td> <td colspan="2" data-bbox="1137 1114 1496 1152">No BAT-AEEL</td> </tr> <tr> <td data-bbox="322 1152 595 1190">CCGT, ≥ 600 MW_{th}</td> <td data-bbox="595 1152 712 1190">57–60,5</td> <td data-bbox="712 1152 855 1190">50–60</td> <td data-bbox="855 1152 1137 1190">No BAT-AEEL</td> <td colspan="2" data-bbox="1137 1152 1496 1190">No BAT-AEEL</td> </tr> <tr> <td data-bbox="322 1190 595 1228">CHP CCGT, 50–600 MW_{th}</td> <td data-bbox="595 1190 712 1228">53–58,5</td> <td data-bbox="712 1190 855 1228">46–54</td> <td data-bbox="855 1190 1137 1228">65–95</td> <td colspan="2" data-bbox="1137 1190 1496 1228">No BAT-AEEL</td> </tr> <tr> <td data-bbox="322 1228 595 1257">CHP CCGT, ≥ 600 MW_{th}</td> <td data-bbox="595 1228 712 1257">57–60,5</td> <td data-bbox="712 1228 855 1257">50–60</td> <td data-bbox="855 1228 1137 1257">65–95</td> <td colspan="2" data-bbox="1137 1228 1496 1257">No BAT-AEEL</td> </tr> </tbody> </table> | Technique | Description | Applicability | a. Combined cycle | See description in Section 8.2 | Generally applicable to new gas turbines and engines except when operated < 1 500 h/yr. Applicable to existing gas turbines and engines within the constraints associated with the steam cycle design and the space availability. Not applicable to existing gas turbines and engines operated < 1 500 h/yr. Not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns. Not applicable to boilers | Type of combustion unit | BAT-AEELs ⁽¹³⁶⁾ ⁽¹³⁷⁾ | | | | | Net electrical efficiency (%) | | Net total fuel utilisation (%) ⁽¹³⁸⁾ ⁽¹³⁹⁾ | Net mechanical energy efficiency (%) ⁽¹³⁹⁾ ⁽¹⁴⁰⁾ | | New unit | Existing unit | New unit | Existing unit | Gas engine | 39,5–44 ⁽¹⁴¹⁾ | 35–44 ⁽¹⁴¹⁾ | 56–85 ⁽¹⁴¹⁾ | No BAT-AEEL. | | Gas-fired boiler | 39–42,5 | 38–40 | 78–95 | No BAT-AEEL. | | Open cycle gas turbine, ≥ 50 MW _{th} | 36–41,5 | 33–41,5 | No BAT-AEEL | 36,5–41 | 33,5–41 | CCGT, 50–600 MW _{th} | 53–58,5 | 46–54 | No BAT-AEEL | No BAT-AEEL | | CCGT, ≥ 600 MW _{th} | 57–60,5 | 50–60 | No BAT-AEEL | No BAT-AEEL | | CHP CCGT, 50–600 MW _{th} | 53–58,5 | 46–54 | 65–95 | No BAT-AEEL | | CHP CCGT, ≥ 600 MW _{th} | 57–60,5 | 50–60 | 65–95 | No BAT-AEEL | | CC | <p>BAT 12: a, b, d, f, g, h, p and q.</p> <p>Combined cycle is not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns.</p> <p>The net mechanical efficiency of LCP245 and LCP246 is 39.1%. This is based on product data from the original equipment manufacturer.</p> <p>A process monitoring requirement has been set in table S3.3 which requires energy efficiency monitoring after an overhaul.</p> |
| Technique | Description | Applicability | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| a. Combined cycle | See description in Section 8.2 | Generally applicable to new gas turbines and engines except when operated < 1 500 h/yr. Applicable to existing gas turbines and engines within the constraints associated with the steam cycle design and the space availability. Not applicable to existing gas turbines and engines operated < 1 500 h/yr. Not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns. Not applicable to boilers | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Type of combustion unit | BAT-AEELs ⁽¹³⁶⁾ ⁽¹³⁷⁾ | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | Net electrical efficiency (%) | | Net total fuel utilisation (%) ⁽¹³⁸⁾ ⁽¹³⁹⁾ | Net mechanical energy efficiency (%) ⁽¹³⁹⁾ ⁽¹⁴⁰⁾ | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | New unit | Existing unit | | New unit | Existing unit | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Gas engine | 39,5–44 ⁽¹⁴¹⁾ | 35–44 ⁽¹⁴¹⁾ | 56–85 ⁽¹⁴¹⁾ | No BAT-AEEL. | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Gas-fired boiler | 39–42,5 | 38–40 | 78–95 | No BAT-AEEL. | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Open cycle gas turbine, ≥ 50 MW _{th} | 36–41,5 | 33–41,5 | No BAT-AEEL | 36,5–41 | 33,5–41 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| CCGT, 50–600 MW _{th} | 53–58,5 | 46–54 | No BAT-AEEL | No BAT-AEEL | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| CCGT, ≥ 600 MW _{th} | 57–60,5 | 50–60 | No BAT-AEEL | No BAT-AEEL | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| CHP CCGT, 50–600 MW _{th} | 53–58,5 | 46–54 | 65–95 | No BAT-AEEL | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| CHP CCGT, ≥ 600 MW _{th} | 57–60,5 | 50–60 | 65–95 | No BAT-AEEL | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 41 | <p>In order to prevent or reduce NO_x emissions to air from the combustion of natural gas in boilers, BAT is to use one or a combination of the techniques given below.</p> <table border="1" data-bbox="322 1326 1496 1367"> <thead> <tr> <th data-bbox="322 1326 577 1367">Technique</th> <th data-bbox="577 1326 1021 1367">Description</th> <th data-bbox="1021 1326 1496 1367">Applicability</th> </tr> </thead> <tbody> </tbody> </table> | Technique | Description | Applicability | NA | Not applicable to Gas Turbines | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Technique | Description | Applicability | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

| BAT Concn. Number | Summary of BAT Conclusion requirement | | | Status NA/ CC / FC / NC | Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement |
|-------------------|--|--|--|-------------------------|---|
| | a. Air and/or fuel staging | See descriptions in Section 8.3. Air staging is often associated with low-NO _x burners | Generally applicable | | |
| | b. Flue-gas recirculation | See description in Section 8.3 | | | |
| | c. Low-NO _x burners (LNB) | | | | |
| | d. Advanced control system | See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr | The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system | | |
| | e. Reduction of the combustion air temperature | See description in Section 8.3 | Generally applicable within the constraints associated with the process needs | | |
| | f. Selective non-catalytic reduction (SNCR) | | Not applicable to combustion plants operated < 500 h/yr with highly variable boiler loads. The applicability may be limited in the case of combustion plants operated between 500 h/yr and 1 500 h/yr with highly variable boiler loads | | |
| | g. Selective catalytic reduction (SCR) | | Not applicable to combustion plants operated < 500 h/yr. Not generally applicable to combustion plants of < 100 MW _{th} . There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr | | |
| 42 | In order to prevent or reduce NO _x emissions to air from the combustion of natural gas in gas turbines, BAT is to use one or a combination of the techniques given below. | | | CC | Operator confirms they are Compliant with the BAT AELs for NO _x through combustion system design and control. |
| | Technique | Description | Applicability | | |
| | a. Advanced control system | See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr | The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system | | |
| | b. Water/steam addition | See description in Section 8.3 | The applicability may be limited due to water availability | | |

| BAT Concn. Number | Summary of BAT Conclusion requirement | | | Status NA/ CC / FC / NC | Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement | |
|-------------------|---|---|---|---|---|--|
| | c. | Dry low-NO _x burners (DLN) | | The applicability may be limited in the case of turbines where a retrofit package is not available or when water/steam addition systems are installed | | |
| d. | Low-load design concept | Adaptation of the process control and related equipment to maintain good combustion efficiency when the demand in energy varies, e.g. by improving the inlet airflow control capability or by splitting the combustion process into decoupled combustion stages | The applicability may be limited by the gas turbine design | | | |
| e. | Low-NO _x burners (LNB) | See description in Section 8.3 | Generally applicable to supplementary firing for heat recovery steam generators (HRSGs) in the case of combined-cycle gas turbine (CCGT) combustion plants | | | |
| f. | Selective catalytic reduction (SCR) | | Not applicable in the case of combustion plants operated < 500 h/yr. Not generally applicable to existing combustion plants of < 100 MW _{th} . Retrofitting existing combustion plants may be constrained by the availability of sufficient space. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr | | | |
| 43 | In order to prevent or reduce NO _x emissions to air from the combustion of natural gas in engines, BAT is to use one or a combination of the techniques given below. | | | NA | Not applicable to Gas Turbines | |
| | | Technique | Description | Applicability | | |
| a. | Advanced control system | See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr | The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system | | | |
| b. | Lean-burn concept | See description in Section 8.3. Generally used in combination with SCR | Only applicable to new gas-fired engines | | | |
| c. | Advanced lean-burn concept | See descriptions in Section 8.3 | Only applicable to new spark plug ignited engines | | | |

| BAT Concn. Number | Summary of BAT Conclusion requirement | | | Status NA/ CC / FC / NC | Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
|---|---|--|--|--------------------------|---|--|--|--|---|--|--|--|--|----------|------|-------|-------|---|------|-------|------------------------|--|--|--|--|----------|------|-------|-------|---|-------|-------|-------|---|-------|-------|------------------------|---|--------|-------|-------|---|--------|------------------------|------------------------|----|--|
| | d. Selective catalytic reduction (SCR) | | Retrofitting existing combustion plants may be constrained by the availability of sufficient space. Not applicable to combustion plants operated < 500 h/yr. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 44 | <p>In order to prevent or reduce CO emissions to air from the combustion of natural gas, BAT is to ensure optimised combustion and/or to use oxidation catalysts.</p> <p>Description - See descriptions in Section 8.3. BAT-associated emission levels (BAT-AELs) for NO_x emissions to air from the combustion of natural gas in gas turbines</p> <table border="1" data-bbox="322 778 1496 1382"> <thead> <tr> <th rowspan="2">Type of combustion plant</th> <th rowspan="2">Combustion plant total rated thermal input (MW_{th})</th> <th colspan="2">BAT-AELs (mg/Nm³) ⁽¹⁴²⁾ ⁽¹⁴³⁾</th> </tr> <tr> <th>Yearly average ⁽¹⁴⁴⁾ ⁽¹⁴⁵⁾</th> <th>Daily average or average over the sampling period</th> </tr> </thead> <tbody> <tr> <td colspan="4" style="text-align: center;">Open-cycle gas turbines (OCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁷⁾</td> </tr> <tr> <td>New OCGT</td> <td>≥ 50</td> <td>15–35</td> <td>25–50</td> </tr> <tr> <td>Existing OCGT (excluding turbines for mechanical drive applications) — All but plants operated < 500 h/yr</td> <td>≥ 50</td> <td>15–50</td> <td>25–55 ⁽¹⁴⁸⁾</td> </tr> <tr> <td colspan="4" style="text-align: center;">Combined-cycle gas turbines (CCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁹⁾</td> </tr> <tr> <td>New CCGT</td> <td>≥ 50</td> <td>10–30</td> <td>15–40</td> </tr> <tr> <td>Existing CCGT with a net total fuel utilisation of < 75 %</td> <td>≥ 600</td> <td>10–40</td> <td>18–50</td> </tr> <tr> <td>Existing CCGT with a net total fuel utilisation of ≥ 75 %</td> <td>≥ 600</td> <td>10–50</td> <td>18–55 ⁽¹⁵⁰⁾</td> </tr> <tr> <td>Existing CCGT with a net total fuel utilisation of < 75 %</td> <td>50–600</td> <td>10–45</td> <td>35–55</td> </tr> <tr> <td>Existing CCGT with a net total fuel utilisation of ≥ 75 %</td> <td>50–600</td> <td>25–50 ⁽¹⁵¹⁾</td> <td>35–55 ⁽¹⁵²⁾</td> </tr> </tbody> </table> | | | Type of combustion plant | Combustion plant total rated thermal input (MW _{th}) | BAT-AELs (mg/Nm ³) ⁽¹⁴²⁾ ⁽¹⁴³⁾ | | Yearly average ⁽¹⁴⁴⁾ ⁽¹⁴⁵⁾ | Daily average or average over the sampling period | Open-cycle gas turbines (OCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁷⁾ | | | | New OCGT | ≥ 50 | 15–35 | 25–50 | Existing OCGT (excluding turbines for mechanical drive applications) — All but plants operated < 500 h/yr | ≥ 50 | 15–50 | 25–55 ⁽¹⁴⁸⁾ | Combined-cycle gas turbines (CCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁹⁾ | | | | New CCGT | ≥ 50 | 10–30 | 15–40 | Existing CCGT with a net total fuel utilisation of < 75 % | ≥ 600 | 10–40 | 18–50 | Existing CCGT with a net total fuel utilisation of ≥ 75 % | ≥ 600 | 10–50 | 18–55 ⁽¹⁵⁰⁾ | Existing CCGT with a net total fuel utilisation of < 75 % | 50–600 | 10–45 | 35–55 | Existing CCGT with a net total fuel utilisation of ≥ 75 % | 50–600 | 25–50 ⁽¹⁵¹⁾ | 35–55 ⁽¹⁵²⁾ | CC | <p>Operator confirms they are compliant with the BAT AELs for CO through combustion system design and control.</p> <p>Where the existing permit sets monthly, daily and hourly average emission limits for CO and NO_x. Under the principal of “no backsliding”, the current emission limits will be retained unless tighter limits are set by the BREF.</p> <p>Limits for CO and NO_x are applicable above 55% MCR. See the key issues section for further information.</p> |
| Type of combustion plant | Combustion plant total rated thermal input (MW _{th}) | BAT-AELs (mg/Nm ³) ⁽¹⁴²⁾ ⁽¹⁴³⁾ | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | Yearly average ⁽¹⁴⁴⁾ ⁽¹⁴⁵⁾ | Daily average or average over the sampling period | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Open-cycle gas turbines (OCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁷⁾ | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| New OCGT | ≥ 50 | 15–35 | 25–50 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Existing OCGT (excluding turbines for mechanical drive applications) — All but plants operated < 500 h/yr | ≥ 50 | 15–50 | 25–55 ⁽¹⁴⁸⁾ | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Combined-cycle gas turbines (CCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁹⁾ | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| New CCGT | ≥ 50 | 10–30 | 15–40 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Existing CCGT with a net total fuel utilisation of < 75 % | ≥ 600 | 10–40 | 18–50 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Existing CCGT with a net total fuel utilisation of ≥ 75 % | ≥ 600 | 10–50 | 18–55 ⁽¹⁵⁰⁾ | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Existing CCGT with a net total fuel utilisation of < 75 % | 50–600 | 10–45 | 35–55 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Existing CCGT with a net total fuel utilisation of ≥ 75 % | 50–600 | 25–50 ⁽¹⁵¹⁾ | 35–55 ⁽¹⁵²⁾ | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

| BAT Concn. Number | Summary of BAT Conclusion requirement | Status NA/ CC / FC / NC | Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
|--|---|--|---|---------------------------------|--|---|------|------------------------|------------------------|--------------------------|--------------------------------|--|--|--|---------------------------------|--|---|--|-----------|---------------------------------|-----------|---------------------------------|--------|-------|--------|-------|--------|-------------------------|-------|--------|-------|-------------------------|--|--|
| | <p style="text-align: center;">Open- and combined-cycle gas turbines</p> <table border="1" data-bbox="322 427 1491 596"> <tr> <td data-bbox="322 427 786 512">Gas turbine put into operation no later than 27 November 2003, or existing gas turbine for emergency use and operated < 500 h/yr</td> <td data-bbox="786 427 1028 512">≥ 50</td> <td data-bbox="1028 427 1252 512">No BAT-AEL</td> <td data-bbox="1252 427 1491 512">60–140 ⁽¹⁵³⁾ ⁽¹⁵⁴⁾</td> </tr> <tr> <td data-bbox="322 512 786 596">Existing gas turbine for mechanical drive applications — All but plants operated < 500 h/yr</td> <td data-bbox="786 512 1028 596">≥ 50</td> <td data-bbox="1028 512 1252 596">15–50 ⁽¹⁵⁵⁾</td> <td data-bbox="1252 512 1491 596">25–55 ⁽¹⁵⁶⁾</td> </tr> </table> <p>As an indication, the yearly average CO emission levels for each type of existing combustion plant operated ≥ 1 500 h/yr and for each type of new combustion plant will generally be as follows:</p> <ul style="list-style-type: none"> — New OCGT of ≥ 50 MW_{th}: < 5–40 mg/Nm³. For plants with a net electrical efficiency (EE) greater than 39 %, a correction factor may be applied to the higher end of this range, corresponding to [higher end] × EE/39, where EE is the net electrical energy efficiency or net mechanical energy efficiency of the plant determined at ISO baseload conditions. — Existing OCGT of ≥ 50 MW_{th} (excluding turbines for mechanical drive applications): < 5–40 mg/Nm³. The higher end of this range will generally be 80 mg/Nm³ in the case of existing plants that cannot be fitted with dry techniques for NO_x reduction, or 50 mg/Nm³ for plants that operate at low load. — New CCGT of ≥ 50 MW_{th}: < 5–30 mg/Nm³. For plants with a net electrical efficiency (EE) greater than 55 %, a correction factor may be applied to the higher end of the range, corresponding to [higher end] × EE/55, where EE is the net electrical energy efficiency of the plant determined at ISO baseload conditions. — Existing CCGT of ≥ 50 MW_{th}: < 5–30 mg/Nm³. The higher end of this range will generally be 50 mg/Nm³ for plants that operate at low load. — Existing gas turbines of ≥ 50 MW_{th} for mechanical drive applications: < 5–40 mg/Nm³. The higher end of the range will generally be 50 mg/Nm³ when plants operate at low load. <p>In the case of a gas turbine equipped with DLN burners, these indicative levels correspond to when the DLN operation is effective.</p> <p style="text-align: center;">BAT-associated emission levels (BAT-AELs) for NO_x emissions to air from the combustion of natural gas in boilers and engines</p> <table border="1" data-bbox="322 1145 1491 1369"> <thead> <tr> <th data-bbox="322 1145 613 1299" rowspan="3">Type of combustion plant</th> <th colspan="4" data-bbox="613 1145 1491 1177">BAT-AELs (mg/Nm³)</th> </tr> <tr> <th colspan="2" data-bbox="613 1177 965 1241">Yearly average ⁽¹⁵⁷⁾</th> <th colspan="2" data-bbox="965 1177 1491 1241">Daily average or average over the sampling period</th> </tr> <tr> <th data-bbox="613 1241 752 1299">New plant</th> <th data-bbox="752 1241 965 1299">Existing plant ⁽¹⁵⁸⁾</th> <th data-bbox="965 1241 1171 1299">New plant</th> <th data-bbox="1171 1241 1491 1299">Existing plant ⁽¹⁵⁹⁾</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 1299 613 1331">Boiler</td> <td data-bbox="613 1299 752 1331">10–60</td> <td data-bbox="752 1299 965 1331">50–100</td> <td data-bbox="965 1299 1171 1331">30–85</td> <td data-bbox="1171 1299 1491 1331">85–110</td> </tr> <tr> <td data-bbox="322 1331 613 1369">Engine ⁽¹⁶⁰⁾</td> <td data-bbox="613 1331 752 1369">20–75</td> <td data-bbox="752 1331 965 1369">20–100</td> <td data-bbox="965 1331 1171 1369">55–85</td> <td data-bbox="1171 1331 1491 1369">55–110 ⁽¹⁶¹⁾</td> </tr> </tbody> </table> | Gas turbine put into operation no later than 27 November 2003, or existing gas turbine for emergency use and operated < 500 h/yr | ≥ 50 | No BAT-AEL | 60–140 ⁽¹⁵³⁾ ⁽¹⁵⁴⁾ | Existing gas turbine for mechanical drive applications — All but plants operated < 500 h/yr | ≥ 50 | 15–50 ⁽¹⁵⁵⁾ | 25–55 ⁽¹⁵⁶⁾ | Type of combustion plant | BAT-AELs (mg/Nm ³) | | | | Yearly average ⁽¹⁵⁷⁾ | | Daily average or average over the sampling period | | New plant | Existing plant ⁽¹⁵⁸⁾ | New plant | Existing plant ⁽¹⁵⁹⁾ | Boiler | 10–60 | 50–100 | 30–85 | 85–110 | Engine ⁽¹⁶⁰⁾ | 20–75 | 20–100 | 55–85 | 55–110 ⁽¹⁶¹⁾ | | |
| Gas turbine put into operation no later than 27 November 2003, or existing gas turbine for emergency use and operated < 500 h/yr | ≥ 50 | No BAT-AEL | 60–140 ⁽¹⁵³⁾ ⁽¹⁵⁴⁾ | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Existing gas turbine for mechanical drive applications — All but plants operated < 500 h/yr | ≥ 50 | 15–50 ⁽¹⁵⁵⁾ | 25–55 ⁽¹⁵⁶⁾ | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Type of combustion plant | BAT-AELs (mg/Nm ³) | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | Yearly average ⁽¹⁵⁷⁾ | | Daily average or average over the sampling period | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | New plant | Existing plant ⁽¹⁵⁸⁾ | New plant | Existing plant ⁽¹⁵⁹⁾ | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Boiler | 10–60 | 50–100 | 30–85 | 85–110 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Engine ⁽¹⁶⁰⁾ | 20–75 | 20–100 | 55–85 | 55–110 ⁽¹⁶¹⁾ | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

| BAT Concn. Number | Summary of BAT Conclusion requirement | Status NA/ CC / FC / NC | Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement | | | | | | | | | | | | | | | | | | | |
|--|--|--|---|--|--|--------------|-----------------|--|--|----------------------------------|--|--|--|-----------------------|-----------|----------------|------|-----------------------|--------------------------|---|----|--------------------------------|
| | <p>As an indication, the yearly average CO emission levels will generally be:</p> <ul style="list-style-type: none"> — < 5–40 mg/Nm³ for existing boilers operated ≥ 1 500 h/yr, — < 5–15 mg/Nm³ for new boilers, — 30–100 mg/Nm³ for existing engines operated ≥ 1 500 h/yr and for new engines. | | | | | | | | | | | | | | | | | | | | | |
| 45 | <p>In order to reduce non-methane volatile organic compounds (NMVOC) and methane (CH₄) emissions to air from the combustion of natural gas in spark-ignited lean-burn gas engines, BAT is to ensure optimised combustion and/or to use oxidation catalysts.</p> <p>Description See descriptions in Section 8.3. Oxidation catalysts are not effective at reducing the emissions of saturated hydrocarbons containing less than four carbon atoms.</p> <p>BAT-associated emission levels (BAT-AELs) for formaldehyde and CH₄ emissions to air from the combustion of natural gas in a spark-ignited lean-burn gas engine</p> <table border="1" data-bbox="322 770 1496 944"> <thead> <tr> <th data-bbox="322 770 887 807" rowspan="2">Combustion plant total rated thermal input (MW_{th})</th> <th colspan="3" data-bbox="887 770 1496 807">BAT-AELs (mg/Nm³)</th> </tr> <tr> <th data-bbox="887 807 1151 844">Formaldehyde</th> <th colspan="2" data-bbox="1151 807 1496 844">CH₄</th> </tr> <tr> <td data-bbox="322 844 887 880"></td> <th colspan="3" data-bbox="887 844 1496 880">Average over the sampling period</th> </tr> <tr> <td data-bbox="322 880 887 917"></td> <th data-bbox="887 880 1151 917">New or existing plant</th> <th data-bbox="1151 880 1296 917">New plant</th> <th data-bbox="1296 880 1496 917">Existing plant</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 917 887 944">≥ 50</td> <td data-bbox="887 917 1151 944">5–15 ⁽¹⁶²⁾</td> <td data-bbox="1151 917 1296 944">215–500 ⁽¹⁶³⁾</td> <td data-bbox="1296 917 1496 944">215–560 ⁽¹⁶²⁾ ⁽¹⁶³⁾</td> </tr> </tbody> </table> | Combustion plant total rated thermal input (MW _{th}) | BAT-AELs (mg/Nm ³) | | | Formaldehyde | CH ₄ | | | Average over the sampling period | | | | New or existing plant | New plant | Existing plant | ≥ 50 | 5–15 ⁽¹⁶²⁾ | 215–500 ⁽¹⁶³⁾ | 215–560 ⁽¹⁶²⁾ ⁽¹⁶³⁾ | NA | Not applicable to Gas Turbines |
| Combustion plant total rated thermal input (MW _{th}) | BAT-AELs (mg/Nm ³) | | | | | | | | | | | | | | | | | | | | | |
| | Formaldehyde | CH ₄ | | | | | | | | | | | | | | | | | | | | |
| | Average over the sampling period | | | | | | | | | | | | | | | | | | | | | |
| | New or existing plant | New plant | Existing plant | | | | | | | | | | | | | | | | | | | |
| ≥ 50 | 5–15 ⁽¹⁶²⁾ | 215–500 ⁽¹⁶³⁾ | 215–560 ⁽¹⁶²⁾ ⁽¹⁶³⁾ | | | | | | | | | | | | | | | | | | | |

6. Review and assessment of derogation requests made by the operator in relation to BAT Conclusions which include an associated emission level (AEL) value

The IED enables a competent authority to allow derogations from BAT AELs stated in BAT Conclusions under specific circumstances as detailed under Article 15(4):

By way of derogation from paragraph 3, and without prejudice to Article 18, the competent authority may, in specific cases, set less strict emission limit values. Such a derogation may apply only where an assessment shows that the achievement of emission levels associated with the best available techniques as described in BAT conclusions would lead to disproportionately higher costs compared to the environmental benefits due to:

(a) the geographical location or the local environmental conditions of the installation concerned; or

(b) the technical characteristics of the installation concerned.

As part of their Regulation 61 Note response, the operator has not requested a derogation from compliance with any AEL values.

7. Emissions to Water

The consolidated permit incorporates the current discharge to controlled waters identified as W1.

There are no BAT AELs specified in the BAT Conclusions for this type of plant. There are also no additional treatment options identified as BAT for the installation. We have therefore not carried out any additional assessment of the emissions to water as part of this review.

8 Additional IED Chapter II requirements:

There are no additional IED Chapter II requirements addressed through the permit review.

9 Review and assessment of changes that are not part of the BAT Conclusions derived permit review.

This document should be read in conjunction with the application, supporting information and notice.

| Aspect considered | Decision |
|---|---|
| Receipt of application | |
| Confidential information | A claim for commercial or industrial confidentiality has not been made. |
| Identifying confidential information | We have not identified information provided as part of the application that we consider to be confidential. |
| The site | |
| Biodiversity, heritage, landscape and nature conservation | <p>The application is within the relevant distance criteria of a site of heritage, landscape or nature conservation, and/or protected species or habitat.</p> <p>A full assessment of the application and its potential to affect the site(s)/species/habitat has not been carried out as part of the permit review process. We consider that the review will not affect the features of the site(s)/species/habitat as the conditions will provide at least the same level of protection as those in the previous permit and in some cases will provide a higher level of protection to those in the previous permit.</p> <p>We have not consulted Natural England on the application. The decision was taken in accordance with our guidance.</p> |
| Operating techniques | |
| General operating techniques | <p>We have reviewed the techniques used by the operator where they are relevant to the BAT Conclusions and compared these with the relevant guidance notes.</p> <p>The permit conditions ensure compliance with the relevant BREF, BAT Conclusions. The ELVs deliver compliance with the BAT-AELs.</p> |
| Permit conditions | |
| Updating permit conditions during consolidation | We have updated permit conditions to those in the current generic permit template as part of permit consolidation. The conditions will provide at least the same level of protection as those in the previous permit and in some cases will provide a higher level of protection to those in the previous permit. |

| Aspect considered | Decision |
|---|--|
| Changes to the permit conditions due to an Environment Agency initiated variation | We have varied the permit as stated in the variation notice. |
| Use of conditions other than those from the template | We have retained condition 2.3.4 relating to the annual Network Review. This is a condition of the permits for all National Grid Gas compressor stations. |
| Improvement programme | We have also removed the completed improvement conditions from the permit (Improvement conditions 1 to 8). |
| Emission limits | <p>We have decided that emission limits should be set for the parameters listed in the permit.</p> <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p> <p>It is considered that the ELVs/equivalent parameters or technical measures described above will ensure that significant pollution of the environment is prevented and a high level of protection for the environment is secured.</p> |
| Monitoring | <p>We have decided that monitoring should be carried out for the parameters listed in the permit, using the methods detailed and to the frequencies specified.</p> <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p> <p>Table S3.3 Process monitoring requirements was amended to include the requirement to monitor energy efficiency after overhauls on site in line with BAT2.</p> <p>Based on the information in the application we are satisfied that the operator's techniques, personnel and equipment have either MCERTS certification or MCERTS accreditation as appropriate.</p> |
| Reporting | <p>We have specified reporting in the permit for the following parameters:</p> <ul style="list-style-type: none"> • Nitrogen dioxide • Carbon monoxide <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p> |
| Operator competence | |
| Management system | There is no known reason to consider that the operator will not have the management system to enable it to comply with the permit conditions. |
| Growth Duty | |

| Aspect considered | Decision |
|--|---|
| <p>Section 108 Deregulation Act 2015 – Growth duty</p> | <p>We have considered our duty to have regard to the desirability of promoting economic growth set out in section 108(1) of the Deregulation Act 2015 and the guidance issued under section 110 of that Act in deciding whether to grant this permit.</p> <p>Paragraph 1.3 of the guidance says:</p> <p>“The primary role of regulators, in delivering regulation, is to achieve the regulatory outcomes for which they are responsible. For a number of regulators, these regulatory outcomes include an explicit reference to development or growth. The growth duty establishes economic growth as a factor that all specified regulators should have regard to, alongside the delivery of the protections set out in the relevant legislation.”</p> <p>We have addressed the legislative requirements and environmental standards to be set for this operation in the body of the decision document above. The guidance is clear at paragraph 1.5 that the growth duty does not legitimise non-compliance and its purpose is not to achieve or pursue economic growth at the expense of necessary protections.</p> <p>We consider the requirements and standards we have set in this permit are reasonable and necessary to avoid a risk of an unacceptable level of pollution. This also promotes growth amongst legitimate operators because the standards applied to the operator are consistent across businesses in this sector and have been set to achieve the required legislative standards.</p> |