

Environment Agency

Review of an Environmental Permit for an Installation subject to Chapter II of the Industrial Emissions Directive under the Environmental Permitting (England & Wales) Regulations 2016

Decision document recording our decision-making process following review of a permit

The Permit number is: EPR/BU5631IR
The Operator is: National Grid Gas Plc
The Installation is: Carnforth/Nether Kellet Gas Compressor Station
This Variation Notice number is: EPR/BU5631IR/V005

What this document is about

Article 21(3) of the Industrial Emissions Directive (IED) requires the Environment Agency to review conditions in permits that it has issued and to ensure that the permit delivers compliance with relevant standards, within four years of the publication of updated decisions on best available techniques (BAT) conclusions.

We have reviewed the permit for this installation against the revised BAT Conclusions for large combustion plant published on 17th August 2017. This is our decision document, which explains the reasoning for the consolidated variation notice that we are issuing.

It explains how we have reviewed and considered the techniques used by the Operator in the operation and control of the plant and activities of the installation. This review has been undertaken with reference to the decision made by the European Commission establishing best available techniques (BAT) conclusions ('BAT Conclusions') for large combustion plant as detailed in document reference IEDC-7-1. It is our record of our decision-making process and shows how we have taken into account all relevant factors in reaching our position. It also provides a justification for the inclusion of any specific conditions in the permit that are in addition to those included in our generic permit template.

As well as considering the review of the operating techniques used by the Operator for the operation of the plant and activities of the installation, the consolidated variation notice takes into account and brings together in a single document all previous

variations that relate to the original permit issued. It also modernises the entire permit to reflect the conditions contained in our current generic permit template.

The introduction of new template conditions makes the Permit consistent with our current general approach and philosophy and with other permits issued to installations in this sector. Although the wording of some conditions has changed, while others have been removed because of the new regulatory approach, it does not reduce the level of environmental protection achieved by the Permit in any way. In this document we therefore address only our determination of substantive issues relating to the new BAT Conclusions.

Throughout this document we will use a number of expressions. These are as referred to in the glossary and have the same meaning as described in “Schedule 6 Interpretation” of the Permit.

We try to explain our decision as accurately, comprehensively and plainly as possible. We would welcome any feedback as to how we might improve our decision documents in future. A lot of technical terms and acronyms are inevitable in a document of this nature: we provide a glossary of acronyms near the front of the document, for ease of reference.

How this document is structured

Glossary of terms

- 1 Our decision
- 2 How we reached our decision
- 2.1 Requesting information to demonstrate compliance with BAT
Conclusions for Large Combustion Plant
- 2.2 Review of our own information in respect to the capability of the
installation to meet revised standards included in the BAT Conclusions
document
- 3 The legal framework
- 4 Key Issues
- 5 Decision checklist regarding relevant BAT Conclusions
- 6 Review and assessment of derogation requests made by the operator in
relation to BAT Conclusions which include an associated emission level
(AEL) value
- 7 Emissions to Water
- 8 Additional IED Chapter II requirements
- 9 Review and assessment of changes that are not part of the BAT
Conclusions derived permit review.

Glossary of acronyms used in this document

(Please note that this glossary is standard for our decision documents and therefore not all these acronyms are necessarily used in this document.)

APC	Air Pollution Control
BAT	Best Available Technique(s)
BAT-AEEL	BAT Associated Energy Efficiency Level
BAT-AEL	BAT Associated Emission Level
BATc	BAT conclusion
BREF	Best available techniques reference document
CEM	Continuous emissions monitor
CHP	Combined heat and power
CV	Calorific value
DAA	Directly associated activity – Additional activities necessary to be carried out to allow the principal activity to be carried out
DLN	Dry Low NOx burners
DLN-E	Dry Low NOx effective
EIONET	European environment information and observation network is a partnership network of the European Environment Agency
ELV	Emission limit value derived under BAT or an emission limit value set out in IED
EMS	Environmental Management System
EPR	Environmental Permitting (England and Wales) Regulations 2016 (SI 2016 No. 1154)
EWC	European waste catalogue
FSA	Food Standards Agency
IC	Improvement Condition
IED	Industrial Emissions Directive (2010/75/EU)
IPPCD	Integrated Pollution Prevention and Control Directive (2008/1/EC) – now superseded by IED
LCP	Large Combustion Plant subject to Chapter III of IED
MSUL/MSDL	Minimum start up load/minimum shut-down load
NOx	Oxides of nitrogen (NO plus NO ₂ expressed as NO ₂)
NPV	Net Present Value
OCGT	Open Cycle Gas Turbine
PHE	Public Health England
SAC	Special Area of Conservation
SGN	Sector guidance note
TGN	Technical guidance note
TOC	Total Organic Carbon
WFD	Water Framework Directive (2000/60/EC)

1 Our decision

We have decided to issue the consolidated variation notice to the Operator. This will allow it to continue to operate the Installation, subject to the conditions in the consolidated variation notice.

We consider that, in reaching that decision, we have taken into account all relevant considerations and legal requirements and that the varied permit will ensure that a high level of protection is provided for the environment and human health.

The consolidated variation notice contains many conditions taken from our standard Environmental Permit template including the relevant Annexes. We developed these conditions in consultation with industry, having regard to the legal requirements of the Environmental Permitting Regulations and other relevant legislation. This document does not therefore include an explanation for these standard conditions. Where they are included in the Notice, we have considered the techniques identified by the operator for the operation of their installation, and have accepted that the details are sufficient and satisfactory to make those standard conditions appropriate. This document does, however, provide an explanation of our use of “tailor-made” or installation-specific conditions, or where our Permit template provides two or more options.

2 How we reached our decision

2.1 Requesting information to demonstrate compliance with BAT Conclusions for Large Combustion Plant

We issued a Notice under Regulation 61(1) of the Environmental Permitting (England and Wales) Regulations 2016 (a Regulation 61 Notice) on 1st May 2018 requiring the Operator to provide information to demonstrate how the operation of their installation currently meets, or will subsequently meet, the revised standards described in the large combustion plant BAT Conclusions document. The Notice also required that where the revised standards are not currently met, the operator should provide information that:

- Describes the techniques that will be implemented before 17th August 2021, which will then ensure that operations meet the revised standard, or
- Justifies why standards will not be met by 17th August 2021, and confirmation of the date when the operation of those processes will cease within the installation or an explanation of why the revised BAT standard is not applicable to those processes, or
- Justifies why an alternative technique will achieve the same level of environmental protection equivalent to the revised standard described in the BAT Conclusions.

Where the Operator proposed that they were not intending to meet a BAT standard that also included a BAT Associated Emission Level (BAT AEL) described in the BAT

Conclusions Document, the Regulation 61 Notice requested that the Operator make a formal request for derogation from compliance with that AEL (as provisioned by Article 15(4) of IED). In this circumstance, the Notice identified that any such request for derogation must be supported and justified by sufficient technical and commercial information that would enable us to determine acceptability of the derogation request.

The Regulation 61 Notice response from the Operator was received on 30th November 2018.

We considered it was in the correct form and contained sufficient information for us to begin our determination of the permit review but not that it necessarily contained all the information we would need to complete that review.

2.2 Review of our own information in respect to the capability of the installation to meet revised standards included in the BAT Conclusions document

Based on our records and previous regulatory activities with the facility we have no reason to consider that the operator will not be able to comply with the conditions that we include in the permit.

3 The legal framework

The consolidated variation notice will be issued under Regulation 20 of the EPR. The Environmental Permitting regime is a legal vehicle which delivers most of the relevant legal requirements for activities falling within its scope. In particular, the regulated facility is:

- an *installation* as described by the IED;
- subject to aspects of other relevant legislation which also have to be addressed.

We consider that the consolidated variation notice will ensure that the operation of the Installation complies with all relevant legal requirements and that a high level of protection will be delivered for the environment and human health.

We explain how we have addressed specific statutory requirements more fully in the rest of this document.

4 The key issues

The key issues arising during this permit review are:

- Emissions to air and the emission limits applied to the plant
- The energy efficiency levels associated with the Best Available Techniques (BAT-AEELs)
- The review and assessment of the availability of BAT for gas turbines operating <500 hours per year

We therefore describe how we determined these issues in most detail in the relevant sections of this document.

4.1 Emissions to air and the emission limits applied to the plant

A number of general principles were applied during the permit review. These included:

- The upper value of the BAT AELs ranges specified were used unless use of the tighter limit was justified.
- The principle of no backsliding where if existing limits in the permit were already tighter than those specified in the BREF, the existing permit limits were retained.
- Where a limit was specified in both IED Annex V and the BAT Conclusions for a particular reference period, the tighter limit was applied and in the majority of cases this was from the BAT Conclusions.
- Where AELs are indicative in the BAT Conclusions, these were applied unless adequate justification was provided by the operator to demonstrate that an alternative limit was more appropriate.

The LCP(s) on site consist of:

LCP 235 consists of 1 x 71.9 MWth OCGT which vents at emission point A3. The unit burns natural gas only.

LCP 236 consists of 1 x 66.3 MWth OCGT which vents at emission point A1. The unit burns natural gas only.

LCP 237 consists of 1 x 63.7 MWth OCGT which vents at emission point A2. The unit burns natural gas only.

The plant was put into operation before IED came into force and therefore the existing limits in the permit are from Part 1 of IED Annex V applicable to existing plant.

The ELVs and AELs are based on the following operating regime:

- LCP 235: Unlimited hours operation
- LCP 236: Limited Life Derogation under IED until December 2023
- LCP 237: <500 hours emergency only plant

The Operator submitted the operational performance emissions data for NO_x and carbon monoxide (CO) for each individual turbine as part of the original permit application in 2006. This excluded any data collected when the plant was operating at <55% Maximum Continuous Rating (MCR). These figures provided the realistic emission values that individual turbines could achieve at >55% MCR and were the basis on which emission limit values for CO and NO_x were set. The Limits in the previous permit did not apply during start up, shut down or during operation at loads <55% of MCR.

On this site the plant is required by the gas grid to operate at low load for usually only short periods of time. In order to ensure that emissions between MSUL and 55% are monitored we have the option of either setting additional ELVs or recording the hours below 55% operation and retaining the note that the limits are excluded at operation <55%.

We have agreed to retain the current approach of recording hours of operation below 55% MCR. This is because the ELVs would have to be set very high which would not reflect environmental risk. This would further complicate an already complex system where more than one ELV is set. The environmental risk is low and we have decided to maintain monitoring using the number of operating hours in this mode as a proxy.

We have included a note in tables S3.1 and S3.1a for all National Grid Gas sites that states 'excluding start up, shut down and operation at loads <55% of MCR'. A requirement for the hours of operation below 55% to be recorded is included in Schedule 4 of the permit.

IED specified that limits apply over 70% load and the BAT Conclusions specify that AELs apply when dry low NO_x is effective (DLN-E). For NGG permits 55% MCR is used as a proxy for DLN-E. We have used 55% MCR as a default across all monitoring requirements for NO_x and CO.

LCP 235:

The following tables outline the limits that have been incorporated into the permit for LCP235, where these were derived from and the reference periods at which they apply. The emission limits refer to concentrations, expressed as mass of emitted substance per volume of flue-gas under the following standard conditions: dry gas at a temperature of 273,15 K, pressure of 101,3 kPa and 15% volume reference oxygen concentration if flue gases. The emission limits and monitoring requirements have been incorporated into Schedule 3 of the permit.

NOx limits (mg/Nm ³)						
Averaging	IED (Annex V Part 1) - Existing	BREF (Table 24 BAT-c)	Expected permit limits	Basis	Limits apply	Monitoring
Annual	None	60 ^{Note 1}	60	BREF	>55% of MCR ^{Note 3}	Continuous (Predictive Emissions Monitoring)
Monthly	75	None	65 ^{Note 2}	Note 2	>55% of MCR ^{Note 3}	
Daily	82	65 ^{Note 1}	65	BREF	>55% of MCR ^{Note 3}	
95 th %ile of hr means	150	None	150	IED	>55% of MCR ^{Note 3}	
<p>Note 1: As an existing OCGT Mechanical Drive plant put into operation no later than 7 January 2014, footnotes 14 and 15 to Table 24 of the BAT Conclusions apply, these footnote specify the applicable BAT-AELs.</p> <p>Note 2: This limit is tighter than the IED annex V limit (75mg/m³) which was previously set in the permit. The monthly limit cannot be higher than the daily limit, therefore we have set a monthly limit which matches the daily limit given in the BAT Conclusions.</p> <p>Note 3: The BAT Conclusions specify that AELs apply when dry low NOx is effective (DLN-E). For NGG permits, 55% MCR is used as a proxy for DLN-E.</p>						

CO limits (mg/Nm ³)							
Averaging	Permit – Non-IED - Existing	IED (Annex V Part 1) - Existing	BREF	Expected permit limits	Basis	Limits apply	Monitoring
Annual	None	None	40	40	BREF	>55% of MCR ^{Note 1}	Continuous (Predictive Emissions Monitoring)
Monthly	None	100	None	100	IED	>55% of MCR ^{Note 1}	
Daily	100	110	None	100	Permit	>55% of MCR ^{Note 1}	
95 th %ile of hr means	100	200	None	100	Permit	>55% of MCR ^{Note 1}	
<p>Note 1: The BAT Conclusions specify that AELs apply when dry low NOx is effective (DLN-E). For NGG permits, 55% MCR is used as a proxy for DLN-E.</p>							

LCP 236:

In 2015, the Operator chose to operate LCP 236 under a Limited Life Derogation (LLD) as described in Article 33(1)(a) of the Industrial Emissions Directive 2010/75/EU. This

means the gas turbine will not be operated for more than 17,500 hours, starting from 1 January 2016 and ending no later than 31 December 2023.

Operators of combustion plants that have opted for the LLD do not have to comply with the BATcs applicable to the air pollutants that are subject to the LLD. Therefore the current emission limits will be retained and we have not set any additional or revised emission limits for LCP 236 as part of this review.

All other provisions of the BATcs do apply (for example energy efficiency and monitoring requirements).

LCP 237:

LCP 237 is operated <500hours per year for emergency use, therefore indicative BAT does not apply. There are no BAT-AELs or emissions limit values (ELVs) set in the permit for LCP 237.

4.2 The energy efficiency levels associated with the Best Available Techniques Conclusions

An energy efficiency level associated with the best available techniques (BAT-AEEL) refers to the ratio between the combustion unit's net energy output(s) and the combustion unit's fuel/feedstock energy input at actual unit design. The net energy output(s) is determined at the combustion unit boundaries, including auxiliary systems (e.g. flue-gas treatment systems), and for the unit operated at full load.

For LCP 237, Table 23 of the LCP BAT Conclusions specifies that the BAT-AEELs for this type of plant are not applicable to plant operating less than 1500 hours per year. We have therefore not assessed this operational aspect of the plant. We have however included a process monitoring requirement in table S3.3 of the consolidated variation notice. This is required to demonstrate that efficiency levels are maintained following any significant overhauls of equipment in order to fulfil the requirement of BAT Conclusion 2. For <500 hour plant we have specified that the assessment of efficiency can be based on calculation. This is because we will not require plant to fire up with the sole purpose of carrying out an assessment of efficiency.

For LCP 236 and LCP 235, the table below sets out the BAT-AEELs specified in the LCP BAT Conclusions for the large combustion plant on the site and the energy efficiency levels confirmed through the Regulation 61 notice response. The Operator confirmed that the original equipment manufacturer provided a calculation based on their internal product data for the equipment installed in order to determine the net mechanical efficiency.

BAT AEELs (%)			Plant efficiency (%)		
Net electrical efficiency	Net total fuel utilisation	Net mechanical efficiency	Net electrical efficiency	Net total fuel utilisation	Net mechanical efficiency
LCP 235: Open cycle gas turbine, ≥ 50 MWth, Existing unit, Mechanical Drive					
None	None	33.5-41	NA	NA	39.1
LCP 235: Open cycle gas turbine, ≥ 50 MWth, Existing unit, Mechanical Drive					
None	None	33.5-41	NA	NA	33.3

For LCP 235, we consider this plant is BAT in relation to the AEELs.

LCP 236 does not meet the BAT-AEEL range for this type of plant. However, LCP 236 is operated under a Limited Life Derogation (LLD) as described in Article 33(1)(a) of the Industrial Emissions Directive 2010/75/EU. This means that the operator has agreed that the plant will not operate past 31 December 2023. We are therefore satisfied that it would not be cost effective for any upgrades to this plant and that the current net mechanical efficiency is BAT.

A formal derogation is not required from the BAT-AEELs under Article 15(4) where it is proven that alternative values can be regarded as BAT. If the operator intends to continue operation after 31 December 2023 they will require a permit variation to allow further operation and the requirements of these BAT Conclusions will apply.

4.3 The review and assessment of BAT for gas turbines operating < 500 hours per year

Joint Environmental Programme (JEP) produced a document '*BAT Assessment for Existing Gas and Liquid Fuel Fired OCGTs, CCGTs and Dual-fuel GTs with a Thermal Input Rating of 50MWth or Greater Operating <500 Hours Per Year*' dated October 2018. The content of this document has been agreed in principle by the Environment Agency and we have therefore taken the document into account during our determination of this variation.

The JEP document states that plants operated for emergency use will have very low running hours, comprising testing of critical systems and operation during site emergencies only. As such, emissions will be limited and abatement techniques are unlikely to be cost-effective.

We agree that the techniques reported under BAT conclusion 42 are not applicable to LCP 236.

In all cases, the minimum BAT requirements are considered to be: i) the continued compliance with any permit requirements already in place to protect air quality and ii)

the demonstration of an appropriate maintenance regime to maintain plant emissions performance.

5 Decision checklist regarding relevant BAT Conclusions

BAT Conclusions for large combustion plant, were published by the European Commission on 17th August 2017. There are 75 BAT Conclusions. Only the BAT Conclusions relevant to the particular fuel type used on site have been replicated below.

This annex provides a record of decisions made in relation to each relevant BAT Conclusion applicable to the installation. This annex should be read in conjunction with the Consolidated Variation Notice.

The conditions in the permit through which the relevant BAT Conclusions are implemented include but are not limited to the following:

BAT Conclusion requirement topic	Permit condition(s)	Permit table(s)
Environmental Management System	1.1.1	S1.2
BAT AELs	3.1.1 and 3.5.1	S3.1a
Monitoring	2.3, 3.5 and 3.6	S1.2, S1.5, S1.4, S3.1a
Energy efficiency	1.2 and 2.3	S3.3
Noise	3.4 and 2.3	S1.2
Other operating techniques	2.3	S1.2

The overall status of compliance with the BAT conclusion is indicated in the table as:

- NA Not Applicable
- CC Currently Compliant
- FC Compliant in the future (within 4 years of publication of BAT conclusions)
- NC Not Compliant
- PC Partially Compliant

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
General			
1	<p>In order to improve the overall environmental performance, BAT is to implement and adhere to an environmental management system (EMS) that incorporates all of the following features:</p> <ul style="list-style-type: none"> i. commitment of the management, including senior management; ii. definition of an environmental policy that includes the continuous improvement of the installation by the management; iii. planning and establishing the necessary procedures, objectives and targets, in conjunction with financial planning and investment; iv. implementation of procedures <ul style="list-style-type: none"> (a) Structure and responsibility (b) Training (c) Communication (d) Employee involvement (e) Documentation (f) Efficient process control (g) Maintenance programmes (h) Emergency preparedness and response (i) Safeguarding compliance with environmental legislation v. checking performance and taking corrective action, paying particular attention to: <ul style="list-style-type: none"> (a) monitoring and measurement (see also the Reference Document on the General Principles of Monitoring) (b) corrective and preventive action (c) maintenance of records (d) independent (where practicable) internal and external auditing in order to determine whether or not the EMS conforms to planned arrangements and has been properly implemented and maintained; vi. review of the EMS and its continuing suitability, adequacy and effectiveness by senior management; vii. following the development of cleaner technologies; viii. consideration for the environmental impacts from the eventual decommissioning of the installation at the stage of designing a new plant, and throughout its operating life; viii. consideration for the environmental impacts from the eventual decommissioning of the installation at the stage of designing a new plant, and throughout its operating life; ix. application of sectoral benchmarking on a regular basis. <p>Etc - see BAT Conclusions</p>	CC	<p>National Grid operates an ISO14001 certified EMS.</p> <p>The operator has confirmed that National Grid Plc operates a corporate EMS for all it's business units. National Grid Gas (Gas Transmission) has management procedures of its own to implement the requirements of the corporate EMS which are common to all installations. Each installation has its own site specific aspects and impacts register.</p>

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement												
	<p>Applicability. The scope (e.g. level of detail) and nature of the EMS (e.g. standardised or non-standardised) will generally be related to the nature, scale and complexity of the installation, and the range of environmental impacts it may have.</p>														
2	<p>BAT is to determine the net electrical efficiency and/or the net total fuel utilisation and/or the net mechanical energy efficiency of the gasification, IGCC and/or combustion units by carrying out a performance test at full load (1), according to EN standards, after the commissioning of the unit and after each modification that could significantly affect the net electrical efficiency and/or the net total fuel utilisation and/or the net mechanical energy efficiency of the unit. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.</p>	CC	<p>The net mechanical efficiency of LCP 235 is 39.1%, the net mechanical efficiency of LCP 236 and LCP 237 is 33.3%. This is based on product data from the original equipment manufacturer. We consider this plant is BAT in relation to the AEELs. See Section 4.2 of this decision document for further information.</p> <p>For LCP 237, the BAT-AEELs are not applicable to plant operating <1500 hours.</p> <p>A process monitoring requirement has been set in table S3.3 which requires energy efficiency monitoring after an overhaul.</p>												
3	<p>BAT is to monitor key process parameters relevant for emissions to air and water including those given below.</p> <table border="1" data-bbox="322 1139 1491 1315"> <thead> <tr> <th data-bbox="322 1139 687 1171">Stream</th> <th data-bbox="687 1139 1122 1171">Parameter(s)</th> <th data-bbox="1122 1139 1491 1171">Monitoring</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 1171 687 1278" rowspan="3">Flue-gas</td> <td data-bbox="687 1171 1122 1203">Flow</td> <td data-bbox="1122 1171 1491 1203">Periodic or continuous determination</td> </tr> <tr> <td data-bbox="687 1203 1122 1235">Oxygen content, temperature, and pressure</td> <td data-bbox="1122 1203 1491 1235" rowspan="2">Periodic or continuous measurement</td> </tr> <tr> <td data-bbox="687 1235 1122 1278">Water vapour content ⁽³⁾</td> </tr> <tr> <td data-bbox="322 1278 687 1315">Waste water from flue-gas treatment</td> <td data-bbox="687 1278 1122 1315">Flow, pH, and temperature</td> <td data-bbox="1122 1278 1491 1315">Continuous measurement</td> </tr> </tbody> </table>	Stream	Parameter(s)	Monitoring	Flue-gas	Flow	Periodic or continuous determination	Oxygen content, temperature, and pressure	Periodic or continuous measurement	Water vapour content ⁽³⁾	Waste water from flue-gas treatment	Flow, pH, and temperature	Continuous measurement	CC	<p>Flow - Fuel gas usage is measured and flue-gas flow is determined by stoichiometric calculations.</p> <p>Oxygen content, temperature and pressure - NO_x, CO and O₂ concentration content is measured via periodic measurements, conducted by UKAS ISO17025 laboratory to EN standards.</p>
Stream	Parameter(s)	Monitoring													
Flue-gas	Flow	Periodic or continuous determination													
	Oxygen content, temperature, and pressure	Periodic or continuous measurement													
	Water vapour content ⁽³⁾														
Waste water from flue-gas treatment	Flow, pH, and temperature	Continuous measurement													

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																		
			<p>Emissions measurements taken in this way are not affected by changes in temperature and pressure and these parameters are not required for correction to reference conditions. We are satisfied with the Operators justification of why temperature and pressure are not measured.</p> <p>Water vapour content - Flue gas is dried prior to measurement for periodic monitoring.</p> <p>Waste water from flue-gas treatment - no waste water is generated from flue-gas treatment.</p>																		
4	<p>BAT is to monitor emissions to air with at least the frequency given below and in accordance with EN standards. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.</p> <table border="1" data-bbox="322 983 1491 1385"> <thead> <tr> <th data-bbox="322 983 477 1099">Substance/Parameter</th> <th data-bbox="477 983 790 1099">Fuel/Process/Type of combustion plant</th> <th data-bbox="790 983 947 1099">Combustion plant total rated thermal input</th> <th data-bbox="947 983 1126 1099">Standard(s)⁽⁴⁾</th> <th data-bbox="1126 983 1346 1099">Minimum monitoring frequency⁽⁶⁾</th> <th data-bbox="1346 983 1491 1099">Monitoring associated with</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 1099 477 1166">NH₃</td> <td data-bbox="477 1099 790 1166">— When SCR and/or SNCR is used</td> <td data-bbox="790 1099 947 1166">All sizes</td> <td data-bbox="947 1099 1126 1166">Generic EN standards</td> <td data-bbox="1126 1099 1346 1166">Continuous⁽⁶⁾⁽⁷⁾</td> <td data-bbox="1346 1099 1491 1166">BAT 7</td> </tr> <tr> <td data-bbox="322 1166 477 1385">NO_x</td> <td data-bbox="477 1166 790 1385"> <ul style="list-style-type: none"> — Coal and/or lignite including waste co-incineration — Solid biomass and/or peat including waste co-incineration — HFO- and/or gas-oil-fired boilers and engines </td> <td data-bbox="790 1166 947 1385">All sizes</td> <td data-bbox="947 1166 1126 1385">Generic EN standards</td> <td data-bbox="1126 1166 1346 1385">Continuous⁽⁶⁾⁽⁸⁾</td> <td data-bbox="1346 1166 1491 1385"> BAT 20 BAT 24 BAT 28 BAT 32 BAT 37 BAT 41 BAT 42 BAT 43 BAT 47 </td> </tr> </tbody> </table>	Substance/Parameter	Fuel/Process/Type of combustion plant	Combustion plant total rated thermal input	Standard(s) ⁽⁴⁾	Minimum monitoring frequency ⁽⁶⁾	Monitoring associated with	NH ₃	— When SCR and/or SNCR is used	All sizes	Generic EN standards	Continuous ⁽⁶⁾ ⁽⁷⁾	BAT 7	NO _x	<ul style="list-style-type: none"> — Coal and/or lignite including waste co-incineration — Solid biomass and/or peat including waste co-incineration — HFO- and/or gas-oil-fired boilers and engines 	All sizes	Generic EN standards	Continuous ⁽⁶⁾ ⁽⁸⁾	BAT 20 BAT 24 BAT 28 BAT 32 BAT 37 BAT 41 BAT 42 BAT 43 BAT 47	CC	<p>A Predicative Emission Monitoring System (PEMS) is used for monitoring of NO_x validated by periodic measurement. Footnote 5 to BAT 4 confirms that PEMS may be used for existing OCGTs.</p>
Substance/Parameter	Fuel/Process/Type of combustion plant	Combustion plant total rated thermal input	Standard(s) ⁽⁴⁾	Minimum monitoring frequency ⁽⁶⁾	Monitoring associated with																
NH ₃	— When SCR and/or SNCR is used	All sizes	Generic EN standards	Continuous ⁽⁶⁾ ⁽⁷⁾	BAT 7																
NO _x	<ul style="list-style-type: none"> — Coal and/or lignite including waste co-incineration — Solid biomass and/or peat including waste co-incineration — HFO- and/or gas-oil-fired boilers and engines 	All sizes	Generic EN standards	Continuous ⁽⁶⁾ ⁽⁸⁾	BAT 20 BAT 24 BAT 28 BAT 32 BAT 37 BAT 41 BAT 42 BAT 43 BAT 47																

BAT Concn. Numbe r	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
		<ul style="list-style-type: none"> — Gas-oil-fired gas turbines — Natural-gas-fired boilers, engines, and turbines — Iron and steel process gases — Process fuels from the chemical industry — IGCC plants 				BAT 48 BAT 56 BAT 64 BAT 65 BAT 73		
		<ul style="list-style-type: none"> — Combustion plants on offshore platforms 	All sizes	EN 14792	Once every year ⁽⁹⁾	BAT 53		
	N ₂ O	<ul style="list-style-type: none"> — Coal and/or lignite in circulating fluidised bed boilers — Solid biomass and/or peat in circulating fluidised bed boilers 	All sizes	EN 21258	Once every year ⁽¹⁰⁾	BAT 20 BAT 24		
	CO	<ul style="list-style-type: none"> — Coal and/or lignite including waste co-incineration — Solid biomass and/or peat including waste co-incineration — HFO- and/or gas-oil-fired boilers and engines — Gas-oil-fired gas turbines — Natural-gas-fired boilers, engines, and turbines — Iron and steel process gases — Process fuels from the chemical industry — IGCC plants 	All sizes	Generic EN standards	Continuous ⁽⁶⁾ ⁽⁸⁾	BAT 20 BAT 24 BAT 28 BAT 33 BAT 38 BAT 44 BAT 49 BAT 56 BAT 64 BAT 65 BAT 73		
		<ul style="list-style-type: none"> — Combustion plants on offshore platforms 	All sizes	EN 15058	Once every year ⁽⁹⁾	BAT 54		

BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	SO ₂	<ul style="list-style-type: none"> — Coal and/or lignite incl waste co-incineration — Solid biomass and/or peat incl waste co-incineration — HFO- and/or gas-oil-fired boilers — HFO- and/or gas-oil-fired engines — Gas-oil-fired gas turbines — Iron and steel process gases — Process fuels from the chemical industry in boilers — IGCC plants 	All sizes	Generic EN standards and EN 14791	Continuous ⁽⁶⁾ ⁽¹¹⁾ ⁽¹²⁾	BAT 21 BAT 25 BAT 29 BAT 34 BAT 39 BAT 50 BAT 57 BAT 66 BAT 67 BAT 74		
	SO ₃	<ul style="list-style-type: none"> — When SCR is used 	All sizes	No EN standard available	Once every year	—		
	Dust	<ul style="list-style-type: none"> — Coal and/or lignite — Solid biomass and/or peat — HFO- and/or gas-oil-fired boilers — Iron and steel process gases — Process fuels from the chemical industry in boilers — IGCC plants — HFO- and/or gas-oil-fired engines — Gas-oil-fired gas turbines 	All sizes	Generic EN standards and EN 13284-1 and EN 13284-2	Continuous ⁽⁶⁾ ⁽¹⁷⁾	BAT 22 BAT 26 BAT 30 BAT 35 BAT 39 BAT 51 BAT 58 BAT 75		
		<ul style="list-style-type: none"> — Waste co-incineration 	All sizes	Generic EN standards and EN 13284-2	Continuous	BAT 68 BAT 69		

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																	
5	BAT is to monitor emissions to water from flue-gas treatment with at least the frequency given in BAT 5 and in accordance with EN standards. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.	NA	No flue-gas treatment.																	
6	<p>In order to improve the general environmental performance of combustion plants and to reduce emissions to air of CO and unburnt substances, BAT is to ensure optimised combustion and to use an appropriate combination of the techniques given below.</p> <table border="1" data-bbox="331 612 1487 1216"> <thead> <tr> <th data-bbox="331 612 555 644">Technique</th> <th data-bbox="555 612 994 644">Description</th> <th data-bbox="994 612 1487 644">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="331 644 555 730">a. Fuel blending and mixing</td> <td data-bbox="555 644 994 730">Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type</td> <td data-bbox="994 644 1487 730" rowspan="2">Generally applicable</td> </tr> <tr> <td data-bbox="331 730 555 817">b. Maintenance of the combustion system</td> <td data-bbox="555 730 994 817">Regular planned maintenance according to suppliers' recommendations</td> </tr> <tr> <td data-bbox="331 817 555 903">c. Advanced control system</td> <td data-bbox="555 817 994 903">See description in Section 8.1</td> <td data-bbox="994 817 1487 903">The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> <tr> <td data-bbox="331 903 555 989">d. Good design of the combustion equipment</td> <td data-bbox="555 903 994 989">Good design of furnace, combustion chambers, burners and associated devices</td> <td data-bbox="994 903 1487 989">Generally applicable to new combustion plants</td> </tr> <tr> <td data-bbox="331 989 555 1216">e. Fuel choice</td> <td data-bbox="555 989 994 1216">Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used</td> <td data-bbox="994 989 1487 1216">Applicable within the constraints associated with the availability of suitable types of fuel with a better environmental profile as a whole, which may be impacted by the energy policy of the Member State, or by the integrated site's fuel balance in the case of combustion of industrial process fuels. For existing combustion plants, the type of fuel chosen may be limited by the configuration and the design of the plant</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Fuel blending and mixing	Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type	Generally applicable	b. Maintenance of the combustion system	Regular planned maintenance according to suppliers' recommendations	c. Advanced control system	See description in Section 8.1	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system	d. Good design of the combustion equipment	Good design of furnace, combustion chambers, burners and associated devices	Generally applicable to new combustion plants	e. Fuel choice	Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used	Applicable within the constraints associated with the availability of suitable types of fuel with a better environmental profile as a whole, which may be impacted by the energy policy of the Member State, or by the integrated site's fuel balance in the case of combustion of industrial process fuels. For existing combustion plants, the type of fuel chosen may be limited by the configuration and the design of the plant	CC	<p>Fuel blending and mixing - the plant is run on natural gas, there are no backup or start up fuels. There is no requirement to blend or mix fuels.</p> <p>Maintenance of the combustion system - National Grid operates a preventative maintenance management system which is certified to both PAS 55 and ISO 55001. The maintenance system identifies all site plant and equipment and details the frequency and requirements for the maintenance set by the manufacturer, British and international standards and input from incidents and failures.</p> <p>Advanced Control Systems – LCP 235 – The control system on this unit is advanced and controls parameters on the combustion system to reduce emissions within the required limits.</p> <p>BAT 6 states that the applicability to old combustion plants may be constrained by the need to retrofit</p>
Technique	Description	Applicability																		
a. Fuel blending and mixing	Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type	Generally applicable																		
b. Maintenance of the combustion system	Regular planned maintenance according to suppliers' recommendations																			
c. Advanced control system	See description in Section 8.1	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system																		
d. Good design of the combustion equipment	Good design of furnace, combustion chambers, burners and associated devices	Generally applicable to new combustion plants																		
e. Fuel choice	Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used	Applicable within the constraints associated with the availability of suitable types of fuel with a better environmental profile as a whole, which may be impacted by the energy policy of the Member State, or by the integrated site's fuel balance in the case of combustion of industrial process fuels. For existing combustion plants, the type of fuel chosen may be limited by the configuration and the design of the plant																		

BAT Concn. Numbe r	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
			<p>the combustion system and/or control demand system.</p> <p>LCP 236 – The control system is constrained by the configuration and design of the gas turbine to reduce the combustion emissions. The unit is operating under LLD and will cease operation by 31 December 2023. Therefore the Operator confirms that there are no plans to update the control system to a more advanced configuration.</p> <p>LCP 237 – The control system is constrained by the configuration and design of the gas turbine to reduce the combustion emissions. The unit is operating less than 500 hours/year under its current configuration. Therefore the Operator confirms that there are no plans to update the control system to a more advanced configuration.</p> <p>Good design of the combustion equipment – All units are approximately 20 years old and of a design that maximises the combustion system. The operator confirms that LCP 235 is able to achieve the relevant emission limits.</p>

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
			Fuel Choice – The plant is operated using natural gas, there are no backup or start up fuels. Natural gas quality is determined by the Gas Supply and Management Regulations (GSMR) and requires the gas to be controlled with in tight limits for quality, contents (low sulphur) and combustion characteristics.
7	<p>In order to reduce emissions of ammonia to air from the use of selective catalytic reduction (SCR) and/or selective non-catalytic reduction (SNCR) for the abatement of NO_x emissions, BAT is to optimise the design and/or operation of SCR and/or SNCR (e.g. optimised reagent to NO_x ratio, homogeneous reagent distribution and optimum size of the reagent drops).</p> <p>BAT-associated emission levels</p> <p>The BAT-associated emission level (BAT-AEL) for emissions of NH₃ to air from the use of SCR and/or SNCR is < 3–10 mg/Nm³ as a yearly average or average over the sampling period. The lower end of the range can be achieved when using SCR and the upper end of the range can be achieved when using SNCR without wet abatement techniques. In the case of plants combusting biomass and operating at variable loads as well as in the case of engines combusting HFO and/or gas oil, the higher end of the BAT-AEL range is 15 mg/Nm³.</p>	NA	Not applicable - no SCR or SNCR on site.
8	In order to prevent or reduce emissions to air during normal operating conditions, BAT is to ensure, by appropriate design, operation and maintenance, that the emission abatement systems are used at optimal capacity and availability.	NA	Not applicable as there is no emission abatement systems in operation at the installation.
9	<p>In order to improve the general environmental performance of combustion and/or gasification plants and to reduce emissions to air, BAT is to include the following elements in the quality assurance/quality control programmes for all the fuels used, as part of the environmental management system (see BAT 1):</p> <ul style="list-style-type: none"> (i) Initial full characterisation of the fuel used including at least the parameters listed below and in accordance with EN standards. ISO, national or other international standards may be used provided they ensure the provision of data of an equivalent scientific quality; (ii) Regular testing of the fuel quality to check that it is consistent with the initial characterisation and according to the plant design specifications. The frequency of testing and the parameters chosen from the table below are based on the 	CC	LCPs are fired on Natural Gas only. This gas has to meet a nationally agreed specification for all the parameters listed. We consider that for plants which burn natural gas from the National Grid as a fuel that it is not necessary for the operator to replicate the

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																								
	<p>variability of the fuel and an assessment of the relevance of pollutant releases (e.g. concentration in fuel, flue-gas treatment employed);</p> <p>(iii) Subsequent adjustment of the plant settings as and when needed and practicable (e.g. integration of the fuel characterisation and control in the advanced control system (see description in Section 8.1)).</p> <p>Description Initial characterisation and regular testing of the fuel can be performed by the operator and/or the fuel supplier. If performed by the supplier, the full results are provided to the operator in the form of a product (fuel) supplier specification and/or guarantee.</p> <table border="1" data-bbox="322 619 1491 1378"> <thead> <tr> <th data-bbox="322 619 712 651">Fuel(s)</th> <th data-bbox="712 619 1491 651">Substances/Parameters subject to characterisation</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 651 712 858" rowspan="4">Biomass/peat</td> <td data-bbox="712 651 1491 691">— LHV</td> </tr> <tr> <td data-bbox="712 691 1491 735">— moisture</td> </tr> <tr> <td data-bbox="712 735 1491 775">— Ash</td> </tr> <tr> <td data-bbox="712 775 1491 858">— C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn)</td> </tr> <tr> <td data-bbox="322 858 712 1070" rowspan="4">Coal/lignite</td> <td data-bbox="712 858 1491 898">— LHV</td> </tr> <tr> <td data-bbox="712 898 1491 938">— Moisture</td> </tr> <tr> <td data-bbox="712 938 1491 978">— Volatiles, ash, fixed carbon, C, H, N, O, S</td> </tr> <tr> <td data-bbox="712 978 1491 1023">— Br, Cl, F</td> </tr> <tr> <td data-bbox="322 1023 1491 1070">— Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)</td> </tr> <tr> <td data-bbox="322 1070 712 1155" rowspan="2">HFO</td> <td data-bbox="712 1070 1491 1110">— Ash</td> </tr> <tr> <td data-bbox="712 1110 1491 1155">— C, S, N, Ni, V</td> </tr> <tr> <td data-bbox="322 1155 712 1240" rowspan="2">Gas oil</td> <td data-bbox="712 1155 1491 1195">— Ash</td> </tr> <tr> <td data-bbox="712 1195 1491 1240">— N, C, S</td> </tr> <tr> <td data-bbox="322 1240 712 1324" rowspan="2">Natural gas</td> <td data-bbox="712 1240 1491 1279">— LHV</td> </tr> <tr> <td data-bbox="712 1279 1491 1324">— CH₄, C₂H₆, C₃, C₄₊, CO₂, N₂, Wobbe index</td> </tr> <tr> <td data-bbox="322 1324 712 1378">Process fuels from the chemical industry⁽²⁷⁾</td> <td data-bbox="712 1324 1491 1378">— Br, C, Cl, F, H, N, O, S</td> </tr> </tbody> </table>	Fuel(s)	Substances/Parameters subject to characterisation	Biomass/peat	— LHV	— moisture	— Ash	— C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn)	Coal/lignite	— LHV	— Moisture	— Volatiles, ash, fixed carbon, C, H, N, O, S	— Br, Cl, F	— Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)	HFO	— Ash	— C, S, N, Ni, V	Gas oil	— Ash	— N, C, S	Natural gas	— LHV	— CH ₄ , C ₂ H ₆ , C ₃ , C ₄₊ , CO ₂ , N ₂ , Wobbe index	Process fuels from the chemical industry ⁽²⁷⁾	— Br, C, Cl, F, H, N, O, S		testing carried out by the National Grid
Fuel(s)	Substances/Parameters subject to characterisation																										
Biomass/peat	— LHV																										
	— moisture																										
	— Ash																										
	— C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn)																										
Coal/lignite	— LHV																										
	— Moisture																										
	— Volatiles, ash, fixed carbon, C, H, N, O, S																										
	— Br, Cl, F																										
— Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)																											
HFO	— Ash																										
	— C, S, N, Ni, V																										
Gas oil	— Ash																										
	— N, C, S																										
Natural gas	— LHV																										
	— CH ₄ , C ₂ H ₆ , C ₃ , C ₄₊ , CO ₂ , N ₂ , Wobbe index																										
Process fuels from the chemical industry ⁽²⁷⁾	— Br, C, Cl, F, H, N, O, S																										

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement						
	<table border="1"> <tr> <td data-bbox="322 384 712 432"></td> <td data-bbox="712 384 1491 432">— Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)</td> </tr> <tr> <td data-bbox="322 432 712 504">Iron and steel process gases</td> <td data-bbox="712 432 1491 504">— LHV, CH₄ (for COG), C_xH_y (for COG), CO₂, H₂, N₂, total sulphur, dust, Wobbe index</td> </tr> <tr> <td data-bbox="322 504 712 659">Waste⁽²⁸⁾</td> <td data-bbox="712 504 1491 659"> <ul style="list-style-type: none"> — LHV — Moisture — Volatiles, ash, Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) </td> </tr> </table>		— Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)	Iron and steel process gases	— LHV, CH ₄ (for COG), C _x H _y (for COG), CO ₂ , H ₂ , N ₂ , total sulphur, dust, Wobbe index	Waste ⁽²⁸⁾	<ul style="list-style-type: none"> — LHV — Moisture — Volatiles, ash, Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) 		
	— Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)								
Iron and steel process gases	— LHV, CH ₄ (for COG), C _x H _y (for COG), CO ₂ , H ₂ , N ₂ , total sulphur, dust, Wobbe index								
Waste ⁽²⁸⁾	<ul style="list-style-type: none"> — LHV — Moisture — Volatiles, ash, Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) 								
10	<p>In order to reduce emissions to air and/or to water during other than normal operating conditions (OTNOC), BAT is to set up and implement a management plan as part of the environmental management system (see BAT 1), commensurate with the relevance of potential pollutant releases, that includes the following elements:</p> <ul style="list-style-type: none"> — appropriate design of the systems considered relevant in causing OTNOC that may have an impact on emissions to air, water and/or soil (e.g. low-load design concepts for reducing the minimum start-up and shutdown loads for stable generation in gas turbines), — set-up and implementation of a specific preventive maintenance plan for these relevant systems, — review and recording of emissions caused by OTNOC and associated circumstances and implementation of corrective actions if necessary, — periodic assessment of the overall emissions during OTNOC (e.g. frequency of events, duration, emissions quantification/estimation) and implementation of corrective actions if necessary. 	CC	The LCPs control systems monitor critical gas turbine running parameters and shut down in case of malfunction and OTNOC.						
11	<p>BAT is to appropriately monitor emissions to air and/or to water during OTNOC.</p> <p>Description</p> <p>The monitoring can be carried out by direct measurement of emissions or by monitoring of surrogate parameters if this proves to be of equal or better scientific quality than the direct measurement of emissions. Emissions during start-up and shutdown (SU/SD) may be assessed based on a detailed emission measurement carried out for a typical SU/SD procedure at least once every year, and using the results of this measurement to estimate the emissions for each and every SU/SD throughout the year.</p>	CC	The LCPs control systems monitor critical gas turbine running parameters and shut down in case of malfunction and OTNOC.						
12	<p>In order to increase the energy efficiency of combustion, gasification and/or IGCC units operated ≥ 1 500 h/yr, BAT is to use an appropriate combination of the techniques given below.</p> <table border="1" data-bbox="322 1289 1491 1382"> <thead> <tr> <th data-bbox="322 1289 577 1326">Technique</th> <th data-bbox="577 1289 1057 1326">Description</th> <th data-bbox="1057 1289 1491 1326">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 1326 577 1382">a. Combustion optimisation</td> <td data-bbox="577 1326 1057 1382">See description in Section 8.2.</td> <td data-bbox="1057 1326 1491 1382">Generally applicable</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Combustion optimisation	See description in Section 8.2.	Generally applicable	CC	For LCP 235: Combustion optimisation -Dry Low Emission (DLE) lean burn pre-mixed combustion system ensures that fuel and air are pre-
Technique	Description	Applicability							
a. Combustion optimisation	See description in Section 8.2.	Generally applicable							

BAT Concn. Number	Summary of BAT Conclusion requirement				Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
			Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues			<p>mixed prior to combustion to give a more homogenous reaction (flame) temperature below the temperatures at which thermal NO_x production rates are elevated</p> <p>Optimisation of the working medium conditions - Operation of compressor units are aimed to be at optimum efficiency with the constraints of the system and supply/demand gas patterns, all medium used is pre-defined in the Gas Safety management Regulations (GSMR).</p> <p>Minimisation of energy consumption - Gas turbine, Power Turbine, and Gas Compressor are sized and optimised for the duty required</p> <p>Pre-heating of combustion air - Only used where anti-icing techniques are employed at low ambient temperatures.</p> <p>Fuel pre-heating - preheating by oil to gas heat exchanger.</p> <p>Advanced control system - The DLE system is governed by the overall automatic combustion control system, which is controlled and monitored by programmable logic controllers (PLC)</p>
	b.	Optimisation of the working medium conditions	Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO _x emissions or the characteristics of energy demanded			
	c.	Optimisation of the steam cycle	Operate with lower turbine exhaust pressure by utilisation of the lowest possible temperature of the condenser cooling water, within the design conditions			
	d.	Minimisation of energy consumption	Minimising the internal energy consumption (e.g. greater efficiency of the feed-water pump)			
	e.	Preheating of combustion air	Reuse of part of the heat recovered from the combustion flue-gas to preheat the air used in combustion	Generally applicable within the constraints related to the need to control NO _x emissions		
	f.	Fuel preheating	Preheating of fuel using recovered heat	Generally applicable within the constraints associated with the boiler design and the need to control NO _x emissions		
	g.	Advanced control system	See description in Section 8.2. Computerised control of the main combustion parameters enables the combustion efficiency to be improved	Generally applicable to new units. The applicability to old units may be constrained by the need to retrofit the combustion system and/or control command system		
	h.	Feed-water preheating using recovered heat	Preheat water coming out of the steam condenser with recovered heat, before reusing it in the boiler	Only applicable to steam circuits and not to hot boilers. Applicability to existing units may be limited due to constraints associated with the plant configuration and the amount of recoverable heat		
	i.	Heat recovery by cogeneration (CHP)	Recovery of heat (mainly from the steam system) for producing hot water/steam to be used in industrial processes/activities or in a public network for district heating. Additional heat recovery is possible from: — flue-gas	Applicable within the constraints associated with the local heat and power demand. The applicability may be limited in the case of gas compressors with an unpredictable operational heat profile		

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
			<ul style="list-style-type: none"> — grate cooling — circulating fluidised bed 		<p>LCP 236 is operated under a Limited Life Derogation (LLD) as described in Article 33(1)(a) of the Industrial Emissions Directive 2010/75/EU. This means that the operator has agreed that the plant will not operate past 31 December 2023. The operator has stated that the units are old technology and it is not financially feasible to upgrade due to the limited life of the units. We are satisfied that it would not be cost effective for any upgrades to this plant. If the operator intends to continue operation after 31 December 2023 they will require a permit variation and the requirements of these BAT Conclusions will apply.</p> <p>LCP 237 – BATc 12 is not applicable to plant which operates less than 1500 hours per year</p>
j.	CHP readiness	See description in Section 8.2.	Only applicable to new units where there is a realistic potential for the future use of heat in the vicinity of the unit		
k.	Flue-gas condenser	See description in Section 8.2.	Generally applicable to CHP units provided there is enough demand for low-temperature heat		
l.	Heat accumulation	Heat accumulation storage in CHP mode	Only applicable to CHP plants. The applicability may be limited in the case of low heat load demand		
m.	Wet stack	See description in Section 8.2.	Generally applicable to new and existing units fitted with wet FGD		
n.	Cooling tower discharge	The release of emissions to air through a cooling tower and not via a dedicated stack	Only applicable to units fitted with wet FGD where reheating of the flue-gas is necessary before release, and where the unit cooling system is a cooling tower		
o.	Fuel pre-drying	The reduction of fuel moisture content before combustion to improve combustion conditions	Applicable to the combustion of biomass and/or peat within the constraints associated with spontaneous combustion risks (e.g. the moisture content of peat is kept above 40 % throughout the delivery chain). The retrofit of existing plants may be restricted by the extra calorific value that can be obtained from the drying operation and by the limited retrofit possibilities offered by some boiler designs or plant configurations		
p.	Minimisation of heat losses	Minimising residual heat losses, e.g. those that occur via the slag or those that can be reduced by insulating radiating sources	Only applicable to solid-fuel-fired combustion units and to gasification/IGCC units		
q.	Advanced materials	Use of advanced materials proven to be capable of withstanding high operating temperatures and pressures and thus to achieve increased steam/combustion process efficiencies	Only applicable to new plants		

BAT Concn. Number	Summary of BAT Conclusion requirement				Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	r.	Steam turbine upgrades	This includes techniques such as increasing the temperature and pressure of medium-pressure steam, addition of a low-pressure turbine, and modifications to the geometry of the turbine rotor blades	The applicability may be restricted by demand, steam conditions and/or limited plant lifetime		
	s.	Supercritical and ultra-supercritical steam conditions	Use of a steam circuit, including steam reheating systems, in which steam can reach pressures above 220,6 bar and temperatures above 374 °C in the case of supercritical conditions, and above 250 – 300 bar and temperatures above 580 – 600 °C in the case of ultra-supercritical conditions	Only applicable to new units of $\geq 600 \text{ MW}_{\text{th}}$ operated $> 4\,000 \text{ h/yr}$. Not applicable when the purpose of the unit is to produce low steam temperatures and/or pressures in process industries. Not applicable to gas turbines and engines generating steam in CHP mode. For units combusting biomass, the applicability may be constrained by high-temperature corrosion in the case of certain biomasses		
13	In order to reduce water usage and the volume of contaminated waste water discharged, BAT is to use one or both of the techniques given below.				NA	Water is not used in the process of gas turbine driven mechanical drive gas compression in operation at the installation.
	Technique		Description		Applicability	
	a.	Water recycling	Residual aqueous streams, including run-off water, from the plant are reused for other purposes. The degree of recycling is limited by the quality requirements of the recipient water stream and the water balance of the plant	Not applicable to waste water from cooling systems when water treatment chemicals and/or high concentrations of salts from seawater are present		
	b.	Dry bottom ash handling	Dry, hot bottom ash falls from the furnace onto a mechanical conveyor system and is cooled down by ambient air. No water is used in the process.	Only applicable to plants combusting solid fuels. There may be technical restrictions that prevent retrofitting to existing combustion plants		
14	In order to prevent the contamination of uncontaminated waste water and to reduce emissions to water, BAT is to segregate waste water streams and to treat them separately, depending on the pollutant content.				CC	Water is not used in the process and there is no direct water based effluent from the operation of the gas turbines on site. A small amount of water (20 to 50 litres) is used with detergent to
	Description					
	Waste water streams that are typically segregated and treated include surface run-off water, cooling water, and waste water from flue-gas treatment.					
	Applicability					
	The applicability may be restricted in the case of existing plants due to the configuration of the drainage systems.					

BAT Concn. Numbe r	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
			<p>complete a "wash" of the gas turbine, to clean out combustion and airborne debris from the engine internals. This is done on a monitored condition basis, the more hours the unit is running, the greater the frequency of washing required. All of the water used to complete washing is contaminated, thus is collected, segregated and disposed of as hazardous waste.</p> <p>There are no discharges to sewer from the installation. Domestic discharges from the facilities in the control buildings are directed to two domestic effluent holding tanks. The contents of the tanks are pumped out, by a third-party contractor, on a regular basis.</p> <p>As no process effluent is discharged from emission points W1 and W2. All surface water passes through the installation's two main interceptors to remove any residual oil collected from site run-off, prior to being discharged to W1 or W2.</p> <p>A programme of visual inspection of the discharge, for oil and grease, is in place to ensure efficiency of the oil interceptor.</p>

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																																																			
15	<p>In order to reduce emissions to water from flue-gas treatment, BAT is to use an appropriate combination of the techniques given below, and to use secondary techniques as close as possible to the source in order to avoid dilution.</p> <table border="1" data-bbox="322 469 1491 1361"> <thead> <tr> <th data-bbox="322 469 712 528">Technique</th> <th data-bbox="712 469 1025 528">Typical pollutants prevented/abated</th> <th data-bbox="1025 469 1491 528">Applicability</th> </tr> </thead> <tbody> <tr> <td colspan="3" data-bbox="322 528 1491 563" style="text-align: center;">Primary techniques</td> </tr> <tr> <td data-bbox="322 563 367 651">a.</td> <td data-bbox="367 563 712 651">Optimised combustion (see BAT 6) and flue-gas treatment systems (e.g. SCR/SNCR, see BAT 7)</td> <td data-bbox="712 563 1025 651">Organic compounds, ammonia (NH₃)</td> </tr> <tr> <td colspan="3" data-bbox="322 651 1491 686" style="text-align: center;">Secondary techniques ⁽²⁹⁾</td> </tr> <tr> <td data-bbox="322 686 367 746">b.</td> <td data-bbox="367 686 712 746">Adsorption on activated carbon</td> <td data-bbox="712 686 1025 746">Organic compounds, mercury (Hg)</td> </tr> <tr> <td data-bbox="322 746 367 879">c.</td> <td data-bbox="367 746 712 879">Aerobic biological treatment</td> <td data-bbox="712 746 1491 879">Biodegradable organic compounds, ammonium (NH₄⁺)</td> </tr> <tr> <td data-bbox="322 879 367 941">d.</td> <td data-bbox="367 879 712 941">Anoxic/anaerobic biological treatment</td> <td data-bbox="712 879 1025 941">Mercury (Hg), nitrate (NO₃⁻), nitrite (NO₂⁻)</td> </tr> <tr> <td data-bbox="322 941 367 971">e.</td> <td data-bbox="367 941 712 971">Coagulation and flocculation</td> <td data-bbox="712 941 1025 971">Suspended solids</td> </tr> <tr> <td data-bbox="322 971 367 1034">f.</td> <td data-bbox="367 971 712 1034">Crystallisation</td> <td data-bbox="712 971 1491 1034">Metals and metalloids, sulphate (SO₄²⁻), fluoride (F⁻)</td> </tr> <tr> <td data-bbox="322 1034 367 1096">g.</td> <td data-bbox="367 1034 712 1096">Filtration (e.g. sand filtration, microfiltration, ultrafiltration)</td> <td data-bbox="712 1034 1025 1096">Suspended solids, metals</td> </tr> <tr> <td data-bbox="322 1096 367 1126">h.</td> <td data-bbox="367 1096 712 1126">Flotation</td> <td data-bbox="712 1096 1025 1126">Suspended solids, free oil</td> </tr> <tr> <td data-bbox="322 1126 367 1157">i.</td> <td data-bbox="367 1126 712 1157">Ion exchange</td> <td data-bbox="712 1126 1025 1157">Metals</td> </tr> <tr> <td data-bbox="322 1157 367 1187">j.</td> <td data-bbox="367 1157 712 1187">Neutralisation</td> <td data-bbox="712 1157 1025 1187">Acids, alkalis</td> </tr> <tr> <td data-bbox="322 1187 367 1217">k.</td> <td data-bbox="367 1187 712 1217">Oxidation</td> <td data-bbox="712 1187 1025 1217">Sulphide (S²⁻), sulphite (SO₃²⁻)</td> </tr> <tr> <td data-bbox="322 1217 367 1248">l.</td> <td data-bbox="367 1217 712 1248">Precipitation</td> <td data-bbox="712 1217 1491 1248">Metals and metalloids, sulphate (SO₄²⁻), fluoride (F⁻)</td> </tr> <tr> <td data-bbox="322 1248 367 1278">m.</td> <td data-bbox="367 1248 712 1278">Sedimentation</td> <td data-bbox="712 1248 1025 1278">Suspended solids</td> </tr> <tr> <td data-bbox="322 1278 367 1308">n.</td> <td data-bbox="367 1278 712 1308">Stripping</td> <td data-bbox="712 1278 1025 1308">Ammonia (NH₃)</td> </tr> </tbody> </table>	Technique	Typical pollutants prevented/abated	Applicability	Primary techniques			a.	Optimised combustion (see BAT 6) and flue-gas treatment systems (e.g. SCR/SNCR, see BAT 7)	Organic compounds, ammonia (NH ₃)	Secondary techniques ⁽²⁹⁾			b.	Adsorption on activated carbon	Organic compounds, mercury (Hg)	c.	Aerobic biological treatment	Biodegradable organic compounds, ammonium (NH ₄ ⁺)	d.	Anoxic/anaerobic biological treatment	Mercury (Hg), nitrate (NO ₃ ⁻), nitrite (NO ₂ ⁻)	e.	Coagulation and flocculation	Suspended solids	f.	Crystallisation	Metals and metalloids, sulphate (SO ₄ ²⁻), fluoride (F ⁻)	g.	Filtration (e.g. sand filtration, microfiltration, ultrafiltration)	Suspended solids, metals	h.	Flotation	Suspended solids, free oil	i.	Ion exchange	Metals	j.	Neutralisation	Acids, alkalis	k.	Oxidation	Sulphide (S ²⁻), sulphite (SO ₃ ²⁻)	l.	Precipitation	Metals and metalloids, sulphate (SO ₄ ²⁻), fluoride (F ⁻)	m.	Sedimentation	Suspended solids	n.	Stripping	Ammonia (NH ₃)	NA	Not applicable as no emissions to water from flue-gas treatment.
Technique	Typical pollutants prevented/abated	Applicability																																																				
Primary techniques																																																						
a.	Optimised combustion (see BAT 6) and flue-gas treatment systems (e.g. SCR/SNCR, see BAT 7)	Organic compounds, ammonia (NH ₃)																																																				
Secondary techniques ⁽²⁹⁾																																																						
b.	Adsorption on activated carbon	Organic compounds, mercury (Hg)																																																				
c.	Aerobic biological treatment	Biodegradable organic compounds, ammonium (NH ₄ ⁺)																																																				
d.	Anoxic/anaerobic biological treatment	Mercury (Hg), nitrate (NO ₃ ⁻), nitrite (NO ₂ ⁻)																																																				
e.	Coagulation and flocculation	Suspended solids																																																				
f.	Crystallisation	Metals and metalloids, sulphate (SO ₄ ²⁻), fluoride (F ⁻)																																																				
g.	Filtration (e.g. sand filtration, microfiltration, ultrafiltration)	Suspended solids, metals																																																				
h.	Flotation	Suspended solids, free oil																																																				
i.	Ion exchange	Metals																																																				
j.	Neutralisation	Acids, alkalis																																																				
k.	Oxidation	Sulphide (S ²⁻), sulphite (SO ₃ ²⁻)																																																				
l.	Precipitation	Metals and metalloids, sulphate (SO ₄ ²⁻), fluoride (F ⁻)																																																				
m.	Sedimentation	Suspended solids																																																				
n.	Stripping	Ammonia (NH ₃)																																																				

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																										
	<p>The BAT-AELs refer to direct discharges to a receiving water body at the point where the emission leaves the installation.</p> <p style="text-align: center;">BAT-AELs for direct discharges to a receiving water body from flue-gas treatment</p> <table border="1" data-bbox="322 469 1491 1056"> <thead> <tr> <th data-bbox="322 469 976 536" rowspan="2">Substance/Parameter</th> <th data-bbox="976 469 1491 501">BAT-AELs</th> </tr> <tr> <th data-bbox="976 501 1491 536">Daily average</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 536 976 568">Total organic carbon (TOC)</td> <td data-bbox="976 536 1491 568">20–50 mg/l ⁽³⁰⁾ ⁽³¹⁾ ⁽³²⁾</td> </tr> <tr> <td data-bbox="322 568 976 600">Chemical oxygen demand (COD)</td> <td data-bbox="976 568 1491 600">60–150 mg/l ⁽³⁰⁾ ⁽³¹⁾ ⁽³²⁾</td> </tr> <tr> <td data-bbox="322 600 976 632">Total suspended solids (TSS)</td> <td data-bbox="976 600 1491 632">10–30 mg/l</td> </tr> <tr> <td data-bbox="322 632 976 663">Fluoride (F⁻)</td> <td data-bbox="976 632 1491 663">10–25 mg/l ⁽³²⁾</td> </tr> <tr> <td data-bbox="322 663 976 695">Sulphate (SO₄²⁻)</td> <td data-bbox="976 663 1491 695">1,3–2,0 g/l ⁽³²⁾ ⁽³³⁾ ⁽³⁴⁾ ⁽³⁵⁾</td> </tr> <tr> <td data-bbox="322 695 976 727">Sulphide (S²⁻), easily released</td> <td data-bbox="976 695 1491 727">0,1–0,2 mg/l ⁽³²⁾</td> </tr> <tr> <td data-bbox="322 727 976 759">Sulphite (SO₃²⁻)</td> <td data-bbox="976 727 1491 759">1–20 mg/l ⁽³²⁾</td> </tr> <tr> <td data-bbox="322 759 976 1056" rowspan="8">Metals and metalloids</td> <td data-bbox="976 759 1491 791">As 10–50 µg/l</td> </tr> <tr> <td data-bbox="976 791 1491 823">Cd 2–5 µg/l</td> </tr> <tr> <td data-bbox="976 823 1491 855">Cr 10–50 µg/l</td> </tr> <tr> <td data-bbox="976 855 1491 887">Cu 10–50 µg/l</td> </tr> <tr> <td data-bbox="976 887 1491 919">Hg 0,2–3 µg/l</td> </tr> <tr> <td data-bbox="976 919 1491 951">Ni 10–50 µg/l</td> </tr> <tr> <td data-bbox="976 951 1491 983">Pb 10–20 µg/l</td> </tr> <tr> <td data-bbox="976 983 1491 1056">Zn 50–200 µg/l</td> </tr> </tbody> </table>	Substance/Parameter	BAT-AELs	Daily average	Total organic carbon (TOC)	20–50 mg/l ⁽³⁰⁾ ⁽³¹⁾ ⁽³²⁾	Chemical oxygen demand (COD)	60–150 mg/l ⁽³⁰⁾ ⁽³¹⁾ ⁽³²⁾	Total suspended solids (TSS)	10–30 mg/l	Fluoride (F ⁻)	10–25 mg/l ⁽³²⁾	Sulphate (SO ₄ ²⁻)	1,3–2,0 g/l ⁽³²⁾ ⁽³³⁾ ⁽³⁴⁾ ⁽³⁵⁾	Sulphide (S ²⁻), easily released	0,1–0,2 mg/l ⁽³²⁾	Sulphite (SO ₃ ²⁻)	1–20 mg/l ⁽³²⁾	Metals and metalloids	As 10–50 µg/l	Cd 2–5 µg/l	Cr 10–50 µg/l	Cu 10–50 µg/l	Hg 0,2–3 µg/l	Ni 10–50 µg/l	Pb 10–20 µg/l	Zn 50–200 µg/l		
Substance/Parameter	BAT-AELs																												
	Daily average																												
Total organic carbon (TOC)	20–50 mg/l ⁽³⁰⁾ ⁽³¹⁾ ⁽³²⁾																												
Chemical oxygen demand (COD)	60–150 mg/l ⁽³⁰⁾ ⁽³¹⁾ ⁽³²⁾																												
Total suspended solids (TSS)	10–30 mg/l																												
Fluoride (F ⁻)	10–25 mg/l ⁽³²⁾																												
Sulphate (SO ₄ ²⁻)	1,3–2,0 g/l ⁽³²⁾ ⁽³³⁾ ⁽³⁴⁾ ⁽³⁵⁾																												
Sulphide (S ²⁻), easily released	0,1–0,2 mg/l ⁽³²⁾																												
Sulphite (SO ₃ ²⁻)	1–20 mg/l ⁽³²⁾																												
Metals and metalloids	As 10–50 µg/l																												
	Cd 2–5 µg/l																												
	Cr 10–50 µg/l																												
	Cu 10–50 µg/l																												
	Hg 0,2–3 µg/l																												
	Ni 10–50 µg/l																												
	Pb 10–20 µg/l																												
	Zn 50–200 µg/l																												
16	<p>In order to reduce the quantity of waste sent for disposal from the combustion and/or gasification process and abatement techniques, BAT is to organise operations so as to maximise, in order of priority and taking into account life-cycle thinking:</p> <ul style="list-style-type: none"> (a) waste prevention, e.g. maximise the proportion of residues which arise as by-products; (b) waste preparation for reuse, e.g. according to the specific requested quality criteria; (c) waste recycling; (d) other waste recovery (e.g. energy recovery), <p>by implementing an appropriate combination of techniques such as:</p> <table border="1" data-bbox="322 1347 1491 1378"> <thead> <tr> <th data-bbox="322 1347 573 1378">Technique</th> <th data-bbox="573 1347 1079 1378">Description</th> <th data-bbox="1079 1347 1491 1378">Applicability</th> </tr> </thead> <tbody> <tr> <td> </td> <td> </td> <td> </td> </tr> </tbody> </table>	Technique	Description	Applicability				CC	There is no waste generated from combustion process and no abatement systems in operation at the installation.																				
Technique	Description	Applicability																											

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	a.	Generation of gypsum as a by-product	Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g. as raw material in the plasterboard industry). The quality of limestone used in the wet FGD influences the purity of the gypsum produced	Generally applicable within the constraints associated with the required gypsum quality, the health requirements associated to each specific use, and by the market conditions	
	b.	Recycling or recovery of residues in the construction sector	Recycling or recovery of residues (e.g. from semi-dry desulphurisation processes, fly ash, bottom ash) as a construction material (e.g. in road building, to replace sand in concrete production, or in the cement industry)	Generally applicable within the constraints associated with the required material quality (e.g. physical properties, content of harmful substances) associated to each specific use, and by the market conditions	
	c.	Energy recovery by using waste in the fuel mix	The residual energy content of carbon-rich ash and sludges generated by the combustion of coal, lignite, heavy fuel oil, peat or biomass can be recovered for example by mixing with the fuel	Generally applicable where plants can accept waste in the fuel mix and are technically able to feed the fuels into the combustion chamber	
	d.	Preparation of spent catalyst for reuse	Preparation of catalyst for reuse (e.g. up to four times for SCR catalysts) restores some or all of the original performance, extending the service life of the catalyst to several decades. Preparation of spent catalyst for reuse is integrated in a catalyst management scheme	The applicability may be limited by the mechanical condition of the catalyst and the required performance with respect to controlling NO _x and NH ₃ emissions	
17	In order to reduce noise emissions, BAT is to use one or a combination of the techniques given below.			CC	<p>The operator has confirmed that equipment is operated by experienced staff and a scheduled preventative maintenance programme is in place.</p> <p>The gas turbine intake and exhaust systems are housed in an acoustically insulated building. Compressors are in the same building as gas turbine with acoustically lagged compressor pipework.</p>
a.	Operational measures	<p>These include:</p> <ul style="list-style-type: none"> — improved inspection and maintenance of equipment — closing of doors and windows of enclosed areas, if possible — equipment operated by experienced staff — avoidance of noisy activities at night, if possible — provisions for noise control during maintenance activities 	Generally applicable		

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																				
	b.	Low-noise equipment	This potentially includes compressors, pumps and disks	Generally applicable when the equipment is new or replaced	Depressurisation valves and vents; high velocity vents are required for atmospheric dispersion (safety requirement). However their use, including running for maintenance, is infrequent.																				
	c.	Noise attenuation	Noise propagation can be reduced by inserting obstacles between the emitter and the receiver. Appropriate obstacles include protection walls, embankments and buildings	Generally applicable to new plants. In the case of existing plants, the insertion of obstacles may be restricted by lack of space																					
	d.	Noise-control equipment	This includes: — noise-reducers — equipment insulation — enclosure of noisy equipment — soundproofing of buildings	The applicability may be restricted by lack of space																					
	e.	Appropriate location of equipment and buildings	Noise levels can be reduced by increasing the distance between the emitter and the receiver and by using buildings as noise screens	Generally applicable to new plant																					
Combustion of gaseous fuels																									
40	In order to increase the energy efficiency of natural gas combustion, BAT is to use an appropriate combination of the techniques given in BAT 12 and below.			CC	<p>BAT 12: a, b, d, f, g, h, p and q.</p> <p>For LCP 237, BATc 12 is not applicable to plant which operates less than 1500 hours per year.</p> <p>Combined cycle is not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns.</p> <p>The net mechanical efficiency of LCP235 is 39.1%. This is based on product data from the original equipment manufacturer. We consider this plant is BAT in relation to the AEELs.</p>																				
<table border="1"> <thead> <tr> <th data-bbox="324 943 501 975">Technique</th> <th data-bbox="508 943 725 975">Description</th> <th data-bbox="732 943 1494 975">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="324 979 501 1177">a.</td> <td data-bbox="508 979 725 1177">Combined cycle See description in Section 8.2</td> <td data-bbox="732 979 1494 1177">Generally applicable to new gas turbines and engines except when operated < 1 500 h/yr. Applicable to existing gas turbines and engines within the constraints associated with the steam cycle design and the space availability. Not applicable to existing gas turbines and engines operated < 1 500 h/yr. Not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns. Not applicable to boilers</td> </tr> </tbody> </table>						Technique	Description	Applicability	a.	Combined cycle See description in Section 8.2	Generally applicable to new gas turbines and engines except when operated < 1 500 h/yr. Applicable to existing gas turbines and engines within the constraints associated with the steam cycle design and the space availability. Not applicable to existing gas turbines and engines operated < 1 500 h/yr. Not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns. Not applicable to boilers														
Technique	Description	Applicability																							
a.	Combined cycle See description in Section 8.2	Generally applicable to new gas turbines and engines except when operated < 1 500 h/yr. Applicable to existing gas turbines and engines within the constraints associated with the steam cycle design and the space availability. Not applicable to existing gas turbines and engines operated < 1 500 h/yr. Not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns. Not applicable to boilers																							
<p>BAT-associated energy efficiency levels (BAT-AEELs) for the combustion of natural gas</p> <table border="1"> <thead> <tr> <th data-bbox="324 1209 591 1369" rowspan="3">Type of combustion unit</th> <th colspan="4" data-bbox="598 1209 1494 1246">BAT-AEELs ⁽¹³⁶⁾ ⁽¹³⁷⁾</th> </tr> <tr> <th colspan="2" data-bbox="598 1251 853 1310">Net electrical efficiency (%)</th> <th data-bbox="860 1251 1137 1310" rowspan="2">Net total fuel utilisation (%) ⁽¹³⁸⁾ ⁽¹³⁹⁾</th> <th colspan="2" data-bbox="1144 1251 1494 1310">Net mechanical energy efficiency (%) ⁽¹³⁹⁾ ⁽¹⁴⁰⁾</th> </tr> <tr> <th data-bbox="598 1315 710 1369">New unit</th> <th data-bbox="716 1315 853 1369">Existing unit</th> <th data-bbox="1144 1315 1290 1369">New unit</th> <th data-bbox="1296 1315 1494 1369">Existing unit</th> </tr> </thead> <tbody> <tr> <td data-bbox="324 1374 591 1383"></td> <td data-bbox="598 1374 710 1383"></td> <td data-bbox="716 1374 853 1383"></td> <td data-bbox="860 1374 1137 1383"></td> <td data-bbox="1144 1374 1290 1383"></td> <td data-bbox="1296 1374 1494 1383"></td> </tr> </tbody> </table>						Type of combustion unit	BAT-AEELs ⁽¹³⁶⁾ ⁽¹³⁷⁾				Net electrical efficiency (%)		Net total fuel utilisation (%) ⁽¹³⁸⁾ ⁽¹³⁹⁾	Net mechanical energy efficiency (%) ⁽¹³⁹⁾ ⁽¹⁴⁰⁾		New unit	Existing unit	New unit	Existing unit						
Type of combustion unit	BAT-AEELs ⁽¹³⁶⁾ ⁽¹³⁷⁾																								
	Net electrical efficiency (%)		Net total fuel utilisation (%) ⁽¹³⁸⁾ ⁽¹³⁹⁾	Net mechanical energy efficiency (%) ⁽¹³⁹⁾ ⁽¹⁴⁰⁾																					
	New unit	Existing unit		New unit	Existing unit																				

BAT Concn. Number	Summary of BAT Conclusion requirement					Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	Gas engine	39,5–44 ⁽¹⁴¹⁾	35–44 ⁽¹⁴¹⁾	56–85 ⁽¹⁴¹⁾	No BAT-AEEL.		<p>The net mechanical efficiency for LCP236 is 33.3%. This is based on product data from the original equipment manufacturer. LCP 236 does not meet the BAT-AEEL range for this type of plant. However, LCP 236 is operated under a Limited Life Derogation (LLD). We are therefore satisfied that it would not be cost effective for any upgrades to this plant and that the current net mechanical efficiency is BAT.</p> <p>For LCP 237, Table 23 of the LCP BAT Conclusions specifies that the BAT-AEELs are not applicable to plant operating less than 1500 hours per year.</p> <p>A process monitoring requirement has been set in table S3.3 which requires energy efficiency monitoring after an overhaul for each LCP.</p>
Gas-fired boiler	39–42,5	38–40	78–95	No BAT-AEEL.			
Open cycle gas turbine, ≥ 50 MW _{th}	36–41,5	33–41,5	No BAT-AEEL	36,5–41	33,5–41		
Combined cycle gas turbine (CCGT)							
CCGT, 50–600 MW _{th}	53–58,5	46–54	No BAT-AEEL	No BAT-AEEL			
CCGT, ≥ 600 MW _{th}	57–60,5	50–60	No BAT-AEEL	No BAT-AEEL			
CHP CCGT, 50–600 MW _{th}	53–58,5	46–54	65–95	No BAT-AEEL			
CHP CCGT, ≥ 600 MW _{th}	57–60,5	50–60	65–95	No BAT-AEEL			
41	In order to prevent or reduce NO _x emissions to air from the combustion of natural gas in boilers, BAT is to use one or a combination of the techniques given below.					NA	Not applicable to Gas Turbines
Technique		Description			Applicability		
a.	Air and/or fuel staging	See descriptions in Section 8.3. Air staging is often associated with low-NO _x burners			Generally applicable		
b.	Flue-gas recirculation	See description in Section 8.3					

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																				
	<table border="1"> <tr> <td data-bbox="320 384 353 443">c.</td> <td data-bbox="353 384 580 443">Low-NO_x burners (LNB)</td> <td data-bbox="580 384 1021 443"></td> <td data-bbox="1021 384 1496 443"></td> </tr> <tr> <td data-bbox="320 443 353 555">d.</td> <td data-bbox="353 443 580 555">Advanced control system</td> <td data-bbox="580 443 1021 555">See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr</td> <td data-bbox="1021 443 1496 555">The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> <tr> <td data-bbox="320 555 353 639">e.</td> <td data-bbox="353 555 580 639">Reduction of the combustion air temperature</td> <td data-bbox="580 555 1021 639">See description in Section 8.3</td> <td data-bbox="1021 555 1496 639">Generally applicable within the constraints associated with the process needs</td> </tr> <tr> <td data-bbox="320 639 353 767">f.</td> <td data-bbox="353 639 580 767">Selective non-catalytic reduction (SNCR)</td> <td data-bbox="580 639 1021 767"></td> <td data-bbox="1021 639 1496 767">Not applicable to combustion plants operated < 500 h/yr with highly variable boiler loads. The applicability may be limited in the case of combustion plants operated between 500 h/yr and 1 500 h/yr with highly variable boiler loads</td> </tr> <tr> <td data-bbox="320 767 353 983">g.</td> <td data-bbox="353 767 580 983">Selective catalytic reduction (SCR)</td> <td data-bbox="580 767 1021 983"></td> <td data-bbox="1021 767 1496 983">Not applicable to combustion plants operated < 500 h/yr. Not generally applicable to combustion plants of < 100 MW_{th}. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr</td> </tr> </table>	c.	Low-NO _x burners (LNB)			d.	Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system	e.	Reduction of the combustion air temperature	See description in Section 8.3	Generally applicable within the constraints associated with the process needs	f.	Selective non-catalytic reduction (SNCR)		Not applicable to combustion plants operated < 500 h/yr with highly variable boiler loads. The applicability may be limited in the case of combustion plants operated between 500 h/yr and 1 500 h/yr with highly variable boiler loads	g.	Selective catalytic reduction (SCR)		Not applicable to combustion plants operated < 500 h/yr. Not generally applicable to combustion plants of < 100 MW _{th} . There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr				
c.	Low-NO _x burners (LNB)																								
d.	Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system																						
e.	Reduction of the combustion air temperature	See description in Section 8.3	Generally applicable within the constraints associated with the process needs																						
f.	Selective non-catalytic reduction (SNCR)		Not applicable to combustion plants operated < 500 h/yr with highly variable boiler loads. The applicability may be limited in the case of combustion plants operated between 500 h/yr and 1 500 h/yr with highly variable boiler loads																						
g.	Selective catalytic reduction (SCR)		Not applicable to combustion plants operated < 500 h/yr. Not generally applicable to combustion plants of < 100 MW _{th} . There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr																						
42	In order to prevent or reduce NO _x emissions to air from the combustion of natural gas in gas turbines, BAT is to use one or a combination of the techniques given below.			CC	<p>LCP 235 is compliant with the BAT AELs for NO_x through combustion system design and control.</p> <p>LCP 236 is operated under a Limited Life Derogation (LLD) as described in Article 33(1)(a) of the Industrial Emissions Directive 2010/75/EU. This means that the operator has agreed that the plant will not operate past 31 December 2023. The operator has stated that the units are old technology</p>																				
	<table border="1"> <thead> <tr> <th data-bbox="551 1061 580 1082">Technique</th> <th data-bbox="580 1061 1093 1082">Description</th> <th data-bbox="1093 1061 1496 1082">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="551 1082 580 1198">a.</td> <td data-bbox="580 1082 1093 1198">Advanced control system</td> <td data-bbox="1093 1082 1496 1198">See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr</td> </tr> <tr> <td data-bbox="551 1198 580 1257">b.</td> <td data-bbox="580 1198 1093 1257">Water/steam addition</td> <td data-bbox="1093 1198 1496 1257">See description in Section 8.3</td> </tr> <tr> <td data-bbox="551 1257 580 1388">c.</td> <td data-bbox="580 1257 1093 1388">Dry low-NO_x burners (DLN)</td> <td data-bbox="1093 1257 1496 1388">The applicability may be limited due to water availability</td> </tr> <tr> <td data-bbox="551 1388 580 1388"></td> <td data-bbox="580 1388 1093 1388"></td> <td data-bbox="1093 1388 1496 1388">The applicability may be limited in the case of turbines where a retrofit package is not available or when water/steam addition systems are installed</td> </tr> </tbody> </table>	Technique	Description	Applicability	a.	Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	b.	Water/steam addition	See description in Section 8.3	c.	Dry low-NO _x burners (DLN)	The applicability may be limited due to water availability			The applicability may be limited in the case of turbines where a retrofit package is not available or when water/steam addition systems are installed									
Technique	Description	Applicability																							
a.	Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr																							
b.	Water/steam addition	See description in Section 8.3																							
c.	Dry low-NO _x burners (DLN)	The applicability may be limited due to water availability																							
		The applicability may be limited in the case of turbines where a retrofit package is not available or when water/steam addition systems are installed																							

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	d.	Low-load design concept	Adaptation of the process control and related equipment to maintain good combustion efficiency when the demand in energy varies, e.g. by improving the inlet airflow control capability or by splitting the combustion process into decoupled combustion stages	The applicability may be limited by the gas turbine design	<p>and it is not financially feasible to upgrade due to the limited life of the units. We are satisfied that it would not be cost effective for any upgrades to this plant. If the operator intends to continue operation after 31 December 2023 they will require a permit variation and the requirements of these BAT Conclusions will apply. There are no BAT-AELs for plant operating under a LLD.</p> <p>LCP236 is operating less than 500 hours/year and does not have allocated BAT-AELs. We consider that the techniques described by this BAT conclusion are not applicable to LCP236 because:</p> <ul style="list-style-type: none"> - It operates less than 500 hours per year; - There are currently no NOx emission reduction options available; - Selective catalytic reduction (SCR) is not applicable to combustion plants operated less than 500 hour year. <p>In making this assessment, we have considered the reference technical information available within the Joint Environmental Programme (JEP) report</p>
e.	Low-NO _x burners (LNB)	See description in Section 8.3	Generally applicable to supplementary firing for heat recovery steam generators (HRSGs) in the case of combined-cycle gas turbine (CCGT) combustion plants		
f.	Selective catalytic reduction (SCR)		<p>Not applicable in the case of combustion plants operated < 500 h/yr.</p> <p>Not generally applicable to existing combustion plants of < 100 MW_{th}.</p> <p>Retrofitting existing combustion plants may be constrained by the availability of sufficient space.</p> <p>There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr</p>		

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement														
			UTG/18/PMP/774/R. Further details are discussed in the key issues section.														
43	<p>In order to prevent or reduce NO_x emissions to air from the combustion of natural gas in engines, BAT is to use one or a combination of the techniques given below.</p> <table border="1" data-bbox="322 568 1491 1011"> <thead> <tr> <th data-bbox="322 568 533 603">Technique</th> <th data-bbox="533 568 999 603">Description</th> <th data-bbox="999 568 1491 603">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 603 533 711">a. Advanced control system</td> <td data-bbox="533 603 999 711">See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr</td> <td data-bbox="999 603 1491 711">The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> <tr> <td data-bbox="322 711 533 769">b. Lean-burn concept</td> <td data-bbox="533 711 999 769">See description in Section 8.3. Generally used in combination with SCR</td> <td data-bbox="999 711 1491 769">Only applicable to new gas-fired engines</td> </tr> <tr> <td data-bbox="322 769 533 829">c. Advanced lean-burn concept</td> <td data-bbox="533 769 999 829" rowspan="2">See descriptions in Section 8.3</td> <td data-bbox="999 769 1491 829">Only applicable to new spark plug ignited engines</td> </tr> <tr> <td data-bbox="322 829 533 1011">d. Selective catalytic reduction (SCR)</td> <td data-bbox="999 829 1491 1011">Retrofitting existing combustion plants may be constrained by the availability of sufficient space. Not applicable to combustion plants operated < 500 h/yr. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system	b. Lean-burn concept	See description in Section 8.3. Generally used in combination with SCR	Only applicable to new gas-fired engines	c. Advanced lean-burn concept	See descriptions in Section 8.3	Only applicable to new spark plug ignited engines	d. Selective catalytic reduction (SCR)	Retrofitting existing combustion plants may be constrained by the availability of sufficient space. Not applicable to combustion plants operated < 500 h/yr. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr	NA	Not applicable to Gas Turbines
Technique	Description	Applicability															
a. Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system															
b. Lean-burn concept	See description in Section 8.3. Generally used in combination with SCR	Only applicable to new gas-fired engines															
c. Advanced lean-burn concept	See descriptions in Section 8.3	Only applicable to new spark plug ignited engines															
d. Selective catalytic reduction (SCR)		Retrofitting existing combustion plants may be constrained by the availability of sufficient space. Not applicable to combustion plants operated < 500 h/yr. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr															
44	<p>In order to prevent or reduce CO emissions to air from the combustion of natural gas, BAT is to ensure optimised combustion and/or to use oxidation catalysts.</p> <p>Description - See descriptions in Section 8.3.</p> <p>BAT-associated emission levels (BAT-AELs) for NO_x emissions to air from the combustion of natural gas in gas turbines</p> <table border="1" data-bbox="322 1168 1491 1369"> <thead> <tr> <th data-bbox="322 1168 788 1289" rowspan="2">Type of combustion plant</th> <th data-bbox="788 1168 1025 1289" rowspan="2">Combustion plant total rated thermal input (MW_{th})</th> <th colspan="2" data-bbox="1025 1168 1491 1203">BAT-AELs (mg/Nm³) ⁽¹⁴²⁾ ⁽¹⁴³⁾</th> </tr> <tr> <th data-bbox="1025 1203 1249 1289">Yearly average ⁽¹⁴⁴⁾ ⁽¹⁴⁵⁾</th> <th data-bbox="1249 1203 1491 1289">Daily average or average over the sampling period</th> </tr> </thead> <tbody> <tr> <td colspan="4" data-bbox="322 1289 1491 1327" style="text-align: center;">Open-cycle gas turbines (OCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁷⁾</td> </tr> <tr> <td data-bbox="322 1327 788 1369">New OCGT</td> <td data-bbox="788 1327 1025 1369">≥ 50</td> <td data-bbox="1025 1327 1249 1369">15–35</td> <td data-bbox="1249 1327 1491 1369">25–50</td> </tr> </tbody> </table>	Type of combustion plant	Combustion plant total rated thermal input (MW _{th})	BAT-AELs (mg/Nm ³) ⁽¹⁴²⁾ ⁽¹⁴³⁾		Yearly average ⁽¹⁴⁴⁾ ⁽¹⁴⁵⁾	Daily average or average over the sampling period	Open-cycle gas turbines (OCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁷⁾				New OCGT	≥ 50	15–35	25–50	CC	<p>LCP 235 is compliant with the BAT AELs for CO and NO_x through combustion system design and control.</p> <p>For LCP 235, as an existing OCGT Mechanical Drive plant put into operation no later than 7 January 2014, operating with unlimited hours, the applicable NO_x BAT-AELs are 60 mg/m³ (annually) and 65 mg/m³ (daily).</p>
Type of combustion plant	Combustion plant total rated thermal input (MW _{th})			BAT-AELs (mg/Nm ³) ⁽¹⁴²⁾ ⁽¹⁴³⁾													
		Yearly average ⁽¹⁴⁴⁾ ⁽¹⁴⁵⁾	Daily average or average over the sampling period														
Open-cycle gas turbines (OCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁷⁾																	
New OCGT	≥ 50	15–35	25–50														

BAT Concn. Number	Summary of BAT Conclusion requirement				Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	Existing OCGT (excluding turbines for mechanical drive applications) — All but plants operated < 500 h/yr	≥ 50	15–50	25–55 ⁽¹⁴⁸⁾		<p>The indicative annual CO BAT-AEL is 40 mg/m³.</p> <p>Where the existing permit sets monthly, daily and hourly average emission limits for CO and NO_x. Under the principal of “no backsliding”, the current emission limits will be retained unless tighter limits are set by the BREF.</p> <p>Limits for CO and NO_x are applicable above 55% MCR. See the key issues section for further information.</p> <p>LCP 236: In 2015, the Operator chose to operate LCP 236 under a Limited Life Derogation (LLD) as described in Article 33(1)(a) of the Industrial Emissions Directive 2010/75/EU. This means the gas turbine will not be operated for more than 17,500 hours, starting from 1 January 2016 and ending no later than 31 December 2023. Operators of combustion plants that have opted for the LLD do not have to comply with the BATcs applicable to the air pollutants that are subject to the LLD. Therefore the current emission limits will be retained and we have not set any additional or revised emission limits for LCP 236 as part of this review.</p>
Combined-cycle gas turbines (CCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁹⁾						
New CCGT	≥ 50	10–30	15–40			
Existing CCGT with a net total fuel utilisation of < 75 %	≥ 600	10–40	18–50			
Existing CCGT with a net total fuel utilisation of ≥ 75 %	≥ 600	10–50	18–55 ⁽¹⁵⁰⁾			
Existing CCGT with a net total fuel utilisation of < 75 %	50–600	10–45	35–55			
Existing CCGT with a net total fuel utilisation of ≥ 75 %	50–600	25–50 ⁽¹⁵¹⁾	35–55 ⁽¹⁵²⁾			
Open- and combined-cycle gas turbines						
Gas turbine put into operation no later than 27 November 2003, or existing gas turbine for emergency use and operated < 500 h/yr	≥ 50	No BAT-AEL	60–140 ⁽¹⁵³⁾ ⁽¹⁵⁴⁾			
Existing gas turbine for mechanical drive applications — All but plants operated < 500 h/yr	≥ 50	15–50 ⁽¹⁵⁵⁾	25–55 ⁽¹⁵⁶⁾			
<p>As an indication, the yearly average CO emission levels for each type of existing combustion plant operated ≥ 1 500 h/yr and for each type of new combustion plant will generally be as follows:</p> <ul style="list-style-type: none"> — New OCGT of ≥ 50 MW_{th}: < 5–40 mg/Nm³. For plants with a net electrical efficiency (EE) greater than 39 %, a correction factor may be applied to the higher end of this range, corresponding to [higher end] × EE/39, where EE is the net electrical energy efficiency or net mechanical energy efficiency of the plant determined at ISO baseload conditions. — Existing OCGT of ≥ 50 MW_{th} (excluding turbines for mechanical drive applications): < 5–40 mg/Nm³. The higher end of this range will generally be 80 mg/Nm³ in the case of existing plants that cannot be fitted with dry techniques for NO_x reduction, or 50 mg/Nm³ for plants that operate at low load. — New CCGT of ≥ 50 MW_{th}: < 5–30 mg/Nm³. For plants with a net electrical efficiency (EE) greater than 55 %, a correction factor may be applied to the higher end of the range, corresponding to [higher end] × EE/55, where EE is the net electrical energy efficiency of the plant determined at ISO baseload conditions. — Existing CCGT of ≥ 50 MW_{th}: < 5–30 mg/Nm³. The higher end of this range will generally be 50 mg/Nm³ for plants that operate at low load. 						

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																							
	<p>— Existing gas turbines of $\geq 50 \text{ MW}_{\text{th}}$ for mechanical drive applications: $< 5\text{--}40 \text{ mg/Nm}^3$. The higher end of the range will generally be 50 mg/Nm^3 when plants operate at low load.</p> <p>In the case of a gas turbine equipped with DLN burners, these indicative levels correspond to when the DLN operation is effective.</p> <p>BAT-associated emission levels (BAT-AELs) for NO_x emissions to air from the combustion of natural gas in boilers and engines</p> <table border="1" data-bbox="322 555 1496 778"> <thead> <tr> <th rowspan="3">Type of combustion plant</th> <th colspan="4">BAT-AELs (mg/Nm³)</th> </tr> <tr> <th colspan="2">Yearly average ⁽¹⁵⁷⁾</th> <th colspan="2">Daily average or average over the sampling period</th> </tr> <tr> <th>New plant</th> <th>Existing plant ⁽¹⁵⁸⁾</th> <th>New plant</th> <th>Existing plant ⁽¹⁵⁹⁾</th> </tr> </thead> <tbody> <tr> <td>Boiler</td> <td>10–60</td> <td>50–100</td> <td>30–85</td> <td>85–110</td> </tr> <tr> <td>Engine ⁽¹⁶⁰⁾</td> <td>20–75</td> <td>20–100</td> <td>55–85</td> <td>55–110 ⁽¹⁶¹⁾</td> </tr> </tbody> </table> <p>As an indication, the yearly average CO emission levels will generally be:</p> <ul style="list-style-type: none"> — $< 5\text{--}40 \text{ mg/Nm}^3$ for existing boilers operated $\geq 1\,500 \text{ h/yr}$, — $< 5\text{--}15 \text{ mg/Nm}^3$ for new boilers, — $30\text{--}100 \text{ mg/Nm}^3$ for existing engines operated $\geq 1\,500 \text{ h/yr}$ and for new engines. 	Type of combustion plant	BAT-AELs (mg/Nm ³)				Yearly average ⁽¹⁵⁷⁾		Daily average or average over the sampling period		New plant	Existing plant ⁽¹⁵⁸⁾	New plant	Existing plant ⁽¹⁵⁹⁾	Boiler	10–60	50–100	30–85	85–110	Engine ⁽¹⁶⁰⁾	20–75	20–100	55–85	55–110 ⁽¹⁶¹⁾		<p>LCP 237 is operated < 500 hours per year for emergency use, therefore indicative BAT does not apply. There are no BAT-AELs or emissions limit values (ELVs) set in the permit for LCP 237</p>
Type of combustion plant	BAT-AELs (mg/Nm ³)																									
	Yearly average ⁽¹⁵⁷⁾		Daily average or average over the sampling period																							
	New plant	Existing plant ⁽¹⁵⁸⁾	New plant	Existing plant ⁽¹⁵⁹⁾																						
Boiler	10–60	50–100	30–85	85–110																						
Engine ⁽¹⁶⁰⁾	20–75	20–100	55–85	55–110 ⁽¹⁶¹⁾																						
45	<p>In order to reduce non-methane volatile organic compounds (NMVOC) and methane (CH₄) emissions to air from the combustion of natural gas in spark-ignited lean-burn gas engines, BAT is to ensure optimised combustion and/or to use oxidation catalysts.</p> <p>Description</p> <p>See descriptions in Section 8.3. Oxidation catalysts are not effective at reducing the emissions of saturated hydrocarbons containing less than four carbon atoms.</p> <p>BAT-associated emission levels (BAT-AELs) for formaldehyde and CH₄ emissions to air from the combustion of natural gas in a spark-ignited lean-burn gas engine</p> <table border="1" data-bbox="322 1166 1496 1342"> <thead> <tr> <th rowspan="4">Combustion plant total rated thermal input (MW_{th})</th> <th colspan="3">BAT-AELs (mg/Nm³)</th> </tr> <tr> <th>Formaldehyde</th> <th colspan="2">CH₄</th> </tr> <tr> <th colspan="3">Average over the sampling period</th> </tr> <tr> <th>New or existing plant</th> <th>New plant</th> <th>Existing plant</th> </tr> </thead> <tbody> <tr> <td>≥ 50</td> <td>$5\text{--}15$ ⁽¹⁶²⁾</td> <td>$215\text{--}500$ ⁽¹⁶³⁾</td> <td>$215\text{--}560$ ⁽¹⁶²⁾ ⁽¹⁶³⁾</td> </tr> </tbody> </table>	Combustion plant total rated thermal input (MW _{th})	BAT-AELs (mg/Nm ³)			Formaldehyde	CH ₄		Average over the sampling period			New or existing plant	New plant	Existing plant	≥ 50	$5\text{--}15$ ⁽¹⁶²⁾	$215\text{--}500$ ⁽¹⁶³⁾	$215\text{--}560$ ⁽¹⁶²⁾ ⁽¹⁶³⁾	NA	Not applicable to Gas Turbines						
Combustion plant total rated thermal input (MW _{th})	BAT-AELs (mg/Nm ³)																									
	Formaldehyde		CH ₄																							
	Average over the sampling period																									
	New or existing plant	New plant	Existing plant																							
≥ 50	$5\text{--}15$ ⁽¹⁶²⁾	$215\text{--}500$ ⁽¹⁶³⁾	$215\text{--}560$ ⁽¹⁶²⁾ ⁽¹⁶³⁾																							

6. Review and assessment of derogation requests made by the operator in relation to BAT Conclusions which include an associated emission level (AEL) value

The IED enables a competent authority to allow derogations from BAT AELs stated in BAT Conclusions under specific circumstances as detailed under Article 15(4):

By way of derogation from paragraph 3, and without prejudice to Article 18, the competent authority may, in specific cases, set less strict emission limit values. Such a derogation may apply only where an assessment shows that the achievement of emission levels associated with the best available techniques as described in BAT conclusions would lead to disproportionately higher costs compared to the environmental benefits due to:

(a) the geographical location or the local environmental conditions of the installation concerned; or

(b) the technical characteristics of the installation concerned.

As part of their Regulation 61 Note response, the operator has not requested a derogation from compliance with any AEL values.

7. Emissions to Water

The consolidated permit incorporates the two current discharges to controlled waters identified as W1 and W2.

There are no BAT AELs specified in the BAT Conclusions for this type of plant. There are also no additional treatment options identified as BAT for the installation. We have therefore not carried out any additional assessment of the emissions to water as part of this review.

8 Additional IED Chapter II requirements:

There are no additional IED Chapter II requirements addressed through the permit review.

9 Review and assessment of changes that are not part of the BAT Conclusions derived permit review.

This document should be read in conjunction with the application, supporting information and notice.

Aspect considered	Decision
Receipt of application	
Confidential information	A claim for commercial or industrial confidentiality has not been made.
Identifying confidential information	We have not identified information provided as part of the application that we consider to be confidential.
The site	
Biodiversity, heritage, landscape and nature conservation	<p>The application is within the relevant distance criteria of a site of heritage, landscape or nature conservation, and/or protected species or habitat.</p> <p>A full assessment of the application and its potential to affect the site(s)/species/habitat has not been carried out as part of the permit review process. We consider that the review will not affect the features of the site(s)/species/habitat as the conditions will provide at least the same level of protection as those in the previous permit and in some cases will provide a higher level of protection to those in the previous permit.</p> <p>We have not consulted Natural England on the application. The decision was taken in accordance with our guidance.</p>
Operating techniques	
General operating techniques	<p>We have reviewed the techniques used by the operator where they are relevant to the BAT Conclusions and compared these with the relevant guidance notes.</p> <p>The permit conditions ensure compliance with the relevant BREF, BAT Conclusions. The ELVs deliver compliance with the BAT-AELs.</p>
Permit conditions	
Updating permit conditions during consolidation	We have updated permit conditions to those in the current generic permit template as part of permit consolidation. The conditions will provide at least the same level of protection as those in the previous permit and in some cases will provide a higher level of protection to those in the previous permit.

Aspect considered	Decision
Changes to the permit conditions due to an Environment Agency initiated variation	We have varied the permit as stated in the variation notice.
Use of conditions other than those from the template	<p>We have retained conditions 2.3.4 and 2.3.5 from the original permit relating to the simultaneous operation of the turbine units (referred to in the conditions as Cab A to Cab E).</p> <p>We have also retained condition 2.3.6 relating to the annual Network Review. This is a condition of the permits for all National Grid Gas compressor stations.</p>
Improvement programme	We have also removed the completed improvement conditions from the permit (Improvement conditions 1 to 9).
Emission limits	<p>We have decided that emission limits should be set for the parameters listed in the permit.</p> <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p> <p>It is considered that the ELVs/equivalent parameters or technical measures described above will ensure that significant pollution of the environment is prevented and a high level of protection for the environment is secured.</p>
Monitoring	<p>We have decided that monitoring should be carried out for the parameters listed in the permit, using the methods detailed and to the frequencies specified.</p> <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p> <p>Table S3.3 Process monitoring requirements was amended to include the requirement to monitor energy efficiency after overhauls on site in line with BAT2.</p> <p>Based on the information in the application we are satisfied that the operator's techniques, personnel and equipment have either MCERTS certification or MCERTS accreditation as appropriate.</p>
Reporting	<p>We have specified reporting in the permit for the following parameters:</p> <ul style="list-style-type: none"> • Nitrogen dioxide • Carbon monoxide <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p>

Aspect considered	Decision
Operator competence	
Management system	There is no known reason to consider that the operator will not have the management system to enable it to comply with the permit conditions.
Growth Duty	
Section 108 Deregulation Act 2015 – Growth duty	<p>We have considered our duty to have regard to the desirability of promoting economic growth set out in section 108(1) of the Deregulation Act 2015 and the guidance issued under section 110 of that Act in deciding whether to grant this permit.</p> <p>Paragraph 1.3 of the guidance says: “The primary role of regulators, in delivering regulation, is to achieve the regulatory outcomes for which they are responsible. For a number of regulators, these regulatory outcomes include an explicit reference to development or growth. The growth duty establishes economic growth as a factor that all specified regulators should have regard to, alongside the delivery of the protections set out in the relevant legislation.”</p> <p>We have addressed the legislative requirements and environmental standards to be set for this operation in the body of the decision document above. The guidance is clear at paragraph 1.5 that the growth duty does not legitimise non-compliance and its purpose is not to achieve or pursue economic growth at the expense of necessary protections.</p> <p>We consider the requirements and standards we have set in this permit are reasonable and necessary to avoid a risk of an unacceptable level of pollution. This also promotes growth amongst legitimate operators because the standards applied to the operator are consistent across businesses in this sector and have been set to achieve the required legislative standards.</p>