

Environment Agency

Review of an Environmental Permit for an Installation subject to Chapter II of the Industrial Emissions Directive under the Environmental Permitting (England & Wales) Regulations 2016

Decision document recording our decision-making process following review of a permit

The Permit number is: [EPR/XP3839XV](#)
The Operator is: SembCorp Utilities (UK) Limited
The Installation is: Wilton No.2 Gas Turbine
This Variation Notice number is: [EPR/XP3839XV/V005](#)

What this document is about

Article 21(3) of the Industrial Emissions Directive (IED) requires the Environment Agency to review conditions in permits that it has issued and to ensure that the permit delivers compliance with relevant standards, within four years of the publication of updated decisions on best available techniques (BAT) Conclusions.

We have reviewed the permit for this installation against the revised BAT Conclusions for large combustion plant (LCP) published on 17 August 2017. This is our decision document, which explains the reasoning for the consolidated variation notice that we are issuing.

It explains how we have reviewed and considered the techniques used by the Operator in the operation and control of the plant and activities of the installation. This review has been undertaken with reference to the decision made by the European Commission establishing BAT Conclusions for LCP as detailed in document reference IEDC-7-1. It is our record of our decision-making process and shows how we have taken into account all relevant factors in reaching our position. It also provides a justification for the inclusion of any specific conditions in the permit that are in addition to those included in our generic permit template.

As well as considering the review of the operating techniques used by the Operator for the operation of the plant and activities of the installation, the consolidated variation notice takes into account and brings together in a single document all previous variations that relate to the original permit issued. It also modernises the entire permit to reflect the conditions contained in our current generic permit template.

The introduction of new template conditions makes the permit consistent with our current general approach and philosophy and with other permits issued to installations in this sector. Although the wording of some conditions has changed, while others have been removed because of the new regulatory approach, it does not reduce the level of environmental protection achieved by the permit in any way. In this document we therefore address only our determination of substantive issues relating to the new BAT Conclusions.

Throughout this document we will use a number of expressions. These are as referred to in the glossary and have the same meaning as described in “Schedule 6 Interpretation” of the permit.

We try to explain our decision as accurately, comprehensively and plainly as possible. We would welcome any feedback as to how we might improve our decision documents in future. A lot of technical terms and acronyms are inevitable in a document of this nature: we provide a glossary of acronyms near the front of the document, for ease of reference.

How this document is structured

Glossary of terms

- 1 Our decision
- 2 How we reached our decision
- 2.1 Requesting information to demonstrate compliance with BAT
Conclusions for Large Combustion Plant
- 2.2 Review of our own information in respect to the capability of the
installation to meet revised standards included in the BAT Conclusions
document
- 3 The legal framework
- 4 Key issues
- 5 Decision checklist regarding relevant BAT Conclusions
- 6 Review and assessment of derogation requests made by the operator in
relation to BAT Conclusions which include an associated emission level
(AEL) value
- 7 Emissions to water
- 8 Additional IED Chapter II requirements
- 9 Review and assessment of changes that are not part of the BAT
Conclusions derived permit review.

Glossary of acronyms used in this document

(Please note that this glossary is standard for our decision documents and therefore not all these acronyms are necessarily used in this document.)

APC	Air Pollution Control
BAT	Best Available Technique(s)
BAT-AEEL	BAT Associated Energy Efficiency Level
BAT-AEL	BAT Associated Emission Level
BATc	BAT conclusion
BREF	Best available techniques reference document
CCGT	Combined Cycle Gas Turbine
CEM	Continuous emissions monitor
CHP	Combined heat and power
CV	Calorific value
DAA	Directly associated activity – Additional activities necessary to be carried out to allow the principal activity to be carried out
DLN	Dry Low NOx burners
DLN-E	Dry Low NOx effective
EIONET	European environment information and observation network is a partnership network of the European Environment Agency
ELV	Emission limit value derived under BAT or an emission limit value set out in IED
EMS	Environmental Management System
EPR	Environmental Permitting (England and Wales) Regulations 2016 (SI 2016 No. 1154)
EWC	European waste catalogue
FSA	Food Standards Agency
IC	Improvement Condition
IED	Industrial Emissions Directive (2010/75/EU)
IPPCD	Integrated Pollution Prevention and Control Directive (2008/1/EC) – now superseded by IED
LCP	Large Combustion Plant subject to Chapter III of IED
MSUL/MSDL	Minimum start up load/minimum shut-down load
NOx	Oxides of nitrogen (NO plus NO2 expressed as NO2)
NPV	Net Present Value
OCGT	Open Cycle Gas Turbine
PHE	Public Health England
SAC	Special Area of Conservation
SGN	Sector guidance note
TGN	Technical guidance note
TNP	Transitional National Plan
TOC	Total Organic Carbon
WFD	Water Framework Directive (2000/60/EC)

1 Our decision

We have decided to issue the consolidated variation notice to the Operator. This will allow them to continue to operate the installation, subject to the conditions in the consolidated variation notice.

We consider that, in reaching that decision, we have taken into account all relevant considerations and legal requirements and that the varied permit will ensure that a high level of protection is provided for the environment and human health.

The consolidated variation notice contains many conditions taken from our standard Environmental Permit template including the relevant Annexes. We developed these conditions in consultation with industry, having regard to the legal requirements of the Environmental Permitting Regulations (EPR) (England and Wales) 2016 and other relevant legislation. This document does not therefore include an explanation for these standard conditions. Where they are included in the Notice, we have considered the techniques identified by the Operator for the operation of their installation, and have accepted that the details are sufficient and satisfactory to make those standard conditions appropriate. This document does, however, provide an explanation of our use of “tailor-made” or installation-specific conditions, or where our permit template provides two or more options.

2 How we reached our decision

2.1 Requesting information to demonstrate compliance with BAT Conclusions for Large Combustion Plant

We issued a Notice under Regulation 61(1) of the EPR 2016 (a Regulation 61 Notice) on 01 May 2018 requiring the Operator to provide information to demonstrate how the operation of their installation currently meets, or will subsequently meet, the revised standards described in the LCP BAT Conclusions document. The Notice also required that where the revised standards are not currently met, the Operator should provide information that:

- Describes the techniques that will be implemented before 17 August 2021, which will then ensure that operations meet the revised standard, or
- Justifies why standards will not be met by 17 August 2021, and confirmation of the date when the operation of those processes will cease within the installation or an explanation of why the revised BAT standard is not applicable to those processes, or
- Justifies why an alternative technique will achieve the same level of environmental protection equivalent to the revised standard described in the BAT Conclusions.

Where the Operator proposed that they were not intending to meet a BAT standard that also included a BAT Associated Emission Level (BAT AEL) described in the BAT Conclusions document, the Regulation 61 Notice requested that the Operator make a formal request for derogation from compliance with that AEL (as provisioned by Article 15(4) of the IED). In this circumstance, the Notice identified that any such request for derogation must be supported and justified by sufficient technical and commercial information that would enable us to determine acceptability of the derogation request.

We did not receive any such request from the Operator.

The Regulation 61 notice response from the Operator was received on 19 March 2019.

We considered it was in the correct form and contained sufficient information for us to begin our determination of the permit review but not that it necessarily contained all the information we would need to complete that review: see below.

Request for information sent 23 January 2020. BAT Conclusions 1, 2, 5, 10, 12, 16, 40, 42 and 44	Response received 13 March 2020.
BAT Conclusions 40 and 44	Response received 01 April 2020
LCP thermal inputs	Response received 04 May 2020

2.2 Review of our own information in respect to the capability of the installation to meet revised standards included in the BAT Conclusions document

Based on our records and previous regulatory activities with the facility we have no reason to consider that the Operator will not be able to comply with the conditions that we include in the permit.

In relation to BAT Conclusions 2, 9 and 40 we agree with the Operator in respect to their current stated capability as recorded in their Regulation 61 Notice response that improvements are required.

We have therefore included improvement conditions in the consolidated variation notice, which requires them to upgrade their operational techniques so that the requirements of these BAT Conclusions are delivered by 17 August 2021. This is discussed in more detail in the Key issues section and in the decision checklist regarding relevant BAT Conclusions.

3 The legal framework

The consolidated variation notice will be issued under Regulation 20 of the EPR. The Environmental Permitting regime is a legal vehicle which delivers most of the relevant legal requirements for activities falling within its scope. In particular, the regulated facility is:

- an *installation* as described by the IED;
- subject to aspects of other relevant legislation which also have to be addressed.

We consider that the consolidated variation notice will ensure that the operation of the installation complies with all relevant legal requirements and that a high level of protection will be delivered for the environment and human health.

We explain how we have addressed specific statutory requirements more fully in the rest of this document.

4 The key issues

The key issues arising during this permit review are:

- Emissions to air and the emission limits applied to the plant.
- The energy efficiency levels associated with the Best Available Techniques (BAT-AEELs).

We therefore describe how we determined these issues in most detail in the relevant sections of this document.

4.1 Emissions to air and the emission limits applied to the plant

A number of general principles were applied during the permit review. These included:

- The upper value of the BAT AELs ranges specified were used unless use of the tighter limit was justified.
- The principle of no backsliding where if existing limits in the permit were already tighter than those specified in the BREF, the existing permit limits were retained.
- Where a limit was specified in both IED Annex V and the BAT Conclusions for a particular reference period, the tighter limit was applied and in the majority of cases this was from the BAT Conclusions.
- Where AELs are indicative in the BAT Conclusions, these were applied unless adequate justification was provided by the Operator to demonstrate that an alternative limit was more appropriate.

- For gas turbines where the IED specified that limits applied over 70% load and the BAT Conclusions specified that AELs applied when dry low NOx is effective (DLN-E), we have used DLN-E as a default across all monitoring requirements for NOx and CO.

a) LCP 320 configuration

This is a natural gas-fired combined heat and power (CHP) plant located within the Wilton International site. The **133.1 MWth** Wilton No.2 gas turbine incorporates a Combined Cycle Gas Turbine (CCGT) and a single pressure heat recovery steam generator (HRSG) which is capable of 162 tonnes/hour of IP steam at 18 barg and 300 °C or 100 tonnes/hour of HP steam at 96 barg and 320 °C.

The turbine runs on natural gas and vents through a 50m high single stack, at emission point A6. The plant does not operate in open cycle i.e. open cycle gas turbine (OCGT).

b) Emission limits

The plant was put into operation before the IED came into force and therefore the existing limits in the permit are from Part 1 of IED Annex V, applicable to existing plant.

The emission limit values (ELVs) and AELs are based on an unlimited hours operating regime.

The following tables outline the limits that have been incorporated into the permit for LCP 320, where these were derived from and the reference periods at which they apply. The emission limits refer to concentrations, expressed as mass of emitted substance per volume of flue-gas under the following standard conditions:

- dry gas at a temperature of 273.15 K;
- pressure of 101.3 kPa; and
- 15% volume reference oxygen concentration in the flue gases.

The emission limits and monitoring requirements have been incorporated into Schedule 3 of the permit.

NOx limits – BAT Conclusion 44

NOx limits (mg/Nm ³) – corrected to 15% oxygen						
Averaging	IED (Annex V Part 1) – Existing plant	BREF (BAT C 44, Table 24)	Permit limits	Basis	Limits apply	Monitoring
Annual	None	45 (50-600 MW _{th} , <75%) ¹	45	BREF	DLN-E	Continuous
Monthly	50	None	50	IED	DLN-E	
Daily	55	55 (50-600 MW _{th} , <75%) ¹	55	BREF	DLN-E	
95 th %ile of hourly means	100	None	100	IED	DLN-E	
1 – The Operator confirmed that the lower limits for existing CCGT with a net total fuel utilisation of <75% are achievable (telecon 30 April 2020).						

The Operator confirmed that DLN operation is effective for the gas turbine at 26 MW, which corresponds to 62% load (telecon 30 April 2020).

They also confirmed that this is also the point of MSUL/MSDL. Refer to section 8 of this document.

A formal submission will be required in accordance with existing permit improvement condition IC9.

We have also set a daily limit applicable from MSUL/MSDL to baseload, consistent with the daily limit when DLN is effective. The Operator will be required to submit a formal submission in accordance with existing permit improvement condition IC10.

Tables S1.5, S1.6, S3.1 and S3.1a of the permit have been updated to reflect these requirements.

CO limits – BAT Conclusion 44

CO indicative emission levels are a yearly average of 30 mg/Nm³. For plants operating at low load, the higher end of this range will be 50 mg/Nm³.

The Operator has proposed a yearly average limit of 30 mg/Nm³ (telecon 30 April 2020), with the existing IED Annex V ELVs remaining unchanged.

The applicable indicative BAT AELs are set out in the table below. We have also added the limits which will be in the varied permit and confirmed the basis for their inclusion.

CO (indicative) limits (mg/Nm ³) – corrected to 15% oxygen							
Averaging	IED (Annex V Part 1) – Existing plant	Actual existing permit limits	BREF (BAT C 44, Table 24)	Permit limits	Basis	Limits apply	Monitoring
Annual	None	None	30	30	BREF	DLN-E	Continuous
Monthly	100	100	None	100	IED	DLN-E	
Daily	110	100	None	100	IED	DLN-E	
95 th %ile of hr means	200	200	None	200	IED	DLN-E	

We have also set a daily limit applicable from MSUL/MSDL to baseload, consistent with the daily limit when DLN is effective. The Operator will be required to submit a formal submission in accordance with existing permit improvement condition IC10.

Tables S1.5, S1.6, S3.1 and S3.1a of the permit have been updated to reflect these requirements.

4.2 The energy efficiency levels associated with the Best Available Techniques Conclusions

An energy efficiency level associated with the best available techniques (BAT-AEEL) refers to the ratio between the combustion unit's net energy output(s) and the combustion unit's fuel/feedstock energy input at actual unit design. The net energy output(s) is determined at the combustion unit boundaries, including auxiliary systems (e.g. flue-gas treatment systems), and for the unit operated at full load.

We have included a process monitoring requirement in table S3.3 of the consolidated variation notice. This is required to demonstrate that efficiency levels are maintained following any significant overhauls of equipment in order to fulfil the requirement of BAT Conclusion 2.

The table below sets out the BAT AEELs specified in the LCP BAT Conclusions for the LCP on the site and the energy efficiency levels confirmed through the additional information received 01 April 2020.

We are not fully satisfied that performance testing has been carried out in accordance with BAT Conclusion 2 and have set an improvement condition to address this. The Operator has committed to carrying out a performance test after the next major overhaul which is anticipated to take place in 2020. The improvement condition secures this commitment.

BAT AEELs (%) ^{Note 1}			Plant efficiency (%)		
Net electrical efficiency	Net total fuel utilisation ^{Note 2}	Net mechanical efficiency	Net electrical efficiency	Net total fuel utilisation	Net mechanical efficiency
CHP CCGT, 50–600 MWth LCP 320 CHP CCGT 133.1 MWth					
46 - 54	65-95	None	Note 1	81.4	NA
Note 1: In the case of CHP units, only one of the two BAT-AEELs 'Net electrical efficiency' or 'Net total fuel utilisation' applies, depending on the CHP unit design (i.e. either more oriented towards electricity generation or heat generation. The Operator confirmed that 'Net total fuel utilisation' applies. Note 2: Net total fuel utilisation BAT AEELs may not be achievable if the potential heat demand is too low.					

4.3 Fuel characterisation

BAT 9 requires the Operator to carry out fuel characterisation.

For the natural gas from Egdon resources, we have therefore included an improvement condition in the consolidated variation notice requiring the Operator to submit a plan outlining how this will be carried out for approval prior to the implementation date for the BAT Conclusions.

5 Decision checklist regarding relevant BAT Conclusions

BAT Conclusions for LCP were published by the European Commission on 17 August 2017. There are 75 BAT Conclusions. Only the BAT Conclusions relevant to the particular fuel type used on site have been replicated below.

This annex provides a record of decisions made in relation to each relevant BAT Conclusion applicable to the installation. This annex should be read in conjunction with the consolidated variation notice.

The conditions in the permit through which the relevant BAT Conclusions are implemented include but are not limited to the following:

BAT Conclusion requirement topic	Permit condition(s)	Permit table(s)
Environmental Management System	1.1.1	S1.2
BAT AELs	3.1.1 and 3.5.1	S3.1a
Monitoring	2.3, 3.5 and 3.6	S1.2, S1.5, S1.6, S3.1a
Energy efficiency	1.2 and 2.3	S3.3
Noise	2.3 and 3.4	S1.2
Other operating techniques	2.3	S1.2

The overall status of compliance with the BAT conclusion is indicated in the table as:

- NA Not applicable
- CC Currently compliant
- FC Compliant in the future (within 4 years of publication of BAT Conclusions)
- NC Not compliant
- PC Partially compliant

BAT C No.	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
General			
1	<p>In order to improve the overall environmental performance, BAT is to implement and adhere to an environmental management system (EMS) that incorporates all of the following features:</p> <ul style="list-style-type: none"> i. commitment of the management, including senior management; ii. definition of an environmental policy that includes the continuous improvement of the installation by the management; iii. planning and establishing the necessary procedures, objectives and targets, in conjunction with financial planning and investment; iv. implementation of procedures <ul style="list-style-type: none"> (a) Structure and responsibility (b) Training (c) Communication (d) Employee involvement (e) Documentation (f) Efficient process control (g) Maintenance programmes (h) Emergency preparedness and response (i) Safeguarding compliance with environmental legislation v. checking performance and taking corrective action, paying particular attention to: <ul style="list-style-type: none"> (a) monitoring and measurement (see also the Reference Document on the General Principles of Monitoring) (b) corrective and preventive action (c) maintenance of records (d) independent (where practicable) internal and external auditing in order to determine whether or not the EMS conforms to planned arrangements and has been properly implemented and maintained; vi. review of the EMS and its continuing suitability, adequacy and effectiveness by senior management; vii. following the development of cleaner technologies; viii. consideration for the environmental impacts from the eventual decommissioning of the installation at the stage of designing a new plant, and throughout its operating life; viii. consideration for the environmental impacts from the eventual decommissioning of the installation at the stage of designing a new 	FC	<p>The Operator confirmed that:</p> <p>An EMS currently exists but is not formalised into ISO 14001. This is currently being progressed. ISO 500001 and ISO 90001 are already in place.</p> <p>In their response to our further information request received 13 March 2020 they confirmed that they anticipated ISO 14001 certification was to be achieved by the middle of 2020.</p> <p>We agree with the Operator's stated compliance.</p>

BAT C No.	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement												
	<p>plant, and throughout its operating life; ix. application of sectoral benchmarking on a regular basis. Etc - see BAT Conclusions</p> <p>Applicability. The scope (e.g. level of detail) and nature of the EMS (e.g. standardised or non-standardised) will generally be related to the nature, scale and complexity of the installation, and the range of environmental impacts it may have.</p>														
2	<p>BAT is to determine the net electrical efficiency and/or the net total fuel utilisation and/or the net mechanical energy efficiency of the gasification, IGCC and/or combustion units by carrying out a performance test at full load (1), according to EN standards, after the commissioning of the unit and after each modification that could significantly affect the net electrical efficiency and/or the net total fuel utilisation and/or the net mechanical energy efficiency of the unit. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.</p>	FC	<p>The Operator confirmed that:</p> <p>They monitor energy efficiency on the assets using something called the “assumptions book”. This method is listed in their ISO 50001 management system.</p> <p>This looks at the GT design criteria for a given set of conditions and measures current performance against what the design criteria states the efficiency to be. There is a variation against this which is measured monthly.</p> <p>We are not satisfied that the requirements of this BAT Conclusion are met and have set an improvement condition to address the deficiencies.</p> <p>We do not agree with the Operator’s stated compliance of CC and have set the compliance status to FC.</p>												
3	<p>BAT is to monitor key process parameters relevant for emissions to air and water including those given below.</p> <table border="1" data-bbox="277 1054 1025 1305"> <thead> <tr> <th data-bbox="277 1054 510 1086">Stream</th> <th data-bbox="510 1054 786 1086">Parameter(s)</th> <th data-bbox="786 1054 1025 1086">Monitoring</th> </tr> </thead> <tbody> <tr> <td data-bbox="277 1086 510 1241" rowspan="3">Flue-gas</td> <td data-bbox="510 1086 786 1145">Flow</td> <td data-bbox="786 1086 1025 1145">Periodic or continuous determination</td> </tr> <tr> <td data-bbox="510 1145 786 1241">Oxygen content, temperature, and pressure</td> <td data-bbox="786 1145 1025 1241" rowspan="2">Periodic or continuous measurement</td> </tr> <tr> <td data-bbox="510 1209 786 1241">Water vapour content (3)</td> </tr> <tr> <td data-bbox="277 1241 510 1305">Waste water from flue-gas treatment</td> <td data-bbox="510 1241 786 1305">Flow, pH, and temperature</td> <td data-bbox="786 1241 1025 1305">Continuous measurement</td> </tr> </tbody> </table>	Stream	Parameter(s)	Monitoring	Flue-gas	Flow	Periodic or continuous determination	Oxygen content, temperature, and pressure	Periodic or continuous measurement	Water vapour content (3)	Waste water from flue-gas treatment	Flow, pH, and temperature	Continuous measurement	CC	<p>The Operator confirmed that:</p> <p>CEMS are already in place on this gas turbine and monitoring the required parameters.</p> <p>We agree with the Operator’s stated compliance.</p>
Stream	Parameter(s)	Monitoring													
Flue-gas	Flow	Periodic or continuous determination													
	Oxygen content, temperature, and pressure	Periodic or continuous measurement													
	Water vapour content (3)														
Waste water from flue-gas treatment	Flow, pH, and temperature	Continuous measurement													
4	<p>BAT is to monitor emissions to air with at least the frequency given below and in accordance with EN standards. If EN standards are not</p>	CC	<p>The Operator confirmed that:</p>												

BAT C No.	Summary of BAT Conclusion requirement					Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.						<p>CEMS are already in place on the gas turbine and monitoring the required parameters and in accordance with EN standards.</p> <p>We agree with the Operator's stated compliance.</p>
	Substance/Parameter	Fuel/Process/Type of combustion plant	Combustion plant total rated thermal input	Standard(s) ⁽⁴⁾	Minimum monitoring frequency ⁽⁵⁾	Monitoring associated with	
	NH ₃	— When SCR and/or SNCR is used	All sizes	Generic EN standards	Continuous ⁽⁶⁾ (7)	BAT 7	
	NO _x	<ul style="list-style-type: none"> — Coal and/or lignite including waste co-incineration — Solid biomass and/or peat including waste co-incineration — HFO- and/or gas-oil-fired boilers and engines — Gas-oil-fired gas turbines — Natural-gas-fired boilers, engines, and turbines — Iron and steel process gases — Process fuels from the chemical industry — IGCC plants 	All sizes	Generic EN standards	Continuous ⁽⁶⁾ (8)	BAT 20 BAT 24 BAT 28 BAT 32 BAT 37 BAT 41 BAT 42 BAT 43 BAT 47 BAT 48 BAT 56 BAT 64 BAT 65 BAT 73	
		— Combustion plants on offshore	All sizes	EN 14792	Once every year ⁽⁹⁾	BAT 53	

BAT C No.	Summary of BAT Conclusion requirement					Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
		platforms					
	N ₂ O	<ul style="list-style-type: none"> — Coal and/or lignite in circulating fluidised bed boilers — Solid biomass and/or peat in circulating fluidised bed boilers 	All sizes	EN 21258	Once every year ⁽¹⁰⁾	BAT 20 BAT 24	
	CO	<ul style="list-style-type: none"> — Coal and/or lignite including waste co-incineration — Solid biomass and/or peat including waste co-incineration — HFO- and/or gas-oil-fired boilers and engines — Gas-oil-fired gas turbines — Natural-gas-fired boilers, engines, and turbines — Iron and steel process gases — Process fuels from the chemical industry — IGCC plants 	All sizes	Generic EN standards	Continuous ⁽⁶⁾	BAT 20 BAT 24 BAT 28 BAT 33 BAT 38 BAT 44 BAT 49 BAT 56 BAT 64 BAT 65 BAT 73	
		<ul style="list-style-type: none"> — Combustion plants on offshore platforms 	All sizes	EN 15058	Once every year ⁽⁹⁾	BAT 54	

BAT C No.	Summary of BAT Conclusion requirement					Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	SO ₂	<ul style="list-style-type: none"> — Coal and/or lignite incl waste co-incineration — Solid biomass and/or peat incl waste co-incineration — HFO- and/or gas-oil-fired boilers — HFO- and/or gas-oil-fired engines — Gas-oil-fired gas turbines — Iron and steel process gases — Process fuels from the chemical industry in boilers — IGCC plants 	All sizes	Generic EN standards and EN 14791	Continuous ⁽⁶⁾ (⁽¹⁾ , ⁽¹²⁾)	BAT 21 BAT 25 BAT 29 BAT 34 BAT 39 BAT 50 BAT 57 BAT 66 BAT 67 BAT 74	
	SO ₃	<ul style="list-style-type: none"> — When SCR is used 	All sizes	No EN standard available	Once every year	—	
	Gaseous chlorides, expressed as HCl	<ul style="list-style-type: none"> — Coal and/or lignite — Process fuels from the chemical industry in boilers 	All sizes	EN 1911	Once every three months ⁽⁶⁾ , ⁽¹³⁾ ⁽¹⁴⁾	BAT 21 BAT 57	
		<ul style="list-style-type: none"> — Solid biomass and/or peat 	All sizes	Generic EN standards	Continuous ⁽¹⁵⁾ ⁽¹⁶⁾	BAT 25	
		<ul style="list-style-type: none"> — Waste co-incineration 	All sizes	Generic EN standards	Continuous ⁽⁶⁾ ⁽¹⁶⁾	BAT 66 BAT 67	
	HF	<ul style="list-style-type: none"> — Coal and/or 	All sizes	No EN	Once every	BAT 21	

BAT C No.	Summary of BAT Conclusion requirement					Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	— lignite		standard available	three months ⁽⁶⁾ ⁽¹³⁾ ⁽¹⁴⁾	BAT 57		
	— Solid biomass and/or peat	All sizes	No EN standard available	Once every year	BAT 25		
	— Waste co-incineration	All sizes	Generic EN standards	Continuous ⁽⁶⁾ ⁽¹⁶⁾	BAT 66 BAT 67		
Dust	<ul style="list-style-type: none"> — Coal and/or lignite — Solid biomass and/or peat — HFO- and/or gas-oil-fired boilers — Iron and steel process gases — Process fuels from the chemical industry in boilers — IGCC plants — HFO- and/or gas-oil-fired engines — Gas-oil-fired gas turbines 	All sizes	Generic EN standards and EN 13284-1 and EN 13284-2	Continuous ⁽⁶⁾ ⁽¹⁷⁾	BAT 22 BAT 26 BAT 30 BAT 35 BAT 39 BAT 51 BAT 58 BAT 75		
	— Waste co-incineration	All sizes	Generic EN standards and EN 13284-2	Continuous	BAT 68 BAT 69		
Metals and metalloids except mercury	<ul style="list-style-type: none"> — Coal and/or lignite — Solid biomass and/or peat 	All sizes	EN 14385	Once every year ⁽¹⁸⁾	BAT 22 BAT 26 BAT 30		

BAT C No.	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	(As, Cd, Co, Cr, Cu, Mn, Ni, Pb, Sb, Se, Ti, V, Zn)	— HFO- and/or gas-oil-fired boilers and engines						
— Waste co-incineration		< 300 MW th	EN 14385	Once every six months ⁽¹³⁾	BAT 68	BAT 69		
		≥ 300 MW th	EN 14385	Once every three months ⁽¹⁹⁾ ⁽¹³⁾				
	— IGCC plants	≥ 100 MW th	EN 14385	Once every year ⁽¹⁸⁾	BAT 75			
Hg	— Coal and/or lignite including waste co-incineration	< 300 MW th	EN 13211	Once every three months ⁽¹³⁾ ⁽²⁰⁾	BAT 23			
		≥ 300 MW th	Generic EN standards and EN 14884	Continuous ⁽¹⁶⁾ ⁽²¹⁾				
	— Solid biomass and/or peat	All sizes	EN 13211	Once every year ⁽²²⁾	BAT 27			
	— Waste co-incineration with solid biomass and/or peat	All sizes	EN 13211	Once every three months ⁽¹³⁾	BAT 70			
	— IGCC plants	≥ 100 MW th	EN 13211	Once every year ⁽²³⁾	BAT 75			
TVOC	— HFO- and/or gas-oil-fired engines	All sizes	EN 12619	Once every six months ⁽¹³⁾	BAT 33	BAT 59		
	— Process fuels from chemical industry in boilers							
	— Waste co-incineration with coal, lignite, solid biomass and/or peat	All sizes	Generic EN standards	Continuous	BAT 71			

BAT C No.	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																											
	Formaldehyde	— Natural-gas in spark-ignited lean-burn gas and dual fuel engines	All sizes	No EN standard available	Once every year	BAT 45																													
	CH ₄	— Natural-gas-fired engines	All sizes	EN ISO 25139	Once every year ⁽²⁴⁾	BAT 45																													
	PCDD/F	— Process fuels from chemical industry in boilers — Waste co-incineration	All sizes	EN 1948-1, EN 1948-2, EN 1948-3	Once every six months ⁽¹³⁾ ⁽²⁵⁾	BAT 59 BAT 71																													
5	<p>BAT is to monitor emissions to water from flue-gas treatment with at least the frequency given below and in accordance with EN standards. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.</p> <table border="1" data-bbox="271 852 1037 1385"> <thead> <tr> <th data-bbox="271 852 501 963">Substance/Parameter</th> <th data-bbox="501 852 725 963">Standard(s)</th> <th data-bbox="725 852 875 963">Minimum monitoring frequency</th> <th data-bbox="875 852 1037 963">Monitoring associated with</th> </tr> </thead> <tbody> <tr> <td data-bbox="271 963 501 1019">Total organic carbon (TOC)⁽²⁶⁾</td> <td data-bbox="501 963 725 1019">EN 1484</td> <td data-bbox="725 963 875 1019" rowspan="8">Once every month</td> <td data-bbox="875 963 1037 1019" rowspan="8">BAT 15</td> </tr> <tr> <td data-bbox="271 1019 501 1075">Chemical oxygen demand (COD)⁽²⁶⁾</td> <td data-bbox="501 1019 725 1075">No EN standard available</td> </tr> <tr> <td data-bbox="271 1075 501 1139">Total suspended solids (TSS)</td> <td data-bbox="501 1075 725 1139">EN 872</td> </tr> <tr> <td data-bbox="271 1139 501 1171">Fluoride (F⁻)</td> <td data-bbox="501 1139 725 1171">EN ISO 10304-1</td> </tr> <tr> <td data-bbox="271 1171 501 1203">Sulphate (SO₄²⁻)</td> <td data-bbox="501 1171 725 1203">EN ISO 10304-1</td> </tr> <tr> <td data-bbox="271 1203 501 1267">Sulphide, easily released (S²⁻)</td> <td data-bbox="501 1203 725 1267">No EN standard available</td> </tr> <tr> <td data-bbox="271 1267 501 1299">Sulphite (SO₃²⁻)</td> <td data-bbox="501 1267 725 1299">EN ISO 10304-3</td> </tr> <tr> <td data-bbox="271 1299 501 1385">Metals and metalloids</td> <td data-bbox="501 1299 725 1385" rowspan="2">Various EN standards available (e.g.</td> <td data-bbox="725 1299 875 1331">As</td> <td data-bbox="875 1299 1037 1331"></td> </tr> <tr> <td data-bbox="271 1331 501 1385"></td> <td data-bbox="725 1331 875 1385">Cd</td> <td data-bbox="875 1331 1037 1385"></td> </tr> </tbody> </table>						Substance/Parameter	Standard(s)	Minimum monitoring frequency	Monitoring associated with	Total organic carbon (TOC) ⁽²⁶⁾	EN 1484	Once every month	BAT 15	Chemical oxygen demand (COD) ⁽²⁶⁾	No EN standard available	Total suspended solids (TSS)	EN 872	Fluoride (F ⁻)	EN ISO 10304-1	Sulphate (SO ₄ ²⁻)	EN ISO 10304-1	Sulphide, easily released (S ²⁻)	No EN standard available	Sulphite (SO ₃ ²⁻)	EN ISO 10304-3	Metals and metalloids	Various EN standards available (e.g.	As			Cd		NA	<p>In the Operator's response to our request for information received 13 March 2020 they confirmed that this BAT Conclusion is not applicable because there is no flue-gas treatment at the installation.</p> <p>This BAT Conclusion is not applicable to the activities carried out at the installation.</p>
Substance/Parameter	Standard(s)	Minimum monitoring frequency	Monitoring associated with																																
Total organic carbon (TOC) ⁽²⁶⁾	EN 1484	Once every month	BAT 15																																
Chemical oxygen demand (COD) ⁽²⁶⁾	No EN standard available																																		
Total suspended solids (TSS)	EN 872																																		
Fluoride (F ⁻)	EN ISO 10304-1																																		
Sulphate (SO ₄ ²⁻)	EN ISO 10304-1																																		
Sulphide, easily released (S ²⁻)	No EN standard available																																		
Sulphite (SO ₃ ²⁻)	EN ISO 10304-3																																		
Metals and metalloids	Various EN standards available (e.g.			As																															
		Cd																																	

BAT C No.	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																																								
	<table border="1"> <tr> <td data-bbox="293 336 456 363"></td> <td data-bbox="456 336 725 363">Cr</td> <td data-bbox="725 336 1016 363">EN ISO 11885 or</td> <td data-bbox="882 336 1016 363"></td> <td data-bbox="882 363 1016 391"></td> </tr> <tr> <td data-bbox="293 363 456 391"></td> <td data-bbox="456 363 725 391">Cu</td> <td data-bbox="725 363 1016 391">EN ISO 17294-2)</td> <td data-bbox="882 363 1016 391"></td> <td data-bbox="882 391 1016 418"></td> </tr> <tr> <td data-bbox="293 391 456 418"></td> <td data-bbox="456 391 725 418">Ni</td> <td data-bbox="725 391 1016 418"></td> <td data-bbox="882 391 1016 418"></td> <td data-bbox="882 418 1016 445"></td> </tr> <tr> <td data-bbox="293 418 456 445"></td> <td data-bbox="456 418 725 445">Pb</td> <td data-bbox="725 418 1016 445"></td> <td data-bbox="882 418 1016 445"></td> <td data-bbox="882 445 1016 472"></td> </tr> <tr> <td data-bbox="293 445 456 472"></td> <td data-bbox="456 445 725 472">Zn</td> <td data-bbox="725 445 1016 472"></td> <td data-bbox="882 445 1016 472"></td> <td data-bbox="882 472 1016 499"></td> </tr> <tr> <td data-bbox="293 472 456 499"></td> <td data-bbox="456 472 725 499">Hg</td> <td data-bbox="725 472 1016 499">Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)</td> <td data-bbox="882 472 1016 499"></td> <td data-bbox="882 499 1016 526"></td> </tr> <tr> <td data-bbox="293 499 456 526">Chloride (Cl⁻)</td> <td data-bbox="456 499 725 526"></td> <td data-bbox="725 499 1016 526">Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)</td> <td data-bbox="882 499 1016 526"></td> <td data-bbox="882 526 1016 553">—</td> </tr> <tr> <td data-bbox="293 526 456 553">Total nitrogen</td> <td data-bbox="456 526 725 553"></td> <td data-bbox="725 526 1016 553">EN 12260</td> <td data-bbox="882 526 1016 553"></td> <td data-bbox="882 553 1016 580">—</td> </tr> </table>		Cr	EN ISO 11885 or				Cu	EN ISO 17294-2)				Ni					Pb					Zn					Hg	Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)			Chloride (Cl ⁻)		Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)		—	Total nitrogen		EN 12260		—		
	Cr	EN ISO 11885 or																																									
	Cu	EN ISO 17294-2)																																									
	Ni																																										
	Pb																																										
	Zn																																										
	Hg	Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)																																									
Chloride (Cl ⁻)		Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)		—																																							
Total nitrogen		EN 12260		—																																							
6	<p>In order to improve the general environmental performance of combustion plants and to reduce emissions to air of CO and unburnt substances, BAT is to ensure optimised combustion and to use an appropriate combination of the techniques given below.</p> <table border="1"> <thead> <tr> <th data-bbox="293 906 443 933">Technique</th> <th data-bbox="456 906 712 933">Description</th> <th data-bbox="725 906 1016 933">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="293 933 443 1070">a Fuel blending and mixing</td> <td data-bbox="456 933 712 1070">Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type</td> <td data-bbox="725 933 1016 1070">Generally applicable</td> </tr> <tr> <td data-bbox="293 1070 443 1177">b Maintenance of the combustion system</td> <td data-bbox="456 1070 712 1177">Regular planned maintenance according to suppliers' recommendations</td> <td data-bbox="725 1070 1016 1177"></td> </tr> <tr> <td data-bbox="293 1177 443 1342">c Advanced control system</td> <td data-bbox="456 1177 712 1342">See description in Section 8.1</td> <td data-bbox="725 1177 1016 1342">The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> <tr> <td data-bbox="293 1342 443 1369">d Good</td> <td data-bbox="456 1342 712 1369">Good design of furnace,</td> <td data-bbox="725 1342 1016 1369">Generally applicable to new</td> </tr> </tbody> </table>	Technique	Description	Applicability	a Fuel blending and mixing	Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type	Generally applicable	b Maintenance of the combustion system	Regular planned maintenance according to suppliers' recommendations		c Advanced control system	See description in Section 8.1	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system	d Good	Good design of furnace,	Generally applicable to new	CC	<p>The Operator confirmed that the following techniques are implemented:</p> <p>This is achieved through:</p> <p>b. maintenance; and d. good design of the combustion system.</p> <p>This is an appropriate combination of techniques for the installation.</p> <p>We agree with the Operator's stated compliance.</p>																									
Technique	Description	Applicability																																									
a Fuel blending and mixing	Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type	Generally applicable																																									
b Maintenance of the combustion system	Regular planned maintenance according to suppliers' recommendations																																										
c Advanced control system	See description in Section 8.1	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system																																									
d Good	Good design of furnace,	Generally applicable to new																																									

BAT C No.	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	. e .	design of the combustion equipment	combustion chambers, burners and associated devices	combustion plants	
7		Fuel choice	Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used	Applicable within the constraints associated with the availability of suitable types of fuel with a better environmental profile as a whole, which may be impacted by the energy policy of the Member State, or by the integrated site's fuel balance in the case of combustion of industrial process fuels. For existing combustion plants, the type of fuel chosen may be limited by the configuration and the design of the plant	<p>The Operator confirmed that:</p> <p>No SCR or SNCR used.</p> <p>We can conclude that this BAT Conclusion is not applicable to the activities carried out at the installation.</p>

BAT C No.	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement						
8	In order to prevent or reduce emissions to air during normal operating conditions, BAT is to ensure, by appropriate design, operation and maintenance, that the emission abatement systems are used at optimal capacity and availability.	CC	<p>The Operator confirmed that:</p> <p>Regular monitoring and maintenance of the equipment is carried out.</p> <p>We agree with the Operators stated compliance.</p>						
9	<p>In order to improve the general environmental performance of combustion and/or gasification plants and to reduce emissions to air, BAT is to include the following elements in the quality assurance/quality control programmes for all the fuels used, as part of the environmental management system (see BAT 1):</p> <p>(i) Initial full characterisation of the fuel used including at least the parameters listed below and in accordance with EN standards. ISO, national or other international standards may be used provided they ensure the provision of data of an equivalent scientific quality;</p> <p>(ii) Regular testing of the fuel quality to check that it is consistent with the initial characterisation and according to the plant design specifications. The frequency of testing and the parameters chosen from the table below are based on the variability of the fuel and an assessment of the relevance of pollutant releases (e.g. concentration in fuel, flue-gas treatment employed);</p> <p>(iii) Subsequent adjustment of the plant settings as and when needed and practicable (e.g. integration of the fuel characterisation and control in the advanced control system (see description in Section 8.1)).</p> <p>Description Initial characterisation and regular testing of the fuel can be performed by the operator and/or the fuel supplier. If performed by the supplier, the full results are provided to the operator in the form of a product (fuel) supplier specification and/or guarantee.</p> <table border="1" data-bbox="280 1214 1025 1353"> <thead> <tr> <th data-bbox="280 1214 533 1273">Fuel(s)</th> <th data-bbox="533 1214 1025 1273">Substances/Parameters subject to characterisation</th> </tr> </thead> <tbody> <tr> <td data-bbox="280 1273 533 1316">Biomass/peat</td> <td data-bbox="533 1273 1025 1316">— LHV</td> </tr> <tr> <td data-bbox="280 1316 533 1353"></td> <td data-bbox="533 1316 1025 1353">— moisture</td> </tr> </tbody> </table>	Fuel(s)	Substances/Parameters subject to characterisation	Biomass/peat	— LHV		— moisture	FC	<p>The Operator confirmed that:</p> <p>Details of how points (i), (ii) and (iii) are implemented are not required for natural gas.</p> <p>We consider that for plants which burn natural gas from the National Grid as a fuel that it is not necessary for the Operator to replicate the testing carried out by the National Grid.</p> <p>We agree with the Operators stated compliance of CC for natural gas.</p> <p>However, for the natural gas from Egdon Resources authorised in table S2.1 of the permit we are required to set an improvement condition, refer to section 4.3 of this document.</p> <p>We have set this BAT Conclusion to FC.</p>
Fuel(s)	Substances/Parameters subject to characterisation								
Biomass/peat	— LHV								
	— moisture								

BAT C No.	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																
	<table border="1"> <tr> <td data-bbox="277 325 533 475"></td> <td data-bbox="533 325 1025 475"> <ul style="list-style-type: none"> — Ash — C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn) </td> </tr> <tr> <td data-bbox="277 475 533 715">Coal/lignite</td> <td data-bbox="533 475 1025 715"> <ul style="list-style-type: none"> — LHV — Moisture — Volatiles, ash, fixed carbon, C, H, N, O, S — Br, Cl, F — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) </td> </tr> <tr> <td data-bbox="277 715 533 794">HFO</td> <td data-bbox="533 715 1025 794"> <ul style="list-style-type: none"> — Ash — C, S, N, Ni, V </td> </tr> <tr> <td data-bbox="277 794 533 874">Gas oil</td> <td data-bbox="533 794 1025 874"> <ul style="list-style-type: none"> — Ash — N, C, S </td> </tr> <tr> <td data-bbox="277 874 533 962">Natural gas</td> <td data-bbox="533 874 1025 962"> <ul style="list-style-type: none"> — LHV — CH₄, C₂H₆, C₃, C₄₊, CO₂, N₂, Wobbe index </td> </tr> <tr> <td data-bbox="277 962 533 1074">Process fuels from the chemical industry⁽²⁷⁾</td> <td data-bbox="533 962 1025 1074"> <ul style="list-style-type: none"> — Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) </td> </tr> <tr> <td data-bbox="277 1074 533 1145">Iron and steel process gases</td> <td data-bbox="533 1074 1025 1145"> <ul style="list-style-type: none"> — LHV, CH₄ (for COG), C_xH_y (for COG), CO₂, H₂, N₂, total sulphur, dust, Wobbe index </td> </tr> <tr> <td data-bbox="277 1145 533 1321">Waste⁽²⁸⁾</td> <td data-bbox="533 1145 1025 1321"> <ul style="list-style-type: none"> — LHV — Moisture — Volatiles, ash, Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) </td> </tr> </table>		<ul style="list-style-type: none"> — Ash — C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn) 	Coal/lignite	<ul style="list-style-type: none"> — LHV — Moisture — Volatiles, ash, fixed carbon, C, H, N, O, S — Br, Cl, F — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) 	HFO	<ul style="list-style-type: none"> — Ash — C, S, N, Ni, V 	Gas oil	<ul style="list-style-type: none"> — Ash — N, C, S 	Natural gas	<ul style="list-style-type: none"> — LHV — CH₄, C₂H₆, C₃, C₄₊, CO₂, N₂, Wobbe index 	Process fuels from the chemical industry ⁽²⁷⁾	<ul style="list-style-type: none"> — Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) 	Iron and steel process gases	<ul style="list-style-type: none"> — LHV, CH₄ (for COG), C_xH_y (for COG), CO₂, H₂, N₂, total sulphur, dust, Wobbe index 	Waste ⁽²⁸⁾	<ul style="list-style-type: none"> — LHV — Moisture — Volatiles, ash, Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) 		
	<ul style="list-style-type: none"> — Ash — C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn) 																		
Coal/lignite	<ul style="list-style-type: none"> — LHV — Moisture — Volatiles, ash, fixed carbon, C, H, N, O, S — Br, Cl, F — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) 																		
HFO	<ul style="list-style-type: none"> — Ash — C, S, N, Ni, V 																		
Gas oil	<ul style="list-style-type: none"> — Ash — N, C, S 																		
Natural gas	<ul style="list-style-type: none"> — LHV — CH₄, C₂H₆, C₃, C₄₊, CO₂, N₂, Wobbe index 																		
Process fuels from the chemical industry ⁽²⁷⁾	<ul style="list-style-type: none"> — Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) 																		
Iron and steel process gases	<ul style="list-style-type: none"> — LHV, CH₄ (for COG), C_xH_y (for COG), CO₂, H₂, N₂, total sulphur, dust, Wobbe index 																		
Waste ⁽²⁸⁾	<ul style="list-style-type: none"> — LHV — Moisture — Volatiles, ash, Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) 																		

BAT C No.	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
10	<p>In order to reduce emissions to air and/or to water during other than normal operating conditions (OTNOC), BAT is to set up and implement a management plan as part of the environmental management system (see BAT 1), commensurate with the relevance of potential pollutant releases, that includes the following elements:</p> <ul style="list-style-type: none"> — appropriate design of the systems considered relevant in causing OTNOC that may have an impact on emissions to air, water and/or soil (e.g. low-load design concepts for reducing the minimum start-up and shutdown loads for stable generation in gas turbines), — set-up and implementation of a specific preventive maintenance plan for these relevant systems, — review and recording of emissions caused by OTNOC and associated circumstances and implementation of corrective actions if necessary, — periodic assessment of the overall emissions during OTNOC (e.g. frequency of events, duration, emissions quantification/estimation) and implementation of corrective actions if necessary. 	CC	<p>The Operator confirmed that:</p> <ul style="list-style-type: none"> - Standard operating procedures (controlled documents) are used to adjust for optimum load ensuring the load does not fall below minimum levels and to ensure system balance for good environmental performance of emissions. <p>In their response to our request for information received 13 March 2020 they confirmed that:</p> <ul style="list-style-type: none"> - Fuel/air mix is optimised and automated and is mainly used at times of start-up and shut-down - Review of emissions caused by OTNOC. Emissions are displayed real time in the control room and monitored 24 hours per day. CEMS are in place. Emissions are reviewed after OTNOC but no formal procedure is in place. - Assessment after OTNOC takes place and any issues are logged or reported and actions are assigned if necessary. <p>We agree with the Operator's stated compliance.</p>
11	<p>BAT is to appropriately monitor emissions to air and/or to water during OTNOC.</p> <p>Description</p> <p>The monitoring can be carried out by direct measurement of emissions or by monitoring of surrogate parameters if this proves to be of equal or better scientific quality than the direct measurement of emissions. Emissions during start-up and shutdown (SU/SD) may be assessed based on a detailed emission measurement carried out for a typical SU/SD procedure at least once every year, and using the results of this measurement to estimate the emissions for each and every SU/SD throughout the year.</p>	CC	<p>The Operator confirmed that:</p> <p>Whilst operational the gas turbine operates at optimal load. If there are abnormal operating conditions then the gas turbine would be shut-down until these were able to be corrected. If the CEMS fails a portable meter is deployed.</p> <p>We agree with the Operator's stated compliance.</p>

BAT C No.	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																					
12	<p>In order to increase the energy efficiency of combustion, gasification and/or IGCC units operated $\geq 1\,500$ h/yr, BAT is to use an appropriate combination of the techniques given below.</p> <table border="1" data-bbox="277 411 1025 1362"> <thead> <tr> <th data-bbox="277 411 450 443">Technique</th> <th data-bbox="450 411 750 443">Description</th> <th data-bbox="750 411 1025 443">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="277 443 450 628">a. Combustion optimisation</td> <td data-bbox="450 443 750 628">See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues</td> <td data-bbox="750 443 1025 628">Generally applicable</td> </tr> <tr> <td data-bbox="277 628 450 858">b. Optimisation of the working medium conditions</td> <td data-bbox="450 628 750 858">Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO_x emissions or the characteristics of energy demanded</td> <td data-bbox="750 628 1025 858"></td> </tr> <tr> <td data-bbox="277 858 450 1018">c. Optimisation of the steam cycle</td> <td data-bbox="450 858 750 1018">Operate with lower turbine exhaust pressure by utilisation of the lowest possible temperature of the condenser cooling water, within the design conditions</td> <td data-bbox="750 858 1025 1018"></td> </tr> <tr> <td data-bbox="277 1018 450 1129">d. Minimisation of energy consumption</td> <td data-bbox="450 1018 750 1129">Minimising the internal energy consumption (e.g. greater efficiency of the feed-water pump)</td> <td data-bbox="750 1018 1025 1129"></td> </tr> <tr> <td data-bbox="277 1129 450 1262">e. Preheating of combustion air</td> <td data-bbox="450 1129 750 1262">Reuse of part of the heat recovered from the combustion flue-gas to preheat the air used in combustion</td> <td data-bbox="750 1129 1025 1262">Generally applicable within the constraints related to the need to control NO_x emissions</td> </tr> <tr> <td data-bbox="277 1262 450 1362">f. Fuel preheating</td> <td data-bbox="450 1262 750 1362">Preheating of fuel using recovered heat</td> <td data-bbox="750 1262 1025 1362">Generally applicable within the constraints associated with the boiler design and the need to control</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Combustion optimisation	See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues	Generally applicable	b. Optimisation of the working medium conditions	Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO _x emissions or the characteristics of energy demanded		c. Optimisation of the steam cycle	Operate with lower turbine exhaust pressure by utilisation of the lowest possible temperature of the condenser cooling water, within the design conditions		d. Minimisation of energy consumption	Minimising the internal energy consumption (e.g. greater efficiency of the feed-water pump)		e. Preheating of combustion air	Reuse of part of the heat recovered from the combustion flue-gas to preheat the air used in combustion	Generally applicable within the constraints related to the need to control NO _x emissions	f. Fuel preheating	Preheating of fuel using recovered heat	Generally applicable within the constraints associated with the boiler design and the need to control	CC	<p>The Operator confirmed that the following techniques are employed:</p> <ul style="list-style-type: none"> a. Combustion optimisation. c. Optimisation of steam cycle. d. A new efficient feed water pump is due to be installed as part of a larger project. f. Fuel preheating. h. Feed water preheating. i. Heat recovery by CHP. <p>We agree with the Operator's stated compliance.</p>
Technique	Description	Applicability																						
a. Combustion optimisation	See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues	Generally applicable																						
b. Optimisation of the working medium conditions	Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO _x emissions or the characteristics of energy demanded																							
c. Optimisation of the steam cycle	Operate with lower turbine exhaust pressure by utilisation of the lowest possible temperature of the condenser cooling water, within the design conditions																							
d. Minimisation of energy consumption	Minimising the internal energy consumption (e.g. greater efficiency of the feed-water pump)																							
e. Preheating of combustion air	Reuse of part of the heat recovered from the combustion flue-gas to preheat the air used in combustion	Generally applicable within the constraints related to the need to control NO _x emissions																						
f. Fuel preheating	Preheating of fuel using recovered heat	Generally applicable within the constraints associated with the boiler design and the need to control																						

BAT C No.	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
			NO _x emissions		
	g. Advanced control system	See description in Section 8.2. Computerised control of the main combustion parameters enables the combustion efficiency to be improved	Generally applicable to new units. The applicability to old units may be constrained by the need to retrofit the combustion system and/or control command system		
	h. Feed-water preheating using recovered heat	Preheat water coming out of the steam condenser with recovered heat, before reusing it in the boiler	Only applicable to steam circuits and not to hot boilers. Applicability to existing units may be limited due to constraints associated with the plant configuration and the amount of recoverable heat		
	i. Heat recovery by cogeneration (CHP)	Recovery of heat (mainly from the steam system) for producing hot water/steam to be used in industrial processes/activities or in a public network for district heating. Additional heat recovery is possible from: <ul style="list-style-type: none"> — flue-gas — grate cooling — circulating fluidised bed 	Applicable within the constraints associated with the local heat and power demand. The applicability may be limited in the case of gas compressors with an unpredictable operational heat profile		
	j. CHP readiness	See description in Section 8.2.	Only applicable to new units where there is a realistic potential for the future use of heat in the vicinity of the unit		
	k. Flue-gas condenser	See description in Section 8.2.	Generally applicable to CHP units provided there is enough demand for low-temperature heat		
	l. Heat	Heat accumulation storage in	Only applicable to CHP		

BAT C No.	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
		accumulation	CHP mode	plants. The applicability may be limited in the case of low heat load demand	
	m.	Wet stack	See description in Section 8.2.	Generally applicable to new and existing units fitted with wet FGD	
	n.	Cooling tower discharge	The release of emissions to air through a cooling tower and not via a dedicated stack	Only applicable to units fitted with wet FGD where reheating of the flue-gas is necessary before release, and where the unit cooling system is a cooling tower	
	o.	Fuel pre-drying	The reduction of fuel moisture content before combustion to improve combustion conditions	Applicable to the combustion of biomass and/or peat within the constraints associated with spontaneous combustion risks (e.g. the moisture content of peat is kept above 40 % throughout the delivery chain). The retrofit of existing plants may be restricted by the extra calorific value that can be obtained from the drying operation and by the limited retrofit possibilities offered by some boiler designs or plant configurations	
	p.	Minimisation of heat losses	Minimising residual heat losses, e.g. those that occur via the slag or those that can be reduced by insulating radiating sources	Only applicable to solid-fuel-fired combustion units and to gasification/IGCC units	
	q.	Advanced materials	Use of advanced materials proven to be capable of withstanding high operating temperatures and pressures	Only applicable to new plants	

BAT C No.	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
			and thus to achieve increased steam/combustion process efficiencies		
	r.	Steam turbine upgrades	This includes techniques such as increasing the temperature and pressure of medium-pressure steam, addition of a low-pressure turbine, and modifications to the geometry of the turbine rotor blades	The applicability may be restricted by demand, steam conditions and/or limited plant lifetime	
	s.	Supercritical and ultra-supercritical steam conditions	Use of a steam circuit, including steam reheating systems, in which steam can reach pressures above 220,6 bar and temperatures above 374 °C in the case of supercritical conditions, and above 250 – 300 bar and temperatures above 580 – 600 °C in the case of ultra-supercritical conditions	Only applicable to new units of $\geq 600 \text{ MW}_{th}$ operated $> 4\,000 \text{ h/yr}$. Not applicable when the purpose of the unit is to produce low steam temperatures and/or pressures in process industries. Not applicable to gas turbines and engines generating steam in CHP mode. For units combusting biomass, the applicability may be constrained by high-temperature corrosion in the case of certain biomasses	
13	In order to reduce water usage and the volume of contaminated waste water discharged, BAT is to use one or both of the techniques given below.			NA	The Operator confirmed that: The water run-off produced by the installation is minimal. Whilst the Operator stated that they are NC, we consider that this BAT Conclusion is NA to the activities carried out at the installation.
		Technique	Description	Applicability	
	a	Water recycling	Residual aqueous streams, including run-off water, from the plant are reused for other purposes. The degree of recycling	Not applicable to waste water from cooling systems when water treatment chemicals	

BAT C No.	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement									
		is limited by the quality requirements of the recipient water stream and the water balance of the plant	and/or high concentrations of salts from seawater are present											
	b. Dry bottom ash handling	Dry, hot bottom ash falls from the furnace onto a mechanical conveyor system and is cooled down by ambient air. No water is used in the process.	Only applicable to plants combusting solid fuels. There may be technical restrictions that prevent retrofitting to existing combustion plants											
14	<p>In order to prevent the contamination of uncontaminated waste water and to reduce emissions to water, BAT is to segregate waste water streams and to treat them separately, depending on the pollutant content.</p> <p>Description Waste water streams that are typically segregated and treated include surface run-off water, cooling water, and waste water from flue-gas treatment.</p> <p>Applicability The applicability may be restricted in the case of existing plants due to the configuration of the drainage systems.</p>			CC	<p>The Operator confirmed that:</p> <p>The site is a large industrial site and all effluent goes to a drain via a consent to discharge. Consideration is being given to building an industrial effluent treatment plant but no firm date is in place.</p> <p>It is anticipated that this plant would receive effluent from all industries within Wilton International and not just effluent from this installation. If this is the case, emissions from this plant would be regulated by a discharge consent and therefore this is not relevant to this permit review.</p> <p>Whilst the Operator stated that they are NC, we consider that they are CC with this BAT Conclusion.</p>									
15	<p>In order to reduce emissions to water from flue-gas treatment, BAT is to use an appropriate combination of the techniques given below, and to use secondary techniques as close as possible to the source in order to avoid dilution.</p> <table border="1" data-bbox="280 1102 1025 1214"> <thead> <tr> <th data-bbox="280 1102 533 1214">Technique</th> <th data-bbox="533 1102 728 1214">Typical pollutants prevented/abated</th> <th data-bbox="728 1102 1025 1214">Applicability</th> </tr> </thead> <tbody> <tr> <td colspan="3" data-bbox="280 1214 1025 1246" style="text-align: center;">Primary techniques</td> </tr> <tr> <td data-bbox="280 1246 533 1377">a. Optimised combustion (see BAT 6) and flue-gas treatment systems (e.g. SCR/SNCR,</td> <td data-bbox="533 1246 728 1377">Organic compounds, ammonia (NH₃)</td> <td data-bbox="728 1246 1025 1377">Generally applicable</td> </tr> </tbody> </table>			Technique	Typical pollutants prevented/abated	Applicability	Primary techniques			a. Optimised combustion (see BAT 6) and flue-gas treatment systems (e.g. SCR/SNCR,	Organic compounds, ammonia (NH ₃)	Generally applicable	NA	<p>In their response to our request for information received 13 March 2020 the Operator confirmed that this BAT Conclusion is not applicable.</p> <p>The BAT AELs refer to direct discharges to a receiving water body at the point where the emission leaves the installation.</p> <p>We agree that this BAT Conclusion is not applicable to the activities carried out at the installation.</p>
Technique	Typical pollutants prevented/abated	Applicability												
Primary techniques														
a. Optimised combustion (see BAT 6) and flue-gas treatment systems (e.g. SCR/SNCR,	Organic compounds, ammonia (NH ₃)	Generally applicable												

BAT C No.	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	see BAT 7)				
	Secondary techniques ⁽²⁹⁾				
	b.	Adsorption on activated carbon	Organic compounds, mercury (Hg)	Generally applicable	
	c.	Aerobic biological treatment	Biodegradable organic compounds, ammonium (NH ₄ ⁺)	Generally applicable for the treatment of organic compounds. Aerobic biological treatment of ammonium (NH ₄ ⁺) may not be applicable in the case of high chloride concentrations (i.e. around 10 g/l)	
	d.	Anoxic/anaerobic biological treatment	Mercury (Hg), nitrate (NO ₃ ⁻), nitrite (NO ₂ ⁻)	Generally applicable	
	e.	Coagulation and flocculation	Suspended solids	Generally applicable	
	f.	Crystallisation	Metals and metalloids, sulphate (SO ₄ ²⁻), fluoride (F ⁻)	Generally applicable	
	g.	Filtration (e.g. sand filtration, microfiltration, ultrafiltration)	Suspended solids, metals	Generally applicable	
	h.	Flotation	Suspended solids, free oil	Generally applicable	
	i.	Ion exchange	Metals	Generally applicable	
	j.	Neutralisation	Acids, alkalis	Generally applicable	
	k.	Oxidation	Sulphide (S ²⁻), sulphite (SO ₃ ²⁻)	Generally applicable	
	l.	Precipitation	Metals and metalloids, sulphate (SO ₄ ²⁻), fluoride (F ⁻)	Generally applicable	
	m.	Sedimentation	Suspended solids	Generally applicable	

BAT C No.	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																																																
	<table border="1" data-bbox="280 327 1025 399"> <tr> <td data-bbox="280 327 533 363">n.</td> <td data-bbox="533 327 734 363">Stripping</td> <td data-bbox="734 327 936 363">Ammonia (NH₃)</td> <td data-bbox="936 327 1025 363">Generally applicable</td> </tr> </table> <p data-bbox="280 399 1025 454">The BAT-AELs refer to direct discharges to a receiving water body at the point where the emission leaves the installation.</p> <p data-bbox="280 454 1025 510">BAT-AELs for direct discharges to a receiving water body from flue-gas treatment</p> <table border="1" data-bbox="280 510 1025 1107"> <thead> <tr> <th colspan="2" data-bbox="280 510 698 547">Substance/Parameter</th> <th data-bbox="698 510 1025 547">BAT-AELs</th> </tr> <tr> <th colspan="2" data-bbox="280 547 698 584"></th> <th data-bbox="698 547 1025 584">Daily average</th> </tr> </thead> <tbody> <tr> <td data-bbox="280 584 698 620">Total organic carbon (TOC)</td> <td data-bbox="698 584 1025 620"></td> <td data-bbox="698 584 1025 620">20–50 mg/l ⁽³⁰⁾ ⁽³¹⁾ ⁽³²⁾</td> </tr> <tr> <td data-bbox="280 620 698 657">Chemical oxygen demand (COD)</td> <td data-bbox="698 620 1025 657"></td> <td data-bbox="698 620 1025 657">60–150 mg/l ⁽³⁰⁾ ⁽³¹⁾ ⁽³²⁾</td> </tr> <tr> <td data-bbox="280 657 698 694">Total suspended solids (TSS)</td> <td data-bbox="698 657 1025 694"></td> <td data-bbox="698 657 1025 694">10–30 mg/l</td> </tr> <tr> <td data-bbox="280 694 698 730">Fluoride (F⁻)</td> <td data-bbox="698 694 1025 730"></td> <td data-bbox="698 694 1025 730">10–25 mg/l ⁽³²⁾</td> </tr> <tr> <td data-bbox="280 730 698 767">Sulphate (SO₄²⁻)</td> <td data-bbox="698 730 1025 767"></td> <td data-bbox="698 730 1025 767">1,3–2,0 g/l ⁽³²⁾ ⁽³³⁾ ⁽³⁴⁾ ⁽³⁵⁾</td> </tr> <tr> <td data-bbox="280 767 698 804">Sulphide (S²⁻), easily released</td> <td data-bbox="698 767 1025 804"></td> <td data-bbox="698 767 1025 804">0,1–0,2 mg/l ⁽³²⁾</td> </tr> <tr> <td data-bbox="280 804 698 841">Sulphite (SO₃²⁻)</td> <td data-bbox="698 804 1025 841"></td> <td data-bbox="698 804 1025 841">1–20 mg/l ⁽³²⁾</td> </tr> <tr> <td data-bbox="280 841 629 1107" rowspan="8">Metals and metalloids</td> <td data-bbox="629 841 698 861">As</td> <td data-bbox="698 841 1025 861">10–50 µg/l</td> </tr> <tr> <td data-bbox="629 861 698 882">Cd</td> <td data-bbox="698 861 1025 882">2–5 µg/l</td> </tr> <tr> <td data-bbox="629 882 698 903">Cr</td> <td data-bbox="698 882 1025 903">10–50 µg/l</td> </tr> <tr> <td data-bbox="629 903 698 924">Cu</td> <td data-bbox="698 903 1025 924">10–50 µg/l</td> </tr> <tr> <td data-bbox="629 924 698 944">Hg</td> <td data-bbox="698 924 1025 944">0,2–3 µg/l</td> </tr> <tr> <td data-bbox="629 944 698 965">Ni</td> <td data-bbox="698 944 1025 965">10–50 µg/l</td> </tr> <tr> <td data-bbox="629 965 698 986">Pb</td> <td data-bbox="698 965 1025 986">10–20 µg/l</td> </tr> <tr> <td data-bbox="629 986 698 1007">Zn</td> <td data-bbox="698 986 1025 1007">50–200 µg/l</td> </tr> </tbody> </table>	n.	Stripping	Ammonia (NH ₃)	Generally applicable	Substance/Parameter		BAT-AELs			Daily average	Total organic carbon (TOC)		20–50 mg/l ⁽³⁰⁾ ⁽³¹⁾ ⁽³²⁾	Chemical oxygen demand (COD)		60–150 mg/l ⁽³⁰⁾ ⁽³¹⁾ ⁽³²⁾	Total suspended solids (TSS)		10–30 mg/l	Fluoride (F ⁻)		10–25 mg/l ⁽³²⁾	Sulphate (SO ₄ ²⁻)		1,3–2,0 g/l ⁽³²⁾ ⁽³³⁾ ⁽³⁴⁾ ⁽³⁵⁾	Sulphide (S ²⁻), easily released		0,1–0,2 mg/l ⁽³²⁾	Sulphite (SO ₃ ²⁻)		1–20 mg/l ⁽³²⁾	Metals and metalloids	As	10–50 µg/l	Cd	2–5 µg/l	Cr	10–50 µg/l	Cu	10–50 µg/l	Hg	0,2–3 µg/l	Ni	10–50 µg/l	Pb	10–20 µg/l	Zn	50–200 µg/l		
n.	Stripping	Ammonia (NH ₃)	Generally applicable																																																
Substance/Parameter		BAT-AELs																																																	
		Daily average																																																	
Total organic carbon (TOC)		20–50 mg/l ⁽³⁰⁾ ⁽³¹⁾ ⁽³²⁾																																																	
Chemical oxygen demand (COD)		60–150 mg/l ⁽³⁰⁾ ⁽³¹⁾ ⁽³²⁾																																																	
Total suspended solids (TSS)		10–30 mg/l																																																	
Fluoride (F ⁻)		10–25 mg/l ⁽³²⁾																																																	
Sulphate (SO ₄ ²⁻)		1,3–2,0 g/l ⁽³²⁾ ⁽³³⁾ ⁽³⁴⁾ ⁽³⁵⁾																																																	
Sulphide (S ²⁻), easily released		0,1–0,2 mg/l ⁽³²⁾																																																	
Sulphite (SO ₃ ²⁻)		1–20 mg/l ⁽³²⁾																																																	
Metals and metalloids	As	10–50 µg/l																																																	
	Cd	2–5 µg/l																																																	
	Cr	10–50 µg/l																																																	
	Cu	10–50 µg/l																																																	
	Hg	0,2–3 µg/l																																																	
	Ni	10–50 µg/l																																																	
	Pb	10–20 µg/l																																																	
	Zn	50–200 µg/l																																																	
16	<p data-bbox="280 1120 1025 1230">In order to reduce the quantity of waste sent for disposal from the combustion and/or gasification process and abatement techniques, BAT is to organise operations so as to maximise, in order of priority and taking into account life-cycle thinking:</p> <p data-bbox="280 1230 1025 1369">(a) waste prevention, e.g. maximise the proportion of residues which arise as by-products;</p> <p data-bbox="280 1305 1025 1369">(b) waste preparation for reuse, e.g. according to the specific requested quality criteria;</p>	CC	<p data-bbox="1162 1120 2042 1150">The Operator confirmed that waste goes to an energy recovery plant (d).</p> <p data-bbox="1162 1174 2042 1230">In response to our request for information received 13 March 2020 they confirmed that a) to c) are not applicable.</p> <p data-bbox="1162 1254 2042 1310">They also confirm that waste management takes place on site and a push to improve the number of recycling streams is planned during 2020.</p> <p data-bbox="1162 1334 2042 1369">We agree with the Operator's stated compliance.</p>																																																

BAT C No.	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement															
	<p>(c) waste recycling;</p> <p>(d) other waste recovery (e.g. energy recovery),</p> <p>by implementing an appropriate combination of techniques such as:</p> <table border="1" data-bbox="280 437 1025 1372"> <thead> <tr> <th data-bbox="280 437 443 472">Technique</th> <th data-bbox="443 437 763 472">Description</th> <th data-bbox="763 437 1025 472">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="280 472 443 727">a Generation of gypsum as a by-product</td> <td data-bbox="443 472 763 727">Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g. as raw material in the plasterboard industry). The quality of limestone used in the wet FGD influences the purity of the gypsum produced</td> <td data-bbox="763 472 1025 727">Generally applicable within the constraints associated with the required gypsum quality, the health requirements associated to each specific use, and by the market conditions</td> </tr> <tr> <td data-bbox="280 727 443 959">b Recycling or recovery of residues in the construction sector</td> <td data-bbox="443 727 763 959">Recycling or recovery of residues (e.g. from semi-dry desulphurisation processes, fly ash, bottom ash) as a construction material (e.g. in road building, to replace sand in concrete production, or in the cement industry)</td> <td data-bbox="763 727 1025 959">Generally applicable within the constraints associated with the required material quality (e.g. physical properties, content of harmful substances) associated to each specific use, and by the market conditions</td> </tr> <tr> <td data-bbox="280 959 443 1142">c Energy recovery by using waste in the fuel mix</td> <td data-bbox="443 959 763 1142">The residual energy content of carbon-rich ash and sludges generated by the combustion of coal, lignite, heavy fuel oil, peat or biomass can be recovered for example by mixing with the fuel</td> <td data-bbox="763 959 1025 1142">Generally applicable where plants can accept waste in the fuel mix and are technically able to feed the fuels into the combustion chamber</td> </tr> <tr> <td data-bbox="280 1142 443 1372">d Preparation of spent catalyst for reuse</td> <td data-bbox="443 1142 763 1372">Preparation of catalyst for reuse (e.g. up to four times for SCR catalysts) restores some or all of the original performance, extending the service life of the catalyst to several decades. Preparation of spent catalyst for reuse is integrated in a catalyst management scheme</td> <td data-bbox="763 1142 1025 1372">The applicability may be limited by the mechanical condition of the catalyst and the required performance with respect to controlling NO_x and NH₃ emissions</td> </tr> </tbody> </table>	Technique	Description	Applicability	a Generation of gypsum as a by-product	Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g. as raw material in the plasterboard industry). The quality of limestone used in the wet FGD influences the purity of the gypsum produced	Generally applicable within the constraints associated with the required gypsum quality, the health requirements associated to each specific use, and by the market conditions	b Recycling or recovery of residues in the construction sector	Recycling or recovery of residues (e.g. from semi-dry desulphurisation processes, fly ash, bottom ash) as a construction material (e.g. in road building, to replace sand in concrete production, or in the cement industry)	Generally applicable within the constraints associated with the required material quality (e.g. physical properties, content of harmful substances) associated to each specific use, and by the market conditions	c Energy recovery by using waste in the fuel mix	The residual energy content of carbon-rich ash and sludges generated by the combustion of coal, lignite, heavy fuel oil, peat or biomass can be recovered for example by mixing with the fuel	Generally applicable where plants can accept waste in the fuel mix and are technically able to feed the fuels into the combustion chamber	d Preparation of spent catalyst for reuse	Preparation of catalyst for reuse (e.g. up to four times for SCR catalysts) restores some or all of the original performance, extending the service life of the catalyst to several decades. Preparation of spent catalyst for reuse is integrated in a catalyst management scheme	The applicability may be limited by the mechanical condition of the catalyst and the required performance with respect to controlling NO _x and NH ₃ emissions		
Technique	Description	Applicability																
a Generation of gypsum as a by-product	Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g. as raw material in the plasterboard industry). The quality of limestone used in the wet FGD influences the purity of the gypsum produced	Generally applicable within the constraints associated with the required gypsum quality, the health requirements associated to each specific use, and by the market conditions																
b Recycling or recovery of residues in the construction sector	Recycling or recovery of residues (e.g. from semi-dry desulphurisation processes, fly ash, bottom ash) as a construction material (e.g. in road building, to replace sand in concrete production, or in the cement industry)	Generally applicable within the constraints associated with the required material quality (e.g. physical properties, content of harmful substances) associated to each specific use, and by the market conditions																
c Energy recovery by using waste in the fuel mix	The residual energy content of carbon-rich ash and sludges generated by the combustion of coal, lignite, heavy fuel oil, peat or biomass can be recovered for example by mixing with the fuel	Generally applicable where plants can accept waste in the fuel mix and are technically able to feed the fuels into the combustion chamber																
d Preparation of spent catalyst for reuse	Preparation of catalyst for reuse (e.g. up to four times for SCR catalysts) restores some or all of the original performance, extending the service life of the catalyst to several decades. Preparation of spent catalyst for reuse is integrated in a catalyst management scheme	The applicability may be limited by the mechanical condition of the catalyst and the required performance with respect to controlling NO _x and NH ₃ emissions																

BAT C No.	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																		
17	<p>In order to reduce noise emissions, BAT is to use one or a combination of the techniques given below.</p> <table border="1" data-bbox="280 384 1025 1359"> <thead> <tr> <th data-bbox="280 384 454 416">Technique</th> <th data-bbox="454 384 775 416">Description</th> <th data-bbox="775 384 1025 416">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="280 416 454 831">a . Operational measures</td> <td data-bbox="454 416 775 831"> These include: <ul style="list-style-type: none"> — improved inspection and maintenance of equipment — closing of doors and windows of enclosed areas, if possible — equipment operated by experienced staff — avoidance of noisy activities at night, if possible — provisions for noise control during maintenance activities </td> <td data-bbox="775 416 1025 831">Generally applicable</td> </tr> <tr> <td data-bbox="280 831 454 919">b . Low-noise equipment</td> <td data-bbox="454 831 775 919">This potentially includes compressors, pumps and disks</td> <td data-bbox="775 831 1025 919">Generally applicable when the equipment is new or replaced</td> </tr> <tr> <td data-bbox="280 919 454 1078">c . Noise attenuation</td> <td data-bbox="454 919 775 1078">Noise propagation can be reduced by inserting obstacles between the emitter and the receiver. Appropriate obstacles include protection walls, embankments and buildings</td> <td data-bbox="775 919 1025 1078">Generally applicable to new plants. In the case of existing plants, the insertion of obstacles may be restricted by lack of space</td> </tr> <tr> <td data-bbox="280 1078 454 1286">d . Noise-control equipment</td> <td data-bbox="454 1078 775 1286"> This includes: <ul style="list-style-type: none"> — noise-reducers — equipment insulation — enclosure of noisy equipment — soundproofing of buildings </td> <td data-bbox="775 1078 1025 1286">The applicability may be restricted by lack of space</td> </tr> <tr> <td data-bbox="280 1286 454 1359">e . Appropriate location of equipment</td> <td data-bbox="454 1286 775 1359">Noise levels can be reduced by increasing the distance between the emitter and the receiver and</td> <td data-bbox="775 1286 1025 1359">Generally applicable to new plant</td> </tr> </tbody> </table>	Technique	Description	Applicability	a . Operational measures	These include: <ul style="list-style-type: none"> — improved inspection and maintenance of equipment — closing of doors and windows of enclosed areas, if possible — equipment operated by experienced staff — avoidance of noisy activities at night, if possible — provisions for noise control during maintenance activities 	Generally applicable	b . Low-noise equipment	This potentially includes compressors, pumps and disks	Generally applicable when the equipment is new or replaced	c . Noise attenuation	Noise propagation can be reduced by inserting obstacles between the emitter and the receiver. Appropriate obstacles include protection walls, embankments and buildings	Generally applicable to new plants. In the case of existing plants, the insertion of obstacles may be restricted by lack of space	d . Noise-control equipment	This includes: <ul style="list-style-type: none"> — noise-reducers — equipment insulation — enclosure of noisy equipment — soundproofing of buildings 	The applicability may be restricted by lack of space	e . Appropriate location of equipment	Noise levels can be reduced by increasing the distance between the emitter and the receiver and	Generally applicable to new plant	CC	<p>The Operator confirmed that the following techniques are in place:</p> <p>a. operational measures are in place as described in a. c. location of existing assets are on an industrial site and are located specifically away from the nearest residential areas.</p> <p>We agree with the Operator's stated compliance.</p> <p>We have however included a general noise improvement condition as detailed in section 8 of this document.</p>
Technique	Description	Applicability																			
a . Operational measures	These include: <ul style="list-style-type: none"> — improved inspection and maintenance of equipment — closing of doors and windows of enclosed areas, if possible — equipment operated by experienced staff — avoidance of noisy activities at night, if possible — provisions for noise control during maintenance activities 	Generally applicable																			
b . Low-noise equipment	This potentially includes compressors, pumps and disks	Generally applicable when the equipment is new or replaced																			
c . Noise attenuation	Noise propagation can be reduced by inserting obstacles between the emitter and the receiver. Appropriate obstacles include protection walls, embankments and buildings	Generally applicable to new plants. In the case of existing plants, the insertion of obstacles may be restricted by lack of space																			
d . Noise-control equipment	This includes: <ul style="list-style-type: none"> — noise-reducers — equipment insulation — enclosure of noisy equipment — soundproofing of buildings 	The applicability may be restricted by lack of space																			
e . Appropriate location of equipment	Noise levels can be reduced by increasing the distance between the emitter and the receiver and	Generally applicable to new plant																			

BAT C No.	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																											
	and buildings by using buildings as noise screens																													
Combustion of solid fuels only (coal and/or lignite) – BAT Conclusions 18 to 23 deleted Combustion of solid fuels (solid biomass and/or peat) - BAT Conclusions 24 to 27 deleted Combustion of liquid fuels (HFO and/or gas-oil-fired boilers) – BAT Conclusions 28 to 30 deleted Combustion of liquid fuels (HFO and/or gas-oil-fired engines) – BAT Conclusions 31 to 35 deleted Combustion of liquid fuels (gas oil fired gas turbines) – BAT Conclusions 36 to 39 deleted Not applicable to the activities carried out at the installation																														
Combustion of gaseous fuels																														
40	<p>In order to increase the energy efficiency of natural gas combustion, BAT is to use an appropriate combination of the techniques given in BAT 12 and below.</p> <table border="1"> <thead> <tr> <th>Technique</th> <th>Description</th> <th>Applicability</th> </tr> </thead> <tbody> <tr> <td>a Combined cycle</td> <td>See description in Section 8.2</td> <td>Generally applicable to new gas turbines and engines except when operated < 1 500 h/yr. Applicable to existing gas turbines and engines within the constraints associated with the steam cycle design and the space availability. Not applicable to existing gas turbines and engines operated < 1 500 h/yr. Not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns. Not applicable to boilers</td> </tr> </tbody> </table> <p>BAT-associated energy efficiency levels (BAT-AEELs) for the combustion of natural gas</p> <table border="1"> <thead> <tr> <th rowspan="3">Type of combustion unit</th> <th colspan="5">BAT-AEELs ⁽¹³⁶⁾ ⁽¹³⁷⁾</th> </tr> <tr> <th colspan="2">Net electrical efficiency (%)</th> <th rowspan="2">Net total fuel utilisation (%) ⁽¹³⁸⁾ ⁽¹³⁹⁾</th> <th colspan="2">Net mechanical energy efficiency (%) ⁽¹³⁹⁾ ⁽¹⁴⁰⁾</th> </tr> <tr> <th>New unit</th> <th>Existing unit</th> <th>New unit</th> <th>Existing unit</th> </tr> </thead> <tbody> <tr> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>	Technique	Description	Applicability	a Combined cycle	See description in Section 8.2	Generally applicable to new gas turbines and engines except when operated < 1 500 h/yr. Applicable to existing gas turbines and engines within the constraints associated with the steam cycle design and the space availability. Not applicable to existing gas turbines and engines operated < 1 500 h/yr. Not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns. Not applicable to boilers	Type of combustion unit	BAT-AEELs ⁽¹³⁶⁾ ⁽¹³⁷⁾					Net electrical efficiency (%)		Net total fuel utilisation (%) ⁽¹³⁸⁾ ⁽¹³⁹⁾	Net mechanical energy efficiency (%) ⁽¹³⁹⁾ ⁽¹⁴⁰⁾		New unit	Existing unit	New unit	Existing unit							FC	<p>The Operator confirmed that:</p> <p>GT2 – 81.4% Net fuel input to GT2 & HRSG (inc feed heat as fuel equivalent).</p> <p>In their response to our request for information received 13 March 2020 they confirmed that the original test results were at full load only which explains the higher efficiency. The lower heating value (LHV) varies as a result of varying customer steam demand. The BAT AEEL is met.</p> <p>They also confirmed that the efficiency calculation is based on:</p> <p>Net Fuel input to GT2 & HRSG (Feed heat produced internally) Net power from GT2 Net Heat from GT2</p> <p>These figures are taken from their verified CHPQA data for the GT2 Scheme and converted from gross to net calorific value (CV).</p> <p>In their response received 01 April 2020 they confirmed that the applicable BAT AEEL is the 'net total fuel utilisation'.</p> <p>Refer to section 4.2 of this document.</p> <p>We are not fully satisfied that the requirements of this BAT Conclusion are met and have set an improvement condition to address the deficiencies.</p> <p>We do not agree with the Operator's stated compliance of CC and have set the</p>
Technique	Description	Applicability																												
a Combined cycle	See description in Section 8.2	Generally applicable to new gas turbines and engines except when operated < 1 500 h/yr. Applicable to existing gas turbines and engines within the constraints associated with the steam cycle design and the space availability. Not applicable to existing gas turbines and engines operated < 1 500 h/yr. Not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns. Not applicable to boilers																												
Type of combustion unit	BAT-AEELs ⁽¹³⁶⁾ ⁽¹³⁷⁾																													
	Net electrical efficiency (%)		Net total fuel utilisation (%) ⁽¹³⁸⁾ ⁽¹³⁹⁾	Net mechanical energy efficiency (%) ⁽¹³⁹⁾ ⁽¹⁴⁰⁾																										
	New unit	Existing unit		New unit	Existing unit																									

BAT C No.	Summary of BAT Conclusion requirement					Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	
		t					compliance status to FC.	
Gas engine	39,5–44 ⁽¹⁴¹⁾	35–44 ⁽¹⁴¹⁾	56–85 ⁽¹⁴¹⁾		No BAT-AEEL.			
Gas-fired boiler	39–42,5	38–40	78–95		No BAT-AEEL.			
Open cycle gas turbine, ≥ 50 MW _{th}	36–41,5	33–41,5	No BAT-AEEL	36,5–41	33,5–41			
Combined cycle gas turbine (CCGT)								
CCGT, 50–600 MW _{th}	53–58,5	46–54	No BAT-AEEL		No BAT-AEEL			
CCGT, ≥ 600 MW _{th}	57–60,5	50–60	No BAT-AEEL		No BAT-AEEL			
CHP CCGT, 50–600 MW _{th}	53–58,5	46–54	65–95		No BAT-AEEL			
CHP CCGT, ≥ 600 MW _{th}	57–60,5	50–60	65–95		No BAT-AEEL			
41	In order to prevent or reduce NO _x emissions to air from the combustion of natural gas in boilers, BAT is to use one or a combination of the techniques given below.					NA		<p>This BAT Conclusion is applicable to the combustion of natural gas in boilers and therefore is not applicable to this installation.</p> <p>The Operator stated that they are CC. We don't agree with the Operator's stated compliance. This BAT Conclusion is not applicable to the activities carried out at the installation.</p>
	Technique	Description	Applicability					
a	Air and/or fuel staging	See descriptions in Section 8.3. Air staging is often associated with low-NO _x burners	Generally applicable					
b	Flue-gas recirculation	See description in Section 8.3						
c	Low-NO _x burners (LNB)							
d	Advanced control system	See description in Section 8.3. This technique is often	The applicability to old combustion plants may be constrained by the need to					

BAT C No.	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
		used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	retrofit the combustion system and/or control command system		
	e .	Reduction of the combustion air temperature	See description in Section 8.3		
	f .	Selective non-catalytic reduction (SNCR)	Generally applicable within the constraints associated with the process needs		
	g .	Selective catalytic reduction (SCR)	Not applicable to combustion plants operated < 500 h/yr with highly variable boiler loads. The applicability may be limited in the case of combustion plants operated between 500 h/yr and 1 500 h/yr with highly variable boiler loads		
42	In order to prevent or reduce NO _x emissions to air from the combustion of natural gas in gas turbines, BAT is to use one or a combination of the techniques given below.			CC	The Operator confirmed that: In their response to our request for information received 13 March 2020 they confirmed that the following techniques are used to manage NO _x emissions: a. Advanced control system b. DLN burners and Air staging
	Technique	Description	Applicability		
	a .	Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for		
			The applicability to old combustion plants may be constrained by the need to retrofit the		

BAT C No.	Summary of BAT Conclusion requirement		Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
		combustion plants operated < 500 h/yr	combustion system and/or control command system	Lean burn concept and advanced lean burn We agree with the Operator's stated compliance.
b	Water/steam addition	See description in Section 8.3	The applicability may be limited due to water availability	
c	Dry low-NO _x burners (DLN)		The applicability may be limited in the case of turbines where a retrofit package is not available or when water/steam addition systems are installed	
d	Low-load design concept	Adaptation of the process control and related equipment to maintain good combustion efficiency when the demand in energy varies, e.g. by improving the inlet airflow control capability or by splitting the combustion process into decoupled combustion stages	The applicability may be limited by the gas turbine design	
e	Low-NO _x burners (LNB)	See description in Section 8.3	Generally applicable to supplementary firing for heat recovery steam generators (HRSGs) in the case of combined-cycle gas turbine (CCGT) combustion plants	
f	Selective catalytic reduction (SCR)		Not applicable in the case of combustion plants operated < 500 h/yr. Not generally applicable to existing combustion plants of < 100 MW _{th} . Retrofitting existing combustion plants may be constrained by the availability of sufficient	

BAT C No.	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
			space. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr		
43	In order to prevent or reduce NO _x emissions to air from the combustion of natural gas in engines, BAT is to use one or a combination of the techniques given below.			NA	The Operator did not provide a response to this BAT Conclusion. We consider that this BAT Conclusion is not applicable to the activities carried out at the installation because there are no engines at the installation.
	Technique	Description	Applicability		
a	Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system		
b	Lean-burn concept	See description in Section 8.3. Generally used in combination with SCR	Only applicable to new gas-fired engines		
c	Advanced lean-burn concept	See descriptions in Section 8.3	Only applicable to new spark plug ignited engines		
d	Selective catalytic reduction (SCR)		Retrofitting existing combustion plants may be constrained by the availability of sufficient space. Not applicable to combustion plants operated < 500 h/yr. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr		

BAT C No.	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																																																		
44	<p>In order to prevent or reduce CO emissions to air from the combustion of natural gas, BAT is to ensure optimised combustion and/or to use oxidation catalysts.</p> <p>Description - See descriptions in Section 8.3.</p> <p>BAT-associated emission levels (BAT-AELs) for NO_x emissions to air from the combustion of natural gas in gas turbines</p> <table border="1" data-bbox="280 496 1025 715"> <thead> <tr> <th rowspan="2">Type of combustion plant</th> <th rowspan="2">Combustion plant total rated thermal input (MW_{th})</th> <th colspan="2">BAT-AELs (mg/Nm³)⁽¹⁴²⁾ ⁽¹⁴³⁾</th> </tr> <tr> <th>Yearly average⁽¹⁴⁴⁾⁽¹⁴⁵⁾</th> <th>Daily average or average over the sampling period</th> </tr> </thead> <tbody> <tr> <td colspan="4" style="text-align: center;">Open-cycle gas turbines (OCGTs)⁽¹⁴⁶⁾ ⁽¹⁴⁷⁾</td> </tr> <tr> <td>New OCGT</td> <td>≥ 50</td> <td>15–35</td> <td>25–50</td> </tr> <tr> <td>Existing OCGT (excluding turbines for mechanical drive applications) — All but plants operated < 500 h/yr</td> <td>≥ 50</td> <td>15–50</td> <td>25–55⁽¹⁴⁸⁾</td> </tr> <tr> <td colspan="4" style="text-align: center;">Combined-cycle gas turbines (CCGTs)⁽¹⁴⁶⁾ ⁽¹⁴⁹⁾</td> </tr> <tr> <td>New CCGT</td> <td>≥ 50</td> <td>10–30</td> <td>15–40</td> </tr> <tr> <td>Existing CCGT with a net total fuel utilisation of < 75 %</td> <td>≥ 600</td> <td>10–40</td> <td>18–50</td> </tr> <tr> <td>Existing CCGT with a net total fuel utilisation of ≥ 75 %</td> <td>≥ 600</td> <td>10–50</td> <td>18–55⁽¹⁵⁰⁾</td> </tr> <tr> <td>Existing CCGT with a net total fuel utilisation of < 75 %</td> <td>50–600</td> <td>10–45</td> <td>35–55</td> </tr> <tr> <td>Existing CCGT with a net total fuel utilisation of ≥ 75 %</td> <td>50–600</td> <td>25–50⁽¹⁵¹⁾</td> <td>35–55⁽¹⁵²⁾</td> </tr> <tr> <td colspan="4" style="text-align: center;">Open- and combined-cycle gas turbines</td> </tr> <tr> <td>Gas turbine put into operation no later than 27 November 2003, or existing gas turbine for emergency</td> <td>≥ 50</td> <td>No BAT-AEL</td> <td>60–140⁽¹⁵³⁾ ⁽¹⁵⁴⁾</td> </tr> </tbody> </table>	Type of combustion plant	Combustion plant total rated thermal input (MW _{th})	BAT-AELs (mg/Nm ³) ⁽¹⁴²⁾ ⁽¹⁴³⁾		Yearly average ⁽¹⁴⁴⁾ ⁽¹⁴⁵⁾	Daily average or average over the sampling period	Open-cycle gas turbines (OCGTs)⁽¹⁴⁶⁾ ⁽¹⁴⁷⁾				New OCGT	≥ 50	15–35	25–50	Existing OCGT (excluding turbines for mechanical drive applications) — All but plants operated < 500 h/yr	≥ 50	15–50	25–55 ⁽¹⁴⁸⁾	Combined-cycle gas turbines (CCGTs)⁽¹⁴⁶⁾ ⁽¹⁴⁹⁾				New CCGT	≥ 50	10–30	15–40	Existing CCGT with a net total fuel utilisation of < 75 %	≥ 600	10–40	18–50	Existing CCGT with a net total fuel utilisation of ≥ 75 %	≥ 600	10–50	18–55 ⁽¹⁵⁰⁾	Existing CCGT with a net total fuel utilisation of < 75 %	50–600	10–45	35–55	Existing CCGT with a net total fuel utilisation of ≥ 75 %	50–600	25–50 ⁽¹⁵¹⁾	35–55 ⁽¹⁵²⁾	Open- and combined-cycle gas turbines				Gas turbine put into operation no later than 27 November 2003, or existing gas turbine for emergency	≥ 50	No BAT-AEL	60–140 ⁽¹⁵³⁾ ⁽¹⁵⁴⁾	CC	<p>The Operator confirmed that they are compliant with both the yearly and daily average BAT AELs for NO_x and the indicative yearly average for CO.</p> <p>We have set limits as detailed in section 4.1 of this document.</p> <p>We agree with the Operator's stated compliance.</p>
Type of combustion plant	Combustion plant total rated thermal input (MW _{th})			BAT-AELs (mg/Nm ³) ⁽¹⁴²⁾ ⁽¹⁴³⁾																																																	
		Yearly average ⁽¹⁴⁴⁾ ⁽¹⁴⁵⁾	Daily average or average over the sampling period																																																		
Open-cycle gas turbines (OCGTs)⁽¹⁴⁶⁾ ⁽¹⁴⁷⁾																																																					
New OCGT	≥ 50	15–35	25–50																																																		
Existing OCGT (excluding turbines for mechanical drive applications) — All but plants operated < 500 h/yr	≥ 50	15–50	25–55 ⁽¹⁴⁸⁾																																																		
Combined-cycle gas turbines (CCGTs)⁽¹⁴⁶⁾ ⁽¹⁴⁹⁾																																																					
New CCGT	≥ 50	10–30	15–40																																																		
Existing CCGT with a net total fuel utilisation of < 75 %	≥ 600	10–40	18–50																																																		
Existing CCGT with a net total fuel utilisation of ≥ 75 %	≥ 600	10–50	18–55 ⁽¹⁵⁰⁾																																																		
Existing CCGT with a net total fuel utilisation of < 75 %	50–600	10–45	35–55																																																		
Existing CCGT with a net total fuel utilisation of ≥ 75 %	50–600	25–50 ⁽¹⁵¹⁾	35–55 ⁽¹⁵²⁾																																																		
Open- and combined-cycle gas turbines																																																					
Gas turbine put into operation no later than 27 November 2003, or existing gas turbine for emergency	≥ 50	No BAT-AEL	60–140 ⁽¹⁵³⁾ ⁽¹⁵⁴⁾																																																		

BAT C No.	Summary of BAT Conclusion requirement				Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	
	use and operated < 500 h/yr						
	Existing gas turbine for mechanical drive applications — All but plants operated < 500 h/yr	≥ 50	15–50 ⁽¹⁵⁵⁾	25–55 ⁽¹⁵⁶⁾			
	<p>As an indication, the yearly average CO emission levels for each type of existing combustion plant operated ≥ 1 500 h/yr and for each type of new combustion plant will generally be as follows:</p> <ul style="list-style-type: none"> — New OCGT of ≥ 50 MW_{th}: < 5–40 mg/Nm³. For plants with a net electrical efficiency (EE) greater than 39 %, a correction factor may be applied to the higher end of this range, corresponding to [higher end] × EE/39, where EE is the net electrical energy efficiency or net mechanical energy efficiency of the plant determined at ISO baseload conditions. — Existing OCGT of ≥ 50 MW_{th} (excluding turbines for mechanical drive applications): < 5–40 mg/Nm³. The higher end of this range will generally be 80 mg/Nm³ in the case of existing plants that cannot be fitted with dry techniques for NO_x reduction, or 50 mg/Nm³ for plants that operate at low load. — New CCGT of ≥ 50 MW_{th}: < 5–30 mg/Nm³. For plants with a net electrical efficiency (EE) greater than 55 %, a correction factor may be applied to the higher end of the range, corresponding to [higher end] × EE/55, where EE is the net electrical energy efficiency of the plant determined at ISO baseload conditions. — Existing CCGT of ≥ 50 MW_{th}: < 5–30 mg/Nm³. The higher end of this range will generally be 50 mg/Nm³ for plants that operate at low load. — Existing gas turbines of ≥ 50 MW_{th} for mechanical drive applications: < 5–40 mg/Nm³. The higher end of the range will generally be 50 mg/Nm³ when plants operate at low load. <p>In the case of a gas turbine equipped with DLN burners, these indicative levels correspond to when the DLN operation is effective.</p> <p>BAT-associated emission levels (BAT-AELs) for NO_x emissions to air from the combustion of natural gas in boilers and engines</p>						
	Type of combustion plant	BAT-AELs (mg/Nm ³)					
		Yearly average ⁽¹⁵⁷⁾		Daily average or average over the sampling period			
		New plant	Existing plant ⁽¹⁵⁸⁾	New plant	Existing plant ⁽¹⁵⁹⁾		

BAT C No.	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																		
	<table border="1" data-bbox="280 327 1025 432"> <thead> <tr> <th></th> <th colspan="4">t</th> </tr> </thead> <tbody> <tr> <td>Boiler</td> <td>10–60</td> <td>50–100</td> <td>30–85</td> <td>85–110</td> </tr> <tr> <td>Engine ⁽¹⁶⁰⁾</td> <td>20–75</td> <td>20–100</td> <td>55–85</td> <td>55–110 ⁽¹⁶¹⁾</td> </tr> </tbody> </table> <p>As an indication, the yearly average CO emission levels will generally be:</p> <ul style="list-style-type: none"> — < 5–40 mg/Nm³ for existing boilers operated ≥ 1 500 h/yr, — < 5–15 mg/Nm³ for new boilers, — 30–100 mg/Nm³ for existing engines operated ≥ 1 500 h/yr and for new engines. 		t				Boiler	10–60	50–100	30–85	85–110	Engine ⁽¹⁶⁰⁾	20–75	20–100	55–85	55–110 ⁽¹⁶¹⁾					
	t																				
Boiler	10–60	50–100	30–85	85–110																	
Engine ⁽¹⁶⁰⁾	20–75	20–100	55–85	55–110 ⁽¹⁶¹⁾																	
45	<p>In order to reduce non-methane volatile organic compounds (NMVOC) and methane (CH₄) emissions to air from the combustion of natural gas in spark-ignited lean-burn gas engines, BAT is to ensure optimised combustion and/or to use oxidation catalysts.</p> <p>Description</p> <p>See descriptions in Section 8.3. Oxidation catalysts are not effective at reducing the emissions of saturated hydrocarbons containing less than four carbon atoms.</p> <p>BAT-associated emission levels (BAT-AELs) for formaldehyde and CH₄ emissions to air from the combustion of natural gas in a spark-ignited lean-burn gas engine</p> <table border="1" data-bbox="280 959 1025 1259"> <thead> <tr> <th rowspan="3">Combustion plant total rated thermal input (MW_{th})</th> <th colspan="3">BAT-AELs (mg/Nm³)</th> </tr> <tr> <th>Formaldehyde</th> <th colspan="2">CH₄</th> </tr> <tr> <th colspan="3">Average over the sampling period</th> </tr> <tr> <th></th> <th>New or existing plant</th> <th>New plant</th> <th>Existing plant</th> </tr> </thead> <tbody> <tr> <td>≥ 50</td> <td>5–15 ⁽¹⁶²⁾</td> <td>215–500 ⁽¹⁶³⁾</td> <td>215–560 ⁽¹⁶²⁾ ₍₁₆₃₎</td> </tr> </tbody> </table>	Combustion plant total rated thermal input (MW _{th})	BAT-AELs (mg/Nm ³)			Formaldehyde	CH ₄		Average over the sampling period				New or existing plant	New plant	Existing plant	≥ 50	5–15 ⁽¹⁶²⁾	215–500 ⁽¹⁶³⁾	215–560 ⁽¹⁶²⁾ ₍₁₆₃₎	NA	<p>The Operator did not provide a response to this BAT Conclusion.</p> <p>We consider that this BAT Conclusion is not applicable to the activities carried out at the installation because there are no engines at the installation.</p>
Combustion plant total rated thermal input (MW _{th})	BAT-AELs (mg/Nm ³)																				
	Formaldehyde		CH ₄																		
	Average over the sampling period																				
	New or existing plant	New plant	Existing plant																		
≥ 50	5–15 ⁽¹⁶²⁾	215–500 ⁽¹⁶³⁾	215–560 ⁽¹⁶²⁾ ₍₁₆₃₎																		
<p>BAT Conclusions for iron and steel process gases – BAT Conclusions 46 to 51 deleted BAT Conclusions for offshore platforms – BAT Conclusions BAT 52 to 54 deleted BAT Conclusions for chemical process gases – BAT Conclusions 55 to 59 deleted BAT Conclusions for co-incineration – BAT Conclusions 60 to 71</p>																					

BAT C No.	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
BAT Conclusions for gasification – BAT Conclusions 72 to 75 deleted Not applicable to the activities carried out at the installation			

6 Review and assessment of derogation requests made by the Operator in relation to BAT Conclusions which include an associated emission level (AEL) value

The IED enables a competent authority to allow derogations from BAT AELs stated in BAT Conclusions under specific circumstances as detailed under Article 15(4):

By way of derogation from paragraph 3, and without prejudice to Article 18, the competent authority may, in specific cases, set less strict emission limit values. Such a derogation may apply only where an assessment shows that the achievement of emission levels associated with the best available techniques as described in BAT conclusions would lead to disproportionately higher costs compared to the environmental benefits due to:

(a) the geographical location or the local environmental conditions of the installation concerned; or

(b) the technical characteristics of the installation concerned.

The Operator has not made any such request.

7 Emissions to water

There are no direct emissions to water from the installation.

There are no BAT AELs specified in the BAT Conclusions for this type of plant.

8 Additional IED Chapter II requirements:

Condition/table	Justification
Condition 2.3.7, improvement condition IC12 and definition in Schedule 6 added	<p>In the event of a black out National Grid would call on combustion plant to operate and may require them to do so outside their permitted conditions. We have dedicated black start plant and they are permitted to run as such but this scenario is relevant to the rest of the LCP which could be called depending on the circumstances.</p> <p>A risk assessment will be carried out by Energy UK/Joint Environmental Programme on behalf of LCP connected to the National Transmission System. Air emissions modelling will be based on generic black start scenarios to establish whether they have the potential to have a local impact on the environment or not (on a national basis). If the modelling demonstrates that no significant impacts are likely, the plant can operate under condition 2.3.7. This condition allows the hourly ELVs for plants operating under a black start instruction to be discounted for the purpose of reporting. We would also require there to be a procedure in place for minimisation of emissions in the case of a black start event and for reporting in the event of a black start. This modelling and the procedures have not been agreed in advance of the issue of the permit review and therefore a condition linking back to an improvement condition has been included in the permit.</p>
Condition 3.5.1 amended	To reference table S3.3 for process monitoring parameters and to remove reference to annual limits specified in table S3.3.
Condition 3.5.4 amended	To reference table S3.3 process monitoring requirements at emission point S7.
Table S1.1 amended	<p>To amend the thermal input of the gas turbine from 133.1 MWth to 133 MWth and to include the thermal input of 70 MWth for the HRSG.</p> <p>To include waste oil storage as a directly associated activity.</p>
Table S1.3 amended to confirm the completion of improvement conditions and the addition of a noise improvement condition	<p>The existing permit contains a specific control for noise in table S1.2 as follows:</p> <p>The venting of steam during start up shall be minimised between the hours of 22:00hrs and 08:00hrs on any calendar day, except where it is essential to maintain plant security.</p> <p>The improvement condition expands on this requiring an updated noise management plan. The update shall include additional noise control measures together with a definition</p>

	<p>for 'emergency' operation.</p> <p>Following approval these will be incorporated into table S1.2 of the permit.</p> <p>IC8 complete – response received 02 September 2016, no changes to the permit required.</p> <p>IC11 complete</p>
Table S1.4 amended	Note 1 added to refer to table S3.3 for process monitoring.
Table S1.5	<p>Amended to redefine the MSUL/MSDL following a telecon 30 April 2020.</p> <p>A formal submission will be required in accordance with existing permit improvement condition IP9.</p>
Table S2.1 amended	To add natural gas, consistent with other permits in the sector.
Table S3.3 deleted (Table S3.4 renumbered to S3.3)	<p>To remove annual limits for cadmium and mercury present in raw materials.</p> <p>This is a legacy requirement where controls were in place for mercury in raw materials, primarily caustic soda. This is now generally 'mercury free' and as such we are no longer required to set limits for these parameters in raw materials.</p>
Table S3.4 (now S3.3) amended	<p>Note 1 amended from:</p> <p>The methods will be supplied as per pre operational condition 3.</p> <p>to</p> <p>In accordance with the methods supplied and approved for pre-operational condition 3 in table S1.4 of this permit.</p>
Table S4.1 amended	<p>Sulphur dioxide reporting frequency changed from every six months to every year.</p> <p>Mass release of cadmium and mercury to sewer deleted.</p> <p>To include process monitoring at emission point S7.</p>
Schedule 6 Interpretation	<p>“energy efficiency” the ISO base load net plant efficiency means the performance value established by acceptance testing following commissioning or performance testing following improvements made to the plant that could affect the efficiency.</p> <p>Deleted and replaced with:</p> <p>“energy efficiency” the annual net plant energy efficiency means the value calculated from the operational data collected over the year.</p> <p>Amended the reference conditions interpretation to remove those that are not applicable to the facility.</p>

9 Review and assessment of changes that are not part of the BAT Conclusions derived permit review.

This document should be read in conjunction with the application, supporting information and notice.

Aspect considered	Decision
Receipt of application	
Confidential information	A claim for commercial or industrial confidentiality has not been made.
Identifying confidential information	We have not identified information provided as part of the application that we consider to be confidential.
The site	
Extent of the site of the facility	The Operator has provided a plan which we consider is satisfactory, showing the extent of the site of the facility. The plan is included in the permit.
Biodiversity, heritage, landscape and nature conservation	<p>The application is within the relevant distance criteria of a site of heritage, landscape or nature conservation, and/or protected species or habitat.</p> <p>A full assessment of the application and its potential to affect the sites/species/habitat has not been carried out as part of the permit review process. We consider that the review will not affect the features of the sites/species/habitat as the conditions will provide at least the same level of protection as those in the previous permit and in some cases will provide a higher level of protection to those in the previous permit.</p> <p>We have not consulted Natural England on the application. The decision was taken in accordance with our guidance.</p>

Aspect considered	Decision
Operating techniques	
General operating techniques	<p>We have reviewed the techniques used by the Operator where they are relevant to the BAT Conclusions and compared these with the relevant guidance notes.</p> <p>The permit conditions ensure compliance with the relevant BREF, BAT Conclusions. The ELVs deliver compliance with the BAT-AELs.</p>
Permit conditions	
Updating permit conditions during consolidation	<p>We have updated permit conditions to those in the current generic permit template as part of permit consolidation. The conditions will provide at least the same level of protection as those in the previous permit and in some cases will provide a higher level of protection to those in the previous permit.</p>
Changes to the permit conditions due to an Environment Agency initiated variation	<p>We have varied the permit as stated in the variation notice.</p>
Improvement programme	<p>Based on the information in the Regulation 61 response, we consider that we need to impose an improvement programme. The reasons for this are detailed in the relevant sections of this document.</p>
Emission limits	<p>We have decided that emission limits should be set for the parameters listed in the permit.</p> <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p> <p>It is considered that the ELVs described above will ensure that significant pollution of the environment is prevented and a high level of protection for the environment is secured.</p>

Aspect considered	Decision
Monitoring	<p>We have decided that monitoring should be carried out for the parameters listed in the permit, using the methods detailed and to the frequencies specified.</p> <p>These are described in the relevant BAT Conclusions in Sections 4.1 and 5 of this document.</p> <p>Table S3.3 Process monitoring requirements was amended to include the requirement to monitor energy efficiency after overhauls on site in line with BAT Conclusion 2.</p> <p>Based on the information in the application we are satisfied that the Operator’s techniques, personnel and equipment have either MCERTS certification or MCERTS accreditation as appropriate.</p>
Reporting	<p>We have specified reporting in the permit for the following parameters:</p> <ul style="list-style-type: none"> • Nitrogen dioxide • Carbon monoxide • Sulphur dioxide <p>These are described in the relevant BAT Conclusions in Sections 4.1 and 5 of this document.</p>
Operator competence	
Management system	<p>There is no known reason to consider that the Operator will not have the management system to enable them to comply with the permit conditions.</p>
Growth Duty	
Section 108 Deregulation Act 2015 – Growth duty	<p>We have considered our duty to have regard to the desirability of promoting economic growth set out in section 108(1) of the Deregulation Act 2015 and the guidance issued under section 110 of that Act in deciding whether to grant this permit.</p> <p>Paragraph 1.3 of the guidance says: “The primary role of regulators, in delivering regulation, is to achieve the regulatory outcomes for which they are responsible. For a number of regulators, these regulatory outcomes include an</p>

Aspect considered	Decision
	<p>explicit reference to development or growth. The growth duty establishes economic growth as a factor that all specified regulators should have regard to, alongside the delivery of the protections set out in the relevant legislation.”</p> <p>We have addressed the legislative requirements and environmental standards to be set for this operation in the body of the decision document above. The guidance is clear at paragraph 1.5 that the growth duty does not legitimise non-compliance and its purpose is not to achieve or pursue economic growth at the expense of necessary protections.</p> <p>We consider the requirements and standards we have set in this permit are reasonable and necessary to avoid a risk of an unacceptable level of pollution. This also promotes growth amongst legitimate operators because the standards applied to the operator are consistent across businesses in this sector and have been set to achieve the required legislative standards.</p>