

Environment Agency

Review of an Environmental Permit for an Installation subject to Chapter II of the Industrial Emissions Directive under the Environmental Permitting (England & Wales) Regulations 2016

Decision document recording our decision-making process following review of a permit

The Permit number is: EPR/BS5380IC
The Operator is: Rocksavage Power Company Limited
The Installation is: Rocksavage Power Station
This Variation Notice number is: EPR/BS5380IC/V004

What this document is about

Article 21(3) of the Industrial Emissions Directive (IED) requires the Environment Agency to review conditions in permits that it has issued and to ensure that the permit delivers compliance with relevant standards, within four years of the publication of updated decisions on best available techniques (BAT) Conclusions.

We have reviewed the permit for this installation against the revised BAT Conclusions for large combustion plant (LCP) published on 17 August 2017. This is our decision document, which explains the reasoning for the consolidated variation notice that we are issuing.

It explains how we have reviewed and considered the techniques used by the operator in the operation and control of the plant and activities of the installation. This review has been undertaken with reference to the decision made by the European Commission establishing BAT Conclusions for LCP as detailed in document reference IEDC-7-1. It is our record of our decision-making process and shows how we have taken into account all relevant factors in reaching our position. It also provides a justification for the inclusion of any specific conditions in the permit that are in addition to those included in our generic permit template.

As well as considering the review of the operating techniques used by the operator for the operation of the plant and activities of the installation, the consolidated variation notice takes into account and brings together in a single document all previous variations that relate to the original permit

issued. It also modernises the entire permit to reflect the conditions contained in our current generic permit template.

The introduction of new template conditions makes the permit consistent with our current general approach and philosophy and with other permits issued to installations in this sector. Although the wording of some conditions has changed, while others have been removed because of the new regulatory approach, it does not reduce the level of environmental protection achieved by the permit in any way. In this document we therefore address only our determination of substantive issues relating to the new BAT Conclusions.

This is our record of our decision-making process and shows how we have taken into account all relevant factors in reaching our position.

Throughout this document we use a number of expressions. These are as referred to in the glossary and have the same meaning as described in “Schedule 6 Interpretation” of the permit.

We try to explain our decision as accurately, comprehensively and plainly as possible. We would welcome any feedback as to how we might improve our decision documents in future. A lot of technical terms and acronyms are inevitable in a document of this nature: we provide a glossary of acronyms near the front of the document, for ease of reference.

How this document is structured

Glossary of terms

- 1 Our decision
- 2 How we reached our decision
- 2.1 Requesting information to demonstrate compliance with BAT Conclusions for Large Combustion Plant
- 2.2 Review of our own information in respect to the capability of the installation to meet revised standards included in the BAT Conclusions document
- 3 The legal framework
- 4 Key issues
- 5 Decision checklist regarding relevant BAT Conclusions
- 6 Review and assessment of derogation requests made by the operator in relation to BAT Conclusions which include an associated emission level (AEL) value
- 7 Emissions to water
- 8 Additional IED Chapter II requirements
- 9 Review and assessment of changes that are not part of the BAT Conclusions derived permit review.

Glossary of acronyms used in this document

(Please note that this glossary is standard for our decision documents and therefore not all these acronyms are necessarily used in this document.)

APC	Air Pollution Control
BAT	Best Available Technique(s)
BAT-AEEL	BAT Associated Energy Efficiency Level
BAT-AEL	BAT Associated Emission Level
BATc	BAT conclusion
BREF	Best available techniques reference document
CCGT	Combined Cycle Gas Turbine
CEM	Continuous emissions monitor
CHP	Combined heat and power
CV	Calorific value
DAA	Directly associated activity – Additional activities necessary to be carried out to allow the principal activity to be carried out
DLN	Dry Low NOx burners
DLN-E	Dry Low NOx effective
EIONET	European environment information and observation network is a partnership network of the European Environment Agency
ELV	Emission limit value derived under BAT or an emission limit value set out in IED
EMS	Environmental Management System
EPR	Environmental Permitting (England and Wales) Regulations 2016 (SI 2016 No. 1154)
EWC	European waste catalogue
FSA	Food Standards Agency
IC	Improvement Condition
IED	Industrial Emissions Directive (2010/75/EU)
IPPCD	Integrated Pollution Prevention and Control Directive (2008/1/EC) – now superseded by IED
LCP	Large Combustion Plant subject to Chapter III of IED
MSUL/MSDL	Minimum start up load/minimum shut-down load
NOx	Oxides of nitrogen (NO plus NO ₂ expressed as NO ₂)
NPV	Net Present Value
OCGT	Open Cycle Gas Turbine
PHE	Public Health England
SAC	Special Area of Conservation
SGN	Sector guidance note
TGN	Technical guidance note
TNP	Transitional National Plan
TOC	Total Organic Carbon
WFD	Water Framework Directive (2000/60/EC)

1 Our decision

We have decided to issue the consolidated variation notice to the operator. This will allow them to continue to operate the installation, subject to the conditions in the consolidated variation notice.

We consider that, in reaching that decision, we have taken into account all relevant considerations and legal requirements and that the varied permit will ensure that a high level of protection is provided for the environment and human health.

The consolidated variation notice contains many conditions taken from our standard environmental permit template including the relevant Annexes. We developed these conditions in consultation with industry, having regard to the legal requirements of the Environmental Permitting Regulations (EPR) and other relevant legislation. This document does not therefore include an explanation for these standard conditions. Where they are included in the notice, we have considered the techniques identified by the operator for the operation of their installation, and have accepted that the details are sufficient and satisfactory to make those standard conditions appropriate. This document does, however, provide an explanation of our use of “tailor-made” or installation-specific conditions, or where our permit template provides two or more options.

2 How we reached our decision

2.1 Requesting information to demonstrate compliance with BAT Conclusions for Large Combustion Plant

We issued a Notice under Regulation 61(1) of the Environmental Permitting (England and Wales) Regulations (EPR) 2016 (a regulation 61 Notice) on 01 May 2018 requiring the operator to provide information to demonstrate how the operation of their installation currently meets, or will subsequently meet, the revised standards described in the LCP BAT Conclusions document. The notice also required that where the revised standards are not currently met, the operator should provide information that:

- Describes the techniques that will be implemented before 17 August 2021, which will then ensure that operations meet the revised standard, or
- Justifies why standards will not be met by 17 August 2021, and confirmation of the date when the operation of those processes will cease within the installation or an explanation of why the revised BAT standard is not applicable to those processes, or
- Justifies why an alternative technique will achieve the same level of environmental protection equivalent to the revised standard described in the BAT Conclusions.

Where the operator proposed that they were not intending to meet a BAT standard that also included a BAT Associated Emission Level (BAT AEL) described in the BAT Conclusions Document, the regulation 61 notice requested that the operator make a formal request for derogation from compliance with that AEL (as provisioned by Article 15(4) of IED). In this circumstance, the notice identified that any such request for derogation must be supported and justified by sufficient technical and commercial information that would enable us to determine acceptability of the derogation request.

We did not receive any such request.

The regulation 61 notice response from the operator was received on 12 September 2018.

We considered it was in the correct form and contained sufficient information for us to begin our determination of the permit review but not that it necessarily contained all the information we would need to complete that review. We received further information as follows:

Date received	Additional information
12 December 2018	Email confirming BAT AELs for oxides of nitrogen (NOx) and carbon monoxide (CO)
12 December 2019	CO/NOx emissions and low part load operation
04 March 2020	MSUL/DLN-E definition and low part load operation
17 April 2020	Energy efficiency
15 May 2020	MSUL/MSDL/DLN-E definition and low part load operation Replaces submission received 04 March 2020

2.2 Review of our own information in respect to the capability of the installation to meet revised standards included in the BAT Conclusions document

Based on our records and previous regulatory activities with the facility we have no reason to consider that the operator will not be able to comply with the conditions that we include in the permit.

In relation to BAT Conclusion 44 we agree with the Operator in respect to their current stated capability as recorded in their Regulation 61 Notice response that improvements are required.

We have therefore included an improvement condition in the consolidated variation notice, which requires them to upgrade their operational techniques so that the requirements of the BAT Conclusion are delivered by 17 August 2021. This is discussed in more detail in the key issues section of this document.

3 The legal framework

The consolidated variation notice will be issued under Regulation 20 of the EPR. The Environmental Permitting regime is a legal vehicle which delivers most of the relevant legal requirements for activities falling within its scope. In particular, the regulated facility is:

- an *installation* as described by the IED;
- subject to aspects of other relevant legislation which also have to be addressed.

We consider that the consolidated variation notice will ensure that the operation of the installation complies with all relevant legal requirements and that a high level of protection will be delivered for the environment and human health.

We explain how we have addressed specific statutory requirements more fully in the rest of this document.

4 Key issues

The key issues arising during this permit review are:

- Emissions to air and the emission limits applied to the plant.
- The energy efficiency levels associated with the BAT-AEELs.

We therefore describe how we determined these issues in most detail in the relevant sections of this document.

We have also considered low part load (LPL) operation, refer to section 8 of this document for additional changes outside of the permit review.

4.1 Emissions to air and the emission limits applied to the plant

A number of general principles were applied during the permit review. These included:

- The upper value of the BAT AELs ranges specified were used unless use of the tighter limit was justified.
- The principle of no backsliding where if existing limits in the permit were already tighter than those specified in the BREF, the existing permit limits were retained.

- Where a limit was specified in both IED Annex V and the BAT Conclusions for a particular reference period, the tighter limit was applied and in the majority of cases this was from the BAT Conclusions.
- Where AELs are indicative in the BAT Conclusions, these were applied unless adequate justification was provided by the operator to demonstrate that an alternative limit was more appropriate.
- For gas turbines where the IED specified that limits applied over 70% load and the BAT Conclusions specified that AELs applied when dry low NOx is effective (DLN-E), we have used DLN-E as a default across all monitoring requirements for NOx and CO.

a) LCP configuration

The LCPs (LCP287 and LCP401) on site consist of:

Two combined cycle gas turbines (CCGT) (gas turbine A & gas turbine B), two heat recovery steam generators (HRSG) and one steam turbine.


Each LCP is 712 MWth with natural gas as the fuel. There is no stand-by fuel available at the installation.

Gas is burnt in the gas turbine which rotates a generator producing electricity. The hot combustion gases (500-600°C) then pass through a HRSG which uses the heat in the gas to produce steam. Steam from the two HRSG's combine to pass through the steam turbine, generating more electricity.

After the HRSG the waste combustion gases are emitted to atmosphere via two 70 metre high stacks at emission points A1 and A2 (one for each turbine).

The purpose of the installation is to generate electricity, with the potential to generate 770 MWe.

Figure 1 Illustration of Electricity Generation Process at Rocksavage Power Station



b) Emission limits

The plant was put into operation before the IED came into force and therefore the existing limits in the permit are from Part 1 of IED Annex V applicable to existing plant.

The emission limit values (ELVs) and AELs are based on unlimited operating hours.

The following tables outline the limits that have been incorporated into the permit for LCP287 and LCP401, where these were derived from and the reference periods at which they apply.

The emission limits refer to concentrations, expressed as mass of emitted substance per volume of flue-gas under the following standard conditions:

- dry gas at a temperature of 273,15 K, pressure of 101,3 kPa and 15% volume reference oxygen concentration in flue gases.

The emission limits and monitoring requirements have been incorporated into Schedule 3 of the permit.

c) Dry low NOx effective (DLN-E)

In their response to our request for further information the operator confirmed the following:

Based on current guidance, DLN-E is the point at which AEL's are achieved, which is equivalent to the stable export limit (SEL). This is based on single unit gas turbine operation.

The lowest MW value at which both NOx and CO emissions come within compliance limits is 165 MW.

The most recent performance test carried out in June 2019 identified the corrected baseload as :

LCP287 – 258 MW

LCP401 – 255 MW

MEAN BASELOAD = 256.5 MW

Proposed DLN-E = $165/256.5 = 64.3\%$ load

We agree with the operator's proposal and have included the parameters in table S1.5 of the permit.

d) BAT Conclusion 42 - LCP287 and LCP401 (CCGT) - (See section 5 below)

NOx emissions

The IED Annex V limits for NOx apply when the load is >70%, this is now when dry low NOx is effective (see above).

The existing permit has provision for low part load operation with higher limits set for when the load varies between MSUL/MSDL and base load during the daily reference period. This existing additional daily limit has been included in the permit to maintain flexibility of the plant required by the operation in low part load.

NOx limits (mg/Nm ³) - corrected to 15% oxygen						
Averaging	IED (Annex V Part 1) - Existing	BREF (Table 24 BAT C)	Expected permit limits from 17 August 2021	Basis	Limits apply	Monitoring
Annual	None	40 ^{Note 1}	40 ^{Note 1}	BREF	E-DLN	Continuous
Monthly	50	None	50	IED	E-DLN	
Daily	55	50 ^{Note 1}	50 ^{Note 1}	BREF	E-DLN	
	(60) ^{Note 2}		(60) ^{Note 2}	IED	MSUL/MSDL	
95 th %ile of hr means	100	None	100	IED	E-DLN	

Note 1: Existing CCGT > 600 MWth with a net total fuel utilisation of < 75 %.

Note 2: Gas turbine emission limit, when the load varies between MSUL/MSDL and base load during the daily reference period.

e) BAT Conclusion 44 – LCP287 and LCP401 (CCGT) – (See section 5 below)

CO indicative emission levels are a yearly average of 30 mg/Nm³. For plants operating at low load, the higher end of this range will be 50 mg/Nm³.

The operator has indicated that limits of 30 mg/Nm³ (during normal operation) and 50 mg/Nm³ (low part load operation) may be achievable; however they have suggested that they need to carry out further checks to confirm this.

The applicable indicative BAT AELs are set out in the table below. We have also added the limits which will be in the varied permit and confirmed the basis for their inclusion.

We have set an improvement condition to ensure compliance with the indicative CO limit or a site specific justification for alternative limits.

The existing permit has provision for low part load operation with higher limits set for when the load varies between MSUL/MSDL and base load during the daily reference period. This existing additional daily limit has been included in the permit to maintain flexibility of the plant required by the operation in low part load.

The existing IED Annex V ELVs remaining unchanged.

CO emissions

CO (indicative) limits (mg/Nm ³) - corrected to 15% oxygen						
Averaging	IED (Annex V Part 1) - Existing	BREF (Table 24 BAT C)	Expected permit limits from 17 August 2021	Basis	Limits apply	Monitoring
Annual	None	30/50	Note 3	BREF	E-DLN	Continuous
Monthly	100	None	100	IED	E-DLN	
Daily	100 Note 1	None	100 Note 1	IED	E-DLN	
	200 Note 2		200 Note 2		MSUL/MSDL	
95 th %ile of hr means	200	None	200	IED	E-DLN	

Note 1: Limit was set lower than the 110 mg/Nm³ Annex V limit on the basis of no backsliding.

Note 2: Low load gas turbine emission limit, when the load varies between MSUL/MSDL and base load during the daily reference period.

Note 3: Limit to be set following completion of the BAT Conclusion 44 improvement condition.

4.2 The energy efficiency levels associated with the BAT Conclusions

An energy efficiency level associated with the BAT AEEL refers to the ratio between the combustion units net energy outputs and the combustion units fuel/feedstock energy input at actual unit design. The net energy outputs are determined at the combustion unit boundaries, including auxiliary systems (e.g. flue-gas treatment systems), and for the units operated at full load.

The table below sets out the BAT AEELs specified in table 23 of BAT Conclusion 40 for the LCPs on the site and the energy efficiency levels confirmed through the regulation 61 notice response and an email received from the Operator 17 April 2020. In this email they confirm that the last performance test was carried out 05 July 2019, at which time the plant efficiency was 49.93%.

This is just marginally below the lower end of the BAT AEEL range of 50%.

BAT AEELs (%)			Plant efficiency (%)		
Net electrical efficiency	Net total fuel utilisation	Net mechanical efficiency	Net electrical efficiency	Net total fuel utilisation	Net mechanical efficiency
LCP287 and LCP401 (CCGT): Existing CCGT, ≥ 600 MWth					
50 - 60	None	None	49.93	NA	NA

We have included a process monitoring requirement in table S3.4 of the consolidated variation notice. This is required to demonstrate that efficiency levels are maintained following any significant overhauls of equipment in order to fulfil the requirement of BAT Conclusion 2.

5 Decision checklist regarding relevant BAT Conclusions

BAT Conclusions for LCP were published by the European Commission on 17 August 2017. There are 75 BAT Conclusions. Only the BAT Conclusions relevant to the particular fuel type used on site have been replicated below..

This annex provides a record of decisions made in relation to each relevant BAT Conclusion applicable to the installation. This annex should be read in conjunction with the consolidated variation notice.

The conditions in the permit through which the relevant BAT Conclusions are implemented include but are not limited to the following:

BAT Conclusion requirement topic	Permit conditions	Permit tables
Environmental Management System	1.1.1	S1.2
BAT AELs	3.1.1 and 3.5.1	S3.1a
Monitoring	2.3, 3.5 and 3.6	S1.2, S1.4, S1.5, S3.1a
Energy efficiency	1.2 and 2.3	S3.4
Noise	3.4 and 2.3	S1.2
Other operating techniques	2.3	S1.2

The overall status of compliance with the BAT conclusion is indicated in the table as:

- NA Not applicable
- CC Currently compliant
- FC Compliant in the future (within 4 years of publication of BAT conclusions)
- NC Not compliant
- PC Partially compliant

BAT C No.	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
General			
1	<p>In order to improve the overall environmental performance, BAT is to implement and adhere to an environmental management system (EMS) that incorporates all of the following features:</p> <ul style="list-style-type: none"> i. commitment of the management, including senior management; ii. definition of an environmental policy that includes the continuous improvement of the installation by the management; iii. planning and establishing the necessary procedures, objectives and targets, in conjunction with financial planning and investment; iv. implementation of procedures <ul style="list-style-type: none"> (a) Structure and responsibility (b) Training (c) Communication (d) Employee involvement (e) Documentation (f) Efficient process control (g) Maintenance programmes (h) Emergency preparedness and response (i) Safeguarding compliance with environmental legislation v. checking performance and taking corrective action, paying particular attention to: <ul style="list-style-type: none"> (a) monitoring and measurement (see also the Reference Document on the General Principles of Monitoring) (b) corrective and preventive action (c) maintenance of records (d) independent (where practicable) internal and external auditing in order to determine whether or not the EMS conforms to planned arrangements and has been properly implemented and maintained; vi. review of the EMS and its continuing suitability, adequacy and effectiveness by senior management; vii. following the development of cleaner technologies; viii. consideration for the environmental impacts from the eventual decommissioning of the installation at the stage of designing a new plant, and throughout its operating life; viii. consideration for the environmental impacts from the eventual decommissioning of the installation at the stage of designing a new plant, and throughout its operating life; 	CC	<p>The operator confirmed that:</p> <p>There is an EMS in place which is maintained in accordance with ISO 14001 standard and it meets requirements (i) through to (xvi) set out in this BAT Conclusion.</p> <p>We agree with the operator's stated compliance.</p>

BAT C No.	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement												
	ix. application of sectoral benchmarking on a regular basis. Etc - see BAT Conclusions Applicability. The scope (e.g. level of detail) and nature of the EMS (e.g. standardised or non-standardised) will generally be related to the nature, scale and complexity of the installation, and the range of environmental impacts it may have.														
2	BAT is to determine the net electrical efficiency and/or the net total fuel utilisation and/or the net mechanical energy efficiency of the gasification, IGCC and/or combustion units by carrying out a performance test at full load (1), according to EN standards, after the commissioning of the unit and after each modification that could significantly affect the net electrical efficiency and/or the net total fuel utilisation and/or the net mechanical energy efficiency of the unit. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.	CC	The operator confirmed that: Performance tests are jointly carried out by the original equipment manufacturer (OEM) and InterGen following every major overhaul or plant upgrade. In addition, bi-annual performance checks are conducted to calculate commercial short run marginal cost (SRMC) and to determine degradation. We agree with the operator's stated compliance.												
3	BAT is to monitor key process parameters relevant for emissions to air and water including those given below. <table border="1" data-bbox="280 890 1106 1136"> <thead> <tr> <th>Stream</th> <th>Parameter(s)</th> <th>Monitoring</th> </tr> </thead> <tbody> <tr> <td rowspan="3">Flue-gas</td> <td>Flow</td> <td>Periodic or continuous determination</td> </tr> <tr> <td>Oxygen content, temperature, and pressure</td> <td rowspan="2">Periodic or continuous measurement</td> </tr> <tr> <td>Water vapour content⁽³⁾</td> </tr> <tr> <td>Waste water from flue-gas treatment</td> <td>Flow, pH, and temperature</td> <td>Continuous measurement</td> </tr> </tbody> </table>	Stream	Parameter(s)	Monitoring	Flue-gas	Flow	Periodic or continuous determination	Oxygen content, temperature, and pressure	Periodic or continuous measurement	Water vapour content ⁽³⁾	Waste water from flue-gas treatment	Flow, pH, and temperature	Continuous measurement	CC	The operator confirmed that: All emissions to air and water are continually monitored. They note that no flue gas treatment is required, therefore no waste water is produced. We agree with the operator's stated compliance.
Stream	Parameter(s)	Monitoring													
Flue-gas	Flow	Periodic or continuous determination													
	Oxygen content, temperature, and pressure	Periodic or continuous measurement													
	Water vapour content ⁽³⁾														
Waste water from flue-gas treatment	Flow, pH, and temperature	Continuous measurement													
4	BAT is to monitor emissions to air with at least the frequency given below and in accordance with EN standards. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality. <table border="1" data-bbox="280 1267 1106 1385"> <thead> <tr> <th>Substance/Parameter</th> <th>Fuel/Process/Type of combustion plant</th> <th>Combustion plant total rated</th> <th>Standard (s)⁽⁴⁾</th> <th>Minimum monitoring frequency⁽⁵⁾</th> <th>Monitoring associated with</th> </tr> </thead> <tbody> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> </tbody> </table>	Substance/Parameter	Fuel/Process/Type of combustion plant	Combustion plant total rated	Standard (s) ⁽⁴⁾	Minimum monitoring frequency ⁽⁵⁾	Monitoring associated with							CC	The operator confirmed that: For each unit the NOx and CO are continuously monitored. The monitoring frequency and standards utilised meet the requirements of BAT42. We agree with the operator's stated compliance.
Substance/Parameter	Fuel/Process/Type of combustion plant	Combustion plant total rated	Standard (s) ⁽⁴⁾	Minimum monitoring frequency ⁽⁵⁾	Monitoring associated with										

BAT C No.	Summary of BAT Conclusion requirement					Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
			thermal input				
NH ₃	— When SCR and/or SNCR is used	All sizes	Generic EN standards	Continuous ₍₇₎	BAT 7		
NO _x	<ul style="list-style-type: none"> — Coal and/or lignite including waste co-incineration — Solid biomass and/or peat including waste co-incineration — HFO- and/or gas-oil-fired boilers and engines — Gas-oil-fired gas turbines — Natural-gas-fired boilers, engines, and turbines — Iron and steel process gases — Process fuels from the chemical industry — IGCC plants 	All sizes	Generic EN standards	Continuous ₍₈₎	BAT 20 BAT 24 BAT 28 BAT 32 BAT 37 BAT 41 BAT 42 BAT 43 BAT 47 BAT 48 BAT 56 BAT 64 BAT 65 BAT 73		
	— Combustion plants on offshore platforms	All sizes	EN 14792	Once every year ₍₉₎	BAT 53		
N ₂ O	<ul style="list-style-type: none"> — Coal and/or lignite in circulating fluidised bed boilers — Solid biomass and/or peat in circulating fluidised bed 	All sizes	EN 21258	Once every year ₍₁₀₎	BAT 20 BAT 24		

BAT C No.	Summary of BAT Conclusion requirement					Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
		boilers					
CO	<ul style="list-style-type: none"> — Coal and/or lignite including waste co-incineration — Solid biomass and/or peat including waste co-incineration — HFO- and/or gas-oil-fired boilers and engines — Gas-oil-fired gas turbines — Natural-gas-fired boilers, engines, and turbines — Iron and steel process gases — Process fuels from the chemical industry — IGCC plants 	All sizes	Generic EN standards	Continuous ₍₉₎ (8)	BAT 20 BAT 24 BAT 28 BAT 33 BAT 38 BAT 44 BAT 49 BAT 56 BAT 64 BAT 65 BAT 73		
	<ul style="list-style-type: none"> — Combustion plants on offshore platforms 	All sizes	EN 15058	Once every year ₍₉₎	BAT 54		
SO ₂	<ul style="list-style-type: none"> — Coal and/or lignite incl waste co-incineration — Solid biomass and/or peat incl waste co-incineration — HFO- and/or gas-oil-fired boilers — HFO- and/or gas-oil-fired engines 	All sizes	Generic EN standards and EN 14791	Continuous ₍₉₎ (1) (12)	BAT 21 BAT 25 BAT 29 BAT 34 BAT 39 BAT 50 BAT 57 BAT 66 BAT 67 BAT 74		

BAT C No.	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	<ul style="list-style-type: none"> — Gas-oil-fired gas turbines — Iron and steel process gases — Process fuels from the chemical industry in boilers — IGCC plants 							
SO ₃	— When SCR is used	All sizes	No EN standard available	Once every year	—			
Gaseous chlorides, expressed as HCl	<ul style="list-style-type: none"> — Coal and/or lignite — Process fuels from the chemical industry in boilers 	All sizes	EN 1911	Once every three months ⁽⁶⁾ ₍₁₃₎ ₍₁₄₎	BAT 21 BAT 57			
	— Solid biomass and/or peat	All sizes	Generic EN standards	Continuous ⁽¹⁵⁾ ₍₁₆₎	BAT 25			
	— Waste co-incineration	All sizes	Generic EN standards	Continuous ⁽⁶⁾ ₍₁₎	BAT 66 BAT 67			
HF	<ul style="list-style-type: none"> — Coal and/or lignite — Process fuels from the chemical industry in boilers 	All sizes	No EN standard available	Once every three months ⁽⁶⁾ ₍₁₃₎ ₍₁₄₎	BAT 21 BAT 57			
	— Solid biomass and/or peat	All sizes	No EN standard available	Once every year	BAT 25			
	— Waste co-incineration	All sizes	Generic EN standards	Continuous ⁽⁶⁾ ₍₁₎	BAT 66 BAT 67			
Dust	<ul style="list-style-type: none"> — Coal and/or lignite 	All sizes	Generic EN standards and EN 13284-1 and	Continuous ⁽⁶⁾ ₍₁₎ ₍₇₎	BAT 22 BAT 26 BAT 30 BAT 35 BAT 39			
	— Solid biomass and/or peat	All sizes	Generic EN standards and EN 13284-1 and	Continuous ⁽⁶⁾ ₍₁₎ ₍₇₎	BAT 22 BAT 26 BAT 30 BAT 35 BAT 39			

BAT C No.	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
		<ul style="list-style-type: none"> — HFO- and/or gas-oil-fired boilers — Iron and steel process gases — Process fuels from the chemical industry in boilers — IGCC plants — HFO- and/or gas-oil-fired engines — Gas-oil-fired gas turbines 		EN 13284-2		BAT 51 BAT 58 BAT 75		
		— Waste co-incineration	All sizes	Generic EN standards and EN 13284-2	Continuous	BAT 68 BAT 69		
	Metals and metalloids except mercury (As, Cd, Co, Cr, Cu, Mn, Ni, Pb, Sb, Se, Tl, V, Zn)	<ul style="list-style-type: none"> — Coal and/or lignite — Solid biomass and/or peat — HFO- and/or gas-oil-fired boilers and engines 	All sizes	EN 14385	Once every year ⁽¹⁸⁾	BAT 22 BAT 26 BAT 30		
		— Waste co-incineration	< 300 MW _{th}	EN 14385	Once every six months ⁽¹³⁾	BAT 68 BAT 69		
			≥ 300 MW _{th}	EN 14385	Once every three months ⁽¹⁹⁾ ⁽¹³⁾			
		— IGCC plants	≥ 100 MW _{th}	EN 14385	Once every year ⁽¹⁸⁾	BAT 75		
	Hg	<ul style="list-style-type: none"> — Coal and/or lignite including waste co-incineration 	< 300 MW _{th}	EN 13211	Once every three months ⁽¹³⁾ ⁽²⁰⁾	BAT 23		
			≥ 300 MW _{th}	Generic EN standards and EN 14884	Continuous ⁽¹⁶⁾ ⁽²¹⁾			
		— Solid biomass	All sizes	EN 13211	Once every	BAT 27		

BAT C No.	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement								
		and/or peat			year ⁽²²⁾											
	—	Waste co-incineration with solid biomass and/or peat	All sizes	EN 13211	Once every three months ⁽¹³⁾	BAT 70										
	—	IGCC plants	≥ 100 MW _{th}	EN 13211	Once every year ⁽²³⁾	BAT 75										
	TVOC	— HFO- and/or gas-oil-fired engines — Process fuels from chemical industry in boilers	All sizes	EN 12619	Once every six months ⁽¹³⁾	BAT 33 BAT 59										
	—	Waste co-incineration with coal, lignite, solid biomass and/or peat	All sizes	Generic EN standards	Continuous	BAT 71										
	Formaldehyde	— Natural-gas in spark-ignited lean-burn gas and dual fuel engines	All sizes	No EN standard available	Once every year	BAT 45										
	CH ₄	— Natural-gas-fired engines	All sizes	EN ISO 25139	Once every year ⁽²⁴⁾	BAT 45										
	PCDD/F	— Process fuels from chemical industry in boilers — Waste co-incineration	All sizes	EN 1948-1, EN 1948-2, EN 1948-3	Once every six months ⁽¹³⁾ ⁽²⁵⁾	BAT 59 BAT 71										
5	<p>BAT is to monitor emissions to water from flue-gas treatment with at least the frequency given below and in accordance with EN standards. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.</p> <table border="1" data-bbox="286 1305 1099 1369"> <thead> <tr> <th data-bbox="286 1305 524 1369">Substance/Parameter</th> <th data-bbox="524 1305 775 1369">Standard(s)</th> <th data-bbox="775 1305 943 1369">Minimum monitoring</th> <th data-bbox="943 1305 1099 1369">Monitoring associated</th> </tr> </thead> <tbody> <tr> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>						Substance/Parameter	Standard(s)	Minimum monitoring	Monitoring associated					NA	<p>The operator confirmed that:</p> <p>This is a gas turbine powered facility with no flue gas treatment and as such this BAT Conclusion is not applicable.</p> <p>We agree that this BAT Conclusion is not applicable to the activities carried out at the installation.</p>
Substance/Parameter	Standard(s)	Minimum monitoring	Monitoring associated													

BAT C No.	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																																									
	<table border="1"> <thead> <tr> <th></th> <th>frequency</th> <th>with</th> </tr> </thead> <tbody> <tr> <td>Total organic carbon (TOC)₍₂₆₎</td> <td>Once every month</td> <td>BAT 15</td> </tr> <tr> <td>Chemical oxygen demand (COD)₍₂₆₎</td> <td></td> <td></td> </tr> <tr> <td>Total suspended solids (TSS)</td> <td></td> <td></td> </tr> <tr> <td>Fluoride (F⁻)</td> <td></td> <td></td> </tr> <tr> <td>Sulphate (SO₄²⁻)</td> <td></td> <td></td> </tr> <tr> <td>Sulphide, easily released (S²⁻)</td> <td></td> <td></td> </tr> <tr> <td>Sulphite (SO₃²⁻)</td> <td></td> <td></td> </tr> <tr> <td rowspan="8">Metals and metalloids</td> <td>As</td> <td rowspan="8">Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)</td> </tr> <tr> <td>Cd</td> </tr> <tr> <td>Cr</td> </tr> <tr> <td>Cu</td> </tr> <tr> <td>Ni</td> </tr> <tr> <td>Pb</td> </tr> <tr> <td>Zn</td> </tr> <tr> <td>Hg</td> <td>Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)</td> </tr> <tr> <td>Chloride (Cl⁻)</td> <td>Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)</td> <td>—</td> </tr> <tr> <td>Total nitrogen</td> <td>EN 12260</td> <td>—</td> </tr> </tbody> </table>		frequency	with	Total organic carbon (TOC) ₍₂₆₎	Once every month	BAT 15	Chemical oxygen demand (COD) ₍₂₆₎			Total suspended solids (TSS)			Fluoride (F ⁻)			Sulphate (SO ₄ ²⁻)			Sulphide, easily released (S ²⁻)			Sulphite (SO ₃ ²⁻)			Metals and metalloids	As	Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)	Cd	Cr	Cu	Ni	Pb	Zn	Hg	Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)	Chloride (Cl ⁻)	Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)	—	Total nitrogen	EN 12260	—	<p>EN 1484</p> <p>No EN standard available</p> <p>EN 872</p> <p>EN ISO 10304-1</p> <p>EN ISO 10304-1</p> <p>No EN standard available</p> <p>EN ISO 10304-3</p> <p>Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)</p> <p>Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)</p> <p>Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)</p> <p>EN 12260</p>			
	frequency	with																																												
Total organic carbon (TOC) ₍₂₆₎	Once every month	BAT 15																																												
Chemical oxygen demand (COD) ₍₂₆₎																																														
Total suspended solids (TSS)																																														
Fluoride (F ⁻)																																														
Sulphate (SO ₄ ²⁻)																																														
Sulphide, easily released (S ²⁻)																																														
Sulphite (SO ₃ ²⁻)																																														
Metals and metalloids	As	Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)																																												
	Cd																																													
	Cr																																													
	Cu																																													
	Ni																																													
	Pb																																													
	Zn																																													
	Hg		Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)																																											
Chloride (Cl ⁻)	Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)	—																																												
Total nitrogen	EN 12260	—																																												
6	<p>In order to improve the general environmental performance of combustion plants and to reduce emissions to air of CO and unburnt substances, BAT is to ensure optimised combustion and to use an appropriate combination of the techniques given below.</p> <table border="1"> <thead> <tr> <th>Technique</th> <th>Description</th> <th>Applicability</th> </tr> </thead> <tbody> <tr> <td></td> <td></td> <td></td> </tr> </tbody> </table>			Technique	Description	Applicability				CC	<p>The operator confirmed that:</p> <p>The following techniques are applied:</p> <p>b - maintenance of the combustion system</p>																																			
Technique	Description	Applicability																																												

BAT C No.	Summary of BAT Conclusion requirement				Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	a	Fuel blending and mixing	Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type	Generally applicable		c - advanced control system d - combustion equipment design e - low sulphur natural gas We agree with the operator's stated compliance.
b	Maintenance of the combustion system	Regular planned maintenance according to suppliers' recommendations				
c	Advanced control system	See description in Section 8.1	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system			
d	Good design of the combustion equipment	Good design of furnace, combustion chambers, burners and associated devices	Generally applicable to new combustion plants			
e	Fuel choice	Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used	Applicable within the constraints associated with the availability of suitable types of fuel with a better environmental profile as a whole, which may be impacted by the energy policy of the Member State, or by the integrated site's fuel balance in the case of combustion of industrial process fuels. For existing combustion plants, the type of fuel chosen may be limited by the configuration and the design of the plant			

BAT C No.	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
7	<p>In order to reduce emissions of ammonia to air from the use of selective catalytic reduction (SCR) and/or selective non-catalytic reduction (SNCR) for the abatement of NO_x emissions, BAT is to optimise the design and/or operation of SCR and/or SNCR (e.g. optimised reagent to NO_x ratio, homogeneous reagent distribution and optimum size of the reagent drops).</p> <p>BAT-associated emission levels</p> <p>The BAT-associated emission level (BAT-AEL) for emissions of NH₃ to air from the use of SCR and/or SNCR is < 3–10 mg/Nm³ as a yearly average or average over the sampling period. The lower end of the range can be achieved when using SCR and the upper end of the range can be achieved when using SNCR without wet abatement techniques. In the case of plants combusting biomass and operating at variable loads as well as in the case of engines combusting HFO and/or gas oil, the higher end of the BAT-AEL range is 15 mg/Nm³.</p>	NA	<p>The operator confirmed that:</p> <p>This is a gas turbine powered facility, no SCR or SNCR fitted and as such this BAT Conclusion is not applicable.</p> <p>We agree that this BAT Conclusion is not applicable to the activities carried out at the installation.</p>
8	<p>In order to prevent or reduce emissions to air during normal operating conditions, BAT is to ensure, by appropriate design, operation and maintenance, that the emission abatement systems are used at optimal capacity and availability.</p>	CC	<p>The operator confirmed that:</p> <p>The design of the gas turbine utilising low NO_x burners ensures that emissions to air are maintained within permit requirements. In addition, maintenance is undertaken in accordance with OEM guidelines to ensure that turbine efficiency and emissions limits are maintained.</p> <p>We agree with the operator's stated compliance.</p>
9	<p>In order to improve the general environmental performance of combustion and/or gasification plants and to reduce emissions to air, BAT is to include the following elements in the quality assurance/quality control programmes for all the fuels used, as part of the environmental management system (see BAT 1):</p> <ul style="list-style-type: none"> (i) Initial full characterisation of the fuel used including at least the parameters listed below and in accordance with EN standards. ISO, national or other international standards may be used provided they ensure the provision of data of an equivalent scientific quality; (ii) Regular testing of the fuel quality to check that it is consistent with the initial characterisation and according to the plant design specifications. The frequency of testing and the parameters chosen from the table below are based on the variability of the fuel and an assessment of the relevance of pollutant releases (e.g. concentration in fuel, flue-gas treatment employed); 	CC	<p>The operator confirmed that:</p> <p>Characterisation of the fuel is continually provided by the fuel supplier. In addition the turbines utilise fuel flexibility technology to optimise the combustion process and reduce emissions.</p> <p>We consider that for plants which burn natural gas from the National Grid as a fuel, it is not necessary for the operator to replicate the testing carried out by the National Grid.</p> <p>We agree with the operator's stated compliance.</p>

BAT C No.	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																							
	<p>(iii) Subsequent adjustment of the plant settings as and when needed and practicable (e.g. integration of the fuel characterisation and control in the advanced control system (see description in Section 8.1)).</p> <p>Description Initial characterisation and regular testing of the fuel can be performed by the operator and/or the fuel supplier. If performed by the supplier, the full results are provided to the operator in the form of a product (fuel) supplier specification and/or guarantee.</p> <table border="1" data-bbox="280 555 1106 1385"> <thead> <tr> <th data-bbox="280 555 555 612">Fuel(s)</th> <th data-bbox="555 555 1106 612">Substances/Parameters subject to characterisation</th> </tr> </thead> <tbody> <tr> <td data-bbox="280 612 555 842" rowspan="4">Biomass/peat</td> <td data-bbox="555 612 1106 654">— LHV</td> </tr> <tr> <td data-bbox="555 654 1106 695">— moisture</td> </tr> <tr> <td data-bbox="555 695 1106 737">— Ash</td> </tr> <tr> <td data-bbox="555 737 1106 842">— C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn)</td> </tr> <tr> <td data-bbox="280 842 555 1072" rowspan="4">Coal/lignite</td> <td data-bbox="555 842 1106 884">— LHV</td> </tr> <tr> <td data-bbox="555 884 1106 925">— Moisture</td> </tr> <tr> <td data-bbox="555 925 1106 967">— Volatiles, ash, fixed carbon, C, H, N, O, S</td> </tr> <tr> <td data-bbox="555 967 1106 1072">— Br, Cl, F — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)</td> </tr> <tr> <td data-bbox="280 1072 555 1161" rowspan="2">HFO</td> <td data-bbox="555 1072 1106 1117">— Ash</td> </tr> <tr> <td data-bbox="555 1117 1106 1161">— C, S, N, Ni, V</td> </tr> <tr> <td data-bbox="280 1161 555 1251" rowspan="2">Gas oil</td> <td data-bbox="555 1161 1106 1203">— Ash</td> </tr> <tr> <td data-bbox="555 1203 1106 1251">— N, C, S</td> </tr> <tr> <td data-bbox="280 1251 555 1337" rowspan="2">Natural gas</td> <td data-bbox="555 1251 1106 1292">— LHV</td> </tr> <tr> <td data-bbox="555 1292 1106 1337">— CH₄, C₂H₆, C₃, C₄₊, CO₂, N₂, Wobbe index</td> </tr> <tr> <td data-bbox="280 1337 555 1385">Process fuels from the chemical industry ⁽²⁷⁾</td> <td data-bbox="555 1337 1106 1385">— Br, C, Cl, F, H, N, O, S</td> </tr> </tbody> </table>	Fuel(s)	Substances/Parameters subject to characterisation	Biomass/peat	— LHV	— moisture	— Ash	— C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn)	Coal/lignite	— LHV	— Moisture	— Volatiles, ash, fixed carbon, C, H, N, O, S	— Br, Cl, F — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)	HFO	— Ash	— C, S, N, Ni, V	Gas oil	— Ash	— N, C, S	Natural gas	— LHV	— CH ₄ , C ₂ H ₆ , C ₃ , C ₄₊ , CO ₂ , N ₂ , Wobbe index	Process fuels from the chemical industry ⁽²⁷⁾	— Br, C, Cl, F, H, N, O, S		
Fuel(s)	Substances/Parameters subject to characterisation																									
Biomass/peat	— LHV																									
	— moisture																									
	— Ash																									
	— C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn)																									
Coal/lignite	— LHV																									
	— Moisture																									
	— Volatiles, ash, fixed carbon, C, H, N, O, S																									
	— Br, Cl, F — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)																									
HFO	— Ash																									
	— C, S, N, Ni, V																									
Gas oil	— Ash																									
	— N, C, S																									
Natural gas	— LHV																									
	— CH ₄ , C ₂ H ₆ , C ₃ , C ₄₊ , CO ₂ , N ₂ , Wobbe index																									
Process fuels from the chemical industry ⁽²⁷⁾	— Br, C, Cl, F, H, N, O, S																									

BAT C No.	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement						
	<table border="1"> <tr> <td data-bbox="280 330 555 400"></td> <td data-bbox="555 330 1106 400"> <ul style="list-style-type: none"> — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) </td> </tr> <tr> <td data-bbox="280 400 555 470">Iron and steel process gases</td> <td data-bbox="555 400 1106 470"> <ul style="list-style-type: none"> — LHV, CH₄ (for COG), C_xH_y (for COG), CO₂, H₂, N₂, total sulphur, dust, Wobbe index </td> </tr> <tr> <td data-bbox="280 470 555 654">Waste⁽²⁸⁾</td> <td data-bbox="555 470 1106 654"> <ul style="list-style-type: none"> — LHV — Moisture — Volatiles, ash, Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) </td> </tr> </table>		<ul style="list-style-type: none"> — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) 	Iron and steel process gases	<ul style="list-style-type: none"> — LHV, CH₄ (for COG), C_xH_y (for COG), CO₂, H₂, N₂, total sulphur, dust, Wobbe index 	Waste ⁽²⁸⁾	<ul style="list-style-type: none"> — LHV — Moisture — Volatiles, ash, Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) 		
	<ul style="list-style-type: none"> — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) 								
Iron and steel process gases	<ul style="list-style-type: none"> — LHV, CH₄ (for COG), C_xH_y (for COG), CO₂, H₂, N₂, total sulphur, dust, Wobbe index 								
Waste ⁽²⁸⁾	<ul style="list-style-type: none"> — LHV — Moisture — Volatiles, ash, Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) 								
10	<p>In order to reduce emissions to air and/or to water during other than normal operating conditions (OTNOC), BAT is to set up and implement a management plan as part of the environmental management system (see BAT 1), commensurate with the relevance of potential pollutant releases, that includes the following elements:</p> <ul style="list-style-type: none"> — appropriate design of the systems considered relevant in causing OTNOC that may have an impact on emissions to air, water and/or soil (e.g. low-load design concepts for reducing the minimum start-up and shutdown loads for stable generation in gas turbines), — set-up and implementation of a specific preventive maintenance plan for these relevant systems, — review and recording of emissions caused by OTNOC and associated circumstances and implementation of corrective actions if necessary, — periodic assessment of the overall emissions during OTNOC (e.g. frequency of events, duration, emissions quantification/estimation) and implementation of corrective actions if necessary. 	CC	<p>The operator confirmed that:</p> <p>A 'low part load' upgrade fitted to both units during the 2018 major outage enable the turbines to be operated at lower loads without any adverse impact on emissions to air. We have incorporated operating techniques for low part load operation into table S1.2 of the permit.</p> <p>Emissions to water/soil are not impacted during periods of OTNOC operation. In addition, automated software protection is deployed to prevent exceedances of emissions to air during frequency response provision.</p> <p>We agree with the operator's stated compliance.</p>						
11	<p>BAT is to appropriately monitor emissions to air and/or to water during OTNOC.</p> <p>Description</p> <p>The monitoring can be carried out by direct measurement of emissions or by monitoring of surrogate parameters if this proves to be of equal or better scientific quality than the direct measurement of emissions. Emissions during start-up and shutdown (SU/SD) may be assessed based on a detailed emission measurement carried out for a typical SU/SD procedure at least</p>	CC	<p>The operator confirmed that:</p> <p>All parameters for emissions to air are continually monitored during periods of OTNOC operation including start-ups and shut-downs.</p> <p>We agree with the operator's stated compliance.</p>						

BAT C No.	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																								
	once every year, and using the results of this measurement to estimate the emissions for each and every SU/SD throughout the year.																										
12	<p>In order to increase the energy efficiency of combustion, gasification and/or IGCC units operated $\geq 1\,500$ h/yr, BAT is to use an appropriate combination of the techniques given below.</p> <table border="1" data-bbox="277 485 1102 1374"> <thead> <tr> <th data-bbox="277 485 465 517">Technique</th> <th data-bbox="465 485 797 517">Description</th> <th data-bbox="797 485 1102 517">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="277 517 465 651">a. Combustion optimisation</td> <td data-bbox="465 517 797 651">See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues</td> <td data-bbox="797 517 1102 651">Generally applicable</td> </tr> <tr> <td data-bbox="277 651 465 858">b. Optimisation of the working medium conditions</td> <td data-bbox="465 651 797 858">Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO_x emissions or the characteristics of energy demanded</td> <td data-bbox="797 651 1102 858"></td> </tr> <tr> <td data-bbox="277 858 465 992">c. Optimisation of the steam cycle</td> <td data-bbox="465 858 797 992">Operate with lower turbine exhaust pressure by utilisation of the lowest possible temperature of the condenser cooling water, within the design conditions</td> <td data-bbox="797 858 1102 992"></td> </tr> <tr> <td data-bbox="277 992 465 1104">d. Minimisation of energy consumption</td> <td data-bbox="465 992 797 1104">Minimising the internal energy consumption (e.g. greater efficiency of the feed-water pump)</td> <td data-bbox="797 992 1102 1104"></td> </tr> <tr> <td data-bbox="277 1104 465 1209">e. Preheating of combustion air</td> <td data-bbox="465 1104 797 1209">Reuse of part of the heat recovered from the combustion flue-gas to preheat the air used in combustion</td> <td data-bbox="797 1104 1102 1209">Generally applicable within the constraints related to the need to control NO_x emissions</td> </tr> <tr> <td data-bbox="277 1209 465 1321">f. Fuel preheating</td> <td data-bbox="465 1209 797 1321">Preheating of fuel using recovered heat</td> <td data-bbox="797 1209 1102 1321">Generally applicable within the constraints associated with the boiler design and the need to control NO_x emissions</td> </tr> <tr> <td data-bbox="277 1321 465 1374">g. Advanced control</td> <td data-bbox="465 1321 797 1374">See description in Section 8.2. Computerised control of the main</td> <td data-bbox="797 1321 1102 1374">Generally applicable to new units. The applicability to old</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Combustion optimisation	See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues	Generally applicable	b. Optimisation of the working medium conditions	Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO _x emissions or the characteristics of energy demanded		c. Optimisation of the steam cycle	Operate with lower turbine exhaust pressure by utilisation of the lowest possible temperature of the condenser cooling water, within the design conditions		d. Minimisation of energy consumption	Minimising the internal energy consumption (e.g. greater efficiency of the feed-water pump)		e. Preheating of combustion air	Reuse of part of the heat recovered from the combustion flue-gas to preheat the air used in combustion	Generally applicable within the constraints related to the need to control NO _x emissions	f. Fuel preheating	Preheating of fuel using recovered heat	Generally applicable within the constraints associated with the boiler design and the need to control NO _x emissions	g. Advanced control	See description in Section 8.2. Computerised control of the main	Generally applicable to new units. The applicability to old	CC	<p>The operator confirmed that:</p> <ul style="list-style-type: none"> a. Use of a high performance monitoring and an advanced combustion optimisation system. b. Operation at the highest possible temperatures and pressures giving due regard to NO_x emissions. c. Equipment utilises an evaporative condenser under vacuum to optimise steam turbine efficiency. d. Utilisation of variable speed drives. e. Not applicable to gas turbine plant. f. Pre-heating with heat recovered from feed water/steam is utilised. g. The gas turbines utilise a computer based control system incorporating high performance monitoring. h. The HRSGs are fitted with feed-water heaters/economisers. i. CHP is not applicable due to age of plant and local constraints. j. CHP is not applicable due to age of plant and local constraints. k. CHP is not applicable due to age of plant and local constraints. l. CHP is not applicable due to age of plant and local constraints. m. Not applicable, no FGD. n. Not applicable, no FGD. o. Not applicable, natural gas fuelled. p. Not applicable, natural gas fuelled. q. Not applicable. r. High Temperature and pressure steam used & cascade by-pass system utilised during start-ups. s. Not applicable to gas turbine. <p>We agree with the operator's stated compliance.</p>
Technique	Description	Applicability																									
a. Combustion optimisation	See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues	Generally applicable																									
b. Optimisation of the working medium conditions	Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO _x emissions or the characteristics of energy demanded																										
c. Optimisation of the steam cycle	Operate with lower turbine exhaust pressure by utilisation of the lowest possible temperature of the condenser cooling water, within the design conditions																										
d. Minimisation of energy consumption	Minimising the internal energy consumption (e.g. greater efficiency of the feed-water pump)																										
e. Preheating of combustion air	Reuse of part of the heat recovered from the combustion flue-gas to preheat the air used in combustion	Generally applicable within the constraints related to the need to control NO _x emissions																									
f. Fuel preheating	Preheating of fuel using recovered heat	Generally applicable within the constraints associated with the boiler design and the need to control NO _x emissions																									
g. Advanced control	See description in Section 8.2. Computerised control of the main	Generally applicable to new units. The applicability to old																									

BAT C No.	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	system	combustion parameters enables the combustion efficiency to be improved	units may be constrained by the need to retrofit the combustion system and/or control command system		
h.	Feed-water preheating using recovered heat	Preheat water coming out of the steam condenser with recovered heat, before reusing it in the boiler	Only applicable to steam circuits and not to hot boilers. Applicability to existing units may be limited due to constraints associated with the plant configuration and the amount of recoverable heat		
i.	Heat recovery by cogeneration (CHP)	Recovery of heat (mainly from the steam system) for producing hot water/steam to be used in industrial processes/activities or in a public network for district heating. Additional heat recovery is possible from: — flue-gas — grate cooling — circulating fluidised bed	Applicable within the constraints associated with the local heat and power demand. The applicability may be limited in the case of gas compressors with an unpredictable operational heat profile		
j.	CHP readiness	See description in Section 8.2.	Only applicable to new units where there is a realistic potential for the future use of heat in the vicinity of the unit		
k.	Flue-gas condenser	See description in Section 8.2.	Generally applicable to CHP units provided there is enough demand for low-temperature heat		
l.	Heat accumulation	Heat accumulation storage in CHP mode	Only applicable to CHP plants. The applicability may be limited in the case of low heat load demand		
m	Wet stack	See description in Section 8.2.	Generally applicable to new and existing units fitted with wet FGD		
n.	Cooling tower	The release of emissions to air	Only applicable to units fitted		

BAT C No.	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	discharge	through a cooling tower and not via a dedicated stack	with wet FGD where reheating of the flue-gas is necessary before release, and where the unit cooling system is a cooling tower		
	o. Fuel pre-drying	The reduction of fuel moisture content before combustion to improve combustion conditions	Applicable to the combustion of biomass and/or peat within the constraints associated with spontaneous combustion risks (e.g. the moisture content of peat is kept above 40 % throughout the delivery chain). The retrofit of existing plants may be restricted by the extra calorific value that can be obtained from the drying operation and by the limited retrofit possibilities offered by some boiler designs or plant configurations		
	p. Minimisation of heat losses	Minimising residual heat losses, e.g. those that occur via the slag or those that can be reduced by insulating radiating sources	Only applicable to solid-fuel-fired combustion units and to gasification/IGCC units		
	q. Advanced materials	Use of advanced materials proven to be capable of withstanding high operating temperatures and pressures and thus to achieve increased steam/combustion process efficiencies	Only applicable to new plants		
	r. Steam turbine upgrades	This includes techniques such as increasing the temperature and pressure of medium-pressure steam, addition of a low-pressure turbine, and modifications to the geometry of the turbine rotor blades	The applicability may be restricted by demand, steam conditions and/or limited plant lifetime		
	s. Supercritical	Use of a steam circuit, including	Only applicable to new units		

BAT C No.	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement									
		and ultra-supercritical steam conditions	steam reheating systems, in which steam can reach pressures above 220,6 bar and temperatures above 374 °C in the case of supercritical conditions, and above 250 – 300 bar and temperatures above 580 – 600 °C in the case of ultra-supercritical conditions	of ≥ 600 MW _{th} operated > 4 000 h/yr. Not applicable when the purpose of the unit is to produce low steam temperatures and/or pressures in process industries. Not applicable to gas turbines and engines generating steam in CHP mode. For units combusting biomass, the applicability may be constrained by high-temperature corrosion in the case of certain biomasses										
13	In order to reduce water usage and the volume of contaminated waste water discharged, BAT is to use one or both of the techniques given below.			CC	The operator confirmed that: a. Boiler water blow-down is diverted to the cooling tower basin to reduce discharges to waste water. b. Not applicable as natural gas fuel plant. We agree with the operator's stated compliance.									
14	<table border="1" data-bbox="271 807 1111 1217"> <thead> <tr> <th data-bbox="271 807 315 871">Technique</th> <th data-bbox="315 807 797 871">Description</th> <th data-bbox="797 807 1111 871">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="271 871 315 1050">a</td> <td data-bbox="315 871 797 1050">Water recycling Residual aqueous streams, including run-off water, from the plant are reused for other purposes. The degree of recycling is limited by the quality requirements of the recipient water stream and the water balance of the plant</td> <td data-bbox="797 871 1111 1050">Not applicable to waste water from cooling systems when water treatment chemicals and/or high concentrations of salts from seawater are present</td> </tr> <tr> <td data-bbox="271 1050 315 1217">b</td> <td data-bbox="315 1050 797 1217">Dry bottom ash handling Dry, hot bottom ash falls from the furnace onto a mechanical conveyor system and is cooled down by ambient air. No water is used in the process.</td> <td data-bbox="797 1050 1111 1217">Only applicable to plants combusting solid fuels. There may be technical restrictions that prevent retrofitting to existing combustion plants</td> </tr> </tbody> </table> <p data-bbox="271 1217 1111 1398">In order to prevent the contamination of uncontaminated waste water and to reduce emissions to water, BAT is to segregate waste water streams and to treat them separately, depending on the pollutant content. Description Waste water streams that are typically segregated and treated include surface run-off water, cooling water, and waste water from flue-gas</p>			Technique	Description	Applicability	a	Water recycling Residual aqueous streams, including run-off water, from the plant are reused for other purposes. The degree of recycling is limited by the quality requirements of the recipient water stream and the water balance of the plant	Not applicable to waste water from cooling systems when water treatment chemicals and/or high concentrations of salts from seawater are present	b	Dry bottom ash handling Dry, hot bottom ash falls from the furnace onto a mechanical conveyor system and is cooled down by ambient air. No water is used in the process.	Only applicable to plants combusting solid fuels. There may be technical restrictions that prevent retrofitting to existing combustion plants	CC	The operator confirmed that: Process water is segregated from surface water and continuously monitored with control systems in place to reduce emissions to waste water.
Technique	Description	Applicability												
a	Water recycling Residual aqueous streams, including run-off water, from the plant are reused for other purposes. The degree of recycling is limited by the quality requirements of the recipient water stream and the water balance of the plant	Not applicable to waste water from cooling systems when water treatment chemicals and/or high concentrations of salts from seawater are present												
b	Dry bottom ash handling Dry, hot bottom ash falls from the furnace onto a mechanical conveyor system and is cooled down by ambient air. No water is used in the process.	Only applicable to plants combusting solid fuels. There may be technical restrictions that prevent retrofitting to existing combustion plants												

BAT C No.	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																														
	treatment. Applicability The applicability may be restricted in the case of existing plants due to the configuration of the drainage systems.		We agree with the operator's stated compliance.																														
15	In order to reduce emissions to water from flue-gas treatment, BAT is to use an appropriate combination of the techniques given below, and to use secondary techniques as close as possible to the source in order to avoid dilution. <table border="1" data-bbox="280 568 1099 1390"> <thead> <tr> <th data-bbox="280 568 555 655">Technique</th> <th data-bbox="555 568 775 655">Typical pollutants prevented/abated</th> <th data-bbox="775 568 1099 655">Applicability</th> </tr> </thead> <tbody> <tr> <td colspan="3" data-bbox="280 655 1099 687" style="text-align: center;">Primary techniques</td> </tr> <tr> <td data-bbox="280 687 555 823">a. Optimised combustion (see BAT 6) and flue-gas treatment systems (e.g. SCR/SNCR, see BAT 7)</td> <td data-bbox="555 687 775 823">Organic compounds, ammonia (NH₃)</td> <td data-bbox="775 687 1099 823">Generally applicable</td> </tr> <tr> <td colspan="3" data-bbox="280 823 1099 855" style="text-align: center;">Secondary techniques ⁽²⁹⁾</td> </tr> <tr> <td data-bbox="280 855 555 919">b. Adsorption on activated carbon</td> <td data-bbox="555 855 775 919">Organic compounds, mercury (Hg)</td> <td data-bbox="775 855 1099 919">Generally applicable</td> </tr> <tr> <td data-bbox="280 919 555 1102">c. Aerobic biological treatment</td> <td data-bbox="555 919 775 1102">Biodegradable organic compounds, ammonium (NH₄⁺)</td> <td data-bbox="775 919 1099 1102">Generally applicable for the treatment of organic compounds. Aerobic biological treatment of ammonium (NH₄⁺) may not be applicable in the case of high chloride concentrations (i.e. around 10 g/l)</td> </tr> <tr> <td data-bbox="280 1102 555 1158">d. Anoxic/anaerobic biological treatment</td> <td data-bbox="555 1102 775 1158">Mercury (Hg), nitrate (NO₃⁻), nitrite (NO₂⁻)</td> <td data-bbox="775 1102 1099 1158">Generally applicable</td> </tr> <tr> <td data-bbox="280 1158 555 1214">e. Coagulation and flocculation</td> <td data-bbox="555 1158 775 1214">Suspended solids</td> <td data-bbox="775 1158 1099 1214">Generally applicable</td> </tr> <tr> <td data-bbox="280 1214 555 1302">f. Crystallisation</td> <td data-bbox="555 1214 775 1302">Metals and metalloids, sulphate (SO₄²⁻), fluoride (F⁻)</td> <td data-bbox="775 1214 1099 1302">Generally applicable</td> </tr> <tr> <td data-bbox="280 1302 555 1390">g. Filtration (e.g. sand filtration, microfiltration, ultrafiltration)</td> <td data-bbox="555 1302 775 1390">Suspended solids, metals</td> <td data-bbox="775 1302 1099 1390">Generally applicable</td> </tr> </tbody> </table>	Technique	Typical pollutants prevented/abated	Applicability	Primary techniques			a. Optimised combustion (see BAT 6) and flue-gas treatment systems (e.g. SCR/SNCR, see BAT 7)	Organic compounds, ammonia (NH ₃)	Generally applicable	Secondary techniques ⁽²⁹⁾			b. Adsorption on activated carbon	Organic compounds, mercury (Hg)	Generally applicable	c. Aerobic biological treatment	Biodegradable organic compounds, ammonium (NH ₄ ⁺)	Generally applicable for the treatment of organic compounds. Aerobic biological treatment of ammonium (NH ₄ ⁺) may not be applicable in the case of high chloride concentrations (i.e. around 10 g/l)	d. Anoxic/anaerobic biological treatment	Mercury (Hg), nitrate (NO ₃ ⁻), nitrite (NO ₂ ⁻)	Generally applicable	e. Coagulation and flocculation	Suspended solids	Generally applicable	f. Crystallisation	Metals and metalloids, sulphate (SO ₄ ²⁻), fluoride (F ⁻)	Generally applicable	g. Filtration (e.g. sand filtration, microfiltration, ultrafiltration)	Suspended solids, metals	Generally applicable	NA	The operator confirmed that: This is a gas turbine powered facility with no flue gas treatment. We agree that this BAT Conclusion is not applicable to the activities carried out at the installation.
Technique	Typical pollutants prevented/abated	Applicability																															
Primary techniques																																	
a. Optimised combustion (see BAT 6) and flue-gas treatment systems (e.g. SCR/SNCR, see BAT 7)	Organic compounds, ammonia (NH ₃)	Generally applicable																															
Secondary techniques ⁽²⁹⁾																																	
b. Adsorption on activated carbon	Organic compounds, mercury (Hg)	Generally applicable																															
c. Aerobic biological treatment	Biodegradable organic compounds, ammonium (NH ₄ ⁺)	Generally applicable for the treatment of organic compounds. Aerobic biological treatment of ammonium (NH ₄ ⁺) may not be applicable in the case of high chloride concentrations (i.e. around 10 g/l)																															
d. Anoxic/anaerobic biological treatment	Mercury (Hg), nitrate (NO ₃ ⁻), nitrite (NO ₂ ⁻)	Generally applicable																															
e. Coagulation and flocculation	Suspended solids	Generally applicable																															
f. Crystallisation	Metals and metalloids, sulphate (SO ₄ ²⁻), fluoride (F ⁻)	Generally applicable																															
g. Filtration (e.g. sand filtration, microfiltration, ultrafiltration)	Suspended solids, metals	Generally applicable																															

BAT C No.	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																																										
	h.	Flotation	Suspended solids, free oil	Generally applicable																																											
	i.	Ion exchange	Metals	Generally applicable																																											
	j.	Neutralisation	Acids, alkalis	Generally applicable																																											
	k.	Oxidation	Sulphide (S ²⁻), sulphite (SO ₃ ²⁻)	Generally applicable																																											
	l.	Precipitation	Metals and metalloids, sulphate (SO ₄ ²⁻), fluoride (F ⁻)	Generally applicable																																											
	m	Sedimentation	Suspended solids	Generally applicable																																											
	n.	Stripping	Ammonia (NH ₃)	Generally applicable																																											
	<p>The BAT-AELs refer to direct discharges to a receiving water body at the point where the emission leaves the installation.</p> <p>BAT-AELs for direct discharges to a receiving water body from flue-gas treatment</p> <table border="1" data-bbox="280 810 1099 1366"> <thead> <tr> <th colspan="2" data-bbox="280 810 741 879">Substance/Parameter</th> <th data-bbox="741 810 1099 879">BAT-AELs</th> </tr> <tr> <th colspan="2"></th> <th data-bbox="741 847 1099 879">Daily average</th> </tr> </thead> <tbody> <tr> <td colspan="2">Total organic carbon (TOC)</td> <td>20–50 mg/l ⁽³⁰⁾ ⁽³¹⁾ ⁽³²⁾</td> </tr> <tr> <td colspan="2">Chemical oxygen demand (COD)</td> <td>60–150 mg/l ⁽³⁰⁾ ⁽³¹⁾ ⁽³²⁾</td> </tr> <tr> <td colspan="2">Total suspended solids (TSS)</td> <td>10–30 mg/l</td> </tr> <tr> <td colspan="2">Fluoride (F⁻)</td> <td>10–25 mg/l ⁽³²⁾</td> </tr> <tr> <td colspan="2">Sulphate (SO₄²⁻)</td> <td>1,3–2,0 g/l ⁽³²⁾ ⁽³³⁾ ⁽³⁴⁾ ⁽³⁵⁾</td> </tr> <tr> <td colspan="2">Sulphide (S²⁻), easily released</td> <td>0,1–0,2 mg/l ⁽³²⁾</td> </tr> <tr> <td colspan="2">Sulphite (SO₃²⁻)</td> <td>1–20 mg/l ⁽³²⁾</td> </tr> <tr> <td rowspan="7">Metals and metalloids</td> <td>As</td> <td>10–50 µg/l</td> </tr> <tr> <td>Cd</td> <td>2–5 µg/l</td> </tr> <tr> <td>Cr</td> <td>10–50 µg/l</td> </tr> <tr> <td>Cu</td> <td>10–50 µg/l</td> </tr> <tr> <td>Hg</td> <td>0,2–3 µg/l</td> </tr> <tr> <td>Ni</td> <td>10–50 µg/l</td> </tr> <tr> <td>Pb</td> <td>10–20 µg/l</td> </tr> </tbody> </table>					Substance/Parameter		BAT-AELs			Daily average	Total organic carbon (TOC)		20–50 mg/l ⁽³⁰⁾ ⁽³¹⁾ ⁽³²⁾	Chemical oxygen demand (COD)		60–150 mg/l ⁽³⁰⁾ ⁽³¹⁾ ⁽³²⁾	Total suspended solids (TSS)		10–30 mg/l	Fluoride (F ⁻)		10–25 mg/l ⁽³²⁾	Sulphate (SO ₄ ²⁻)		1,3–2,0 g/l ⁽³²⁾ ⁽³³⁾ ⁽³⁴⁾ ⁽³⁵⁾	Sulphide (S ²⁻), easily released		0,1–0,2 mg/l ⁽³²⁾	Sulphite (SO ₃ ²⁻)		1–20 mg/l ⁽³²⁾	Metals and metalloids	As	10–50 µg/l	Cd	2–5 µg/l	Cr	10–50 µg/l	Cu	10–50 µg/l	Hg	0,2–3 µg/l	Ni	10–50 µg/l	Pb	10–20 µg/l
Substance/Parameter		BAT-AELs																																													
		Daily average																																													
Total organic carbon (TOC)		20–50 mg/l ⁽³⁰⁾ ⁽³¹⁾ ⁽³²⁾																																													
Chemical oxygen demand (COD)		60–150 mg/l ⁽³⁰⁾ ⁽³¹⁾ ⁽³²⁾																																													
Total suspended solids (TSS)		10–30 mg/l																																													
Fluoride (F ⁻)		10–25 mg/l ⁽³²⁾																																													
Sulphate (SO ₄ ²⁻)		1,3–2,0 g/l ⁽³²⁾ ⁽³³⁾ ⁽³⁴⁾ ⁽³⁵⁾																																													
Sulphide (S ²⁻), easily released		0,1–0,2 mg/l ⁽³²⁾																																													
Sulphite (SO ₃ ²⁻)		1–20 mg/l ⁽³²⁾																																													
Metals and metalloids	As	10–50 µg/l																																													
	Cd	2–5 µg/l																																													
	Cr	10–50 µg/l																																													
	Cu	10–50 µg/l																																													
	Hg	0,2–3 µg/l																																													
	Ni	10–50 µg/l																																													
	Pb	10–20 µg/l																																													

BAT C No.	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement									
		Zn	50–200 µg/l											
16	<p>In order to reduce the quantity of waste sent for disposal from the combustion and/or gasification process and abatement techniques, BAT is to organise operations so as to maximise, in order of priority and taking into account life-cycle thinking:</p> <p>(a) waste prevention, e.g. maximise the proportion of residues which arise) as by-products;</p> <p>(b) waste preparation for reuse, e.g. according to the specific requested) quality criteria;</p> <p>(c) waste recycling;</p> <p>(d) other waste recovery (e.g. energy recovery),</p> <p>by implementing an appropriate combination of techniques such as:</p>			NA	<p>The operator confirmed that:</p> <p>This is a gas turbine powered facility with no combustion process waste.</p> <p>We agree that this BAT Conclusion is not applicable to the activities carried out at the installation.</p>									
<table border="1"> <thead> <tr> <th data-bbox="280 742 309 767">Technique</th> <th data-bbox="309 742 813 767">Description</th> <th data-bbox="813 742 1102 767">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="280 767 309 1007">a</td> <td data-bbox="309 767 813 1007">Generation of gypsum as a by-product Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g. as raw material in the plasterboard industry). The quality of limestone used in the wet FGD influences the purity of the gypsum produced</td> <td data-bbox="813 767 1102 1007">Generally applicable within the constraints associated with the required gypsum quality, the health requirements associated to each specific use, and by the market conditions</td> </tr> <tr> <td data-bbox="280 1007 309 1233">b</td> <td data-bbox="309 1007 813 1233">Recycling or recovery of residues in the construction sector Recycling or recovery of residues (e.g. from semi-dry desulphurisation processes, fly ash, bottom ash) as a construction material (e.g. in road building, to replace sand in concrete production, or in the cement industry)</td> <td data-bbox="813 1007 1102 1233">Generally applicable within the constraints associated with the required material quality (e.g. physical properties, content of harmful substances) associated to each specific use, and by the market conditions</td> </tr> </tbody> </table>						Technique	Description	Applicability	a	Generation of gypsum as a by-product Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g. as raw material in the plasterboard industry). The quality of limestone used in the wet FGD influences the purity of the gypsum produced	Generally applicable within the constraints associated with the required gypsum quality, the health requirements associated to each specific use, and by the market conditions	b	Recycling or recovery of residues in the construction sector Recycling or recovery of residues (e.g. from semi-dry desulphurisation processes, fly ash, bottom ash) as a construction material (e.g. in road building, to replace sand in concrete production, or in the cement industry)	Generally applicable within the constraints associated with the required material quality (e.g. physical properties, content of harmful substances) associated to each specific use, and by the market conditions
Technique	Description	Applicability												
a	Generation of gypsum as a by-product Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g. as raw material in the plasterboard industry). The quality of limestone used in the wet FGD influences the purity of the gypsum produced	Generally applicable within the constraints associated with the required gypsum quality, the health requirements associated to each specific use, and by the market conditions												
b	Recycling or recovery of residues in the construction sector Recycling or recovery of residues (e.g. from semi-dry desulphurisation processes, fly ash, bottom ash) as a construction material (e.g. in road building, to replace sand in concrete production, or in the cement industry)	Generally applicable within the constraints associated with the required material quality (e.g. physical properties, content of harmful substances) associated to each specific use, and by the market conditions												

BAT C No.	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	c	Energy recovery by using waste in the fuel mix	The residual energy content of carbon-rich ash and sludges generated by the combustion of coal, lignite, heavy fuel oil, peat or biomass can be recovered for example by mixing with the fuel	Generally applicable where plants can accept waste in the fuel mix and are technically able to feed the fuels into the combustion chamber	
	d	Preparation of spent catalyst for reuse	Preparation of catalyst for reuse (e.g. up to four times for SCR catalysts) restores some or all of the original performance, extending the service life of the catalyst to several decades. Preparation of spent catalyst for reuse is integrated in a catalyst management scheme	The applicability may be limited by the mechanical condition of the catalyst and the required performance with respect to controlling NO _x and NH ₃ emissions	
17	In order to reduce noise emissions, BAT is to use one or a combination of the techniques given below.			CC	<p>The operator confirmed that:</p> <p>a. Operational measures include:</p> <ul style="list-style-type: none"> - inspection of equipment in line with OEM recommendations - equipment operated by experienced staff - avoidance of noisy activities at night, if possible <p>b. Low noise equipment - NA</p> <p>c. Noise Attenuation</p> <ul style="list-style-type: none"> - use of protection walls, embankments and buildings <p>d. Noise Control equipment:</p> <ul style="list-style-type: none"> - enclosure of noisy equipment <p>e. Appropriate location of equipment/buildings - NA</p> <p>The operator did not state their compliance status. We confirm that they are currently compliant.</p>
	Technique	Description	Applicability		
a	Operational measures	These include: <ul style="list-style-type: none"> — improved inspection and maintenance of equipment — closing of doors and windows of enclosed areas, if possible — equipment operated by experienced staff — avoidance of noisy activities at night, if possible — provisions for noise control during maintenance activities 	Generally applicable		
b	Low-noise equipment	This potentially includes compressors, pumps and disks	Generally applicable when the equipment is new or replaced		
c	Noise attenuation	Noise propagation can be reduced by inserting obstacles between the emitter and the receiver. Appropriate obstacles include protection walls, embankments and	Generally applicable to new plants. In the case of existing plants, the insertion of obstacles may be restricted by lack of		

BAT C No.	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement											
	d	Noise-control equipment	buildings This includes: <ul style="list-style-type: none"> — noise-reducers — equipment insulation — enclosure of noisy equipment — soundproofing of buildings 													
	e	Appropriate location of equipment and buildings	Noise levels can be reduced by increasing the distance between the emitter and the receiver and by using buildings as noise screens													
BAT Conclusions 18 to 27, for the combustion of solid fuels, are not applicable to the activities carried out at the installation.																
BAT Conclusions 28 to 39, for the combustion of liquid fuels, are not applicable to the activities carried out at the installation.																
Combustion of gaseous fuels																
40	In order to increase the energy efficiency of natural gas combustion, BAT is to use an appropriate combination of the techniques given in BAT 12 and below.			CC	LCP287 and LCP401 only operate in combined cycle mode. The station uses techniques a, b, c, d, f, g, h and r given in BAT Conclusion 12. See above for further details. BAT AEELs: Refer to Section 4.2 above. We agree with the operator's stated compliance.											
<table border="1"> <thead> <tr> <th data-bbox="271 887 416 959">Technique</th> <th data-bbox="416 887 573 959">Description</th> <th data-bbox="573 887 1115 959">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="271 959 416 1238">a</td> <td data-bbox="416 959 573 1238">Combined cycle See description in Section 8.2</td> <td data-bbox="573 959 1115 1238"> Generally applicable to new gas turbines and engines except when operated < 1 500 h/yr. Applicable to existing gas turbines and engines within the constraints associated with the steam cycle design and the space availability. Not applicable to existing gas turbines and engines operated < 1 500 h/yr. Not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns. Not applicable to boilers </td> </tr> </tbody> </table>				Technique	Description	Applicability	a	Combined cycle See description in Section 8.2	Generally applicable to new gas turbines and engines except when operated < 1 500 h/yr. Applicable to existing gas turbines and engines within the constraints associated with the steam cycle design and the space availability. Not applicable to existing gas turbines and engines operated < 1 500 h/yr. Not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns. Not applicable to boilers							
Technique	Description	Applicability														
a	Combined cycle See description in Section 8.2	Generally applicable to new gas turbines and engines except when operated < 1 500 h/yr. Applicable to existing gas turbines and engines within the constraints associated with the steam cycle design and the space availability. Not applicable to existing gas turbines and engines operated < 1 500 h/yr. Not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns. Not applicable to boilers														
BAT-associated energy efficiency levels (BAT-AEELs) for the combustion of natural gas																
<table border="1"> <thead> <tr> <th data-bbox="271 1294 472 1388" rowspan="2">Type of combustion unit</th> <th colspan="3" data-bbox="472 1294 1115 1334">BAT-AEELs ⁽¹³⁶⁾ ⁽¹³⁷⁾</th> </tr> <tr> <th data-bbox="472 1334 651 1388">Net electrical efficiency (%)</th> <th data-bbox="651 1334 846 1388">Net total fuel utilisation</th> <th data-bbox="846 1334 1115 1388">Net mechanical energy efficiency</th> </tr> </thead> <tbody> <tr> <td data-bbox="271 1388 472 1388"></td> <td data-bbox="472 1388 651 1388"></td> <td data-bbox="651 1388 846 1388"></td> <td data-bbox="846 1388 1115 1388"></td> </tr> </tbody> </table>				Type of combustion unit	BAT-AEELs ⁽¹³⁶⁾ ⁽¹³⁷⁾			Net electrical efficiency (%)	Net total fuel utilisation	Net mechanical energy efficiency						
Type of combustion unit	BAT-AEELs ⁽¹³⁶⁾ ⁽¹³⁷⁾															
	Net electrical efficiency (%)	Net total fuel utilisation	Net mechanical energy efficiency													

BAT C No.	Summary of BAT Conclusion requirement					Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement													
		New unit	Existing unit	(%)(¹³⁸) (¹³⁹)	(%)(¹³⁹) (¹⁴⁰)	New unit	Existing unit													
	Gas engine	39,5–44 (¹⁴¹)	35–44 (¹⁴¹)	56–85 (¹⁴¹)		No BAT-AEEL.														
	Gas-fired boiler	39–42,5	38–40	78–95		No BAT-AEEL.														
	Open cycle gas turbine, ≥ 50 MW _{th}	36–41,5	33–41,5	No BAT-AEEL		36,5–41	33,5–41													
	Combined cycle gas turbine (CCGT)																			
	CCGT, 50–600 MW _{th}	53–58,5	46–54	No BAT-AEEL		No BAT-AEEL														
	CCGT, ≥ 600 MW _{th}	57–60,5	50–60	No BAT-AEEL		No BAT-AEEL														
	CHP CCGT, 50–600 MW _{th}	53–58,5	46–54	65–95		No BAT-AEEL														
	CHP CCGT, ≥ 600 MW _{th}	57–60,5	50–60	65–95		No BAT-AEEL														
41	In order to prevent or reduce NO _x emissions to air from the combustion of natural gas in boilers, BAT is to use one or a combination of the techniques given below.			NA	<p>The operator confirmed that:</p> <p>This BAT Conclusion is not applicable as it is a gas turbine powered facility.</p> <p>We agree that this BAT Conclusion is not applicable to the activities carried out at the installation.</p>															
	<table border="1"> <thead> <tr> <th data-bbox="271 1034 472 1074">Technique</th> <th data-bbox="472 1034 779 1074">Description</th> <th data-bbox="779 1034 1115 1074">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="271 1074 472 1185">a Air and/or fuel staging</td> <td data-bbox="472 1074 779 1185">See descriptions in Section 8.3. Air staging is often associated with low-NO_x burners</td> <td data-bbox="779 1074 1115 1185" rowspan="3">Generally applicable</td> </tr> <tr> <td data-bbox="271 1185 472 1241">b Flue-gas recirculation</td> <td data-bbox="472 1185 779 1241">See description in Section 8.3</td> </tr> <tr> <td data-bbox="271 1241 472 1297">c Low-NO_x burners (LNB)</td> <td data-bbox="472 1241 779 1297"></td> </tr> <tr> <td data-bbox="271 1297 472 1386">d Advanced control system</td> <td data-bbox="472 1297 779 1386">See description in Section 8.3. This technique is often used in combination with other</td> <td data-bbox="779 1297 1115 1386">The applicability to old combustion plants may be constrained by the need to</td> </tr> </tbody> </table>							Technique	Description	Applicability	a Air and/or fuel staging	See descriptions in Section 8.3. Air staging is often associated with low-NO _x burners	Generally applicable	b Flue-gas recirculation	See description in Section 8.3	c Low-NO _x burners (LNB)		d Advanced control system	See description in Section 8.3. This technique is often used in combination with other	The applicability to old combustion plants may be constrained by the need to
Technique	Description	Applicability																		
a Air and/or fuel staging	See descriptions in Section 8.3. Air staging is often associated with low-NO _x burners	Generally applicable																		
b Flue-gas recirculation	See description in Section 8.3																			
c Low-NO _x burners (LNB)																				
d Advanced control system	See description in Section 8.3. This technique is often used in combination with other	The applicability to old combustion plants may be constrained by the need to																		

BAT C No.	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement									
		techniques or may be used alone for combustion plants operated < 500 h/yr	retrofit the combustion system and/or control command system											
	e	Reduction of the combustion air temperature	See description in Section 8.3 Generally applicable within the constraints associated with the process needs											
	f.	Selective non-catalytic reduction (SNCR)	Not applicable to combustion plants operated < 500 h/yr with highly variable boiler loads. The applicability may be limited in the case of combustion plants operated between 500 h/yr and 1 500 h/yr with highly variable boiler loads											
	g	Selective catalytic reduction (SCR)	Not applicable to combustion plants operated < 500 h/yr. Not generally applicable to combustion plants of < 100 MW _{th} . There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr											
42	In order to prevent or reduce NO _x emissions to air from the combustion of natural gas in gas turbines, BAT is to use one or a combination of the techniques given below.			CC	<p>The operator confirmed that:</p> <ul style="list-style-type: none"> a. Advanced control system – in place b. Water/steam addition - NA c. Low-NO_x burners - twin combustion system to reduce NO_x, equipped with low NO_x burners d. Low load design concept - installed in 2018 e. Low-NO_x burners - NA (no duct burners) f. Selective catalytic reduction - not installed, unable to retrofit due to lack of space <p>They have re-defined MSUL/MSDL as set out in Section 8 of this document. This is set out in their submission received 15 May 2020.</p>									
	<table border="1"> <thead> <tr> <th data-bbox="271 1086 439 1123">Technique</th> <th data-bbox="439 1086 824 1123">Description</th> <th data-bbox="824 1086 1115 1123">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="271 1123 439 1283">a</td> <td data-bbox="439 1123 824 1283">Advanced control system See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr</td> <td data-bbox="824 1123 1115 1283">The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> <tr> <td data-bbox="271 1283 439 1398">b</td> <td data-bbox="439 1283 824 1398">Water/steam addition See description in Section 8.3</td> <td data-bbox="824 1283 1115 1398">The applicability may be limited due to water availability</td> </tr> </tbody> </table>			Technique	Description	Applicability	a	Advanced control system See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system	b	Water/steam addition See description in Section 8.3	The applicability may be limited due to water availability		
Technique	Description	Applicability												
a	Advanced control system See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system												
b	Water/steam addition See description in Section 8.3	The applicability may be limited due to water availability												

BAT C No.	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement						
	c. Dry low-NO _x burners (DLN)		The applicability may be limited in the case of turbines where a retrofit package is not available or when water/steam addition systems are installed		<p>In this submission they also confirmed that dry low NO_x is effective (DLN-E) when the AELs are achieved, which is equivalent to the stable export limit (SEL). They propose DLN-E as detailed in section 4.1 of this document.</p> <p>They also confirmed that:</p> <p>The LCPs will be able to meet the BAT AELs for NO_x as shown in Table 24 of the BAT Conclusions Document :</p> <table border="1" data-bbox="1240 608 1973 692"> <tr> <td colspan="2"><i>Existing CCGT with a net total fuel utilisation of <75% and >600MW_{th}</i></td> </tr> <tr> <td><u>YEARLY AVERAGE</u></td> <td><u>DAILY AVERAGE</u></td> </tr> <tr> <td>10-40</td> <td>18-50</td> </tr> </table> <p>The LCPs will be unable to meet the indicative BAT AELs for CO as shown in the notes at the end of Table 24 of the BAT Conclusions Document.</p> <p><i>Existing CCGT >50 MW_{th}: <5-30 mg/Nm³. The higher end of the range will generally be 50mg/Nm³ when plants operate at low load.</i></p> <p>This is because the plant is operated in a manner which will effectively manage NO_x emissions as well as meeting commercial demands.</p> <p>We have set limits as set out in section 4.1 of this document.</p> <p>We agree with the operator's stated compliance for NO_x emissions.</p> <p>Refer to BAT Conclusion 44 of this table for our assessment of CO emissions.</p>	<i>Existing CCGT with a net total fuel utilisation of <75% and >600MW_{th}</i>		<u>YEARLY AVERAGE</u>	<u>DAILY AVERAGE</u>	10-40	18-50
<i>Existing CCGT with a net total fuel utilisation of <75% and >600MW_{th}</i>											
<u>YEARLY AVERAGE</u>	<u>DAILY AVERAGE</u>										
10-40	18-50										
d. Low-load design concept	Adaptation of the process control and related equipment to maintain good combustion efficiency when the demand in energy varies, e.g. by improving the inlet airflow control capability or by splitting the combustion process into decoupled combustion stages	The applicability may be limited by the gas turbine design									
e. Low-NO _x burners (LNB)	See description in Section 8.3	Generally applicable to supplementary firing for heat recovery steam generators (HRSGs) in the case of combined-cycle gas turbine (CCGT) combustion plants									
f. Selective catalytic reduction (SCR)		Not applicable in the case of combustion plants operated < 500 h/yr. Not generally applicable to existing combustion plants of < 100 MW _{th} . Retrofitting existing combustion plants may be constrained by the availability of sufficient space. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr									

BAT C No.	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement														
43	<p>In order to prevent or reduce NO_x emissions to air from the combustion of natural gas in engines, BAT is to use one or a combination of the techniques given below.</p> <table border="1" data-bbox="280 411 1106 1032"> <thead> <tr> <th data-bbox="280 411 434 448">Technique</th> <th data-bbox="434 411 757 448">Description</th> <th data-bbox="757 411 1106 448">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="280 448 434 608">a Advanced control system</td> <td data-bbox="434 448 757 608">See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr</td> <td data-bbox="757 448 1106 608">The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> <tr> <td data-bbox="280 608 434 687">b Lean-burn concept</td> <td data-bbox="434 608 757 687">See description in Section 8.3. Generally used in combination with SCR</td> <td data-bbox="757 608 1106 687">Only applicable to new gas-fired engines</td> </tr> <tr> <td data-bbox="280 687 434 767">c Advanced lean-burn concept</td> <td data-bbox="434 687 757 767" rowspan="2">See descriptions in Section 8.3</td> <td data-bbox="757 687 1106 767">Only applicable to new spark plug ignited engines</td> </tr> <tr> <td data-bbox="280 767 434 1032">d Selective catalytic reduction (SCR)</td> <td data-bbox="757 767 1106 1032">Retrofitting existing combustion plants may be constrained by the availability of sufficient space. Not applicable to combustion plants operated < 500 h/yr. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr</td> </tr> </tbody> </table>	Technique	Description	Applicability	a Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system	b Lean-burn concept	See description in Section 8.3. Generally used in combination with SCR	Only applicable to new gas-fired engines	c Advanced lean-burn concept	See descriptions in Section 8.3	Only applicable to new spark plug ignited engines	d Selective catalytic reduction (SCR)	Retrofitting existing combustion plants may be constrained by the availability of sufficient space. Not applicable to combustion plants operated < 500 h/yr. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr	NA	<p>The operator confirmed that:</p> <p>This BAT Conclusion is not applicable as it is a gas turbine powered facility.</p> <p>We agree that this BAT Conclusion is not applicable to the activities carried out at the installation.</p>
Technique	Description	Applicability															
a Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system															
b Lean-burn concept	See description in Section 8.3. Generally used in combination with SCR	Only applicable to new gas-fired engines															
c Advanced lean-burn concept	See descriptions in Section 8.3	Only applicable to new spark plug ignited engines															
d Selective catalytic reduction (SCR)		Retrofitting existing combustion plants may be constrained by the availability of sufficient space. Not applicable to combustion plants operated < 500 h/yr. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr															
44	<p>In order to prevent or reduce CO emissions to air from the combustion of natural gas, BAT is to ensure optimised combustion and/or to use oxidation catalysts.</p> <p>Description - See descriptions in Section 8.3.</p> <p>BAT-associated emission levels (BAT-AELs) for NO_x emissions to air from the combustion of natural gas in gas turbines</p> <table border="1" data-bbox="280 1214 1106 1378"> <thead> <tr> <th data-bbox="280 1214 602 1378" rowspan="2">Type of combustion plant</th> <th data-bbox="602 1214 770 1378" rowspan="2">Combustion plant total rated thermal input (MW_{th})</th> <th colspan="2" data-bbox="770 1214 1106 1273">BAT-AELs (mg/Nm³) ⁽¹⁴²⁾₍₁₄₃₎</th> </tr> <tr> <th data-bbox="770 1273 927 1378">Yearly average ⁽¹⁴⁴⁾₍₁₄₅₎</th> <th data-bbox="927 1273 1106 1378">Daily average or average over the</th> </tr> </thead> <tbody> <tr> <td data-bbox="280 1378 602 1385"></td> <td data-bbox="602 1378 770 1385"></td> <td data-bbox="770 1378 927 1385"></td> <td data-bbox="927 1378 1106 1385"></td> </tr> </tbody> </table>	Type of combustion plant	Combustion plant total rated thermal input (MW _{th})	BAT-AELs (mg/Nm ³) ⁽¹⁴²⁾ ₍₁₄₃₎		Yearly average ⁽¹⁴⁴⁾ ₍₁₄₅₎	Daily average or average over the					FC	<p>The operator confirmed that:</p> <p>a. use of high performance monitoring and an advanced combustion system</p> <p>Refer to BAT Conclusion 42 above.</p> <p>The operator stated that they are currently complaint (CC); however they are currently uncertain about what CO limits they can achieve. We have set an improvement condition to address this, refer to section 4.1 of this document.</p>				
Type of combustion plant	Combustion plant total rated thermal input (MW _{th})			BAT-AELs (mg/Nm ³) ⁽¹⁴²⁾ ₍₁₄₃₎													
		Yearly average ⁽¹⁴⁴⁾ ₍₁₄₅₎	Daily average or average over the														

BAT C No.	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																																																				
	<table border="1" data-bbox="280 328 1106 1177"> <thead> <tr> <th></th> <th></th> <th></th> <th>sampling period</th> </tr> </thead> <tbody> <tr> <td colspan="4" style="text-align: center;">Open-cycle gas turbines (OCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁷⁾</td> </tr> <tr> <td>New OCGT</td> <td>≥ 50</td> <td>15–35</td> <td>25–50</td> </tr> <tr> <td>Existing OCGT (excluding turbines for mechanical drive applications) — All but plants operated < 500 h/yr</td> <td>≥ 50</td> <td>15–50</td> <td>25–55 ⁽¹⁴⁸⁾</td> </tr> <tr> <td colspan="4" style="text-align: center;">Combined-cycle gas turbines (CCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁹⁾</td> </tr> <tr> <td>New CCGT</td> <td>≥ 50</td> <td>10–30</td> <td>15–40</td> </tr> <tr> <td>Existing CCGT with a net total fuel utilisation of < 75 %</td> <td>≥ 600</td> <td>10–40</td> <td>18–50</td> </tr> <tr> <td>Existing CCGT with a net total fuel utilisation of ≥ 75 %</td> <td>≥ 600</td> <td>10–50</td> <td>18–55 ⁽¹⁵⁰⁾</td> </tr> <tr> <td>Existing CCGT with a net total fuel utilisation of < 75 %</td> <td>50–600</td> <td>10–45</td> <td>35–55</td> </tr> <tr> <td>Existing CCGT with a net total fuel utilisation of ≥ 75 %</td> <td>50–600</td> <td>25–50 ⁽¹⁵¹⁾</td> <td>35–55 ⁽¹⁵²⁾</td> </tr> <tr> <td colspan="4" style="text-align: center;">Open- and combined-cycle gas turbines</td> </tr> <tr> <td>Gas turbine put into operation no later than 27 November 2003, or existing gas turbine for emergency use and operated < 500 h/yr</td> <td>≥ 50</td> <td>No BAT-AEL</td> <td>60–140 ⁽¹⁵³⁾ ⁽¹⁵⁴⁾</td> </tr> <tr> <td>Existing gas turbine for mechanical drive applications — All but plants operated < 500 h/yr</td> <td>≥ 50</td> <td>15–50 ⁽¹⁵⁵⁾</td> <td>25–55 ⁽¹⁵⁶⁾</td> </tr> </tbody> </table> <p data-bbox="280 1182 1106 1262">As an indication, the yearly average CO emission levels for each type of existing combustion plant operated ≥ 1 500 h/yr and for each type of new combustion plant will generally be as follows:</p> <p data-bbox="280 1267 1106 1374">— New OCGT of ≥ 50 MW_{th}: < 5–40 mg/Nm³. For plants with a net electrical efficiency (EE) greater than 39 %, a correction factor may be applied to the higher end of this range, corresponding to [higher end] × EE/39, where EE is the net electrical energy efficiency or net mechanical energy efficiency of the plant</p>				sampling period	Open-cycle gas turbines (OCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁷⁾				New OCGT	≥ 50	15–35	25–50	Existing OCGT (excluding turbines for mechanical drive applications) — All but plants operated < 500 h/yr	≥ 50	15–50	25–55 ⁽¹⁴⁸⁾	Combined-cycle gas turbines (CCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁹⁾				New CCGT	≥ 50	10–30	15–40	Existing CCGT with a net total fuel utilisation of < 75 %	≥ 600	10–40	18–50	Existing CCGT with a net total fuel utilisation of ≥ 75 %	≥ 600	10–50	18–55 ⁽¹⁵⁰⁾	Existing CCGT with a net total fuel utilisation of < 75 %	50–600	10–45	35–55	Existing CCGT with a net total fuel utilisation of ≥ 75 %	50–600	25–50 ⁽¹⁵¹⁾	35–55 ⁽¹⁵²⁾	Open- and combined-cycle gas turbines				Gas turbine put into operation no later than 27 November 2003, or existing gas turbine for emergency use and operated < 500 h/yr	≥ 50	No BAT-AEL	60–140 ⁽¹⁵³⁾ ⁽¹⁵⁴⁾	Existing gas turbine for mechanical drive applications — All but plants operated < 500 h/yr	≥ 50	15–50 ⁽¹⁵⁵⁾	25–55 ⁽¹⁵⁶⁾		We don't agree with the operator's stated compliance and have confirmed that they will be future compliant (FC).
			sampling period																																																				
Open-cycle gas turbines (OCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁷⁾																																																							
New OCGT	≥ 50	15–35	25–50																																																				
Existing OCGT (excluding turbines for mechanical drive applications) — All but plants operated < 500 h/yr	≥ 50	15–50	25–55 ⁽¹⁴⁸⁾																																																				
Combined-cycle gas turbines (CCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁹⁾																																																							
New CCGT	≥ 50	10–30	15–40																																																				
Existing CCGT with a net total fuel utilisation of < 75 %	≥ 600	10–40	18–50																																																				
Existing CCGT with a net total fuel utilisation of ≥ 75 %	≥ 600	10–50	18–55 ⁽¹⁵⁰⁾																																																				
Existing CCGT with a net total fuel utilisation of < 75 %	50–600	10–45	35–55																																																				
Existing CCGT with a net total fuel utilisation of ≥ 75 %	50–600	25–50 ⁽¹⁵¹⁾	35–55 ⁽¹⁵²⁾																																																				
Open- and combined-cycle gas turbines																																																							
Gas turbine put into operation no later than 27 November 2003, or existing gas turbine for emergency use and operated < 500 h/yr	≥ 50	No BAT-AEL	60–140 ⁽¹⁵³⁾ ⁽¹⁵⁴⁾																																																				
Existing gas turbine for mechanical drive applications — All but plants operated < 500 h/yr	≥ 50	15–50 ⁽¹⁵⁵⁾	25–55 ⁽¹⁵⁶⁾																																																				

BAT C No.	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																							
	<p>determined at ISO baseload conditions.</p> <ul style="list-style-type: none"> — Existing OCGT of $\geq 50 \text{ MW}_{th}$ (excluding turbines for mechanical drive applications): $< 5\text{--}40 \text{ mg/Nm}^3$. The higher end of this range will generally be 80 mg/Nm^3 in the case of existing plants that cannot be fitted with dry techniques for NO_x reduction, or 50 mg/Nm^3 for plants that operate at low load. — New CCGT of $\geq 50 \text{ MW}_{th}$: $< 5\text{--}30 \text{ mg/Nm}^3$. For plants with a net electrical efficiency (EE) greater than 55 %, a correction factor may be applied to the higher end of the range, corresponding to [higher end] \times EE/55, where EE is the net electrical energy efficiency of the plant determined at ISO baseload conditions. — Existing CCGT of $\geq 50 \text{ MW}_{th}$: $< 5\text{--}30 \text{ mg/Nm}^3$. The higher end of this range will generally be 50 mg/Nm^3 for plants that operate at low load. — Existing gas turbines of $\geq 50 \text{ MW}_{th}$ for mechanical drive applications: $< 5\text{--}40 \text{ mg/Nm}^3$. The higher end of the range will generally be 50 mg/Nm^3 when plants operate at low load. <p>In the case of a gas turbine equipped with DLN burners, these indicative levels correspond to when the DLN operation is effective.</p> <p>BAT-associated emission levels (BAT-AELs) for NO_x emissions to air from the combustion of natural gas in boilers and engines</p> <table border="1" data-bbox="280 842 1102 1066"> <thead> <tr> <th rowspan="3">Type of combustion plant</th> <th colspan="4">BAT-AELs (mg/Nm^3)</th> </tr> <tr> <th colspan="2">Yearly average ⁽¹⁵⁷⁾</th> <th colspan="2">Daily average or average over the sampling period</th> </tr> <tr> <th>New plant</th> <th>Existing plant ⁽¹⁵⁸⁾</th> <th>New plant</th> <th>Existing plant ⁽¹⁵⁹⁾</th> </tr> </thead> <tbody> <tr> <td>Boiler</td> <td>10–60</td> <td>50–100</td> <td>30–85</td> <td>85–110</td> </tr> <tr> <td>Engine ⁽¹⁶⁰⁾</td> <td>20–75</td> <td>20–100</td> <td>55–85</td> <td>55–110 ⁽¹⁶¹⁾</td> </tr> </tbody> </table> <p>As an indication, the yearly average CO emission levels will generally be:</p> <ul style="list-style-type: none"> — $< 5\text{--}40 \text{ mg/Nm}^3$ for existing boilers operated $\geq 1\,500 \text{ h/yr}$, — $< 5\text{--}15 \text{ mg/Nm}^3$ for new boilers, — $30\text{--}100 \text{ mg/Nm}^3$ for existing engines operated $\geq 1\,500 \text{ h/yr}$ and for new engines. 	Type of combustion plant	BAT-AELs (mg/Nm^3)				Yearly average ⁽¹⁵⁷⁾		Daily average or average over the sampling period		New plant	Existing plant ⁽¹⁵⁸⁾	New plant	Existing plant ⁽¹⁵⁹⁾	Boiler	10–60	50–100	30–85	85–110	Engine ⁽¹⁶⁰⁾	20–75	20–100	55–85	55–110 ⁽¹⁶¹⁾		
Type of combustion plant	BAT-AELs (mg/Nm^3)																									
	Yearly average ⁽¹⁵⁷⁾		Daily average or average over the sampling period																							
	New plant	Existing plant ⁽¹⁵⁸⁾	New plant	Existing plant ⁽¹⁵⁹⁾																						
Boiler	10–60	50–100	30–85	85–110																						
Engine ⁽¹⁶⁰⁾	20–75	20–100	55–85	55–110 ⁽¹⁶¹⁾																						

BAT C No.	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																		
45	<p>In order to reduce non-methane volatile organic compounds (NMVOC) and methane (CH₄) emissions to air from the combustion of natural gas in spark-ignited lean-burn gas engines, BAT is to ensure optimised combustion and/or to use oxidation catalysts.</p> <p>Description See descriptions in Section 8.3. Oxidation catalysts are not effective at reducing the emissions of saturated hydrocarbons containing less than four carbon atoms.</p> <p>BAT-associated emission levels (BAT-AELs) for formaldehyde and CH₄ emissions to air from the combustion of natural gas in a spark-ignited lean-burn gas engine</p> <table border="1" data-bbox="280 635 1106 857"> <thead> <tr> <th rowspan="3">Combustion plant total rated thermal input (MW_{th})</th> <th colspan="3">BAT-AELs (mg/Nm³)</th> </tr> <tr> <th>Formaldehyde</th> <th colspan="2">CH₄</th> </tr> <tr> <th colspan="3">Average over the sampling period</th> </tr> <tr> <th></th> <th>New or existing plant</th> <th>New plant</th> <th>Existing plant</th> </tr> </thead> <tbody> <tr> <td>≥ 50</td> <td>5–15⁽¹⁶²⁾</td> <td>215–500⁽¹⁶³⁾</td> <td>215–560⁽¹⁶²⁾ ₍₁₆₃₎</td> </tr> </tbody> </table>	Combustion plant total rated thermal input (MW _{th})	BAT-AELs (mg/Nm ³)			Formaldehyde	CH ₄		Average over the sampling period				New or existing plant	New plant	Existing plant	≥ 50	5–15 ⁽¹⁶²⁾	215–500 ⁽¹⁶³⁾	215–560 ⁽¹⁶²⁾ ₍₁₆₃₎	NA	<p>The operator confirmed that:</p> <p>This BAT Conclusion is not applicable as it is a gas turbine powered facility.</p> <p>We agree that this BAT Conclusion is not applicable to the activities carried out at the installation.</p>
Combustion plant total rated thermal input (MW _{th})	BAT-AELs (mg/Nm ³)																				
	Formaldehyde		CH ₄																		
	Average over the sampling period																				
	New or existing plant	New plant	Existing plant																		
≥ 50	5–15 ⁽¹⁶²⁾	215–500 ⁽¹⁶³⁾	215–560 ⁽¹⁶²⁾ ₍₁₆₃₎																		
<p>The following BAT Conclusions are not applicable to the activities carried out at the installation:</p> <p>BAT Conclusions 46 to 51 for iron and steel process gases</p> <p>BAT Conclusions 52 to 54 for offshore platforms</p> <p>BAT Conclusions 55 to 59 for chemical process gases</p> <p>BAT Conclusions 60 to 71 for co-incineration</p> <p>BAT Conclusions 72 to 75 for gasification</p>																					

6 Review and assessment of derogation requests made by the operator in relation to BAT Conclusions which include an associated emission level (AEL) value

The IED enables a competent authority to allow derogations from BAT AELs stated in BAT Conclusions under specific circumstances as detailed under Article 15(4):

By way of derogation from paragraph 3, and without prejudice to Article 18, the competent authority may, in specific cases, set less strict emission limit values. Such a derogation may apply only where an assessment shows that the achievement of emission levels associated with the best available techniques as described in BAT conclusions would lead to disproportionately higher costs compared to the environmental benefits due to:

(a) the geographical location or the local environmental conditions of the installation concerned; or

(b) the technical characteristics of the installation concerned.

We have not received any such request from the operator.

7 Emissions to water

The consolidated permit includes the discharge of surface water to Clifton Brook (controlled waters) from the installation at emission point W1.

BAT AELs are not applicable as they are only required for releases from flue gas treatment. Refer to BAT Conclusion 15 in section 5 above.

8 Additional IED Chapter II requirements:

Condition/table	Justification
Condition 2.3.7, IP4 and definition in Schedule 6 added	<p>In the event of a black out National Grid would call on combustion plant to operate and may require them to do so outside their permitted conditions. We have dedicated black start plant and they are permitted to run as such but this scenario is relevant to the rest of the LCP which could be called depending on the circumstances.</p> <p>A risk assessment will be carried out by Energy UK/Joint Environmental Programme on behalf of LCP connected to the National Transmission System. Air emissions modelling will be based on generic black start scenarios to establish whether they have the potential to have a local impact on the environment or not (on a national basis). If the modelling demonstrates that no significant impacts are likely, the plant can operate under condition 2.3.7. This condition allows the hourly ELVs for plants operating under a black start instruction to be discounted for the purpose of reporting. We would also require there to be a procedure in place for minimisation of emissions in the case of a black start event and for reporting in the event of a black start. This modelling and the procedures have not been agreed in advance of the issue of the permit review and therefore a condition linking back to an improvement condition has been included in the permit.</p>
Condition 3.1.3 deleted	<p>There are no annual emissions and there is no table S3.4 to which the condition refers, in the existing permit. Condition 3.1.4 renumbered to 3.1.3.</p>
Condition 3.6.7 amended	<p>To reference tables S3.1 and S3.1a instead of S4.1.</p>
Table S1.1	<p>Amended to include the auxiliary diesel fired boiler. The operator confirmed that it is used to raise a small amount of steam for use in the fuel gas heaters. The gas has to be brought up to a minimum temperature before it can be admitted to the gas turbine burners. Normally this steam can be diverted off from other parts of the system but the auxiliary boiler is required for 'cold starts.' Cold starts are required when the steam turbine has been shut down for a period of time and there is little pressure in the system.</p>
Table S1.2	<p>Amended to incorporate operating techniques for low part load operation. This is set out in their submission received 15 May 2020.</p> <p>The low part load operations enable a more flexible and attractive operational proposition to the grid. This is consistent with our duty to have regard to promoting economic growth as set out in section 9 of this document.</p>

Table S1.3	Amended to confirm that IP3 is completed.
Table S1.4	MSUL/MSDL re-defined (see below)
Table S3.1 amended	Emission point reference for sulphur dioxide from A1 to A2, to correct an error. LCP 287 amended to LCP 401 to correct an error.
Table S3.2 amended	To add 'uncontaminated' surface water.
Schedule 6- Interpretation	Deleted interpretation for "background concentration" which isn't relevant to the installation.
	Deleted interpretation for "breakdown", the abatement condition to which this applies isn't relevant to the installation. The abatement condition is applicable where the abatement is listed in part A, appendix B, of the ESI Compliance Protocol, or uses water injection as an abatement measure as outlined in the protocol.
	Deleted interpretation for "malfunction", the abatement condition to which this applies isn't relevant to the installation. Refer to "breakdown" above.
	Added definition for low part load operation.

MSUL/MSDL

In the existing permit the MSUL/MSDL is defined as meeting two out of three criteria as set out below. These thresholds will apply until 16 August 2021.

Table S1.4 Start-up and Shut-down thresholds		
Emission Point and Unit Reference	"Minimum start up load" When two of the criteria listed below for the LCP or unit have been met.	"Minimum shut-down load" When two of the criteria listed below for the LCP or unit have been met.
A1(LCP287)	fuel flow of >7.5 Kg/s	fuel flow of <7.5 Kg/s
A1(LCP287)	Turbine exhaust gas temperature >600°C	Turbine exhaust gas temperature <600°C
A1(LCP287)	Variable Inlet Guide Vane(ViVG) angle of >-40°	Variable Inlet Guide Vane(ViVG) angle of <-40°
A2(LCP401)	fuel flow of >7.5 Kg/s	fuel flow of <7.5 Kg/s
A2(LCP401)	Turbine exhaust gas temperature >600°C	Turbine exhaust gas temperature <600°C
A2(LCP401)	Variable Inlet Guide Vane(ViVG) angle of >-40°	Variable Inlet Guide Vane(ViVG) angle of <-40°

The operator has proposed that the MSUL/MSDL is re-defined at a MW output equivalent. They undertook a review of operational data from 01 September 2019 to 01 January 2020 to calculate the average MW values at which two out of three criteria in the table above are met. Based on this review they propose that 100MW is used for MSUL/MSDL for both LCPs. Based upon the information the operator has provided, we agree that this represents the point at which the plant is in stable operation.

The most recent performance test carried out in June 2019 identified a mean baseload of 256.5MW for both LCPs.

MSUL/MSDL = 100/256.5MW = 39% load.

MSUL/MSDL is re-defined in the varied permit as set out below. These thresholds will apply from 17 August 2021.

Table S1.4 Start-up and Shut-down thresholds		
Emission Point and Unit Reference	“Minimum Start-Up Load” Load in MW and as percent of rated power output (%)	“Minimum Shut-Down Load” Load in MW and as percent of rated power output (%)
A1(LCP287)	100 MW; 39% (GT only)	100 MW; 39% (GT only)
A2(LCP401)	100 MW; 39% (GT only)	100 MW; 39% (GT only)

We agree with all of these definitions and have set these thresholds in the permit accordingly. We consider that this amendment will not change the emission profile of the installation during its stationary operation and will not result in any increased risk to the environment.

9 Review and assessment of changes that are not part of the BAT Conclusions derived permit review.

This document should be read in conjunction with the application, supporting information and notice.

Aspect considered	Decision
Receipt of application	
Confidential information	A claim for commercial or industrial confidentiality has not been made.
Identifying confidential information	We have not identified information provided as part of the application that we consider to be confidential.
The site	
Biodiversity, heritage, landscape and nature conservation	<p>The application is within the relevant distance criteria of a site of heritage, landscape or nature conservation, and/or protected species or habitat.</p> <p>A full assessment of the application and its potential to affect the sites/species/habitat has not been carried out as part of the permit review process. We consider that the review will not affect the features of the sites/species/habitat as the conditions will provide at least the same level of protection as those in the previous permit and in some cases will provide a higher level of protection to those in the previous permit.</p> <p>We have not consulted Natural England on the application. The decision was taken in accordance with our guidance.</p>
Operating techniques	
General operating techniques	<p>We have reviewed the techniques used by the operator where they are relevant to the BAT Conclusions and compared these with the relevant guidance notes.</p> <p>The permit conditions ensure compliance with the relevant BREF, BAT Conclusions. The ELVs deliver</p>

Aspect considered	Decision
	compliance with the BAT AELs.
Permit conditions	
Updating permit conditions during consolidation	We have updated permit conditions to those in the current generic permit template as part of permit consolidation. The conditions will provide at least the same level of protection as those in the previous permit and in some cases will provide a higher level of protection to those in the previous permit.
Changes to the permit conditions due to an Environment Agency initiated variation	We have varied the permit as stated in the variation notice.
Improvement programme	Based on the information on the application, we consider that we need to impose an improvement programme. This is explained in the relevant sections of this document.
Emission limits	<p>We have decided that emission limits should be set for the parameters listed in the permit.</p> <p>These are described in the relevant BAT Conclusions in sections 4.1 and 5 of this document.</p> <p>It is considered that the ELVs described above will ensure that significant pollution of the environment is prevented and a high level of protection for the environment is secured.</p>
Monitoring	<p>We have decided that monitoring should be carried out for the parameters listed in the permit, using the methods detailed and to the frequencies specified.</p> <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p> <p>Table S3.4 Process monitoring requirements was added to include the requirement to monitor energy efficiency after overhauls on site in line with BAT</p>

Aspect considered	Decision
	<p>Conclusion 2.</p> <p>Based on the information in the application we are satisfied that the operator's techniques, personnel and equipment have either MCERTS certification or MCERTS accreditation as appropriate.</p>
Reporting	<p>We have specified reporting in the permit for the following parameters:</p> <ul style="list-style-type: none"> • Nitrogen dioxide • Carbon monoxide • Sulphur dioxide <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p>
Operator competence	
Management system	<p>There is no known reason to consider that the operator will not have the management system to enable them to comply with the permit conditions.</p>
Growth Duty	
Section 108 Deregulation Act 2015 – Growth duty	<p>We have considered our duty to have regard to the desirability of promoting economic growth set out in section 108(1) of the Deregulation Act 2015 and the guidance issued under section 110 of that Act in deciding whether to grant this permit.</p> <p>Paragraph 1.3 of the guidance says:</p> <p>“The primary role of regulators, in delivering regulation, is to achieve the regulatory outcomes for which they are responsible. For a number of regulators, these regulatory outcomes include an explicit reference to development or growth. The growth duty establishes economic growth as a factor that all specified regulators should have regard to, alongside the delivery of the protections set out in the relevant legislation.”</p> <p>We have addressed the legislative requirements and environmental standards to be set for this operation in the body of the decision document above. The guidance is clear at paragraph 1.5 that the growth</p>

Aspect considered	Decision
	<p>duty does not legitimise non-compliance and its purpose is not to achieve or pursue economic growth at the expense of necessary protections.</p> <p>We consider the requirements and standards we have set in this permit are reasonable and necessary to avoid a risk of an unacceptable level of pollution. This also promotes growth amongst legitimate operators because the standards applied to the operator are consistent across businesses in this sector and have been set to achieve the required legislative standards.</p>