

## Environment Agency

# Review of an Environmental Permit for an Installation subject to Chapter II of the Industrial Emissions Directive under the Environmental Permitting (England & Wales) Regulations 2016

## Decision document recording our decision-making process following review of a permit

The Permit number is: EPR/PP3536TV  
The Operator is: Whitetower Energy Limited  
The Installation is: Exeter Plant  
This Variation Notice number is: EPR/PP3536TV/V004

### What this document is about

Article 21(3) of the Industrial Emissions Directive (IED) requires the Environment Agency to review conditions in permits that it has issued and to ensure that the permit delivers compliance with relevant standards, within four years of the publication of updated decisions on best available techniques (BAT) conclusions.

We have reviewed the permit for this installation against the revised BAT Conclusions for large combustion plant published on 17<sup>th</sup> August 2017. This is our decision document, which explains the reasoning for the consolidated variation notice that we are issuing.

It explains how we have reviewed and considered the techniques used by the Operator in the operation and control of the plant and activities of the installation. This review has been undertaken with reference to the decision made by the European Commission establishing best available techniques (BAT) conclusions ('BAT Conclusions') for large combustion plant as detailed in document reference IEDC-7-1. It is our record of our decision-making process and shows how we have taken into account all relevant factors in reaching our position. It also provides a justification for the inclusion of any specific conditions in the permit that are in addition to those included in our generic permit template.

As well as considering the review of the operating techniques used by the Operator for the operation of the plant and activities of the installation, the consolidated variation notice takes into account and brings together in a single document all previous variations that relate to the original permit

issued. It also modernises the entire permit to reflect the conditions contained in our current generic permit template.

The introduction of new template conditions makes the Permit consistent with our current general approach and philosophy and with other permits issued to installations in this sector. Although the wording of some conditions has changed, while others have been removed because of the new regulatory approach, it does not reduce the level of environmental protection achieved by the Permit in any way. In this document we therefore address only our determination of substantive issues relating to the new BAT Conclusions.

Throughout this document we will use a number of expressions. These are as referred to in the glossary and have the same meaning as described in “Schedule 6 Interpretation” of the Permit.

We try to explain our decision as accurately, comprehensively and plainly as possible. We would welcome any feedback as to how we might improve our decision documents in future. A lot of technical terms and acronyms are inevitable in a document of this nature: we provide a glossary of acronyms near the front of the document, for ease of reference.

## How this document is structured

### Glossary of terms

- 1 Our decision
- 2 How we reached our decision
- 2.1 Requesting information to demonstrate compliance with BAT Conclusions for Large Combustion Plant
- 2.2 Review of our own information in respect to the capability of the installation to meet revised standards included in the BAT Conclusions document
- 3 The legal framework
- 4 Key Issues
- 5 Decision checklist regarding relevant BAT Conclusions
- 6 Review and assessment of derogation requests made by the operator in relation to BAT Conclusions which include an associated emission level (AEL) value
- 7 Emissions to Water
- 8 Additional IED Chapter II requirements
- 9 Review and assessment of changes that are not part of the BAT Conclusions derived permit review.

## Glossary of acronyms used in this document

(Please note that this glossary is standard for our decision documents and therefore not all these acronyms are necessarily used in this document.)

APC	Air Pollution Control
BAT	Best Available Technique(s)
BAT-AEEL	BAT Associated Energy Efficiency Level
BAT-AEL	BAT Associated Emission Level
BATc	BAT conclusion
BREF	Best available techniques reference document
CCGT	Combined Cycle Gas Turbine
CEM	Continuous emissions monitor
CHP	Combined heat and power
CV	Calorific value
DAA	Directly associated activity – Additional activities necessary to be carried out to allow the principal activity to be carried out
DLN	Dry Low NOx burners
DLN-E	Dry Low NOx effective
EIONET	European environment information and observation network is a partnership network of the European Environment Agency
ELV	Emission limit value derived under BAT or an emission limit value set out in IED
EMS	Environmental Management System
EPR	Environmental Permitting (England and Wales) Regulations 2016 (SI 2016 No. 1154)
EWC	European waste catalogue
FSA	Food Standards Agency
IC	Improvement Condition
IED	Industrial Emissions Directive (2010/75/EU)
IPPCD	Integrated Pollution Prevention and Control Directive (2008/1/EC) – now superseded by IED
LCP	Large Combustion Plant subject to Chapter III of IED
MSUL/MSDL	Minimum start up load/minimum shut-down load
NOx	Oxides of nitrogen (NO plus NO <sub>2</sub> expressed as NO <sub>2</sub> )
NPV	Net Present Value
OCGT	Open Cycle Gas Turbine
PHE	Public Health England
SAC	Special Area of Conservation
SGN	Sector guidance note
TGN	Technical guidance note
TNP	Transitional National Plan
TOC	Total Organic Carbon
WFD	Water Framework Directive (2000/60/EC)

## 1 Our decision

We have decided to issue the consolidated variation notice to the Operator. This will allow it to continue to operate the Installation, subject to the conditions in the consolidated variation notice.

We consider that, in reaching that decision, we have taken into account all relevant considerations and legal requirements and that the varied permit will ensure that a high level of protection is provided for the environment and human health.

The consolidated variation notice contains many conditions taken from our standard Environmental Permit template including the relevant Annexes. We developed these conditions in consultation with industry, having regard to the legal requirements of the Environmental Permitting Regulations and other relevant legislation. This document does not therefore include an explanation for these standard conditions. Where they are included in the Notice, we have considered the techniques identified by the operator for the operation of their installation, and have accepted that the details are sufficient and satisfactory to make those standard conditions appropriate. This document does, however, provide an explanation of our use of “tailor-made” or installation-specific conditions, or where our Permit template provides two or more options.

## 2 How we reached our decision

### 2.1 Requesting information to demonstrate compliance with BAT Conclusions for Large Combustion Plant

We issued a Notice under Regulation 61(1) of the Environmental Permitting (England and Wales) Regulations 2016 (a Regulation 61 Notice) on 1<sup>st</sup> May 2018 requiring the Operator to provide information to demonstrate how the operation of their installation currently meets, or will subsequently meet, the revised standards described in the large combustion plant BAT Conclusions document. The Notice also required that where the revised standards are not currently met, the operator should provide information that:

- Describes the techniques that will be implemented before 17<sup>th</sup> August 2021, which will then ensure that operations meet the revised standard, or
- Justifies why standards will not be met by 17<sup>th</sup> August 2021, and confirmation of the date when the operation of those processes will cease within the installation or an explanation of why the revised BAT standard is not applicable to those processes, or
- Justifies why an alternative technique will achieve the same level of environmental protection equivalent to the revised standard described in the BAT Conclusions.

Where the Operator proposed that they were not intending to meet a BAT standard that also included a BAT Associated Emission Level (BAT AEL) described in the BAT Conclusions Document, the Regulation 61 Notice requested that the Operator make a formal request for derogation from compliance with that AEL (as provisioned by Article 15(4) of IED). In this circumstance, the Notice identified that any such request for derogation must be supported and justified by sufficient technical and commercial information that would enable us to determine acceptability of the derogation request.

The Regulation 61 Notice response from the Operator was received on 30 October 2018.

We considered it was in the correct form and contained sufficient information for us to begin our determination of the permit review but not that it necessarily contained all the information we would need to complete that review.

An updated Regulation 61 Notice response from the Operator was received on 12 May 2020. This response contains additional information and supersedes the previous Regulation 61 response. We have based our review on this submission.

## **2.2 Review of our own information in respect to the capability of the installation to meet revised standards included in the BAT Conclusions document**

Based on our records and previous regulatory activities with the facility we have no reason to consider that the operator will not be able to comply with the conditions that we include in the permit.

### 3 The legal framework

The consolidated variation notice will be issued under Regulation 20 of the EPR. The Environmental Permitting regime is a legal vehicle which delivers most of the relevant legal requirements for activities falling within its scope. In particular, the regulated facility is:

- an *installation* as described by the IED;
- subject to aspects of other relevant legislation which also have to be addressed.

We consider that the consolidated variation notice will ensure that the operation of the Installation complies with all relevant legal requirements and that a high level of protection will be delivered for the environment and human health.

We explain how we have addressed specific statutory requirements more fully in the rest of this document.

## 4 The key issues

The key issues arising during this permit review are:

- Emissions to air and the emission limits applied to the plant.
- The energy efficiency levels associated with the Best Available Techniques (BAT-AEELs)

We therefore describe how we determined these issues in most detail in the relevant sections of this document.

### 4.1 Emissions to air and the emission limits applied to the plant

A number of general principles were applied during the permit review. These included:

- The upper value of the BAT AELs ranges specified were used unless use of the tighter limit was justified.
- The principle of no backsliding where if existing limits in the permit were already tighter than those specified in the BREF, the existing permit limits were retained.
- Where a limit was specified in both IED Annex V and the BAT Conclusions for a particular reference period, the tighter limit was applied and in the majority of cases this was from the BAT Conclusions.
- Where AELs are indicative in the BAT Conclusions, these were applied unless adequate justification was provided by the operator to demonstrate that an alternative limit was more appropriate.
- For gas turbines where the IED specified that limits applied over 70% load and the BAT Conclusions specified that AELs applied when dry low NO<sub>x</sub> is effective (DLN-E), we have used DLN-E as a default across all monitoring requirements for NO<sub>x</sub> and CO.

LCP 156 consists of a 120.2 MWth OCGT which vents at emission point A1. The unit burns natural gas only.

The OCGT is limited to 1,500 hours of operation per annum. See section 8 of this document for further information.

The plant was put into operation before/after IED came into force and therefore the existing limits in the permit are from Part 1 of IED Annex V applicable to existing plant.

The ELVs and AELs are based on the following operating regime:

- <1500 hours operation

The following tables outline the limits that have been incorporated into the permit for LCP156, where these were derived from and the reference periods



at which they apply. The emission limits refer to concentrations, expressed as mass of emitted substance per volume of flue-gas under the following standard conditions: dry gas at a temperature of 273,15 K, pressure of 101,3 kPa and 15% volume reference oxygen concentration if flue gases. The emission limits and monitoring requirements have been incorporated into Schedule 3 of the permit.

NOx limits (mg/Nm <sup>3</sup> )							
Averaging	Existing permit (Non-IED limit)	IED (Annex V Part 2) - New	BREF (Table 24 BAT-c)	Expected permit limits	Basis	Limits apply	Monitoring
Monthly	-	50	-	50	IED	DLN-E	Continuous
Daily	50	55	55	50 <sup>Note 1</sup>	Existing limit	DLN-E and MSUL/MSDL to baseload	
95 <sup>th</sup> %ile of hr means	50	100	-	50 <sup>Note 1</sup>	Existing limit	DLN-E	

Note 1: existing permit limits which are tighter than the IED ELV and/or BAT-AEL and are therefore retained under the principle of 'no backsliding'.

CO limits (mg/Nm <sup>3</sup> )							
Averaging	Existing permit (Non-IED limit)	IED (Annex V Part 2) - New	BREF (Table 24 BAT-c)	Expected permit limits	Basis	Limits apply	Monitoring
Monthly	-	100	-	100	IED	DLN-E	Continuous
Daily	100	110	-	100 <sup>Note 1</sup>	Existing limit	DLN-E and MSUL/MSDL to baseload	
95 <sup>th</sup> %ile of hr means	100	200	-	100 <sup>Note 1</sup>	Existing limit	DLN-E	

Note 1: existing permit limits which are tighter than the IED ELV and/or BAT-AEL and are therefore retained under the principle of 'no backsliding'.

#### 4.2 The energy efficiency levels associated with the Best Available Techniques Conclusions

An energy efficiency level associated with the best available techniques (BAT-AEEL) refers to the ratio between the combustion unit's net energy output(s) and the combustion unit's fuel/feedstock energy input at actual unit design. The net energy output(s) is determined at the combustion unit boundaries, including auxiliary systems (e.g. flue-gas treatment systems), and for the unit operated at full load.

The existing permit has no restriction on operating hours and the Regulation 61 response was based on unlimited operational hours. During the permit review, we have introduced a limit on operating hours in Open Cycle Mode for the LCP in line with our guidance 'BAT for Balancing Plant' (refer to section 8 of this document) as we do not consider this mode of operation as BAT for plant operating over 1,500 hours/year.

Footnote 1 of Table 23 of the LCP BAT Conclusions specifies that the BAT AEELs for this type of plant are not applicable as the plant will operate for <1,500 hours/year. Whilst the BAT AEELs do not apply to this plant, we have included the information provided by the Operator.

The table below sets out the BAT AEELs specified in the LCP BAT Conclusions for LCP operating >1,500 hours/year and the energy efficiency levels confirmed through the Regulation 61 notice response. Although not applicable, we consider this plant is BAT in relation to the AEELs.

BAT AEELs (%)			Plant efficiency (%)		
Net electrical efficiency	Net total fuel utilisation	Net mechanical efficiency	Net electrical efficiency	Net total fuel utilisation	Net mechanical efficiency
<b>LCP 156: Open cycle gas turbine ≥ 50 MWth</b>					
33-41.5	None	NA	41.6 ± 1.1	NA	NA

We have included a process monitoring requirement in table S3.3 of the consolidated variation notice. This is required to demonstrate that efficiency levels are maintained following any significant overhauls of equipment in order to fulfil the requirement of BAT Conclusion 2. If the plant operates for <500 hours/year we have specified that the assessment of efficiency can be based on calculation. This is because we will not require plant to fire up with the sole purpose of carrying out an assessment of efficiency.

## 5 Decision checklist regarding relevant BAT Conclusions

BAT Conclusions for large combustion plant, were published by the European Commission on 17<sup>th</sup> August 2017. There are 75 BAT Conclusions. Only the BAT Conclusions relevant to the particular fuel type used on site have been replicated below.

This annex provides a record of decisions made in relation to each relevant BAT Conclusion applicable to the installation. This annex should be read in conjunction with the Consolidated Variation Notice.

The conditions in the permit through which the relevant BAT Conclusions are implemented include but are not limited to the following:

BAT Conclusion requirement topic	Permit condition(s)	Permit table(s)
Environmental Management System	1.1.1	S1.2
BAT AELs	3.1.1 and 3.5.1	S3.1a
Monitoring	2.3, 3.5 and 3.6	S1.2, S1.4, S1.5, S3.1a
Energy efficiency	1.2 and 2.3	S3.3
Noise	2.3 and 3.4	S1.2
Other operating techniques	2.3	S1.2

The overall status of compliance with the BAT conclusion is indicated in the table as:

- NA Not Applicable
- CC Currently Compliant
- FC Compliant in the future (within 4 years of publication of BAT conclusions)
- NC Not Compliant
- PC Partially Compliant

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
<b>General</b>			
1	<p><b>In order to improve the overall environmental performance, BAT is to implement and adhere to an environmental management system (EMS) that incorporates all of the following features:</b></p> <ul style="list-style-type: none"> <li>i. commitment of the management, including senior management;</li> <li>ii. definition of an environmental policy that includes the continuous improvement of the installation by the management;</li> <li>iii. planning and establishing the necessary procedures, objectives and targets, in conjunction with financial planning and investment;</li> <li>iv. implementation of procedures <ul style="list-style-type: none"> <li>(a) Structure and responsibility</li> <li>(b) Training</li> <li>(c) Communication</li> <li>(d) Employee involvement</li> <li>(e) Documentation</li> <li>(f) Efficient process control</li> <li>(g) Maintenance programmes</li> <li>(h) Emergency preparedness and response</li> <li>(i) Safeguarding compliance with environmental legislation</li> </ul> </li> <li>v. checking performance and taking corrective action, paying particular attention to: <ul style="list-style-type: none"> <li>(a) monitoring and measurement (see also the Reference Document on the General Principles of Monitoring)</li> <li>(b) corrective and preventive action</li> <li>(c) maintenance of records</li> <li>(d) independent (where practicable) internal and external auditing in order to determine whether or not the EMS conforms to planned arrangements and has been properly implemented and maintained;</li> </ul> </li> <li>vi. review of the EMS and its continuing suitability, adequacy and effectiveness by senior management;</li> <li>vii. following the development of cleaner technologies;</li> <li>viii. consideration for the environmental impacts from the eventual decommissioning of the installation at the stage of designing a new plant, and throughout its operating life;</li> <li>viii. consideration for the environmental impacts from the eventual decommissioning of the installation at the stage of designing a new plant, and throughout its operating life;</li> <li>ix. application of sectoral benchmarking on a regular basis.</li> </ul> <p>Etc - see BAT Conclusions</p>	FC	<p>There was a change in ownership in 2019 when the company name was changed to Whitetower Energy Limited.</p> <p>From 1 June 2020 the site operations and therefore the EMS will be provided by the new operations and maintenance (O &amp; M) provider, NAES Power Solutions Limited.</p> <p>The existing RWE EMS is compliant with ISO 14001. This EMS is currently in compliance with features i through to xvi of this BAT Conclusion.</p> <p>The Operator has confirmed that, when fully implemented, the NAES EMS will also meet all requirements of BAT Conclusion 1.</p> <p>Due to the change of EMS and the expected implementation timescales, we do not agree with the Operator's stated compliance of CC and have changed the status to FC. We do not consider it necessary to set an improvement condition as we will track progress via compliance. It is expected that the NAES EMS</p>

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement													
	<b>Applicability.</b> The scope (e.g. level of detail) and nature of the EMS (e.g. standardised or non-standardised) will generally be related to the nature, scale and complexity of the installation, and the range of environmental impacts it may have.		will be implemented by 17 August 2021 and that the site will be compliant with BAT Conclusion 1.													
2	BAT is to determine the net electrical efficiency and/or the net total fuel utilisation and/or the net mechanical energy efficiency of the gasification, IGCC and/or combustion units by carrying out a performance test at full load (1), according to EN standards, after the commissioning of the unit and after each modification that could significantly affect the net electrical efficiency and/or the net total fuel utilisation and/or the net mechanical energy efficiency of the unit. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.	CC	<p>An assessment of efficiency was calculated based on efficiency data and determined to be 41.6 (± 1.1%). Reg60 Data submitted 21st July 2015 Calculations of Industrial Trent Efficiency</p> <p>Specific data will be reviewed by the O &amp; M provider and Siemens. Siemens will provide engine performance data. O &amp; M to provide a site efficiency report as a review of historic site data and improvements.</p> <p>A process monitoring requirement has been set in table S3.3 which requires energy efficiency monitoring after an overhaul.</p>													
3	<p><b>BAT is to monitor key process parameters relevant for emissions to air and water including those given below.</b></p> <table border="1" data-bbox="322 1110 1494 1286"> <thead> <tr> <th data-bbox="322 1110 687 1145">Stream</th> <th data-bbox="687 1110 1122 1145">Parameter(s)</th> <th data-bbox="1122 1110 1494 1145">Monitoring</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 1145 687 1251" rowspan="3">Flue-gas</td> <td data-bbox="687 1145 1122 1181">Flow</td> <td data-bbox="1122 1145 1494 1181">Periodic or continuous determination</td> </tr> <tr> <td data-bbox="687 1181 1122 1216">Oxygen content, temperature, and pressure</td> <td data-bbox="1122 1181 1494 1216">Periodic or continuous measurement</td> </tr> <tr> <td data-bbox="687 1216 1122 1251">Water vapour content (%)</td> <td data-bbox="1122 1216 1494 1251"></td> </tr> <tr> <td data-bbox="322 1251 687 1286">Waste water from flue-gas treatment</td> <td data-bbox="687 1251 1122 1286">Flow, pH, and temperature</td> <td data-bbox="1122 1251 1494 1286">Continuous measurement</td> </tr> </tbody> </table>	Stream	Parameter(s)	Monitoring	Flue-gas	Flow	Periodic or continuous determination	Oxygen content, temperature, and pressure	Periodic or continuous measurement	Water vapour content (%)		Waste water from flue-gas treatment	Flow, pH, and temperature	Continuous measurement	CC	<p>MCERT installed CEMS systems (continuous monitoring).</p> <p>Parameters are continuously monitored as required by BAT 3.</p> <p>Flow, Temperature, and Pressure are measured by instruments installed on the Gas Turbine Air system and Gas Fuel system.</p>
Stream	Parameter(s)	Monitoring														
Flue-gas	Flow	Periodic or continuous determination														
	Oxygen content, temperature, and pressure	Periodic or continuous measurement														
	Water vapour content (%)															
Waste water from flue-gas treatment	Flow, pH, and temperature	Continuous measurement														

BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
								<p>Oxygen is measured on a continuous basis by the CEMS analyser.</p> <p>The site does not carry out flue-gas treatment.</p>
4	<p>BAT is to monitor emissions to air with at least the frequency given below and in accordance with EN standards. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.</p>						CC	<p>MCERT installed CEMS systems (continuous monitoring).</p> <p>Parameters are continuously monitored as required by BAT 4.</p> <p>Servicing is carried out to the requirements of EN14181 by the maintenance contractors.</p>
	Substance/Parameter	Fuel/Process/Type of combustion plant	Combustion plant total rated thermal input	Standard(s) <sup>(4)</sup>	Minimum monitoring frequency <sup>(5)</sup>	Monitoring associated with		
NH <sub>3</sub>	— When SCR and/or SNCR is used	All sizes	Generic EN standards	Continuous <sup>(6)</sup> / <sup>(7)</sup>	BAT 7			
NO <sub>x</sub>	<ul style="list-style-type: none"> <li>— Coal and/or lignite including waste co-incineration</li> <li>— Solid biomass and/or peat including waste co-incineration</li> <li>— HFO- and/or gas-oil-fired boilers and engines</li> <li>— Gas-oil-fired gas turbines</li> <li>— Natural-gas-fired boilers, engines, and turbines</li> <li>— Iron and steel process gases</li> <li>— Process fuels from the chemical industry</li> <li>— IGCC plants</li> </ul>	All sizes	Generic EN standards	Continuous <sup>(6)</sup> / <sup>(8)</sup>	BAT 20 BAT 24 BAT 28 BAT 32 BAT 37 BAT 41 BAT 42 BAT 43 BAT 47 BAT 48 BAT 56 BAT 64 BAT 65 BAT 73			
	— Combustion plants on offshore platforms	All sizes	EN 14792	Once every year <sup>(9)</sup>	BAT 53			

BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	N <sub>2</sub> O	<ul style="list-style-type: none"> <li>— Coal and/or lignite in circulating fluidised bed boilers</li> <li>— Solid biomass and/or peat in circulating fluidised bed boilers</li> </ul>	All sizes	EN 21258	Once every year <sup>(10)</sup>	BAT 20 BAT 24		
	CO	<ul style="list-style-type: none"> <li>— Coal and/or lignite including waste co-incineration</li> <li>— Solid biomass and/or peat including waste co-incineration</li> <li>— HFO- and/or gas-oil-fired boilers and engines</li> <li>— Gas-oil-fired gas turbines</li> <li>— Natural-gas-fired boilers, engines, and turbines</li> <li>— Iron and steel process gases</li> <li>— Process fuels from the chemical industry</li> <li>— IGCC plants</li> </ul>	All sizes	Generic EN standards	Continuous <sup>(6)</sup> <sub>(8)</sub>	BAT 20 BAT 24 BAT 28 BAT 33 BAT 38 BAT 44 BAT 49 BAT 56 BAT 64 BAT 65 BAT 73		
		<ul style="list-style-type: none"> <li>— Combustion plants on offshore platforms</li> </ul>	All sizes	EN 15058	Once every year <sup>(9)</sup>	BAT 54		
	SO <sub>2</sub>	<ul style="list-style-type: none"> <li>— Coal and/or lignite incl waste co-incineration</li> <li>— Solid biomass and/or peat incl waste co-incineration</li> <li>— HFO- and/or gas-oil-fired boilers</li> <li>— HFO- and/or gas-oil-fired engines</li> <li>— Gas-oil-fired gas turbines</li> <li>— Iron and steel process gases</li> </ul>	All sizes	Generic EN standards and EN 14791	Continuous <sup>(6)</sup> <sub>(11)</sub> <sub>(12)</sub>	BAT 21 BAT 25 BAT 29 BAT 34 BAT 39 BAT 50 BAT 57 BAT 66 BAT 67 BAT 74		

BAT Concn. Numbe r	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
		<ul style="list-style-type: none"> <li>— Process fuels from the chemical industry in boilers</li> <li>— IGCC plants</li> </ul>						
	SO <sub>3</sub>	<ul style="list-style-type: none"> <li>— When SCR is used</li> </ul>	All sizes	No EN standard available	Once every year	—		
	Gaseous chlorides, expressed as HCl	<ul style="list-style-type: none"> <li>— Coal and/or lignite</li> <li>— Process fuels from the chemical industry in boilers</li> </ul>	All sizes	EN 1911	Once every three months <sup>(6)</sup> <sup>(13)</sup> <sup>(14)</sup>	BAT 21 BAT 57		
		<ul style="list-style-type: none"> <li>— Solid biomass and/or peat</li> </ul>	All sizes	Generic EN standards	Continuous <sup>(15)</sup> <sup>(16)</sup>	BAT 25		
		<ul style="list-style-type: none"> <li>— Waste co-incineration</li> </ul>	All sizes	Generic EN standards	Continuous <sup>(6)</sup> <sup>(16)</sup>	BAT 66 BAT 67		
	HF	<ul style="list-style-type: none"> <li>— Coal and/or lignite</li> <li>— Process fuels from the chemical industry in boilers</li> </ul>	All sizes	No EN standard available	Once every three months <sup>(6)</sup> <sup>(13)</sup> <sup>(14)</sup>	BAT 21 BAT 57		
		<ul style="list-style-type: none"> <li>— Solid biomass and/or peat</li> </ul>	All sizes	No EN standard available	Once every year	BAT 25		
		<ul style="list-style-type: none"> <li>— Waste co-incineration</li> </ul>	All sizes	Generic EN standards	Continuous <sup>(6)</sup> <sup>(16)</sup>	BAT 66 BAT 67		
	Dust	<ul style="list-style-type: none"> <li>— Coal and/or lignite</li> <li>— Solid biomass and/or peat</li> <li>— HFO- and/or gas-oil-fired boilers</li> <li>— Iron and steel process gases</li> <li>— Process fuels from the chemical industry in boilers</li> <li>— IGCC plants</li> <li>— HFO- and/or gas-oil-fired engines</li> </ul>	All sizes	Generic EN standards and EN 13284-1 and EN 13284-2	Continuous <sup>(6)</sup> <sup>(17)</sup>	BAT 22 BAT 26 BAT 30 BAT 35 BAT 39 BAT 51 BAT 58 BAT 75		



BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
		— Gas-oil-fired gas turbines						
		— Waste co-incineration	All sizes	Generic EN standards and EN 13284-2	Continuous	BAT 68 BAT 69		
	Metals and metalloids except mercury (As, Cd, Co, Cr, Cu, Mn, Ni, Pb, Sb, Se, Tl, V, Zn)	— Coal and/or lignite	All sizes	EN 14385	Once every year <sub>(18)</sub>	BAT 22 BAT 26 BAT 30		
		— Solid biomass and/or peat						
		— HFO- and/or gas-oil-fired boilers and engines						
		— Waste co-incineration	< 300 MW <sub>th</sub>	EN 14385	Once every six months <sub>(13)</sub>	BAT 68 BAT 69		
	Hg	— IGCC plants	≥ 300 MW <sub>th</sub>	EN 14385	Once every three months <sub>(19)</sub> <sub>(13)</sub>			
		— Coal and/or lignite including waste co-incineration	< 300 MW <sub>th</sub>	EN 13211	Once every three months <sub>(13)</sub> <sub>(20)</sub>	BAT 23		
			≥ 300 MW <sub>th</sub>	Generic EN standards and EN 14884	Continuous <sub>(16)</sub> <sub>(21)</sub>			
		— Solid biomass and/or peat	All sizes	EN 13211	Once every year <sub>(22)</sub>	BAT 27		
		— Waste co-incineration with solid biomass and/or peat	All sizes	EN 13211	Once every three months <sub>(13)</sub>	BAT 70		
	TVOC	— IGCC plants	≥ 100 MW <sub>th</sub>	EN 13211	Once every year <sub>(23)</sub>	BAT 75		
		— HFO- and/or gas-oil-fired engines	All sizes	EN 12619	Once every six months <sub>(13)</sub>	BAT 33 BAT 59		
		— Process fuels from chemical industry in boilers						
	Formaldehyde	— Waste co-incineration with coal, lignite, solid biomass and/or peat	All sizes	Generic EN standards	Continuous	BAT 71		
		— Natural-gas in spark-ignited lean-burn gas and dual fuel engines	All sizes	No EN standard available	Once every year	BAT 45		

BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																																		
	CH <sub>4</sub>	— Natural-gas-fired engines	All sizes	EN ISO 25139	Once every year <sup>(24)</sup>	BAT 45																																				
	PCDD/F	— Process fuels from chemical industry in boilers — Waste co-incineration	All sizes	EN 1948-1, EN 1948-2, EN 1948-3	Once every six months <sup>(13)</sup> <sup>(25)</sup>	BAT 59 BAT 71																																				
5	<p>BAT is to monitor emissions to water from flue-gas treatment with at least the frequency given below and in accordance with EN standards. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.</p> <table border="1" data-bbox="315 660 1496 1382"> <thead> <tr> <th data-bbox="315 660 667 740">Substance/Parameter</th> <th data-bbox="667 660 1025 740">Standard(s)</th> <th data-bbox="1025 660 1267 740">Minimum monitoring frequency</th> <th data-bbox="1267 660 1496 740">Monitoring associated with</th> </tr> </thead> <tbody> <tr> <td data-bbox="315 740 667 775">Total organic carbon (TOC)<sub>(26)</sub></td> <td data-bbox="667 740 1025 775">EN 1484</td> <td data-bbox="1025 740 1267 1315" rowspan="8">Once every month</td> <td data-bbox="1267 740 1496 1315" rowspan="8">BAT 15</td> </tr> <tr> <td data-bbox="315 775 667 839">Chemical oxygen demand (COD)<sub>(26)</sub></td> <td data-bbox="667 775 1025 839">No EN standard available</td> </tr> <tr> <td data-bbox="315 839 667 874">Total suspended solids (TSS)</td> <td data-bbox="667 839 1025 874">EN 872</td> </tr> <tr> <td data-bbox="315 874 667 909">Fluoride (F<sup>-</sup>)</td> <td data-bbox="667 874 1025 909">EN ISO 10304-1</td> </tr> <tr> <td data-bbox="315 909 667 944">Sulphate (SO<sub>4</sub><sup>2-</sup>)</td> <td data-bbox="667 909 1025 944">EN ISO 10304-1</td> </tr> <tr> <td data-bbox="315 944 667 979">Sulphide, easily released (S<sup>2-</sup>)</td> <td data-bbox="667 944 1025 979">No EN standard available</td> </tr> <tr> <td data-bbox="315 979 667 1015">Sulphite (SO<sub>3</sub><sup>2-</sup>)</td> <td data-bbox="667 979 1025 1015">EN ISO 10304-3</td> </tr> <tr> <td data-bbox="315 1015 667 1315">Metals and metalloids</td> <td data-bbox="667 1015 1025 1315"> <table border="1" data-bbox="600 1015 667 1315"> <tr><td data-bbox="600 1015 667 1050">As</td></tr> <tr><td data-bbox="600 1050 667 1085">Cd</td></tr> <tr><td data-bbox="600 1085 667 1120">Cr</td></tr> <tr><td data-bbox="600 1120 667 1155">Cu</td></tr> <tr><td data-bbox="600 1155 667 1190">Ni</td></tr> <tr><td data-bbox="600 1190 667 1225">Pb</td></tr> <tr><td data-bbox="600 1225 667 1260">Zn</td></tr> <tr><td data-bbox="600 1260 667 1315">Hg</td></tr> </table>           Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)         </td> </tr> <tr> <td data-bbox="315 1315 667 1382">Chloride (Cl<sup>-</sup>)</td> <td data-bbox="667 1315 1025 1382">Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)</td> <td data-bbox="1025 1315 1267 1382"></td> <td data-bbox="1267 1315 1496 1382">—</td> </tr> </tbody> </table>						Substance/Parameter	Standard(s)	Minimum monitoring frequency	Monitoring associated with	Total organic carbon (TOC) <sub>(26)</sub>	EN 1484	Once every month	BAT 15	Chemical oxygen demand (COD) <sub>(26)</sub>	No EN standard available	Total suspended solids (TSS)	EN 872	Fluoride (F <sup>-</sup> )	EN ISO 10304-1	Sulphate (SO <sub>4</sub> <sup>2-</sup> )	EN ISO 10304-1	Sulphide, easily released (S <sup>2-</sup> )	No EN standard available	Sulphite (SO <sub>3</sub> <sup>2-</sup> )	EN ISO 10304-3	Metals and metalloids	<table border="1" data-bbox="600 1015 667 1315"> <tr><td data-bbox="600 1015 667 1050">As</td></tr> <tr><td data-bbox="600 1050 667 1085">Cd</td></tr> <tr><td data-bbox="600 1085 667 1120">Cr</td></tr> <tr><td data-bbox="600 1120 667 1155">Cu</td></tr> <tr><td data-bbox="600 1155 667 1190">Ni</td></tr> <tr><td data-bbox="600 1190 667 1225">Pb</td></tr> <tr><td data-bbox="600 1225 667 1260">Zn</td></tr> <tr><td data-bbox="600 1260 667 1315">Hg</td></tr> </table> Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)	As	Cd	Cr	Cu	Ni	Pb	Zn	Hg	Chloride (Cl <sup>-</sup> )	Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)		—	NA	No applicable as the site does not carry out flue-gas treatment.
Substance/Parameter	Standard(s)	Minimum monitoring frequency	Monitoring associated with																																							
Total organic carbon (TOC) <sub>(26)</sub>	EN 1484	Once every month	BAT 15																																							
Chemical oxygen demand (COD) <sub>(26)</sub>	No EN standard available																																									
Total suspended solids (TSS)	EN 872																																									
Fluoride (F <sup>-</sup> )	EN ISO 10304-1																																									
Sulphate (SO <sub>4</sub> <sup>2-</sup> )	EN ISO 10304-1																																									
Sulphide, easily released (S <sup>2-</sup> )	No EN standard available																																									
Sulphite (SO <sub>3</sub> <sup>2-</sup> )	EN ISO 10304-3																																									
Metals and metalloids	<table border="1" data-bbox="600 1015 667 1315"> <tr><td data-bbox="600 1015 667 1050">As</td></tr> <tr><td data-bbox="600 1050 667 1085">Cd</td></tr> <tr><td data-bbox="600 1085 667 1120">Cr</td></tr> <tr><td data-bbox="600 1120 667 1155">Cu</td></tr> <tr><td data-bbox="600 1155 667 1190">Ni</td></tr> <tr><td data-bbox="600 1190 667 1225">Pb</td></tr> <tr><td data-bbox="600 1225 667 1260">Zn</td></tr> <tr><td data-bbox="600 1260 667 1315">Hg</td></tr> </table> Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)			As	Cd	Cr	Cu	Ni	Pb	Zn	Hg																															
As																																										
Cd																																										
Cr																																										
Cu																																										
Ni																																										
Pb																																										
Zn																																										
Hg																																										
Chloride (Cl <sup>-</sup> )	Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)		—																																							

BAT Concn. Number	Summary of BAT Conclusion requirement				Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																	
	Total nitrogen	EN 12260		—																			
6	<p>In order to improve the general environmental performance of combustion plants and to reduce emissions to air of CO and unburnt substances, BAT is to ensure optimised combustion and to use an appropriate combination of the techniques given below.</p> <table border="1" data-bbox="331 539 1487 1142"> <thead> <tr> <th data-bbox="331 539 555 574">Technique</th> <th data-bbox="555 539 994 574">Description</th> <th data-bbox="994 539 1487 574">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="331 574 555 657">a. Fuel blending and mixing</td> <td data-bbox="555 574 994 657">Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type</td> <td data-bbox="994 574 1487 657" rowspan="2">Generally applicable</td> </tr> <tr> <td data-bbox="331 657 555 740">b. Maintenance of the combustion system</td> <td data-bbox="555 657 994 740">Regular planned maintenance according to suppliers' recommendations</td> </tr> <tr> <td data-bbox="331 740 555 823">c. Advanced control system</td> <td data-bbox="555 740 994 823">See description in Section 8.1</td> <td data-bbox="994 740 1487 823">The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> <tr> <td data-bbox="331 823 555 906">d. Good design of the combustion equipment</td> <td data-bbox="555 823 994 906">Good design of furnace, combustion chambers, burners and associated devices</td> <td data-bbox="994 823 1487 906">Generally applicable to new combustion plants</td> </tr> <tr> <td data-bbox="331 906 555 1142">e. Fuel choice</td> <td data-bbox="555 906 994 1142">Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used</td> <td data-bbox="994 906 1487 1142">Applicable within the constraints associated with the availability of suitable types of fuel with a better environmental profile as a whole, which may be impacted by the energy policy of the Member State, or by the integrated site's fuel balance in the case of combustion of industrial process fuels. For existing combustion plants, the type of fuel chosen may be limited by the configuration and the design of the plant</td> </tr> </tbody> </table>				Technique	Description	Applicability	a. Fuel blending and mixing	Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type	Generally applicable	b. Maintenance of the combustion system	Regular planned maintenance according to suppliers' recommendations	c. Advanced control system	See description in Section 8.1	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system	d. Good design of the combustion equipment	Good design of furnace, combustion chambers, burners and associated devices	Generally applicable to new combustion plants	e. Fuel choice	Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used	Applicable within the constraints associated with the availability of suitable types of fuel with a better environmental profile as a whole, which may be impacted by the energy policy of the Member State, or by the integrated site's fuel balance in the case of combustion of industrial process fuels. For existing combustion plants, the type of fuel chosen may be limited by the configuration and the design of the plant	CC	<p>The Operator confirmed that:</p> <p>a) Fuel blending - not applicable</p> <p>b) Maintenance of combustion system - maintenance of the gas turbine is undertaken to maintain environmental performance. This includes camera inspections and combustion tuning, with improvements carried out through a service agreement.</p> <p>c) Advanced control system – the gas turbine is controlled with an engine management system which is maintained through a service agreement.</p> <p>d) Good design of combustion equipment – the gas turbine is fitted with a three stage DLN combustion system to provide combustion stability and emissions performance.</p> <p>e) Fuel choice – the gas turbine can only operate on natural gas.</p>
Technique	Description	Applicability																					
a. Fuel blending and mixing	Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type	Generally applicable																					
b. Maintenance of the combustion system	Regular planned maintenance according to suppliers' recommendations																						
c. Advanced control system	See description in Section 8.1	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system																					
d. Good design of the combustion equipment	Good design of furnace, combustion chambers, burners and associated devices	Generally applicable to new combustion plants																					
e. Fuel choice	Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used	Applicable within the constraints associated with the availability of suitable types of fuel with a better environmental profile as a whole, which may be impacted by the energy policy of the Member State, or by the integrated site's fuel balance in the case of combustion of industrial process fuels. For existing combustion plants, the type of fuel chosen may be limited by the configuration and the design of the plant																					

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
7	<p>In order to reduce emissions of ammonia to air from the use of selective catalytic reduction (SCR) and/or selective non-catalytic reduction (SNCR) for the abatement of NO<sub>x</sub> emissions, BAT is to optimise the design and/or operation of SCR and/or SNCR (e.g. optimised reagent to NO<sub>x</sub> ratio, homogeneous reagent distribution and optimum size of the reagent drops).</p> <p><b>BAT-associated emission levels</b></p> <p>The BAT-associated emission level (BAT-AEL) for emissions of NH<sub>3</sub> to air from the use of SCR and/or SNCR is &lt; 3–10 mg/Nm<sup>3</sup> as a yearly average or average over the sampling period. The lower end of the range can be achieved when using SCR and the upper end of the range can be achieved when using SNCR without wet abatement techniques. In the case of plants combusting biomass and operating at variable loads as well as in the case of engines combusting HFO and/or gas oil, the higher end of the BAT-AEL range is 15 mg/Nm<sup>3</sup>.</p>	NA	Not applicable - no SCR or SNCR on site.
8	<p>In order to prevent or reduce emissions to air during normal operating conditions, BAT is to ensure, by appropriate design, operation and maintenance, that the emission abatement systems are used at optimal capacity and availability.</p>	NA	<p>Not applicable - no abatement systems are installed.</p> <p>The Operator confirmed that, gas turbine servicing and engine tuning is undertaken. Also, engines are run at full load capacity, therefore most efficient running. They do not run at reduced load.</p>
9	<p>In order to improve the general environmental performance of combustion and/or gasification plants and to reduce emissions to air, BAT is to include the following elements in the quality assurance/quality control programmes for all the fuels used, as part of the environmental management system (see BAT 1):</p> <ul style="list-style-type: none"> <li>(i) Initial full characterisation of the fuel used including at least the parameters listed below and in accordance with EN standards. ISO, national or other international standards may be used provided they ensure the provision of data of an equivalent scientific quality;</li> <li>(ii) Regular testing of the fuel quality to check that it is consistent with the initial characterisation and according to the plant design specifications. The frequency of testing and the parameters chosen from the table below are based on the variability of the fuel and an assessment of the relevance of pollutant releases (e.g. concentration in fuel, flue-gas treatment employed);</li> </ul>	CC	<p>The Operator confirmed that:</p> <ul style="list-style-type: none"> <li>i) and ii) All fuel gas is supplied through the national gas networks. National inventory data is used for quality measurement. There are no alternative fuels for the gas turbine.</li> <li>iii) Gas turbine engine tuning is carried out by the O &amp; M service provider.</li> </ul>

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																							
	<p>(iii) Subsequent adjustment of the plant settings as and when needed and practicable (e.g. integration of the fuel characterisation and control in the advanced control system (see description in Section 8.1)).</p> <p><b>Description</b> Initial characterisation and regular testing of the fuel can be performed by the operator and/or the fuel supplier. If performed by the supplier, the full results are provided to the operator in the form of a product (fuel) supplier specification and/or guarantee.</p> <table border="1" data-bbox="322 555 1496 1342"> <thead> <tr> <th data-bbox="322 555 712 592">Fuel(s)</th> <th data-bbox="712 555 1496 592">Substances/Parameters subject to characterisation</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 592 712 794" rowspan="4">Biomass/peat</td> <td data-bbox="712 592 1496 628">— LHV</td> </tr> <tr> <td data-bbox="712 628 1496 675">— moisture</td> </tr> <tr> <td data-bbox="712 675 1496 711">— Ash</td> </tr> <tr> <td data-bbox="712 711 1496 794">— C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn)</td> </tr> <tr> <td data-bbox="322 794 712 1010" rowspan="4">Coal/lignite</td> <td data-bbox="712 794 1496 831">— LHV</td> </tr> <tr> <td data-bbox="712 831 1496 868">— Moisture</td> </tr> <tr> <td data-bbox="712 868 1496 914">— Volatiles, ash, fixed carbon, C, H, N, O, S</td> </tr> <tr> <td data-bbox="712 914 1496 1010">— Br, Cl, F — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)</td> </tr> <tr> <td data-bbox="322 1010 712 1094" rowspan="2">HFO</td> <td data-bbox="712 1010 1496 1046">— Ash</td> </tr> <tr> <td data-bbox="712 1046 1496 1094">— C, S, N, Ni, V</td> </tr> <tr> <td data-bbox="322 1094 712 1179" rowspan="2">Gas oil</td> <td data-bbox="712 1094 1496 1131">— Ash</td> </tr> <tr> <td data-bbox="712 1131 1496 1179">— N, C, S</td> </tr> <tr> <td data-bbox="322 1179 712 1264" rowspan="2">Natural gas</td> <td data-bbox="712 1179 1496 1216">— LHV</td> </tr> <tr> <td data-bbox="712 1216 1496 1264">— CH<sub>4</sub>, C<sub>2</sub>H<sub>6</sub>, C<sub>3</sub>, C<sub>4+</sub>, CO<sub>2</sub>, N<sub>2</sub>, Wobbe index</td> </tr> <tr> <td data-bbox="322 1264 712 1342">Process fuels from the chemical industry<sup>(27)</sup></td> <td data-bbox="712 1264 1496 1342">— Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)</td> </tr> </tbody> </table>	Fuel(s)	Substances/Parameters subject to characterisation	Biomass/peat	— LHV	— moisture	— Ash	— C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn)	Coal/lignite	— LHV	— Moisture	— Volatiles, ash, fixed carbon, C, H, N, O, S	— Br, Cl, F — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)	HFO	— Ash	— C, S, N, Ni, V	Gas oil	— Ash	— N, C, S	Natural gas	— LHV	— CH <sub>4</sub> , C <sub>2</sub> H <sub>6</sub> , C <sub>3</sub> , C <sub>4+</sub> , CO <sub>2</sub> , N <sub>2</sub> , Wobbe index	Process fuels from the chemical industry <sup>(27)</sup>	— Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)		We consider that for plants which burn natural gas from the National Grid as a fuel that it is not necessary for the operator to replicate the testing carried out by the National Grid
Fuel(s)	Substances/Parameters subject to characterisation																									
Biomass/peat	— LHV																									
	— moisture																									
	— Ash																									
	— C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn)																									
Coal/lignite	— LHV																									
	— Moisture																									
	— Volatiles, ash, fixed carbon, C, H, N, O, S																									
	— Br, Cl, F — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)																									
HFO	— Ash																									
	— C, S, N, Ni, V																									
Gas oil	— Ash																									
	— N, C, S																									
Natural gas	— LHV																									
	— CH <sub>4</sub> , C <sub>2</sub> H <sub>6</sub> , C <sub>3</sub> , C <sub>4+</sub> , CO <sub>2</sub> , N <sub>2</sub> , Wobbe index																									
Process fuels from the chemical industry <sup>(27)</sup>	— Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)																									

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement						
	<table border="1"> <tr> <td data-bbox="324 387 712 456">Iron and steel process gases</td> <td data-bbox="723 387 1494 456">— LHV, CH<sub>4</sub> (for COG), C<sub>x</sub>H<sub>y</sub> (for COG), CO<sub>2</sub>, H<sub>2</sub>, N<sub>2</sub>, total sulphur, dust, Wobbe index</td> </tr> <tr> <td data-bbox="324 464 712 612">Waste<sup>(28)</sup></td> <td data-bbox="723 464 1494 612"> <ul style="list-style-type: none"> <li>— LHV</li> <li>— Moisture</li> <li>— Volatiles, ash, Br, C, Cl, F, H, N, O, S</li> <li>— Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Ti, V, Zn)</li> </ul> </td> </tr> </table>	Iron and steel process gases	— LHV, CH <sub>4</sub> (for COG), C <sub>x</sub> H <sub>y</sub> (for COG), CO <sub>2</sub> , H <sub>2</sub> , N <sub>2</sub> , total sulphur, dust, Wobbe index	Waste <sup>(28)</sup>	<ul style="list-style-type: none"> <li>— LHV</li> <li>— Moisture</li> <li>— Volatiles, ash, Br, C, Cl, F, H, N, O, S</li> <li>— Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Ti, V, Zn)</li> </ul>				
Iron and steel process gases	— LHV, CH <sub>4</sub> (for COG), C <sub>x</sub> H <sub>y</sub> (for COG), CO <sub>2</sub> , H <sub>2</sub> , N <sub>2</sub> , total sulphur, dust, Wobbe index								
Waste <sup>(28)</sup>	<ul style="list-style-type: none"> <li>— LHV</li> <li>— Moisture</li> <li>— Volatiles, ash, Br, C, Cl, F, H, N, O, S</li> <li>— Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Ti, V, Zn)</li> </ul>								
10	<p>In order to reduce emissions to air and/or to water during other than normal operating conditions (OTNOC), BAT is to set up and implement a management plan as part of the environmental management system (see BAT 1), commensurate with the relevance of potential pollutant releases, that includes the following elements:</p> <ul style="list-style-type: none"> <li>— appropriate design of the systems considered relevant in causing OTNOC that may have an impact on emissions to air, water and/or soil (e.g. low-load design concepts for reducing the minimum start-up and shutdown loads for stable generation in gas turbines),</li> <li>— set-up and implementation of a specific preventive maintenance plan for these relevant systems,</li> <li>— review and recording of emissions caused by OTNOC and associated circumstances and implementation of corrective actions if necessary,</li> <li>— periodic assessment of the overall emissions during OTNOC (e.g. frequency of events, duration, emissions quantification/estimation) and implementation of corrective actions if necessary.</li> </ul>	CC	<p>The OCGT is shut down for investigation in the event of abnormal emissions.</p> <p>Operation of the Gas Turbine is designed to keep start up times and to engine testing durations to a minimum.</p> <p>The energy supply contracts are for peaking operations, which reduces operational hours.</p>						
11	<p>BAT is to appropriately monitor emissions to air and/or to water during OTNOC.</p> <p><b>Description</b></p> <p>The monitoring can be carried out by direct measurement of emissions or by monitoring of surrogate parameters if this proves to be of equal or better scientific quality than the direct measurement of emissions. Emissions during start-up and shutdown (SU/SD) may be assessed based on a detailed emission measurement carried out for a typical SU/SD procedure at least once every year, and using the results of this measurement to estimate the emissions for each and every SU/SD throughout the year.</p>	CC	<p>The OCGT is shut down for investigation in the event of abnormal emissions.</p> <p>The plant is not operated when the CEMS is out of service as no alternative method of analysis is available.</p>						
12	<p>In order to increase the energy efficiency of combustion, gasification and/or IGCC units operated ≥ 1 500 h/yr, BAT is to use an appropriate combination of the techniques given below.</p> <table border="1" data-bbox="324 1310 1494 1345"> <thead> <tr> <th data-bbox="324 1310 577 1345">Technique</th> <th data-bbox="589 1310 1055 1345">Description</th> <th data-bbox="1066 1310 1494 1345">Applicability</th> </tr> </thead> <tbody> <tr> <td> </td> <td> </td> <td> </td> </tr> </tbody> </table>	Technique	Description	Applicability				CC	<p>The Operator confirmed that:</p> <p>a) Combustion optimisation - gas turbine performance is monitored by the O &amp; M provider who</p>
Technique	Description	Applicability							

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	a.	Combustion optimisation	See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues	Generally applicable	<p>recommend any actions to maintain / improve performance.</p> <p>b) Optimisation of working medium conditions – the gas turbine engine is controlled with an engine management system which is maintained through a service agreement.</p> <p>d) Minimisation of energy consumption - routine checks of the fuel usage are carried out to compare historic data to measure gas turbine performance technically and commercially.</p> <p>p) Minimisation of heat loss - gas fuel pipe-work is insulated after the gas compression.</p> <p>q) Advanced materials – the gas turbine is engineered from aero derivative based technology and uses the same materials and technologies.</p> <p>The site operates in open cycle mode only and is not capable of CCGT/ CHP operations so some techniques do not apply.</p> <p>We agree with the Operator's stated compliance that an appropriate combination of techniques are being used.</p>
b.	Optimisation of the working medium conditions	Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO <sub>x</sub> emissions or the characteristics of energy demanded			
c.	Optimisation of the steam cycle	Operate with lower turbine exhaust pressure by utilisation of the lowest possible temperature of the condenser cooling water, within the design conditions			
d.	Minimisation of energy consumption	Minimising the internal energy consumption (e.g. greater efficiency of the feed-water pump)			
e.	Preheating of combustion air	Reuse of part of the heat recovered from the combustion flue-gas to preheat the air used in combustion	Generally applicable within the constraints related to the need to control NO <sub>x</sub> emissions		
f.	Fuel preheating	Preheating of fuel using recovered heat	Generally applicable within the constraints associated with the boiler design and the need to control NO <sub>x</sub> emissions		
g.	Advanced control system	See description in Section 8.2. Computerised control of the main combustion parameters enables the combustion efficiency to be improved	Generally applicable to new units. The applicability to old units may be constrained by the need to retrofit the combustion system and/or control command system		
h.	Feed-water preheating using recovered heat	Preheat water coming out of the steam condenser with recovered heat, before reusing it in the boiler	Only applicable to steam circuits and not to hot boilers. Applicability to existing units may be limited due to constraints associated with the plant configuration and the amount of recoverable heat		
i.	Heat recovery by cogeneration (CHP)	Recovery of heat (mainly from the steam system) for producing hot water/steam to be used in industrial processes/activities or in a public network for district heating. Additional heat recovery is possible from:	Applicable within the constraints associated with the local heat and power demand. The applicability may be limited in the case of gas compressors with an unpredictable operational heat profile		

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
			<ul style="list-style-type: none"> <li>— flue-gas</li> <li>— grate cooling</li> <li>— circulating fluidised bed</li> </ul>		
	j.	CHP readiness	See description in Section 8.2.	Only applicable to new units where there is a realistic potential for the future use of heat in the vicinity of the unit	
	k.	Flue-gas condenser	See description in Section 8.2.	Generally applicable to CHP units provided there is enough demand for low-temperature heat	
	l.	Heat accumulation	Heat accumulation storage in CHP mode	Only applicable to CHP plants. The applicability may be limited in the case of low heat load demand	
	m.	Wet stack	See description in Section 8.2.	Generally applicable to new and existing units fitted with wet FGD	
	n.	Cooling tower discharge	The release of emissions to air through a cooling tower and not via a dedicated stack	Only applicable to units fitted with wet FGD where reheating of the flue-gas is necessary before release, and where the unit cooling system is a cooling tower	
	o.	Fuel pre-drying	The reduction of fuel moisture content before combustion to improve combustion conditions	Applicable to the combustion of biomass and/or peat within the constraints associated with spontaneous combustion risks (e.g. the moisture content of peat is kept above 40 % throughout the delivery chain). The retrofit of existing plants may be restricted by the extra calorific value that can be obtained from the drying operation and by the limited retrofit possibilities offered by some boiler designs or plant configurations	
	p.	Minimisation of heat losses	Minimising residual heat losses, e.g. those that occur via the slag or those that can be reduced by insulating radiating sources	Only applicable to solid-fuel-fired combustion units and to gasification/IGCC units	
	q.	Advanced materials	Use of advanced materials proven to be capable of withstanding high operating temperatures and pressures and thus to achieve increased steam/combustion process efficiencies	Only applicable to new plants	



BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	
	r.	Steam turbine upgrades	This includes techniques such as increasing the temperature and pressure of medium-pressure steam, addition of a low-pressure turbine, and modifications to the geometry of the turbine rotor blades	The applicability may be restricted by demand, steam conditions and/or limited plant lifetime		
	s.	Supercritical and ultra-supercritical steam conditions	Use of a steam circuit, including steam reheating systems, in which steam can reach pressures above 220,6 bar and temperatures above 374 °C in the case of supercritical conditions, and above 250 – 300 bar and temperatures above 580 – 600 °C in the case of ultra-supercritical conditions	Only applicable to new units of $\geq 600 \text{ MW}_{\text{th}}$ operated $> 4\,000 \text{ h/yr}$ . Not applicable when the purpose of the unit is to produce low steam temperatures and/or pressures in process industries. Not applicable to gas turbines and engines generating steam in CHP mode. For units combusting biomass, the applicability may be constrained by high-temperature corrosion in the case of certain biomasses		
13	In order to reduce water usage and the volume of contaminated waste water discharged, BAT is to use one or both of the techniques given below.			CC	Contents of plant blind sump is removed and tankered off site as required for recycling. This equates to approximately four tonnes per year.	
		<b>Technique</b>	<b>Description</b>	<b>Applicability</b>		
	a.	Water recycling	Residual aqueous streams, including run-off water, from the plant are reused for other purposes. The degree of recycling is limited by the quality requirements of the recipient water stream and the water balance of the plant	Not applicable to waste water from cooling systems when water treatment chemicals and/or high concentrations of salts from seawater are present		
	b.	Dry bottom ash handling	Dry, hot bottom ash falls from the furnace onto a mechanical conveyor system and is cooled down by ambient air. No water is used in the process.	Only applicable to plants combusting solid fuels. There may be technical restrictions that prevent retrofitting to existing combustion plants		
14	In order to prevent the contamination of uncontaminated waste water and to reduce emissions to water, BAT is to segregate waste water streams and to treat them separately, depending on the pollutant content. <b>Description</b> Waste water streams that are typically segregated and treated include surface run-off water, cooling water, and waste water from flue-gas treatment. <b>Applicability</b> The applicability may be restricted in the case of existing plants due to the configuration of the drainage systems.			CC	Foul Water is piped off site through local sewage network via an oil/water interceptor. Rain water runoff is via site outlet point, site sumps are visually inspected for condition before discharge.	

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																																																			
15	<p>In order to reduce emissions to water from flue-gas treatment, BAT is to use an appropriate combination of the techniques given below, and to use secondary techniques as close as possible to the source in order to avoid dilution.</p> <table border="1" data-bbox="320 469 1494 1358"> <thead> <tr> <th data-bbox="320 469 712 528">Technique</th> <th data-bbox="712 469 1025 528">Typical pollutants prevented/abated</th> <th data-bbox="1025 469 1494 528">Applicability</th> </tr> </thead> <tbody> <tr> <td colspan="3" data-bbox="320 528 1494 563" style="text-align: center;"><b>Primary techniques</b></td> </tr> <tr> <td data-bbox="320 563 371 651">a.</td> <td data-bbox="371 563 712 651">Optimised combustion (see BAT 6) and flue-gas treatment systems (e.g. SCR/SNCR, see BAT 7)</td> <td data-bbox="712 563 1025 651">Organic compounds, ammonia (NH<sub>3</sub>)</td> </tr> <tr> <td colspan="3" data-bbox="320 651 1494 686" style="text-align: center;"><b>Secondary techniques <sup>(29)</sup></b></td> </tr> <tr> <td data-bbox="320 686 371 746">b.</td> <td data-bbox="371 686 712 746">Adsorption on activated carbon</td> <td data-bbox="712 686 1025 746">Organic compounds, mercury (Hg)</td> </tr> <tr> <td data-bbox="320 746 371 879">c.</td> <td data-bbox="371 746 712 879">Aerobic biological treatment</td> <td data-bbox="712 746 1494 879">Biodegradable organic compounds, ammonium (NH<sub>4</sub><sup>+</sup>)</td> </tr> <tr> <td data-bbox="320 879 371 940">d.</td> <td data-bbox="371 879 712 940">Anoxic/anaerobic biological treatment</td> <td data-bbox="712 879 1025 940">Mercury (Hg), nitrate (NO<sub>3</sub><sup>-</sup>), nitrite (NO<sub>2</sub><sup>-</sup>)</td> </tr> <tr> <td data-bbox="320 940 371 970">e.</td> <td data-bbox="371 940 712 970">Coagulation and flocculation</td> <td data-bbox="712 940 1025 970">Suspended solids</td> </tr> <tr> <td data-bbox="320 970 371 1031">f.</td> <td data-bbox="371 970 712 1031">Crystallisation</td> <td data-bbox="712 970 1025 1031">Metals and metalloids, sulphate (SO<sub>4</sub><sup>2-</sup>), fluoride (F<sup>-</sup>)</td> </tr> <tr> <td data-bbox="320 1031 371 1091">g.</td> <td data-bbox="371 1031 712 1091">Filtration (e.g. sand filtration, microfiltration, ultrafiltration)</td> <td data-bbox="712 1031 1025 1091">Suspended solids, metals</td> </tr> <tr> <td data-bbox="320 1091 371 1121">h.</td> <td data-bbox="371 1091 712 1121">Flotation</td> <td data-bbox="712 1091 1025 1121">Suspended solids, free oil</td> </tr> <tr> <td data-bbox="320 1121 371 1152">i.</td> <td data-bbox="371 1121 712 1152">Ion exchange</td> <td data-bbox="712 1121 1025 1152">Metals</td> </tr> <tr> <td data-bbox="320 1152 371 1182">j.</td> <td data-bbox="371 1152 712 1182">Neutralisation</td> <td data-bbox="712 1152 1025 1182">Acids, alkalis</td> </tr> <tr> <td data-bbox="320 1182 371 1212">k.</td> <td data-bbox="371 1182 712 1212">Oxidation</td> <td data-bbox="712 1182 1025 1212">Sulphide (S<sup>2-</sup>), sulphite (SO<sub>3</sub><sup>2-</sup>)</td> </tr> <tr> <td data-bbox="320 1212 371 1243">l.</td> <td data-bbox="371 1212 712 1243">Precipitation</td> <td data-bbox="712 1212 1025 1243">Metals and metalloids, sulphate (SO<sub>4</sub><sup>2-</sup>), fluoride (F<sup>-</sup>)</td> </tr> <tr> <td data-bbox="320 1243 371 1273">m.</td> <td data-bbox="371 1243 712 1273">Sedimentation</td> <td data-bbox="712 1243 1025 1273">Suspended solids</td> </tr> <tr> <td data-bbox="320 1273 371 1303">n.</td> <td data-bbox="371 1273 712 1303">Stripping</td> <td data-bbox="712 1273 1025 1303">Ammonia (NH<sub>3</sub>)</td> </tr> </tbody> </table>	Technique	Typical pollutants prevented/abated	Applicability	<b>Primary techniques</b>			a.	Optimised combustion (see BAT 6) and flue-gas treatment systems (e.g. SCR/SNCR, see BAT 7)	Organic compounds, ammonia (NH <sub>3</sub> )	<b>Secondary techniques <sup>(29)</sup></b>			b.	Adsorption on activated carbon	Organic compounds, mercury (Hg)	c.	Aerobic biological treatment	Biodegradable organic compounds, ammonium (NH <sub>4</sub> <sup>+</sup> )	d.	Anoxic/anaerobic biological treatment	Mercury (Hg), nitrate (NO <sub>3</sub> <sup>-</sup> ), nitrite (NO <sub>2</sub> <sup>-</sup> )	e.	Coagulation and flocculation	Suspended solids	f.	Crystallisation	Metals and metalloids, sulphate (SO <sub>4</sub> <sup>2-</sup> ), fluoride (F <sup>-</sup> )	g.	Filtration (e.g. sand filtration, microfiltration, ultrafiltration)	Suspended solids, metals	h.	Flotation	Suspended solids, free oil	i.	Ion exchange	Metals	j.	Neutralisation	Acids, alkalis	k.	Oxidation	Sulphide (S <sup>2-</sup> ), sulphite (SO <sub>3</sub> <sup>2-</sup> )	l.	Precipitation	Metals and metalloids, sulphate (SO <sub>4</sub> <sup>2-</sup> ), fluoride (F <sup>-</sup> )	m.	Sedimentation	Suspended solids	n.	Stripping	Ammonia (NH <sub>3</sub> )	NA	Not applicable – no flue gas treatment undertaken on site
Technique	Typical pollutants prevented/abated	Applicability																																																				
<b>Primary techniques</b>																																																						
a.	Optimised combustion (see BAT 6) and flue-gas treatment systems (e.g. SCR/SNCR, see BAT 7)	Organic compounds, ammonia (NH <sub>3</sub> )																																																				
<b>Secondary techniques <sup>(29)</sup></b>																																																						
b.	Adsorption on activated carbon	Organic compounds, mercury (Hg)																																																				
c.	Aerobic biological treatment	Biodegradable organic compounds, ammonium (NH <sub>4</sub> <sup>+</sup> )																																																				
d.	Anoxic/anaerobic biological treatment	Mercury (Hg), nitrate (NO <sub>3</sub> <sup>-</sup> ), nitrite (NO <sub>2</sub> <sup>-</sup> )																																																				
e.	Coagulation and flocculation	Suspended solids																																																				
f.	Crystallisation	Metals and metalloids, sulphate (SO <sub>4</sub> <sup>2-</sup> ), fluoride (F <sup>-</sup> )																																																				
g.	Filtration (e.g. sand filtration, microfiltration, ultrafiltration)	Suspended solids, metals																																																				
h.	Flotation	Suspended solids, free oil																																																				
i.	Ion exchange	Metals																																																				
j.	Neutralisation	Acids, alkalis																																																				
k.	Oxidation	Sulphide (S <sup>2-</sup> ), sulphite (SO <sub>3</sub> <sup>2-</sup> )																																																				
l.	Precipitation	Metals and metalloids, sulphate (SO <sub>4</sub> <sup>2-</sup> ), fluoride (F <sup>-</sup> )																																																				
m.	Sedimentation	Suspended solids																																																				
n.	Stripping	Ammonia (NH <sub>3</sub> )																																																				

BAT Concn. Numbe r	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																																												
	<p>The BAT-AELs refer to direct discharges to a receiving water body at the point where the emission leaves the installation.</p> <p style="text-align: center;"><b>BAT-AELs for direct discharges to a receiving water body from flue-gas treatment</b></p> <table border="1" data-bbox="322 469 1491 1059"> <thead> <tr> <th colspan="2" data-bbox="322 469 976 501">Substance/Parameter</th> <th data-bbox="976 469 1491 501">BAT-AELs</th> </tr> <tr> <th colspan="2"></th> <th data-bbox="976 501 1491 533">Daily average</th> </tr> </thead> <tbody> <tr> <td colspan="2" data-bbox="322 533 976 564">Total organic carbon (TOC)</td> <td data-bbox="976 533 1491 564">20–50 mg/l <sup>(30)</sup> <sup>(31)</sup> <sup>(32)</sup></td> </tr> <tr> <td colspan="2" data-bbox="322 564 976 596">Chemical oxygen demand (COD)</td> <td data-bbox="976 564 1491 596">60–150 mg/l <sup>(30)</sup> <sup>(31)</sup> <sup>(32)</sup></td> </tr> <tr> <td colspan="2" data-bbox="322 596 976 628">Total suspended solids (TSS)</td> <td data-bbox="976 596 1491 628">10–30 mg/l</td> </tr> <tr> <td colspan="2" data-bbox="322 628 976 660">Fluoride (F<sup>-</sup>)</td> <td data-bbox="976 628 1491 660">10–25 mg/l <sup>(32)</sup></td> </tr> <tr> <td colspan="2" data-bbox="322 660 976 692">Sulphate (SO<sub>4</sub><sup>2-</sup>)</td> <td data-bbox="976 660 1491 692">1,3–2,0 g/l <sup>(32)</sup> <sup>(33)</sup> <sup>(34)</sup> <sup>(35)</sup></td> </tr> <tr> <td colspan="2" data-bbox="322 692 976 724">Sulphide (S<sup>2-</sup>), easily released</td> <td data-bbox="976 692 1491 724">0,1–0,2 mg/l <sup>(32)</sup></td> </tr> <tr> <td colspan="2" data-bbox="322 724 976 756">Sulphite (SO<sub>3</sub><sup>2-</sup>)</td> <td data-bbox="976 724 1491 756">1–20 mg/l <sup>(32)</sup></td> </tr> <tr> <td data-bbox="322 756 875 1059" rowspan="8">Metals and metalloids</td> <td data-bbox="875 756 976 788">As</td> <td data-bbox="976 756 1491 788">10–50 µg/l</td> </tr> <tr> <td data-bbox="875 788 976 820">Cd</td> <td data-bbox="976 788 1491 820">2–5 µg/l</td> </tr> <tr> <td data-bbox="875 820 976 852">Cr</td> <td data-bbox="976 820 1491 852">10–50 µg/l</td> </tr> <tr> <td data-bbox="875 852 976 884">Cu</td> <td data-bbox="976 852 1491 884">10–50 µg/l</td> </tr> <tr> <td data-bbox="875 884 976 916">Hg</td> <td data-bbox="976 884 1491 916">0,2–3 µg/l</td> </tr> <tr> <td data-bbox="875 916 976 948">Ni</td> <td data-bbox="976 916 1491 948">10–50 µg/l</td> </tr> <tr> <td data-bbox="875 948 976 979">Pb</td> <td data-bbox="976 948 1491 979">10–20 µg/l</td> </tr> <tr> <td data-bbox="875 979 976 1059">Zn</td> <td data-bbox="976 979 1491 1059">50–200 µg/l</td> </tr> </tbody> </table>	Substance/Parameter		BAT-AELs			Daily average	Total organic carbon (TOC)		20–50 mg/l <sup>(30)</sup> <sup>(31)</sup> <sup>(32)</sup>	Chemical oxygen demand (COD)		60–150 mg/l <sup>(30)</sup> <sup>(31)</sup> <sup>(32)</sup>	Total suspended solids (TSS)		10–30 mg/l	Fluoride (F <sup>-</sup> )		10–25 mg/l <sup>(32)</sup>	Sulphate (SO <sub>4</sub> <sup>2-</sup> )		1,3–2,0 g/l <sup>(32)</sup> <sup>(33)</sup> <sup>(34)</sup> <sup>(35)</sup>	Sulphide (S <sup>2-</sup> ), easily released		0,1–0,2 mg/l <sup>(32)</sup>	Sulphite (SO <sub>3</sub> <sup>2-</sup> )		1–20 mg/l <sup>(32)</sup>	Metals and metalloids	As	10–50 µg/l	Cd	2–5 µg/l	Cr	10–50 µg/l	Cu	10–50 µg/l	Hg	0,2–3 µg/l	Ni	10–50 µg/l	Pb	10–20 µg/l	Zn	50–200 µg/l		
Substance/Parameter		BAT-AELs																																													
		Daily average																																													
Total organic carbon (TOC)		20–50 mg/l <sup>(30)</sup> <sup>(31)</sup> <sup>(32)</sup>																																													
Chemical oxygen demand (COD)		60–150 mg/l <sup>(30)</sup> <sup>(31)</sup> <sup>(32)</sup>																																													
Total suspended solids (TSS)		10–30 mg/l																																													
Fluoride (F <sup>-</sup> )		10–25 mg/l <sup>(32)</sup>																																													
Sulphate (SO <sub>4</sub> <sup>2-</sup> )		1,3–2,0 g/l <sup>(32)</sup> <sup>(33)</sup> <sup>(34)</sup> <sup>(35)</sup>																																													
Sulphide (S <sup>2-</sup> ), easily released		0,1–0,2 mg/l <sup>(32)</sup>																																													
Sulphite (SO <sub>3</sub> <sup>2-</sup> )		1–20 mg/l <sup>(32)</sup>																																													
Metals and metalloids	As	10–50 µg/l																																													
	Cd	2–5 µg/l																																													
	Cr	10–50 µg/l																																													
	Cu	10–50 µg/l																																													
	Hg	0,2–3 µg/l																																													
	Ni	10–50 µg/l																																													
	Pb	10–20 µg/l																																													
	Zn	50–200 µg/l																																													
16	<p>In order to reduce the quantity of waste sent for disposal from the combustion and/or gasification process and abatement techniques, BAT is to organise operations so as to maximise, in order of priority and taking into account life-cycle thinking:</p> <ul style="list-style-type: none"> <li>(a) waste prevention, e.g. maximise the proportion of residues which arise as by-products;</li> <li>(b) waste preparation for reuse, e.g. according to the specific requested quality criteria;</li> <li>(c) waste recycling;</li> <li>(d) other waste recovery (e.g. energy recovery),</li> </ul> <p>by implementing an appropriate combination of techniques such as:</p> <table border="1" data-bbox="322 1347 1491 1378"> <thead> <tr> <th data-bbox="322 1347 573 1378">Technique</th> <th data-bbox="573 1347 1079 1378">Description</th> <th data-bbox="1079 1347 1491 1378">Applicability</th> </tr> </thead> <tbody> <tr> <td></td> <td></td> <td></td> </tr> </tbody> </table>	Technique	Description	Applicability				CC	<p>The Operator confirmed that, volumes of waste are very low due to activity levels on site. Disposal of waste where possible is via recycling processes with contractors.</p>																																						
Technique	Description	Applicability																																													

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	a.	Generation of gypsum as a by-product	Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g. as raw material in the plasterboard industry). The quality of limestone used in the wet FGD influences the purity of the gypsum produced	Generally applicable within the constraints associated with the required gypsum quality, the health requirements associated to each specific use, and by the market conditions	
b.	Recycling or recovery of residues in the construction sector	Recycling or recovery of residues (e.g. from semi-dry desulphurisation processes, fly ash, bottom ash) as a construction material (e.g. in road building, to replace sand in concrete production, or in the cement industry)	Generally applicable within the constraints associated with the required material quality (e.g. physical properties, content of harmful substances) associated to each specific use, and by the market conditions		
c.	Energy recovery by using waste in the fuel mix	The residual energy content of carbon-rich ash and sludges generated by the combustion of coal, lignite, heavy fuel oil, peat or biomass can be recovered for example by mixing with the fuel	Generally applicable where plants can accept waste in the fuel mix and are technically able to feed the fuels into the combustion chamber		
d.	Preparation of spent catalyst for reuse	Preparation of catalyst for reuse (e.g. up to four times for SCR catalysts) restores some or all of the original performance, extending the service life of the catalyst to several decades. Preparation of spent catalyst for reuse is integrated in a catalyst management scheme	The applicability may be limited by the mechanical condition of the catalyst and the required performance with respect to controlling NO <sub>x</sub> and NH <sub>3</sub> emissions		
17	In order to reduce noise emissions, BAT is to use one or a combination of the techniques given below.			CC	<p>The Operator confirmed that the following steps are taken to control/ reduce noise emissions:</p> <ul style="list-style-type: none"> <li>- Maintaining site noise prevention devices / sound proofing.</li> <li>- Low levels of operating hours during the year.</li> <li>- Regular maintenance of plant.</li> <li>- The plant is as design and operated remotely with no new plant items requiring new noise assessments.</li> </ul>
a.	Operational measures	<p>These include:</p> <ul style="list-style-type: none"> <li>— improved inspection and maintenance of equipment</li> <li>— closing of doors and windows of enclosed areas, if possible</li> <li>— equipment operated by experienced staff</li> <li>— avoidance of noisy activities at night, if possible</li> <li>— provisions for noise control during maintenance activities</li> </ul>	Generally applicable		

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																		
	b.	Low-noise equipment	This potentially includes compressors, pumps and disks	Generally applicable when the equipment is new or replaced	- O & M plan noise surveys to check against historic levels.																		
	c.	Noise attenuation	Noise propagation can be reduced by inserting obstacles between the emitter and the receiver. Appropriate obstacles include protection walls, embankments and buildings	Generally applicable to new plants. In the case of existing plants, the insertion of obstacles may be restricted by lack of space																			
	d.	Noise-control equipment	This includes: — noise-reducers — equipment insulation — enclosure of noisy equipment — soundproofing of buildings	The applicability may be restricted by lack of space																			
	e.	Appropriate location of equipment and buildings	Noise levels can be reduced by increasing the distance between the emitter and the receiver and by using buildings as noise screens	Generally applicable to new plant																			
<b>Combustion of gaseous fuels</b>																							
40	In order to increase the energy efficiency of natural gas combustion, BAT is to use an appropriate combination of the techniques given in BAT 12 and below.			CC	The station uses techniques a, b, d, p and q given in BAT 12. See above for further details.  The plant only operates as an OCGT, during the permit review, we have introduced a limit on operating hours in line with our guidance 'BAT for Balancing Plant' (refer to section 8 of this document) as we do not consider this mode of operation as BAT for plant operating over 1,500 hours/year.  Footnote 1 of Table 23 of the LCP BAT Conclusions specifies that the BAT AEELs for this type of																		
<table border="1"> <thead> <tr> <th data-bbox="322 943 501 975">Technique</th> <th data-bbox="508 943 725 975">Description</th> <th data-bbox="732 943 1494 975">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 979 501 1182">a.</td> <td data-bbox="508 979 725 1182">Combined cycle See description in Section 8.2</td> <td data-bbox="732 979 1494 1182">Generally applicable to new gas turbines and engines except when operated &lt; 1 500 h/yr. Applicable to existing gas turbines and engines within the constraints associated with the steam cycle design and the space availability. Not applicable to existing gas turbines and engines operated &lt; 1 500 h/yr. Not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns. Not applicable to boilers</td> </tr> </tbody> </table>			Technique			Description	Applicability	a.	Combined cycle See description in Section 8.2	Generally applicable to new gas turbines and engines except when operated < 1 500 h/yr. Applicable to existing gas turbines and engines within the constraints associated with the steam cycle design and the space availability. Not applicable to existing gas turbines and engines operated < 1 500 h/yr. Not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns. Not applicable to boilers													
Technique	Description	Applicability																					
a.	Combined cycle See description in Section 8.2	Generally applicable to new gas turbines and engines except when operated < 1 500 h/yr. Applicable to existing gas turbines and engines within the constraints associated with the steam cycle design and the space availability. Not applicable to existing gas turbines and engines operated < 1 500 h/yr. Not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns. Not applicable to boilers																					
<b>BAT-associated energy efficiency levels (BAT-AEELs) for the combustion of natural gas</b>																							
<table border="1"> <thead> <tr> <th data-bbox="322 1219 591 1377" rowspan="3">Type of combustion unit</th> <th colspan="4" data-bbox="598 1219 1494 1251">BAT-AEELs <sup>(136)</sup> <sup>(137)</sup></th> </tr> <tr> <th colspan="2" data-bbox="598 1256 853 1310">Net electrical efficiency (%)</th> <th data-bbox="860 1256 1137 1310" rowspan="2">Net total fuel utilisation (%) <sup>(138)</sup> <sup>(139)</sup></th> <th colspan="2" data-bbox="1144 1256 1494 1310">Net mechanical energy efficiency (%) <sup>(139)</sup> <sup>(140)</sup></th> </tr> <tr> <th data-bbox="598 1315 710 1377">New unit</th> <th data-bbox="716 1315 853 1377">Existing unit</th> <th data-bbox="1144 1315 1290 1377">New unit</th> <th data-bbox="1296 1315 1494 1377">Existing unit</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 1382 591 1382"></td> <td data-bbox="598 1382 710 1382"></td> <td data-bbox="716 1382 853 1382"></td> <td data-bbox="860 1382 1137 1382"></td> <td data-bbox="1144 1382 1290 1382"></td> <td data-bbox="1296 1382 1494 1382"></td> </tr> </tbody> </table>			Type of combustion unit	BAT-AEELs <sup>(136)</sup> <sup>(137)</sup>				Net electrical efficiency (%)		Net total fuel utilisation (%) <sup>(138)</sup> <sup>(139)</sup>	Net mechanical energy efficiency (%) <sup>(139)</sup> <sup>(140)</sup>		New unit	Existing unit	New unit	Existing unit							
Type of combustion unit	BAT-AEELs <sup>(136)</sup> <sup>(137)</sup>																						
	Net electrical efficiency (%)			Net total fuel utilisation (%) <sup>(138)</sup> <sup>(139)</sup>	Net mechanical energy efficiency (%) <sup>(139)</sup> <sup>(140)</sup>																		
	New unit	Existing unit	New unit		Existing unit																		

BAT Concn. Number	Summary of BAT Conclusion requirement					Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	Gas engine	39,5–44 <sup>(141)</sup>	35–44 <sup>(141)</sup>	56–85 <sup>(141)</sup>	No BAT-AEEL.		plant are not applicable as the plant will operate for <1,500 hours/year. Whilst the BAT AEELs do not apply to this plant, the Operator provided details of the plant efficiency calculations. The Operator has confirmed that the efficiency for LCP156 is 46.1%± 1.1%. This is within the BAT-AEEL range for existing open cycle gas turbines.
Gas-fired boiler	39–42,5	38–40	78–95	No BAT-AEEL.			
Open cycle gas turbine, ≥ 50 MW <sub>th</sub>	36–41,5	33–41,5	No BAT-AEEL	36,5–41      33,5–41			
<b>Combined cycle gas turbine (CCGT)</b>							
CCGT, 50–600 MW <sub>th</sub>	53–58,5	46–54	No BAT-AEEL	No BAT-AEEL			
CCGT, ≥ 600 MW <sub>th</sub>	57–60,5	50–60	No BAT-AEEL	No BAT-AEEL			
CHP CCGT, 50–600 MW <sub>th</sub>	53–58,5	46–54	65–95	No BAT-AEEL			
CHP CCGT, ≥ 600 MW <sub>th</sub>	57–60,5	50–60	65–95	No BAT-AEEL			
41	In order to prevent or reduce NO <sub>x</sub> emissions to air from the combustion of natural gas in boilers, BAT is to use one or a combination of the techniques given below.				NA	Not applicable to gas turbines.	
<b>Technique</b>		<b>Description</b>		<b>Applicability</b>			
a.	Air and/or fuel staging	See descriptions in Section 8.3. Air staging is often associated with low-NO <sub>x</sub> burners		Generally applicable			
b.	Flue-gas recirculation	See description in Section 8.3					
c.	Low-NO <sub>x</sub> burners (LNB)						
d.	Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr		The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system			
e.	Reduction of the combustion air temperature	See description in Section 8.3		Generally applicable within the constraints associated with the process needs			
f.	Selective non-catalytic reduction (SNCR)			Not applicable to combustion plants operated < 500 h/yr with highly variable boiler loads. The applicability may be limited in the case of combustion plants operated between 500 h/yr and 1 500 h/yr with highly variable boiler loads			

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																		
	g. Selective catalytic reduction (SCR)		Not applicable to combustion plants operated < 500 h/yr. Not generally applicable to combustion plants of < 100 MW <sub>th</sub> . There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr																				
42	In order to prevent or reduce NO <sub>x</sub> emissions to air from the combustion of natural gas in gas turbines, BAT is to use one or a combination of the techniques given below.			CC	<p>The Operator confirmed that:</p> <p>a) Advanced control system – the gas turbine is controlled with an engine management system which is maintained through a service agreement.</p> <p>c) Dry low-NO<sub>x</sub> burners – the gas turbine has a DLN combustion system.</p> <p>d) Low-load design concept – the gas turbine is not capable at operations at low load.</p> <p>We accept that as this OCGT is an existing plant and the DLN-E definition is accepted</p> <p>i. The output load @ 35MWe or ii. This output load @70% Thermal</p>																		
<table border="1"> <thead> <tr> <th data-bbox="322 667 533 699">Technique</th> <th data-bbox="533 667 1093 699">Description</th> <th data-bbox="1093 667 1491 699">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 699 533 810">a. Advanced control system</td> <td data-bbox="533 699 1093 810">See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated &lt; 500 h/yr</td> <td data-bbox="1093 699 1491 810">The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> <tr> <td data-bbox="322 810 533 874">b. Water/steam addition</td> <td data-bbox="533 810 1093 874" rowspan="2">See description in Section 8.3</td> <td data-bbox="1093 810 1491 874">The applicability may be limited due to water availability</td> </tr> <tr> <td data-bbox="322 874 533 978">c. Dry low-NO<sub>x</sub> burners (DLN)</td> <td data-bbox="1093 874 1491 978">The applicability may be limited in the case of turbines where a retrofit package is not available or when water/steam addition systems are installed</td> </tr> <tr> <td data-bbox="322 978 533 1114">d. Low-load design concept</td> <td data-bbox="533 978 1093 1114">Adaptation of the process control and related equipment to maintain good combustion efficiency when the demand in energy varies, e.g. by improving the inlet airflow control capability or by splitting the combustion process into decoupled combustion stages</td> <td data-bbox="1093 978 1491 1114">The applicability may be limited by the gas turbine design</td> </tr> <tr> <td data-bbox="322 1114 533 1217">e. Low-NO<sub>x</sub> burners (LNB)</td> <td data-bbox="533 1114 1093 1217" rowspan="2">See description in Section 8.3</td> <td data-bbox="1093 1114 1491 1217">Generally applicable to supplementary firing for heat recovery steam generators (HRSGs) in the case of combined-cycle gas turbine (CCGT) combustion plants</td> </tr> <tr> <td data-bbox="322 1217 533 1329">f. Selective catalytic reduction (SCR)</td> <td data-bbox="1093 1217 1491 1329">Not applicable in the case of combustion plants operated &lt; 500 h/yr. Not generally applicable to existing combustion plants of &lt; 100 MW<sub>th</sub>.</td> </tr> </tbody> </table>			Technique			Description	Applicability	a. Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system	b. Water/steam addition	See description in Section 8.3	The applicability may be limited due to water availability	c. Dry low-NO <sub>x</sub> burners (DLN)	The applicability may be limited in the case of turbines where a retrofit package is not available or when water/steam addition systems are installed	d. Low-load design concept	Adaptation of the process control and related equipment to maintain good combustion efficiency when the demand in energy varies, e.g. by improving the inlet airflow control capability or by splitting the combustion process into decoupled combustion stages	The applicability may be limited by the gas turbine design	e. Low-NO <sub>x</sub> burners (LNB)	See description in Section 8.3	Generally applicable to supplementary firing for heat recovery steam generators (HRSGs) in the case of combined-cycle gas turbine (CCGT) combustion plants	f. Selective catalytic reduction (SCR)	Not applicable in the case of combustion plants operated < 500 h/yr. Not generally applicable to existing combustion plants of < 100 MW <sub>th</sub> .
Technique	Description	Applicability																					
a. Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system																					
b. Water/steam addition	See description in Section 8.3	The applicability may be limited due to water availability																					
c. Dry low-NO <sub>x</sub> burners (DLN)		The applicability may be limited in the case of turbines where a retrofit package is not available or when water/steam addition systems are installed																					
d. Low-load design concept	Adaptation of the process control and related equipment to maintain good combustion efficiency when the demand in energy varies, e.g. by improving the inlet airflow control capability or by splitting the combustion process into decoupled combustion stages	The applicability may be limited by the gas turbine design																					
e. Low-NO <sub>x</sub> burners (LNB)	See description in Section 8.3	Generally applicable to supplementary firing for heat recovery steam generators (HRSGs) in the case of combined-cycle gas turbine (CCGT) combustion plants																					
f. Selective catalytic reduction (SCR)		Not applicable in the case of combustion plants operated < 500 h/yr. Not generally applicable to existing combustion plants of < 100 MW <sub>th</sub> .																					

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement															
			Retrofitting existing combustion plants may be constrained by the availability of sufficient space. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr																	
43	In order to prevent or reduce NO <sub>x</sub> emissions to air from the combustion of natural gas in engines, BAT is to use one or a combination of the techniques given below.			NA	Not applicable to gas turbines.															
<table border="1"> <thead> <tr> <th data-bbox="315 644 535 676">Technique</th> <th data-bbox="542 644 994 676">Description</th> <th data-bbox="1001 644 1509 676">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="315 681 535 783">a. Advanced control system</td> <td data-bbox="542 681 994 783">See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated &lt; 500 h/yr</td> <td data-bbox="1001 681 1509 783">The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> <tr> <td data-bbox="315 788 535 842">b. Lean-burn concept</td> <td data-bbox="542 788 994 842">See description in Section 8.3. Generally used in combination with SCR</td> <td data-bbox="1001 788 1509 842">Only applicable to new gas-fired engines</td> </tr> <tr> <td data-bbox="315 847 535 901">c. Advanced lean-burn concept</td> <td data-bbox="542 847 994 901" rowspan="2">See descriptions in Section 8.3</td> <td data-bbox="1001 847 1509 901">Only applicable to new spark plug ignited engines</td> </tr> <tr> <td data-bbox="315 906 535 1094">d. Selective catalytic reduction (SCR)</td> <td data-bbox="1001 906 1509 1094">Retrofitting existing combustion plants may be constrained by the availability of sufficient space. Not applicable to combustion plants operated &lt; 500 h/yr. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr</td> </tr> </tbody> </table>			Technique			Description	Applicability	a. Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system	b. Lean-burn concept	See description in Section 8.3. Generally used in combination with SCR	Only applicable to new gas-fired engines	c. Advanced lean-burn concept	See descriptions in Section 8.3	Only applicable to new spark plug ignited engines	d. Selective catalytic reduction (SCR)	Retrofitting existing combustion plants may be constrained by the availability of sufficient space. Not applicable to combustion plants operated < 500 h/yr. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr		
Technique	Description	Applicability																		
a. Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system																		
b. Lean-burn concept	See description in Section 8.3. Generally used in combination with SCR	Only applicable to new gas-fired engines																		
c. Advanced lean-burn concept	See descriptions in Section 8.3	Only applicable to new spark plug ignited engines																		
d. Selective catalytic reduction (SCR)		Retrofitting existing combustion plants may be constrained by the availability of sufficient space. Not applicable to combustion plants operated < 500 h/yr. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr																		
In order to prevent or reduce CO emissions to air from the combustion of natural gas, BAT is to ensure optimised combustion and/or to use oxidation catalysts.			CC	<p>The Operator confirmed that, historic engine CO emissions are below ELVs as required in the permit. This is a characteristic of this type of gas turbine.</p> <p>They also confirm that they would be compliant with a yearly CO emission limit of 40 mg/Nm<sup>3</sup>. However, as we have introduced</p>																
<p><b>Description - See descriptions in Section 8.3.</b></p> <p><b>BAT-associated emission levels (BAT-AELs) for NO<sub>x</sub> emissions to air from the combustion of natural gas in gas turbines</b></p> <table border="1"> <thead> <tr> <th data-bbox="315 1241 786 1278">Type of combustion plant</th> <th data-bbox="792 1241 1028 1362" rowspan="2">Combustion plant total rated thermal input (MW<sub>th</sub>)</th> <th colspan="2" data-bbox="1034 1241 1509 1278">BAT-AELs (mg/Nm<sup>3</sup>) <sup>(142)</sup> <sup>(143)</sup></th> </tr> <tr> <th data-bbox="315 1283 786 1362"></th> <th data-bbox="1034 1283 1252 1362">Yearly average <sup>(144)</sup> <sup>(145)</sup></th> <th data-bbox="1258 1283 1509 1362">Daily average or average over the sampling period</th> </tr> </thead> <tbody> <tr> <td data-bbox="315 1367 786 1388"></td> <td data-bbox="792 1367 1028 1388"></td> <td data-bbox="1034 1367 1252 1388"></td> <td data-bbox="1258 1367 1509 1388"></td> </tr> </tbody> </table>					Type of combustion plant	Combustion plant total rated thermal input (MW <sub>th</sub> )	BAT-AELs (mg/Nm <sup>3</sup> ) <sup>(142)</sup> <sup>(143)</sup>			Yearly average <sup>(144)</sup> <sup>(145)</sup>	Daily average or average over the sampling period									
Type of combustion plant	Combustion plant total rated thermal input (MW <sub>th</sub> )	BAT-AELs (mg/Nm <sup>3</sup> ) <sup>(142)</sup> <sup>(143)</sup>																		
		Yearly average <sup>(144)</sup> <sup>(145)</sup>	Daily average or average over the sampling period																	



BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																																				
	<p style="text-align: center;"><b>Open-cycle gas turbines (OCGTs) <sup>(146)</sup> <sup>(147)</sup></b></p> <table border="1" data-bbox="322 427 1491 549"> <tr> <td>New OCGT</td> <td>≥ 50</td> <td>15–35</td> <td>25–50</td> </tr> <tr> <td>Existing OCGT (excluding turbines for mechanical drive applications) — All but plants operated &lt; 500 h/yr</td> <td>≥ 50</td> <td>15–50</td> <td>25–55 <sup>(148)</sup></td> </tr> </table> <p style="text-align: center;"><b>Combined-cycle gas turbines (CCGTs) <sup>(146)</sup> <sup>(149)</sup></b></p> <table border="1" data-bbox="322 593 1491 868"> <tr> <td>New CCGT</td> <td>≥ 50</td> <td>10–30</td> <td>15–40</td> </tr> <tr> <td>Existing CCGT with a net total fuel utilisation of &lt; 75 %</td> <td>≥ 600</td> <td>10–40</td> <td>18–50</td> </tr> <tr> <td>Existing CCGT with a net total fuel utilisation of ≥ 75 %</td> <td>≥ 600</td> <td>10–50</td> <td>18–55 <sup>(150)</sup></td> </tr> <tr> <td>Existing CCGT with a net total fuel utilisation of &lt; 75 %</td> <td>50–600</td> <td>10–45</td> <td>35–55</td> </tr> <tr> <td>Existing CCGT with a net total fuel utilisation of ≥ 75 %</td> <td>50–600</td> <td>25–50 <sup>(151)</sup></td> <td>35–55 <sup>(152)</sup></td> </tr> </table> <p style="text-align: center;"><b>Open- and combined-cycle gas turbines</b></p> <table border="1" data-bbox="322 912 1491 1078"> <tr> <td>Gas turbine put into operation no later than 27 November 2003, or existing gas turbine for emergency use and operated &lt; 500 h/yr</td> <td>≥ 50</td> <td>No BAT-AEL</td> <td>60–140 <sup>(153)</sup> <sup>(154)</sup></td> </tr> <tr> <td>Existing gas turbine for mechanical drive applications — All but plants operated &lt; 500 h/yr</td> <td>≥ 50</td> <td>15–50 <sup>(155)</sup></td> <td>25–55 <sup>(156)</sup></td> </tr> </table> <p>As an indication, the yearly average CO emission levels for each type of existing combustion plant operated ≥ 1 500 h/yr and for each type of new combustion plant will generally be as follows:</p> <ul style="list-style-type: none"> <li>— New OCGT of ≥ 50 MW<sub>th</sub>: &lt; 5–40 mg/Nm<sup>3</sup>. For plants with a net electrical efficiency (EE) greater than 39 %, a correction factor may be applied to the higher end of this range, corresponding to [higher end] × EE/39, where EE is the net electrical energy efficiency or net mechanical energy efficiency of the plant determined at ISO baseload conditions.</li> <li>— Existing OCGT of ≥ 50 MW<sub>th</sub> (excluding turbines for mechanical drive applications): &lt; 5–40 mg/Nm<sup>3</sup>. The higher end of this range will generally be 80 mg/Nm<sup>3</sup> in the case of existing plants that cannot be fitted with dry techniques for NO<sub>x</sub> reduction, or 50 mg/Nm<sup>3</sup> for plants that operate at low load.</li> </ul>	New OCGT	≥ 50	15–35	25–50	Existing OCGT (excluding turbines for mechanical drive applications) — All but plants operated < 500 h/yr	≥ 50	15–50	25–55 <sup>(148)</sup>	New CCGT	≥ 50	10–30	15–40	Existing CCGT with a net total fuel utilisation of < 75 %	≥ 600	10–40	18–50	Existing CCGT with a net total fuel utilisation of ≥ 75 %	≥ 600	10–50	18–55 <sup>(150)</sup>	Existing CCGT with a net total fuel utilisation of < 75 %	50–600	10–45	35–55	Existing CCGT with a net total fuel utilisation of ≥ 75 %	50–600	25–50 <sup>(151)</sup>	35–55 <sup>(152)</sup>	Gas turbine put into operation no later than 27 November 2003, or existing gas turbine for emergency use and operated < 500 h/yr	≥ 50	No BAT-AEL	60–140 <sup>(153)</sup> <sup>(154)</sup>	Existing gas turbine for mechanical drive applications — All but plants operated < 500 h/yr	≥ 50	15–50 <sup>(155)</sup>	25–55 <sup>(156)</sup>		<p>a restriction on operating hours for the OCGT to &lt;1,500 hours per year, the yearly BAT-AEL for NO<sub>x</sub> and the yearly indicative emission limit for CO are not applicable.</p> <p>As an existing OCGT plant the applicable NO<sub>x</sub> BAT-AEL is 55 mg/m<sup>3</sup> (daily). This limit is applicable when the DLN system is fully effective.</p> <p>The existing permit already sets monthly, daily and hourly average emission limits for carbon monoxide and NO<sub>x</sub>. Under the principal of “no backsliding”, the current emission limits will be retained unless tighter limits are set by the BREF.</p> <p>Refer to section 4.1 of this document for further details of the limits set in the consolidated permit</p> <p>NO<sub>x</sub> and CO emissions are continuously monitored.</p>
New OCGT	≥ 50	15–35	25–50																																				
Existing OCGT (excluding turbines for mechanical drive applications) — All but plants operated < 500 h/yr	≥ 50	15–50	25–55 <sup>(148)</sup>																																				
New CCGT	≥ 50	10–30	15–40																																				
Existing CCGT with a net total fuel utilisation of < 75 %	≥ 600	10–40	18–50																																				
Existing CCGT with a net total fuel utilisation of ≥ 75 %	≥ 600	10–50	18–55 <sup>(150)</sup>																																				
Existing CCGT with a net total fuel utilisation of < 75 %	50–600	10–45	35–55																																				
Existing CCGT with a net total fuel utilisation of ≥ 75 %	50–600	25–50 <sup>(151)</sup>	35–55 <sup>(152)</sup>																																				
Gas turbine put into operation no later than 27 November 2003, or existing gas turbine for emergency use and operated < 500 h/yr	≥ 50	No BAT-AEL	60–140 <sup>(153)</sup> <sup>(154)</sup>																																				
Existing gas turbine for mechanical drive applications — All but plants operated < 500 h/yr	≥ 50	15–50 <sup>(155)</sup>	25–55 <sup>(156)</sup>																																				

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																							
	<p>— New CCGT of <math>\geq 50 \text{ MW}_{th}</math>: <math>&lt; 5\text{--}30 \text{ mg/Nm}^3</math>. For plants with a net electrical efficiency (EE) greater than 55 %, a correction factor may be applied to the higher end of the range, corresponding to [higher end] <math>\times</math> EE/55, where EE is the net electrical energy efficiency of the plant determined at ISO baseload conditions.</p> <p>— Existing CCGT of <math>\geq 50 \text{ MW}_{th}</math>: <math>&lt; 5\text{--}30 \text{ mg/Nm}^3</math>. The higher end of this range will generally be <math>50 \text{ mg/Nm}^3</math> for plants that operate at low load.</p> <p>— Existing gas turbines of <math>\geq 50 \text{ MW}_{th}</math> for mechanical drive applications: <math>&lt; 5\text{--}40 \text{ mg/Nm}^3</math>. The higher end of the range will generally be <math>50 \text{ mg/Nm}^3</math> when plants operate at low load.</p> <p>In the case of a gas turbine equipped with DLN burners, these indicative levels correspond to when the DLN operation is effective.</p> <p><b>BAT-associated emission levels (BAT-AELs) for NO<sub>x</sub> emissions to air from the combustion of natural gas in boilers and engines</b></p> <table border="1" data-bbox="322 703 1496 930"> <thead> <tr> <th rowspan="3">Type of combustion plant</th> <th colspan="4">BAT-AELs (mg/Nm<sup>3</sup>)</th> </tr> <tr> <th colspan="2">Yearly average <sup>(157)</sup></th> <th colspan="2">Daily average or average over the sampling period</th> </tr> <tr> <th>New plant</th> <th>Existing plant <sup>(158)</sup></th> <th>New plant</th> <th>Existing plant <sup>(159)</sup></th> </tr> </thead> <tbody> <tr> <td>Boiler</td> <td>10–60</td> <td>50–100</td> <td>30–85</td> <td>85–110</td> </tr> <tr> <td>Engine <sup>(160)</sup></td> <td>20–75</td> <td>20–100</td> <td>55–85</td> <td>55–110 <sup>(161)</sup></td> </tr> </tbody> </table> <p>As an indication, the yearly average CO emission levels will generally be:</p> <ul style="list-style-type: none"> <li>— <math>&lt; 5\text{--}40 \text{ mg/Nm}^3</math> for existing boilers operated <math>\geq 1\,500 \text{ h/yr}</math>,</li> <li>— <math>&lt; 5\text{--}15 \text{ mg/Nm}^3</math> for new boilers,</li> <li>— <math>30\text{--}100 \text{ mg/Nm}^3</math> for existing engines operated <math>\geq 1\,500 \text{ h/yr}</math> and for new engines.</li> </ul>	Type of combustion plant	BAT-AELs (mg/Nm <sup>3</sup> )				Yearly average <sup>(157)</sup>		Daily average or average over the sampling period		New plant	Existing plant <sup>(158)</sup>	New plant	Existing plant <sup>(159)</sup>	Boiler	10–60	50–100	30–85	85–110	Engine <sup>(160)</sup>	20–75	20–100	55–85	55–110 <sup>(161)</sup>		
Type of combustion plant	BAT-AELs (mg/Nm <sup>3</sup> )																									
	Yearly average <sup>(157)</sup>		Daily average or average over the sampling period																							
	New plant	Existing plant <sup>(158)</sup>	New plant	Existing plant <sup>(159)</sup>																						
Boiler	10–60	50–100	30–85	85–110																						
Engine <sup>(160)</sup>	20–75	20–100	55–85	55–110 <sup>(161)</sup>																						

## **6. Review and assessment of derogation requests made by the operator in relation to BAT Conclusions which include an associated emission level (AEL) value**

The IED enables a competent authority to allow derogations from BAT AELs stated in BAT Conclusions under specific circumstances as detailed under Article 15(4):

By way of derogation from paragraph 3, and without prejudice to Article 18, the competent authority may, in specific cases, set less strict emission limit values. Such a derogation may apply only where an assessment shows that the achievement of emission levels associated with the best available techniques as described in BAT conclusions would lead to disproportionately higher costs compared to the environmental benefits due to:

*(a) the geographical location or the local environmental conditions of the installation concerned; or*

*(b) the technical characteristics of the installation concerned.*

As part of their Regulation 61 Note response, the operator has not requested a derogation from compliance with any AEL values.

## **7. Emissions to Water**

The consolidated permit incorporates the current discharge to sewer identified as S1. There are no discharges to controlled waters.

There are no BAT AELs specified in the BAT Conclusions for this type of plant. There are also no additional treatment options identified as BAT for the installation. We have therefore not carried out any additional assessment of the emissions to water as part of this review.

## 8 Additional IED Chapter II requirements:

### Operating hours:

We have introduced a limit on operating hours in open cycle mode for the LCP in line with our guidance 'BAT for Balancing Plant' (see below) as we do not consider this mode of operation as BAT for plant operating over 1,500 hours/year.

We have amended the reporting requirements in the permit. We have added in a reporting requirement for operating hours to be reported over a five year rolling average to demonstrate compliance with the less than 1,500 hours/year operational limit.

The OCGT was previously permitted to operate up to 4500 hours per year. However, we are not satisfied that there is sufficient evidence available to demonstrate that OCGTs represent BAT for plants operating for more than 1,500 hours/year. Therefore, we have specified 1,500 hours as a limit on operational hours in the permit.

Article 11 of the IED 2010/75/EU states that BAT are applied. BAT requires the use of the most effective and advanced techniques to prevent or minimise emissions and impacts on the environment.

Relevant guidance that we have drawn on, for BAT, includes the Department of Energy and Climate Change '*Developing best available techniques (BAT) for combustion plants operating in the balancing market*' and Chapter III of IED and the BAT Conclusions, all of which specifically identify two categories of combustion plant operating in the balancing market as peaking plant: those that operate less than 500 hours and those that operate from 500 hours up to 1,500 hours. Within these documents no other categories of operational regimes are recognised other than base load operation.

Furthermore, draft Environment Agency guidance '*BAT guidance for >50 MWth gas and liquid fuel combustion plant exporting electricity under commercial arrangements for <1,500 hours per annum*' consolidates our position on the above and stipulates that combustion plants operating in a single cycle, will be limited to 1,500 hours per annum on a rolling average.

OCGTs operating as peaking plant are classed as fast start, lower efficiency and would generally have higher emissions of oxides of nitrogen (NOx) per megawatt hour of energy produced than would be expected for natural gas fired base load plant. Therefore, OCGTs are better suited to fast reserve running for short periods of time in comparison to base load plants which are more appropriate for steady state running operations.

The use of fast start combined cycle gas turbines (CCGT) aero derivative, gas turbine combined heat and power (GT-CHP) or a large gas engine with

combined heat and power would be considered to be a more favourable alternative, in terms of energy efficiency, than the proposal presented in this Regulation 61 response.

The National Emissions Ceiling Directive (NECD) sets national targets for reductions in pollutants including NO<sub>x</sub>. Restrictions on plants with higher NO<sub>x</sub> intensity directly contributes to achieving the NECD targets.

For this reason the variation restricts the hours of operation of the plant to no more than 1,500 hours/year as a rolling average over a 5 year period and with operation of the turbine in any individual year limited to a maximum of 2,250 hours. We have included permit condition 2.3.6 and updated tables S1.1 and S4.3 to reflect the permitted hours of operation.

*Black Start Operation:*

In the event of a black out National Grid would call on combustion plant to operate and may require them to do so outside their permitted conditions. We have dedicated black start plant and they are permitted to run as such but this scenario is relevant to the rest of the large combustion plant which could be called depending on the circumstances.

A risk assessment will be carried out by Energy UK/Joint Environmental Programme on behalf of Large Combustion Plant connected to the National Transmission System. Air emissions modelling will be based on generic black start scenarios to establish whether they have the potential to have local impact on the environment or not (on a national basis). If the modelling demonstrates that no significant impacts are likely, the plant can operate under condition 2.3.8. This conditions allows the hourly ELVs for plants operating under a black start instruction to be discounted for the purpose of reporting. We would also require there to be a procedure in place for minimisation of emissions in the case of a black start event and for reporting in the event of a black start. This modelling and the procedures have not been agreed in advance of the issue of the permit review and therefore a condition linking back to an improvement condition have been included in the permit.

*Site name change:*

At the request of the Operator the site name has been changed from Exeter OCGT Power Station to Exeter Plant.

## 9 Review and assessment of changes that are not part of the BAT Conclusions derived permit review.

This document should be read in conjunction with the application, supporting information and notice.

Aspect considered	Decision
<b>Receipt of application</b>	
Confidential information	A claim for commercial or industrial confidentiality has not been made.
Identifying confidential information	We have not identified information provided as part of the application that we consider to be confidential.
<b>The site</b>	
Biodiversity, heritage, landscape and nature conservation	<p>The application is within the relevant distance criteria of a site of heritage, landscape or nature conservation, and/or protected species or habitat.</p> <p>A full assessment of the application and its potential to affect the site(s)/species/habitat has not been carried out as part of the permit review process. We consider that the review will not affect the features of the site(s)/species/habitat as the conditions will provide at least the same level of protection as those in the previous permit and in some cases will provide a higher level of protection to those in the previous permit.</p> <p>We have not consulted Natural England on the application. The decision was taken in accordance with our guidance.</p>
<b>Operating techniques</b>	
General operating techniques	<p>We have reviewed the techniques used by the operator where they are relevant to the BAT Conclusions and compared these with the relevant guidance notes.</p> <p>The permit conditions ensure compliance with the relevant BREF, BAT Conclusions. The ELVs deliver compliance with the BAT-AELs.</p> <p>We have introduced a limit on operating hours in Open Cycle Mode for the LCP in line with our guidance 'BAT for Balancing Plant' as we do not consider this mode of operation as BAT for plant operating over 1,500 hours. See section 8 for further information.</p>

Aspect considered	Decision
<b>Permit conditions</b>	
Updating permit conditions during consolidation	We have updated permit conditions to those in the current generic permit template as part of permit consolidation. The conditions will provide at least the same level of protection as those in the previous permit and in some cases will provide a higher level of protection to those in the previous permit.
Changes to the permit conditions due to an Environment Agency initiated variation	We have varied the permit as stated in the variation notice.
Improvement programme	<p>Permit condition 2.3.8 has been included in the permit with corresponding improvement condition IC8 requiring the operator to submit a report in relation to potential black start operation of the plant. See Section 8 for further information.</p> <p>We have also removed the completed improvement conditions from the permit.</p>
Emission limits	<p>We have decided that emission limits should be set for the parameters listed in the permit.</p> <p>These are described in the relevant BAT Conclusions in Sections 4.1 and 5 of this document.</p> <p>It is considered that the ELVs/equivalent parameters or technical measures described above will ensure that significant pollution of the environment is prevented and a high level of protection for the environment is secured.</p>
Monitoring	<p>We have decided that monitoring should be carried out for the parameters listed in the permit, using the methods detailed and to the frequencies specified.</p> <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p> <p>Table S3.3 Process monitoring requirements was amended to include the requirement to monitor energy efficiency after overhauls on site in line with BAT Conclusion 2.</p> <p>Based on the information in the application we are satisfied that the operator's techniques, personnel and equipment have either MCERTS certification or MCERTS accreditation as appropriate.</p>
Reporting	<p>We have specified reporting in the permit for the following parameters:</p> <ul style="list-style-type: none"> <li>• Nitrogen dioxide</li> <li>• Carbon monoxide</li> </ul>



Aspect considered	Decision
	<p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p> <p>We have added in a reporting requirement in for operating hours to be reported over a 5 year rolling average to demonstrate compliance with the less than 1500 hour operational limit.</p>
<b>Operator competence</b>	
Management system	There is no known reason to consider that the operator will not have the management system to enable it to comply with the permit conditions.
<b>Growth Duty</b>	
Section 108 Deregulation Act 2015 – Growth duty	<p>We have considered our duty to have regard to the desirability of promoting economic growth set out in section 108(1) of the Deregulation Act 2015 and the guidance issued under section 110 of that Act in deciding whether to grant this permit.</p> <p>Paragraph 1.3 of the guidance says:</p> <p>“The primary role of regulators, in delivering regulation, is to achieve the regulatory outcomes for which they are responsible. For a number of regulators, these regulatory outcomes include an explicit reference to development or growth. The growth duty establishes economic growth as a factor that all specified regulators should have regard to, alongside the delivery of the protections set out in the relevant legislation.”</p> <p>We have addressed the legislative requirements and environmental standards to be set for this operation in the body of the decision document above. The guidance is clear at paragraph 1.5 that the growth duty does not legitimise non-compliance and its purpose is not to achieve or pursue economic growth at the expense of necessary protections.</p> <p>We consider the requirements and standards we have set in this permit are reasonable and necessary to avoid a risk of an unacceptable level of pollution. This also promotes growth amongst legitimate operators because the standards applied to the operator are consistent across businesses in this sector and have been set to achieve the required legislative standards.</p>