

Environment Agency

Review of an Environmental Permit for an Installation subject to Chapter II of the Industrial Emissions Directive under the Environmental Permitting (England & Wales) Regulations 2016

Decision document recording our decision-making process following review of a permit

The Permit number is: EPR/MP3304PJ
The Operator is: BWSC Generation Services UK Ltd
The Installation is: Kent Renewable Energy CHP Plant
This Variation Notice number is: EPR/MP3304PJ/V002

What this document is about

Article 21(3) of the Industrial Emissions Directive (IED) requires the Environment Agency to review conditions in permits that it has issued and to ensure that the permit delivers compliance with relevant standards, within four years of the publication of updated decisions on best available techniques (BAT) conclusions.

We have reviewed the permit for this installation against the revised BAT Conclusions for large combustion plant published on 17th August 2017. This is our decision document, which explains the reasoning for the consolidated variation notice that we are issuing.

It explains how we have reviewed and considered the techniques used by the Operator in the operation and control of the plant and activities of the installation. This review has been undertaken with reference to the decision made by the European Commission establishing best available techniques (BAT) conclusions ('BAT Conclusions') for large combustion plant as detailed in document reference IEDC-7-1. It is our record of our decision-making process and shows how we have taken into account all relevant factors in reaching our position. It also provides a justification for the inclusion of any specific conditions in the permit that are in addition to those included in our generic permit template.

As well as considering the review of the operating techniques used by the Operator for the operation of the plant and activities of the installation, the consolidated variation notice takes into account and brings together in a single document all previous variations that relate to the original permit

issued. It also modernises the entire permit to reflect the conditions contained in our current generic permit template.

The introduction of new template conditions makes the Permit consistent with our current general approach and philosophy and with other permits issued to installations in this sector. Although the wording of some conditions has changed, while others have been removed because of the new regulatory approach, it does not reduce the level of environmental protection achieved by the Permit in any way. In this document we therefore address only our determination of substantive issues relating to the new BAT Conclusions.

Throughout this document we will use a number of expressions. These are as referred to in the glossary and have the same meaning as described in “Schedule 6 Interpretation” of the Permit.

We try to explain our decision as accurately, comprehensively and plainly as possible. We would welcome any feedback as to how we might improve our decision documents in future. A lot of technical terms and acronyms are inevitable in a document of this nature: we provide a glossary of acronyms near the front of the document, for ease of reference.

How this document is structured

Glossary of terms

- 1 Our decision
- 2 How we reached our decision
- 2.1 Requesting information to demonstrate compliance with BAT Conclusions for Large Combustion Plant
- 2.2 Review of our own information in respect to the capability of the installation to meet revised standards included in the BAT Conclusions document
- 3 The legal framework
- 4 Key Issues
- 4.1 Emissions to air and the emission limits applied to the plant
- 4.2 The energy efficiency levels associated with the Best Available Techniques Conclusions
- 4.3 Environment Management System
- 4.4 Fuel characterisation
- 5 Decision checklist regarding relevant BAT Conclusions
- 6 Review and assessment of derogation requests made by the operator in relation to BAT Conclusions which include an associated emission level (AEL) value
- 7 Emissions to Water
- 8 Additional IED Chapter II requirements
- 9 Review and assessment of changes that are not part of the BAT Conclusions derived permit review.

Glossary of acronyms used in this document

(Please note that this glossary is standard for our decision documents and therefore not all these acronyms are necessarily used in this document.)

APC	Air Pollution Control
BAT	Best Available Technique(s)
BAT-AEEL	BAT Associated Energy Efficiency Level
BAT-AEL	BAT Associated Emission Level
BATc	BAT conclusion
BREF	Best available techniques reference document
CEM	Continuous emissions monitor
CHP	Combined heat and power
CV	Calorific value
DAA	Directly associated activity – Additional activities necessary to be carried out to allow the principal activity to be carried out
EIONET	European environment information and observation network is a partnership network of the European Environment Agency
ELV	Emission limit value derived under BAT or an emission limit value set out in IED
EMS	Environmental Management System
EPR	Environmental Permitting (England and Wales) Regulations 2016 (SI 2016 No. 1154)
EWC	European waste catalogue
FSA	Food Standards Agency
IC	Improvement Condition
IED	Industrial Emissions Directive (2010/75/EU)
IPPCD	Integrated Pollution Prevention and Control Directive (2008/1/EC) – now superseded by IED
LCP	Large Combustion Plant subject to Chapter III of IED
MSUL/MSDL	Minimum start up load/minimum shut-down load
NOx	Oxides of nitrogen (NO plus NO ₂ expressed as NO ₂)
NPV	Net Present Value
PHE	Public Health England
SAC	Special Area of Conservation
SGN	Sector guidance note
TGN	Technical guidance note
TOC	Total Organic Carbon
WFD	Water Framework Directive (2000/60/EC)

1 Our decision

We have decided to issue the consolidated variation notice to the Operator. This will allow it to continue to operate the Installation, subject to the conditions in the consolidated variation notice.

We consider that, in reaching that decision, we have taken into account all relevant considerations and legal requirements and that the varied permit will ensure that a high level of protection is provided for the environment and human health.

The consolidated variation notice contains many conditions taken from our standard Environmental Permit template including the relevant Annexes. We developed these conditions in consultation with industry, having regard to the legal requirements of the Environmental Permitting Regulations and other relevant legislation. This document does not therefore include an explanation for these standard conditions. Where they are included in the Notice, we have considered the techniques identified by the operator for the operation of their installation, and have accepted that the details are sufficient and satisfactory to make those standard conditions appropriate. This document does, however, provide an explanation of our use of “tailor-made” or installation-specific conditions, or where our Permit template provides two or more options.

2 How we reached our decision

2.1 Requesting information to demonstrate compliance with BAT Conclusions for Large Combustion Plant

We issued a Notice under Regulation 61(1) of the Environmental Permitting (England and Wales) Regulations 2016 (a Regulation 61 Notice) on 1st May 2018 requiring the Operator to provide information to demonstrate how the operation of their installation currently meets, or will subsequently meet, the revised standards described in the large combustion plant BAT Conclusions document. The Notice also required that where the revised standards are not currently met, the operator should provide information that:

- Describes the techniques that will be implemented before 17th August 2021, which will then ensure that operations meet the revised standard, or
- Justifies why standards will not be met by 17th August 2021, and confirmation of the date when the operation of those processes will cease within the installation or an explanation of why the revised BAT standard is not applicable to those processes, or
- Justifies why an alternative technique will achieve the same level of environmental protection equivalent to the revised standard described in the BAT Conclusions.

Where the Operator proposed that they were not intending to meet a BAT standard that also included a BAT Associated Emission Level (BAT AEL) described in the BAT Conclusions Document, the Regulation 61 Notice requested that the Operator make a formal request for derogation from compliance with that AEL (as provisioned by Article 15(4) of IED). In this circumstance, the Notice identified that any such request for derogation must be supported and justified by sufficient technical and commercial information that would enable us to determine acceptability of the derogation request.

The Regulation 61 Notice response from the Operator was received on 31/10/18.

- We considered that the response did not contain sufficient information for us to commence the permit review. We therefore issued a further information request to the Operator on 10/03/20. Suitable further information was provided by the Operator on 08/04/20 and 20/04/20.

Further information regarding the emergency diesel generator was requested on 21/04/20 and 24/04/20 and was received on 21/04/20 and 24/04/20 respectively.

2.2 Review of our own information in respect to the capability of the installation to meet revised standards included in the BAT Conclusions document

Based on our records and previous regulatory activities with the facility we have no reason to consider that the operator will not be able to comply with the conditions that we include in the permit.

In relation to BAT Conclusion(s) 1, 9 and 10 we agree with the operator in respect to their current stated capability as recorded in their Regulation 61 Notice response that improvements are required.

We have therefore updated an improvement condition IC03 (BAT 1 and 10) and included an improvement condition IC09 (BAT 9) in the consolidated variation notice, which requires them to upgrade their operational techniques so that the requirements of the BAT Conclusion are delivered by 17 August 2021. This is discussed in more detail in the key issues section and/or in the decision checklist regarding relevant BAT Conclusions.

3 The legal framework

The consolidated variation notice will be issued under Regulation 20 of the EPR. The Environmental Permitting regime is a legal vehicle which delivers most of the relevant legal requirements for activities falling within its scope. In particular, the regulated facility is:

- an *installation* as described by the IED;
- subject to aspects of other relevant legislation which also have to be addressed.

We consider that the consolidated variation notice will ensure that the operation of the Installation complies with all relevant legal requirements and that a high level of protection will be delivered for the environment and human health.

We explain how we have addressed specific statutory requirements more fully in the rest of this document.

4 The key issues

The key issues arising during this permit review are:

- Emissions to air and the emission limits applied to the plant.
- The energy efficiency levels associated with the Best Available Techniques (BAT-AEELs)
- BAT1 and BAT 10 Environment Management System
- BAT 9 characterisation of fuel

We therefore describe how we determined these issues in most detail in the relevant sections of this document.

4.1 Emissions to air and the emission limits applied to the plant

A number of general principles were applied during the permit review. These included:

- The upper value of the BAT AELs ranges specified were used unless use of the tighter limit was justified.
- The principle of no backsliding where if existing limits in the permit were already tighter than those specified in the BREF, the existing permit limits were retained.
- Where a limit was specified in both IED Annex V and the BAT Conclusions for a particular reference period, the tighter limit was applied and in the majority of cases this was from the BAT Conclusions.
- Where AELs are indicative in the BAT Conclusions, these were applied unless adequate justification was provided by the operator to demonstrate that an alternative limit was more appropriate.

The one LCP on site is referenced as LCP462 and is a biomass fired boiler which has a thermal input of 78MWth.

The plant was put into operation after IED came into force and therefore the existing limits in the permit are from Part 2 of IED Annex V applicable to new plant.

The ELVs and AELs are based on the following operating regime:

- Unlimited hours operation

The following tables outline the limits that have been incorporated into the permit for LCP462, where these were derived from and the reference periods at which they apply. The emission limits refer to concentrations, expressed as mass of emitted substance per volume of flue-gas under the following standard conditions: dry gas at a temperature of 273,15 K, pressure of 101,3

kPa and 6% select correct oxygen reference value for plant volume reference oxygen concentration if flue gases. The emission limits and monitoring requirements have been incorporated into Schedule 3 of the permit.

NOx limits (mg/Nm ³)						
Averaging	IED (Annex V Part 2) – New	BREF (Table 9 BAT-c)	Expected permit limits	Basis	Limits apply	Monitoring
Annual	None	225	225	BREF	MSUL/MSDL to baseload	Continuous
Monthly	250	None	250	IED	MSUL/MSDL to baseload	
Daily	275	275	275	IED	MSUL/MSDL to baseload	
95 th %ile of hr means	500	None	500	IED	MSUL/MSDL to baseload	

CO limits (mg/Nm ³)						
Averaging	IED (Annex V Part 2) - New	BREF (Table 9 BAT-c)	Expected permit limits	Basis	Limits apply	Monitoring
Annual	None	250	250	BREF	MSUL/MSDL to baseload	Continuous

SO ₂ limits (mg/Nm ³)						
Averaging	IED (Annex V Part 2) - New	BREF (Table 10 BAT-c)	Expected permit limits	Basis	Limits apply	Monitoring
Annual	None	100	100	BREF	MSUL/MSDL to baseload	Continuous
Monthly	200	None	100	Existing Permit	MSUL/MSDL to baseload	
Daily	220	215	110	Existing Permit	MSUL/MSDL to baseload	
95 th %ile of hr means	400	None	200	Existing Permit	MSUL/MSDL to baseload	

Under the no backsliding rule the Monthly, Daily and Hourly limits will be 100 mg/Nm³, 110 mg/Nm³ and 200 mg/Nm³ respectively, as specified in the existing permit.

HCl limits (mg/Nm ³)						
Averaging	IED (Annex V Part 2) - New	BREF (Table 11 BAT-c)	Expected permit limits	Basis	Limits apply	Monitoring
Annual	None	15	15	BREF	MSUL/MSDL to baseload	Continuous
Daily	None	35	35	BREF	MSUL/MSDL to baseload	

HF limits (mg/Nm ³)						
Averaging	IED (Annex V Part 2) - New	BREF (Table 11 BAT-c)	Expected permit limits	Basis	Limits apply	Monitoring
Average over sampling period	None	< 1.5	< 1.5	BREF	MSUL/MSDL to baseload	Once per year

Dust limits (mg/Nm ³)						
Averaging	IED (Annex V Part 2) - New	BREF (Table 12 BAT-c)	Expected permit limits	Basis	Limits apply	Monitoring
Annual	None	15	15	BREF	MSUL/MSDL to baseload	Continuous
Monthly	20	None	20	IED	MSUL/MSDL to baseload	
Daily	22	22	22	IED	MSUL/MSDL to baseload	
95 th %ile of hr means	40	None	40	IED	MSUL/MSDL to baseload	

NH ₃ limits (mg/Nm ³)						
Averaging	IED (Annex V Part 2) - New	BREF (BAT conclusion 7)	Expected permit limits	Basis	Limits apply	Monitoring
Yearly	None	15	10	BREF	MSUL/MSDL to baseload	Continuous

The H1 air impact assessment with the original permit was undertaken with an ammonia concentration of 10 mg/m³. To ensure the protection of the environment the limit will be set at 10 mg/m³.

Hg limits (µg/Nm ³)						
Averaging	IED (Annex V Part 2) - New	BREF (BAT conclusion 27)	Expected permit limits	Basis	Limits apply	Monitoring
Average over sampling period	None	5	5	BREF	MSUL/MSDL to baseload	Once per year

4.2 The energy efficiency levels associated with the Best Available Techniques Conclusions

An energy efficiency level associated with the best available techniques (BAT-AEEL) refers to the ratio between the combustion unit's net energy output(s) and the combustion unit's fuel/feedstock energy input at actual unit design. The net energy output(s) is determined at the combustion unit boundaries, including auxiliary systems (e.g. flue-gas treatment systems), and for the unit operated at full load.

The table below sets out the BAT-AEELs specified in the LCP BAT Conclusions for the large combustion plant on the site and the energy efficiency levels confirmed through the Regulation 61 notice response. The

evidence provided to demonstrate that the AEELs are met was in the form of a response to a request for information dated 08/04/20. We consider this plant is BAT in relation to the AEELs.

BAT AEELs (%)			Plant efficiency (%)		
Net electrical efficiency	Net total fuel utilisation	Net mechanical efficiency	Net electrical efficiency	Net total fuel utilisation	Net mechanical efficiency
LCP462: unit description from the AEEL table					
28 - 38	None	None	34.594	NA	NA

4.3 Environment Management System

BAT 1 requires the operator to have an environment management system (EMS) in place that addresses all relevant points (i) – (xvi) as specified under this BAT conclusion. An EMS is not currently in place for this installation.

We have therefore updated improvement condition ICO3 requiring the operator provides an EMS that addresses all the requirements of BAT 1, as specified under points (i) – (xvi).

BAT 10 requires that procedures are in place for OTNOC, improvement condition 3 has been updated requiring that the EMS includes such procedures.

4.4 Fuel characterisation

BAT 9 requires the operator to carry out fuel characterisation. The operator has not yet demonstrated that fuel characterisation is in place as required under point i) of this BAT conclusion. Criteria ii) in relation to the regular testing of fuels and iii) in relation to incorporating the fuel characterisation changes identified as a result of regular testing back into the control system to improve performance have not been developed.

We have therefore included an improvement condition (IC) in the consolidated variation notice ICO9 requiring the operator to submit a plan outlining how this will be carried out for approval prior to the implementation date for the BAT Conclusions.

5 Decision checklist regarding relevant BAT Conclusions

BAT Conclusions for large combustion plant, were published by the European Commission on 17th August 2017. There are 75 BAT Conclusions. Only the BAT Conclusions relevant to the particular fuel type used on site have been replicated below.

This annex provides a record of decisions made in relation to each relevant BAT Conclusion applicable to the installation. This annex should be read in conjunction with the Consolidated Variation Notice.

The conditions in the permit through which the relevant BAT Conclusions are implemented include but are not limited to the following:

BAT Conclusion requirement topic	Permit condition(s)	Permit table(s)
Environmental Management System	1.1.1	S1.2
BAT AELs	3.1.1 and 3.5.1	S3.1a
Monitoring	2.3, 3.5 and 3.6	S3.1, S3.1a, S3.2
Energy efficiency	1.2 and 2.3	S3.3
Noise	3.4 and 2.3	S1.2
Other operating techniques	2.3	S1.2

The overall status of compliance with the BAT conclusion is indicated in the table as:

- NA Not Applicable
- CC Currently Compliant
- FC Compliant in the future (within 4 years of publication of BAT conclusions)
- NC Not Compliant
- PC Partially Compliant

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
General			
1	<p>In order to improve the overall environmental performance, BAT is to implement and adhere to an environmental management system (EMS) that incorporates all of the following features:</p> <ul style="list-style-type: none"> i. commitment of the management, including senior management; ii. definition of an environmental policy that includes the continuous improvement of the installation by the management; iii. planning and establishing the necessary procedures, objectives and targets, in conjunction with financial planning and investment; iv. implementation of procedures <ul style="list-style-type: none"> (a) Structure and responsibility (b) Training (c) Communication (d) Employee involvement (e) Documentation (f) Efficient process control (g) Maintenance programmes (h) Emergency preparedness and response (i) Safeguarding compliance with environmental legislation v. checking performance and taking corrective action, paying particular attention to: <ul style="list-style-type: none"> (a) monitoring and measurement (see also the Reference Document on the General Principles of Monitoring) (b) corrective and preventive action (c) maintenance of records (d) independent (where practicable) internal and external auditing in order to determine whether or not the EMS conforms to planned arrangements and has been properly implemented and maintained; vi. review of the EMS and its continuing suitability, adequacy and effectiveness by senior management; vii. following the development of cleaner technologies; viii. consideration for the environmental impacts from the eventual decommissioning of the installation at the stage of designing a new plant, and throughout its operating life; viii. consideration for the environmental impacts from the eventual decommissioning of the installation at the stage of designing a new plant, and throughout its operating life; ix. application of sectoral benchmarking on a regular basis. <p>Etc - see BAT Conclusions</p>	FC	The EMS is still under production at the time of this review. Improvement condition ICO3 has been updated to ensure that it is in compliance with BAT1.

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																		
	Applicability. The scope (e.g. level of detail) and nature of the EMS (e.g. standardised or non-standardised) will generally be related to the nature, scale and complexity of the installation, and the range of environmental impacts it may have.																				
2	BAT is to determine the net electrical efficiency and/or the net total fuel utilisation and/or the net mechanical energy efficiency of the gasification, IGCC and/or combustion units by carrying out a performance test at full load (1), according to EN standards, after the commissioning of the unit and after each modification that could significantly affect the net electrical efficiency and/or the net total fuel utilisation and/or the net mechanical energy efficiency of the unit. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.	CC	The operator has confirmed that the net electrical efficiency of the plant is 34.595% based upon a performance test undertaken on November 2018.																		
3	<p>BAT is to monitor key process parameters relevant for emissions to air and water including those given below.</p> <table border="1" data-bbox="320 722 1494 898"> <thead> <tr> <th data-bbox="320 722 689 759">Stream</th> <th data-bbox="689 722 1124 759">Parameter(s)</th> <th data-bbox="1124 722 1494 759">Monitoring</th> </tr> </thead> <tbody> <tr> <td data-bbox="320 759 689 863" rowspan="3">Flue-gas</td> <td data-bbox="689 759 1124 796">Flow</td> <td data-bbox="1124 759 1494 796">Periodic or continuous determination</td> </tr> <tr> <td data-bbox="689 796 1124 833">Oxygen content, temperature, and pressure</td> <td data-bbox="1124 796 1494 833" rowspan="2">Periodic or continuous measurement</td> </tr> <tr> <td data-bbox="689 833 1124 863">Water vapour content ⁽³⁾</td> </tr> <tr> <td data-bbox="320 863 689 898">Waste water from flue-gas treatment</td> <td data-bbox="689 863 1124 898">Flow, pH, and temperature</td> <td data-bbox="1124 863 1494 898">Continuous measurement</td> </tr> </tbody> </table>	Stream	Parameter(s)	Monitoring	Flue-gas	Flow	Periodic or continuous determination	Oxygen content, temperature, and pressure	Periodic or continuous measurement	Water vapour content ⁽³⁾	Waste water from flue-gas treatment	Flow, pH, and temperature	Continuous measurement	CC	<p>The operator has confirmed the following:</p> <p>Flow, Oxygen, Temperature, pressure and water vapour content are all monitored.</p>						
Stream	Parameter(s)	Monitoring																			
Flue-gas	Flow	Periodic or continuous determination																			
	Oxygen content, temperature, and pressure	Periodic or continuous measurement																			
	Water vapour content ⁽³⁾																				
Waste water from flue-gas treatment	Flow, pH, and temperature	Continuous measurement																			
4	<p>BAT is to monitor emissions to air with at least the frequency given below and in accordance with EN standards. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.</p> <table border="1" data-bbox="320 999 1494 1385"> <thead> <tr> <th data-bbox="320 999 477 1115">Substance/Parameter</th> <th data-bbox="477 999 792 1115">Fuel/Process/Type of combustion plant</th> <th data-bbox="792 999 949 1115">Combustion plant total rated thermal input</th> <th data-bbox="949 999 1124 1115">Standard(s) ⁽⁴⁾</th> <th data-bbox="1124 999 1346 1115">Minimum monitoring frequency ⁽⁵⁾</th> <th data-bbox="1346 999 1494 1115">Monitoring associated with</th> </tr> </thead> <tbody> <tr> <td data-bbox="320 1115 477 1182">NH₃</td> <td data-bbox="477 1115 792 1182">— When SCR and/or SNCR is used</td> <td data-bbox="792 1115 949 1182">All sizes</td> <td data-bbox="949 1115 1124 1182">Generic EN standards</td> <td data-bbox="1124 1115 1346 1182">Continuous ⁽⁶⁾ ⁽⁷⁾</td> <td data-bbox="1346 1115 1494 1182">BAT 7</td> </tr> <tr> <td data-bbox="320 1182 477 1385">NO_x</td> <td data-bbox="477 1182 792 1385">— Coal and/or lignite including waste co-incineration — Solid biomass and/or peat including waste co-incineration</td> <td data-bbox="792 1182 949 1385">All sizes</td> <td data-bbox="949 1182 1124 1385">Generic EN standards</td> <td data-bbox="1124 1182 1346 1385">Continuous ⁽⁶⁾ ⁽⁸⁾</td> <td data-bbox="1346 1182 1494 1385">BAT 20 BAT 24 BAT 28 BAT 32 BAT 37 BAT 41 BAT 42 BAT 43 BAT 47</td> </tr> </tbody> </table>	Substance/Parameter	Fuel/Process/Type of combustion plant	Combustion plant total rated thermal input	Standard(s) ⁽⁴⁾	Minimum monitoring frequency ⁽⁵⁾	Monitoring associated with	NH ₃	— When SCR and/or SNCR is used	All sizes	Generic EN standards	Continuous ⁽⁶⁾ ⁽⁷⁾	BAT 7	NO _x	— Coal and/or lignite including waste co-incineration — Solid biomass and/or peat including waste co-incineration	All sizes	Generic EN standards	Continuous ⁽⁶⁾ ⁽⁸⁾	BAT 20 BAT 24 BAT 28 BAT 32 BAT 37 BAT 41 BAT 42 BAT 43 BAT 47	CC	<p>The operator has confirmed the following.</p> <p>Monitoring of the following parameters for emissions to air apply to solid biomass combustion plant.</p> <p>NH₃ – Continuous – BS 14181</p> <p>NO_x – Continuous – BS 14181</p> <p>CO - Continuous – BS14281</p> <p>SO₂ – Continuous – BS 14181</p> <p>HCl – Continuous – BS14181</p>
Substance/Parameter	Fuel/Process/Type of combustion plant	Combustion plant total rated thermal input	Standard(s) ⁽⁴⁾	Minimum monitoring frequency ⁽⁵⁾	Monitoring associated with																
NH ₃	— When SCR and/or SNCR is used	All sizes	Generic EN standards	Continuous ⁽⁶⁾ ⁽⁷⁾	BAT 7																
NO _x	— Coal and/or lignite including waste co-incineration — Solid biomass and/or peat including waste co-incineration	All sizes	Generic EN standards	Continuous ⁽⁶⁾ ⁽⁸⁾	BAT 20 BAT 24 BAT 28 BAT 32 BAT 37 BAT 41 BAT 42 BAT 43 BAT 47																

BAT Concn. Number	Summary of BAT Conclusion requirement					Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	<ul style="list-style-type: none"> — HFO- and/or gas-oil-fired boilers and engines — Gas-oil-fired gas turbines — Natural-gas-fired boilers, engines, and turbines — Iron and steel process gases — Process fuels from the chemical industry — IGCC plants 					BAT 48 BAT 56 BAT 64 BAT 65 BAT 73	<p>HF – at least once per year – ISO15713</p> <p>Dust – Continuous – BS14181</p> <p>Metals and Metalloids – Periodic (once per year) – EN14385. The operator has confirmed that the installation will be compliant with this monitoring requirement by 31st July 2021, which is the date by which full compliance with BAT conclusions is required.</p> <p>Hg – Periodic (once per year) – EN 13211. The operator has confirmed that the installation will be compliant with this monitoring requirement by 31st July 2021, which is the date by which full compliance with BAT conclusions is required.</p> <p>We agree that the operator is in compliance with the monitoring requirements of this BAT conclusion.</p>
	<ul style="list-style-type: none"> — Combustion plants on offshore platforms 	All sizes	EN 14792	Once every year ⁽⁹⁾	BAT 53		
N ₂ O	<ul style="list-style-type: none"> — Coal and/or lignite in circulating fluidised bed boilers — Solid biomass and/or peat in circulating fluidised bed boilers 	All sizes	EN 21258	Once every year ⁽¹⁰⁾	BAT 20 BAT 24		
CO	<ul style="list-style-type: none"> — Coal and/or lignite including waste co-incineration — Solid biomass and/or peat including waste co-incineration — HFO- and/or gas-oil-fired boilers and engines — Gas-oil-fired gas turbines — Natural-gas-fired boilers, engines, and turbines — Iron and steel process gases — Process fuels from the chemical industry — IGCC plants 	All sizes	Generic EN standards	Continuous ⁽⁶⁾ ⁽⁸⁾	BAT 20 BAT 24 BAT 28 BAT 33 BAT 38 BAT 44 BAT 49 BAT 56 BAT 64 BAT 65 BAT 73		

BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	—	Combustion plants on offshore platforms	All sizes	EN 15058	Once every year ⁽⁹⁾	BAT 54		
SO ₂	—	Coal and/or lignite incl waste co-incineration	All sizes	Generic EN standards and EN 14791	Continuous ⁽⁶⁾ ₍₁₁₎ ₍₁₂₎	BAT 21 BAT 25 BAT 29 BAT 34 BAT 39 BAT 50 BAT 57 BAT 66 BAT 67 BAT 74		
	—	Solid biomass and/or peat incl waste co-incineration						
	—	HFO- and/or gas-oil-fired boilers						
	—	HFO- and/or gas-oil-fired engines						
	—	Gas-oil-fired gas turbines						
	—	Iron and steel process gases						
	—	Process fuels from the chemical industry in boilers						
	—	IGCC plants						
SO ₃	—	When SCR is used	All sizes	No EN standard available	Once every year	—		
Gaseous chlorides, expressed as HCl	—	Coal and/or lignite	All sizes	EN 1911	Once every three months ⁽⁶⁾ ₍₁₃₎ ₍₁₄₎	BAT 21 BAT 57		
	—	Process fuels from the chemical industry in boilers						
	—	Solid biomass and/or peat	All sizes	Generic EN standards	Continuous ⁽¹⁵⁾ ₍₁₆₎	BAT 25		
	—	Waste co-incineration	All sizes	Generic EN standards	Continuous ⁽⁶⁾ ₍₁₆₎	BAT 66 BAT 67		
HF	—	Coal and/or lignite	All sizes	No EN standard available	Once every three months ⁽⁶⁾ ₍₁₃₎ ₍₁₄₎	BAT 21 BAT 57		
	—	Process fuels from the chemical industry in boilers						
	—	Solid biomass and/or peat	All sizes	No EN standard available	Once every year	BAT 25		
	—	Waste co-incineration	All sizes	Generic EN standards	Continuous ⁽⁶⁾ ₍₁₆₎	BAT 66 BAT 67		

BAT Concn. Number	Summary of BAT Conclusion requirement					Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	Dust	<ul style="list-style-type: none"> — Coal and/or lignite — Solid biomass and/or peat — HFO- and/or gas-oil-fired boilers — Iron and steel process gases — Process fuels from the chemical industry in boilers — IGCC plants — HFO- and/or gas-oil-fired engines — Gas-oil-fired gas turbines 	All sizes	Generic EN standards and EN 13284-1 and EN 13284-2	Continuous ⁽⁶⁾ ₍₁₇₎	BAT 22 BAT 26 BAT 30 BAT 35 BAT 39 BAT 51 BAT 58 BAT 75	
		— Waste co-incineration	All sizes	Generic EN standards and EN 13284-2	Continuous	BAT 68 BAT 69	
	Metals and metalloids except mercury (As, Cd, Co, Cr, Cu, Mn, Ni, Pb, Sb, Se, Ti, V, Zn)	<ul style="list-style-type: none"> — Coal and/or lignite — Solid biomass and/or peat — HFO- and/or gas-oil-fired boilers and engines 	All sizes	EN 14385	Once every year ₍₁₈₎	BAT 22 BAT 26 BAT 30	
		— Waste co-incineration	< 300 MW _{th}	EN 14385	Once every six months ₍₁₃₎	BAT 68 BAT 69	
			≥ 300 MW _{th}	EN 14385	Once every three months ₍₁₉₎ ₍₁₃₎		
		— IGCC plants	≥ 100 MW _{th}	EN 14385	Once every year ₍₁₈₎	BAT 75	
	Hg	<ul style="list-style-type: none"> — Coal and/or lignite including waste co-incineration 	< 300 MW _{th}	EN 13211	Once every three months ₍₁₃₎ ₍₂₀₎	BAT 23	
			≥ 300 MW _{th}	Generic EN standards and EN 14884	Continuous ₍₁₆₎ ₍₂₁₎		
		— Solid biomass and/or peat	All sizes	EN 13211	Once every year ₍₂₂₎	BAT 27	
		— Waste co-incineration with solid biomass and/or peat	All sizes	EN 13211	Once every three months ₍₁₃₎	BAT 70	

BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																		
		— IGCC plants	≥ 100 MW _{th}	EN 13211	Once every year ⁽²³⁾	BAT 75																				
TVOC		— HFO- and/or gas-oil-fired engines — Process fuels from chemical industry in boilers	All sizes	EN 12619	Once every six months ⁽¹³⁾	BAT 33 BAT 59																				
		— Waste co-incineration with coal, lignite, solid biomass and/or peat	All sizes	Generic EN standards	Continuous	BAT 71																				
Formaldehyde		— Natural-gas in spark-ignited lean-burn gas and dual fuel engines	All sizes	No EN standard available	Once every year	BAT 45																				
CH ₄		— Natural-gas-fired engines	All sizes	EN ISO 25139	Once every year ⁽²⁴⁾	BAT 45																				
PCDD/F		— Process fuels from chemical industry in boilers — Waste co-incineration	All sizes	EN 1948-1, EN 1948-2, EN 1948-3	Once every six months ⁽¹³⁾ ⁽²⁵⁾	BAT 59 BAT 71																				
5	BAT is to monitor emissions to water from flue-gas treatment with at least the frequency given below and in accordance with EN standards. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.						NA	Flue gas treatment is a dry process, therefore, no waste water is generated from the process. This BAT conclusion is thus not applicable.																		
	<table border="1"> <thead> <tr> <th data-bbox="324 1018 654 1098">Substance/Parameter</th> <th data-bbox="665 1018 1021 1098">Standard(s)</th> <th data-bbox="1023 1018 1263 1098">Minimum monitoring frequency</th> <th data-bbox="1265 1018 1491 1098">Monitoring associated with</th> </tr> </thead> <tbody> <tr> <td data-bbox="324 1099 654 1139">Total organic carbon (TOC)⁽²⁶⁾</td> <td data-bbox="665 1099 1021 1139">EN 1484</td> <td data-bbox="1023 1099 1263 1139" rowspan="7">Once every month</td> <td data-bbox="1265 1099 1491 1139" rowspan="7">BAT 15</td> </tr> <tr> <td data-bbox="324 1141 654 1197">Chemical oxygen demand (COD)⁽²⁶⁾</td> <td data-bbox="665 1141 1021 1197">No EN standard available</td> </tr> <tr> <td data-bbox="324 1198 654 1238">Total suspended solids (TSS)</td> <td data-bbox="665 1198 1021 1238">EN 872</td> </tr> <tr> <td data-bbox="324 1240 654 1272">Fluoride (F⁻)</td> <td data-bbox="665 1240 1021 1272">EN ISO 10304-1</td> </tr> <tr> <td data-bbox="324 1273 654 1305">Sulphate (SO₄²⁻)</td> <td data-bbox="665 1273 1021 1305">EN ISO 10304-1</td> </tr> <tr> <td data-bbox="324 1307 654 1339">Sulphide, easily released (S²⁻)</td> <td data-bbox="665 1307 1021 1339">No EN standard available</td> </tr> <tr> <td data-bbox="324 1340 654 1372">Sulphite (SO₃²⁻)</td> <td data-bbox="665 1340 1021 1372">EN ISO 10304-3</td> </tr> </tbody> </table>	Substance/Parameter	Standard(s)	Minimum monitoring frequency	Monitoring associated with	Total organic carbon (TOC) ⁽²⁶⁾	EN 1484	Once every month	BAT 15	Chemical oxygen demand (COD) ⁽²⁶⁾	No EN standard available	Total suspended solids (TSS)	EN 872	Fluoride (F ⁻)	EN ISO 10304-1	Sulphate (SO ₄ ²⁻)	EN ISO 10304-1	Sulphide, easily released (S ²⁻)	No EN standard available	Sulphite (SO ₃ ²⁻)	EN ISO 10304-3					
Substance/Parameter	Standard(s)	Minimum monitoring frequency	Monitoring associated with																							
Total organic carbon (TOC) ⁽²⁶⁾	EN 1484	Once every month	BAT 15																							
Chemical oxygen demand (COD) ⁽²⁶⁾	No EN standard available																									
Total suspended solids (TSS)	EN 872																									
Fluoride (F ⁻)	EN ISO 10304-1																									
Sulphate (SO ₄ ²⁻)	EN ISO 10304-1																									
Sulphide, easily released (S ²⁻)	No EN standard available																									
Sulphite (SO ₃ ²⁻)	EN ISO 10304-3																									

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																						
	<table border="1"> <tr> <td data-bbox="331 392 595 692" rowspan="7">Metals and metalloids</td> <td data-bbox="595 392 663 424">As</td> <td data-bbox="663 392 1025 692" rowspan="7">Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)</td> <td data-bbox="1025 392 1267 692" rowspan="7"></td> </tr> <tr><td data-bbox="595 424 663 456">Cd</td></tr> <tr><td data-bbox="595 456 663 488">Cr</td></tr> <tr><td data-bbox="595 488 663 520">Cu</td></tr> <tr><td data-bbox="595 520 663 552">Ni</td></tr> <tr><td data-bbox="595 552 663 584">Pb</td></tr> <tr><td data-bbox="595 584 663 616">Zn</td></tr> <tr> <td data-bbox="331 692 595 751"></td> <td data-bbox="595 692 663 751">Hg</td> <td data-bbox="663 692 1025 751">Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)</td> <td data-bbox="1025 692 1267 751"></td> </tr> <tr> <td data-bbox="331 751 595 783">Chloride (Cl⁻)</td> <td data-bbox="595 751 1025 783"></td> <td data-bbox="1025 751 1267 783">Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)</td> <td data-bbox="1267 751 1491 783">—</td> </tr> <tr> <td data-bbox="331 783 595 799">Total nitrogen</td> <td data-bbox="595 783 1025 799"></td> <td data-bbox="1025 783 1267 799">EN 12260</td> <td data-bbox="1267 783 1491 799">—</td> </tr> </table>	Metals and metalloids	As	Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)		Cd	Cr	Cu	Ni	Pb	Zn		Hg	Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)		Chloride (Cl ⁻)		Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)	—	Total nitrogen		EN 12260	—		
Metals and metalloids	As		Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)																						
	Cd																								
	Cr																								
	Cu																								
	Ni																								
	Pb																								
	Zn																								
	Hg	Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)																							
Chloride (Cl ⁻)		Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)	—																						
Total nitrogen		EN 12260	—																						
6	<p>In order to improve the general environmental performance of combustion plants and to reduce emissions to air of CO and unburnt substances, BAT is to ensure optimised combustion and to use an appropriate combination of the techniques given below.</p> <table border="1"> <thead> <tr> <th data-bbox="331 903 555 935">Technique</th> <th data-bbox="555 903 994 935">Description</th> <th data-bbox="994 903 1491 935">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="331 935 555 1023">a. Fuel blending and mixing</td> <td data-bbox="555 935 994 1023">Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type</td> <td data-bbox="994 935 1491 1023" rowspan="2">Generally applicable</td> </tr> <tr> <td data-bbox="331 1023 555 1102">b. Maintenance of the combustion system</td> <td data-bbox="555 1023 994 1102">Regular planned maintenance according to suppliers' recommendations</td> </tr> <tr> <td data-bbox="331 1102 555 1190">c. Advanced control system</td> <td data-bbox="555 1102 994 1190">See description in Section 8.1</td> <td data-bbox="994 1102 1491 1190">The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> <tr> <td data-bbox="331 1190 555 1270">d. Good design of the combustion equipment</td> <td data-bbox="555 1190 994 1270">Good design of furnace, combustion chambers, burners and associated devices</td> <td data-bbox="994 1190 1491 1270">Generally applicable to new combustion plants</td> </tr> <tr> <td data-bbox="331 1270 555 1382">e. Fuel choice</td> <td data-bbox="555 1270 994 1382">Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels,</td> <td data-bbox="994 1270 1491 1382">Applicable within the constraints associated with the availability of suitable types of fuel with a better environmental profile as a whole, which may be impacted by the energy policy of the Member</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Fuel blending and mixing	Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type	Generally applicable	b. Maintenance of the combustion system	Regular planned maintenance according to suppliers' recommendations	c. Advanced control system	See description in Section 8.1	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system	d. Good design of the combustion equipment	Good design of furnace, combustion chambers, burners and associated devices	Generally applicable to new combustion plants	e. Fuel choice	Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels,	Applicable within the constraints associated with the availability of suitable types of fuel with a better environmental profile as a whole, which may be impacted by the energy policy of the Member	CC	<p>The operator has confirmed that the following measures are in place:</p> <p>That they are compliant with the requirements through a combination of techniques as set out below:</p> <p>a) Fuel blending and mixing – The fuel mix is blended together is the proportions 85% virgin wood and 15% clean uncontaminated waste wood.</p> <p>b) Maintenance of the combustion system –Maintenance is undertaken in accordance with the manufacturer's recommendations.</p>					
Technique	Description	Applicability																							
a. Fuel blending and mixing	Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type	Generally applicable																							
b. Maintenance of the combustion system	Regular planned maintenance according to suppliers' recommendations																								
c. Advanced control system	See description in Section 8.1	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system																							
d. Good design of the combustion equipment	Good design of furnace, combustion chambers, burners and associated devices	Generally applicable to new combustion plants																							
e. Fuel choice	Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels,	Applicable within the constraints associated with the availability of suitable types of fuel with a better environmental profile as a whole, which may be impacted by the energy policy of the Member																							

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement			
	<table border="1" data-bbox="331 392 1491 523"> <tr> <td data-bbox="331 392 555 523"></td> <td data-bbox="555 392 994 523">including in start-up situations or when back-up fuels are used</td> <td data-bbox="994 392 1491 523">State, or by the integrated site's fuel balance in the case of combustion of industrial process fuels. For existing combustion plants, the type of fuel chosen may be limited by the configuration and the design of the plant</td> </tr> </table>		including in start-up situations or when back-up fuels are used	State, or by the integrated site's fuel balance in the case of combustion of industrial process fuels. For existing combustion plants, the type of fuel chosen may be limited by the configuration and the design of the plant		<p>c) Advanced control system – As the construction of the plant has only recently been completed in September 2018, a modern control system has only recently been installed.</p> <p>d) Good design – The plant uses proven vibrating grate technology with a dual fuel burner for start-up and shut-down. Air flows are automatically controlled for efficient combustion, with manual control if necessary.</p> <p>e) Fuel choice – The main fuel is virgin timber which has a low sulphur content (approx. 0.02%).</p>
	including in start-up situations or when back-up fuels are used	State, or by the integrated site's fuel balance in the case of combustion of industrial process fuels. For existing combustion plants, the type of fuel chosen may be limited by the configuration and the design of the plant				
7	<p>In order to reduce emissions of ammonia to air from the use of selective catalytic reduction (SCR) and/or selective non-catalytic reduction (SNCR) for the abatement of NO_x emissions, BAT is to optimise the design and/or operation of SCR and/or SNCR (e.g. optimised reagent to NO_x ratio, homogeneous reagent distribution and optimum size of the reagent drops).</p> <p>BAT-associated emission levels</p> <p>The BAT-associated emission level (BAT-AEL) for emissions of NH₃ to air from the use of SCR and/or SNCR is < 3–10 mg/Nm³ as a yearly average or average over the sampling period. The lower end of the range can be achieved when using SCR and the upper end of the range can be achieved when using SNCR without wet abatement techniques. In the case of plants combusting biomass and operating at variable loads as well as in the case of engines combusting HFO and/or gas oil, the higher end of the BAT-AEL range is 15 mg/Nm³.</p>	CC	<p>The operator has confirmed the following:</p> <p>SNCR is installed at the installation and will be used to minimise NO_x emissions.</p> <p>The plant has been designed to operate on a variable load, this could be to meet potential grid requirements, to operate in a power island mode or for financial reasons. In accordance with BAT 7 an emissions limit of 10 mg/Nm³ is appropriate. Although there is</p>			

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
			the option of setting 15 mg/Nm ³ if the plant has a variable load, the original permit application for this site was assessed on 10 mg/Nm ³ and therefore it is not appropriate to set a limit higher than this.
8	In order to prevent or reduce emissions to air during normal operating conditions, BAT is to ensure, by appropriate design, operation and maintenance, that the emission abatement systems are used at optimal capacity and availability.	CC	The operator has confirmed the following: In order to prevent or reduce emissions during normal operations the following will be in place: performance analysis of the plant, continuous emissions monitoring, discontinuous emissions monitoring and progressive tuning of the systems.
9	In order to improve the general environmental performance of combustion and/or gasification plants and to reduce emissions to air, BAT is to include the following elements in the quality assurance/quality control programmes for all the fuels used, as part of the environmental management system (see BAT 1): (i) Initial full characterisation of the fuel used including at least the parameters listed below and in accordance with EN standards. ISO, national or other international standards may be used provided they ensure the provision of data of an equivalent scientific quality; (ii) Regular testing of the fuel quality to check that it is consistent with the initial characterisation and according to the plant design specifications. The frequency of testing and the parameters chosen from the table below are based on the variability of the fuel and an assessment of the relevance of pollutant releases (e.g. concentration in fuel, flue-gas treatment employed); (iii) Subsequent adjustment of the plant settings as and when needed and practicable (e.g. integration of the fuel characterisation and control in the advanced control system (see description in Section 8.1)).	FC	An improvement condition ICO9 has been included in the permit requiring the operator to provide full details of their fuel characterisation procedures that are fully compliant with BAT9.

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																									
	<p>Description Initial characterisation and regular testing of the fuel can be performed by the operator and/or the fuel supplier. If performed by the supplier, the full results are provided to the operator in the form of a product (fuel) supplier specification and/or guarantee.</p> <table border="1" data-bbox="322 496 1494 1353"> <thead> <tr> <th data-bbox="322 496 712 528">Fuel(s)</th> <th data-bbox="712 496 1494 528">Substances/Parameters subject to characterisation</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 528 712 735" rowspan="4">Biomass/peat</td> <td data-bbox="712 528 1494 568">— LHV</td> </tr> <tr> <td data-bbox="712 568 1494 608">— moisture</td> </tr> <tr> <td data-bbox="712 608 1494 647">— Ash</td> </tr> <tr> <td data-bbox="712 647 1494 735">— C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn)</td> </tr> <tr> <td data-bbox="322 735 712 951" rowspan="4">Coal/lignite</td> <td data-bbox="712 735 1494 775">— LHV</td> </tr> <tr> <td data-bbox="712 775 1494 815">— Moisture</td> </tr> <tr> <td data-bbox="712 815 1494 855">— Volatiles, ash, fixed carbon, C, H, N, O, S</td> </tr> <tr> <td data-bbox="712 855 1494 951">— Br, Cl, F — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Ti, V, Zn)</td> </tr> <tr> <td data-bbox="322 951 712 1031" rowspan="2">HFO</td> <td data-bbox="712 951 1494 991">— Ash</td> </tr> <tr> <td data-bbox="712 991 1494 1031">— C, S, N, Ni, V</td> </tr> <tr> <td data-bbox="322 1031 712 1110" rowspan="2">Gas oil</td> <td data-bbox="712 1031 1494 1070">— Ash</td> </tr> <tr> <td data-bbox="712 1070 1494 1110">— N, C, S</td> </tr> <tr> <td data-bbox="322 1110 712 1198" rowspan="2">Natural gas</td> <td data-bbox="712 1110 1494 1150">— LHV</td> </tr> <tr> <td data-bbox="712 1150 1494 1198">— CH₄, C₂H₆, C₃, C₄₊, CO₂, N₂, Wobbe index</td> </tr> <tr> <td data-bbox="322 1198 712 1286">Process fuels from the chemical industry⁽²⁷⁾</td> <td data-bbox="712 1198 1494 1286">— Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Ti, V, Zn)</td> </tr> <tr> <td data-bbox="322 1286 712 1353">Iron and steel process gases</td> <td data-bbox="712 1286 1494 1353">— LHV, CH₄ (for COG), C_xH_y (for COG), CO₂, H₂, N₂, total sulphur, dust, Wobbe index</td> </tr> </tbody> </table>	Fuel(s)	Substances/Parameters subject to characterisation	Biomass/peat	— LHV	— moisture	— Ash	— C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn)	Coal/lignite	— LHV	— Moisture	— Volatiles, ash, fixed carbon, C, H, N, O, S	— Br, Cl, F — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Ti, V, Zn)	HFO	— Ash	— C, S, N, Ni, V	Gas oil	— Ash	— N, C, S	Natural gas	— LHV	— CH ₄ , C ₂ H ₆ , C ₃ , C ₄₊ , CO ₂ , N ₂ , Wobbe index	Process fuels from the chemical industry ⁽²⁷⁾	— Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Ti, V, Zn)	Iron and steel process gases	— LHV, CH ₄ (for COG), C _x H _y (for COG), CO ₂ , H ₂ , N ₂ , total sulphur, dust, Wobbe index		
Fuel(s)	Substances/Parameters subject to characterisation																											
Biomass/peat	— LHV																											
	— moisture																											
	— Ash																											
	— C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn)																											
Coal/lignite	— LHV																											
	— Moisture																											
	— Volatiles, ash, fixed carbon, C, H, N, O, S																											
	— Br, Cl, F — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Ti, V, Zn)																											
HFO	— Ash																											
	— C, S, N, Ni, V																											
Gas oil	— Ash																											
	— N, C, S																											
Natural gas	— LHV																											
	— CH ₄ , C ₂ H ₆ , C ₃ , C ₄₊ , CO ₂ , N ₂ , Wobbe index																											
Process fuels from the chemical industry ⁽²⁷⁾	— Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Ti, V, Zn)																											
Iron and steel process gases	— LHV, CH ₄ (for COG), C _x H _y (for COG), CO ₂ , H ₂ , N ₂ , total sulphur, dust, Wobbe index																											

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement								
	<table border="1"> <tr> <td data-bbox="322 384 712 544">Waste⁽²⁸⁾</td> <td data-bbox="712 384 1496 544"> <ul style="list-style-type: none"> — LHV — Moisture — Volatiles, ash, Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) </td> </tr> </table>	Waste ⁽²⁸⁾	<ul style="list-style-type: none"> — LHV — Moisture — Volatiles, ash, Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) 								
Waste ⁽²⁸⁾	<ul style="list-style-type: none"> — LHV — Moisture — Volatiles, ash, Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) 										
10	<p>In order to reduce emissions to air and/or to water during other than normal operating conditions (OTNOC), BAT is to set up and implement a management plan as part of the environmental management system (see BAT 1), commensurate with the relevance of potential pollutant releases, that includes the following elements:</p> <ul style="list-style-type: none"> — appropriate design of the systems considered relevant in causing OTNOC that may have an impact on emissions to air, water and/or soil (e.g. low-load design concepts for reducing the minimum start-up and shutdown loads for stable generation in gas turbines), — set-up and implementation of a specific preventive maintenance plan for these relevant systems, — review and recording of emissions caused by OTNOC and associated circumstances and implementation of corrective actions if necessary, — periodic assessment of the overall emissions during OTNOC (e.g. frequency of events, duration, emissions quantification/estimation) and implementation of corrective actions if necessary. 	FC	The operator has confirmed that ONTOC procedures will be included in the EMS. Improvement Condition 3 has been updated requiring that details of OTNOC are included in the EMS.								
11	<p>BAT is to appropriately monitor emissions to air and/or to water during OTNOC.</p> <p>Description The monitoring can be carried out by direct measurement of emissions or by monitoring of surrogate parameters if this proves to be of equal or better scientific quality than the direct measurement of emissions. Emissions during start-up and shutdown (SU/SD) may be assessed based on a detailed emission measurement carried out for a typical SU/SD procedure at least once every year, and using the results of this measurement to estimate the emissions for each and every SU/SD throughout the year.</p>	CC	The operator has confirmed that during OTNOC continuous emission monitoring continues.								
12	<p>In order to increase the energy efficiency of combustion, gasification and/or IGCC units operated $\geq 1\,500$ h/yr, BAT is to use an appropriate combination of the techniques given below.</p> <table border="1" data-bbox="322 1171 1496 1315"> <thead> <tr> <th data-bbox="322 1171 367 1203"></th> <th data-bbox="367 1171 577 1203">Technique</th> <th data-bbox="577 1171 1057 1203">Description</th> <th data-bbox="1057 1171 1496 1203">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 1203 367 1315">a.</td> <td data-bbox="367 1203 577 1315">Combustion optimisation</td> <td data-bbox="577 1203 1057 1315">See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues</td> <td data-bbox="1057 1203 1496 1315">Generally applicable</td> </tr> </tbody> </table>		Technique	Description	Applicability	a.	Combustion optimisation	See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues	Generally applicable	CC	<p>The operator has confirmed that the following measures are in place:</p> <p>a) Combustion optimisation – The plant is constantly monitored and automatic adjustments are made to achieve good combustion. The operators will also tune</p>
	Technique	Description	Applicability								
a.	Combustion optimisation	See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues	Generally applicable								

BAT Concn. Number	Summary of BAT Conclusion requirement				Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	b.	Optimisation of the working medium conditions	Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO _x emissions or the characteristics of energy demanded			<p>combustion manually when required.</p> <p>b) Optimisation of the working medium conditions – The plant is normally operated at maximum steam temperature and pressure to achieve the best efficiency of the plant.</p> <p>c) Optimisation of the steam cycle – The turbine exhaust is operated at the best vacuum conditions at all loads automatically controlled by the monitoring system.</p> <p>d) Minimisation of energy consumption – All main electrical drives are controlled by variable speed drives to minimise energy consumption. All non-essential lighting is controlled via photo cells. Workshop and control room heating and hot water systems are heated by an energy recovery unit.</p> <p>e) Preheating of combustion air – Air is drawn from the top of the boiler house and has been warmed by heat from the plant.</p> <p>g) Advanced control System – The plant has an advanced control system fitted and automatic adjustments are made</p>
	c.	Optimisation of the steam cycle	Operate with lower turbine exhaust pressure by utilisation of the lowest possible temperature of the condenser cooling water, within the design conditions			
	d.	Minimisation of energy consumption	Minimising the internal energy consumption (e.g. greater efficiency of the feed-water pump)			
	e.	Preheating of combustion air	Reuse of part of the heat recovered from the combustion flue-gas to preheat the air used in combustion	Generally applicable within the constraints related to the need to control NO _x emissions		
	f.	Fuel preheating	Preheating of fuel using recovered heat	Generally applicable within the constraints associated with the boiler design and the need to control NO _x emissions		
	g.	Advanced control system	See description in Section 8.2. Computerised control of the main combustion parameters enables the combustion efficiency to be improved	Generally applicable to new units. The applicability to old units may be constrained by the need to retrofit the combustion system and/or control command system		
	h.	Feed-water preheating using recovered heat	Preheat water coming out of the steam condenser with recovered heat, before reusing it in the boiler	Only applicable to steam circuits and not to hot boilers. Applicability to existing units may be limited due to constraints associated with the plant configuration and the amount of recoverable heat		
	i.	Heat recovery by cogeneration (CHP)	Recovery of heat (mainly from the steam system) for producing hot water/steam to be used in industrial processes/activities or in a public network for district heating. Additional heat recovery is possible from: <ul style="list-style-type: none"> — flue-gas — grate cooling — circulating fluidised bed 	Applicable within the constraints associated with the local heat and power demand. The applicability may be limited in the case of gas compressors with an unpredictable operational heat profile		

BAT Concn. Number	Summary of BAT Conclusion requirement				Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	j.	CHP readiness	See description in Section 8.2.	Only applicable to new units where there is a realistic potential for the future use of heat in the vicinity of the unit		<p>to control the combustion and other items e.g. VSD system to improve efficiency.</p> <p>h) Feed-water preheating using recovered heat – The plant is fitted with flue gas coolers that recover heat from the flue gas to pre-heat the feed water.</p> <p>i) Heat recovery by cogeneration (CHP) - Heat export system is currently fitted and in use supplying heat to Discovery park. Heat recovery is also used on site for workshop and control room heating and hot water.</p> <p>j) Minimisation of heat losses – Lagging is fitted and maintained on the boiler and steam / condensate systems.</p>
k.	Flue-gas condenser	See description in Section 8.2.	Generally applicable to CHP units provided there is enough demand for low-temperature heat			
l.	Heat accumulation	Heat accumulation storage in CHP mode	Only applicable to CHP plants. The applicability may be limited in the case of low heat load demand			
m.	Wet stack	See description in Section 8.2.	Generally applicable to new and existing units fitted with wet FGD			
n.	Cooling tower discharge	The release of emissions to air through a cooling tower and not via a dedicated stack	Only applicable to units fitted with wet FGD where reheating of the flue-gas is necessary before release, and where the unit cooling system is a cooling tower			
o.	Fuel pre-drying	The reduction of fuel moisture content before combustion to improve combustion conditions	Applicable to the combustion of biomass and/or peat within the constraints associated with spontaneous combustion risks (e.g. the moisture content of peat is kept above 40 % throughout the delivery chain). The retrofit of existing plants may be restricted by the extra calorific value that can be obtained from the drying operation and by the limited retrofit possibilities offered by some boiler designs or plant configurations			
p.	Minimisation of heat losses	Minimising residual heat losses, e.g. those that occur via the slag or those that can be reduced by insulating radiating sources	Only applicable to solid-fuel-fired combustion units and to gasification/IGCC units			
q.	Advanced materials	Use of advanced materials proven to be capable of withstanding high operating temperatures and pressures and thus to achieve increased steam/combustion process efficiencies	Only applicable to new plants			
r.	Steam turbine upgrades	This includes techniques such as increasing the temperature and pressure of medium-pressure steam, addition of a low-pressure turbine, and modifications to the geometry of the turbine rotor blades	The applicability may be restricted by demand, steam conditions and/or limited plant lifetime			

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	
	s.	Supercritical and ultra-supercritical steam conditions	Use of a steam circuit, including steam reheating systems, in which steam can reach pressures above 220,6 bar and temperatures above 374 °C in the case of supercritical conditions, and above 250 – 300 bar and temperatures above 580 – 600 °C in the case of ultra-supercritical conditions	Only applicable to new units of $\geq 600 \text{ MW}_{\text{th}}$ operated $> 4\,000 \text{ h/yr.}$ Not applicable when the purpose of the unit is to produce low steam temperatures and/or pressures in process industries. Not applicable to gas turbines and engines generating steam in CHP mode. For units combusting biomass, the applicability may be constrained by high-temperature corrosion in the case of certain biomasses		
13	In order to reduce water usage and the volume of contaminated waste water discharged, BAT is to use one or both of the techniques given below.			CC	The operator has confirmed that: a) Water Recycling – Water reclaimed from the rest of the plant is used to wet the ash. Rain water is also harvested and used in the wet ash conveyor, as mist air, in the wet ash pit and boiler water canon systems. b) Dry bottom ash handling – This is a wet ash system and so this is not relevant.	
		Technique	Description	Applicability		
a.		Water recycling	Residual aqueous streams, including run-off water, from the plant are reused for other purposes. The degree of recycling is limited by the quality requirements of the recipient water stream and the water balance of the plant	Not applicable to waste water from cooling systems when water treatment chemicals and/or high concentrations of salts from seawater are present		
b.		Dry bottom ash handling	Dry, hot bottom ash falls from the furnace onto a mechanical conveyor system and is cooled down by ambient air. No water is used in the process.	Only applicable to plants combusting solid fuels. There may be technical restrictions that prevent retrofitting to existing combustion plants		
14	In order to prevent the contamination of uncontaminated waste water and to reduce emissions to water, BAT is to segregate waste water streams and to treat them separately, depending on the pollutant content.			CC	Surface water from roadways and roofs is discharge to the surface water sewer. Process water that cannot be reused within the CHP plant are sent via the foul sewer to Discovery Park Waste Water Treatment plant.	
		Description				
		Waste water streams that are typically segregated and treated include surface run-off water, cooling water, and waste water from flue-gas treatment.				
		Applicability				
		The applicability may be restricted in the case of existing plants due to the configuration of the drainage systems.				

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																																													
			We agree with the operators stated compliance.																																													
15	<p>In order to reduce emissions to water from flue-gas treatment, BAT is to use an appropriate combination of the techniques given below, and to use secondary techniques as close as possible to the source in order to avoid dilution.</p> <table border="1" data-bbox="322 539 1491 1358"> <thead> <tr> <th data-bbox="322 539 712 600">Technique</th> <th data-bbox="712 539 1025 600">Typical pollutants prevented/abated</th> <th data-bbox="1025 539 1491 600">Applicability</th> </tr> </thead> <tbody> <tr> <td colspan="3" data-bbox="322 600 1491 635" style="text-align: center;">Primary techniques</td> </tr> <tr> <td data-bbox="322 635 367 719">a.</td> <td data-bbox="367 635 712 719">Optimised combustion (see BAT 6) and flue-gas treatment systems (e.g. SCR/SNCR, see BAT 7)</td> <td data-bbox="712 635 1025 719">Organic compounds, ammonia (NH₃)</td> </tr> <tr> <td colspan="3" data-bbox="322 719 1491 754" style="text-align: center;">Secondary techniques ⁽²⁹⁾</td> </tr> <tr> <td data-bbox="322 754 367 815">b.</td> <td data-bbox="367 754 712 815">Adsorption on activated carbon</td> <td data-bbox="712 754 1025 815">Organic compounds, mercury (Hg)</td> </tr> <tr> <td data-bbox="322 815 367 951">c.</td> <td data-bbox="367 815 712 951">Aerobic biological treatment</td> <td data-bbox="712 815 1491 951">Biodegradable organic compounds, ammonium (NH₄⁺)</td> </tr> <tr> <td data-bbox="322 951 367 1011">d.</td> <td data-bbox="367 951 712 1011">Anoxic/anaerobic biological treatment</td> <td data-bbox="712 951 1025 1011">Mercury (Hg), nitrate (NO₃⁻), nitrite (NO₂⁻)</td> </tr> <tr> <td data-bbox="322 1011 367 1046">e.</td> <td data-bbox="367 1011 712 1046">Coagulation and flocculation</td> <td data-bbox="712 1011 1025 1046">Suspended solids</td> </tr> <tr> <td data-bbox="322 1046 367 1107">f.</td> <td data-bbox="367 1046 712 1107">Crystallisation</td> <td data-bbox="712 1046 1491 1107">Metals and metalloids, sulphate (SO₄²⁻), fluoride (F⁻)</td> </tr> <tr> <td data-bbox="322 1107 367 1168">g.</td> <td data-bbox="367 1107 712 1168">Filtration (e.g. sand filtration, microfiltration, ultrafiltration)</td> <td data-bbox="712 1107 1025 1168">Suspended solids, metals</td> </tr> <tr> <td data-bbox="322 1168 367 1203">h.</td> <td data-bbox="367 1168 712 1203">Flotation</td> <td data-bbox="712 1168 1025 1203">Suspended solids, free oil</td> </tr> <tr> <td data-bbox="322 1203 367 1238">i.</td> <td data-bbox="367 1203 712 1238">Ion exchange</td> <td data-bbox="712 1203 1025 1238">Metals</td> </tr> <tr> <td data-bbox="322 1238 367 1273">j.</td> <td data-bbox="367 1238 712 1273">Neutralisation</td> <td data-bbox="712 1238 1025 1273">Acids, alkalis</td> </tr> <tr> <td data-bbox="322 1273 367 1308">k.</td> <td data-bbox="367 1273 712 1308">Oxidation</td> <td data-bbox="712 1273 1491 1308">Sulphide (S²⁻), sulphite (SO₃²⁻)</td> </tr> <tr> <td data-bbox="322 1308 367 1358">l.</td> <td data-bbox="367 1308 712 1358">Precipitation</td> <td data-bbox="712 1308 1491 1358">Metals and metalloids, sulphate (SO₄²⁻), fluoride (F⁻)</td> </tr> </tbody> </table>	Technique	Typical pollutants prevented/abated	Applicability	Primary techniques			a.	Optimised combustion (see BAT 6) and flue-gas treatment systems (e.g. SCR/SNCR, see BAT 7)	Organic compounds, ammonia (NH ₃)	Secondary techniques ⁽²⁹⁾			b.	Adsorption on activated carbon	Organic compounds, mercury (Hg)	c.	Aerobic biological treatment	Biodegradable organic compounds, ammonium (NH ₄ ⁺)	d.	Anoxic/anaerobic biological treatment	Mercury (Hg), nitrate (NO ₃ ⁻), nitrite (NO ₂ ⁻)	e.	Coagulation and flocculation	Suspended solids	f.	Crystallisation	Metals and metalloids, sulphate (SO ₄ ²⁻), fluoride (F ⁻)	g.	Filtration (e.g. sand filtration, microfiltration, ultrafiltration)	Suspended solids, metals	h.	Flotation	Suspended solids, free oil	i.	Ion exchange	Metals	j.	Neutralisation	Acids, alkalis	k.	Oxidation	Sulphide (S ²⁻), sulphite (SO ₃ ²⁻)	l.	Precipitation	Metals and metalloids, sulphate (SO ₄ ²⁻), fluoride (F ⁻)	NA	The flue gas treatment at the installation uses dry abatement. Therefore, BAT 15 is not applicable.
Technique	Typical pollutants prevented/abated	Applicability																																														
Primary techniques																																																
a.	Optimised combustion (see BAT 6) and flue-gas treatment systems (e.g. SCR/SNCR, see BAT 7)	Organic compounds, ammonia (NH ₃)																																														
Secondary techniques ⁽²⁹⁾																																																
b.	Adsorption on activated carbon	Organic compounds, mercury (Hg)																																														
c.	Aerobic biological treatment	Biodegradable organic compounds, ammonium (NH ₄ ⁺)																																														
d.	Anoxic/anaerobic biological treatment	Mercury (Hg), nitrate (NO ₃ ⁻), nitrite (NO ₂ ⁻)																																														
e.	Coagulation and flocculation	Suspended solids																																														
f.	Crystallisation	Metals and metalloids, sulphate (SO ₄ ²⁻), fluoride (F ⁻)																																														
g.	Filtration (e.g. sand filtration, microfiltration, ultrafiltration)	Suspended solids, metals																																														
h.	Flotation	Suspended solids, free oil																																														
i.	Ion exchange	Metals																																														
j.	Neutralisation	Acids, alkalis																																														
k.	Oxidation	Sulphide (S ²⁻), sulphite (SO ₃ ²⁻)																																														
l.	Precipitation	Metals and metalloids, sulphate (SO ₄ ²⁻), fluoride (F ⁻)																																														

BAT Concn. Number	Summary of BAT Conclusion requirement				Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	m.	Sedimentation	Suspended solids	Generally applicable		
	n.	Stripping	Ammonia (NH ₃)	Generally applicable		
	The BAT-AELs refer to direct discharges to a receiving water body at the point where the emission leaves the installation.					
	BAT-AELs for direct discharges to a receiving water body from flue-gas treatment					
	Substance/Parameter		BAT-AELs			
			Daily average			
	Total organic carbon (TOC)		20–50 mg/l ₍₃₀₎ ₍₃₁₎ ₍₃₂₎			
	Chemical oxygen demand (COD)		60–150 mg/l ₍₃₀₎ ₍₃₁₎ ₍₃₂₎			
	Total suspended solids (TSS)		10–30 mg/l			
	Fluoride (F ⁻)		10–25 mg/l ₍₃₂₎			
	Sulphate (SO ₄ ²⁻)		1,3–2,0 g/l ₍₃₂₎ ₍₃₃₎ ₍₃₄₎ ₍₃₅₎			
	Sulphide (S ²⁻), easily released		0,1–0,2 mg/l ₍₃₂₎			
	Sulphite (SO ₃ ²⁻)		1–20 mg/l ₍₃₂₎			
	Metals and metalloids		As	10–50 µg/l		
			Cd	2–5 µg/l		
			Cr	10–50 µg/l		
			Cu	10–50 µg/l		
			Hg	0,2–3 µg/l		
			Ni	10–50 µg/l		
			Pb	10–20 µg/l		
16			<p>In order to reduce the quantity of waste sent for disposal from the combustion and/or gasification process and abatement techniques, BAT is to organise operations so as to maximise, in order of priority and taking into account life-cycle thinking:</p> <ul style="list-style-type: none"> (a) waste prevention, e.g. maximise the proportion of residues which arise as by-products; (b) waste preparation for reuse, e.g. according to the specific requested quality criteria; (c) waste recycling; (d) other waste recovery (e.g. energy recovery), 			

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																				
	by implementing an appropriate combination of techniques such as:																								
	<table border="1"> <thead> <tr> <th data-bbox="322 416 360 443"></th> <th data-bbox="360 416 573 443">Technique</th> <th data-bbox="573 416 1081 443">Description</th> <th data-bbox="1081 416 1494 443">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 451 360 603">a.</td> <td data-bbox="360 451 573 603">Generation of gypsum as a by-product</td> <td data-bbox="573 451 1081 603">Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g. as raw material in the plasterboard industry). The quality of limestone used in the wet FGD influences the purity of the gypsum produced</td> <td data-bbox="1081 451 1494 603">Generally applicable within the constraints associated with the required gypsum quality, the health requirements associated to each specific use, and by the market conditions</td> </tr> <tr> <td data-bbox="322 611 360 738">b.</td> <td data-bbox="360 611 573 738">Recycling or recovery of residues in the construction sector</td> <td data-bbox="573 611 1081 738">Recycling or recovery of residues (e.g. from semi-dry desulphurisation processes, fly ash, bottom ash) as a construction material (e.g. in road building, to replace sand in concrete production, or in the cement industry)</td> <td data-bbox="1081 611 1494 738">Generally applicable within the constraints associated with the required material quality (e.g. physical properties, content of harmful substances) associated to each specific use, and by the market conditions</td> </tr> <tr> <td data-bbox="322 746 360 850">c.</td> <td data-bbox="360 746 573 850">Energy recovery by using waste in the fuel mix</td> <td data-bbox="573 746 1081 850">The residual energy content of carbon-rich ash and sludges generated by the combustion of coal, lignite, heavy fuel oil, peat or biomass can be recovered for example by mixing with the fuel</td> <td data-bbox="1081 746 1494 850">Generally applicable where plants can accept waste in the fuel mix and are technically able to feed the fuels into the combustion chamber</td> </tr> <tr> <td data-bbox="322 858 360 1002">d.</td> <td data-bbox="360 858 573 1002">Preparation of spent catalyst for reuse</td> <td data-bbox="573 858 1081 1002">Preparation of catalyst for reuse (e.g. up to four times for SCR catalysts) restores some or all of the original performance, extending the service life of the catalyst to several decades. Preparation of spent catalyst for reuse is integrated in a catalyst management scheme</td> <td data-bbox="1081 858 1494 1002">The applicability may be limited by the mechanical condition of the catalyst and the required performance with respect to controlling NO_x and NH₃ emissions</td> </tr> </tbody> </table>				Technique	Description	Applicability	a.	Generation of gypsum as a by-product	Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g. as raw material in the plasterboard industry). The quality of limestone used in the wet FGD influences the purity of the gypsum produced	Generally applicable within the constraints associated with the required gypsum quality, the health requirements associated to each specific use, and by the market conditions	b.	Recycling or recovery of residues in the construction sector	Recycling or recovery of residues (e.g. from semi-dry desulphurisation processes, fly ash, bottom ash) as a construction material (e.g. in road building, to replace sand in concrete production, or in the cement industry)	Generally applicable within the constraints associated with the required material quality (e.g. physical properties, content of harmful substances) associated to each specific use, and by the market conditions	c.	Energy recovery by using waste in the fuel mix	The residual energy content of carbon-rich ash and sludges generated by the combustion of coal, lignite, heavy fuel oil, peat or biomass can be recovered for example by mixing with the fuel	Generally applicable where plants can accept waste in the fuel mix and are technically able to feed the fuels into the combustion chamber	d.	Preparation of spent catalyst for reuse	Preparation of catalyst for reuse (e.g. up to four times for SCR catalysts) restores some or all of the original performance, extending the service life of the catalyst to several decades. Preparation of spent catalyst for reuse is integrated in a catalyst management scheme	The applicability may be limited by the mechanical condition of the catalyst and the required performance with respect to controlling NO _x and NH ₃ emissions		<p>- Bark that is liberated as part of the process to create the wood chips is sent off site as a product for use as a mulch on gardens and in horticulture.</p> <p>-Wood dust and chips that are cleaned up using the site vacuum system are recycled into the fuel delivery pits and it is used as fuel in the boiler.</p> <p>a) Generation of gypsum as a by-product - wet flue gas treatment is not utilised at this installation and so this is not applicable.</p> <p>b) Recycling or recovery of residues in the construction sector – The intention for bottom ash and fly ash is for it to be reused as a fertiliser. Full details have now been provided following the completion of Preoperational Condition 4.</p> <p>d) Preparation of spent catalyst for reuse – SNCR rather than SCR is used. Therefore, this technique is not applicable.</p> <p>We agree with the operators stated compliance.</p>
	Technique	Description	Applicability																						
a.	Generation of gypsum as a by-product	Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g. as raw material in the plasterboard industry). The quality of limestone used in the wet FGD influences the purity of the gypsum produced	Generally applicable within the constraints associated with the required gypsum quality, the health requirements associated to each specific use, and by the market conditions																						
b.	Recycling or recovery of residues in the construction sector	Recycling or recovery of residues (e.g. from semi-dry desulphurisation processes, fly ash, bottom ash) as a construction material (e.g. in road building, to replace sand in concrete production, or in the cement industry)	Generally applicable within the constraints associated with the required material quality (e.g. physical properties, content of harmful substances) associated to each specific use, and by the market conditions																						
c.	Energy recovery by using waste in the fuel mix	The residual energy content of carbon-rich ash and sludges generated by the combustion of coal, lignite, heavy fuel oil, peat or biomass can be recovered for example by mixing with the fuel	Generally applicable where plants can accept waste in the fuel mix and are technically able to feed the fuels into the combustion chamber																						
d.	Preparation of spent catalyst for reuse	Preparation of catalyst for reuse (e.g. up to four times for SCR catalysts) restores some or all of the original performance, extending the service life of the catalyst to several decades. Preparation of spent catalyst for reuse is integrated in a catalyst management scheme	The applicability may be limited by the mechanical condition of the catalyst and the required performance with respect to controlling NO _x and NH ₃ emissions																						

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
17	In order to reduce noise emissions, BAT is to use one or a combination of the techniques given below.			CC	<p>The operator has confirmed that the following measures are in place:</p> <p>a) Operational measures - Regular maintenance is undertaken in line with the original equipment manufacturers recommendations. These are amended if issues are identified to increase the frequency.</p> <p>Regular (minimum twice per day) site inspections undertaken which includes observing the noise from equipment.</p> <p>Doors are kept closed when not required to be open for operational reasons.</p> <p>b)Low Noise Equipment - Consideration was given to noise limits as stated in the planning requirements when selecting equipment for outside use. This principle will apply when selecting new or replacement equipment.</p> <p>c) Noise attenuation- The site is located with a number of buildings between the site and the residential areas.</p> <p>d) Noise control equipment - Equipment and buildings were</p>
Technique		Description	Applicability		
a.	Operational measures	These include: <ul style="list-style-type: none"> — improved inspection and maintenance of equipment — closing of doors and windows of enclosed areas, if possible — equipment operated by experienced staff — avoidance of noisy activities at night, if possible — provisions for noise control during maintenance activities 	Generally applicable		
b.	Low-noise equipment	This potentially includes compressors, pumps and disks	Generally applicable when the equipment is new or replaced		
c.	Noise attenuation	Noise propagation can be reduced by inserting obstacles between the emitter and the receiver. Appropriate obstacles include protection walls, embankments and buildings	Generally applicable to new plants. In the case of existing plants, the insertion of obstacles may be restricted by lack of space		
d.	Noise-control equipment	This includes: <ul style="list-style-type: none"> — noise-reducers — equipment insulation — enclosure of noisy equipment — soundproofing of buildings 	The applicability may be restricted by lack of space		
e.	Appropriate location of equipment and buildings	Noise levels can be reduced by increasing the distance between the emitter and the receiver and by using buildings as noise screens	Generally applicable to new plant		

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																		
			<p>designed to meet the noise levels as required under the planning conditions.</p> <p>e) Appropriate location -The site is located with a number of buildings between the site and the residential areas.</p>																		
Combustion of solid fuels only																					
Combustion of solid fuels only BAT Conclusions 18 to 23 applicable to coal and/or lignite Deleted from the table as they are not applicable to the activities carried out at the installation. 100% biomass-firing.																					
2.2.1 Table 8	<p>BAT-associated energy efficiency levels (BAT-AEELs) for the combustion of solid biomass and/or peat</p> <table border="1" data-bbox="322 847 1491 1058"> <thead> <tr> <th data-bbox="322 847 600 991" rowspan="3">Type of combustion unit</th> <th colspan="4" data-bbox="600 847 1491 887">BAT-AEELs ⁽⁷³⁾ ⁽⁷⁴⁾</th> </tr> <tr> <th colspan="2" data-bbox="600 887 1093 954">Net electrical efficiency (%) ⁽⁷⁵⁾</th> <th colspan="2" data-bbox="1093 887 1491 954">Net total fuel utilisation (%) ⁽⁷⁶⁾ ⁽⁷⁷⁾</th> </tr> <tr> <th data-bbox="600 954 846 991">New unit ⁽⁷⁸⁾</th> <th data-bbox="846 954 1093 991">Existing unit</th> <th data-bbox="1093 954 1294 991">New unit</th> <th data-bbox="1294 954 1491 991">Existing unit</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 991 600 1058">Solid biomass and/or peat boiler</td> <td data-bbox="600 991 846 1058">33,5–to > 38</td> <td data-bbox="846 991 1093 1058">28–38</td> <td data-bbox="1093 991 1294 1058">73–99</td> <td data-bbox="1294 991 1491 1058">73–99</td> </tr> </tbody> </table>	Type of combustion unit	BAT-AEELs ⁽⁷³⁾ ⁽⁷⁴⁾				Net electrical efficiency (%) ⁽⁷⁵⁾		Net total fuel utilisation (%) ⁽⁷⁶⁾ ⁽⁷⁷⁾		New unit ⁽⁷⁸⁾	Existing unit	New unit	Existing unit	Solid biomass and/or peat boiler	33,5–to > 38	28–38	73–99	73–99	CC	The operator has confirmed that the net electrical efficiency of the plant is 34.595% based upon a performance test undertaken on November 2018.
Type of combustion unit	BAT-AEELs ⁽⁷³⁾ ⁽⁷⁴⁾																				
	Net electrical efficiency (%) ⁽⁷⁵⁾		Net total fuel utilisation (%) ⁽⁷⁶⁾ ⁽⁷⁷⁾																		
	New unit ⁽⁷⁸⁾	Existing unit	New unit	Existing unit																	
Solid biomass and/or peat boiler	33,5–to > 38	28–38	73–99	73–99																	
24	<p>In order to prevent or reduce NO_x emissions to air while limiting CO and N₂O emissions to air from the combustion of solid biomass and/or peat, BAT is to use one or a combination of the techniques given below.</p> <table border="1" data-bbox="322 1129 1491 1361"> <thead> <tr> <th data-bbox="322 1129 651 1166">Technique</th> <th data-bbox="651 1129 981 1166">Description</th> <th data-bbox="981 1129 1491 1166">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 1166 651 1203">a. Combustion optimisation</td> <td data-bbox="651 1166 981 1203" rowspan="5">See descriptions in Section 8.3</td> <td data-bbox="981 1166 1491 1203" rowspan="5">Generally applicable</td> </tr> <tr> <td data-bbox="322 1203 651 1240">b. Low-NO_x burners (LNB)</td> </tr> <tr> <td data-bbox="322 1240 651 1276">c. Air staging</td> </tr> <tr> <td data-bbox="322 1276 651 1313">d. Fuel staging</td> </tr> <tr> <td data-bbox="322 1313 651 1361">e. Flue-gas recirculation</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Combustion optimisation	See descriptions in Section 8.3	Generally applicable	b. Low-NO _x burners (LNB)	c. Air staging	d. Fuel staging	e. Flue-gas recirculation	CC	<p>The operator has confirmed the following techniques are in place:</p> <p>a) Combustion optimisation is completed by the monitoring system and manual adjustments by the operators when required.</p> <p>c) Air staging – Air is fed into the boiler in different areas to achieve good combustion. Primary,</p>								
Technique	Description	Applicability																			
a. Combustion optimisation	See descriptions in Section 8.3	Generally applicable																			
b. Low-NO _x burners (LNB)																					
c. Air staging																					
d. Fuel staging																					
e. Flue-gas recirculation																					

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																												
	f. Selective non-catalytic reduction (SNCR)	See description in Section 8.3. Can be applied with 'slip' SCR	Not applicable to combustion plants operated < 500 h/yr with highly variable boiler loads. The applicability may be limited in the case of combustion plants operated between 500 h/yr and 1 500 h/yr with highly variable boiler loads. For existing combustion plants, applicable within the constraints associated with the required temperature window and residence time for the injected reactants		secondary, spreader air systems are fitted. d) Fuel staging – The fuel is not staged but can be varied across the four sections of the grate when required. f) SNCR – installed, currently utilised when NO _x is > setpoint. The system can be modified to drive NO _x down to 180mg/m ³ with subsequent increase in ammonia release to atmosphere.																												
	g. Selective catalytic reduction (SCR)	See description in Section 8.3. The use of high-alkali fuels (e.g. straw) may require the SCR to be installed downstream of the dust abatement system	Not applicable to combustion plants operated < 500 h/yr. There may be economic restrictions for retrofitting existing combustion plants of < 300 MW _{th} . Not generally applicable to existing combustion plants of < 100 MW _{th}																														
BAT-associated emission levels (BAT-AELs) for NO_x emissions to air from the combustion of solid biomass and/or peat																																	
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th data-bbox="324 946 712 1098" rowspan="3">Combustion plant total rated thermal input (MW_{th})</th> <th colspan="4" data-bbox="723 946 1482 970" style="text-align: center;">BAT-AELs (mg/Nm³)</th> </tr> <tr> <th colspan="2" data-bbox="723 978 1032 1034" style="text-align: center;">Yearly average</th> <th colspan="2" data-bbox="1043 978 1473 1034" style="text-align: center;">Daily average or average over the sampling period</th> </tr> <tr> <th data-bbox="723 1042 846 1098" style="text-align: center;">New plant</th> <th data-bbox="857 1042 1032 1098" style="text-align: center;">Existing plant ⁽⁷⁹⁾</th> <th data-bbox="1043 1042 1218 1098" style="text-align: center;">New plant</th> <th data-bbox="1229 1042 1473 1098" style="text-align: center;">Existing plant ⁽⁸⁰⁾</th> </tr> </thead> <tbody> <tr> <td data-bbox="324 1106 712 1169">50–100</td> <td data-bbox="723 1106 846 1169">70–150 ⁽⁸¹⁾</td> <td data-bbox="857 1106 1032 1169">70–225 ⁽⁸²⁾</td> <td data-bbox="1043 1106 1218 1169">120–200 ⁽⁸³⁾</td> <td data-bbox="1229 1106 1473 1169">120–275 ⁽⁸⁴⁾</td> </tr> <tr> <td data-bbox="324 1177 712 1209">100–300</td> <td data-bbox="723 1177 846 1209">50–140</td> <td data-bbox="857 1177 1032 1209">50–180</td> <td data-bbox="1043 1177 1218 1209">100–200</td> <td data-bbox="1229 1177 1473 1209">100–220</td> </tr> <tr> <td data-bbox="324 1217 712 1241">≥ 300</td> <td data-bbox="723 1217 846 1241">40–140</td> <td data-bbox="857 1217 1032 1241">40–150 ⁽⁸⁵⁾</td> <td data-bbox="1043 1217 1218 1241">65–150</td> <td data-bbox="1229 1217 1473 1241">95–165 ⁽⁸⁶⁾</td> </tr> </tbody> </table>						Combustion plant total rated thermal input (MW _{th})	BAT-AELs (mg/Nm ³)				Yearly average		Daily average or average over the sampling period		New plant	Existing plant ⁽⁷⁹⁾	New plant	Existing plant ⁽⁸⁰⁾	50–100	70–150 ⁽⁸¹⁾	70–225 ⁽⁸²⁾	120–200 ⁽⁸³⁾	120–275 ⁽⁸⁴⁾	100–300	50–140	50–180	100–200	100–220	≥ 300	40–140	40–150 ⁽⁸⁵⁾	65–150	95–165 ⁽⁸⁶⁾
Combustion plant total rated thermal input (MW _{th})	BAT-AELs (mg/Nm ³)																																
	Yearly average		Daily average or average over the sampling period																														
	New plant	Existing plant ⁽⁷⁹⁾	New plant	Existing plant ⁽⁸⁰⁾																													
50–100	70–150 ⁽⁸¹⁾	70–225 ⁽⁸²⁾	120–200 ⁽⁸³⁾	120–275 ⁽⁸⁴⁾																													
100–300	50–140	50–180	100–200	100–220																													
≥ 300	40–140	40–150 ⁽⁸⁵⁾	65–150	95–165 ⁽⁸⁶⁾																													
<p>As an indication, the yearly average CO emission levels will generally be:</p> <p>— < 30–250 mg/Nm³ for existing combustion plants of 50–100 MW_{th} operated ≥ 1 500 h/yr, or new combustion plants of 50–100 MW_{th},</p>																																	

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																												
	<p>— < 30–160 mg/Nm³ for existing combustion plants of 100–300 MW_{th} operated ≥ 1 500 h/yr, or new combustion plants of 100–300 MW_{th},</p> <p>— < 30–80 mg/Nm³ for existing combustion plants of ≥ 300 MW_{th} operated ≥ 1 500 h/yr, or new combustion plants of ≥ 300 MW_{th}.</p>																														
25	<p>In order to prevent or reduce SO_x, HCl and HF emissions to air from the combustion of solid biomass and/or peat, BAT is to use one or a combination of the techniques given below.</p> <table border="1" data-bbox="322 592 1491 1182"> <thead> <tr> <th data-bbox="322 592 640 628">Technique</th> <th data-bbox="640 592 853 628">Description</th> <th data-bbox="853 592 1491 628">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 628 640 695">a. Boiler sorbent injection (in-furnace or in-bed)</td> <td data-bbox="640 628 853 1182" rowspan="8">See descriptions in Section 8.4</td> <td data-bbox="853 628 1491 970">Generally applicable</td> </tr> <tr> <td data-bbox="322 695 640 762">b. Duct sorbent injection (DSI)</td> <td data-bbox="853 970 1491 1090">Not applicable to combustion plants operated < 500 h/yr. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr</td> </tr> <tr> <td data-bbox="322 762 640 829">c. Spray dry absorber (SDA)</td> <td data-bbox="853 1090 1491 1182">Applicable within the constraints associated with the availability of different types of fuel, which may be impacted by the energy policy of the Member State</td> </tr> <tr> <td data-bbox="322 829 640 896">d. Circulating fluidised bed (CFB) dry scrubber</td> <td></td> </tr> <tr> <td data-bbox="322 896 640 963">e. Wet scrubbing</td> <td></td> </tr> <tr> <td data-bbox="322 963 640 1031">f. Flue-gas condenser</td> <td></td> </tr> <tr> <td data-bbox="322 1031 640 1098">g. Wet flue-gas desulphurisation (wet FGD)</td> <td></td> </tr> <tr> <td data-bbox="322 1098 640 1182">h. Fuel choice</td> <td></td> </tr> </tbody> </table> <p>BAT-associated emission levels (BAT-AELs) for SO₂ emissions to air from the combustion of solid biomass and/or peat</p> <table border="1" data-bbox="322 1267 1491 1369"> <thead> <tr> <th data-bbox="322 1267 714 1369" rowspan="2">Combustion plant total rated thermal input (MW_{th})</th> <th colspan="2" data-bbox="714 1267 1491 1303">BAT-AELs for SO₂ (mg/Nm³)</th> </tr> <tr> <th data-bbox="714 1303 1030 1369">Yearly average</th> <th data-bbox="1030 1303 1491 1369">Daily average or average over the sampling period</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 1369 714 1375"></td> <td data-bbox="714 1369 1030 1375"></td> <td data-bbox="1030 1369 1491 1375"></td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Boiler sorbent injection (in-furnace or in-bed)	See descriptions in Section 8.4	Generally applicable	b. Duct sorbent injection (DSI)	Not applicable to combustion plants operated < 500 h/yr. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr	c. Spray dry absorber (SDA)	Applicable within the constraints associated with the availability of different types of fuel, which may be impacted by the energy policy of the Member State	d. Circulating fluidised bed (CFB) dry scrubber		e. Wet scrubbing		f. Flue-gas condenser		g. Wet flue-gas desulphurisation (wet FGD)		h. Fuel choice		Combustion plant total rated thermal input (MW _{th})	BAT-AELs for SO ₂ (mg/Nm ³)		Yearly average	Daily average or average over the sampling period				CC	<p>The operator has confirmed the following measures are in place:</p> <p>b) Duct sorbent injection (DSI) – Lime is injected into the flue gas ductwork prior to the flue gas bag filter system, used to reduce the level of SO₂</p>
Technique	Description	Applicability																													
a. Boiler sorbent injection (in-furnace or in-bed)	See descriptions in Section 8.4	Generally applicable																													
b. Duct sorbent injection (DSI)		Not applicable to combustion plants operated < 500 h/yr. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr																													
c. Spray dry absorber (SDA)		Applicable within the constraints associated with the availability of different types of fuel, which may be impacted by the energy policy of the Member State																													
d. Circulating fluidised bed (CFB) dry scrubber																															
e. Wet scrubbing																															
f. Flue-gas condenser																															
g. Wet flue-gas desulphurisation (wet FGD)																															
h. Fuel choice																															
Combustion plant total rated thermal input (MW _{th})	BAT-AELs for SO ₂ (mg/Nm ³)																														
	Yearly average	Daily average or average over the sampling period																													

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																																																												
	<table border="1"> <thead> <tr> <th></th> <th>New plant</th> <th>Existing plant ⁽⁸⁷⁾</th> <th>New plant</th> <th>Existing plant ⁽⁸⁸⁾</th> </tr> </thead> <tbody> <tr> <td>< 100</td> <td>15–70</td> <td>15–100</td> <td>30–175</td> <td>30–215</td> </tr> <tr> <td>100–300</td> <td>< 10–50</td> <td>< 10–70 ⁽⁸⁹⁾</td> <td>< 20–85</td> <td>< 20–175 ⁽⁹⁰⁾</td> </tr> <tr> <td>≥ 300</td> <td>< 10–35</td> <td>< 10–50 ⁽⁸⁹⁾</td> <td>< 20–70</td> <td>< 20–85 ⁽⁹¹⁾</td> </tr> </tbody> </table> <p>BAT-associated emission levels (BAT-AELs) for HCl and HF emissions to air from the combustion of solid biomass and/or peat</p> <table border="1"> <thead> <tr> <th rowspan="3">Combustion plant total rated thermal input (MW_{th})</th> <th colspan="4">BAT-AELs for HCl (mg/Nm³) ⁽⁹²⁾ ⁽⁹³⁾</th> <th colspan="2">BAT-AELs for HF (mg/Nm³)</th> </tr> <tr> <th colspan="2">Yearly average or average of samples obtained during one year</th> <th colspan="2">Daily average or average over the sampling period</th> <th colspan="2">Average over the sampling period</th> </tr> <tr> <th>New plant</th> <th>Existing plant ⁽⁹⁴⁾ ⁽⁹⁵⁾</th> <th>New plant</th> <th>Existing plant ⁽⁹⁶⁾</th> <th>New plant</th> <th>Existing plant ⁽⁹⁶⁾</th> </tr> </thead> <tbody> <tr> <td>< 100</td> <td>1–7</td> <td>1–15</td> <td>1–12</td> <td>1–35</td> <td>< 1</td> <td>< 1,5</td> </tr> <tr> <td>100–300</td> <td>1–5</td> <td>1–9</td> <td>1–12</td> <td>1–12</td> <td>< 1</td> <td>< 1</td> </tr> <tr> <td>≥ 300</td> <td>1–5</td> <td>1–5</td> <td>1–12</td> <td>1–12</td> <td>< 1</td> <td>< 1</td> </tr> </tbody> </table>		New plant	Existing plant ⁽⁸⁷⁾	New plant	Existing plant ⁽⁸⁸⁾	< 100	15–70	15–100	30–175	30–215	100–300	< 10–50	< 10–70 ⁽⁸⁹⁾	< 20–85	< 20–175 ⁽⁹⁰⁾	≥ 300	< 10–35	< 10–50 ⁽⁸⁹⁾	< 20–70	< 20–85 ⁽⁹¹⁾	Combustion plant total rated thermal input (MW _{th})	BAT-AELs for HCl (mg/Nm ³) ⁽⁹²⁾ ⁽⁹³⁾				BAT-AELs for HF (mg/Nm ³)		Yearly average or average of samples obtained during one year		Daily average or average over the sampling period		Average over the sampling period		New plant	Existing plant ⁽⁹⁴⁾ ⁽⁹⁵⁾	New plant	Existing plant ⁽⁹⁶⁾	New plant	Existing plant ⁽⁹⁶⁾	< 100	1–7	1–15	1–12	1–35	< 1	< 1,5	100–300	1–5	1–9	1–12	1–12	< 1	< 1	≥ 300	1–5	1–5	1–12	1–12	< 1	< 1		
	New plant	Existing plant ⁽⁸⁷⁾	New plant	Existing plant ⁽⁸⁸⁾																																																											
< 100	15–70	15–100	30–175	30–215																																																											
100–300	< 10–50	< 10–70 ⁽⁸⁹⁾	< 20–85	< 20–175 ⁽⁹⁰⁾																																																											
≥ 300	< 10–35	< 10–50 ⁽⁸⁹⁾	< 20–70	< 20–85 ⁽⁹¹⁾																																																											
Combustion plant total rated thermal input (MW _{th})	BAT-AELs for HCl (mg/Nm ³) ⁽⁹²⁾ ⁽⁹³⁾				BAT-AELs for HF (mg/Nm ³)																																																										
	Yearly average or average of samples obtained during one year		Daily average or average over the sampling period		Average over the sampling period																																																										
	New plant	Existing plant ⁽⁹⁴⁾ ⁽⁹⁵⁾	New plant	Existing plant ⁽⁹⁶⁾	New plant	Existing plant ⁽⁹⁶⁾																																																									
< 100	1–7	1–15	1–12	1–35	< 1	< 1,5																																																									
100–300	1–5	1–9	1–12	1–12	< 1	< 1																																																									
≥ 300	1–5	1–5	1–12	1–12	< 1	< 1																																																									
26	<p>In order to reduce dust and particulate-bound metal emissions to air from the combustion of solid biomass and/or peat, BAT is to use one or a combination of the techniques given below.</p> <table border="1"> <thead> <tr> <th>Technique</th> <th>Description</th> <th>Applicability</th> </tr> </thead> <tbody> <tr> <td>a. Electrostatic precipitator (ESP)</td> <td rowspan="2">See description in Section 8.5</td> <td rowspan="2">Generally applicable</td> </tr> <tr> <td>b. Bag filter</td> </tr> <tr> <td>c. Dry or semi-dry FGD system</td> <td rowspan="2">See descriptions in Section 8.5</td> <td rowspan="2">See applicability in BAT 25</td> </tr> <tr> <td>d. Wet flue-gas desulphurisation (wet FGD)</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Electrostatic precipitator (ESP)	See description in Section 8.5	Generally applicable	b. Bag filter	c. Dry or semi-dry FGD system	See descriptions in Section 8.5	See applicability in BAT 25	d. Wet flue-gas desulphurisation (wet FGD)	CC	<p>The operator has confirmed that the following measures are in place:</p> <p>b) Bag filter – is installed and lime is injected prior to the bag filter. The differential pressure is monitored across the bag filter and pulse air is used to clean the bag filter when required. The APC residue is collected in the APC silo or big bags. The APC residue is</p>																																																	
Technique	Description	Applicability																																																													
a. Electrostatic precipitator (ESP)	See description in Section 8.5	Generally applicable																																																													
b. Bag filter																																																															
c. Dry or semi-dry FGD system	See descriptions in Section 8.5	See applicability in BAT 25																																																													
d. Wet flue-gas desulphurisation (wet FGD)																																																															

BAT Concn. Number	Summary of BAT Conclusion requirement				Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	
	e. Fuel choice	See description in Section 8.5	Applicable within the constraints associated with the availability of different types of fuel, which may be impacted by the energy policy of the Member State			transported off-site in sealed tankers.	
BAT-associated emission levels (BAT-AELs) for dust emissions to air from the combustion of solid biomass and/or peat							
Combustion plant total rated thermal input (MW_{th})		BAT-AELs for dust (mg/Nm³)					
		Yearly average		Daily average or average over the sampling period			
		New plant	Existing plant ⁽⁹⁷⁾	New plant	Existing plant ⁽⁹⁸⁾		
< 100		2–5	2–15	2–10	2–22		
100–300		2–5	2–12	2–10	2–18		
≥ 300		2–5	2–10	2–10	2–16		
27	In order to prevent or reduce mercury emissions to air from the combustion of solid biomass and/or peat, BAT is to use one or a combination of the techniques given below.				CC	The operator has confirmed that the following measures are in place: c) Fuel choice - Virgin and clean waste wood should not contain mercury. e) Bag filter – a bag filter is installed which will provide co-benefit.	
Technique		Description		Applicability			
Specific techniques to reduce mercury emissions							
a.	Carbon sorbent (e.g. activated carbon or halogenated activated carbon) injection in the flue-gas	See descriptions in Section 8.5		Generally applicable			
b.	Use of halogenated additives in the fuel or injected in the furnace			Generally applicable in the case of a low halogen content in the fuel			
c.	Fuel choice			Applicable within the constraints associated with the availability of different types of fuel, which may be impacted by the energy policy of the Member State			
Co-benefit from techniques primarily used to reduce emissions of other pollutants							
d.	Electrostatic precipitator (ESP)			Generally applicable			

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	e.	Bag filter	See descriptions in Section 8.5. The techniques are mainly used for dust control		
f.	Dry or semi-dry FGD system	See descriptions in Section 8.5.	See applicability in BAT 25		
g.	Wet flue-gas desulphurisation (wet FGD)	The techniques are mainly used for SO _x , HCl and/or HF control			
The BAT-associated emission level (BAT-AEL) for mercury emissions to air from the combustion of solid biomass and/or peat is < 1–5 µg/Nm ³ as average over the sampling period.					

6. Review and assessment of derogation requests made by the operator in relation to BAT Conclusions which include an associated emission level (AEL) value

The IED enables a competent authority to allow derogations from BAT AELs stated in BAT Conclusions under specific circumstances as detailed under Article 15(4):

By way of derogation from paragraph 3, and without prejudice to Article 18, the competent authority may, in specific cases, set less strict emission limit values. Such a derogation may apply only where an assessment shows that the achievement of emission levels associated with the best available techniques as described in BAT conclusions would lead to disproportionately higher costs compared to the environmental benefits due to:

(a) the geographical location or the local environmental conditions of the installation concerned; or

(b) the technical characteristics of the installation concerned.

As part of their Regulation 61 Note response, the operator has not requested a derogation from compliance with any AEL values.

7. Emissions to Water

The consolidated permit incorporates two current discharges to sewer identified as S1 and S2. There are no limits set by the existing permit.

As part of our delivery of the Water Framework Directive (WFD) requirements, we need to identify and assess the impact of sources of hazardous pollutants to surface waters from regulated industry. This is relevant to discharges to surface water and/or sewer where there are flue gas treatment activities to which BAT Conclusion 15 applies.

BAT Conclusion 15 requires a reduction in emissions to water from flue-gas treatment. The Operator confirmed that this is not applicable as there is no wet flue-gas treatment at the installation. We agree with the applicability of this BAT Conclusion, refer to Section 6 of this document.

There are no BAT AELs specified in the BAT Conclusions for this type of plant. We have therefore not carried out any additional assessment of the emissions to water as part of this review.

A H1 assessment was completed with the original permit application (EPR/LP3034RD/A001) for the discharge to sewer. All emissions screened out and no further assessment was necessary.

8 Additional IED Chapter II requirements:

Black start operations

In the event of a black out National Grid would call on combustion plant to operate and may require them to do so outside their permitted conditions. We have dedicated black start plant and they are permitted to run as such but this scenario is relevant to the rest of the large combustion plant which could be called depending on the circumstances.

A risk assessment will be carried out by Energy UK/Joint Environmental Programme on behalf of Large Combustion Plant connected to the National Transmission System. Air emissions modelling will be based on generic black start scenarios to establish whether they have the potential to have local impact on the environment or not (on a national basis). If the modelling demonstrates that no significant impacts are likely, the plant can operate under condition 2.3.7. This conditions allows the hourly ELVs for plants operating under a black start instruction to be discounted for the purpose of reporting. We would also require there to be a procedure in place for minimisation of emissions in the case of a black start event and for reporting in the event of a black start. This modelling and the procedures have not been agreed in advance of the issue of the permit review and therefore a condition linking back to an improvement condition have been included in the permit.

Fire Prevention Plan

The site has an FPP in place, however for combustion installations that fall under Section 1.1 A(1) (a): Burning any fuel in an appliance with a rated thermal input of 50 megawatts or more, the FPP is incorporated into the EMS rather than being listed as a standalone condition in the permit. This is because it is acknowledged that the sector specific guidance for fire prevention is more applicable than the generic FPP guidance. The FPP on site however, is incorporated into the operating techniques and EMS on site so is still required to be implemented by the operator.

Ammonia emission limit value

An interim periodic ammonia limit has been introduced into table S3.1 as a result of work on improvement condition IC06. This will be superseded by continuous monitoring following the BREF implementation date.

9 Review and assessment of changes that are not part of the BAT Conclusions derived permit review.

This document should be read in conjunction with the application, supporting information and notice.

Aspect considered	Decision
Receipt of application	
Confidential information	A claim for commercial or industrial confidentiality has not been made.
Identifying confidential information	We have not identified information provided as part of the application that we consider to be confidential.
The site	
Biodiversity, heritage, landscape and nature conservation	<p>The application is within the relevant distance criteria of a site of heritage, landscape or nature conservation, and/or protected species or habitat.</p> <p>A full assessment of the application and its potential to affect the site(s)/species/habitat has not been carried out as part of the permit review process. We consider that the review will not affect the features of the site(s)/species/habitat as the conditions will provide at least the same level of protection as those in the previous permit and in some cases will provide a higher level of protection to those in the previous permit.</p> <p>We have not consulted Natural England on the application. The decision was taken in accordance with our guidance.</p>
Operating techniques	
General operating techniques	<p>We have reviewed the techniques used by the operator where they are relevant to the BAT Conclusions and compared these with the relevant guidance notes.</p> <p>The permit conditions ensure compliance with the relevant BREF, BAT Conclusions. The ELVs deliver compliance with the BAT-AELs.</p>
Permit conditions	
Updating permit conditions during consolidation	We have updated permit conditions to those in the current generic permit template as part of permit consolidation. The conditions will provide at least the same level of protection as those in the previous permit and in some cases will provide a higher level of protection to those in the previous permit.

Aspect considered	Decision
Changes to the permit conditions due to an Environment Agency initiated variation	We have varied the permit as stated in the variation notice.
Improvement programme	<p>Based on the information on the application, we consider that we need to impose an improvement programme.</p> <p>We have imposed an improvement programme to ensure that:</p> <ul style="list-style-type: none"> • the Environment Management System contains all procedures specified under BAT 1 • the Environment Management System contains management procedures during OTNOC as required under BAT 16. • the operator will have a plan in place to ensure that the fuel is characterised in line with BAT 9. • the operator will submit a risk assessment for the potential operation of 'black start' on site.
Emission limits	<p>We have decided that emission limits should be set for the parameters listed in the permit.</p> <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p> <p>It is considered that the ELVs/equivalent parameters or technical measures described above will ensure that significant pollution of the environment is prevented and a high level of protection for the environment is secured.</p>
Monitoring	<p>We have decided that monitoring should be carried out for the parameters listed in the permit, using the methods detailed and to the frequencies specified.</p> <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p> <p>Table S3.3 Process monitoring requirements was amended to include the requirement to monitor energy efficiency after overhauls on site in line with BAT2.</p> <p>Based on the information in the application we are satisfied that the operator's techniques, personnel and equipment have either MCERTS certification or MCERTS accreditation as appropriate.</p>
Reporting	<p>We have specified reporting in the permit for the following parameters:</p> <ul style="list-style-type: none"> • Nitrogen dioxide • Carbon monoxide • Sulphur dioxide • Hydrogen Chloride

Aspect considered	Decision
	<ul style="list-style-type: none"> • Hydrogen Fluoride • Dust • Mercury • Ammonia <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p>
Operator competence	
Management system	There is no known reason to consider that the operator will not have the management system to enable it to comply with the permit conditions.
Growth Duty	
Section 108 Deregulation Act 2015 – Growth duty	<p>We have considered our duty to have regard to the desirability of promoting economic growth set out in section 108(1) of the Deregulation Act 2015 and the guidance issued under section 110 of that Act in deciding whether to grant this permit.</p> <p>Paragraph 1.3 of the guidance says:</p> <p>“The primary role of regulators, in delivering regulation, is to achieve the regulatory outcomes for which they are responsible. For a number of regulators, these regulatory outcomes include an explicit reference to development or growth. The growth duty establishes economic growth as a factor that all specified regulators should have regard to, alongside the delivery of the protections set out in the relevant legislation.”</p> <p>We have addressed the legislative requirements and environmental standards to be set for this operation in the body of the decision document above. The guidance is clear at paragraph 1.5 that the growth duty does not legitimise non-compliance and its purpose is not to achieve or pursue economic growth at the expense of necessary protections.</p> <p>We consider the requirements and standards we have set in this permit are reasonable and necessary to avoid a risk of an unacceptable level of pollution. This also promotes growth amongst legitimate operators because the standards applied to the operator are consistent across businesses in this sector and have been set to achieve the required legislative standards.</p>