

## **Review of an Environmental Permit for an Installation subject to Chapter II of the Industrial Emissions Directive under the Environmental Permitting (England & Wales) Regulations 2016**

### **Decision document recording our decision-making process following review of a permit**

The Permit number is: EPR/BL6217IM  
The Operator is: Marchwood Power Limited  
The Installation is: Marchwood Power Station  
This Variation Notice number is: EPR/BL6217IM/V010

### **What this document is about**

Article 21(3) of the Industrial Emissions Directive (IED) requires the Environment Agency to review conditions in permits that it has issued and to ensure that the permit delivers compliance with relevant standards, within four years of the publication of updated decisions on best available techniques (BAT) conclusions.

We have reviewed the permit for this installation against the revised BAT Conclusions for large combustion plant published on 17<sup>th</sup> August 2017. This is our decision document, which explains the reasoning for the consolidated variation notice that we are issuing.

It explains how we have reviewed and considered the techniques used by the Operator in the operation and control of the plant and activities of the installation. This review has been undertaken with reference to the decision made by the European Commission establishing best available techniques (BAT) conclusions ('BAT Conclusions') for large combustion plant as detailed in document reference IEDC-7-1. It is our record of our decision-making process and shows how we have taken into account all relevant factors in reaching our position. It also provides a justification for the inclusion of any specific conditions in the permit that are in addition to those included in our generic permit template.

As well as considering the review of the operating techniques used by the Operator for the operation of the plant and activities of the installation, the consolidated variation notice takes into account and brings together in a single document all previous variations that relate to the original permit

issued. It also modernises the entire permit to reflect the conditions contained in our current generic permit template.

The introduction of new template conditions makes the Permit consistent with our current general approach and philosophy and with other permits issued to installations in this sector. Although the wording of some conditions has changed, while others have been removed because of the new regulatory approach, it does not reduce the level of environmental protection achieved by the Permit in any way. In this document we therefore address only our determination of substantive issues relating to the new BAT Conclusions.

Throughout this document we will use a number of expressions. These are as referred to in the glossary and have the same meaning as described in “Schedule 6 Interpretation” of the Permit.

We try to explain our decision as accurately, comprehensively and plainly as possible. We would welcome any feedback as to how we might improve our decision documents in future. A lot of technical terms and acronyms are inevitable in a document of this nature: we provide a glossary of acronyms near the front of the document, for ease of reference.

## How this document is structured

### Glossary of terms

- 1 Our decision
- 2 How we reached our decision
- 2.1 Requesting information to demonstrate compliance with BAT  
Conclusions for Large Combustion Plant
- 2.2 Review of our own information in respect to the capability of the  
installation to meet revised standards included in the BAT Conclusions  
document
- 3 The legal framework
- 4 Key Issues
- 5 Decision checklist regarding relevant BAT Conclusions
- 6 Emissions to Water
- 7 Additional IED Chapter II requirements and other requirements
- 9 Review and assessment of changes that are not part of the BAT  
Conclusions derived permit review.

## Glossary of acronyms used in this document

(Please note that this glossary is standard for our decision documents and therefore not all these acronyms are necessarily used in this document.)

APC	Air Pollution Control
BAT	Best Available Technique(s)
BAT-AEEL	BAT Associated Energy Efficiency Level
BAT-AEL	BAT Associated Emission Level
BATc	BAT conclusion
BREF	Best available techniques reference document
CCGT	Combined Cycle Gas Turbine
CEM	Continuous emissions monitor
CHP	Combined heat and power
CV	Calorific value
DAA	Directly associated activity – Additional activities necessary to be carried out to allow the principal activity to be carried out
DLN	Dry Low NOx burners
DLN-E	Dry Low NOx effective
EIONET	European environment information and observation network is a partnership network of the European Environment Agency
ELV	Emission limit value derived under BAT or an emission limit value set out in IED
EMS	Environmental Management System
EPR	Environmental Permitting (England and Wales) Regulations 2016 (SI 2016 No. 1154)
EWG	European waste catalogue
FSA	Food Standards Agency
IC	Improvement Condition
IED	Industrial Emissions Directive (2010/75/EU)
IPPCD	Integrated Pollution Prevention and Control Directive (2008/1/EC) – now superseded by IED
LCP	Large Combustion Plant subject to Chapter III of IED
MSUL/MSDL	Minimum start up load/minimum shut-down load
NOx	Oxides of nitrogen (NO plus NO <sub>2</sub> expressed as NO <sub>2</sub> )
NPV	Net Present Value
OCGT	Open Cycle Gas Turbine
PHE	Public Health England
SAC	Special Area of Conservation
SGN	Sector guidance note
TGN	Technical guidance note
TNP	Transitional National Plan
TOC	Total Organic Carbon
WFD	Water Framework Directive (2000/60/EC)

## 1 Our decision

We have decided to issue the consolidated variation notice to the Operator. This will allow it to continue to operate the Installation, subject to the conditions in the consolidated variation notice.

We consider that, in reaching that decision, we have taken into account all relevant considerations and legal requirements and that the varied permit will ensure that a high level of protection is provided for the environment and human health.

The consolidated variation notice contains many conditions taken from our standard Environmental Permit template including the relevant Annexes. We developed these conditions in consultation with industry, having regard to the legal requirements of the Environmental Permitting Regulations and other relevant legislation. This document does not therefore include an explanation for these standard conditions. Where they are included in the Notice, we have considered the techniques identified by the operator for the operation of their installation, and have accepted that the details are sufficient and satisfactory to make those standard conditions appropriate. This document does, however, provide an explanation of our use of “tailor-made” or installation-specific conditions, or where our Permit template provides two or more options.

## 2 How we reached our decision

### 2.1 Requesting information to demonstrate compliance with BAT Conclusions for Large Combustion Plant

We issued a Notice under Regulation 61(1) of the Environmental Permitting (England and Wales) Regulations 2016 (a Regulation 61 Notice) on 1<sup>st</sup> May 2018 requiring the Operator to provide information to demonstrate how the operation of their installation currently meets, or will subsequently meet, the revised standards described in the large combustion plant BAT Conclusions document. The Notice also required that where the revised standards are not currently met, the operator should provide information that:

- Describes the techniques that will be implemented before 17<sup>th</sup> August 2021, which will then ensure that operations meet the revised standard, or
- Justifies why standards will not be met by 17<sup>th</sup> August 2021, and confirmation of the date when the operation of those processes will cease within the installation or an explanation of why the revised BAT standard is not applicable to those processes, or
- Justifies why an alternative technique will achieve the same level of environmental protection equivalent to the revised standard described in the BAT Conclusions.

Where the Operator proposed that they were not intending to meet a BAT standard that also included a BAT Associated Emission Level (BAT AEL) described in the BAT Conclusions Document, the Regulation 61 Notice requested that the Operator make a formal request for derogation from compliance with that AEL (as provisioned by Article 15(4) of IED). In this circumstance, the Notice identified that any such request for derogation must be supported and justified by sufficient technical and commercial information that would enable us to determine acceptability of the derogation request.

The Regulation 61 Notice response from the Operator was received on 22/10/2018.

We considered that the response did not contain sufficient information for us to commence the permit review. We therefore issued a further information request to the Operator on 20/04/2020. Suitable further information was provided by the Operator on 05/05/2020 and 21/05/2020.

We considered it was in the correct form and contained sufficient information for us to begin our determination of the permit review but not that it necessarily contained all the information we would need to complete that review: see below.

The Operator claimed that certain information was commercially confidential and should be withheld from the public register. We considered this request and determined that the following documents received by us on 05/05/2020

- Document titled 'Post-Performance Test Report for Marchwood CCPP following outage in 2019';
- Document titled 'Marchwood CCGT Power Station: Pre and post outage performance tests 2019'

should be withheld from the public register as this information meets the criteria in Regulation 51(c) (i), (ii) and (iii)

- (i) The information is commercial
- (ii) Its confidentiality is provided by law to protect a legitimate economic interest, and
- (iii) In all the circumstances, the public interest in maintaining the confidentiality of the information outweighs the public interest in including it on the register.

Apart from the issues and information just described, we have not received any information in relation to the Regulation 61 Notice response that appears to be confidential in relation to any party.

## **2.2 Review of our own information in respect to the capability of the installation to meet revised standards included in the BAT Conclusions document**

Based on our records and previous regulatory activities with the facility we have no reason to consider that the operator will not be able to comply with the conditions that we include in the permit.

## **3 The legal framework**

The consolidated variation notice will be issued under Regulation 20 of the EPR. The Environmental Permitting regime is a legal vehicle which delivers most of the relevant legal requirements for activities falling within its scope. In particular, the regulated facility is:

- an *installation* as described by the IED;
- subject to aspects of other relevant legislation which also have to be addressed.

We consider that the consolidated variation notice will ensure that the operation of the Installation complies with all relevant legal requirements and that a high level of protection will be delivered for the environment and human health.

We explain how we have addressed specific statutory requirements more fully in the rest of this document.

## 4 The key issues

The key issues arising during this permit review are:

- Emissions to air and the emission limits applied to the plant.
- The energy efficiency levels associated with the Best Available Techniques (BAT-AEELs)

We therefore describe how we determined these issues in most detail in the relevant sections of this document.

### 4.1 Emissions to air and the emission limits applied to the plant

A number of general principles were applied during the permit review. These included:

- The upper value of the BAT AELs ranges specified were used unless use of the tighter limit was justified.
- The principle of no backsliding where if existing limits in the permit were already tighter than those specified in the BREF, the existing permit limits were retained.
- Where a limit was specified in both IED Annex V and the BAT Conclusions for a particular reference period, the tighter limit was applied and in the majority of cases this was from the BAT Conclusions.
- Where AELs are indicative in the BAT Conclusions, these were applied unless adequate justification was provided by the operator to demonstrate that an alternative limit was more appropriate.
- For gas turbines where the IED specified that limits applied over 70% load and the BAT Conclusions specified that AELs applied when dry low NO<sub>x</sub> is effective (DLN-E), we have used DLN-E as a default across all monitoring requirements for NO<sub>x</sub> and CO.

The installation consists of two LCPs:

LCP 216 and LCP 217: CCGT power station comprising two main combustion turbines each with a thermal input of 742 MW<sub>th</sub>, two waste heat recovery boilers, a steam turbine, and ancillary equipment.

The plant was put into operation before IED came into force and therefore the existing limits in the permit are from Part 1 of IED Annex V applicable to existing plant.

The ELVs and AELs are based on the following operating regime:

- Unlimited hours operation

The following tables outline the limits that have been incorporated into the permit for LCP 216 and LCP 217, where these were derived from and the reference periods at which they apply. The emission limits refer to



concentrations, expressed as mass of emitted substance per volume of flue-gas under the following standard conditions: dry gas at a temperature of 273,15 K, pressure of 101,3 kPa and 15% volume reference oxygen concentration if flue gases. The emission limits and monitoring requirements have been incorporated into Schedule 3 of the permit.

<b>Type</b>	Combined Cycle Gas Turbine
<b>Age</b>	Permitted <b>before</b> publication of the LCP BREF
<b>Operating Hours</b>	Unlimited
<b>Fuel</b>	Natural gas
<b>Net electrical efficiency (EE)</b>	58.4%
<b>Net total fuel utilisation (<math>\eta</math>)</b>	<75%
<b>Thermal rating</b>	742 MWth (LCP 215) 742 MWth (LCP 216)

NOx limits (mg/Nm <sup>3</sup> )							
Averaging	IED (Annex V Part 1) - Existing	LCP BREF	Current permit	Revised permit limit	Basis	Limits apply	Monitoring
Annual	None	40 ( $\geq 600 \text{ MW}_{\text{th}}$ , $\eta < 75\%$ ) <sup>1,2</sup>	-	42.4 <sup>1</sup>	BREF	E-DLN	Continuous
Monthly	50 (75 if EE>55% or $\eta > 75\%$ )	None	60	53.1 <sup>1</sup>	BREF <sup>3</sup>	E-DLN	
Daily	55 (82.5 if EE>55% or $\eta > 75\%$ )	50 ( $\geq 600 \text{ MW}_{\text{th}}$ , $\eta < 75\%$ ) <sup>1,2</sup>	60	53.1	BREF	E-DLN	
95 <sup>th</sup> %ile of hr means	100 (150 if EE>55% or $\eta > 75\%$ )	None	120	120	Permit – no backsliding	E-DLN	

Notes:

1 - If electrical generating efficiency (EE) > 55% then limit is [limit] x EE/55. Since the CCGT of LCP 216 and LCP 217 have EE > 55%, the Operator requested that the revised permit limits take into account this energy efficiency uplift. We have therefore set the revised permit limits based on the EE = 58.4% figure declared by the Operator.

2 - Overall plant efficiency,  $\eta$ , based on 'net total fuel utilisation'.

3 - We have set the monthly average limit for NOx lower than the limit of 60 mg/m<sup>3</sup> specified in the current permit, even if there is no monthly BAT AEL specified in the LCP BAT Conclusions. The reason for setting this lower limit is that the monthly average emission limit cannot be higher than the daily average emission limit. Since the daily average BAT AEL of 53.1 mg/m<sup>3</sup> specified according to the LCP BAT Conclusions is lower than the monthly emission limit of 60 mg/m<sup>3</sup> specified by the current permit, we have set the monthly emission limit in the permit at 53.1 mg/m<sup>3</sup> to match the daily emission limit from the BAT Conclusions

CO limits (mg/Nm <sup>3</sup> ) – indicative in <i>italics</i>							
Averaging	IED (Annex V Part 1) - Existing	LCP BREF	Current permit	Revised permit limit	Basis	Limits apply	Monitoring
Annual	None	<i>30</i> <i>(50 for plant operating at low load)</i>	-	30	BREF	E-DLN	Continuous
Monthly	100	None	50	50	Permit – no backsliding	E-DLN	
Daily	110	None	50	50	Permit – no backsliding	E-DLN	
95 <sup>th</sup> %ile of hr means	200	None	50	50	Permit – no backsliding	E-DLN	

The Operator confirmed that the DLN effective point (E-DLN) for the gas turbines of LCP 216 and 217 is considered to be equal to the minimum start-up point (MSUL). We have therefore set daily MSUL/MSDL to base load emission limits that match the limits applicable from E-DLN point.

## 4.2 The energy efficiency levels associated with the Best Available Techniques Conclusions

An energy efficiency level associated with the best available techniques (BAT-AEEL) refers to the ratio between the combustion unit's net energy output(s) and the combustion unit's fuel/feedstock energy input at actual unit design. The net energy output(s) is determined at the combustion unit boundaries, including auxiliary systems (e.g. flue-gas treatment systems), and for the unit operated at full load.

The table below sets out the BAT-AEELs specified in the LCP BAT Conclusions for the large combustion plant on the site and the energy efficiency levels confirmed through the Regulation 61 notice response. The evidence provided to demonstrate that the AEELs are met was in the form of the performance test reports carried out by Siemens (the GTs OEM) in 2019 after the most recent outages of the GTs and a calculation applying the correction factors to standard conditions for the net electrical efficiency.

Due to the process configuration of the plant, with a common steam turbine operating, fed by steam generated in the waste heat boilers of LCP 216 and LCP 217, the Operator provided information on the overall energy efficiency of the installation, as opposed to specific information for each LCP. We agree with this approach.

We consider this plant is BAT in relation to the AEELs.

BAT AEELs (%)			Plant efficiency (%)		
Net electrical efficiency	Net total fuel utilisation	Net mechanical efficiency	Net electrical efficiency	Net total fuel utilisation	Net mechanical efficiency
LCP 216 and LCP 217: Existing CCGT $\geq$ 600 MWth					
50 - 60	None	None	58.4%	NA	NA

## 5 Decision checklist regarding relevant BAT Conclusions

BAT Conclusions for large combustion plant, were published by the European Commission on 17<sup>th</sup> August 2017. There are 75 BAT Conclusions. Only the BAT Conclusions relevant to the particular fuel type used on site have been replicated below.

This annex provides a record of decisions made in relation to each relevant BAT Conclusion applicable to the installation. This annex should be read in conjunction with the Consolidated Variation Notice.

The conditions in the permit through which the relevant BAT Conclusions are implemented include but are not limited to the following:

BAT Conclusion requirement topic	Permit condition(s)	Permit table(s)
Environmental Management System	1.1.1	S1.2
BAT AELs	3.1.1 and 3.5.1	S3.1a
Monitoring	2.3, 3.5 and 3.6	S1.5, S1.6, S1.2, S3.1a
Energy efficiency	1.2 and 2.3	S3.4
Noise	3.4 and 2.3	S1.2
Other operating techniques	2.3	S1.2

The overall status of compliance with the BAT conclusion is indicated in the table as:

- NA Not Applicable
- CC Currently Compliant
- FC Compliant in the future (within 4 years of publication of BAT conclusions)
- NC Not Compliant
- PC Partially Compliant

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
<b>General</b>			
1	<p><b>In order to improve the overall environmental performance, BAT is to implement and adhere to an environmental management system (EMS) that incorporates all of the following features:</b></p> <ul style="list-style-type: none"> <li>i. commitment of the management, including senior management;</li> <li>ii. definition of an environmental policy that includes the continuous improvement of the installation by the management;</li> <li>iii. planning and establishing the necessary procedures, objectives and targets, in conjunction with financial planning and investment;</li> <li>iv. implementation of procedures <ul style="list-style-type: none"> <li>(a) Structure and responsibility</li> <li>(b) Training</li> <li>(c) Communication</li> <li>(d) Employee involvement</li> <li>(e) Documentation</li> <li>(f) Efficient process control</li> <li>(g) Maintenance programmes</li> <li>(h) Emergency preparedness and response</li> <li>(i) Safeguarding compliance with environmental legislation</li> </ul> </li> <li>v. checking performance and taking corrective action, paying particular attention to: <ul style="list-style-type: none"> <li>(a) monitoring and measurement (see also the Reference Document on the General Principles of Monitoring)</li> <li>(b) corrective and preventive action</li> <li>(c) maintenance of records</li> <li>(d) independent (where practicable) internal and external auditing in order to determine whether or not the EMS conforms to planned arrangements and has been properly implemented and maintained;</li> </ul> </li> <li>vi. review of the EMS and its continuing suitability, adequacy and effectiveness by senior management;</li> <li>vii. following the development of cleaner technologies;</li> <li>viii. consideration for the environmental impacts from the eventual decommissioning of the installation at the stage of designing a new plant, and throughout its operating life;</li> <li>viii. consideration for the environmental impacts from the eventual decommissioning of the installation at the stage of designing a new plant, and throughout its operating life;</li> <li>ix. application of sectoral benchmarking on a regular basis.</li> </ul> <p>Etc - see BAT Conclusions</p>	CC	<p>The Operator stated that they consider their operations currently compliant with this BAT conclusion and provided the following description of their relevant operating techniques:</p> <p>Their site operates under an EMS certified to ISO 14001:2015 independently certified by DNV GL.</p> <p>The site EMS incorporates all of the features listed in BAT 1 with the exception of the following:</p> <p><i>(viii) consideration for the environmental impacts from the eventual decommissioning [...]</i></p> <p>The operator provided a justification for the non-applicability of this element, since the Marchwood Power Station was constructed and commissioned prior to the end of 2009 and as such was designed and built using best available techniques at the time. However, the Operator confirmed that underground structures only occur where absolutely necessary, (cooling water culverts and site drainage) and that the</p>

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	<p><b>Applicability.</b> The scope (e.g. level of detail) and nature of the EMS (e.g. standardised or non-standardised) will generally be related to the nature, scale and complexity of the installation, and the range of environmental impacts it may have.</p>		<p>majority of the station is constructed of steel and as such is readily recyclable and lends itself to being easily decontaminated and dismantled.</p> <p><i>(xiv) a dust management plan [...]</i></p> <p>The Operator confirmed that they have evaluated all the stations' environmental aspects and impacts and dust is not considered to be an issue either from stack emissions due to the fuel type or from other activities on site and therefore a dust management plan is not applicable.</p> <p><i>(xvi) for the combustion , gasification or co-incineration of malodourous substances, an odour management plan including...</i></p> <p>This feature is not applicable to Marchwood Power Station.</p> <p>We agree with the compliance status stated by the Operator.</p>
2	<p>BAT is to determine the net electrical efficiency and/or the net total fuel utilisation and/or the net mechanical energy efficiency of the gasification, IGCC and/or combustion units by carrying out a performance test at full load (1), according to EN standards, after the commissioning of the unit and after each modification that could significantly affect the net electrical efficiency and/or the net total fuel utilisation and/or the net mechanical energy efficiency of the unit. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.</p>	CC	<p>The Operator confirmed the following: Post outage performance test are carried out against the following international standards : Combined Cycle ASME PTC 46</p>

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement												
			<p>(1996), Gas analysis ISO 6976, ISO 6974-3 and ISO 12213-2, Water / Steam Flow ISO 5167 Part 1 to 4:2003, Fuel Gas Flow Turbine Flow Meters ISO 9951, November 1994. This is part of the contractual obligation to prove the performance characteristics of the machines prior to commercial handover.</p> <p>We agree that the installation is compliant with this BAT conclusion.</p>												
3	<p><b>BAT is to monitor key process parameters relevant for emissions to air and water including those given below.</b></p> <table><tr><th>Stream</th><th>Parameter(s)</th><th>Monitoring</th></tr><tr><td rowspan="3">Flue-gas</td><td>Flow</td><td>Periodic or continuous determination</td></tr><tr><td>Oxygen content, temperature, and pressure</td><td rowspan="2">Periodic or continuous measurement</td></tr><tr><td>Water vapour content <sup>(3)</sup></td></tr><tr><td>Waste water from flue-gas treatment</td><td>Flow, pH, and temperature</td><td>Continuous measurement</td></tr></table>	Stream	Parameter(s)	Monitoring	Flue-gas	Flow	Periodic or continuous determination	Oxygen content, temperature, and pressure	Periodic or continuous measurement	Water vapour content <sup>(3)</sup>	Waste water from flue-gas treatment	Flow, pH, and temperature	Continuous measurement	CC	<p>The Operator confirmed the following:</p> <ul style="list-style-type: none"><li>- Flue Gas treatment waste water does not apply.</li><li>- Water vapour not recorded in Flue Gas as the sample is dried prior to measurement.</li><li>- Oxygen Content and temperature are continuously measured.</li><li>- Flue gas flow rate figure is accurately calculated from the fuel consumption and the dry oxygen value. Volumetric flow is also measured during the annual</li></ul>
Stream	Parameter(s)	Monitoring													
Flue-gas	Flow	Periodic or continuous determination													
	Oxygen content, temperature, and pressure	Periodic or continuous measurement													
	Water vapour content <sup>(3)</sup>														
Waste water from flue-gas treatment	Flow, pH, and temperature	Continuous measurement													



BAT Concn. Number	Summary of BAT Conclusion requirement					Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
							surveillance tests and QUAL2 validation. We agree that the installation is compliant with this BAT conclusion.
4	BAT is to monitor emissions to air with at least the frequency given below and in accordance with EN standards. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.					CC	The Operator confirmed the following emissions are measured:  NOx - Continuous Siemens Ultramat 23 analysers utilised with Envirosoft data acquisition package. Sample lines are heated to keep the sample in a gaseous state, then chilled prior to analysis hence supplying analyser with a 'dry' sample (water vapour measurement not required). MCERT cert No. Sira MC 040033/01  CO – Continuous Siemens Ultramat 23 analysers utilised with Envirosoft data acquisition package. Sample lines are heated to keep the sample in a gaseous state, then chilled prior to analysis hence supplying analyser with a 'dry' sample (water vapour measurement not required). MCERT cert No. Sira MC 040033/01.  SO2 – Continuous
		Substance/Parameter	Fuel/Process/Type of combustion plant	Combustion plant total rated thermal input	Standard(s) <sup>(4)</sup>	Minimum monitoring frequency <sup>(5)</sup>	Monitoring associated with
		NH <sub>3</sub>	— When SCR and/or SNCR is used	All sizes	Generic EN standards	Continuous <sup>(6)</sup> <sup>(7)</sup>	BAT 7
		NO <sub>x</sub>	— Coal and/or lignite including waste co-incineration — Solid biomass and/or peat including waste co-incineration — HFO- and/or gas-oil-fired boilers and engines — Gas-oil-fired gas turbines — Natural-gas-fired boilers, engines, and turbines — Iron and steel process gases — Process fuels from the chemical industry — IGCC plants	All sizes	Generic EN standards	Continuous <sup>(6)</sup> <sup>(8)</sup>	BAT 20 BAT 24 BAT 28 BAT 32 BAT 37 BAT 41 BAT 42 BAT 43 BAT 47 BAT 48 BAT 56 BAT 64 BAT 65 BAT 73
			— Combustion plants on offshore platforms	All sizes	EN 14792	Once every year <sup>(9)</sup>	BAT 53

BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	N <sub>2</sub> O	<ul style="list-style-type: none"> <li>Coal and/or lignite in circulating fluidised bed boilers</li> <li>Solid biomass and/or peat in circulating fluidised bed boilers</li> </ul>	All sizes	EN 21258	Once every year <sup>(10)</sup>	BAT 20 BAT 24		<p>Siemens Ultramat 23 analysers utilised with Envirosoft data acquisition package. Sample lines are heated to keep the sample in a gaseous state, then chilled prior to analysis hence supplying analyser with a 'dry' sample (water vapour measurement not required). MCERT cert No. Sira MC 040033/01.</p> <p>We agree that the installation is compliant with this BAT conclusion.</p> <p>Although SO<sub>2</sub> is continuously measured on a discretionary basis by the Operator, we have not specified continuous monitoring of this pollutant in the revised permit, because the LCPs at the installation are fired on natural gas and there is no requirement for continuous monitoring of SO<sub>2</sub> for LCPs fired on this type of fuel. We have retained the requirement to report emissions of SO<sub>2</sub> by calculation, based on the sulphur content of the natural gas supplied to the installation from the National Grid.</p>
	CO	<ul style="list-style-type: none"> <li>Coal and/or lignite including waste co-incineration</li> <li>Solid biomass and/or peat including waste co-incineration</li> <li>HFO- and/or gas-oil-fired boilers and engines</li> <li>Gas-oil-fired gas turbines</li> <li>Natural-gas-fired boilers, engines, and turbines</li> <li>Iron and steel process gases</li> <li>Process fuels from the chemical industry</li> <li>IGCC plants</li> </ul>	All sizes	Generic EN standards	Continuous <sup>(6)</sup> <sup>(8)</sup>	BAT 20 BAT 24 BAT 28 BAT 33 BAT 38 BAT 44 BAT 49 BAT 56 BAT 64 BAT 65 BAT 73		
		<ul style="list-style-type: none"> <li>Combustion plants on offshore platforms</li> </ul>	All sizes	EN 15058	Once every year <sup>(9)</sup>	BAT 54		
	SO <sub>2</sub>	<ul style="list-style-type: none"> <li>Coal and/or lignite incl waste co-incineration</li> <li>Solid biomass and/or peat incl waste co-incineration</li> <li>HFO- and/or gas-oil-fired boilers</li> <li>HFO- and/or gas-oil-fired engines</li> <li>Gas-oil-fired gas turbines</li> <li>Iron and steel process gases</li> </ul>	All sizes	Generic EN standards and EN 14791	Continuous <sup>(6)</sup> <sup>(11)</sup> <sup>(12)</sup>	BAT 21 BAT 25 BAT 29 BAT 34 BAT 39 BAT 50 BAT 57 BAT 66 BAT 67 BAT 74		

BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
		— Process fuels from the chemical industry in boilers — IGCC plants						
	SO <sub>3</sub>	— When SCR is used	All sizes	No EN standard available	Once every year	—		
	Gaseous chlorides, expressed as HCl	— Coal and/or lignite — Process fuels from the chemical industry in boilers	All sizes	EN 1911	Once every three months <sup>(6)</sup> <sup>(13)</sup> <sup>(14)</sup>	BAT 21 BAT 57		
		— Solid biomass and/or peat	All sizes	Generic EN standards	Continuous <sup>(15)</sup> <sup>(16)</sup>	BAT 25		
		— Waste co-incineration	All sizes	Generic EN standards	Continuous <sup>(6)</sup> <sup>(16)</sup>	BAT 66 BAT 67		
	HF	— Coal and/or lignite — Process fuels from the chemical industry in boilers	All sizes	No EN standard available	Once every three months <sup>(6)</sup> <sup>(13)</sup> <sup>(14)</sup>	BAT 21 BAT 57		
		— Solid biomass and/or peat	All sizes	No EN standard available	Once every year	BAT 25		
		— Waste co-incineration	All sizes	Generic EN standards	Continuous <sup>(6)</sup> <sup>(16)</sup>	BAT 66 BAT 67		
	Dust	— Coal and/or lignite — Solid biomass and/or peat — HFO- and/or gas-oil-fired boilers — Iron and steel process gases — Process fuels from the chemical industry in boilers — IGCC plants — HFO- and/or gas-oil-fired engines	All sizes	Generic EN standards and EN 13284-1 and EN 13284-2	Continuous <sup>(6)</sup> <sup>(17)</sup>	BAT 22 BAT 26 BAT 30 BAT 35 BAT 39 BAT 51 BAT 58 BAT 75		

BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
		— Gas-oil-fired gas turbines						
		— Waste co-incineration	All sizes	Generic EN standards and EN 13284-2	Continuous	BAT 68 BAT 69		
	Metals and metalloids except mercury (As, Cd, Co, Cr, Cu, Mn, Ni, Pb, Sb, Se, Ti, V, Zn)	— Coal and/or lignite	All sizes	EN 14385	Once every year <sup>(18)</sup>	BAT 22 BAT 26 BAT 30		
		— Solid biomass and/or peat						
		— HFO- and/or gas-oil-fired boilers and engines						
		— Waste co-incineration	< 300 MW <sub>th</sub>	EN 14385	Once every six months <sup>(13)</sup>	BAT 68 BAT 69		
			≥ 300 MW <sub>th</sub>	EN 14385	Once every three months <sup>(19)</sup> <sup>(13)</sup>			
	— IGCC plants	≥ 100 MW <sub>th</sub>	EN 14385	Once every year <sup>(18)</sup>	BAT 75			
	Hg	— Coal and/or lignite including waste co-incineration	< 300 MW <sub>th</sub>	EN 13211	Once every three months <sup>(13)</sup> <sup>(20)</sup>	BAT 23		
			≥ 300 MW <sub>th</sub>	Generic EN standards and EN 14884	Continuous <sup>(16)</sup> <sup>(21)</sup>			
		— Solid biomass and/or peat	All sizes	EN 13211	Once every year <sup>(22)</sup>	BAT 27		
		— Waste co-incineration with solid biomass and/or peat	All sizes	EN 13211	Once every three months <sup>(13)</sup>	BAT 70		
		— IGCC plants	≥ 100 MW <sub>th</sub>	EN 13211	Once every year <sup>(23)</sup>	BAT 75		
	TVOC	— HFO- and/or gas-oil-fired engines	All sizes	EN 12619	Once every six months <sup>(13)</sup>	BAT 33 BAT 59		
		— Process fuels from chemical industry in boilers						
		— Waste co-incineration with coal, lignite, solid biomass and/or peat	All sizes	Generic EN standards	Continuous	BAT 71		
	Formaldehyde	— Natural-gas in spark-ignited lean-burn gas and dual fuel engines	All sizes	No EN standard available	Once every year	BAT 45		

BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																																								
	CH <sub>4</sub>	— Natural-gas-fired engines	All sizes	EN ISO 25139	Once every year <sup>(24)</sup>	BAT 45																																										
	PCDD/F	— Process fuels from chemical industry in boilers — Waste co-incineration	All sizes	EN 1948-1, EN 1948-2, EN 1948-3	Once every six months <sup>(13)</sup> <sup>(25)</sup>	BAT 59 BAT 71																																										
5	BAT is to monitor emissions to water from flue-gas treatment with at least the frequency given below and in accordance with EN standards. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality. <table><tr><th colspan="2">Substance/Parameter</th><th>Standard(s)</th><th>Minimum monitoring frequency</th><th>Monitoring associated with</th></tr><tr><td colspan="2">Total organic carbon (TOC) <sup>(26)</sup></td><td>EN 1484</td><td rowspan="15">Once every month</td><td rowspan="15">BAT 15</td></tr><tr><td colspan="2">Chemical oxygen demand (COD) <sup>(26)</sup></td><td>No EN standard available</td></tr><tr><td colspan="2">Total suspended solids (TSS)</td><td>EN 872</td></tr><tr><td colspan="2">Fluoride (F<sup>-</sup>)</td><td>EN ISO 10304-1</td></tr><tr><td colspan="2">Sulphate (SO<sub>4</sub><sup>2-</sup>)</td><td>EN ISO 10304-1</td></tr><tr><td colspan="2">Sulphide, easily released (S<sup>2-</sup>)</td><td>No EN standard available</td></tr><tr><td colspan="2">Sulphite (SO<sub>3</sub><sup>2-</sup>)</td><td>EN ISO 10304-3</td></tr><tr><td rowspan="7">Metals and metalloids</td><td>As</td><td rowspan="6">Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)</td></tr><tr><td>Cd</td></tr><tr><td>Cr</td></tr><tr><td>Cu</td></tr><tr><td>Ni</td></tr><tr><td>Pb</td></tr><tr><td>Zn</td></tr><tr><td></td><td>Hg</td><td>Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)</td></tr></table>						Substance/Parameter		Standard(s)	Minimum monitoring frequency	Monitoring associated with	Total organic carbon (TOC) <sup>(26)</sup>		EN 1484	Once every month	BAT 15	Chemical oxygen demand (COD) <sup>(26)</sup>		No EN standard available	Total suspended solids (TSS)		EN 872	Fluoride (F <sup>-</sup> )		EN ISO 10304-1	Sulphate (SO <sub>4</sub> <sup>2-</sup> )		EN ISO 10304-1	Sulphide, easily released (S <sup>2-</sup> )		No EN standard available	Sulphite (SO <sub>3</sub> <sup>2-</sup> )		EN ISO 10304-3	Metals and metalloids	As	Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)	Cd	Cr	Cu	Ni	Pb	Zn		Hg	Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)	NA	The installation does not include flue-gas treatment therefore we agree with the Operator that this BAT conclusion is not applicable.
Substance/Parameter		Standard(s)	Minimum monitoring frequency	Monitoring associated with																																												
Total organic carbon (TOC) <sup>(26)</sup>		EN 1484	Once every month	BAT 15																																												
Chemical oxygen demand (COD) <sup>(26)</sup>		No EN standard available																																														
Total suspended solids (TSS)		EN 872																																														
Fluoride (F <sup>-</sup> )		EN ISO 10304-1																																														
Sulphate (SO <sub>4</sub> <sup>2-</sup> )		EN ISO 10304-1																																														
Sulphide, easily released (S <sup>2-</sup> )		No EN standard available																																														
Sulphite (SO <sub>3</sub> <sup>2-</sup> )		EN ISO 10304-3																																														
Metals and metalloids	As	Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)																																														
	Cd																																															
	Cr																																															
	Cu																																															
	Ni																																															
	Pb																																															
	Zn																																															
	Hg	Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)																																														

BAT Concn. Number	Summary of BAT Conclusion requirement				Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																	
	Chloride (Cl <sup>-</sup> )	Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)		—																			
	Total nitrogen	EN 12260		—																			
6	In order to improve the general environmental performance of combustion plants and to reduce emissions to air of CO and unburnt substances, BAT is to ensure optimised combustion and to use an appropriate combination of the techniques given below. <table><tr><th>Technique</th><th>Description</th><th>Applicability</th></tr><tr><td>a. Fuel blending and mixing</td><td>Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type</td><td rowspan="2">Generally applicable</td></tr><tr><td>b. Maintenance of the combustion system</td><td>Regular planned maintenance according to suppliers' recommendations</td></tr><tr><td>c. Advanced control system</td><td>See description in Section 8.1</td><td>The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system</td></tr><tr><td>d. Good design of the combustion equipment</td><td>Good design of furnace, combustion chambers, burners and associated devices</td><td>Generally applicable to new combustion plants</td></tr><tr><td>e. Fuel choice</td><td>Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used</td><td>Applicable within the constraints associated with the availability of suitable types of fuel with a better environmental profile as a whole, which may be impacted by the energy policy of the Member State, or by the integrated site's fuel balance in the case of combustion of industrial process fuels. For existing combustion plants, the type of fuel chosen may be limited by the configuration and the design of the plant</td></tr></table>				Technique	Description	Applicability	a. Fuel blending and mixing	Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type	Generally applicable	b. Maintenance of the combustion system	Regular planned maintenance according to suppliers' recommendations	c. Advanced control system	See description in Section 8.1	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system	d. Good design of the combustion equipment	Good design of furnace, combustion chambers, burners and associated devices	Generally applicable to new combustion plants	e. Fuel choice	Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used	Applicable within the constraints associated with the availability of suitable types of fuel with a better environmental profile as a whole, which may be impacted by the energy policy of the Member State, or by the integrated site's fuel balance in the case of combustion of industrial process fuels. For existing combustion plants, the type of fuel chosen may be limited by the configuration and the design of the plant	CC	<p>The Operator confirmed that techniques b., c., d. and e. are applied, as follows:</p> <p>Marchwood Power Station have a long term maintenance contract with the gas turbine OEM (Siemens). Maintenance periods are dictated by unit running hours and outages planned accordingly.</p> <p>The current control system is the latest OEM version of control system Architecture. The system is continually updated as part of the long term maintenance agreement.</p> <p>The design of the gas turbines was upgraded in 2015.</p> <p>The LCPs at the installation only have one fuel source which is natural gas. It is a standard quality supplied directly from the National Grid network.</p> <p>We agree with the compliance status stated by the Operator.</p>
Technique	Description	Applicability																					
a. Fuel blending and mixing	Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type	Generally applicable																					
b. Maintenance of the combustion system	Regular planned maintenance according to suppliers' recommendations																						
c. Advanced control system	See description in Section 8.1	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system																					
d. Good design of the combustion equipment	Good design of furnace, combustion chambers, burners and associated devices	Generally applicable to new combustion plants																					
e. Fuel choice	Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used	Applicable within the constraints associated with the availability of suitable types of fuel with a better environmental profile as a whole, which may be impacted by the energy policy of the Member State, or by the integrated site's fuel balance in the case of combustion of industrial process fuels. For existing combustion plants, the type of fuel chosen may be limited by the configuration and the design of the plant																					

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
7	<p>In order to reduce emissions of ammonia to air from the use of selective catalytic reduction (SCR) and/or selective non-catalytic reduction (SNCR) for the abatement of NO<sub>x</sub> emissions, BAT is to optimise the design and/or operation of SCR and/or SNCR (e.g. optimised reagent to NO<sub>x</sub> ratio, homogeneous reagent distribution and optimum size of the reagent drops).</p> <p><b>BAT-associated emission levels</b></p> <p>The BAT-associated emission level (BAT-AEL) for emissions of NH<sub>3</sub> to air from the use of SCR and/or SNCR is &lt; 3–10 mg/Nm<sup>3</sup> as a yearly average or average over the sampling period. The lower end of the range can be achieved when using SCR and the upper end of the range can be achieved when using SNCR without wet abatement techniques. In the case of plants combusting biomass and operating at variable loads as well as in the case of engines combusting HFO and/or gas oil, the higher end of the BAT-AEL range is 15 mg/Nm<sup>3</sup>.</p>	NA	The installation does not include SCR/SNCR therefore we agree with the Operator that this BAT conclusion is not applicable.
8	In order to prevent or reduce emissions to air during normal operating conditions, BAT is to ensure, by appropriate design, operation and maintenance, that the emission abatement systems are used at optimal capacity and availability.	NA	<p>The Operator confirmed that the installation does not utilise 'abatement systems' specifically for emissions reduction. The main control system regulates the combustion stability and, by design, the inherent emissions production is low. Combustion tuning is periodically undertaken to ensure the efficiency of the machines is maintained.</p> <p>Since the installation does not include specific abatement systems we consider that this BAT conclusion is not applicable.</p>
9	<p>In order to improve the general environmental performance of combustion and/or gasification plants and to reduce emissions to air, BAT is to include the following elements in the quality assurance/quality control programmes for all the fuels used, as part of the environmental management system (see BAT 1):</p> <p>(i) Initial full characterisation of the fuel used including at least the parameters listed below and in accordance with EN standards. ISO, national or other international standards may be used provided they ensure the provision of data of an equivalent scientific quality;</p>	CC	The LCPs at the installation only have one fuel source which is natural gas. It is a standard quality supplied directly from the National Grid network.

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																					
	<p>(ii) Regular testing of the fuel quality to check that it is consistent with the initial characterisation and according to the plant design specifications. The frequency of testing and the parameters chosen from the table below are based on the variability of the fuel and an assessment of the relevance of pollutant releases (e.g. concentration in fuel, flue-gas treatment employed);</p> <p>(iii) Subsequent adjustment of the plant settings as and when needed and practicable (e.g. integration of the fuel characterisation and control in the advanced control system (see description in Section 8.1)).</p> <p><b>Description</b> Initial characterisation and regular testing of the fuel can be performed by the operator and/or the fuel supplier. If performed by the supplier, the full results are provided to the operator in the form of a product (fuel) supplier specification and/or guarantee.</p> <table><tr><th>Fuel(s)</th><th>Substances/Parameters subject to characterisation</th></tr><tr><td rowspan="4">Biomass/peat</td><td>— LHV</td></tr><tr><td>— moisture</td></tr><tr><td>— Ash</td></tr><tr><td>— C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn)</td></tr><tr><td rowspan="4">Coal/lignite</td><td>— LHV</td></tr><tr><td>— Moisture</td></tr><tr><td>— Volatiles, ash, fixed carbon, C, H, N, O, S</td></tr><tr><td>— Br, Cl, F — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)</td></tr><tr><td rowspan="2">HFO</td><td>— Ash</td></tr><tr><td>— C, S, N, Ni, V</td></tr><tr><td rowspan="2">Gas oil</td><td>— Ash</td></tr><tr><td>— N, C, S</td></tr><tr><td rowspan="2">Natural gas</td><td>— LHV</td></tr><tr><td>— CH<sub>4</sub>, C<sub>2</sub>H<sub>6</sub>, C<sub>3</sub>, C<sub>4</sub>+, CO<sub>2</sub>, N<sub>2</sub>, Wobbe index</td></tr></table>	Fuel(s)	Substances/Parameters subject to characterisation	Biomass/peat	— LHV	— moisture	— Ash	— C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn)	Coal/lignite	— LHV	— Moisture	— Volatiles, ash, fixed carbon, C, H, N, O, S	— Br, Cl, F — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)	HFO	— Ash	— C, S, N, Ni, V	Gas oil	— Ash	— N, C, S	Natural gas	— LHV	— CH <sub>4</sub> , C <sub>2</sub> H <sub>6</sub> , C <sub>3</sub> , C <sub>4</sub> +, CO <sub>2</sub> , N <sub>2</sub> , Wobbe index		<p>We consider that for plants which burn natural gas from the National Grid as a fuel it is not necessary for the operator to replicate the testing carried out by the National Grid.</p> <p>We agree with the compliance status stated by the Operator.</p>
Fuel(s)	Substances/Parameters subject to characterisation																							
Biomass/peat	— LHV																							
	— moisture																							
	— Ash																							
	— C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn)																							
Coal/lignite	— LHV																							
	— Moisture																							
	— Volatiles, ash, fixed carbon, C, H, N, O, S																							
	— Br, Cl, F — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)																							
HFO	— Ash																							
	— C, S, N, Ni, V																							
Gas oil	— Ash																							
	— N, C, S																							
Natural gas	— LHV																							
	— CH <sub>4</sub> , C <sub>2</sub> H <sub>6</sub> , C <sub>3</sub> , C <sub>4</sub> +, CO <sub>2</sub> , N <sub>2</sub> , Wobbe index																							



BAT Concn. Number	Summary of BAT Conclusion requirement		Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	Process fuels from the chemical industry <sup>(27)</sup>	<ul style="list-style-type: none"><li>— Br, C, Cl, F, H, N, O, S</li><li>— Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)</li></ul>		
	Iron and steel process gases	<ul style="list-style-type: none"><li>— LHV, CH<sub>4</sub> (for COG), C<sub>x</sub>H<sub>y</sub> (for COG), CO<sub>2</sub>, H<sub>2</sub>, N<sub>2</sub>, total sulphur, dust, Wobbe index</li></ul>		
	Waste <sup>(28)</sup>	<ul style="list-style-type: none"><li>— LHV</li><li>— Moisture</li><li>— Volatiles, ash, Br, C, Cl, F, H, N, O, S</li><li>— Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)</li></ul>		
10	In order to reduce emissions to air and/or to water during other than normal operating conditions (OTNOC), BAT is to set up and implement a management plan as part of the environmental management system (see BAT 1), commensurate with the relevance of potential pollutant releases, that includes the following elements: <ul style="list-style-type: none"><li>— appropriate design of the systems considered relevant in causing OTNOC that may have an impact on emissions to air, water and/or soil (e.g. low-load design concepts for reducing the minimum start-up and shutdown loads for stable generation in gas turbines),</li><li>— set-up and implementation of a specific preventive maintenance plan for these relevant systems,</li><li>— review and recording of emissions caused by OTNOC and associated circumstances and implementation of corrective actions if necessary,</li><li>— periodic assessment of the overall emissions during OTNOC (e.g. frequency of events, duration, emissions quantification/estimation) and implementation of corrective actions if necessary.</li></ul>		CC	<p>The Operator stated that they consider their operations currently compliant with this BAT conclusion and provided the following description of their relevant operating techniques:</p> <p>The only normal to abnormal plant conditions are the start-up and shutdown periods. The response to permit improvement condition IC12 specifies the conditions when the plant is within these periods and also clarifies when environment reporting should commence and cease.</p> <p>Performance testing extends beyond stable exporting limits to ensure the contractual operational parameters are achieved.</p>

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
			<p>Environmental reporting systems exist to allow the production staff highlights and incidents where OTNOC has caused irregular emissions patterns. A midnight generated report from the data acquisition software package will allow the Shift Engineer to assess the performance throughout the day and raise issue/non-compliance as required. Recording of environmental monitoring occurs through both normal and abnormal plant conditions. Emission data for start-up and shutdown periods is available to trend and analyse at all times.</p> <p>We agree with the compliance status stated by the Operator.</p>
11	<p>BAT is to appropriately monitor emissions to air and/or to water during OTNOC.</p> <p><b>Description</b></p> <p>The monitoring can be carried out by direct measurement of emissions or by monitoring of surrogate parameters if this proves to be of equal or better scientific quality than the direct measurement of emissions. Emissions during start-up and shutdown (SU/SD) may be assessed based on a detailed emission measurement carried out for a typical SU/SD procedure at least once every year, and using the results of this measurement to estimate the emissions for each and every SU/SD throughout the year.</p>	CC	<p>The Operator stated that they consider their operations are currently compliant with this BAT conclusion and provided the following description of their relevant operating techniques:</p> <p>The site has captive drainage and one exit point to the cooling water flow. Whether in OTNOC or not, these will continue to be measured.</p> <p>All air emissions emanate from recognised emissions points</p>

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																													
					<p>stipulated within the Environmental Permit. Also, emission data for start-up and shutdown periods is available to trend and analyse at all times.</p> <p>We agree with the compliance status stated by the Operator.</p>																													
12	<p>In order to increase the energy efficiency of combustion, gasification and/or IGCC units operated <math>\geq 1\,500</math> h/yr, BAT is to use an appropriate combination of the techniques given below.</p> <table><tr><th colspan="2">Technique</th><th>Description</th><th>Applicability</th></tr><tr><td>a.</td><td>Combustion optimisation</td><td>See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues</td><td rowspan="4">Generally applicable</td></tr><tr><td>b.</td><td>Optimisation of the working medium conditions</td><td>Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO<sub>x</sub> emissions or the characteristics of energy demanded</td></tr><tr><td>c.</td><td>Optimisation of the steam cycle</td><td>Operate with lower turbine exhaust pressure by utilisation of the lowest possible temperature of the condenser cooling water, within the design conditions</td></tr><tr><td>d.</td><td>Minimisation of energy consumption</td><td>Minimising the internal energy consumption (e.g. greater efficiency of the feed-water pump)</td></tr><tr><td>e.</td><td>Preheating of combustion air</td><td>Reuse of part of the heat recovered from the combustion flue-gas to preheat the air used in combustion</td><td>Generally applicable within the constraints related to the need to control NO<sub>x</sub> emissions</td></tr><tr><td>f.</td><td>Fuel preheating</td><td>Preheating of fuel using recovered heat</td><td>Generally applicable within the constraints associated with the boiler design and the need to control NO<sub>x</sub>emissions</td></tr><tr><td>g.</td><td>Advanced control system</td><td>See description in Section 8.2.</td><td>Generally applicable to new units. The applicability to old units may be constrained</td></tr></table>			Technique		Description	Applicability	a.	Combustion optimisation	See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues	Generally applicable	b.	Optimisation of the working medium conditions	Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO <sub>x</sub> emissions or the characteristics of energy demanded	c.	Optimisation of the steam cycle	Operate with lower turbine exhaust pressure by utilisation of the lowest possible temperature of the condenser cooling water, within the design conditions	d.	Minimisation of energy consumption	Minimising the internal energy consumption (e.g. greater efficiency of the feed-water pump)	e.	Preheating of combustion air	Reuse of part of the heat recovered from the combustion flue-gas to preheat the air used in combustion	Generally applicable within the constraints related to the need to control NO <sub>x</sub> emissions	f.	Fuel preheating	Preheating of fuel using recovered heat	Generally applicable within the constraints associated with the boiler design and the need to control NO <sub>x</sub> emissions	g.	Advanced control system	See description in Section 8.2.	Generally applicable to new units. The applicability to old units may be constrained	CC	<p>The Operator confirmed that the following appropriate combination of techniques is used at the installation:</p> <p>a. Combustion optimisation. Completed as part of post outage process</p> <p>b. Optimisation of the working medium conditions. By virtue of the combined cycle process and the use of an advanced control system, optimisation occurs. The plant operates to react to energy demands with subsequent emissions reduction occurring with lower operational outputs.</p> <p>c. Optimisation of the steam cycle.</p> <p>d. Minimisation of energy consumption. Energy Saving Group has been established and schemes are</p>
Technique		Description	Applicability																															
a.	Combustion optimisation	See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues	Generally applicable																															
b.	Optimisation of the working medium conditions	Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO <sub>x</sub> emissions or the characteristics of energy demanded																																
c.	Optimisation of the steam cycle	Operate with lower turbine exhaust pressure by utilisation of the lowest possible temperature of the condenser cooling water, within the design conditions																																
d.	Minimisation of energy consumption	Minimising the internal energy consumption (e.g. greater efficiency of the feed-water pump)																																
e.	Preheating of combustion air	Reuse of part of the heat recovered from the combustion flue-gas to preheat the air used in combustion	Generally applicable within the constraints related to the need to control NO <sub>x</sub> emissions																															
f.	Fuel preheating	Preheating of fuel using recovered heat	Generally applicable within the constraints associated with the boiler design and the need to control NO <sub>x</sub> emissions																															
g.	Advanced control system	See description in Section 8.2.	Generally applicable to new units. The applicability to old units may be constrained																															

BAT Concn. Number	Summary of BAT Conclusion requirement				Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
			Computerised control of the main combustion parameters enables the combustion efficiency to be improved	by the need to retrofit the combustion system and/or control command system		<p>devised and actioned. This was aimed at improving the general awareness amongst staff. Project such as variable speed drives have been implemented on the bigger drives (Main Cooling Water pumps). Temporary Operating Instruction (TOI) 16 is in place to ensure cooling water flows are reduced (and hence one of the pumps shutdown) during any two-shift periods.</p> <p>f. Fuel preheating is installed and utilised on site.</p> <p>g. Advanced control system. The main Control System (SPPA-T3000) is advanced.</p> <p>h. Feed-water preheating using recovered heat is installed and utilised on site.</p> <p>q. Advanced materials. As part of the original EPC (Siemens) and the on-going long term maintenance agreement (with Siemens) combustion parts are rated to 500DegC. Improvements are always being researched by the OEM and the Operator have utilised several new types of combustion tile as the materials change and life duration improved.</p>
	h.	Feed-water preheating using recovered heat	Preheat water coming out of the steam condenser with recovered heat, before reusing it in the boiler	Only applicable to steam circuits and not to hot boilers. Applicability to existing units may be limited due to constraints associated with the plant configuration and the amount of recoverable heat		
	i.	Heat recovery by cogeneration (CHP)	Recovery of heat (mainly from the steam system) for producing hot water/steam to be used in industrial processes/activities or in a public network for district heating. Additional heat recovery is possible from: <ul style="list-style-type: none"> <li>— flue-gas</li> <li>— grate cooling</li> <li>— circulating fluidised bed</li> </ul>	Applicable within the constraints associated with the local heat and power demand. The applicability may be limited in the case of gas compressors with an unpredictable operational heat profile		
	j.	CHP readiness	See description in Section 8.2.	Only applicable to new units where there is a realistic potential for the future use of heat in the vicinity of the unit		
	k.	Flue-gas condenser	See description in Section 8.2.	Generally applicable to CHP units provided there is enough demand for low-temperature heat		
	l.	Heat accumulation	Heat accumulation storage in CHP mode	Only applicable to CHP plants. The applicability may be limited in the case of low heat load demand		
	m.	Wet stack	See description in Section 8.2.	Generally applicable to new and existing units fitted with wet FGD		
	n.	Cooling tower discharge	The release of emissions to air through a cooling tower and not via a dedicated stack	Only applicable to units fitted with wet FGD where reheating of the flue-gas is necessary before release, and where the unit cooling system is a cooling tower		
	o.	Fuel pre-drying	The reduction of fuel moisture content before combustion to improve combustion conditions	Applicable to the combustion of biomass and/or peat within the constraints associated with spontaneous combustion		

BAT Concn. Number	Summary of BAT Conclusion requirement				Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
				risks (e.g. the moisture content of peat is kept above 40 % throughout the delivery chain). The retrofit of existing plants may be restricted by the extra calorific value that can be obtained from the drying operation and by the limited retrofit possibilities offered by some boiler designs or plant configurations		Steam turbine upgrades: as part of the on-going term maintenance agreement (with Siemens), Marchwood Power Limited are always made aware of any upgrade schemes associated with the Steam Turbine. One example of this was the upgrade to the L0 blade set in 2015 which provided a more resilient blade type, less likely to generate cracking.  We agree with the compliance status stated by the Operator.
	p.	Minimisation of heat losses	Minimising residual heat losses, e.g. those that occur via the slag or those that can be reduced by insulating radiating sources	Only applicable to solid-fuel-fired combustion units and to gasification/IGCC units		
	q.	Advanced materials	Use of advanced materials proven to be capable of withstanding high operating temperatures and pressures and thus to achieve increased steam/combustion process efficiencies	Only applicable to new plants		
	r.	Steam turbine upgrades	This includes techniques such as increasing the temperature and pressure of medium-pressure steam, addition of a low-pressure turbine, and modifications to the geometry of the turbine rotor blades	The applicability may be restricted by demand, steam conditions and/or limited plant lifetime		
	s.	Supercritical and ultra-supercritical steam conditions	Use of a steam circuit, including steam reheating systems, in which steam can reach pressures above 220,6 bar and temperatures above 374 °C in the case of supercritical conditions, and above 250 – 300 bar and temperatures above 580 – 600 °C in the case of ultra-supercritical conditions	Only applicable to new units of ≥ 600 MW <sub>th</sub> operated > 4 000 h/yr. Not applicable when the purpose of the unit is to produce low steam temperatures and/or pressures in process industries. Not applicable to gas turbines and engines generating steam in CHP mode. For units combusting biomass, the applicability may be constrained by high-temperature corrosion in the case of certain biomasses		
13	In order to reduce water usage and the volume of contaminated waste water discharged, BAT is to use one or both of the techniques given below.				CC	The Operator stated that they consider their operations are currently compliant with this BAT conclusion and provided the
	Technique		Description	Applicability		

BAT Concn. Number	Summary of BAT Conclusion requirement				Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement								
	<table><tr><td>a.</td><td>Water recycling</td><td>Residual aqueous streams, including run-off water, from the plant are reused for other purposes. The degree of recycling is limited by the quality requirements of the recipient water stream and the water balance of the plant</td><td>Not applicable to waste water from cooling systems when water treatment chemicals and/or high concentrations of salts from seawater are present</td></tr><tr><td>b.</td><td>Dry bottom ash handling</td><td>Dry, hot bottom ash falls from the furnace onto a mechanical conveyor system and is cooled down by ambient air. No water is used in the process.</td><td>Only applicable to plants combusting solid fuels. There may be technical restrictions that prevent retrofitting to existing combustion plants</td></tr></table>				a.	Water recycling	Residual aqueous streams, including run-off water, from the plant are reused for other purposes. The degree of recycling is limited by the quality requirements of the recipient water stream and the water balance of the plant	Not applicable to waste water from cooling systems when water treatment chemicals and/or high concentrations of salts from seawater are present	b.	Dry bottom ash handling	Dry, hot bottom ash falls from the furnace onto a mechanical conveyor system and is cooled down by ambient air. No water is used in the process.	Only applicable to plants combusting solid fuels. There may be technical restrictions that prevent retrofitting to existing combustion plants		<p>following description of their relevant operating techniques:</p> <p>Adoption of cetamine dosing as a 'film forming amine' within the boiler steam/water circuit has removed the need for Marchwood Power Limited to utilise draining of boilers as a standard boiler preservation procedure for when the units are due to be off-line for an extended period of time. This saves approximately 300 tonnes of water per boiler. Other boiler preservation techniques also now include 'steam sparging' (to keep the boiler maintained above a certain temperature) and nitrogen capping. Future projects also being considered include:</p> <p>1. Rain Water Harvesting - Steam Turbine Hall</p> <p>2. Clean drains boiler water recovery to the Raw Water Tank</p> <p>Dry bottom ash handling Marchwood Power Limited do not have solid fuels and hence this is not applicable.</p> <p>We agree with the compliance status stated by the Operator.</p>
a.	Water recycling	Residual aqueous streams, including run-off water, from the plant are reused for other purposes. The degree of recycling is limited by the quality requirements of the recipient water stream and the water balance of the plant	Not applicable to waste water from cooling systems when water treatment chemicals and/or high concentrations of salts from seawater are present											
b.	Dry bottom ash handling	Dry, hot bottom ash falls from the furnace onto a mechanical conveyor system and is cooled down by ambient air. No water is used in the process.	Only applicable to plants combusting solid fuels. There may be technical restrictions that prevent retrofitting to existing combustion plants											
14	In order to prevent the contamination of uncontaminated waste water and to reduce emissions to water, BAT is to segregate waste water streams and to treat them separately, depending on the pollutant content. <b>Description</b>				CC	The Operator provided a description of the waste water segregation at the site as follows								

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	<p>Waste water streams that are typically segregated and treated include surface run-off water, cooling water, and waste water from flue-gas treatment.</p> <p><b>Applicability</b> The applicability may be restricted in the case of existing plants due to the configuration of the drainage systems.</p>		<p>and supported the description with a process flow diagram showing the waste water collection systems:</p> <p>The site drainage system captures all surface water and directs to the storm water pit, via oil interceptors.</p> <p>Waste water from the Water Treatment Plant neutralised prior to discharge. The sewage treatment plant is pre-treated and samples are tested on a monthly basis.</p> <p>Cooling Water is pre-treated, as required, prior to discharge. The cooling water pre-treatment includes aeration and when required, dosing of sodium bisulphate.</p> <p>Process water is collected within the 'plant' drainage system and is added to the cooling water flow in the site 'Seal Pit' along with surface water draining flow.</p> <p>The Seal pit mixes used cooling water with other waste water flows and applies aeration. This area is up flow of the site monitoring discharge point WW1. At the final point of discharge the</p>

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																																												
					<p>water under-goes a second stage of aeration over a wear.</p> <p>We consider that the site applies adequate segregation of waste water streams to be considered compliant with this BAT conclusion.</p>																																												
15	<p>In order to reduce emissions to water from flue-gas treatment, BAT is to use an appropriate combination of the techniques given below, and to use secondary techniques as close as possible to the source in order to avoid dilution.</p> <table><tr><th colspan="2">Technique</th><th>Typical pollutants prevented/abated</th><th>Applicability</th></tr><tr><td colspan="4">Primary techniques</td></tr><tr><td>a.</td><td>Optimised combustion (see BAT 6) and flue-gas treatment systems (e.g. SCR/SNCR, see BAT 7)</td><td>Organic compounds, ammonia (NH<sub>3</sub>)</td><td>Generally applicable</td></tr><tr><td colspan="4">Secondary techniques<sup>[29]</sup></td></tr><tr><td>b.</td><td>Adsorption on activated carbon</td><td>Organic compounds, mercury (Hg)</td><td>Generally applicable</td></tr><tr><td>c.</td><td>Aerobic biological treatment</td><td>Biodegradable organic compounds, ammonium (NH<sub>4</sub><sup>+</sup>)</td><td>Generally applicable for the treatment of organic compounds. Aerobic biological treatment of ammonium (NH<sub>4</sub><sup>+</sup>) may not be applicable in the case of high chloride concentrations (i.e. around 10 g/l)</td></tr><tr><td>d.</td><td>Anoxic/anaerobic biological treatment</td><td>Mercury (Hg), nitrate (NO<sub>3</sub><sup>-</sup>), nitrite (NO<sub>2</sub><sup>-</sup>)</td><td>Generally applicable</td></tr><tr><td>e.</td><td>Coagulation and flocculation</td><td>Suspended solids</td><td>Generally applicable</td></tr><tr><td>f.</td><td>Crystallisation</td><td>Metals and metalloids, sulphate (SO<sub>4</sub><sup>2-</sup>), fluoride (F<sup>-</sup>)</td><td>Generally applicable</td></tr><tr><td>g.</td><td>Filtration (e.g. sand filtration, microfiltration, ultrafiltration)</td><td>Suspended solids, metals</td><td>Generally applicable</td></tr><tr><td>h.</td><td>Flotation</td><td>Suspended solids, free oil</td><td>Generally applicable</td></tr></table>			Technique		Typical pollutants prevented/abated	Applicability	Primary techniques				a.	Optimised combustion (see BAT 6) and flue-gas treatment systems (e.g. SCR/SNCR, see BAT 7)	Organic compounds, ammonia (NH <sub>3</sub> )	Generally applicable	Secondary techniques <sup>[29]</sup>				b.	Adsorption on activated carbon	Organic compounds, mercury (Hg)	Generally applicable	c.	Aerobic biological treatment	Biodegradable organic compounds, ammonium (NH <sub>4</sub> <sup>+</sup> )	Generally applicable for the treatment of organic compounds. Aerobic biological treatment of ammonium (NH <sub>4</sub> <sup>+</sup> ) may not be applicable in the case of high chloride concentrations (i.e. around 10 g/l)	d.	Anoxic/anaerobic biological treatment	Mercury (Hg), nitrate (NO <sub>3</sub> <sup>-</sup> ), nitrite (NO <sub>2</sub> <sup>-</sup> )	Generally applicable	e.	Coagulation and flocculation	Suspended solids	Generally applicable	f.	Crystallisation	Metals and metalloids, sulphate (SO <sub>4</sub> <sup>2-</sup> ), fluoride (F <sup>-</sup> )	Generally applicable	g.	Filtration (e.g. sand filtration, microfiltration, ultrafiltration)	Suspended solids, metals	Generally applicable	h.	Flotation	Suspended solids, free oil	Generally applicable	NA	The installation does not include flue-gas treatment therefore we agree with the Operator that this BAT conclusion is not applicable.
Technique		Typical pollutants prevented/abated	Applicability																																														
Primary techniques																																																	
a.	Optimised combustion (see BAT 6) and flue-gas treatment systems (e.g. SCR/SNCR, see BAT 7)	Organic compounds, ammonia (NH <sub>3</sub> )	Generally applicable																																														
Secondary techniques <sup>[29]</sup>																																																	
b.	Adsorption on activated carbon	Organic compounds, mercury (Hg)	Generally applicable																																														
c.	Aerobic biological treatment	Biodegradable organic compounds, ammonium (NH <sub>4</sub> <sup>+</sup> )	Generally applicable for the treatment of organic compounds. Aerobic biological treatment of ammonium (NH <sub>4</sub> <sup>+</sup> ) may not be applicable in the case of high chloride concentrations (i.e. around 10 g/l)																																														
d.	Anoxic/anaerobic biological treatment	Mercury (Hg), nitrate (NO <sub>3</sub> <sup>-</sup> ), nitrite (NO <sub>2</sub> <sup>-</sup> )	Generally applicable																																														
e.	Coagulation and flocculation	Suspended solids	Generally applicable																																														
f.	Crystallisation	Metals and metalloids, sulphate (SO <sub>4</sub> <sup>2-</sup> ), fluoride (F <sup>-</sup> )	Generally applicable																																														
g.	Filtration (e.g. sand filtration, microfiltration, ultrafiltration)	Suspended solids, metals	Generally applicable																																														
h.	Flotation	Suspended solids, free oil	Generally applicable																																														



BAT Concn. Number	Summary of BAT Conclusion requirement				Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	i.	Ion exchange	Metals	Generally applicable		
	j.	Neutralisation	Acids, alkalis	Generally applicable		
	k.	Oxidation	Sulphide (S <sup>2-</sup> ), sulphite (SO <sub>3</sub> <sup>2-</sup> )	Generally applicable		
	l.	Precipitation	Metals and metalloids, sulphate (SO <sub>4</sub> <sup>2-</sup> ), fluoride (F <sup>-</sup> )	Generally applicable		
	m.	Sedimentation	Suspended solids	Generally applicable		
	n.	Stripping	Ammonia (NH <sub>3</sub> )	Generally applicable		
	The BAT-AELs refer to direct discharges to a receiving water body at the point where the emission leaves the installation.					
	BAT-AELs for direct discharges to a receiving water body from flue-gas treatment					
	Substance/Parameter		BAT-AELs			
			Daily average			
	Total organic carbon (TOC)		20–50 mg/l <sup>(30)</sup> <sup>(31)</sup> <sup>(32)</sup>			
	Chemical oxygen demand (COD)		60–150 mg/l <sup>(30)</sup> <sup>(31)</sup> <sup>(32)</sup>			
	Total suspended solids (TSS)		10–30 mg/l			
	Fluoride (F <sup>-</sup> )		10–25 mg/l <sup>(32)</sup>			
	Sulphate (SO <sub>4</sub> <sup>2-</sup> )		1,3–2,0 g/l <sup>(32)</sup> <sup>(33)</sup> <sup>(34)</sup> <sup>(35)</sup>			
	Sulphide (S <sup>2-</sup> ), easily released		0,1–0,2 mg/l <sup>(32)</sup>			
	Sulphite (SO <sub>3</sub> <sup>2-</sup> )		1–20 mg/l <sup>(32)</sup>			
	Metals and metalloids	As	10–50 µg/l			
		Cd	2–5 µg/l			
		Cr	10–50 µg/l			
Cu		10–50 µg/l				
Hg		0,2–3 µg/l				
Ni		10–50 µg/l				
Pb		10–20 µg/l				
Zn	50–200 µg/l					

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																				
16	<p>In order to reduce the quantity of waste sent for disposal from the combustion and/or gasification process and abatement techniques, BAT is to organise operations so as to maximise, in order of priority and taking into account life-cycle thinking:</p> <p>(a) waste prevention, e.g. maximise the proportion of residues which arise as by-products;</p> <p>(b) waste preparation for reuse, e.g. according to the specific requested quality criteria;</p> <p>(c) waste recycling;</p> <p>(d) other waste recovery (e.g. energy recovery),</p> <p>by implementing an appropriate combination of techniques such as:</p> <table><thead><tr><th colspan="2">Technique</th><th>Description</th><th>Applicability</th></tr></thead><tbody><tr><td>a.</td><td>Generation of gypsum as a by-product</td><td>Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g. as raw material in the plasterboard industry). The quality of limestone used in the wet FGD influences the purity of the gypsum produced</td><td>Generally applicable within the constraints associated with the required gypsum quality, the health requirements associated to each specific use, and by the market conditions</td></tr><tr><td>b.</td><td>Recycling or recovery of residues in the construction sector</td><td>Recycling or recovery of residues (e.g. from semi-dry desulphurisation processes, fly ash, bottom ash) as a construction material (e.g. in road building, to replace sand in concrete production, or in the cement industry)</td><td>Generally applicable within the constraints associated with the required material quality (e.g. physical properties, content of harmful substances) associated to each specific use, and by the market conditions</td></tr><tr><td>c.</td><td>Energy recovery by using waste in the fuel mix</td><td>The residual energy content of carbon-rich ash and sludges generated by the combustion of coal, lignite, heavy fuel oil, peat or biomass can be recovered for example by mixing with the fuel</td><td>Generally applicable where plants can accept waste in the fuel mix and are technically able to feed the fuels into the combustion chamber</td></tr><tr><td>d.</td><td>Preparation of spent catalyst for reuse</td><td>Preparation of catalyst for reuse (e.g. up to four times for SCR catalysts) restores some or all of the original performance, extending the service life of the catalyst to several decades. Preparation of spent catalyst for reuse is integrated in a catalyst management scheme</td><td>The applicability may be limited by the mechanical condition of the catalyst and the required performance with respect to controlling NO<sub>x</sub> and NH<sub>3</sub> emissions</td></tr></tbody></table>			Technique		Description	Applicability	a.	Generation of gypsum as a by-product	Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g. as raw material in the plasterboard industry). The quality of limestone used in the wet FGD influences the purity of the gypsum produced	Generally applicable within the constraints associated with the required gypsum quality, the health requirements associated to each specific use, and by the market conditions	b.	Recycling or recovery of residues in the construction sector	Recycling or recovery of residues (e.g. from semi-dry desulphurisation processes, fly ash, bottom ash) as a construction material (e.g. in road building, to replace sand in concrete production, or in the cement industry)	Generally applicable within the constraints associated with the required material quality (e.g. physical properties, content of harmful substances) associated to each specific use, and by the market conditions	c.	Energy recovery by using waste in the fuel mix	The residual energy content of carbon-rich ash and sludges generated by the combustion of coal, lignite, heavy fuel oil, peat or biomass can be recovered for example by mixing with the fuel	Generally applicable where plants can accept waste in the fuel mix and are technically able to feed the fuels into the combustion chamber	d.	Preparation of spent catalyst for reuse	Preparation of catalyst for reuse (e.g. up to four times for SCR catalysts) restores some or all of the original performance, extending the service life of the catalyst to several decades. Preparation of spent catalyst for reuse is integrated in a catalyst management scheme	The applicability may be limited by the mechanical condition of the catalyst and the required performance with respect to controlling NO <sub>x</sub> and NH <sub>3</sub> emissions	CC	<p>The Operator stated that they consider their operations are currently compliant with this BAT conclusion and provided the following description of their relevant operating techniques:</p> <p>Wastes generated directly from the combustion process include gas turbine air filters and combustion chamber tiles. The tiles are recyclable (but not recoverable) to be used as potential road building aggregate but the filters are used as a fuels source for a 'Waste-to-Energy' plant. Neither go to landfill.</p> <p>We agree with the compliance status stated by the Operator.</p>
Technique		Description	Applicability																						
a.	Generation of gypsum as a by-product	Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g. as raw material in the plasterboard industry). The quality of limestone used in the wet FGD influences the purity of the gypsum produced	Generally applicable within the constraints associated with the required gypsum quality, the health requirements associated to each specific use, and by the market conditions																						
b.	Recycling or recovery of residues in the construction sector	Recycling or recovery of residues (e.g. from semi-dry desulphurisation processes, fly ash, bottom ash) as a construction material (e.g. in road building, to replace sand in concrete production, or in the cement industry)	Generally applicable within the constraints associated with the required material quality (e.g. physical properties, content of harmful substances) associated to each specific use, and by the market conditions																						
c.	Energy recovery by using waste in the fuel mix	The residual energy content of carbon-rich ash and sludges generated by the combustion of coal, lignite, heavy fuel oil, peat or biomass can be recovered for example by mixing with the fuel	Generally applicable where plants can accept waste in the fuel mix and are technically able to feed the fuels into the combustion chamber																						
d.	Preparation of spent catalyst for reuse	Preparation of catalyst for reuse (e.g. up to four times for SCR catalysts) restores some or all of the original performance, extending the service life of the catalyst to several decades. Preparation of spent catalyst for reuse is integrated in a catalyst management scheme	The applicability may be limited by the mechanical condition of the catalyst and the required performance with respect to controlling NO <sub>x</sub> and NH <sub>3</sub> emissions																						
17	<p>In order to reduce noise emissions, BAT is to use one or a combination of the techniques given below.</p> <table><thead><tr><th>Technique</th><th>Description</th><th>Applicability</th></tr></thead></table>			Technique	Description	Applicability	CC	<p>The Operator confirmed that the following appropriate combination</p>																	
Technique	Description	Applicability																							

BAT Concn. Number	Summary of BAT Conclusion requirement				Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	a.	Operational measures	These include: — improved inspection and maintenance of equipment  — closing of doors and windows of enclosed areas, if possible  — equipment operated by experienced staff  — avoidance of noisy activities at night, if possible  — provisions for noise control during maintenance activities	Generally applicable		of techniques is used at the installation:  a. Operational measures  1. GT Enclosures are taken apart during maintenance periods. They are then re-erected and tested for both fire protection and sound integrity before the turbines are allowed to re-start. Annual noise surveys are undertaken to prove whether Environmental Permit compliance is being maintained. 2. Site building do not contain windows. All pedestrian and vehicles roller shutter doors remain closed when not in use. 3. All operational staff undertake an 8 to 9 month training period before being allowed to operate site equipment. 4. Night activities are restricted to standard operation only. During outages, the majority of night work is conducted within a building. 5. Due to the location of the site and the nature of the work undertaken, the necessity for noise control is minimal. For extreme noise events (such as safety valve testing where short periods of high pressure steam is
	b.	Low-noise equipment	This potentially includes compressors, pumps and disks	Generally applicable when the equipment is new or replaced		
	c.	Noise attenuation	Noise propagation can be reduced by inserting obstacles between the emitter and the receiver. Appropriate obstacles include protection walls, embankments and buildings	Generally applicable to new plants. In the case of existing plants, the insertion of obstacles may be restricted by lack of space		
	d.	Noise-control equipment	This includes: — noise-reducers — equipment insulation — enclosure of noisy equipment — soundproofing of buildings	The applicability may be restricted by lack of space		
	e.	Appropriate location of equipment and buildings	Noise levels can be reduced by increasing the distance between the emitter and the receiver and by using buildings as noise screens	Generally applicable to new plant		

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
			<p>released) Marchwood Power Limited are duty bound to inform the New Forest District Council 48hours in advance of the release.</p> <p>b. Low-noise equipment. Due to the nature of having equipment housed internally within buildings, low noise equipment has not been specifically selected.</p> <p>c. Noise attenuation. All site buildings have noise attenuation material installed within. All external doors are kept closed during operating conditions. The Gas Turbine enclosures are subsequently protected to ensure the extreme noise is housed and that work can continue externally without additional PPE and that compliance with the Environmental Permit conditions is maintained.</p> <p>d. Noise-control equipment. As per the point above, building sound proofing and enclosures are utilised to ensure compliance with the Environmental Permit limits. Noise reducers are utilised on</p>

BAT Concn. Number	Summary of BAT Conclusion requirement				Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																																									
						<p>vacuum breakers mounted on the main cooling water culvert.</p> <p>e. Appropriate location of equipment and buildings. All major equipment housed within a building (apart from main cooling water pumps).</p> <p>We agree with the compliance status stated by the Operator.</p>																																									
Combustion of gaseous fuels																																															
40	<p>In order to increase the energy efficiency of natural gas combustion, BAT is to use an appropriate combination of the techniques given in BAT 12 and below.</p> <table><tr><th>Technique</th><th>Description</th><th colspan="2">Applicability</th></tr><tr><td>a. Combined cycle</td><td>See description in Section 8.2</td><td colspan="2">Generally applicable to new gas turbines and engines except when operated &lt; 1 500 h/yr. Applicable to existing gas turbines and engines within the constraints associated with the steam cycle design and the space availability. Not applicable to existing gas turbines and engines operated &lt; 1 500 h/yr. Not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns. Not applicable to boilers</td></tr></table> <p><b>BAT-associated energy efficiency levels (BAT-AEELs) for the combustion of natural gas</b></p> <table><tr><th rowspan="3">Type of combustion unit</th><th colspan="5">BAT-AEELs <sup>(136)</sup> <sup>(137)</sup></th></tr><tr><th colspan="2">Net electrical efficiency (%)</th><th rowspan="2">Net total fuel utilisation (%) <sup>(138)</sup> <sup>(139)</sup></th><th colspan="2">Net mechanical energy efficiency (%) <sup>(139)</sup> <sup>(140)</sup></th></tr><tr><th>New unit</th><th>Existing unit</th><th>New unit</th><th>Existing unit</th></tr><tr><td>Gas engine</td><td>39,5–44 <sup>(141)</sup></td><td>35–44 <sup>(141)</sup></td><td>56–85 <sup>(141)</sup></td><td colspan="2">No BAT-AEEL.</td></tr><tr><td>Gas-fired boiler</td><td>39–42,5</td><td>38–40</td><td>78–95</td><td colspan="2">No BAT-AEEL.</td></tr><tr><td>Open cycle gas turbine, ≥ 50 MWth</td><td>36–41,5</td><td>33–41,5</td><td>No BAT-AEEL</td><td>36,5–41</td><td>33,5–41</td></tr></table>				Technique	Description	Applicability		a. Combined cycle	See description in Section 8.2	Generally applicable to new gas turbines and engines except when operated < 1 500 h/yr. Applicable to existing gas turbines and engines within the constraints associated with the steam cycle design and the space availability. Not applicable to existing gas turbines and engines operated < 1 500 h/yr. Not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns. Not applicable to boilers		Type of combustion unit	BAT-AEELs <sup>(136)</sup> <sup>(137)</sup>					Net electrical efficiency (%)		Net total fuel utilisation (%) <sup>(138)</sup> <sup>(139)</sup>	Net mechanical energy efficiency (%) <sup>(139)</sup> <sup>(140)</sup>		New unit	Existing unit	New unit	Existing unit	Gas engine	39,5–44 <sup>(141)</sup>	35–44 <sup>(141)</sup>	56–85 <sup>(141)</sup>	No BAT-AEEL.		Gas-fired boiler	39–42,5	38–40	78–95	No BAT-AEEL.		Open cycle gas turbine, ≥ 50 MWth	36–41,5	33–41,5	No BAT-AEEL	36,5–41	33,5–41	CC	<p>The Operator stated that they consider the installation compliant with this BAT conclusion and provided the following description of the operating techniques and performance indicators relevant to this BAT conclusion:</p> <p>LCP216 and 217 are CCGT. The Operator confirmed that the LCPs are not operated in open cycle. During start-up conditions the GTs are held below MSUL until there is sufficient steam generated by the waste heat boilers to couple the steam turbine.</p> <p>The Operator advised a Net Electrical Efficiency figure of 58.39% for the operation of LCP 216 and LCP 217 in CCGT mode, at reference baseload conditions.</p>
Technique	Description	Applicability																																													
a. Combined cycle	See description in Section 8.2	Generally applicable to new gas turbines and engines except when operated < 1 500 h/yr. Applicable to existing gas turbines and engines within the constraints associated with the steam cycle design and the space availability. Not applicable to existing gas turbines and engines operated < 1 500 h/yr. Not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns. Not applicable to boilers																																													
Type of combustion unit	BAT-AEELs <sup>(136)</sup> <sup>(137)</sup>																																														
	Net electrical efficiency (%)		Net total fuel utilisation (%) <sup>(138)</sup> <sup>(139)</sup>	Net mechanical energy efficiency (%) <sup>(139)</sup> <sup>(140)</sup>																																											
	New unit	Existing unit		New unit	Existing unit																																										
Gas engine	39,5–44 <sup>(141)</sup>	35–44 <sup>(141)</sup>	56–85 <sup>(141)</sup>	No BAT-AEEL.																																											
Gas-fired boiler	39–42,5	38–40	78–95	No BAT-AEEL.																																											
Open cycle gas turbine, ≥ 50 MWth	36–41,5	33–41,5	No BAT-AEEL	36,5–41	33,5–41																																										

BAT Concn. Number	Summary of BAT Conclusion requirement					Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																				
	<div>Combined cycle gas turbine (CCGT)</div> <table><tr><td>CCGT, 50–600 MW<sub>th</sub></td><td>53–58,5</td><td>46–54</td><td>No BAT-AEEL</td><td>No BAT-AEEL</td></tr><tr><td>CCGT, ≥ 600 MW<sub>th</sub></td><td>57–60,5</td><td>50–60</td><td>No BAT-AEEL</td><td>No BAT-AEEL</td></tr><tr><td>CHP CCGT, 50–600 MW<sub>th</sub></td><td>53–58,5</td><td>46–54</td><td>65–95</td><td>No BAT-AEEL</td></tr><tr><td>CHP CCGT, ≥ 600 MW<sub>th</sub></td><td>57–60,5</td><td>50–60</td><td>65–95</td><td>No BAT-AEEL</td></tr></table>					CCGT, 50–600 MW <sub>th</sub>	53–58,5	46–54	No BAT-AEEL	No BAT-AEEL	CCGT, ≥ 600 MW <sub>th</sub>	57–60,5	50–60	No BAT-AEEL	No BAT-AEEL	CHP CCGT, 50–600 MW <sub>th</sub>	53–58,5	46–54	65–95	No BAT-AEEL	CHP CCGT, ≥ 600 MW <sub>th</sub>	57–60,5	50–60	65–95	No BAT-AEEL		<p>This figure is based on the operation in a 2 gas turbine +1 steam turbine configuration, since the LCPs at the site share a common steam turbine. This figure is based on the recent performance tests carried out in 2019 by the gas turbines OEM (Siemens). The Operator provided the performance test reports as supporting evidence.</p> <p>The Net Electrical Efficiency advised by the Operator is within the BAT-AEEL range for the existing CCGT ≥ 600 MW<sub>th</sub>.</p> <p>We agree that the installation is compliant with this BAT conclusion and the applicable BAT-AEEL.</p>
CCGT, 50–600 MW <sub>th</sub>	53–58,5	46–54	No BAT-AEEL	No BAT-AEEL																							
CCGT, ≥ 600 MW <sub>th</sub>	57–60,5	50–60	No BAT-AEEL	No BAT-AEEL																							
CHP CCGT, 50–600 MW <sub>th</sub>	53–58,5	46–54	65–95	No BAT-AEEL																							
CHP CCGT, ≥ 600 MW <sub>th</sub>	57–60,5	50–60	65–95	No BAT-AEEL																							
41	<p>In order to prevent or reduce NO<sub>x</sub> emissions to air from the combustion of natural gas in boilers, BAT is to use one or a combination of the techniques given below.</p> <table><tr><th colspan="2">Technique</th><th>Description</th><th>Applicability</th></tr><tr><td>a.</td><td>Air and/or fuel staging</td><td>See descriptions in Section 8.3. Air staging is often associated with low-NO<sub>x</sub> burners</td><td rowspan="3">Generally applicable</td></tr><tr><td>b.</td><td>Flue-gas recirculation</td><td>See description in Section 8.3</td></tr><tr><td>c.</td><td>Low-NO<sub>x</sub> burners (LNB)</td></tr><tr><td>d.</td><td>Advanced control system</td><td>See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated &lt; 500 h/yr</td><td>The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system</td></tr></table>					Technique		Description	Applicability	a.	Air and/or fuel staging	See descriptions in Section 8.3. Air staging is often associated with low-NO <sub>x</sub> burners	Generally applicable	b.	Flue-gas recirculation	See description in Section 8.3	c.	Low-NO <sub>x</sub> burners (LNB)	d.	Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system	NA	<p>There are no boilers within the LCPs at the installation, therefore this BAT conclusion is not applicable.</p>			
Technique		Description	Applicability																								
a.	Air and/or fuel staging	See descriptions in Section 8.3. Air staging is often associated with low-NO <sub>x</sub> burners	Generally applicable																								
b.	Flue-gas recirculation	See description in Section 8.3																									
c.	Low-NO <sub>x</sub> burners (LNB)																										
d.	Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system																								

BAT Concn. Number	Summary of BAT Conclusion requirement				Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	e.	Reduction of the combustion air temperature	See description in Section 8.3	Generally applicable within the constraints associated with the process needs		
	f.	Selective non-catalytic reduction (SNCR)		Not applicable to combustion plants operated < 500 h/yr with highly variable boiler loads. The applicability may be limited in the case of combustion plants operated between 500 h/yr and 1 500 h/yr with highly variable boiler loads		
	g.	Selective catalytic reduction (SCR)		Not applicable to combustion plants operated < 500 h/yr. Not generally applicable to combustion plants of < 100 MW <sub>th</sub> . There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr		
42	In order to prevent or reduce NO <sub>x</sub> emissions to air from the combustion of natural gas in gas turbines, BAT is to use one or a combination of the techniques given below.				CC	The Operator confirmed that the following combination of techniques is used to achieve compliance: a. Advanced control system. The current control system is the latest OEM version of control system Architecture. The system is continually updated as part of the long term maintenance agreement.  c. Dry Low-NO <sub>x</sub> burners. Dry Low-NO <sub>x</sub> burners are utilised across the entire gas turbine operational range. The Operator confirmed that the DLN-E point for the gas turbines at the installation corresponds to the MSUL point previously agreed
	<b>Technique</b>		<b>Description</b>	<b>Applicability</b>		
	a.	Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system		
	b.	Water/steam addition	See description in Section 8.3	The applicability may be limited due to water availability		
	c.	Dry low-NO <sub>x</sub> burners (DLN)		The applicability may be limited in the case of turbines where a retrofit package is not available or when water/steam addition systems are installed		
	d.	Low-load design concept	Adaptation of the process control and related equipment to maintain good combustion efficiency when the demand in energy varies, e.g. by improving the inlet airflow control capability or by splitting the combustion process into decoupled combustion stages	The applicability may be limited by the gas turbine design		

BAT Concn. Number	Summary of BAT Conclusion requirement				Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement												
	<table><tr><td>e.</td><td>Low-NO<sub>x</sub> burners (LNB)</td><td rowspan="2">See description in Section 8.3</td><td>Generally applicable to supplementary firing for heat recovery steam generators (HRSGs) in the case of combined-cycle gas turbine (CCGT) combustion plants</td></tr><tr><td>f.</td><td>Selective catalytic reduction (SCR)</td><td>Not applicable in the case of combustion plants operated &lt; 500 h/yr. Not generally applicable to existing combustion plants of &lt; 100 MW<sub>th</sub>. Retrofitting existing combustion plants may be constrained by the availability of sufficient space. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr</td></tr></table>				e.	Low-NO <sub>x</sub> burners (LNB)	See description in Section 8.3	Generally applicable to supplementary firing for heat recovery steam generators (HRSGs) in the case of combined-cycle gas turbine (CCGT) combustion plants	f.	Selective catalytic reduction (SCR)	Not applicable in the case of combustion plants operated < 500 h/yr. Not generally applicable to existing combustion plants of < 100 MW <sub>th</sub> . Retrofitting existing combustion plants may be constrained by the availability of sufficient space. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr		<p>with the Environment Agency in response to Improvement Condition 12.</p> <p>d. Low load design concept. Following the SP7 upgrade in 2015, the Stable Export Limit (SEL) was reduced from 560MWatts to 450MWatts and the Maximum Export Limit increased from 848MWatts to 898MWatts.</p> <p>Refer to section 4 of this decision document for the revised emission limits set for LCP 216 and 217 in compliance with the applicable BAT-AEL.</p> <p>We agree that the installation is compliant with this BAT conclusion and the applicable BAT-AELs.</p>					
e.	Low-NO <sub>x</sub> burners (LNB)	See description in Section 8.3	Generally applicable to supplementary firing for heat recovery steam generators (HRSGs) in the case of combined-cycle gas turbine (CCGT) combustion plants															
f.	Selective catalytic reduction (SCR)		Not applicable in the case of combustion plants operated < 500 h/yr. Not generally applicable to existing combustion plants of < 100 MW <sub>th</sub> . Retrofitting existing combustion plants may be constrained by the availability of sufficient space. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr															
43	<p>In order to prevent or reduce NO<sub>x</sub> emissions to air from the combustion of natural gas in engines, BAT is to use one or a combination of the techniques given below.</p> <table><tr><th>Technique</th><th>Description</th><th>Applicability</th></tr><tr><td>a. Advanced control system</td><td>See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated &lt; 500 h/yr</td><td>The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system</td></tr><tr><td>b. Lean-burn concept</td><td>See description in Section 8.3. Generally used in combination with SCR</td><td>Only applicable to new gas-fired engines</td></tr><tr><td>c. Advanced lean-burn concept</td><td>See descriptions in Section 8.3</td><td>Only applicable to new spark plug ignited engines</td></tr></table>				Technique	Description	Applicability	a. Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system	b. Lean-burn concept	See description in Section 8.3. Generally used in combination with SCR	Only applicable to new gas-fired engines	c. Advanced lean-burn concept	See descriptions in Section 8.3	Only applicable to new spark plug ignited engines	NA	<p>There are no gas engines within the LCPs at the installation, therefore this BAT conclusion is not applicable.</p>
Technique	Description	Applicability																
a. Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system																
b. Lean-burn concept	See description in Section 8.3. Generally used in combination with SCR	Only applicable to new gas-fired engines																
c. Advanced lean-burn concept	See descriptions in Section 8.3	Only applicable to new spark plug ignited engines																



BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																																												
	d.	Selective catalytic reduction (SCR)		Retrofitting existing combustion plants may be constrained by the availability of sufficient space. Not applicable to combustion plants operated < 500 h/yr. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr																																													
44	In order to prevent or reduce CO emissions to air from the combustion of natural gas, BAT is to ensure optimised combustion and/or to use oxidation catalysts. <b>Description - See descriptions in Section 8.3.</b> <b>BAT-associated emission levels (BAT-AELs) for NO<sub>x</sub> emissions to air from the combustion of natural gas in gas turbines</b>			CC	The Operator confirmed that optimised combustion is used as a technique to reduce CO and NO <sub>x</sub> emissions: <ul style="list-style-type: none"><li>- Full and part-load optimisation tuning is undertaken on a periodic or performance based frequency by the OEM (Siemens).</li><li>- An advanced control system is used to optimise combustion: The current control system is the latest OEM version of control system Architecture. The system is continually updated as part of the long term maintenance agreement.</li></ul> Refer to section 4 of this decision document for the revised emission limits set for LCP 216 and 217 in compliance with the applicable BAT-AEL.  We agree that the installation is compliant with this BAT																																												
<table><tr><th rowspan="2">Type of combustion plant</th><th rowspan="2">Combustion plant total rated thermal input (MW<sub>th</sub>)</th><th colspan="2">BAT-AELs (mg/Nm<sup>3</sup>) <sup>(142)</sup> <sup>(143)</sup></th></tr><tr><th>Yearly average <sup>(144)</sup> <sup>(145)</sup></th><th>Daily average or average over the sampling period</th></tr><tr><td colspan="4">Open-cycle gas turbines (OCGTs) <sup>(146)</sup> <sup>(147)</sup></td></tr><tr><td>New OCGT</td><td>≥ 50</td><td>15–35</td><td>25–50</td></tr><tr><td>Existing OCGT (excluding turbines for mechanical drive applications) — All but plants operated &lt; 500 h/yr</td><td>≥ 50</td><td>15–50</td><td>25–55 <sup>(148)</sup></td></tr><tr><td colspan="4">Combined-cycle gas turbines (CCGTs) <sup>(146)</sup> <sup>(149)</sup></td></tr><tr><td>New CCGT</td><td>≥ 50</td><td>10–30</td><td>15–40</td></tr><tr><td>Existing CCGT with a net total fuel utilisation of &lt; 75 %</td><td>≥ 600</td><td>10–40</td><td>18–50</td></tr><tr><td>Existing CCGT with a net total fuel utilisation of ≥ 75 %</td><td>≥ 600</td><td>10–50</td><td>18–55 <sup>(150)</sup></td></tr><tr><td>Existing CCGT with a net total fuel utilisation of &lt; 75 %</td><td>50–600</td><td>10–45</td><td>35–55</td></tr><tr><td>Existing CCGT with a net total fuel utilisation of ≥ 75 %</td><td>50–600</td><td>25–50 <sup>(151)</sup></td><td>35–55 <sup>(152)</sup></td></tr><tr><td colspan="4">Open- and combined-cycle gas turbines</td></tr></table>			Type of combustion plant	Combustion plant total rated thermal input (MW <sub>th</sub> )		BAT-AELs (mg/Nm <sup>3</sup> ) <sup>(142)</sup> <sup>(143)</sup>		Yearly average <sup>(144)</sup> <sup>(145)</sup>	Daily average or average over the sampling period	Open-cycle gas turbines (OCGTs) <sup>(146)</sup> <sup>(147)</sup>				New OCGT	≥ 50	15–35	25–50	Existing OCGT (excluding turbines for mechanical drive applications) — All but plants operated < 500 h/yr	≥ 50	15–50	25–55 <sup>(148)</sup>	Combined-cycle gas turbines (CCGTs) <sup>(146)</sup> <sup>(149)</sup>				New CCGT	≥ 50	10–30	15–40	Existing CCGT with a net total fuel utilisation of < 75 %	≥ 600	10–40	18–50	Existing CCGT with a net total fuel utilisation of ≥ 75 %	≥ 600	10–50	18–55 <sup>(150)</sup>	Existing CCGT with a net total fuel utilisation of < 75 %	50–600	10–45	35–55	Existing CCGT with a net total fuel utilisation of ≥ 75 %	50–600	25–50 <sup>(151)</sup>	35–55 <sup>(152)</sup>	Open- and combined-cycle gas turbines			
Type of combustion plant	Combustion plant total rated thermal input (MW <sub>th</sub> )	BAT-AELs (mg/Nm <sup>3</sup> ) <sup>(142)</sup> <sup>(143)</sup>																																															
		Yearly average <sup>(144)</sup> <sup>(145)</sup>	Daily average or average over the sampling period																																														
Open-cycle gas turbines (OCGTs) <sup>(146)</sup> <sup>(147)</sup>																																																	
New OCGT	≥ 50	15–35	25–50																																														
Existing OCGT (excluding turbines for mechanical drive applications) — All but plants operated < 500 h/yr	≥ 50	15–50	25–55 <sup>(148)</sup>																																														
Combined-cycle gas turbines (CCGTs) <sup>(146)</sup> <sup>(149)</sup>																																																	
New CCGT	≥ 50	10–30	15–40																																														
Existing CCGT with a net total fuel utilisation of < 75 %	≥ 600	10–40	18–50																																														
Existing CCGT with a net total fuel utilisation of ≥ 75 %	≥ 600	10–50	18–55 <sup>(150)</sup>																																														
Existing CCGT with a net total fuel utilisation of < 75 %	50–600	10–45	35–55																																														
Existing CCGT with a net total fuel utilisation of ≥ 75 %	50–600	25–50 <sup>(151)</sup>	35–55 <sup>(152)</sup>																																														
Open- and combined-cycle gas turbines																																																	

BAT Concn. Number	Summary of BAT Conclusion requirement				Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																						
	Gas turbine put into operation no later than 27 November 2003, or existing gas turbine for emergency use and operated < 500 h/yr	≥ 50	No BAT-AEL	60–140 <sup>(153)</sup> <sup>(154)</sup>		conclusion and the applicable BAT-AELs.																						
	Existing gas turbine for mechanical drive applications — All but plants operated < 500 h/yr	≥ 50	15–50 <sup>(155)</sup>	25–55 <sup>(156)</sup>																								
<p>As an indication, the yearly average CO emission levels for each type of existing combustion plant operated ≥ 1 500 h/yr and for each type of new combustion plant will generally be as follows:</p> <ul style="list-style-type: none"><li>— New OCGT of ≥ 50 MW<sub>th</sub>: &lt; 5–40 mg/Nm<sup>3</sup>. For plants with a net electrical efficiency (EE) greater than 39 %, a correction factor may be applied to the higher end of this range, corresponding to [higher end] × EE/39, where EE is the net electrical energy efficiency or net mechanical energy efficiency of the plant determined at ISO baseload conditions.</li><li>— Existing OCGT of ≥ 50 MW<sub>th</sub> (excluding turbines for mechanical drive applications): &lt; 5–40 mg/Nm<sup>3</sup>. The higher end of this range will generally be 80 mg/Nm<sup>3</sup> in the case of existing plants that cannot be fitted with dry techniques for NO<sub>x</sub> reduction, or 50 mg/Nm<sup>3</sup> for plants that operate at low load.</li><li>— New CCGT of ≥ 50 MW<sub>th</sub>: &lt; 5–30 mg/Nm<sup>3</sup>. For plants with a net electrical efficiency (EE) greater than 55 %, a correction factor may be applied to the higher end of the range, corresponding to [higher end] × EE/55, where EE is the net electrical energy efficiency of the plant determined at ISO baseload conditions.</li><li>— Existing CCGT of ≥ 50 MW<sub>th</sub>: &lt; 5–30 mg/Nm<sup>3</sup>. The higher end of this range will generally be 50 mg/Nm<sup>3</sup> for plants that operate at low load.</li><li>— Existing gas turbines of ≥ 50 MW<sub>th</sub> for mechanical drive applications: &lt; 5–40 mg/Nm<sup>3</sup>. The higher end of the range will generally be 50 mg/Nm<sup>3</sup> when plants operate at low load.</li></ul> <p>In the case of a gas turbine equipped with DLN burners, these indicative levels correspond to when the DLN operation is effective.</p> <p><b>BAT-associated emission levels (BAT-AELs) for NO<sub>x</sub> emissions to air from the combustion of natural gas in boilers and engines</b></p> <table><tr><th rowspan="3">Type of combustion plant</th><th colspan="4">BAT-AELs (mg/Nm<sup>3</sup>)</th></tr><tr><th colspan="2">Yearly average <sup>(157)</sup></th><th colspan="2">Daily average or average over the sampling period</th></tr><tr><th>New plant</th><th>Existing plant <sup>(158)</sup></th><th>New plant</th><th>Existing plant <sup>(159)</sup></th></tr><tr><td>Boiler</td><td>10–60</td><td>50–100</td><td>30–85</td><td>85–110</td></tr><tr><td>Engine <sup>(160)</sup></td><td>20–75</td><td>20–100</td><td>55–85</td><td>55–110 <sup>(161)</sup></td></tr></table> <p>As an indication, the yearly average CO emission levels will generally be:</p>							Type of combustion plant	BAT-AELs (mg/Nm <sup>3</sup> )				Yearly average <sup>(157)</sup>		Daily average or average over the sampling period		New plant	Existing plant <sup>(158)</sup>	New plant	Existing plant <sup>(159)</sup>	Boiler	10–60	50–100	30–85	85–110	Engine <sup>(160)</sup>	20–75	20–100	55–85
Type of combustion plant	BAT-AELs (mg/Nm <sup>3</sup> )																											
	Yearly average <sup>(157)</sup>		Daily average or average over the sampling period																									
	New plant	Existing plant <sup>(158)</sup>	New plant	Existing plant <sup>(159)</sup>																								
Boiler	10–60	50–100	30–85	85–110																								
Engine <sup>(160)</sup>	20–75	20–100	55–85	55–110 <sup>(161)</sup>																								

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	<ul style="list-style-type: none"> <li>— &lt; 5–40 mg/Nm<sup>3</sup> for existing boilers operated ≥ 1 500 h/yr,</li> <li>— &lt; 5–15 mg/Nm<sup>3</sup> for new boilers,</li> <li>— 30–100 mg/Nm<sup>3</sup> for existing engines operated ≥ 1 500 h/yr and for new engines.</li> </ul>		

## **6. Emissions to Water**

The consolidated permit incorporates the three current discharges to controlled waters identified as WW, SW1 and SW2.

There are no BAT AELs specified in the BAT Conclusions for this type of plant. There are also no additional treatment options identified as BAT for the installation. We have therefore not carried out any additional assessment of the emissions to water as part of this review.

## **7. Additional IED Chapter II requirements and other requirements**

### **LCP reference numbers**

Before this variation, the permit incorrectly referred to the large combustion plants at the installation as LCP 215 and LCP 216, whilst they should have been referred to as LCP 216 and LCP 217; as part of this variation we have corrected the reference number for the LCPs at the installation.

### **Thermal inputs of LCPs**

We have updated the thermal input and output figures for LCP 216 and LCP 217 according to the updated information provided by the operator in response to historical improvement condition IC11, reflecting the past upgrades to their combustion equipment.

### **MSUL/MSDL**

We have set minimum start up and shut down load (MSUL/MSDL) criteria in table S1.5 of the variation and consolidation notice, to reflect the parameters previously agreed with the Environment Agency in response to historical improvement condition IC12.

### **Black start**

In the event of a black out National Grid would call on combustion plant to operate and may require them to do so outside their permitted conditions. We have dedicated black start plant and they are permitted to run as such but this scenario is relevant to the rest of the large combustion plant which could be called depending on the circumstances.

A risk assessment will be carried out by Energy UK/Joint Environmental Programme on behalf of Large Combustion Plant connected to the National Transmission System. Air emissions modelling will be based on generic black start scenarios to establish whether they have the potential to have local impact on the environment or not (on a national basis). If the modelling demonstrates that no significant impacts are likely, the plant can operate under condition 2.3.10. This conditions allows the hourly ELVs for plants operating under a black start instruction to be discounted for the purpose of reporting. We would also require there to be a procedure in place for minimisation of emissions in the case of a black start event and for reporting in the event of a black start. This modelling and the procedures have not been agreed in advance of the issue of the permit review and therefore a condition linking back to an improvement condition have been included in the permit.

## 9 Review and assessment of changes that are not part of the BAT Conclusions derived permit review.

This document should be read in conjunction with the application, supporting information and notice.

Aspect considered	Decision
<b>Receipt of application</b>	
Confidential information	<p>A claim for commercial or industrial confidentiality has been made.</p> <p>Refer to section 2.1 for additional details.</p>
Identifying confidential information	<p>We have not identified information provided as part of the application that we consider to be confidential.</p> <p>The decision was taken in accordance with our guidance on confidentiality.</p>
<b>The site</b>	
Biodiversity, heritage, landscape and nature conservation	<p>The application is within the relevant distance criteria of a site of heritage, landscape or nature conservation, and/or protected species or habitat.</p> <p>A full assessment of the application and its potential to affect the site(s)/species/habitat has not been carried out as part of the permit review process. We consider that the review will not affect the features of the site(s)/species/habitat as the conditions will provide at least the same level of protection as those in the previous permit and in some cases will provide a higher level of protection to those in the previous permit.</p> <p>We have not consulted Natural England on the application. The decision was taken in accordance with our guidance.</p>
<b>Operating techniques</b>	
General operating techniques	<p>We have reviewed the techniques used by the operator where they are relevant to the BAT Conclusions and compared these with the relevant guidance notes.</p> <p>The permit conditions ensure compliance with the relevant BREF, BAT Conclusions. The ELVs deliver compliance with the BAT-AELs.</p>
<b>Permit conditions</b>	
Updating permit conditions during consolidation	<p>We have updated permit conditions to those in the current generic permit template as part of permit consolidation. The conditions will provide at least the same level of protection as</p>

Aspect considered	Decision
	those in the previous permit and in some cases will provide a higher level of protection to those in the previous permit.
Changes to the permit conditions due to an Environment Agency initiated variation	We have varied the permit as stated in the variation notice.
Improvement programme	<p>Based on the information on the application, we consider that we need to impose an improvement programme.</p> <p>We have imposed an improvement programme to ensure that:</p> <ul style="list-style-type: none"> <li>Non-compliance with ELVs set in the permit during a black start instruction from the National Grid is risk assessed (IC13).</li> </ul> <p>We have also marked as completed the historical improvement conditions, according to our records.</p>
Emission limits	<p>We have decided that emission limits should be set for the parameters listed in the permit.</p> <p>These are described in the relevant BAT Conclusions in Sections 4 and 5 of this document.</p> <p>It is considered that the ELVs/equivalent parameters or technical measures described above will ensure that significant pollution of the environment is prevented and a high level of protection for the environment is secured.</p>
Monitoring	<p>We have decided that monitoring should be carried out for the parameters listed in the permit, using the methods detailed and to the frequencies specified.</p> <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p> <p>Table S3.4 Process monitoring requirements - was amended to include the requirement to monitor energy efficiency after overhauls on site in line with BAT2.</p>
Reporting	<p>We have specified reporting in the permit for the following parameters:</p> <ul style="list-style-type: none"> <li>Nitrogen dioxide</li> <li>Carbon monoxide</li> <li>Sulphur dioxide</li> </ul> <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p>

Aspect considered	Decision
<b>Operator competence</b>	
Management system	There is no known reason to consider that the operator will not have the management system to enable it to comply with the permit conditions.
<b>Growth Duty</b>	
Section 108 Deregulation Act 2015 – Growth duty	<p>We have considered our duty to have regard to the desirability of promoting economic growth set out in section 108(1) of the Deregulation Act 2015 and the guidance issued under section 110 of that Act in deciding whether to grant this permit.</p> <p>Paragraph 1.3 of the guidance says:</p> <p>“The primary role of regulators, in delivering regulation, is to achieve the regulatory outcomes for which they are responsible. For a number of regulators, these regulatory outcomes include an explicit reference to development or growth. The growth duty establishes economic growth as a factor that all specified regulators should have regard to, alongside the delivery of the protections set out in the relevant legislation.”</p> <p>We have addressed the legislative requirements and environmental standards to be set for this operation in the body of the decision document above. The guidance is clear at paragraph 1.5 that the growth duty does not legitimise non-compliance and its purpose is not to achieve or pursue economic growth at the expense of necessary protections.</p> <p>We consider the requirements and standards we have set in this permit are reasonable and necessary to avoid a risk of an unacceptable level of pollution. This also promotes growth amongst legitimate operators because the standards applied to the operator are consistent across businesses in this sector and have been set to achieve the required legislative standards.</p>