

Environment Agency

Review of an Environmental Permit for an Installation subject to Chapter II of the Industrial Emissions Directive under the Environmental Permitting (England & Wales) Regulations 2016

Decision document recording our decision-making process following review of a permit

The Permit number is: EPR/GP3538SH
The Operator is: Interconnector (UK) Limited
The Installation is: Interconnector Bacton Terminal
This Variation Notice number is: EPR/GP3538SH/V005

What this document is about

Article 21(3) of the Industrial Emissions Directive (IED) requires the Environment Agency to review conditions in permits that it has issued and to ensure that the permit delivers compliance with relevant standards, within four years of the publication of updated decisions on best available techniques (BAT) conclusions.

We have reviewed the permit for this installation against the revised BAT Conclusions for large combustion plant published on 17th August 2017. This is our decision document, which explains the reasoning for the consolidated variation notice that we are issuing.

It explains how we have reviewed and considered the techniques used by the Operator in the operation and control of the plant and activities of the installation. This review has been undertaken with reference to the decision made by the European Commission establishing best available techniques (BAT) conclusions ('BAT Conclusions') for large combustion plant as detailed in document reference IEDC-7-1. It is our record of our decision-making process and shows how we have taken into account all relevant factors in reaching our position. It also provides a justification for the inclusion of any specific conditions in the permit that are in addition to those included in our generic permit template.

As well as considering the review of the operating techniques used by the Operator for the operation of the plant and activities of the installation, the consolidated variation notice takes into account and brings together in a single document all previous variations that relate to the original permit

issued. It also modernises the entire permit to reflect the conditions contained in our current generic permit template.

The introduction of new template conditions makes the Permit consistent with our current general approach and philosophy and with other permits issued to installations in this sector. Although the wording of some conditions has changed, while others have been removed because of the new regulatory approach, it does not reduce the level of environmental protection achieved by the Permit in any way. In this document we therefore address only our determination of substantive issues relating to the new BAT Conclusions.

This is our record of our decision-making process and shows how we have taken into account all relevant factors in reaching our position.

Throughout this document we will use a number of expressions. These are as referred to in the glossary and have the same meaning as described in “Schedule 6 Interpretation” of the Permit.

We try to explain our decision as accurately, comprehensively and plainly as possible. We would welcome any feedback as to how we might improve our decision documents in future. A lot of technical terms and acronyms are inevitable in a document of this nature: we provide a glossary of acronyms near the front of the document, for ease of reference.

How this document is structured

Glossary of terms

- 1 Our decision
- 2 How we reached our decision
- 3 The legal framework
- 4 Key Issues
- 5 Decision checklist regarding relevant BAT Conclusions
- 6 Emissions to Water
- 7 Review and assessment of changes that are not part of the BAT Conclusions derived permit review.

Glossary of acronyms used in this document

(Please note that this glossary is standard for our decision documents and therefore not all these acronyms are necessarily used in this document.)

APC	Air Pollution Control
BAT	Best Available Technique(s)
BAT-AEEL	BAT Associated Energy Efficiency Level
BAT-AEL	BAT Associated Emission Level
BATc	BAT conclusion
BREF	Best available techniques reference document
CCGT	Combined Cycle Gas Turbine
CEM	Continuous emissions monitor
CHP	Combined heat and power
CV	Calorific value
DAA	Directly associated activity – Additional activities necessary to be carried out to allow the principal activity to be carried out
DLN	Dry Low NOx burners
DLN-E	Dry Low NOx effective
EIONET	European environment information and observation network is a partnership network of the European Environment Agency
ELV	Emission limit value derived under BAT or an emission limit value set out in IED
EMS	Environmental Management System
EPR	Environmental Permitting (England and Wales) Regulations 2016 (SI 2016 No. 1154)
EWC	European waste catalogue
FSA	Food Standards Agency
IC	Improvement Condition
IED	Industrial Emissions Directive (2010/75/EU)
IPPCD	Integrated Pollution Prevention and Control Directive (2008/1/EC) – now superseded by IED
LCP	Large Combustion Plant subject to Chapter III of IED
MSUL/MSDL	Minimum start up load/minimum shut-down load
NOx	Oxides of nitrogen (NO plus NO ₂ expressed as NO ₂)
NPV	Net Present Value
OCGT	Open Cycle Gas Turbine
PEMS	Predictive Emissions Monitoring System
PHE	Public Health England
SAC	Special Area of Conservation
SGN	Sector guidance note
TGN	Technical guidance note
TNP	Transitional National Plan
TOC	Total Organic Carbon
WFD	Water Framework Directive (2000/60/EC)

1 Our decision

We have decided to issue the consolidated variation notice to the Operator. This will allow it to continue to operate the Installation, subject to the conditions in the consolidated variation notice.

We consider that, in reaching that decision, we have taken into account all relevant considerations and legal requirements and that the varied permit will ensure that a high level of protection is provided for the environment and human health.

The consolidated variation notice contains many conditions taken from our standard Environmental Permit template including the relevant Annexes. We developed these conditions in consultation with industry, having regard to the legal requirements of the Environmental Permitting Regulations and other relevant legislation. This document does not therefore include an explanation for these standard conditions. Where they are included in the Notice, we have considered the techniques identified by the Operator for the operation of their installation, and have accepted that the details are sufficient and satisfactory to make those standard conditions appropriate. This document does, however, provide an explanation of our use of “tailor-made” or installation-specific conditions, or where our Permit template provides two or more options.

2 How we reached our decision

2.1 Requesting information to demonstrate compliance with BAT Conclusions for Large Combustion Plant

We issued a Notice under Regulation 61(1) of the Environmental Permitting (England and Wales) Regulations 2016 (a Regulation 61 Notice) on 1st May 2018 requiring the Operator to provide information to demonstrate how the operation of their installation currently meets, or will subsequently meet, the revised standards described in the large combustion plant BAT Conclusions document. The Notice also required that where the revised standards are not currently met, the Operator should provide information that:

- Describes the techniques that will be implemented before 17th August 2021, which will then ensure that operations meet the revised standard, or
- Justifies why standards will not be met by 17th August 2021, and confirmation of the date when the operation of those processes will cease within the installation or an explanation of why the revised BAT standard is not applicable to those processes, or
- Justifies why an alternative technique will achieve the same level of environmental protection equivalent to the revised standard described in the BAT Conclusions.

Where the Operator proposed that they were not intending to meet a BAT standard that also included a BAT Associated Emission Level (BAT AEL) described in the BAT Conclusions Document, the Regulation 61 Notice requested that the Operator make a formal request for derogation from compliance with that AEL (as provisioned by Article 15(4) of IED). In this circumstance, the Notice identified that any such request for derogation must be supported and justified by sufficient technical and commercial information that would enable us to determine acceptability of the derogation request.

The Regulation 61 Notice response from the Operator was received on 18/10/2018.

We considered it was in the correct form and contained sufficient information for us to begin our determination of the permit review but not that it necessarily contained all the information we would need to complete that review: we requested additional information and clarification on the initial Regulation 61 Notice response. The Operator provided additional information on 17/03/2020 and 08/04/2020.

The Operator claimed that certain information was commercially confidential and should be withheld from the public register. We considered this request and determined that the document titled 'Vendor Emissions Guarantees for New LM2500+DLE1' attached to the letter received from the Operator, dated 17/03/2020 (subject: 'Interconnector-GP3538SH-LCPD-Additional Information-Rev A1') should be withheld from the public register as the information meets the criteria in Regulation 51(c) (i), (ii) and (iii)

- (i) The information is commercial
- (ii) Its confidentiality is provided by law to protect a legitimate economic interest, and
- (iii) In all the circumstances, the public interest in maintaining the confidentiality of the information outweighs the public interest in including it on the register.

Apart from the issues and information just described, we have not received any information in relation to the Regulation 61 Notice response that appears to be confidential in relation to any party.

2.2 Review of our own information in respect to the capability of the installation to meet revised standards included in the BAT Conclusions document

Based on our records and previous regulatory activities with the facility we have no reason to consider that the Operator will not be able to comply with the conditions that we include in the permit.

3 The legal framework

The consolidated variation notice will be issued under Regulation 20 of the EPR. The Environmental Permitting regime is a legal vehicle which delivers most of the relevant legal requirements for activities falling within its scope. In particular, the regulated facility is:

- an *installation* as described by the IED;
- subject to aspects of other relevant legislation which also have to be addressed.

We consider that the consolidated variation notice will ensure that the operation of the Installation complies with all relevant legal requirements and that a high level of protection will be delivered for the environment and human health.

We explain how we have addressed specific statutory requirements more fully in the rest of this document.

4 The key issues

The key issues arising during this permit review are:

- Emissions to air and the emission limits applied to the plant.
- The energy efficiency levels associated with the Best Available Techniques (BAT-AEELs)
- BAT 3 monitoring of flue gas parameters

We therefore describe how we determined these issues in most detail in the relevant sections of this document.

4.1 Emissions to air and the emission limits applied to the plant

A number of general principles were applied during the permit review. These included:

- The upper value of the BAT AELs ranges specified were used unless use of the tighter limit was justified.
- The principle of no backsliding where if existing limits in the permit were already tighter than those specified in the BREF, the existing permit limits were retained.
- Where a limit was specified in both IED Annex V and the BAT Conclusions for a particular reference period, the tighter limit was applied and in the majority of cases this was from the BAT Conclusions.
- Where AELs are indicative in the BAT Conclusions, these were applied unless adequate justification was provided by the Operator to demonstrate that an alternative limit was more appropriate.

The installation consists of four LCPs (LCP193, LCP194, LCP195 and LCP196). Each LCP on site consists of a 75 MWth natural gas fired gas turbine for provision of mechanical energy to drive the gas compressors.

The plant was put into operation before IED came into force and therefore the existing limits in the permit are from Part 1 of IED Annex V applicable to existing plant.

The ELVs and AELs are based on the following operating regime:

- Unlimited hours operation

For gas turbines, the IED specifies that limits applied over 70% load and the BAT Conclusions specified that AELs applied when dry low NO_x is effective (DLN-E).

In their response to the Regulation 61(1) Notice, the Operator stated that the DLN-E point for the gas turbines installed on site should be set at 75% load, above the 70% load applicable to the IED Annex V emission limits.

The Operator submitted industrial confidential documentation, showing the emission profile of NOx and CO versus the load, as guaranteed by GE, the equipment manufacturer.

We have reviewed the documentation submitted by the Operator in support of the proposed DLN-E point for the mechanical drive gas turbines of LCP193, LCP194, LCP195 and LCP196 and we have accepted that setting this point at 75% load is consistent with the manufacturer specification of the installed gas turbines and the associated commercial guarantees. We have specified the DLN-E point applicable to the gas turbines on site in Table S1.5 of the consolidated variation notice.

The following tables outline the limits that have been incorporated into the permit for LCP193, LCP194, LCP195 and LCP196, where these were derived from and the reference periods at which they apply. The emission limits refer to concentrations, expressed as mass of emitted substance per volume of flue-gas under the following standard conditions: dry gas at a temperature of 273,15 K, pressure of 101,3 kPa and 15% volume reference oxygen concentration if flue gases. The emission limits and monitoring requirements have been incorporated into Schedule 3 of the permit.

Since we have specified the applicable BAT AELs from the LCP BAT Conclusion to apply above 75% load, we have also retained the relevant IED Annex V Part I emission limits applicable to the same reference periods for loads above 70%.

This results therefore in having three daily limits for NOx specified in the permit (see tables below):

- Daily limit applicable from DLN-E point (75%) to base load, from the LCP BAT conclusions and BREF
- Daily limit applicable from 70% to base load, from the IED
- Daily limit applicable from MSUL/MSDL to base load, specified during the IED Chapter III review of the permit, and retained from the existing permit.

NOx limits (mg/Nm ³)						
Averaging	IED (Annex V Part 1) - Existing	BREF (Table 24 BAT-c)	Expected permit limits	Basis	Limits apply	Monitoring
Annual	None	60 ^{Note 1}	60	BREF	DLN-E point (75%) to base load	Continuous (PEMS) ^{Note 3}
Monthly	75	None	75 ^{Note 4}	IED	70% to base load	
Daily	82.5	65 ^{Note 1}	65	BREF	DLN-E point (75%) to base load	
			82.5	IED and current permit	70% to base load	

			90 ^{Note 2}	Current permit	MSUL/MSDL to base load	
95 th %ile of hr means	150	None	150 ^{Note 4}	IED	70% to base load	

Note 1: As an existing OCGT Mechanical Drive plant put into operation no later than 7 January 2014, footnotes 14 and 15 to Table 24 of the BAT Conclusions apply, these footnote specify the applicable BAT-AELs.
Note 2: Daily part load limit (MSUL/MSDL to base load) is retained from the current permit.
Note 3: Periodic (6 monthly) monitoring is retained from existing permit for validation of predictive monitoring.
Note 4: The current permit only sets daily limits with periodic monitoring. In the consolidated variation notice we have specified continuous predictive monitoring from 17 August 2021 in line with the requirements of the LCP BAT conclusions. Yearly, monthly, daily and hourly reference periods will apply.

Averaging	IED (Annex V Part 1) - Existing	BREF	Expected permit limits	Basis	Limits apply	Monitoring
Annual	None	40	40	BREF	DLN-E point (75%) to base load	Continuous (PEMS) ^{Note 2}
Monthly	100	None	100 ^{Note 3}	IED	70% to base load	
Daily	110	None	110	IED and current permit	70% to base load	
			80 ^{Note 1}	Current permit	MSUL/MSDL to base load	
95 th %ile of hr means	200	None	200 ^{Note 3}	IED	70% to base load	

Note 1: Part load limit (MSUL/MSDL to base load) is retained from the current permit.
Note 2: Periodic (6 monthly) monitoring is retained from existing permit for validation of predictive monitoring.
Note 3: The current permit only sets daily limits with periodic monitoring. In the consolidated variation notice we have specified continuous predictive monitoring from 17 August 2021 in line with the requirements of the LCP BAT conclusions. Yearly, monthly, daily and hourly reference periods will apply.

4.2 The energy efficiency levels associated with the Best Available Techniques Conclusions

An energy efficiency level associated with the best available techniques (BAT-AEEL) refers to the ratio between the combustion unit's net energy output(s) and the combustion unit's fuel/feedstock energy input at actual unit design. The net energy output(s) is determined at the combustion unit boundaries, including auxiliary systems (e.g. flue-gas treatment systems), and for the unit operated at full load.

The table below sets out the BAT-AEELs specified in the LCP BAT Conclusions for the large combustion plant on the site and the energy efficiency levels confirmed through the Regulation 61 notice response.

The information provided by the Operator to demonstrate that the AEELs are met was in the form of the reported mechanical efficiency values continuously predicted by PEMS installed on site for each LCP in the year 2019, according to thermodynamic calculations.

We consider this plant is BAT in relation to the AEELs.

BAT AEELs (%)			Plant efficiency (%)		
Net electrical efficiency	Net total fuel utilisation	Net mechanical efficiency	Net electrical efficiency	Net total fuel utilisation	Net mechanical efficiency
LCP 193: Open cycle gas turbine, ≥ 50 MWth, Existing unit, Mechanical Drive					
NA	NA	33.5 - 41	NA	NA	42.1
LCP 194: Open cycle gas turbine, ≥ 50 MWth, Existing unit, Mechanical Drive					
NA	NA	33.5 - 41	NA	NA	38.9
LCP 195: Open cycle gas turbine, ≥ 50 MWth, Existing unit, Mechanical Drive					
NA	NA	33.5 - 41	NA	NA	38.8
LCP 196: Open cycle gas turbine, ≥ 50 MWth, Existing unit, Mechanical Drive					
NA	NA	33.5 - 41	NA	NA	40.6

4.3 Monitoring of flue gas pressure

BAT conclusion 3 requires that the following process parameters are measured / determined for the flue gas emitted from the LCPs:

Stream	Parameter(s)	Monitoring
Flue-gas	Flow	Periodic or continuous determination
	Oxygen content, temperature, and pressure	Periodic or continuous measurement
	Water vapour content ⁽¹⁾	
(1) The continuous measurement of the water vapour content of the flue-gas is not necessary if the sampled flue-gas is dried before analysis.		

In response to a request for additional information on the initial Regulation 61(1) response, the Operator confirmed that in LCP193, LCP194, LCP195 and LCP196 all the relevant flue gas parameters are measured / determined, except pressure.

The Operator provided the following justification for not undertaking pressure measurement:

Flue gas pressure is not used in the PEMS stack flow determination and its measurement would present an unnecessary safety risk. Pressure is not measured by installed field devices in a location representative of the sample plane. The sample ports are located in a hazardous area (Zone 2 for methane). Periodic monitoring of pressure to validate the PEMS baselines

would introduce physical safety hazards; the sample port is accessible by working at height from the cab roof, on which there are a number of very hot unlagged pipes adjacent to the work area and which has limited headroom for access owing to a ventilator duct around it; this is why stack emissions have been routed to ground level for conditioning and analysis at a location that is not suitable for pressure determination.

We have accepted the justification provided by the Operator for not monitoring pressure of flue gases, based on safety reasons.

We are satisfied that, even if the pressure of the flue gas is not measured, the proposed monitoring schedule for flue gas parameters will achieve the same level of environmental protection equivalent to the revised standard described in this BAT conclusion.

We are satisfied that the installation is compliant with BAT conclusion 3 for the other flue gas parameters.

Since we have accepted the Operator's justification, we have not specified a requirement for flue gas pressure monitoring in the consolidated variation notice.

5 Decision checklist regarding relevant BAT Conclusions

BAT Conclusions for large combustion plant, were published by the European Commission on 17th August 2017. There are 75 BAT Conclusions. Only the BAT Conclusions relevant to the particular fuel type used on site have been replicated below.

This annex provides a record of decisions made in relation to each relevant BAT Conclusion applicable to the installation. This annex should be read in conjunction with the Consolidated Variation Notice.

The conditions in the permit through which the relevant BAT Conclusions are implemented include but are not limited to the following:

BAT Conclusion requirement topic	Permit condition(s)	Permit table(s)
Environmental Management System	1.1.1	S1.2
BAT AELs	3.1.1 and 3.5.1	S3.1a
Monitoring	2.3, 3.5 and 3.6	S1.4, S1.5, S1.2, S3.1a
Energy efficiency	1.2 and 2.3	S3.3
Noise	3.4 and 2.3	S1.2
Other operating techniques	2.3	S1.2

The overall status of compliance with the BAT conclusion is indicated in the table as:

- NA Not Applicable
- CC Currently Compliant
- FC Compliant in the future (within 4 years of publication of BAT conclusions)
- NC Not Compliant
- PC Partially Compliant

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the Operator to demonstrate compliance with the BAT Conclusion requirement
General			
1	<p>In order to improve the overall environmental performance, BAT is to implement and adhere to an environmental management system (EMS) that incorporates all of the following features:</p> <ul style="list-style-type: none"> i. commitment of the management, including senior management; ii. definition of an environmental policy that includes the continuous improvement of the installation by the management; iii. planning and establishing the necessary procedures, objectives and targets, in conjunction with financial planning and investment; iv. implementation of procedures <ul style="list-style-type: none"> (a) Structure and responsibility (b) Training (c) Communication (d) Employee involvement (e) Documentation (f) Efficient process control (g) Maintenance programmes (h) Emergency preparedness and response (i) Safeguarding compliance with environmental legislation v. checking performance and taking corrective action, paying particular attention to: <ul style="list-style-type: none"> (a) monitoring and measurement (see also the Reference Document on the General Principles of Monitoring) (b) corrective and preventive action (c) maintenance of records (d) independent (where practicable) internal and external auditing in order to determine whether or not the EMS conforms to planned arrangements and has been properly implemented and maintained; vi. review of the EMS and its continuing suitability, adequacy and effectiveness by senior management; vii. following the development of cleaner technologies; viii. consideration for the environmental impacts from the eventual decommissioning of the installation at the stage of designing a new plant, and throughout its operating life; viii. consideration for the environmental impacts from the eventual decommissioning of the installation at the stage of designing a new plant, and throughout its operating life; ix. application of sectoral benchmarking on a regular basis. <p>Etc - see BAT Conclusions</p>	CC	<p>The Operator has confirmed that the site operates according to an EMS designed to be compliant with (but not certified to BS EN ISO 14001 : 2004) and that this EMS meets requirements (i) through to (xvi) set out in the BAT Conclusion.</p> <p>We are satisfied that the installation is compliant with this BAT conclusion.</p>

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the Operator to demonstrate compliance with the BAT Conclusion requirement
	<p>Applicability. The scope (e.g. level of detail) and nature of the EMS (e.g. standardised or non-standardised) will generally be related to the nature, scale and complexity of the installation, and the range of environmental impacts it may have.</p>		
2	<p>BAT is to determine the net electrical efficiency and/or the net total fuel utilisation and/or the net mechanical energy efficiency of the gasification, IGCC and/or combustion units by carrying out a performance test at full load (1), according to EN standards, after the commissioning of the unit and after each modification that could significantly affect the net electrical efficiency and/or the net total fuel utilisation and/or the net mechanical energy efficiency of the unit. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.</p>	CC	<p>The Operator confirmed that the mechanical efficiency was originally performance tested in 1999.</p> <p>The performance tested in accordance with ASME PTC-10. Also, a condition monitoring system called Alert purchased from and maintenance contracted to DNV-GL, is in continuous operation to monitor fuel gas consumption and efficiency.</p> <p>We are satisfied that the installation is compliant with this BAT conclusion and that the standard utilised for the initial performance test of the mechanical drive gas turbines (ASME standard) is an international standard that ensures the provision of data of an equivalent scientific quality to EN standards.</p> <p>In Table S3.3 of the variation and consolidation notice, we have specified that the Operator shall determine the net mechanical energy efficiency of the mechanical drive gas turbines, using EN standards or equivalent,</p>

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the Operator to demonstrate compliance with the BAT Conclusion requirement													
			after each modification that could significantly affect these parameters.													
3	<p>BAT is to monitor key process parameters relevant for emissions to air and water including those given below.</p> <table border="1" data-bbox="349 539 1509 715"> <thead> <tr> <th data-bbox="349 539 712 576">Stream</th> <th data-bbox="716 539 1140 576">Parameter(s)</th> <th data-bbox="1144 539 1509 576">Monitoring</th> </tr> </thead> <tbody> <tr> <td data-bbox="349 579 712 679" rowspan="3">Flue-gas</td> <td data-bbox="716 579 1140 608">Flow</td> <td data-bbox="1144 579 1509 608">Periodic or continuous determination</td> </tr> <tr> <td data-bbox="716 611 1140 639">Oxygen content, temperature, and pressure</td> <td data-bbox="1144 611 1509 639">Periodic or continuous measurement</td> </tr> <tr> <td data-bbox="716 643 1140 679">Water vapour content (%)</td> <td data-bbox="1144 643 1509 679"></td> </tr> <tr> <td data-bbox="349 683 712 715">Waste water from flue-gas treatment</td> <td data-bbox="716 683 1140 715">Flow, pH, and temperature</td> <td data-bbox="1144 683 1509 715">Continuous measurement</td> </tr> </tbody> </table>	Stream	Parameter(s)	Monitoring	Flue-gas	Flow	Periodic or continuous determination	Oxygen content, temperature, and pressure	Periodic or continuous measurement	Water vapour content (%)		Waste water from flue-gas treatment	Flow, pH, and temperature	Continuous measurement	PC	<p>In response to a request for additional information on the initial Regulation 61(1) response, the Operator confirmed the following:</p> <ul style="list-style-type: none"> - Oxygen is periodically monitored with MCERTS standards as appropriate for referencing concentrations of periodically monitored emission parameters. Also, the PEMS predicts oxygen content in % volume based upon periodic measurement referenced baseline; - Flue gas temperature is continuously measured; - The dry oxygen referenced flue gas flow rate is continuously determined by the PEMS according to a proprietary calculation based upon fuel mass flowrate converted from mass to normal volume flow rate using a flue gas density calculation; - Emission samples are tested dry, therefore water monitoring is not required; - Pressure of flue gas is not measured and the Operator provided a justification, that
Stream	Parameter(s)	Monitoring														
Flue-gas	Flow	Periodic or continuous determination														
	Oxygen content, temperature, and pressure	Periodic or continuous measurement														
	Water vapour content (%)															
Waste water from flue-gas treatment	Flow, pH, and temperature	Continuous measurement														

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the Operator to demonstrate compliance with the BAT Conclusion requirement																		
			<p>we consider satisfactory. Refer to section 4.3 for details.</p> <p>We are satisfied that the proposed monitoring schedule for flue gas parameters will achieve the same level of environmental protection equivalent to the revised standard described in this BAT conclusion.</p>																		
4	<p>BAT is to monitor emissions to air with at least the frequency given below and in accordance with EN standards. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.</p> <table border="1" data-bbox="349 788 1509 1385"> <thead> <tr> <th data-bbox="349 788 501 906">Substance/Parameter</th> <th data-bbox="506 788 815 906">Fuel/Process/Type of combustion plant</th> <th data-bbox="819 788 967 906">Combustion plant total rated thermal input</th> <th data-bbox="972 788 1146 906">Standard(s) ⁽⁴⁾</th> <th data-bbox="1151 788 1361 906">Minimum monitoring frequency ⁽⁵⁾</th> <th data-bbox="1366 788 1509 906">Monitoring associated with</th> </tr> </thead> <tbody> <tr> <td data-bbox="349 909 501 970">NH₃</td> <td data-bbox="506 909 815 970">— When SCR and/or SNCR is used</td> <td data-bbox="819 909 967 970">All sizes</td> <td data-bbox="972 909 1146 970">Generic EN standards</td> <td data-bbox="1151 909 1361 970">Continuous ⁽⁶⁾ ⁽⁷⁾</td> <td data-bbox="1366 909 1509 970">BAT 7</td> </tr> <tr> <td data-bbox="349 973 501 1382">NO_x</td> <td data-bbox="506 973 815 1382"> <ul style="list-style-type: none"> — Coal and/or lignite including waste co-incineration — Solid biomass and/or peat including waste co-incineration — HFO- and/or gas-oil-fired boilers and engines — Gas-oil-fired gas turbines — Natural-gas-fired boilers, engines, and turbines — Iron and steel process gases — Process fuels from the chemical industry </td> <td data-bbox="819 973 967 1382">All sizes</td> <td data-bbox="972 973 1146 1382">Generic EN standards</td> <td data-bbox="1151 973 1361 1382">Continuous ⁽⁶⁾ ⁽⁸⁾</td> <td data-bbox="1366 973 1509 1382"> BAT 20 BAT 24 BAT 28 BAT 32 BAT 37 BAT 41 BAT 42 BAT 43 BAT 47 BAT 48 BAT 56 BAT 64 BAT 65 BAT 73 </td> </tr> </tbody> </table>	Substance/Parameter	Fuel/Process/Type of combustion plant	Combustion plant total rated thermal input	Standard(s) ⁽⁴⁾	Minimum monitoring frequency ⁽⁵⁾	Monitoring associated with	NH ₃	— When SCR and/or SNCR is used	All sizes	Generic EN standards	Continuous ⁽⁶⁾ ⁽⁷⁾	BAT 7	NO _x	<ul style="list-style-type: none"> — Coal and/or lignite including waste co-incineration — Solid biomass and/or peat including waste co-incineration — HFO- and/or gas-oil-fired boilers and engines — Gas-oil-fired gas turbines — Natural-gas-fired boilers, engines, and turbines — Iron and steel process gases — Process fuels from the chemical industry 	All sizes	Generic EN standards	Continuous ⁽⁶⁾ ⁽⁸⁾	BAT 20 BAT 24 BAT 28 BAT 32 BAT 37 BAT 41 BAT 42 BAT 43 BAT 47 BAT 48 BAT 56 BAT 64 BAT 65 BAT 73	CC	<p>The Operator has installed a predictive emissions monitoring system (PEMS) and proposed that this system is used to comply with BAT4.</p> <p>The PEMS (DNV Alert) predicts NO_x and CO emissions hourly, daily, monthly and yearly. The PEMS predictions are based on model baselines that are updated after combustor performance adjustment (mapping) and periodic emissions testing. The model includes primary and secondary adjustment based upon compressor delivery and flame temperatures respectively.</p> <p>Since the LCPs at the installation are existing OCGT, we are satisfied that the proposed use of PEMS for NO_x and CO monitoring meets the requirement</p>
Substance/Parameter	Fuel/Process/Type of combustion plant	Combustion plant total rated thermal input	Standard(s) ⁽⁴⁾	Minimum monitoring frequency ⁽⁵⁾	Monitoring associated with																
NH ₃	— When SCR and/or SNCR is used	All sizes	Generic EN standards	Continuous ⁽⁶⁾ ⁽⁷⁾	BAT 7																
NO _x	<ul style="list-style-type: none"> — Coal and/or lignite including waste co-incineration — Solid biomass and/or peat including waste co-incineration — HFO- and/or gas-oil-fired boilers and engines — Gas-oil-fired gas turbines — Natural-gas-fired boilers, engines, and turbines — Iron and steel process gases — Process fuels from the chemical industry 	All sizes	Generic EN standards	Continuous ⁽⁶⁾ ⁽⁸⁾	BAT 20 BAT 24 BAT 28 BAT 32 BAT 37 BAT 41 BAT 42 BAT 43 BAT 47 BAT 48 BAT 56 BAT 64 BAT 65 BAT 73																

BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the Operator to demonstrate compliance with the BAT Conclusion requirement
	<ul style="list-style-type: none"> — IGCC plants 							<p>of BAT conclusion 4 (note 5 to BAT conclusion 4). We have specified monitoring of NOx and CO with the PEMS, along with their periodic monitoring with MCERT standards, in table S3.1a of the revised permit.</p>
	<ul style="list-style-type: none"> — Combustion plants on offshore platforms 	All sizes	EN 14792	Once every year ⁽⁹⁾	BAT 53			
N ₂ O	<ul style="list-style-type: none"> — Coal and/or lignite in circulating fluidised bed boilers — Solid biomass and/or peat in circulating fluidised bed boilers 	All sizes	EN 21258	Once every year ⁽¹⁰⁾	BAT 20 BAT 24			
CO	<ul style="list-style-type: none"> — Coal and/or lignite including waste co-incineration — Solid biomass and/or peat including waste co-incineration — HFO- and/or gas-oil-fired boilers and engines — Gas-oil-fired gas turbines — Natural-gas-fired boilers, engines, and turbines — Iron and steel process gases — Process fuels from the chemical industry — IGCC plants 	All sizes	Generic EN standards	Continuous ⁽⁶⁾ ⁽⁸⁾	BAT 20 BAT 24 BAT 28 BAT 33 BAT 38 BAT 44 BAT 49 BAT 56 BAT 64 BAT 65 BAT 73			
	<ul style="list-style-type: none"> — Combustion plants on offshore platforms 	All sizes	EN 15058	Once every year ⁽⁹⁾	BAT 54			
SO ₂	<ul style="list-style-type: none"> — Coal and/or lignite incl waste co-incineration — Solid biomass and/or peat incl waste co-incineration — HFO- and/or gas-oil-fired boilers 	All sizes	Generic EN standards and EN 14791	Continuous ⁽⁶⁾ ⁽¹¹⁾ ⁽¹²⁾	BAT 21 BAT 25 BAT 29 BAT 34 BAT 39 BAT 50 BAT 57 BAT 66 BAT 67			

BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the Operator to demonstrate compliance with the BAT Conclusion requirement
	<ul style="list-style-type: none"> — HFO- and/or gas-oil-fired engines — Gas-oil-fired gas turbines — Iron and steel process gases — Process fuels from the chemical industry in boilers — IGCC plants 					BAT 74		
SO ₃	<ul style="list-style-type: none"> — When SCR is used 	All sizes	No EN standard available	Once every year	—			
Gaseous chlorides, expressed as HCl	<ul style="list-style-type: none"> — Coal and/or lignite — Process fuels from the chemical industry in boilers 	All sizes	EN 1911	Once every three months ⁽⁶⁾ ⁽¹³⁾ ⁽¹⁴⁾	BAT 21 BAT 57			
	<ul style="list-style-type: none"> — Solid biomass and/or peat 	All sizes	Generic EN standards	Continuous ⁽¹⁵⁾ ⁽¹⁶⁾	BAT 25			
	<ul style="list-style-type: none"> — Waste co-incineration 	All sizes	Generic EN standards	Continuous ⁽⁶⁾ ⁽¹⁶⁾	BAT 66 BAT 67			
HF	<ul style="list-style-type: none"> — Coal and/or lignite — Process fuels from the chemical industry in boilers 	All sizes	No EN standard available	Once every three months ⁽⁶⁾ ⁽¹³⁾ ⁽¹⁴⁾	BAT 21 BAT 57			
	<ul style="list-style-type: none"> — Solid biomass and/or peat 	All sizes	No EN standard available	Once every year	BAT 25			
	<ul style="list-style-type: none"> — Waste co-incineration 	All sizes	Generic EN standards	Continuous ⁽⁶⁾ ⁽¹⁶⁾	BAT 66 BAT 67			
Dust	<ul style="list-style-type: none"> — Coal and/or lignite — Solid biomass and/or peat — HFO- and/or gas-oil-fired boilers — Iron and steel process gases 	All sizes	Generic EN standards and EN 13284-1 and EN 13284-2	Continuous ⁽⁶⁾ ⁽¹⁷⁾	BAT 22 BAT 26 BAT 30 BAT 35 BAT 39 BAT 51 BAT 58 BAT 75			

BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the Operator to demonstrate compliance with the BAT Conclusion requirement
		<ul style="list-style-type: none"> — Process fuels from the chemical industry in boilers — IGCC plants — HFO- and/or gas-oil-fired engines — Gas-oil-fired gas turbines 						
		— Waste co-incineration	All sizes	Generic EN standards and EN 13284-2	Continuous	BAT 68 BAT 69		
Metals and metalloids except mercury (As, Cd, Co, Cr, Cu, Mn, Ni, Pb, Sb, Se, Ti, V, Zn)		<ul style="list-style-type: none"> — Coal and/or lignite — Solid biomass and/or peat — HFO- and/or gas-oil-fired boilers and engines 	All sizes	EN 14385	Once every year ₍₁₈₎	BAT 22 BAT 26 BAT 30		
		— Waste co-incineration	< 300 MW _{th}	EN 14385	Once every six months ₍₁₃₎	BAT 68 BAT 69		
			≥ 300 MW _{th}	EN 14385	Once every three months ₍₁₉₎ ₍₁₃₎			
		— IGCC plants	≥ 100 MW _{th}	EN 14385	Once every year ₍₁₈₎	BAT 75		
Hg		<ul style="list-style-type: none"> — Coal and/or lignite including waste co-incineration 	< 300 MW _{th}	EN 13211	Once every three months ₍₁₃₎ ₍₂₀₎	BAT 23		
			≥ 300 MW _{th}	Generic EN standards and EN 14884	Continuous ₍₁₆₎ ₍₂₁₎			
		— Solid biomass and/or peat	All sizes	EN 13211	Once every year ₍₂₂₎	BAT 27		
		— Waste co-incineration with solid biomass and/or peat	All sizes	EN 13211	Once every three months ₍₁₃₎	BAT 70		
		— IGCC plants	≥ 100 MW _{th}	EN 13211	Once every year ₍₂₃₎	BAT 75		
TVOC		<ul style="list-style-type: none"> — HFO- and/or gas-oil-fired engines — Process fuels from chemical industry in boilers 	All sizes	EN 12619	Once every six months ₍₁₃₎	BAT 33 BAT 59		

BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the Operator to demonstrate compliance with the BAT Conclusion requirement
		— Waste co-incineration with coal, lignite, solid biomass and/or peat	All sizes	Generic EN standards	Continuous	BAT 71		
	Formaldehyde	— Natural-gas in spark-ignited lean-burn gas and dual fuel engines	All sizes	No EN standard available	Once every year	BAT 45		
	CH ₄	— Natural-gas-fired engines	All sizes	EN ISO 25139	Once every year ⁽²⁴⁾	BAT 45		
	PCDD/F	— Process fuels from chemical industry in boilers — Waste co-incineration	All sizes	EN 1948-1, EN 1948-2, EN 1948-3	Once every six months ⁽¹³⁾ ⁽²⁵⁾	BAT 59 BAT 71		
5	BAT is to monitor emissions to water from flue-gas treatment with at least the frequency given below and in accordance with EN standards. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.						NA	NOT APPLICABLE. There are no emissions to water from flue-gas treatment.
	Substance/Parameter	Standard(s)	Minimum monitoring frequency	Monitoring associated with				
Total organic carbon (TOC) ⁽²⁶⁾	EN 1484		Once every month	BAT 15				
Chemical oxygen demand (COD) ⁽²⁶⁾	No EN standard available							
Total suspended solids (TSS)	EN 872							
Fluoride (F ⁻)	EN ISO 10304-1							
Sulphate (SO ₄ ²⁻)	EN ISO 10304-1							
Sulphide, easily released (S ²⁻)	No EN standard available							
Sulphite (SO ₃ ²⁻)	EN ISO 10304-3							
Metals and metalloids	As	Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)						
	Cd							
	Cr							
	Cu							
	Ni							

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the Operator to demonstrate compliance with the BAT Conclusion requirement																									
	<table border="1"> <tr> <td data-bbox="362 389 622 544"></td> <td data-bbox="624 389 689 416">Pb</td> <td data-bbox="692 389 1046 544"></td> <td data-bbox="1048 389 1279 544"></td> <td data-bbox="1281 389 1503 544"></td> </tr> <tr> <td data-bbox="362 418 622 461"></td> <td data-bbox="624 418 689 445">Zn</td> <td data-bbox="692 418 1046 461"></td> <td data-bbox="1048 418 1279 461"></td> <td data-bbox="1281 418 1503 461"></td> </tr> <tr> <td data-bbox="362 462 622 544"></td> <td data-bbox="624 462 689 489">Hg</td> <td data-bbox="692 462 1046 544">Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)</td> <td data-bbox="1048 462 1279 544"></td> <td data-bbox="1281 462 1503 544"></td> </tr> <tr> <td data-bbox="362 545 622 627">Chloride (Cl⁻)</td> <td data-bbox="624 545 689 627"></td> <td data-bbox="692 545 1046 627">Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)</td> <td data-bbox="1048 545 1279 627"></td> <td data-bbox="1281 545 1503 627">—</td> </tr> <tr> <td data-bbox="362 628 622 662">Total nitrogen</td> <td data-bbox="624 628 689 662"></td> <td data-bbox="692 628 1046 662">EN 12260</td> <td data-bbox="1048 628 1279 662"></td> <td data-bbox="1281 628 1503 662">—</td> </tr> </table>		Pb					Zn					Hg	Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)			Chloride (Cl ⁻)		Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)		—	Total nitrogen		EN 12260		—		
	Pb																											
	Zn																											
	Hg	Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)																										
Chloride (Cl ⁻)		Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)		—																								
Total nitrogen		EN 12260		—																								
6	<p>In order to improve the general environmental performance of combustion plants and to reduce emissions to air of CO and unburnt substances, BAT is to ensure optimised combustion and to use an appropriate combination of the techniques given below.</p> <table border="1"> <thead> <tr> <th data-bbox="362 778 584 805">Technique</th> <th data-bbox="586 778 1010 805">Description</th> <th data-bbox="1012 778 1503 805">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="362 807 584 895">a. Fuel blending and mixing</td> <td data-bbox="586 807 1010 895">Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type</td> <td data-bbox="1012 807 1503 895">Generally applicable</td> </tr> <tr> <td data-bbox="362 896 584 984">b. Maintenance of the combustion system</td> <td data-bbox="586 896 1010 984">Regular planned maintenance according to suppliers' recommendations</td> <td data-bbox="1012 896 1503 984"></td> </tr> <tr> <td data-bbox="362 986 584 1074">c. Advanced control system</td> <td data-bbox="586 986 1010 1074">See description in Section 8.1</td> <td data-bbox="1012 986 1503 1074">The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> <tr> <td data-bbox="362 1075 584 1163">d. Good design of the combustion equipment</td> <td data-bbox="586 1075 1010 1163">Good design of furnace, combustion chambers, burners and associated devices</td> <td data-bbox="1012 1075 1503 1163">Generally applicable to new combustion plants</td> </tr> <tr> <td data-bbox="362 1165 584 1332">e. Fuel choice</td> <td data-bbox="586 1165 1010 1332">Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used</td> <td data-bbox="1012 1165 1503 1332">Applicable within the constraints associated with the availability of suitable types of fuel with a better environmental profile as a whole, which may be impacted by the energy policy of the Member State, or by the integrated site's fuel balance in the case of combustion of industrial process fuels.</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Fuel blending and mixing	Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type	Generally applicable	b. Maintenance of the combustion system	Regular planned maintenance according to suppliers' recommendations		c. Advanced control system	See description in Section 8.1	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system	d. Good design of the combustion equipment	Good design of furnace, combustion chambers, burners and associated devices	Generally applicable to new combustion plants	e. Fuel choice	Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used	Applicable within the constraints associated with the availability of suitable types of fuel with a better environmental profile as a whole, which may be impacted by the energy policy of the Member State, or by the integrated site's fuel balance in the case of combustion of industrial process fuels.	CC	<p>The Operator confirmed that all the techniques a. to e. inclusive are implemented at the installation. For a: the fuel gas is homogenous and application specific pre-mixers are used for air and gas blending prior to combustion.</p> <p>For b: SAP is used to schedule maintenance for 50kh, 25kh and interim servicing and appropriate manufacturer product development bulletins are implemented. For c: a DLE advanced control system is used.</p> <p>For d: the combustor type is designed to accommodate minimisation of NOx and maximisation of performance notably component life and reliability through modal burner configurations.</p> <p>For e: natural gas is the single fuel and is supplied in accordance with a stringent transport gas</p>							
Technique	Description	Applicability																										
a. Fuel blending and mixing	Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type	Generally applicable																										
b. Maintenance of the combustion system	Regular planned maintenance according to suppliers' recommendations																											
c. Advanced control system	See description in Section 8.1	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system																										
d. Good design of the combustion equipment	Good design of furnace, combustion chambers, burners and associated devices	Generally applicable to new combustion plants																										
e. Fuel choice	Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used	Applicable within the constraints associated with the availability of suitable types of fuel with a better environmental profile as a whole, which may be impacted by the energy policy of the Member State, or by the integrated site's fuel balance in the case of combustion of industrial process fuels.																										

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the Operator to demonstrate compliance with the BAT Conclusion requirement			
	<table border="1" data-bbox="360 392 1503 475"> <tr> <td data-bbox="360 392 394 475"></td> <td data-bbox="398 392 584 475"></td> <td data-bbox="589 392 1503 475">For existing combustion plants, the type of fuel chosen may be limited by the configuration and the design of the plant</td> </tr> </table>			For existing combustion plants, the type of fuel chosen may be limited by the configuration and the design of the plant		<p>quality specification which includes low sulphur content. Alternative dual fuel options are either insufficiently clean or have higher emissions factors. Hydrogen fuel is under consideration by the gas industry as a whole but infrastructure for this is insufficiently developed at this time.</p> <p>We are satisfied that the installation is compliant with this BAT conclusion.</p>
		For existing combustion plants, the type of fuel chosen may be limited by the configuration and the design of the plant				
7	<p>In order to reduce emissions of ammonia to air from the use of selective catalytic reduction (SCR) and/or selective non-catalytic reduction (SNCR) for the abatement of NO_x emissions, BAT is to optimise the design and/or operation of SCR and/or SNCR (e.g. optimised reagent to NO_x ratio, homogeneous reagent distribution and optimum size of the reagent drops).</p> <p>BAT-associated emission levels</p> <p>The BAT-associated emission level (BAT-AEL) for emissions of NH₃ to air from the use of SCR and/or SNCR is < 3–10 mg/Nm³ as a yearly average or average over the sampling period. The lower end of the range can be achieved when using SCR and the upper end of the range can be achieved when using SNCR without wet abatement techniques. In the case of plants combusting biomass and operating at variable loads as well as in the case of engines combusting HFO and/or gas oil, the higher end of the BAT-AEL range is 15 mg/Nm³.</p>	NA	<p>NOT APPLICABLE. There are no emissions of ammonia to air by design, as there are no SCR/SNCR systems installed. We agree with the Operator.</p>			
8	<p>In order to prevent or reduce emissions to air during normal operating conditions, BAT is to ensure, by appropriate design, operation and maintenance, that the emission abatement systems are used at optimal capacity and availability.</p>	CC	<p>The Operator confirmed that the PEMS is expected to highlight when mechanical performance deteriorates such that its predictions become invalid. Periodic monitoring is carried out to the permit schedule. Spot checks are carried out if mechanical performance is in question. Equipment not</p>			

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the Operator to demonstrate compliance with the BAT Conclusion requirement										
			<p>performing to the required standard is selected for maintenance and operational priorities changed.</p> <p>We agree with the compliance status stated by the Operator.</p>										
9	<p>In order to improve the general environmental performance of combustion and/or gasification plants and to reduce emissions to air, BAT is to include the following elements in the quality assurance/quality control programmes for all the fuels used, as part of the environmental management system (see BAT 1):</p> <ul style="list-style-type: none"> (i) Initial full characterisation of the fuel used including at least the parameters listed below and in accordance with EN standards. ISO, national or other international standards may be used provided they ensure the provision of data of an equivalent scientific quality; (ii) Regular testing of the fuel quality to check that it is consistent with the initial characterisation and according to the plant design specifications. The frequency of testing and the parameters chosen from the table below are based on the variability of the fuel and an assessment of the relevance of pollutant releases (e.g. concentration in fuel, flue-gas treatment employed); (iii) Subsequent adjustment of the plant settings as and when needed and practicable (e.g. integration of the fuel characterisation and control in the advanced control system (see description in Section 8.1)). <p>Description Initial characterisation and regular testing of the fuel can be performed by the Operator and/or the fuel supplier. If performed by the supplier, the full results are provided to the Operator in the form of a product (fuel) supplier specification and/or guarantee.</p> <table border="1" data-bbox="349 1046 1507 1369"> <thead> <tr> <th data-bbox="349 1046 736 1082">Fuel(s)</th> <th data-bbox="739 1046 1507 1082">Substances/Parameters subject to characterisation</th> </tr> </thead> <tbody> <tr> <td data-bbox="349 1083 736 1286" rowspan="4">Biomass/peat</td> <td data-bbox="739 1083 1507 1118">— LHV</td> </tr> <tr> <td data-bbox="739 1120 1507 1155">— moisture</td> </tr> <tr> <td data-bbox="739 1157 1507 1192">— Ash</td> </tr> <tr> <td data-bbox="739 1193 1507 1228">— C, Cl, F, N, S, K, Na</td> </tr> <tr> <td data-bbox="349 1287 736 1369" rowspan="2">Coal/lignite</td> <td data-bbox="739 1287 1507 1323">— LHV</td> </tr> <tr> <td data-bbox="739 1324 1507 1369">— Moisture</td> </tr> </tbody> </table>	Fuel(s)	Substances/Parameters subject to characterisation	Biomass/peat	— LHV	— moisture	— Ash	— C, Cl, F, N, S, K, Na	Coal/lignite	— LHV	— Moisture	CC	<p>The installation uses natural gas as a fuel.</p> <p>We consider that, for plants which burn natural gas from the National Grid as a fuel, that the requirements of this BAT are met and it is not necessary for the Operator to replicate the testing carried out by the National Grid.</p> <p>We agree with the compliance status stated by the Operator.</p>
Fuel(s)	Substances/Parameters subject to characterisation												
Biomass/peat	— LHV												
	— moisture												
	— Ash												
	— C, Cl, F, N, S, K, Na												
Coal/lignite	— LHV												
	— Moisture												

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the Operator to demonstrate compliance with the BAT Conclusion requirement																		
	<table border="1"> <tr> <td data-bbox="349 384 734 523"></td> <td data-bbox="739 384 1507 427">— Volatiles, ash, fixed carbon, C, H, N, O, S</td> </tr> <tr> <td data-bbox="349 430 734 474"></td> <td data-bbox="739 430 1507 474">— Br, Cl, F</td> </tr> <tr> <td data-bbox="349 477 734 520"></td> <td data-bbox="739 477 1507 520">— Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)</td> </tr> <tr> <td data-bbox="349 523 734 608">HFO</td> <td data-bbox="739 523 1507 608">— Ash — C, S, N, Ni, V</td> </tr> <tr> <td data-bbox="349 611 734 695">Gas oil</td> <td data-bbox="739 611 1507 695">— Ash — N, C, S</td> </tr> <tr> <td data-bbox="349 699 734 783">Natural gas</td> <td data-bbox="739 699 1507 783">— LHV — CH₄, C₂H₆, C₃, C₄₊, CO₂, N₂, Wobbe index</td> </tr> <tr> <td data-bbox="349 786 734 871">Process fuels from the chemical industry^[27]</td> <td data-bbox="739 786 1507 871">— Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)</td> </tr> <tr> <td data-bbox="349 874 734 927">Iron and steel process gases</td> <td data-bbox="739 874 1507 927">— LHV, CH₄ (for COG), C_xH_y (for COG), CO₂, H₂, N₂, total sulphur, dust, Wobbe index</td> </tr> <tr> <td data-bbox="349 930 734 1086">Waste^[28]</td> <td data-bbox="739 930 1507 1086">— LHV — Moisture — Volatiles, ash, Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)</td> </tr> </table>		— Volatiles, ash, fixed carbon, C, H, N, O, S		— Br, Cl, F		— Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)	HFO	— Ash — C, S, N, Ni, V	Gas oil	— Ash — N, C, S	Natural gas	— LHV — CH ₄ , C ₂ H ₆ , C ₃ , C ₄₊ , CO ₂ , N ₂ , Wobbe index	Process fuels from the chemical industry ^[27]	— Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)	Iron and steel process gases	— LHV, CH ₄ (for COG), C _x H _y (for COG), CO ₂ , H ₂ , N ₂ , total sulphur, dust, Wobbe index	Waste ^[28]	— LHV — Moisture — Volatiles, ash, Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)		
	— Volatiles, ash, fixed carbon, C, H, N, O, S																				
	— Br, Cl, F																				
	— Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)																				
HFO	— Ash — C, S, N, Ni, V																				
Gas oil	— Ash — N, C, S																				
Natural gas	— LHV — CH ₄ , C ₂ H ₆ , C ₃ , C ₄₊ , CO ₂ , N ₂ , Wobbe index																				
Process fuels from the chemical industry ^[27]	— Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)																				
Iron and steel process gases	— LHV, CH ₄ (for COG), C _x H _y (for COG), CO ₂ , H ₂ , N ₂ , total sulphur, dust, Wobbe index																				
Waste ^[28]	— LHV — Moisture — Volatiles, ash, Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)																				
10	<p>In order to reduce emissions to air and/or to water during other than normal operating conditions (OTNOC), BAT is to set up and implement a management plan as part of the environmental management system (see BAT 1), commensurate with the relevance of potential pollutant releases, that includes the following elements:</p> <ul style="list-style-type: none"> — appropriate design of the systems considered relevant in causing OTNOC that may have an impact on emissions to air, water and/or soil (e.g. low-load design concepts for reducing the minimum start-up and shutdown loads for stable generation in gas turbines), — set-up and implementation of a specific preventive maintenance plan for these relevant systems, — review and recording of emissions caused by OTNOC and associated circumstances and implementation of corrective actions if necessary, 	CC	<p>The Operator confirmed that they implement the four elements of this BAT conclusion. In particular:</p> <ul style="list-style-type: none"> - Startup and test cycles are minimised through operational selection. - Startup and shutdown sequences are checked annually for expected levels and significant 																		

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the Operator to demonstrate compliance with the BAT Conclusion requirement
	<p>— periodic assessment of the overall emissions during OTNOC (e.g. frequency of events, duration, emissions quantification/estimation) and implementation of corrective actions if necessary.</p>		<p>deviations/defects are in addressed the task scheduling system.</p> <ul style="list-style-type: none"> - Low load conditions are also mapped by the manufacturer. Low load operating is time recorded and limited. <p>We agree with the compliance status stated by the Operator.</p>
11	<p>BAT is to appropriately monitor emissions to air and/or to water during OTNOC.</p> <p>Description</p> <p>The monitoring can be carried out by direct measurement of emissions or by monitoring of surrogate parameters if this proves to be of equal or better scientific quality than the direct measurement of emissions. Emissions during start-up and shutdown (SU/SD) may be assessed based on a detailed emission measurement carried out for a typical SU/SD procedure at least once every year, and using the results of this measurement to estimate the emissions for each and every SU/SD throughout the year.</p>	CC	<p>The Operator confirmed that, as part of their compliance strategy to this BAT conclusion, operating times in low load conditions are recorded in Alert (the PEMS) and are used to estimate annually reported emissions from expected emissions levels validated during mapping exercises and opportunistic spot emissions test. We agree with the compliance status stated by the Operator. We have specified reporting of operating hours in 'BC mode', in table S4.3 of the consolidated variation notice. 'BC mode' is the lowest stable operating condition for the operation of the mechanical drive gas turbines below the MSUL/MSDL points, corresponding to the operation of mixing nozzles (burners) banks B and C as described in the original application documents.</p>
12	<p>In order to increase the energy efficiency of combustion, gasification and/or IGCC units operated $\geq 1\,500$ h/yr, BAT is to use an appropriate combination of the techniques given below.</p>	CC	<p>The Operator confirmed they use a combination of techniques that</p>

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the Operator to demonstrate compliance with the BAT Conclusion requirement																																					
	<table border="1"> <thead> <tr> <th data-bbox="349 384 394 416"></th> <th data-bbox="400 384 600 416">Technique</th> <th data-bbox="607 384 1070 416">Description</th> <th data-bbox="1077 384 1507 416">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="349 421 394 528">a.</td> <td data-bbox="400 421 600 528">Combustion optimisation</td> <td data-bbox="607 421 1070 528">See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues</td> <td data-bbox="1077 421 1507 528" rowspan="4">Generally applicable</td> </tr> <tr> <td data-bbox="349 533 394 660">b.</td> <td data-bbox="400 533 600 660">Optimisation of the working medium conditions</td> <td data-bbox="607 533 1070 660">Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO_x emissions or the characteristics of energy demanded</td> </tr> <tr> <td data-bbox="349 665 394 772">c.</td> <td data-bbox="400 665 600 772">Optimisation of the steam cycle</td> <td data-bbox="607 665 1070 772">Operate with lower turbine exhaust pressure by utilisation of the lowest possible temperature of the condenser cooling water, within the design conditions</td> </tr> <tr> <td data-bbox="349 777 394 831">d.</td> <td data-bbox="400 777 600 831">Minimisation of energy consumption</td> <td data-bbox="607 777 1070 831">Minimising the internal energy consumption (e.g. greater efficiency of the feed-water pump)</td> </tr> <tr> <td data-bbox="349 836 394 911">e.</td> <td data-bbox="400 836 600 911">Preheating of combustion air</td> <td data-bbox="607 836 1070 911">Reuse of part of the heat recovered from the combustion flue-gas to preheat the air used in combustion</td> <td data-bbox="1077 836 1507 911">Generally applicable within the constraints related to the need to control NO_x emissions</td> </tr> <tr> <td data-bbox="349 916 394 991">f.</td> <td data-bbox="400 916 600 991">Fuel preheating</td> <td data-bbox="607 916 1070 991">Preheating of fuel using recovered heat</td> <td data-bbox="1077 916 1507 991">Generally applicable within the constraints associated with the boiler design and the need to control NO_x emissions</td> </tr> <tr> <td data-bbox="349 995 394 1102">g.</td> <td data-bbox="400 995 600 1102">Advanced control system</td> <td data-bbox="607 995 1070 1102">See description in Section 8.2. Computerised control of the main combustion parameters enables the combustion efficiency to be improved</td> <td data-bbox="1077 995 1507 1102">Generally applicable to new units. The applicability to old units may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> <tr> <td data-bbox="349 1107 394 1262">h.</td> <td data-bbox="400 1107 600 1262">Feed-water preheating using recovered heat</td> <td data-bbox="607 1107 1070 1262">Preheat water coming out of the steam condenser with recovered heat, before reusing it in the boiler</td> <td data-bbox="1077 1107 1507 1262">Only applicable to steam circuits and not to hot boilers. Applicability to existing units may be limited due to constraints associated with the plant configuration and the amount of recoverable heat</td> </tr> <tr> <td data-bbox="349 1267 394 1342">i.</td> <td data-bbox="400 1267 600 1342">Heat recovery by cogeneration (CHP)</td> <td data-bbox="607 1267 1070 1342">Recovery of heat (mainly from the steam system) for producing hot water/steam to be used in industrial processes/activities or in a</td> <td data-bbox="1077 1267 1507 1342">Applicable within the constraints associated with the local heat and power demand.</td> </tr> </tbody> </table>				Technique	Description	Applicability	a.	Combustion optimisation	See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues	Generally applicable	b.	Optimisation of the working medium conditions	Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO _x emissions or the characteristics of energy demanded	c.	Optimisation of the steam cycle	Operate with lower turbine exhaust pressure by utilisation of the lowest possible temperature of the condenser cooling water, within the design conditions	d.	Minimisation of energy consumption	Minimising the internal energy consumption (e.g. greater efficiency of the feed-water pump)	e.	Preheating of combustion air	Reuse of part of the heat recovered from the combustion flue-gas to preheat the air used in combustion	Generally applicable within the constraints related to the need to control NO _x emissions	f.	Fuel preheating	Preheating of fuel using recovered heat	Generally applicable within the constraints associated with the boiler design and the need to control NO _x emissions	g.	Advanced control system	See description in Section 8.2. Computerised control of the main combustion parameters enables the combustion efficiency to be improved	Generally applicable to new units. The applicability to old units may be constrained by the need to retrofit the combustion system and/or control command system	h.	Feed-water preheating using recovered heat	Preheat water coming out of the steam condenser with recovered heat, before reusing it in the boiler	Only applicable to steam circuits and not to hot boilers. Applicability to existing units may be limited due to constraints associated with the plant configuration and the amount of recoverable heat	i.	Heat recovery by cogeneration (CHP)	Recovery of heat (mainly from the steam system) for producing hot water/steam to be used in industrial processes/activities or in a	Applicable within the constraints associated with the local heat and power demand.		include techniques a., b., d. and f. Technique o. is not applied but there is a fuel gas specification which includes impurity, water and hydrocarbon dew point limits. We consider that the installation implements an appropriate combination of energy efficiency techniques specified by this BAT conclusion.
	Technique	Description	Applicability																																							
a.	Combustion optimisation	See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues	Generally applicable																																							
b.	Optimisation of the working medium conditions	Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO _x emissions or the characteristics of energy demanded																																								
c.	Optimisation of the steam cycle	Operate with lower turbine exhaust pressure by utilisation of the lowest possible temperature of the condenser cooling water, within the design conditions																																								
d.	Minimisation of energy consumption	Minimising the internal energy consumption (e.g. greater efficiency of the feed-water pump)																																								
e.	Preheating of combustion air	Reuse of part of the heat recovered from the combustion flue-gas to preheat the air used in combustion	Generally applicable within the constraints related to the need to control NO _x emissions																																							
f.	Fuel preheating	Preheating of fuel using recovered heat	Generally applicable within the constraints associated with the boiler design and the need to control NO _x emissions																																							
g.	Advanced control system	See description in Section 8.2. Computerised control of the main combustion parameters enables the combustion efficiency to be improved	Generally applicable to new units. The applicability to old units may be constrained by the need to retrofit the combustion system and/or control command system																																							
h.	Feed-water preheating using recovered heat	Preheat water coming out of the steam condenser with recovered heat, before reusing it in the boiler	Only applicable to steam circuits and not to hot boilers. Applicability to existing units may be limited due to constraints associated with the plant configuration and the amount of recoverable heat																																							
i.	Heat recovery by cogeneration (CHP)	Recovery of heat (mainly from the steam system) for producing hot water/steam to be used in industrial processes/activities or in a	Applicable within the constraints associated with the local heat and power demand.																																							

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the Operator to demonstrate compliance with the BAT Conclusion requirement	
			public network for district heating. Additional heat recovery is possible from: <ul style="list-style-type: none"> — flue-gas — grate cooling — circulating fluidised bed 	The applicability may be limited in the case of gas compressors with an unpredictable operational heat profile		
	j.	CHP readiness	See description in Section 8.2.	Only applicable to new units where there is a realistic potential for the future use of heat in the vicinity of the unit		
	k.	Flue-gas condenser	See description in Section 8.2.	Generally applicable to CHP units provided there is enough demand for low-temperature heat		
	l.	Heat accumulation	Heat accumulation storage in CHP mode	Only applicable to CHP plants. The applicability may be limited in the case of low heat load demand		
	m.	Wet stack	See description in Section 8.2.	Generally applicable to new and existing units fitted with wet FGD		
	n.	Cooling tower discharge	The release of emissions to air through a cooling tower and not via a dedicated stack	Only applicable to units fitted with wet FGD where reheating of the flue-gas is necessary before release, and where the unit cooling system is a cooling tower		
	o.	Fuel pre-drying	The reduction of fuel moisture content before combustion to improve combustion conditions	Applicable to the combustion of biomass and/or peat within the constraints associated with spontaneous combustion risks (e.g. the moisture content of peat is kept above 40 % throughout the delivery chain). The retrofit of existing plants may be restricted by the extra calorific value that can be obtained from the drying operation and by the limited retrofit possibilities offered by some boiler designs or plant configurations		
	p.	Minimisation of heat losses	Minimising residual heat losses, e.g. those that occur via the slag or those that can be reduced by insulating radiating sources	Only applicable to solid-fuel-fired combustion units and to gasification/IGCC units		

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the Operator to demonstrate compliance with the BAT Conclusion requirement									
	q.	Advanced materials	Use of advanced materials proven to be capable of withstanding high operating temperatures and pressures and thus to achieve increased steam/combustion process efficiencies	Only applicable to new plants										
	r.	Steam turbine upgrades	This includes techniques such as increasing the temperature and pressure of medium-pressure steam, addition of a low-pressure turbine, and modifications to the geometry of the turbine rotor blades	The applicability may be restricted by demand, steam conditions and/or limited plant lifetime										
	s.	Supercritical and ultra-supercritical steam conditions	Use of a steam circuit, including steam reheating systems, in which steam can reach pressures above 220,6 bar and temperatures above 374 °C in the case of supercritical conditions, and above 250 – 300 bar and temperatures above 580 – 600 °C in the case of ultra-supercritical conditions	Only applicable to new units of $\geq 600 \text{ MW}_{\text{th}}$ operated $> 4\,000 \text{ h/yr}$. Not applicable when the purpose of the unit is to produce low steam temperatures and/or pressures in process industries. Not applicable to gas turbines and engines generating steam in CHP mode. For units combusting biomass, the applicability may be constrained by high-temperature corrosion in the case of certain biomasses										
13	In order to reduce water usage and the volume of contaminated waste water discharged, BAT is to use one or both of the techniques given below.			NA	The Operator responded that they consider that this BAT conclusion is not applicable to the installation because there is no process water used other than the demineralised water for engine washing. The engine washing effluent is contaminated with oil. It is captured in a hazardous drain for off-site waste treatment and disposal. It is not commercially viable to clean contaminated wash water to the standard required to meet the manufacturers process cleaning water quality specification.									
	<table border="1"> <thead> <tr> <th data-bbox="347 983 551 1011">Technique</th> <th data-bbox="555 983 1084 1011">Description</th> <th data-bbox="1088 983 1509 1011">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="347 1015 551 1149">a. Water recycling</td> <td data-bbox="555 1015 1084 1149">Residual aqueous streams, including run-off water, from the plant are reused for other purposes. The degree of recycling is limited by the quality requirements of the recipient water stream and the water balance of the plant</td> <td data-bbox="1088 1015 1509 1149">Not applicable to waste water from cooling systems when water treatment chemicals and/or high concentrations of salts from seawater are present</td> </tr> <tr> <td data-bbox="347 1152 551 1283">b. Dry bottom ash handling</td> <td data-bbox="555 1152 1084 1283">Dry, hot bottom ash falls from the furnace onto a mechanical conveyor system and is cooled down by ambient air. No water is used in the process.</td> <td data-bbox="1088 1152 1509 1283">Only applicable to plants combusting solid fuels. There may be technical restrictions that prevent retrofitting to existing combustion plants</td> </tr> </tbody> </table>			Technique	Description	Applicability	a. Water recycling	Residual aqueous streams, including run-off water, from the plant are reused for other purposes. The degree of recycling is limited by the quality requirements of the recipient water stream and the water balance of the plant	Not applicable to waste water from cooling systems when water treatment chemicals and/or high concentrations of salts from seawater are present	b. Dry bottom ash handling	Dry, hot bottom ash falls from the furnace onto a mechanical conveyor system and is cooled down by ambient air. No water is used in the process.	Only applicable to plants combusting solid fuels. There may be technical restrictions that prevent retrofitting to existing combustion plants		
Technique	Description	Applicability												
a. Water recycling	Residual aqueous streams, including run-off water, from the plant are reused for other purposes. The degree of recycling is limited by the quality requirements of the recipient water stream and the water balance of the plant	Not applicable to waste water from cooling systems when water treatment chemicals and/or high concentrations of salts from seawater are present												
b. Dry bottom ash handling	Dry, hot bottom ash falls from the furnace onto a mechanical conveyor system and is cooled down by ambient air. No water is used in the process.	Only applicable to plants combusting solid fuels. There may be technical restrictions that prevent retrofitting to existing combustion plants												

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the Operator to demonstrate compliance with the BAT Conclusion requirement
			Having taken into account the water demand of the installation, we agree with the Operator response and we consider that this BAT conclusion is not applicable because there is only very limited use of water in the process and there is no reasonable scope for its reuse within the installation.
14	<p>In order to prevent the contamination of uncontaminated waste water and to reduce emissions to water, BAT is to segregate waste water streams and to treat them separately, depending on the pollutant content.</p> <p>Description Waste water streams that are typically segregated and treated include surface run-off water, cooling water, and waste water from flue-gas treatment.</p> <p>Applicability The applicability may be restricted in the case of existing plants due to the configuration of the drainage systems.</p>	CC	<p>The Operator responded that the only source of process waste water is the engine washing effluent, which is contaminated with oil. This stream is collected in a hazardous drain for off-site waste treatment and disposal.</p> <p>Rainwater from the Compressor House building is segregated and passes through an Oily-Water Separator (oil interceptor) before exiting the site to local watercourse and thereafter the sea.</p> <p>We consider that the segregation of waste water implemented at the site, is compliant with the requirements of this BAT conclusion.</p>
15	In order to reduce emissions to water from flue-gas treatment, BAT is to use an appropriate combination of the techniques given below, and to use secondary techniques as close as possible to the source in order to avoid dilution.	NA	NOT APPLICABLE. There are no emissions to water from flue-gas treatment.

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the Operator to demonstrate compliance with the BAT Conclusion requirement																																																			
	<table border="1"> <thead> <tr> <th data-bbox="347 384 734 443">Technique</th> <th data-bbox="739 384 1041 443">Typical pollutants prevented/abated</th> <th data-bbox="1046 384 1509 443">Applicability</th> </tr> </thead> <tbody> <tr> <td colspan="3" data-bbox="347 446 1509 475" style="text-align: center;">Primary techniques</td> </tr> <tr> <td data-bbox="347 478 734 587">a. Optimised combustion (see BAT 6) and flue-gas treatment systems (e.g. SCR/SNCR, see BAT 7)</td> <td data-bbox="739 478 1041 587">Organic compounds, ammonia (NH₃)</td> <td data-bbox="1046 478 1509 587">Generally applicable</td> </tr> <tr> <td colspan="3" data-bbox="347 590 1509 619" style="text-align: center;">Secondary techniques⁽²⁹⁾</td> </tr> <tr> <td data-bbox="347 622 734 683">b. Adsorption on activated carbon</td> <td data-bbox="739 622 1041 683">Organic compounds, mercury (Hg)</td> <td data-bbox="1046 622 1509 683">Generally applicable</td> </tr> <tr> <td data-bbox="347 686 734 817">c. Aerobic biological treatment</td> <td data-bbox="739 686 1041 817">Biodegradable organic compounds, ammonium (NH₄⁺)</td> <td data-bbox="1046 686 1509 817">Generally applicable for the treatment of organic compounds. Aerobic biological treatment of ammonium (NH₄⁺) may not be applicable in the case of high chloride concentrations (i.e. around 10 g/l)</td> </tr> <tr> <td data-bbox="347 820 734 880">d. Anoxic/anaerobic biological treatment</td> <td data-bbox="739 820 1041 880">Mercury (Hg), nitrate (NO₃⁻), nitrite (NO₂⁻)</td> <td data-bbox="1046 820 1509 880">Generally applicable</td> </tr> <tr> <td data-bbox="347 884 734 912">e. Coagulation and flocculation</td> <td data-bbox="739 884 1041 912">Suspended solids</td> <td data-bbox="1046 884 1509 912">Generally applicable</td> </tr> <tr> <td data-bbox="347 916 734 976">f. Crystallisation</td> <td data-bbox="739 916 1041 976">Metals and metalloids, sulphate (SO₄²⁻), fluoride (F⁻)</td> <td data-bbox="1046 916 1509 976">Generally applicable</td> </tr> <tr> <td data-bbox="347 979 734 1040">g. Filtration (e.g. sand filtration, microfiltration, ultrafiltration)</td> <td data-bbox="739 979 1041 1040">Suspended solids, metals</td> <td data-bbox="1046 979 1509 1040">Generally applicable</td> </tr> <tr> <td data-bbox="347 1043 734 1072">h. Flotation</td> <td data-bbox="739 1043 1041 1072">Suspended solids, free oil</td> <td data-bbox="1046 1043 1509 1072">Generally applicable</td> </tr> <tr> <td data-bbox="347 1075 734 1104">i. Ion exchange</td> <td data-bbox="739 1075 1041 1104">Metals</td> <td data-bbox="1046 1075 1509 1104">Generally applicable</td> </tr> <tr> <td data-bbox="347 1107 734 1136">j. Neutralisation</td> <td data-bbox="739 1107 1041 1136">Acids, alkalis</td> <td data-bbox="1046 1107 1509 1136">Generally applicable</td> </tr> <tr> <td data-bbox="347 1139 734 1168">k. Oxidation</td> <td data-bbox="739 1139 1041 1168">Sulphide (S²⁻), sulphite (SO₃²⁻)</td> <td data-bbox="1046 1139 1509 1168">Generally applicable</td> </tr> <tr> <td data-bbox="347 1171 734 1232">l. Precipitation</td> <td data-bbox="739 1171 1041 1232">Metals and metalloids, sulphate (SO₄²⁻), fluoride (F⁻)</td> <td data-bbox="1046 1171 1509 1232">Generally applicable</td> </tr> <tr> <td data-bbox="347 1235 734 1264">m. Sedimentation</td> <td data-bbox="739 1235 1041 1264">Suspended solids</td> <td data-bbox="1046 1235 1509 1264">Generally applicable</td> </tr> <tr> <td data-bbox="347 1267 734 1295">n. Stripping</td> <td data-bbox="739 1267 1041 1295">Ammonia (NH₃)</td> <td data-bbox="1046 1267 1509 1295">Generally applicable</td> </tr> </tbody> </table> <p data-bbox="347 1299 1509 1353">The BAT-AELs refer to direct discharges to a receiving water body at the point where the emission leaves the installation.</p> <p data-bbox="347 1356 1509 1382" style="text-align: center;">BAT-AELs for direct discharges to a receiving water body from flue-gas treatment</p>			Technique	Typical pollutants prevented/abated	Applicability	Primary techniques			a. Optimised combustion (see BAT 6) and flue-gas treatment systems (e.g. SCR/SNCR, see BAT 7)	Organic compounds, ammonia (NH ₃)	Generally applicable	Secondary techniques⁽²⁹⁾			b. Adsorption on activated carbon	Organic compounds, mercury (Hg)	Generally applicable	c. Aerobic biological treatment	Biodegradable organic compounds, ammonium (NH ₄ ⁺)	Generally applicable for the treatment of organic compounds. Aerobic biological treatment of ammonium (NH ₄ ⁺) may not be applicable in the case of high chloride concentrations (i.e. around 10 g/l)	d. Anoxic/anaerobic biological treatment	Mercury (Hg), nitrate (NO ₃ ⁻), nitrite (NO ₂ ⁻)	Generally applicable	e. Coagulation and flocculation	Suspended solids	Generally applicable	f. Crystallisation	Metals and metalloids, sulphate (SO ₄ ²⁻), fluoride (F ⁻)	Generally applicable	g. Filtration (e.g. sand filtration, microfiltration, ultrafiltration)	Suspended solids, metals	Generally applicable	h. Flotation	Suspended solids, free oil	Generally applicable	i. Ion exchange	Metals	Generally applicable	j. Neutralisation	Acids, alkalis	Generally applicable	k. Oxidation	Sulphide (S ²⁻), sulphite (SO ₃ ²⁻)	Generally applicable	l. Precipitation	Metals and metalloids, sulphate (SO ₄ ²⁻), fluoride (F ⁻)	Generally applicable	m. Sedimentation	Suspended solids	Generally applicable	n. Stripping	Ammonia (NH ₃)	Generally applicable		
Technique	Typical pollutants prevented/abated	Applicability																																																						
Primary techniques																																																								
a. Optimised combustion (see BAT 6) and flue-gas treatment systems (e.g. SCR/SNCR, see BAT 7)	Organic compounds, ammonia (NH ₃)	Generally applicable																																																						
Secondary techniques⁽²⁹⁾																																																								
b. Adsorption on activated carbon	Organic compounds, mercury (Hg)	Generally applicable																																																						
c. Aerobic biological treatment	Biodegradable organic compounds, ammonium (NH ₄ ⁺)	Generally applicable for the treatment of organic compounds. Aerobic biological treatment of ammonium (NH ₄ ⁺) may not be applicable in the case of high chloride concentrations (i.e. around 10 g/l)																																																						
d. Anoxic/anaerobic biological treatment	Mercury (Hg), nitrate (NO ₃ ⁻), nitrite (NO ₂ ⁻)	Generally applicable																																																						
e. Coagulation and flocculation	Suspended solids	Generally applicable																																																						
f. Crystallisation	Metals and metalloids, sulphate (SO ₄ ²⁻), fluoride (F ⁻)	Generally applicable																																																						
g. Filtration (e.g. sand filtration, microfiltration, ultrafiltration)	Suspended solids, metals	Generally applicable																																																						
h. Flotation	Suspended solids, free oil	Generally applicable																																																						
i. Ion exchange	Metals	Generally applicable																																																						
j. Neutralisation	Acids, alkalis	Generally applicable																																																						
k. Oxidation	Sulphide (S ²⁻), sulphite (SO ₃ ²⁻)	Generally applicable																																																						
l. Precipitation	Metals and metalloids, sulphate (SO ₄ ²⁻), fluoride (F ⁻)	Generally applicable																																																						
m. Sedimentation	Suspended solids	Generally applicable																																																						
n. Stripping	Ammonia (NH ₃)	Generally applicable																																																						

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the Operator to demonstrate compliance with the BAT Conclusion requirement																																												
	<table border="1"> <thead> <tr> <th colspan="2" data-bbox="349 384 999 421">Substance/Parameter</th> <th data-bbox="1001 384 1509 421">BAT-AELs</th> </tr> <tr> <th colspan="2"></th> <th data-bbox="1001 422 1509 459">Daily average</th> </tr> </thead> <tbody> <tr> <td colspan="2" data-bbox="349 461 999 491">Total organic carbon (TOC)</td> <td data-bbox="1001 461 1509 491">20–50 mg/l ₍₃₀₎ ₍₃₁₎ ₍₃₂₎</td> </tr> <tr> <td colspan="2" data-bbox="349 493 999 523">Chemical oxygen demand (COD)</td> <td data-bbox="1001 493 1509 523">60–150 mg/l ₍₃₀₎ ₍₃₁₎ ₍₃₂₎</td> </tr> <tr> <td colspan="2" data-bbox="349 525 999 555">Total suspended solids (TSS)</td> <td data-bbox="1001 525 1509 555">10–30 mg/l</td> </tr> <tr> <td colspan="2" data-bbox="349 557 999 587">Fluoride (F⁻)</td> <td data-bbox="1001 557 1509 587">10–25 mg/l ₍₃₂₎</td> </tr> <tr> <td colspan="2" data-bbox="349 588 999 619">Sulphate (SO₄²⁻)</td> <td data-bbox="1001 588 1509 619">1,3–2,0 g/l ₍₃₂₎ ₍₃₃₎ ₍₃₄₎ ₍₃₅₎</td> </tr> <tr> <td colspan="2" data-bbox="349 620 999 651">Sulphide (S²⁻), easily released</td> <td data-bbox="1001 620 1509 651">0,1–0,2 mg/l ₍₃₂₎</td> </tr> <tr> <td colspan="2" data-bbox="349 652 999 683">Sulphite (SO₃²⁻)</td> <td data-bbox="1001 652 1509 683">1–20 mg/l ₍₃₂₎</td> </tr> <tr> <td data-bbox="349 684 896 976" rowspan="8">Metals and metalloids</td> <td data-bbox="898 684 999 715">As</td> <td data-bbox="1001 684 1509 715">10–50 µg/l</td> </tr> <tr> <td data-bbox="898 716 999 746">Cd</td> <td data-bbox="1001 716 1509 746">2–5 µg/l</td> </tr> <tr> <td data-bbox="898 748 999 778">Cr</td> <td data-bbox="1001 748 1509 778">10–50 µg/l</td> </tr> <tr> <td data-bbox="898 780 999 810">Cu</td> <td data-bbox="1001 780 1509 810">10–50 µg/l</td> </tr> <tr> <td data-bbox="898 812 999 842">Hg</td> <td data-bbox="1001 812 1509 842">0,2–3 µg/l</td> </tr> <tr> <td data-bbox="898 844 999 874">Ni</td> <td data-bbox="1001 844 1509 874">10–50 µg/l</td> </tr> <tr> <td data-bbox="898 876 999 906">Pb</td> <td data-bbox="1001 876 1509 906">10–20 µg/l</td> </tr> <tr> <td data-bbox="898 908 999 938">Zn</td> <td data-bbox="1001 908 1509 938">50–200 µg/l</td> </tr> </tbody> </table>	Substance/Parameter		BAT-AELs			Daily average	Total organic carbon (TOC)		20–50 mg/l ₍₃₀₎ ₍₃₁₎ ₍₃₂₎	Chemical oxygen demand (COD)		60–150 mg/l ₍₃₀₎ ₍₃₁₎ ₍₃₂₎	Total suspended solids (TSS)		10–30 mg/l	Fluoride (F ⁻)		10–25 mg/l ₍₃₂₎	Sulphate (SO ₄ ²⁻)		1,3–2,0 g/l ₍₃₂₎ ₍₃₃₎ ₍₃₄₎ ₍₃₅₎	Sulphide (S ²⁻), easily released		0,1–0,2 mg/l ₍₃₂₎	Sulphite (SO ₃ ²⁻)		1–20 mg/l ₍₃₂₎	Metals and metalloids	As	10–50 µg/l	Cd	2–5 µg/l	Cr	10–50 µg/l	Cu	10–50 µg/l	Hg	0,2–3 µg/l	Ni	10–50 µg/l	Pb	10–20 µg/l	Zn	50–200 µg/l		
Substance/Parameter		BAT-AELs																																													
		Daily average																																													
Total organic carbon (TOC)		20–50 mg/l ₍₃₀₎ ₍₃₁₎ ₍₃₂₎																																													
Chemical oxygen demand (COD)		60–150 mg/l ₍₃₀₎ ₍₃₁₎ ₍₃₂₎																																													
Total suspended solids (TSS)		10–30 mg/l																																													
Fluoride (F ⁻)		10–25 mg/l ₍₃₂₎																																													
Sulphate (SO ₄ ²⁻)		1,3–2,0 g/l ₍₃₂₎ ₍₃₃₎ ₍₃₄₎ ₍₃₅₎																																													
Sulphide (S ²⁻), easily released		0,1–0,2 mg/l ₍₃₂₎																																													
Sulphite (SO ₃ ²⁻)		1–20 mg/l ₍₃₂₎																																													
Metals and metalloids	As	10–50 µg/l																																													
	Cd	2–5 µg/l																																													
	Cr	10–50 µg/l																																													
	Cu	10–50 µg/l																																													
	Hg	0,2–3 µg/l																																													
	Ni	10–50 µg/l																																													
	Pb	10–20 µg/l																																													
	Zn	50–200 µg/l																																													
16	<p>In order to reduce the quantity of waste sent for disposal from the combustion and/or gasification process and abatement techniques, BAT is to organise operations so as to maximise, in order of priority and taking into account life-cycle thinking:</p> <ul style="list-style-type: none"> (a) waste prevention, e.g. maximise the proportion of residues which arise as by-products; (b) waste preparation for reuse, e.g. according to the specific requested quality criteria; (c) waste recycling; (d) other waste recovery (e.g. energy recovery), <p>by implementing an appropriate combination of techniques such as:</p> <table border="1"> <thead> <tr> <th data-bbox="349 1265 595 1295">Technique</th> <th data-bbox="598 1265 1099 1295">Description</th> <th data-bbox="1102 1265 1509 1295">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="349 1297 595 1377">a. Generation of gypsum as a by-product</td> <td data-bbox="598 1297 1099 1377">Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g.</td> <td data-bbox="1102 1297 1509 1377">Generally applicable within the constraints associated with the required gypsum quality, the health requirements</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Generation of gypsum as a by-product	Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g.	Generally applicable within the constraints associated with the required gypsum quality, the health requirements	NA	NOT APPLICABLE. There are no emissions to water from flue-gas treatment.																																						
Technique	Description	Applicability																																													
a. Generation of gypsum as a by-product	Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g.	Generally applicable within the constraints associated with the required gypsum quality, the health requirements																																													

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the Operator to demonstrate compliance with the BAT Conclusion requirement													
			as raw material in the plasterboard industry). The quality of limestone used in the wet FGD influences the purity of the gypsum produced	associated to each specific use, and by the market conditions														
	b.	Recycling or recovery of residues in the construction sector	Recycling or recovery of residues (e.g. from semi-dry desulphurisation processes, fly ash, bottom ash) as a construction material (e.g. in road building, to replace sand in concrete production, or in the cement industry)	Generally applicable within the constraints associated with the required material quality (e.g. physical properties, content of harmful substances) associated to each specific use, and by the market conditions														
	c.	Energy recovery by using waste in the fuel mix	The residual energy content of carbon-rich ash and sludges generated by the combustion of coal, lignite, heavy fuel oil, peat or biomass can be recovered for example by mixing with the fuel	Generally applicable where plants can accept waste in the fuel mix and are technically able to feed the fuels into the combustion chamber														
	d.	Preparation of spent catalyst for reuse	Preparation of catalyst for reuse (e.g. up to four times for SCR catalysts) restores some or all of the original performance, extending the service life of the catalyst to several decades. Preparation of spent catalyst for reuse is integrated in a catalyst management scheme	The applicability may be limited by the mechanical condition of the catalyst and the required performance with respect to controlling NO _x and NH ₃ emissions														
17	In order to reduce noise emissions, BAT is to use one or a combination of the techniques given below.			CC	<p>The Operator has confirmed that they consider that an adequate combination of BAT 17 techniques, including techniques a., c., d. and e. are implemented at the installation.</p> <p>We agree with the compliance status stated by the Operator.</p>													
	<table border="1"> <thead> <tr> <th data-bbox="349 938 387 973"></th> <th data-bbox="392 938 600 973">Technique</th> <th data-bbox="604 938 1099 973">Description</th> <th data-bbox="1104 938 1518 973">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="349 976 387 1289">a.</td> <td data-bbox="392 976 600 1289">Operational measures</td> <td data-bbox="604 976 1099 1289"> These include: <ul style="list-style-type: none"> — improved inspection and maintenance of equipment — closing of doors and windows of enclosed areas, if possible — equipment operated by experienced staff — avoidance of noisy activities at night, if possible — provisions for noise control during maintenance activities </td> <td data-bbox="1104 976 1518 1289">Generally applicable</td> </tr> <tr> <td data-bbox="349 1292 387 1353">b.</td> <td data-bbox="392 1292 600 1353">Low-noise equipment</td> <td data-bbox="604 1292 1099 1353">This potentially includes compressors, pumps and disks</td> <td data-bbox="1104 1292 1518 1353">Generally applicable when the equipment is new or replaced</td> </tr> </tbody> </table>		Technique			Description	Applicability	a.	Operational measures	These include: <ul style="list-style-type: none"> — improved inspection and maintenance of equipment — closing of doors and windows of enclosed areas, if possible — equipment operated by experienced staff — avoidance of noisy activities at night, if possible — provisions for noise control during maintenance activities 	Generally applicable	b.	Low-noise equipment	This potentially includes compressors, pumps and disks	Generally applicable when the equipment is new or replaced			
	Technique	Description	Applicability															
a.	Operational measures	These include: <ul style="list-style-type: none"> — improved inspection and maintenance of equipment — closing of doors and windows of enclosed areas, if possible — equipment operated by experienced staff — avoidance of noisy activities at night, if possible — provisions for noise control during maintenance activities 	Generally applicable															
b.	Low-noise equipment	This potentially includes compressors, pumps and disks	Generally applicable when the equipment is new or replaced															

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the Operator to demonstrate compliance with the BAT Conclusion requirement																				
	c. Noise attenuation	Noise propagation can be reduced by inserting obstacles between the emitter and the receiver. Appropriate obstacles include protection walls, embankments and buildings	Generally applicable to new plants. In the case of existing plants, the insertion of obstacles may be restricted by lack of space																						
	d. Noise-control equipment	This includes: — noise-reducers — equipment insulation — enclosure of noisy equipment — soundproofing of buildings	The applicability may be restricted by lack of space																						
	e. Appropriate location of equipment and buildings	Noise levels can be reduced by increasing the distance between the emitter and the receiver and by using buildings as noise screens	Generally applicable to new plant																						
Combustion of gaseous fuels																									
40	In order to increase the energy efficiency of natural gas combustion, BAT is to use an appropriate combination of the techniques given in BAT 12 and below.			CC	<p>BAT 12 a., b., d. and f. are implemented.</p> <p>We consider that the use of combined cycle is not applicable to the mechanical drive gas turbines at the installation.</p> <p>Performance tests at full load were carried out at the time of the initial commissioning and are repeated at full load during mapping exercises carried out following major services.</p> <p>The Alert system calculates the % efficiency in normal operation.</p> <p>The Operator reported that the base load net mechanical energy percentages for the LCPs at the</p>																				
<table border="1"> <thead> <tr> <th data-bbox="344 882 524 914">Technique</th> <th data-bbox="526 882 748 914">Description</th> <th data-bbox="750 882 1509 914">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="344 916 524 1121">a. Combined cycle</td> <td data-bbox="526 916 748 1121">See description in Section 8.2</td> <td data-bbox="750 916 1509 1121">Generally applicable to new gas turbines and engines except when operated < 1 500 h/yr. Applicable to existing gas turbines and engines within the constraints associated with the steam cycle design and the space availability. Not applicable to existing gas turbines and engines operated < 1 500 h/yr. Not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns. Not applicable to boilers</td> </tr> </tbody> </table>						Technique	Description	Applicability	a. Combined cycle	See description in Section 8.2	Generally applicable to new gas turbines and engines except when operated < 1 500 h/yr. Applicable to existing gas turbines and engines within the constraints associated with the steam cycle design and the space availability. Not applicable to existing gas turbines and engines operated < 1 500 h/yr. Not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns. Not applicable to boilers														
Technique	Description	Applicability																							
a. Combined cycle	See description in Section 8.2	Generally applicable to new gas turbines and engines except when operated < 1 500 h/yr. Applicable to existing gas turbines and engines within the constraints associated with the steam cycle design and the space availability. Not applicable to existing gas turbines and engines operated < 1 500 h/yr. Not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns. Not applicable to boilers																							
<p>BAT-associated energy efficiency levels (BAT-AEELs) for the combustion of natural gas</p> <table border="1"> <thead> <tr> <th data-bbox="344 1155 618 1305" rowspan="3">Type of combustion unit</th> <th colspan="4" data-bbox="620 1155 1509 1187">BAT-AEELs ⁽¹³⁶⁾ ⁽¹³⁷⁾</th> </tr> <tr> <th colspan="2" data-bbox="620 1189 875 1246">Net electrical efficiency (%)</th> <th data-bbox="878 1189 1155 1246" rowspan="2">Net total fuel utilisation (%) ⁽¹³⁸⁾ ⁽¹³⁹⁾</th> <th colspan="2" data-bbox="1158 1189 1509 1246">Net mechanical energy efficiency (%) ⁽¹³⁹⁾ ⁽¹⁴⁰⁾</th> </tr> <tr> <th data-bbox="620 1248 730 1305">New unit</th> <th data-bbox="732 1248 875 1305">Existing unit</th> <th data-bbox="1158 1248 1308 1305">New unit</th> <th data-bbox="1310 1248 1509 1305">Existing unit</th> </tr> </thead> <tbody> <tr> <td data-bbox="344 1307 618 1369">Gas engine</td> <td data-bbox="620 1307 730 1369">39,5–44 ⁽¹⁴¹⁾</td> <td data-bbox="732 1307 875 1369">35–44 ⁽¹⁴¹⁾</td> <td data-bbox="878 1307 1155 1369">56–85 ⁽¹⁴¹⁾</td> <td colspan="2" data-bbox="1158 1307 1509 1369">No BAT-AEEL.</td> </tr> </tbody> </table>						Type of combustion unit	BAT-AEELs ⁽¹³⁶⁾ ⁽¹³⁷⁾				Net electrical efficiency (%)		Net total fuel utilisation (%) ⁽¹³⁸⁾ ⁽¹³⁹⁾	Net mechanical energy efficiency (%) ⁽¹³⁹⁾ ⁽¹⁴⁰⁾		New unit	Existing unit	New unit	Existing unit	Gas engine	39,5–44 ⁽¹⁴¹⁾	35–44 ⁽¹⁴¹⁾	56–85 ⁽¹⁴¹⁾	No BAT-AEEL.	
Type of combustion unit	BAT-AEELs ⁽¹³⁶⁾ ⁽¹³⁷⁾																								
	Net electrical efficiency (%)		Net total fuel utilisation (%) ⁽¹³⁸⁾ ⁽¹³⁹⁾	Net mechanical energy efficiency (%) ⁽¹³⁹⁾ ⁽¹⁴⁰⁾																					
	New unit	Existing unit		New unit	Existing unit																				
Gas engine	39,5–44 ⁽¹⁴¹⁾	35–44 ⁽¹⁴¹⁾	56–85 ⁽¹⁴¹⁾	No BAT-AEEL.																					

BAT Concn. Number	Summary of BAT Conclusion requirement					Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the Operator to demonstrate compliance with the BAT Conclusion requirement	
	Gas-fired boiler	39–42,5	38–40	78–95	No BAT-AEEL.		<p>installation are compliant with the BAT-AEEL for net mechanical energy efficiency in existing open cycle gas turbines, ≥ 50 MW_{th}, see section 4.2.</p> <p>We agree with the compliance status stated by the Operator.</p> <p>A process monitoring requirement has been set in table S3.3 which requires energy efficiency monitoring after an overhaul.</p>	
Open cycle gas turbine, ≥ 50 MW _{th}	36–41,5	33–41,5	No BAT-AEEL	36,5–41	33,5–41			
Combined cycle gas turbine (CCGT)								
CCGT, 50–600 MW _{th}	53–58,5	46–54	No BAT-AEEL	No BAT-AEEL				
CCGT, ≥ 600 MW _{th}	57–60,5	50–60	No BAT-AEEL	No BAT-AEEL				
CHP CCGT, 50–600 MW _{th}	53–58,5	46–54	65–95	No BAT-AEEL				
CHP CCGT, ≥ 600 MW _{th}	57–60,5	50–60	65–95	No BAT-AEEL				
41	In order to prevent or reduce NO _x emissions to air from the combustion of natural gas in boilers, BAT is to use one or a combination of the techniques given below.					NA	NOT APPLICABLE. The LCP's are Gas Turbines with Mechanical Drives.	
Technique		Description		Applicability				
a.	Air and/or fuel staging	See descriptions in Section 8.3. Air staging is often associated with low-NO _x burners		Generally applicable				
b.	Flue-gas recirculation	See description in Section 8.3						
c.	Low-NO _x burners (LNB)							
d.	Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr		The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system				
e.	Reduction of the combustion air temperature	See description in Section 8.3		Generally applicable within the constraints associated with the process needs				
f.	Selective non-catalytic reduction (SNCR)			Not applicable to combustion plants operated < 500 h/yr with highly variable boiler loads. The applicability may be limited in the case of combustion plants operated between 500 h/yr and 1 500 h/yr with highly variable boiler loads				

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the Operator to demonstrate compliance with the BAT Conclusion requirement																		
	g. Selective catalytic reduction (SCR)		Not applicable to combustion plants operated < 500 h/yr. Not generally applicable to combustion plants of < 100 MW _{th} . There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr																				
42	In order to prevent or reduce NO _x emissions to air from the combustion of natural gas in gas turbines, BAT is to use one or a combination of the techniques given below.			CC	<p>In relation to the compliance status against this BAT conclusion, the Operator confirmed that techniques a. and c. are implemented within LCP193, LCP194, LCP195, LCP196 and that the installation is therefore currently compliant with this BAT conclusion:</p> <ul style="list-style-type: none"> - GE DLE technology is applied, which consists of dry low-NO_x burners. - Gas Turbines are mapped to minimise emissions in all modes but guaranteed DLN is only supported by the manufacturer from 75% to maximum load (corresponding to 20.91 MW, referenced to 15°C, 101.325 kPa and 60 %RH). <p>The Operator requested DLN effective point at 75% load, above the threshold of 70% for applicability of IED Annex V emission limits and submitted</p>																		
<table border="1"> <thead> <tr> <th data-bbox="347 673 562 699">Technique</th> <th data-bbox="566 673 1111 699">Description</th> <th data-bbox="1115 673 1500 699">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="347 702 562 807">a. Advanced control system</td> <td data-bbox="566 702 1111 807">See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr</td> <td data-bbox="1115 702 1500 807">The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> <tr> <td data-bbox="347 810 562 868">b. Water/steam addition</td> <td data-bbox="566 810 1111 868" rowspan="2">See description in Section 8.3</td> <td data-bbox="1115 810 1500 868">The applicability may be limited due to water availability</td> </tr> <tr> <td data-bbox="347 871 562 999">c. Dry low-NO_x burners (DLN)</td> <td data-bbox="1115 871 1500 999">The applicability may be limited in the case of turbines where a retrofit package is not available or when water/steam addition systems are installed</td> </tr> <tr> <td data-bbox="347 1002 562 1133">d. Low-load design concept</td> <td data-bbox="566 1002 1111 1133">Adaptation of the process control and related equipment to maintain good combustion efficiency when the demand in energy varies, e.g. by improving the inlet airflow control capability or by splitting the combustion process into decoupled combustion stages</td> <td data-bbox="1115 1002 1500 1133">The applicability may be limited by the gas turbine design</td> </tr> <tr> <td data-bbox="347 1136 562 1267">e. Low-NO_x burners (LNB)</td> <td data-bbox="566 1136 1111 1267" rowspan="2">See description in Section 8.3</td> <td data-bbox="1115 1136 1500 1267">Generally applicable to supplementary firing for heat recovery steam generators (HRSGs) in the case of combined-cycle gas turbine (CCGT) combustion plants</td> </tr> <tr> <td data-bbox="347 1270 562 1375">f. Selective catalytic reduction (SCR)</td> <td data-bbox="1115 1270 1500 1375">Not applicable in the case of combustion plants operated < 500 h/yr. Not generally applicable to existing combustion plants of < 100 MW_{th}.</td> </tr> </tbody> </table>			Technique			Description	Applicability	a. Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system	b. Water/steam addition	See description in Section 8.3	The applicability may be limited due to water availability	c. Dry low-NO _x burners (DLN)	The applicability may be limited in the case of turbines where a retrofit package is not available or when water/steam addition systems are installed	d. Low-load design concept	Adaptation of the process control and related equipment to maintain good combustion efficiency when the demand in energy varies, e.g. by improving the inlet airflow control capability or by splitting the combustion process into decoupled combustion stages	The applicability may be limited by the gas turbine design	e. Low-NO _x burners (LNB)	See description in Section 8.3	Generally applicable to supplementary firing for heat recovery steam generators (HRSGs) in the case of combined-cycle gas turbine (CCGT) combustion plants	f. Selective catalytic reduction (SCR)	Not applicable in the case of combustion plants operated < 500 h/yr. Not generally applicable to existing combustion plants of < 100 MW _{th} .
Technique	Description	Applicability																					
a. Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system																					
b. Water/steam addition	See description in Section 8.3	The applicability may be limited due to water availability																					
c. Dry low-NO _x burners (DLN)		The applicability may be limited in the case of turbines where a retrofit package is not available or when water/steam addition systems are installed																					
d. Low-load design concept	Adaptation of the process control and related equipment to maintain good combustion efficiency when the demand in energy varies, e.g. by improving the inlet airflow control capability or by splitting the combustion process into decoupled combustion stages	The applicability may be limited by the gas turbine design																					
e. Low-NO _x burners (LNB)	See description in Section 8.3	Generally applicable to supplementary firing for heat recovery steam generators (HRSGs) in the case of combined-cycle gas turbine (CCGT) combustion plants																					
f. Selective catalytic reduction (SCR)		Not applicable in the case of combustion plants operated < 500 h/yr. Not generally applicable to existing combustion plants of < 100 MW _{th} .																					

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the Operator to demonstrate compliance with the BAT Conclusion requirement																
			<p>Retrofitting existing combustion plants may be constrained by the availability of sufficient space.</p> <p>There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr</p>		<p>documents to support this request. We agree with the proposal made by the operator Refer to section 4.1 for details.</p> <p>The Operator confirmed that the NO_x BAT-AEL for existing gas turbines with mechanical drives (subnotes 14 and 15) are expected to be achievable above the DLN effective point, proposed at 75% to maximum load:</p> <ul style="list-style-type: none"> - 60 mg/m³ NO_x (annual average); - 65 mg/m³ NO_x (daily average). <p>Refer to the key issues section for the NO_x emission limits specified in table S3.1a of the variation and consolidation notice.</p> <p>We agree with the compliance status stated by the Operator.</p>																
43	In order to prevent or reduce NO _x emissions to air from the combustion of natural gas in engines, BAT is to use one or a combination of the techniques given below.			NA	NOT APPLICABLE. The LCPs at the installation are gas turbines with mechanical drives.																
<table border="1"> <thead> <tr> <th data-bbox="338 1125 383 1157"></th> <th data-bbox="387 1125 562 1157">Technique</th> <th data-bbox="566 1125 1016 1157">Description</th> <th data-bbox="1021 1125 1518 1157">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 1160 383 1265">a.</td> <td data-bbox="387 1160 562 1265">Advanced control system</td> <td data-bbox="566 1160 1016 1265">See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr</td> <td data-bbox="1021 1160 1518 1265">The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> <tr> <td data-bbox="338 1268 383 1326">b.</td> <td data-bbox="387 1268 562 1326">Lean-burn concept</td> <td data-bbox="566 1268 1016 1326">See description in Section 8.3. Generally used in combination with SCR</td> <td data-bbox="1021 1268 1518 1326">Only applicable to new gas-fired engines</td> </tr> <tr> <td data-bbox="338 1329 383 1385">c.</td> <td data-bbox="387 1329 562 1385">Advanced lean-burn concept</td> <td data-bbox="566 1329 1016 1385">See descriptions in Section 8.3</td> <td data-bbox="1021 1329 1518 1385">Only applicable to new spark plug ignited engines</td> </tr> </tbody> </table>							Technique	Description	Applicability	a.	Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system	b.	Lean-burn concept	See description in Section 8.3. Generally used in combination with SCR	Only applicable to new gas-fired engines	c.	Advanced lean-burn concept	See descriptions in Section 8.3	Only applicable to new spark plug ignited engines
	Technique	Description	Applicability																		
a.	Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system																		
b.	Lean-burn concept	See description in Section 8.3. Generally used in combination with SCR	Only applicable to new gas-fired engines																		
c.	Advanced lean-burn concept	See descriptions in Section 8.3	Only applicable to new spark plug ignited engines																		

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the Operator to demonstrate compliance with the BAT Conclusion requirement																																														
	d. Selective catalytic reduction (SCR)		Retrofitting existing combustion plants may be constrained by the availability of sufficient space. Not applicable to combustion plants operated < 500 h/yr. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr																																																
44	<p>In order to prevent or reduce CO emissions to air from the combustion of natural gas, BAT is to ensure optimised combustion and/or to use oxidation catalysts.</p> <p>Description - See descriptions in Section 8.3.</p> <p>BAT-associated emission levels (BAT-AELs) for NO_x emissions to air from the combustion of natural gas in gas turbines</p>			CC	<p>The Operator confirmed that the installation makes use of combustion optimisation (see BAT 12) and advanced control system (see BAT 42). With the Alert system, mechanical failures resulting in incomplete combustion are expected to be detected early so as to prevent this impacting upon the annual average CO emission.</p> <p>The emissions limit for carbon monoxide above the DLN-E point proposed by the Operator is 40 mg/Nm³ (annual average), which is compliant with the indicative BAT-AEL for existing gas turbines of ≥ 50 MWth for mechanical drive applications.</p> <p>We agree with the compliance status stated by the Operator.</p> <p>Refer to the key issues section for the CO emission limits specified in table S3.1a of the variation and consolidation notice.</p>																																														
<table border="1"> <thead> <tr> <th data-bbox="347 726 808 842" rowspan="2">Type of combustion plant</th> <th data-bbox="813 726 1048 842" rowspan="2">Combustion plant total rated thermal input (MW_{th})</th> <th colspan="2" data-bbox="1052 726 1505 758">BAT-AELs (mg/Nm³) ⁽¹⁴²⁾ ⁽¹⁴³⁾</th> </tr> <tr> <th data-bbox="1052 761 1272 842">Yearly average ⁽¹⁴⁴⁾ ⁽¹⁴⁵⁾</th> <th data-bbox="1276 761 1505 842">Daily average or average over the sampling period</th> </tr> </thead> <tbody> <tr> <td colspan="4" data-bbox="347 845 1505 877" style="text-align: center;">Open-cycle gas turbines (OCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁷⁾</td> </tr> <tr> <td data-bbox="347 880 808 912">New OCGT</td> <td data-bbox="813 880 1048 912">≥ 50</td> <td data-bbox="1052 880 1272 912">15–35</td> <td data-bbox="1276 880 1505 912">25–50</td> </tr> <tr> <td data-bbox="347 916 808 1005">Existing OCGT (excluding turbines for mechanical drive applications) — All but plants operated < 500 h/yr</td> <td data-bbox="813 916 1048 1005">≥ 50</td> <td data-bbox="1052 916 1272 1005">15–50</td> <td data-bbox="1276 916 1505 1005">25–55 ⁽¹⁴⁸⁾</td> </tr> <tr> <td colspan="4" data-bbox="347 1008 1505 1040" style="text-align: center;">Combined-cycle gas turbines (CCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁹⁾</td> </tr> <tr> <td data-bbox="347 1043 808 1075">New CCGT</td> <td data-bbox="813 1043 1048 1075">≥ 50</td> <td data-bbox="1052 1043 1272 1075">10–30</td> <td data-bbox="1276 1043 1505 1075">15–40</td> </tr> <tr> <td data-bbox="347 1078 808 1142">Existing CCGT with a net total fuel utilisation of < 75 %</td> <td data-bbox="813 1078 1048 1142">≥ 600</td> <td data-bbox="1052 1078 1272 1142">10–40</td> <td data-bbox="1276 1078 1505 1142">18–50</td> </tr> <tr> <td data-bbox="347 1145 808 1209">Existing CCGT with a net total fuel utilisation of ≥ 75 %</td> <td data-bbox="813 1145 1048 1209">≥ 600</td> <td data-bbox="1052 1145 1272 1209">10–50</td> <td data-bbox="1276 1145 1505 1209">18–55 ⁽¹⁵⁰⁾</td> </tr> <tr> <td data-bbox="347 1212 808 1260">Existing CCGT with a net total fuel utilisation of < 75 %</td> <td data-bbox="813 1212 1048 1260">50–600</td> <td data-bbox="1052 1212 1272 1260">10–45</td> <td data-bbox="1276 1212 1505 1260">35–55</td> </tr> <tr> <td data-bbox="347 1264 808 1311">Existing CCGT with a net total fuel utilisation of ≥ 75 %</td> <td data-bbox="813 1264 1048 1311">50–600</td> <td data-bbox="1052 1264 1272 1311">25–50 ⁽¹⁵¹⁾</td> <td data-bbox="1276 1264 1505 1311">35–55 ⁽¹⁵²⁾</td> </tr> <tr> <td colspan="3" data-bbox="338 1315 1514 1370" style="text-align: center;">Open- and combined-cycle gas turbines</td> <td data-bbox="1523 1315 1653 1370"></td> <td data-bbox="1657 1315 2042 1370"></td> </tr> </tbody> </table>			Type of combustion plant			Combustion plant total rated thermal input (MW _{th})	BAT-AELs (mg/Nm ³) ⁽¹⁴²⁾ ⁽¹⁴³⁾		Yearly average ⁽¹⁴⁴⁾ ⁽¹⁴⁵⁾	Daily average or average over the sampling period	Open-cycle gas turbines (OCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁷⁾				New OCGT	≥ 50	15–35	25–50	Existing OCGT (excluding turbines for mechanical drive applications) — All but plants operated < 500 h/yr	≥ 50	15–50	25–55 ⁽¹⁴⁸⁾	Combined-cycle gas turbines (CCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁹⁾				New CCGT	≥ 50	10–30	15–40	Existing CCGT with a net total fuel utilisation of < 75 %	≥ 600	10–40	18–50	Existing CCGT with a net total fuel utilisation of ≥ 75 %	≥ 600	10–50	18–55 ⁽¹⁵⁰⁾	Existing CCGT with a net total fuel utilisation of < 75 %	50–600	10–45	35–55	Existing CCGT with a net total fuel utilisation of ≥ 75 %	50–600	25–50 ⁽¹⁵¹⁾	35–55 ⁽¹⁵²⁾	Open- and combined-cycle gas turbines				
Type of combustion plant	Combustion plant total rated thermal input (MW _{th})	BAT-AELs (mg/Nm ³) ⁽¹⁴²⁾ ⁽¹⁴³⁾																																																	
		Yearly average ⁽¹⁴⁴⁾ ⁽¹⁴⁵⁾	Daily average or average over the sampling period																																																
Open-cycle gas turbines (OCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁷⁾																																																			
New OCGT	≥ 50	15–35	25–50																																																
Existing OCGT (excluding turbines for mechanical drive applications) — All but plants operated < 500 h/yr	≥ 50	15–50	25–55 ⁽¹⁴⁸⁾																																																
Combined-cycle gas turbines (CCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁹⁾																																																			
New CCGT	≥ 50	10–30	15–40																																																
Existing CCGT with a net total fuel utilisation of < 75 %	≥ 600	10–40	18–50																																																
Existing CCGT with a net total fuel utilisation of ≥ 75 %	≥ 600	10–50	18–55 ⁽¹⁵⁰⁾																																																
Existing CCGT with a net total fuel utilisation of < 75 %	50–600	10–45	35–55																																																
Existing CCGT with a net total fuel utilisation of ≥ 75 %	50–600	25–50 ⁽¹⁵¹⁾	35–55 ⁽¹⁵²⁾																																																
Open- and combined-cycle gas turbines																																																			

BAT Concn. Number	Summary of BAT Conclusion requirement				Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the Operator to demonstrate compliance with the BAT Conclusion requirement
	Gas turbine put into operation no later than 27 November 2003, or existing gas turbine for emergency use and operated < 500 h/yr	≥ 50	No BAT-AEL	60–140 ⁽¹⁵³⁾ ⁽¹⁵⁴⁾		
	Existing gas turbine for mechanical drive applications — All but plants operated < 500 h/yr	≥ 50	15–50 ⁽¹⁵⁵⁾	25–55 ⁽¹⁵⁶⁾		
<p>As an indication, the yearly average CO emission levels for each type of existing combustion plant operated ≥ 1 500 h/yr and for each type of new combustion plant will generally be as follows:</p> <ul style="list-style-type: none"> — New OCGT of ≥ 50 MW_{th}: < 5–40 mg/Nm³. For plants with a net electrical efficiency (EE) greater than 39 %, a correction factor may be applied to the higher end of this range, corresponding to [higher end] × EE/39, where EE is the net electrical energy efficiency or net mechanical energy efficiency of the plant determined at ISO baseload conditions. — Existing OCGT of ≥ 50 MW_{th} (excluding turbines for mechanical drive applications): < 5–40 mg/Nm³. The higher end of this range will generally be 80 mg/Nm³ in the case of existing plants that cannot be fitted with dry techniques for NO_x reduction, or 50 mg/Nm³ for plants that operate at low load. — New CCGT of ≥ 50 MW_{th}: < 5–30 mg/Nm³. For plants with a net electrical efficiency (EE) greater than 55 %, a correction factor may be applied to the higher end of the range, corresponding to [higher end] × EE/55, where EE is the net electrical energy efficiency of the plant determined at ISO baseload conditions. — Existing CCGT of ≥ 50 MW_{th}: < 5–30 mg/Nm³. The higher end of this range will generally be 50 mg/Nm³ for plants that operate at low load. — Existing gas turbines of ≥ 50 MW_{th} for mechanical drive applications: < 5–40 mg/Nm³. The higher end of the range will generally be 50 mg/Nm³ when plants operate at low load. <p>In the case of a gas turbine equipped with DLN burners, these indicative levels correspond to when the DLN operation is effective.</p>						
<p align="center">BAT-associated emission levels (BAT-AELs) for NO_x emissions to air from the combustion of natural gas in boilers and engines</p>						
Type of combustion plant		BAT-AELs (mg/Nm ³)				
		Yearly average ⁽¹⁵⁷⁾		Daily average or average over the sampling period		
		New plant	Existing plant ⁽¹⁵⁸⁾	New plant	Existing plant ⁽¹⁵⁹⁾	

BAT Concn. Number	Summary of BAT Conclusion requirement					Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the Operator to demonstrate compliance with the BAT Conclusion requirement																	
	Boiler	10–60	50–100	30–85	85–110																			
	Engine ⁽¹⁶⁰⁾	20–75	20–100	55–85	55–110 ⁽¹⁶¹⁾																			
	<p>As an indication, the yearly average CO emission levels will generally be:</p> <ul style="list-style-type: none"> — < 5–40 mg/Nm³ for existing boilers operated ≥ 1 500 h/yr, — < 5–15 mg/Nm³ for new boilers, — 30–100 mg/Nm³ for existing engines operated ≥ 1 500 h/yr and for new engines. 																							
45	<p>In order to reduce non-methane volatile organic compounds (NMVOC) and methane (CH₄) emissions to air from the combustion of natural gas in spark-ignited lean-burn gas engines, BAT is to ensure optimised combustion and/or to use oxidation catalysts.</p> <p>Description See descriptions in Section 8.3. Oxidation catalysts are not effective at reducing the emissions of saturated hydrocarbons containing less than four carbon atoms.</p> <p>BAT-associated emission levels (BAT-AELs) for formaldehyde and CH₄ emissions to air from the combustion of natural gas in a spark-ignited lean-burn gas engine</p> <table border="1" data-bbox="349 842 1507 1018"> <thead> <tr> <th data-bbox="349 842 907 882" rowspan="4">Combustion plant total rated thermal input (MW_{th})</th> <th colspan="3" data-bbox="911 842 1507 882">BAT-AELs (mg/Nm³)</th> </tr> <tr> <th colspan="2" data-bbox="911 885 1167 909">Formaldehyde</th> <th data-bbox="1171 885 1507 909">CH₄</th> </tr> <tr> <th colspan="3" data-bbox="911 912 1507 952">Average over the sampling period</th> </tr> <tr> <th data-bbox="911 956 1167 979">New or existing plant</th> <th data-bbox="1171 956 1317 979">New plant</th> <th data-bbox="1321 956 1507 979">Existing plant</th> </tr> </thead> <tbody> <tr> <td data-bbox="349 983 907 1018">≥ 50</td> <td data-bbox="911 983 1167 1018">5–15 ⁽¹⁶²⁾</td> <td data-bbox="1171 983 1317 1018">215–500 ⁽¹⁶³⁾</td> <td data-bbox="1321 983 1507 1018">215–560 ⁽¹⁶²⁾ ⁽¹⁶³⁾</td> </tr> </tbody> </table>					Combustion plant total rated thermal input (MW _{th})	BAT-AELs (mg/Nm ³)			Formaldehyde		CH ₄	Average over the sampling period			New or existing plant	New plant	Existing plant	≥ 50	5–15 ⁽¹⁶²⁾	215–500 ⁽¹⁶³⁾	215–560 ⁽¹⁶²⁾ ⁽¹⁶³⁾	NA	NOT APPLICABLE. The LCPs at the installation are gas turbines with mechanical drives.
Combustion plant total rated thermal input (MW _{th})	BAT-AELs (mg/Nm ³)																							
	Formaldehyde		CH ₄																					
	Average over the sampling period																							
	New or existing plant	New plant	Existing plant																					
≥ 50	5–15 ⁽¹⁶²⁾	215–500 ⁽¹⁶³⁾	215–560 ⁽¹⁶²⁾ ⁽¹⁶³⁾																					

6 Emissions to Water

The consolidated permit incorporates the current discharge to controlled waters identified as W1.

There are no BAT AELs specified in the BAT Conclusions for this type of plant. There are also no additional treatment options identified as BAT for the installation. We have therefore not carried out any additional assessment of the emissions to water as part of this review.

7 Review and assessment of changes that are not part of the BAT Conclusions derived permit review.

This document should be read in conjunction with the application, supporting information and notice.

Aspect considered	Decision
Receipt of application	
Confidential information	<p>A claim for commercial or industrial confidentiality has been made.</p> <p>We have accepted the claim for confidentiality. We have excluded the document titled 'Vendor Emissions Guarantees for New LM2500+DLE1' attached to the letter received from the Operator, dated 17/03/2020 (subject: 'Interconnector-GP3538SH-LCPD-Additional Information-Rev A1') from the public register. We consider that the inclusion of the relevant information on the public register would prejudice the Operator's interests to an unreasonable degree. This is because the document deemed confidential includes information of commercial and contractual nature, covered by industrial confidentiality between the Operator and gas turbines equipment manufacturer.</p> <p>The decision was taken in accordance with our guidance on confidentiality.</p>
Identifying confidential information	We have not identified information provided as part of the application that we consider to be confidential.
The site	
Biodiversity, heritage, landscape and nature conservation	<p>The application is within the relevant distance criteria of a site of heritage, landscape or nature conservation, and/or protected species or habitat.</p> <p>A full assessment of the application and its potential to affect the site(s)/species/habitat has not been carried out as part of the permit review process. We consider that the review will not affect the features of the site(s)/species/habitat as the conditions will provide at least the same level of protection as those in the previous permit and in some cases will provide a higher level of protection to those in the previous permit.</p> <p>We have not consulted Natural England on the application. The decision was taken in accordance with our guidance.</p>

Aspect considered	Decision
Operating techniques	
General operating techniques	<p>We have reviewed the techniques used by the Operator where they are relevant to the BAT Conclusions and compared these with the relevant guidance notes.</p> <p>The permit conditions ensure compliance with the relevant BREF, BAT Conclusions. The ELVs deliver compliance with the BAT-AELs.</p>
Permit conditions	
Updating permit conditions during consolidation	<p>We have updated permit conditions to those in the current generic permit template as part of permit consolidation. The conditions will provide at least the same level of protection as those in the previous permit and in some cases will provide a higher level of protection to those in the previous permit.</p>
Use of conditions other than those from the template	<p>Condition 2.3.4 of the consolidated variation notice is retained from the current permit. This condition specifies that the total accumulated running time in 'BC mode' for each of the gas turbines shall not exceed 3% of the total running time for each of the respective LCP. 'BC mode' is the lowest stable operating condition for the operation of the mechanical drive gas turbines below the MSUL/MSDL points, corresponding to the operation of mixing nozzles (burners) banks B and C as described in the original application documents.</p> <p>We consider that this condition is still relevant and appropriate to the operation of the installation after issuing the consolidated variation notice.</p>
Changes to the permit conditions due to an Environment Agency initiated variation	<p>We have varied the permit as stated in the variation notice.</p>
Emission limits	<p>We have decided that emission limits should be set for the parameters listed in the permit.</p> <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p> <p>It is considered that the ELVs/equivalent parameters or technical measures described above will ensure that significant pollution of the environment is prevented and a high level of protection for the environment is secured.</p>
Monitoring	<p>We have decided that monitoring should be carried out for the parameters listed in the permit, using the methods detailed and to the frequencies specified.</p>

Aspect considered	Decision
	<p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p> <p>Table S3.3 Process monitoring requirements was amended to include the requirement to monitor energy efficiency after overhauls on site in line with BAT2.</p> <p>Based on the information in the application we are satisfied that the Operator's techniques, personnel and equipment have either MCERTS certification or MCERTS accreditation as appropriate.</p>
Reporting	<p>We have specified reporting in the permit for the following parameters:</p> <ul style="list-style-type: none"> • Nitrogen dioxide • Carbon monoxide • Sulphur dioxide <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p>
Operator competence	
Management system	<p>There is no known reason to consider that the Operator will not have the management system to enable it to comply with the permit conditions.</p>
Growth Duty	
Section 108 Deregulation Act 2015 – Growth duty	<p>We have considered our duty to have regard to the desirability of promoting economic growth set out in section 108(1) of the Deregulation Act 2015 and the guidance issued under section 110 of that Act in deciding whether to grant this permit.</p> <p>Paragraph 1.3 of the guidance says:</p> <p>“The primary role of regulators, in delivering regulation, is to achieve the regulatory outcomes for which they are responsible. For a number of regulators, these regulatory outcomes include an explicit reference to development or growth. The growth duty establishes economic growth as a factor that all specified regulators should have regard to, alongside the delivery of the protections set out in the relevant legislation.”</p> <p>We have addressed the legislative requirements and environmental standards to be set for this operation in the body of the decision document above. The guidance is clear at paragraph 1.5 that the growth duty does not legitimise non-compliance and its purpose is not to achieve or pursue economic growth at the expense of necessary protections.</p> <p>We consider the requirements and standards we have set in this permit are reasonable and necessary to avoid a risk of an unacceptable level of pollution. This also promotes growth amongst legitimate Operators because the standards applied to the Operator are consistent across businesses in this sector</p>

Aspect considered	Decision
	and have been set to achieve the required legislative standards.