

Environment Agency

Review of an Environmental Permit for an Installation subject to Chapter II of the Industrial Emissions Directive under the Environmental Permitting (England & Wales) Regulations 2016

Decision document recording our decision-making process following review of a permit

The Permit number is: EPR/CP3337YX
The Operator is: BWSC Generation Services UK Limited
The Installation is: Snetterton Renewable Energy Plant
This Variation Notice number is: EPR/CP3337YX/V002

What this document is about

Article 21(3) of the Industrial Emissions Directive (IED) requires the Environment Agency to review conditions in permits that it has issued and to ensure that the permit delivers compliance with relevant standards, within four years of the publication of updated decisions on best available techniques (BAT) conclusions.

We have reviewed the permit for this installation against the revised BAT Conclusions for large combustion plant published on 17th August 2017. This is our decision document, which explains the reasoning for the consolidated variation notice that we are issuing.

It explains how we have reviewed and considered the techniques used by the Operator in the operation and control of the plant and activities of the installation. This review has been undertaken with reference to the decision made by the European Commission establishing best available techniques (BAT) conclusions ('BAT Conclusions') for large combustion plant as detailed in document reference IEDC-7-1. It is our record of our decision-making process and shows how we have taken into account all relevant factors in reaching our position. It also provides a justification for the inclusion of any specific conditions in the permit that are in addition to those included in our generic permit template.

As well as considering the review of the operating techniques used by the Operator for the operation of the plant and activities of the installation, the consolidated variation notice takes into account and brings together in a single document all previous variations that relate to the original permit

issued. It also modernises the entire permit to reflect the conditions contained in our current generic permit template.

The introduction of new template conditions makes the Permit consistent with our current general approach and philosophy and with other permits issued to installations in this sector. Although the wording of some conditions has changed, while others have been removed because of the new regulatory approach, it does not reduce the level of environmental protection achieved by the Permit in any way. In this document we therefore address only our determination of substantive issues relating to the new BAT Conclusions.

This is our record of our decision-making process and shows how we have taken into account all relevant factors in reaching our position.

Throughout this document we will use a number of expressions. These are as referred to in the glossary and have the same meaning as described in “Schedule 6 Interpretation” of the Permit.

We try to explain our decision as accurately, comprehensively and plainly as possible. We would welcome any feedback as to how we might improve our decision documents in future. A lot of technical terms and acronyms are inevitable in a document of this nature: we provide a glossary of acronyms near the front of the document, for ease of reference.

How this document is structured

Glossary of terms

- 1 Our decision
- 2 How we reached our decision
- 2.1 Requesting information to demonstrate compliance with BAT Conclusions for Large Combustion Plant
- 2.2 Review of our own information in respect to the capability of the installation to meet revised standards included in the BAT Conclusions document
- 3 The legal framework
- 4 Key Issue
- 4.1 Emissions to air and the emission limits applied to the plant
- 4.2 The energy efficiency levels associated with the Best Available Techniques Conclusions
- 4.3 Fuel characterisation
- 5 Decision checklist regarding relevant BAT Conclusions
- 6 Review and assessment of derogation requests made by the operator in relation to BAT Conclusions which include an associated emission level (AEL) value
- 7 Emissions to Water
- 8 Additional IED Chapter II requirements
- 9 Review and assessment of changes that are not part of the BAT Conclusions derived permit review.

Glossary of acronyms used in this document

(Please note that this glossary is standard for our decision documents and therefore not all these acronyms are necessarily used in this document.)

APC	Air Pollution Control
BAT	Best Available Technique(s)
BAT-AEL	BAT Associated Emission Level
BATc	BAT conclusion
BREF	Best available techniques reference document
CEM	Continuous emissions monitor
CHP	Combined heat and power
CROW	Countryside and rights of way Act 2000
CV	Calorific value
DAA	Directly associated activity – Additional activities necessary to be carried out to allow the principal activity to be carried out
Derogation	from BAT AELs stated in BAT Conclusions under specific circumstances as detailed under Article 15(4) of IED where an assessment shows that the achievement of emission levels associated with the best available techniques as described in BAT conclusions would lead to disproportionately higher costs
EIONET	European environment information and observation network is a partnership network of the European Environment Agency
ELV	Emission limit value derived under BAT or an emission limit value set out in IED
EMS	Environmental Management System
EPR	Environmental Permitting (England and Wales) Regulations 2016 (SI 2016 No. 1154)
EWC	European waste catalogue
FSA	Food Standards Agency
IED	Industrial Emissions Directive (2010/75/EU)
IPPCD	Integrated Pollution Prevention and Control Directive (2008/1/EC) – now superseded by IED
LCP	Large Combustion Plant subject to Chapter III of IED
MSUL/MSDL	Minimum start up load/minimum shut-down load
NOx	Oxides of nitrogen (NO plus NO ₂ expressed as NO ₂)
NPV	Net Present Value
PC	Process Contribution
PEC	Predicted Environmental Concentration
PHE	Public Health England
PPS	Public participation statement
SAC	Special Area of Conservation
SGN	Sector guidance note
TGN	Technical guidance note
TOC	Total Organic Carbon
WFD	Water Framework Directive (2000/60/EC)

1 Our decision

We have decided to issue the consolidated variation notice to the Operator. This will allow it to continue to operate the Installation, subject to the conditions in the consolidated variation notice.

We consider that, in reaching that decision, we have taken into account all relevant considerations and legal requirements and that the varied permit will ensure that a high level of protection is provided for the environment and human health.

The consolidated variation notice contains many conditions taken from our standard Environmental Permit template including the relevant Annexes. We developed these conditions in consultation with industry, having regard to the legal requirements of the Environmental Permitting Regulations and other relevant legislation. This document does not therefore include an explanation for these standard conditions. Where they are included in the Notice, we have considered the techniques identified by the operator for the operation of their installation, and have accepted that the details are sufficient and satisfactory to make those standard conditions appropriate. This document does, however, provide an explanation of our use of “tailor-made” or installation-specific conditions, or where our Permit template provides two or more options.

2 How we reached our decision

2.1 Requesting information to demonstrate compliance with BAT Conclusions for Large Combustion Plant

We issued a Notice under Regulation 61(1) of the Environmental Permitting (England and Wales) Regulations 2016 (a Regulation 61 Notice) on 01/05/18 requiring the Operator to provide information to demonstrate how the operation of their installation currently meets, or will subsequently meet, the revised standards described in the large combustion plant BAT Conclusions document. The Notice also required that where the revised standards are not currently met, the operator should provide information that:

- Describes the techniques that will be implemented before 17th August 2021, which will then ensure that operations meet the revised standard, or
- Justifies why standards will not be met by 17th August 2021, and confirmation of the date when the operation of those processes will cease within the installation or an explanation of why the revised BAT standard is not applicable to those processes, or
- Justifies why an alternative technique will achieve the same level of environmental protection equivalent to the revised standard described in the BAT Conclusions.

Where the Operator proposed that they were not intending to meet a BAT standard that also included a BAT Associated Emission Level (BAT AEL) described in the BAT Conclusions Document, the Regulation 61 Notice requested that the Operator make a formal request for derogation from compliance with that AEL (as provisioned by Article 15(4) of IED). In this circumstance, the Notice identified that any such request for derogation must be supported and justified by sufficient technical and commercial information that would enable us to determine acceptability of the derogation request.

The Regulation 61 Notice response from the Operator was received on 18/10/18. We considered it was in the correct form and contained sufficient information for us to begin our determination of the permit review but not that it necessarily contained all the information we would need to complete that review: see below.

We considered that the response did not contain sufficient information for us to commence the permit review. We therefore issued a further information request to the Operator on 18/10/18. Suitable further information was provided by the Operator on 01/04/19, 30/04/19 and 02/07/19.

We have not received any information in relation to the Regulation 61 Notice response that appears to be confidential in relation to any party.

2.2 Review of our own information in respect to the capability of the installation to meet revised standards included in the BAT Conclusions document

Based on our records and previous regulatory activities with the facility we have no reason to consider that the operator will not be able to comply with the conditions that we include in the permit.

3 The legal framework

The consolidated variation notice will be issued under Regulation 20 of the EPR. The Environmental Permitting regime is a legal vehicle which delivers most of the relevant legal requirements for activities falling within its scope. In particular, the regulated facility is:

- an *installation* as described by the IED;
- subject to aspects of other relevant legislation which also have to be addressed.

We consider that the consolidated variation notice will ensure that the operation of the Installation complies with all relevant legal requirements and that a high level of protection will be delivered for the environment and human health.

We explain how we have addressed specific statutory requirements more fully in the rest of this document.

4 The key issues

The key issues arising during this permit review are:

- Emissions to air and the emission limits applied to the plant.
- The energy efficiency levels associated with the Best Available Techniques (BAT-AEELs)
- Fuel Characterisation

We therefore describe how we determined these issues in most detail in the relevant sections of this document.

4.1 Emissions to air and the emission limits applied to the plant

A number of general principles were applied during the permit review. These included:

- The upper value of the BAT AELs ranges specified were used unless use of the tighter limit was justified.
- The principle of no backsliding where if existing limits in the permit were already tighter than those specified in the BREF, the existing permit limits were retained.
- Where a limit was specified in both IED Annex V and the BAT Conclusions for a particular reference period, the tighter limit was applied and in the majority of cases this was from the BAT Conclusions.
- Where AELs are indicative in the BAT Conclusions, these were applied unless adequate justification was demonstrated that an alternative limit was more appropriate.

The one LCP on site is referenced LCP466 and is a biomass fired boiler which has a thermal input of 130 MWth.

The plant was put into operation after IED came into force and therefore the existing limits in the permit are from Part 2 of IED Annex V applicable to new plant.

The ELVs and AELs are based on the following operating regime:

- Unlimited hours operation

The following table outlines the limits that have been incorporated into the permit for LCP466, where these were derived from and the reference periods at which they apply. The emission limits refer to concentrations, expressed as mass of emitted substance per volume of flue-gas under the following standard conditions: dry gas at a temperature of 273,15 K, pressure of 101,3 kPa and 6% volume reference oxygen concentration if flue gases. The

emission limits and monitoring requirements have been incorporated into Schedule 3 of the permit.

NO _x limits (mg/Nm ³)						
Averaging	IED (Annex V Part 2) – New	BREF (Table 9 BAT-c)	Expected permit limits	Basis	Limits apply	Monitoring
Annual	None	180	180	BREF	MSUL/MSDL to baseload	Continuous
Monthly	200	None	200	IED	MSUL/MSDL to baseload	
Daily	220	220	200	Existing Permit	MSUL/MSDL to baseload	
95 th %ile of hr means	400	None	400	IED	MSUL/MSDL to baseload	

Under the no backsliding rule the Daily will be 200 mg/Nm³ as specified in the existing permit.

CO limits (mg/Nm ³)						
Averaging	IED (Annex V Part 2) - New	BREF (Table 9 BAT-c)	Expected permit limits	Basis	Limits apply	Monitoring
Annual	None	160	160	BREF	MSUL/MSDL to baseload	Continuous

SO ₂ limits (mg/Nm ³)						
Averaging	IED (Annex V Part 2) – New	BREF (Table 10 BAT-c)	Expected permit limits note 1	Basis	Limits apply	Monitoring
Annual	None	100 ^{Note 1}	100	BREF	MSUL/MSDL to baseload	Continuous
Monthly	200	None	200	IED	MSUL/MSDL to baseload	
Daily	220	215 ^{Note 2}	200	Existing Permit	MSUL/MSDL to baseload	
95 th %ile of hr means	400	None	400	IED	MSUL/MSDL to baseload	

Note 1 – Operator has provided data demonstrating that average sulphur content is $\geq 0.1\%$. In accordance with footnote 3 of table 10 in the BAT-c a limit of 100mg/Nm³ can be set in this circumstance.

Note 2 - Operator has provided data demonstrating that average sulphur content is $\geq 0.1\%$. In accordance with footnote 4 of table 10 in the BAT-c a limit of 215mg/Nm³ can be set in this circumstance.

Under the no backsliding rule the Daily will be 200 mg/Nm³ as specified in the existing permit.

HCl limits (mg/Nm ³)						
Averaging	IED (Annex V Part 2) - New	BREF (Table 11 BAT-c)	Expected permit limits	Basis	Limits apply	Monitoring
Annual	None	25 ^{Note 1}	25	BREF	MSUL/MSDL to baseload	Continuous
Daily	None	None ^{Note 2}	25	Existing Permit	MSUL/MSDL to baseload	
<p>Note 1 - Operator has provided data demonstrating that average chlorine content is $\geq 0.1\%$. In accordance with footnote 1 of table 11 in the BAT-c a limit of 25 mg/Nm³ can be set in this circumstance.</p> <p>Note 2 - Operator has provided data demonstrating that average chlorine content is $\geq 0.1\%$. In accordance with footnote 1 of table 11 in the BAT-c no daily limit is required in this circumstance.</p>						

Under the no backsliding rule the Daily will be 25mg/Nm³ as specified in the existing permit.

HF limits (mg/Nm ³)						
Averaging	IED (Annex V Part 2) - New	BREF (Table 11 BAT-c)	Expected permit limits	Basis	Limits apply	Monitoring
Average over sampling period	None	< 1	< 1	BREF	MSUL/MSDL to baseload	Once per year

Dust limits (mg/Nm ³)						
Averaging	IED (Annex V Part 2) - New	BREF (Table 12 BAT-c)	Expected permit limits	Basis	Limits apply	Monitoring
Annual	None	12	12	BREF	MSUL/MSDL to baseload	Continuous
Monthly	20	None	20	IED	MSUL/MSDL to baseload	
Daily	22	18	18	BREF	MSUL/MSDL to baseload	
95 th %ile of hr means	40	None	40	IED	MSUL/MSDL to baseload	

NH ₃ limits (mg/Nm ³)						
Averaging	IED (Annex V Part 2) - New	BREF (BAT Conclusion 7)	Expected permit limits	Basis	Limits apply	Monitoring
Yearly	None	15	10	BREF	MSUL/MSDL to baseload	Continuous

Under the no backsliding rule the Yearly limit will be 10 mg/Nm³, as specified in the existing permit.

Hg limits ($\mu\text{g}/\text{Nm}^3$)						
Averaging	IED (Annex V Part 2) - New	BREF (BAT Conclusion 27)	Expected permit limits	Basis	Limits apply	Monitoring
Average over sampling period	None	5	5	BREF	MSUL/MSDL to baseload	Once per year

4.2 The energy efficiency levels associated with the Best Available Techniques Conclusions

An energy efficiency level associated with the best available techniques (BAT-AEEL) refers to the ratio between the combustion unit's net energy output(s) and the combustion unit's fuel/feedstock energy input at actual unit design. The net energy output(s) is determined at the combustion unit boundaries, including auxiliary systems (e.g. flue-gas treatment systems), and for the unit operated at full load.

The table below sets out the AEELs specified in the BAT Conclusions for the large combustion plant on the site and the energy efficiency levels confirmed through the Regulation 61 notice response. The evidence provided to demonstrate that the AEELs are met was in the form of figures from a planned performance test undertaken on 12th September 2017. We consider this plant is BAT in relation to the AEELs.

BAT AEELs (%)			Plant efficiency (%)		
Net electrical efficiency	Net total fuel utilisation	Net mechanical efficiency	Net electrical efficiency	Net total fuel utilisation	Net mechanical efficiency
LCP466: Existing solid biomass and peat boiler					
28% - 38%	None	None	34.6%	NA	NA

4.3 Fuel characterisation

BAT 9 requires the operator to carry out fuel characterisation. The operator does not currently undertake fuel characterisation of F, K, NA or Metals and metalloids (As, Cd, Co, Cr, Cu, Mn, Ni, Pb, Sb, Se, Ti, V, Zn).

We have therefore included an improvement condition in the consolidated variation notice IC8 requiring the operator to submit a plan outlining how this will be carried out for approval prior to the implementation date for the BAT Conclusions.

5 Decision checklist regarding relevant BAT Conclusions

BAT Conclusions for large combustion plant, were published by the European Commission on 17th August 2017. There are 75 BAT Conclusions. Only the BAT Conclusions relevant to the particular fuel type used on site have been replicated below.

This annex provides a record of decisions made in relation to each relevant BAT Conclusion applicable to the installation. This annex should be read in conjunction with the Consolidated Variation Notice.

The conditions in the permit through which the relevant BAT Conclusions are implemented include but are not limited to the following:

BAT Conclusion requirement topic	Permit condition(s)	Permit table(s)
Environmental Management System	1.1.1	S1.2
BAT AELs	3.1.1 and 3.5.1	S3.1, S3.1a
Monitoring	2.3, 3.5 and 3.6	S3.1, S3.1a, S3.2
Energy efficiency	1.2 and 2.3	S3.3
Noise	3.4 and 2.3	S1.2
Other operating techniques	1.2	S1.2

The overall status of compliance with the BAT conclusion is indicated in the table as:

- NA Not Applicable
- CC Currently Compliant
- FC Compliant in the future (within 4 years of publication of BAT conclusions)
- NC Not Compliant
- PC Partially Compliant

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
General			
1	<p>In order to improve the overall environmental performance, BAT is to implement and adhere to an environmental management system (EMS) that incorporates all of the following features:</p> <ul style="list-style-type: none"> i. commitment of the management, including senior management; ii. definition of an environmental policy that includes the continuous improvement of the installation by the management; iii. planning and establishing the necessary procedures, objectives and targets, in conjunction with financial planning and investment; iv. implementation of procedures <ul style="list-style-type: none"> (a) Structure and responsibility (b) Training (c) Communication (d) Employee involvement (e) Documentation (f) Efficient process control (g) Maintenance programmes (h) Emergency preparedness and response (i) Safeguarding compliance with environmental legislation v. checking performance and taking corrective action, paying particular attention to: <ul style="list-style-type: none"> (a) monitoring and measurement (see also the Reference Document on the General Principles of Monitoring) (b) corrective and preventive action (c) maintenance of records (d) independent (where practicable) internal and external auditing in order to determine whether or not the EMS conforms to planned arrangements and has been properly implemented and maintained; vi. review of the EMS and its continuing suitability, adequacy and effectiveness by senior management; vii. following the development of cleaner technologies; 	CC	An Environment Management System (EMS) is in place which has been audited and accredited by ISO 14001.

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement													
	<p>viii. consideration for the environmental impacts from the eventual decommissioning of the installation at the stage of designing a new plant, and throughout its operating life;</p> <p>viii. consideration for the environmental impacts from the eventual decommissioning of the installation at the stage of designing a new plant, and throughout its operating life;</p> <p>ix. application of sectoral benchmarking on a regular basis.</p> <p>Etc - see BAT Conclusions</p> <p>Applicability. The scope (e.g. level of detail) and nature of the EMS (e.g. standardised or non-standardised) will generally be related to the nature, scale and complexity of the installation, and the range of environmental impacts it may have.</p>															
2	<p>BAT is to determine the net electrical efficiency and/or the net total fuel utilisation and/or the net mechanical energy efficiency of the gasification, IGCC and/or combustion units by carrying out a performance test at full load (1), according to EN standards, after the commissioning of the unit and after each modification that could significantly affect the net electrical efficiency and/or the net total fuel utilisation and/or the net mechanical energy efficiency of the unit. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.</p>	CC	<p>The operator has provided details of a performance testing report which states the efficiency of the plant as being 34.6%. The performance testing was undertaken in accordance with EN12952-15.</p>													
3	<p>BAT is to monitor key process parameters relevant for emissions to air and water including those given below.</p> <table border="1" data-bbox="255 1002 1236 1251"> <thead> <tr> <th data-bbox="255 1002 562 1034">Stream</th> <th data-bbox="562 1002 927 1034">Parameter(s)</th> <th data-bbox="927 1002 1236 1034">Monitoring</th> </tr> </thead> <tbody> <tr> <td data-bbox="255 1034 562 1193" rowspan="3">Flue-gas</td> <td data-bbox="562 1034 927 1098">Flow</td> <td data-bbox="927 1034 1236 1098">Periodic or continuous determination</td> </tr> <tr> <td data-bbox="562 1098 927 1161">Oxygen content, temperature, and pressure</td> <td data-bbox="927 1098 1236 1161">Periodic or continuous measurement</td> </tr> <tr> <td data-bbox="562 1161 927 1193">Water vapour content (%)</td> <td data-bbox="927 1161 1236 1193"></td> </tr> <tr> <td data-bbox="255 1193 562 1251">Waste water from flue-gas treatment</td> <td data-bbox="562 1193 927 1251">Flow, pH, and temperature</td> <td data-bbox="927 1193 1236 1251">Continuous measurement</td> </tr> </tbody> </table>	Stream	Parameter(s)	Monitoring	Flue-gas	Flow	Periodic or continuous determination	Oxygen content, temperature, and pressure	Periodic or continuous measurement	Water vapour content (%)		Waste water from flue-gas treatment	Flow, pH, and temperature	Continuous measurement	CC	<p>Flow, Oxygen content, temperature, pressure and water vapour content are all monitored on a continuous basis through installed Continuous Emissions Monitoring (CEMS).</p>
Stream	Parameter(s)	Monitoring														
Flue-gas	Flow	Periodic or continuous determination														
	Oxygen content, temperature, and pressure	Periodic or continuous measurement														
	Water vapour content (%)															
Waste water from flue-gas treatment	Flow, pH, and temperature	Continuous measurement														

BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
4	<p>BAT is to monitor emissions to air with at least the frequency given below and in accordance with EN standards. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.</p>						FC	<p>The operator has specified monitoring frequencies as detailed below. The parameters monitored and frequencies specified are in accordance with the requirements of BAT4 and will be monitored from the implementation date in 2021.</p> <p>NH₃ - Continuous NO_x - Continuous N₂O - Once every year CO – Continuous SO₂ – Continuous SO₃ – Once every year HCl - Continuous HF – Once every year Dust – Continuous Metals and metalloids – Once per year Hg – Once per year</p> <p>For N₂O, SO₃ and Metals and metalloids we have decided not to set monitoring where there is no limit, however the operator has confirmed that these substances will still be monitored.</p>
	Substance/Parameter	Fuel/Process/Type of combustion plant	Combustion plant total rated thermal input	Standard(s) (1)	Minimum monitoring frequency (2)	Monitoring associated with		
	NH ₃	— When SCR and/or SNCR is used	All sizes	Generic EN standards	Continuous (6) (7)	BAT 7		
	NO _x	<ul style="list-style-type: none"> — Coal and/or lignite including waste co-incineration — Solid biomass and/or peat including waste co-incineration — HFO- and/or gas-oil-fired boilers and engines — Gas-oil-fired gas turbines — Natural-gas-fired boilers, engines, and turbines — Iron and steel process gases — Process fuels from the chemical industry — IGCC plants 	All sizes	Generic EN standards	Continuous (6) (6)	BAT 20 BAT 24 BAT 28 BAT 32 BAT 37 BAT 41 BAT 42 BAT 43 BAT 47 BAT 48 BAT 56 BAT 64 BAT 65 BAT 73		
		— Combustion plants on offshore platforms	All sizes	EN 14792	Once every year (8)	BAT 53		

BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	N ₂ O	<ul style="list-style-type: none"> — Coal and/or lignite in circulating fluidised bed boilers — Solid biomass and/or peat in circulating fluidised bed boilers 	All sizes	EN 21258	Once every year ⁽¹⁰⁾	BAT 20 BAT 24		
	CO	<ul style="list-style-type: none"> — Coal and/or lignite including waste co-incineration — Solid biomass and/or peat including waste co-incineration — HFO- and/or gas-oil-fired boilers and engines — Gas-oil-fired gas turbines — Natural-gas-fired boilers, engines, and turbines — Iron and steel process gases — Process fuels from the chemical industry — IGCC plants 	All sizes	Generic EN standards	Continuous ⁽⁶⁾ ⁽⁸⁾	BAT 20 BAT 24 BAT 28 BAT 33 BAT 38 BAT 44 BAT 49 BAT 56 BAT 64 BAT 65 BAT 73		
		<ul style="list-style-type: none"> — Combustion plants on offshore platforms 	All sizes	EN 15058	Once every year ⁽⁹⁾	BAT 54		
	SO ₂	<ul style="list-style-type: none"> — Coal and/or lignite incl waste co-incineration 	All sizes	Generic EN standards and EN 14791	Continuous ⁽⁶⁾ ⁽¹¹⁾ ⁽¹²⁾	BAT 21 BAT 25 BAT 29 BAT 34 BAT 39 BAT 50		

BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
		<ul style="list-style-type: none"> — Solid biomass and/or peat incl waste co-incineration — HFO- and/or gas-oil-fired boilers — HFO- and/or gas-oil-fired engines — Gas-oil-fired gas turbines — Iron and steel process gases — Process fuels from the chemical industry in boilers — IGCC plants 				BAT 57 BAT 66 BAT 67 BAT 74		
	SO ₃	<ul style="list-style-type: none"> — When SCR is used 	All sizes	No EN standard available	Once every year	—		
	Gaseous chlorides, expressed as HCl	<ul style="list-style-type: none"> — Coal and/or lignite — Process fuels from the chemical industry in boilers 	All sizes	EN 1911	Once every three months ⁽⁶⁾ ⁽¹³⁾ ⁽¹⁴⁾	BAT 21 BAT 57		
		<ul style="list-style-type: none"> — Solid biomass and/or peat 	All sizes	Generic EN standards	Continuous ⁽¹⁵⁾ ⁽¹⁶⁾	BAT 25		
		<ul style="list-style-type: none"> — Waste co-incineration 	All sizes	Generic EN standards	Continuous ⁽⁶⁾ ⁽¹⁶⁾	BAT 66 BAT 67		
	HF	<ul style="list-style-type: none"> — Coal and/or lignite — Process fuels from the chemical industry in boilers 	All sizes	No EN standard available	Once every three months ⁽⁶⁾ ⁽¹³⁾ ⁽¹⁴⁾	BAT 21 BAT 57		
		<ul style="list-style-type: none"> — Solid biomass and/or peat 	All sizes	No EN standard available	Once every year	BAT 25		

BAT Concn. Number	Summary of BAT Conclusion requirement					Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	
		— Waste co-incineration	All sizes	Generic EN standards	Continuous ⁽⁶⁾ ₍₁₆₎	BAT 66 BAT 67		
	Dust	<ul style="list-style-type: none"> — Coal and/or lignite — Solid biomass and/or peat — HFO- and/or gas-oil-fired boilers — Iron and steel process gases — Process fuels from the chemical industry in boilers — IGCC plants — HFO- and/or gas-oil-fired engines — Gas-oil-fired gas turbines 	All sizes	Generic EN standards and EN 13284-1 and EN 13284-2	Continuous ⁽⁶⁾ ₍₁₇₎	BAT 22 BAT 26 BAT 30 BAT 35 BAT 39 BAT 51 BAT 58 BAT 75		
		— Waste co-incineration	All sizes	Generic EN standards and EN 13284-2	Continuous	BAT 68 BAT 69		
	Metals and metalloids except mercury (As, Cd, Co, Cr, Cu, Mn, Ni, Pb, Sb, Se, Ti, V, Zn)	<ul style="list-style-type: none"> — Coal and/or lignite — Solid biomass and/or peat — HFO- and/or gas-oil-fired boilers and engines 	All sizes	EN 14385	Once every year ₍₁₈₎	BAT 22 BAT 26 BAT 30		
		— Waste co-incineration	< 300 MW _{th}	EN 14385	Once every six months ₍₁₃₎	BAT 68 BAT 69		
			≥ 300 MW _{th}	EN 14385	Once every three months ₍₁₉₎ ₍₁₃₎			
		— IGCC plants	≥ 100 MW _{th}	EN 14385	Once every year ₍₁₈₎	BAT 75		

BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	Hg	— Coal and/or lignite including waste co-incineration	< 300 MW _{th}	EN 13211	Once every three months ₍₁₃₎ ₍₂₀₎	BAT 23		
			≥ 300 MW _{th}	Generic EN standards and EN 14884	Continuous ₍₁₆₎ ₍₂₁₎			
		— Solid biomass and/or peat	All sizes	EN 13211	Once every year ₍₂₂₎	BAT 27		
		— Waste co-incineration with solid biomass and/or peat	All sizes	EN 13211	Once every three months ₍₁₃₎	BAT 70		
		— IGCC plants	≥ 100 MW _{th}	EN 13211	Once every year ₍₂₃₎	BAT 75		
	TVOC	— HFO- and/or gas-oil-fired engines — Process fuels from chemical industry in boilers	All sizes	EN 12619	Once every six months ₍₁₃₎	BAT 33 BAT 59		
	Formaldehyde	— Natural-gas in spark-ignited lean-burn gas and dual fuel engines	All sizes	No EN standard available	Once every year	BAT 45		
	CH ₄	— Natural-gas-fired engines	All sizes	EN ISO 25139	Once every year ₍₂₄₎	BAT 45		
	PCDD/F	— Process fuels from chemical industry in boilers	All sizes	EN 1948-1, EN 1948-2, EN 1948-3	Once every six months ₍₁₃₎ ₍₂₅₎	BAT 59 BAT 71		
		— Waste co-incineration						

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																																
5	<p>BAT is to monitor emissions to water from flue-gas treatment with at least the frequency given below and in accordance with EN standards. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.</p> <table border="1" data-bbox="266 560 1229 1313"> <thead> <tr> <th data-bbox="266 560 544 644">Substance/Parameter</th> <th data-bbox="544 560 844 644">Standard(s)</th> <th data-bbox="844 560 1041 644">Minimum monitoring frequency</th> <th data-bbox="1041 560 1229 644">Monitoring associated with</th> </tr> </thead> <tbody> <tr> <td data-bbox="266 644 544 703">Total organic carbon (TOC)₍₂₆₎</td> <td data-bbox="544 644 844 703">EN 1484</td> <td data-bbox="844 644 1041 1313" rowspan="8">Once every month</td> <td data-bbox="1041 644 1229 1313" rowspan="8">BAT 15</td> </tr> <tr> <td data-bbox="266 703 544 762">Chemical oxygen demand (COD)₍₂₆₎</td> <td data-bbox="544 703 844 762">No EN standard available</td> </tr> <tr> <td data-bbox="266 762 544 821">Total suspended solids (TSS)</td> <td data-bbox="544 762 844 821">EN 872</td> </tr> <tr> <td data-bbox="266 821 544 858">Fluoride (F⁻)</td> <td data-bbox="544 821 844 858">EN ISO 10304-1</td> </tr> <tr> <td data-bbox="266 858 544 895">Sulphate (SO₄²⁻)</td> <td data-bbox="544 858 844 895">EN ISO 10304-1</td> </tr> <tr> <td data-bbox="266 895 544 954">Sulphide, easily released (S²⁻)</td> <td data-bbox="544 895 844 954">No EN standard available</td> </tr> <tr> <td data-bbox="266 954 544 991">Sulphite (SO₃²⁻)</td> <td data-bbox="544 954 844 991">EN ISO 10304-3</td> </tr> <tr> <td data-bbox="266 991 488 1313">Metals and metalloids</td> <td data-bbox="488 991 844 1313"> <table border="1"> <tr><td data-bbox="488 991 544 1027">As</td><td data-bbox="544 991 844 1230" rowspan="6">Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)</td></tr> <tr><td data-bbox="488 1027 544 1064">Cd</td></tr> <tr><td data-bbox="488 1064 544 1101">Cr</td></tr> <tr><td data-bbox="488 1101 544 1137">Cu</td></tr> <tr><td data-bbox="488 1137 544 1174">Ni</td></tr> <tr><td data-bbox="488 1174 544 1211">Pb</td></tr> <tr><td data-bbox="488 1211 544 1248">Zn</td></tr> <tr><td data-bbox="488 1248 544 1313">Hg</td><td data-bbox="544 1248 844 1313">Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)</td></tr> </table> </td> </tr> </tbody> </table>	Substance/Parameter	Standard(s)	Minimum monitoring frequency	Monitoring associated with	Total organic carbon (TOC) ₍₂₆₎	EN 1484	Once every month	BAT 15	Chemical oxygen demand (COD) ₍₂₆₎	No EN standard available	Total suspended solids (TSS)	EN 872	Fluoride (F ⁻)	EN ISO 10304-1	Sulphate (SO ₄ ²⁻)	EN ISO 10304-1	Sulphide, easily released (S ²⁻)	No EN standard available	Sulphite (SO ₃ ²⁻)	EN ISO 10304-3	Metals and metalloids	<table border="1"> <tr><td data-bbox="488 991 544 1027">As</td><td data-bbox="544 991 844 1230" rowspan="6">Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)</td></tr> <tr><td data-bbox="488 1027 544 1064">Cd</td></tr> <tr><td data-bbox="488 1064 544 1101">Cr</td></tr> <tr><td data-bbox="488 1101 544 1137">Cu</td></tr> <tr><td data-bbox="488 1137 544 1174">Ni</td></tr> <tr><td data-bbox="488 1174 544 1211">Pb</td></tr> <tr><td data-bbox="488 1211 544 1248">Zn</td></tr> <tr><td data-bbox="488 1248 544 1313">Hg</td><td data-bbox="544 1248 844 1313">Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)</td></tr> </table>	As	Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)	Cd	Cr	Cu	Ni	Pb	Zn	Hg	Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)	NA	No flue-gas treatment used at the installation.
Substance/Parameter	Standard(s)	Minimum monitoring frequency	Monitoring associated with																																
Total organic carbon (TOC) ₍₂₆₎	EN 1484	Once every month	BAT 15																																
Chemical oxygen demand (COD) ₍₂₆₎	No EN standard available																																		
Total suspended solids (TSS)	EN 872																																		
Fluoride (F ⁻)	EN ISO 10304-1																																		
Sulphate (SO ₄ ²⁻)	EN ISO 10304-1																																		
Sulphide, easily released (S ²⁻)	No EN standard available																																		
Sulphite (SO ₃ ²⁻)	EN ISO 10304-3																																		
Metals and metalloids	<table border="1"> <tr><td data-bbox="488 991 544 1027">As</td><td data-bbox="544 991 844 1230" rowspan="6">Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)</td></tr> <tr><td data-bbox="488 1027 544 1064">Cd</td></tr> <tr><td data-bbox="488 1064 544 1101">Cr</td></tr> <tr><td data-bbox="488 1101 544 1137">Cu</td></tr> <tr><td data-bbox="488 1137 544 1174">Ni</td></tr> <tr><td data-bbox="488 1174 544 1211">Pb</td></tr> <tr><td data-bbox="488 1211 544 1248">Zn</td></tr> <tr><td data-bbox="488 1248 544 1313">Hg</td><td data-bbox="544 1248 844 1313">Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)</td></tr> </table>			As	Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)	Cd	Cr	Cu	Ni	Pb	Zn	Hg	Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)																						
As	Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)																																		
Cd																																			
Cr																																			
Cu																																			
Ni																																			
Pb																																			
Zn																																			
Hg	Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)																																		

BAT Concn. Number	Summary of BAT Conclusion requirement				Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																	
	Chloride (Cl ⁻)	Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)		—																			
	Total nitrogen	EN 12260		—																			
6	In order to improve the general environmental performance of combustion plants and to reduce emissions to air of CO and unburnt substances, BAT is to ensure optimised combustion and to use an appropriate combination of the techniques given below.				CC	Combustion is optimised through the application of the following measures: A – Fuel Blending and Management – different fuels are stored separately to allow for control of fuel feed and blend. B – Maintenance – fuel feeding system is maintained in accordance with operational procedures for the installation. Plant is shut down once a year to inspect any issues and rectify any problems. C – Advanced control system – Computer based control system and live instrumentation used to monitor and control combustion. E – Fuel Choice – The fuel supply is changed if emissions issues are encountered.																	
	<table border="1"> <thead> <tr> <th data-bbox="297 679 309 715">Technique</th> <th data-bbox="309 679 461 715">Description</th> <th data-bbox="461 679 819 715">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="297 715 309 823">a</td> <td data-bbox="309 715 461 823">Fuel blending and mixing</td> <td data-bbox="461 715 819 823">Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type</td> </tr> <tr> <td data-bbox="297 823 309 932">b</td> <td data-bbox="309 823 461 932">Maintenance of the combustion system</td> <td data-bbox="461 823 819 932">Regular planned maintenance according to suppliers' recommendations</td> </tr> <tr> <td data-bbox="297 932 309 1040">c</td> <td data-bbox="309 932 461 1040">Advanced control system</td> <td data-bbox="461 932 819 1040">See description in Section 8.1</td> </tr> <tr> <td data-bbox="297 1040 309 1149">d</td> <td data-bbox="309 1040 461 1149">Good design of the combustion equipment</td> <td data-bbox="461 1040 819 1149">Good design of furnace, combustion chambers, burners and associated devices</td> </tr> <tr> <td data-bbox="297 1149 309 1347">e</td> <td data-bbox="309 1149 461 1347">Fuel choice</td> <td data-bbox="461 1149 819 1347">Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used</td> </tr> </tbody> </table>	Technique	Description	Applicability	a	Fuel blending and mixing	Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type	b	Maintenance of the combustion system	Regular planned maintenance according to suppliers' recommendations	c	Advanced control system	See description in Section 8.1	d	Good design of the combustion equipment	Good design of furnace, combustion chambers, burners and associated devices	e	Fuel choice	Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used				
Technique	Description	Applicability																					
a	Fuel blending and mixing	Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type																					
b	Maintenance of the combustion system	Regular planned maintenance according to suppliers' recommendations																					
c	Advanced control system	See description in Section 8.1																					
d	Good design of the combustion equipment	Good design of furnace, combustion chambers, burners and associated devices																					
e	Fuel choice	Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used																					

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement				
	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 10%;"></td> <td style="width: 10%;"></td> <td style="width: 10%;"></td> <td style="width: 70%;"> fuel balance in the case of combustion of industrial process fuels. For existing combustion plants, the type of fuel chosen may be limited by the configuration and the design of the plant </td> </tr> </table>				fuel balance in the case of combustion of industrial process fuels. For existing combustion plants, the type of fuel chosen may be limited by the configuration and the design of the plant		
			fuel balance in the case of combustion of industrial process fuels. For existing combustion plants, the type of fuel chosen may be limited by the configuration and the design of the plant				
7	<p>In order to reduce emissions of ammonia to air from the use of selective catalytic reduction (SCR) and/or selective non-catalytic reduction (SNCR) for the abatement of NO_x emissions, BAT is to optimise the design and/or operation of SCR and/or SNCR (e.g. optimised reagent to NO_x ratio, homogeneous reagent distribution and optimum size of the reagent drops).</p> <p>BAT-associated emission levels</p> <p>The BAT-associated emission level (BAT-AEL) for emissions of NH₃ to air from the use of SCR and/or SNCR is < 3–10 mg/Nm³ as a yearly average or average over the sampling period. The lower end of the range can be achieved when using SCR and the upper end of the range can be achieved when using SNCR without wet abatement techniques. In the case of plants combusting biomass and operating at variable loads as well as in the case of engines combusting HFO and/or gas oil, the higher end of the BAT-AEL range is 15 mg/Nm³.</p>	CC	The site uses Selective Catalytic Reduction (SCR) for abatement of NO _x emissions.				
8	In order to prevent or reduce emissions to air during normal operating conditions, BAT is to ensure, by appropriate design, operation and maintenance, that the emission abatement systems are used at optimal capacity and availability.	CC	The site has a number of Standard operating procedures covering all plant operations and maintenance.				
9	<p>In order to improve the general environmental performance of combustion and/or gasification plants and to reduce emissions to air, BAT is to include the following elements in the quality assurance/quality control programmes for all the fuels used, as part of the environmental management system (see BAT 1):</p> <p>(i) Initial full characterisation of the fuel used including at least the parameters listed below and in accordance with EN standards. ISO, national or other international standards may be used provided they ensure the provision of data of an equivalent scientific quality;</p>	FC	<p>Samples are taken daily to form a composite weekly fuel sample which is analysed. This in accordance with OFGEM requirements. The following substances are characterised: Gross and Net CV, moisture, ash, C, Cl, N and S.</p> <p>F, K, Na and metals and metalloids are currently not characterised. The operator will add these to the fuel</p>				

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement															
	<p>(ii) Regular testing of the fuel quality to check that it is consistent with the initial characterisation and according to the plant design specifications. The frequency of testing and the parameters chosen from the table below are based on the variability of the fuel and an assessment of the relevance of pollutant releases (e.g. concentration in fuel, flue-gas treatment employed);</p> <p>(iii) Subsequent adjustment of the plant settings as and when needed and practicable (e.g. integration of the fuel characterisation and control in the advanced control system (see description in Section 8.1)).</p> <p>Description Initial characterisation and regular testing of the fuel can be performed by the operator and/or the fuel supplier. If performed by the supplier, the full results are provided to the operator in the form of a product (fuel) supplier specification and/or guarantee.</p> <table border="1" data-bbox="255 751 1236 1311"> <thead> <tr> <th data-bbox="255 751 584 783">Fuel(s)</th> <th data-bbox="584 751 1236 783">Substances/Parameters subject to characterisation</th> </tr> </thead> <tbody> <tr> <td data-bbox="255 783 584 991" rowspan="4">Biomass/peat</td> <td data-bbox="584 783 1236 823">— LHV</td> </tr> <tr> <td data-bbox="584 823 1236 863">— moisture</td> </tr> <tr> <td data-bbox="584 863 1236 903">— Ash</td> </tr> <tr> <td data-bbox="584 903 1236 991">— C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn)</td> </tr> <tr> <td data-bbox="255 991 584 1230" rowspan="4">Coal/lignite</td> <td data-bbox="584 991 1236 1031">— LHV</td> </tr> <tr> <td data-bbox="584 1031 1236 1070">— Moisture</td> </tr> <tr> <td data-bbox="584 1070 1236 1110">— Volatiles, ash, fixed carbon, C, H, N, O, S</td> </tr> <tr> <td data-bbox="584 1110 1236 1150">— Br, Cl, F</td> </tr> <tr> <td data-bbox="255 1230 584 1311" rowspan="2">HFO</td> <td data-bbox="584 1230 1236 1270">— Ash</td> </tr> <tr> <td data-bbox="584 1270 1236 1311">— C, S, N, Ni, V</td> </tr> </tbody> </table>	Fuel(s)	Substances/Parameters subject to characterisation	Biomass/peat	— LHV	— moisture	— Ash	— C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn)	Coal/lignite	— LHV	— Moisture	— Volatiles, ash, fixed carbon, C, H, N, O, S	— Br, Cl, F	HFO	— Ash	— C, S, N, Ni, V		<p>characterisation requirements and will be compliant by 2021. An improvement condition (IC8) has been included requesting submission of the fuel testing procedures.</p> <p>The methods of testing are in accordance with EN standards, samples are taken on a daily basis to form a composite weekly sample, should any parameters fall outside of the fuel specification Plant Asset Owner/General Manger is notified an assessment is made of the materiality of the parameter and where appropriate the fuel procurement team is asked to action quality improvement.</p>
Fuel(s)	Substances/Parameters subject to characterisation																	
Biomass/peat	— LHV																	
	— moisture																	
	— Ash																	
	— C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn)																	
Coal/lignite	— LHV																	
	— Moisture																	
	— Volatiles, ash, fixed carbon, C, H, N, O, S																	
	— Br, Cl, F																	
HFO	— Ash																	
	— C, S, N, Ni, V																	

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement										
	<table border="1"> <tr> <td data-bbox="255 437 584 523">Gas oil</td> <td data-bbox="584 437 1234 523"> <ul style="list-style-type: none"> — Ash — N, C, S </td> </tr> <tr> <td data-bbox="255 523 584 609">Natural gas</td> <td data-bbox="584 523 1234 609"> <ul style="list-style-type: none"> — LHV — CH₄, C₂H₆, C₃, C₄+, CO₂, N₂, Wobbe index </td> </tr> <tr> <td data-bbox="255 609 584 715">Process fuels from the chemical industry⁽²⁷⁾</td> <td data-bbox="584 609 1234 715"> <ul style="list-style-type: none"> — Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Ti, V, Zn) </td> </tr> <tr> <td data-bbox="255 715 584 785">Iron and steel process gases</td> <td data-bbox="584 715 1234 785"> <ul style="list-style-type: none"> — LHV, CH₄ (for COG), C_xH_y (for COG), CO₂, H₂, N₂, total sulphur, dust, Wobbe index </td> </tr> <tr> <td data-bbox="255 785 584 975">Waste⁽²⁸⁾</td> <td data-bbox="584 785 1234 975"> <ul style="list-style-type: none"> — LHV — Moisture — Volatiles, ash, Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Ti, V, Zn) </td> </tr> </table>	Gas oil	<ul style="list-style-type: none"> — Ash — N, C, S 	Natural gas	<ul style="list-style-type: none"> — LHV — CH₄, C₂H₆, C₃, C₄+, CO₂, N₂, Wobbe index 	Process fuels from the chemical industry ⁽²⁷⁾	<ul style="list-style-type: none"> — Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Ti, V, Zn) 	Iron and steel process gases	<ul style="list-style-type: none"> — LHV, CH₄ (for COG), C_xH_y (for COG), CO₂, H₂, N₂, total sulphur, dust, Wobbe index 	Waste ⁽²⁸⁾	<ul style="list-style-type: none"> — LHV — Moisture — Volatiles, ash, Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Ti, V, Zn) 		
Gas oil	<ul style="list-style-type: none"> — Ash — N, C, S 												
Natural gas	<ul style="list-style-type: none"> — LHV — CH₄, C₂H₆, C₃, C₄+, CO₂, N₂, Wobbe index 												
Process fuels from the chemical industry ⁽²⁷⁾	<ul style="list-style-type: none"> — Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Ti, V, Zn) 												
Iron and steel process gases	<ul style="list-style-type: none"> — LHV, CH₄ (for COG), C_xH_y (for COG), CO₂, H₂, N₂, total sulphur, dust, Wobbe index 												
Waste ⁽²⁸⁾	<ul style="list-style-type: none"> — LHV — Moisture — Volatiles, ash, Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Ti, V, Zn) 												
10	<p>In order to reduce emissions to air and/or to water during other than normal operating conditions (OTNOC), BAT is to set up and implement a management plan as part of the environmental management system (see BAT 1), commensurate with the relevance of potential pollutant releases, that includes the following elements:</p> <ul style="list-style-type: none"> — appropriate design of the systems considered relevant in causing OTNOC that may have an impact on emissions to air, water and/or soil (e.g. low-load design concepts for reducing the minimum start-up and shutdown loads for stable generation in gas turbines), — set-up and implementation of a specific preventive maintenance plan for these relevant systems, — review and recording of emissions caused by OTNOC and associated circumstances and implementation of corrective actions if necessary, 	CC	<p>The operator has confirmed that the following techniques are implemented at this installation:</p> <p>The plant has gone through an independent engineering assessment to ensure compliance with environmental impacts. A maintenance plan is in place where the Original Equipment Manufacturer (OEM) services and calibrates equipment on the installation including CEMs, Water discharge, dust monitors and noise meters. All data is recorded and submitted in line with the requirements of the permit. The data is reviewed on an annual basis with view for continual improvements which feed back into the installations Key Performance Indicators (KPIs) and management systems.</p>										

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement										
	— periodic assessment of the overall emissions during OTNOC (e.g. frequency of events, duration, emissions quantification/estimation) and implementation of corrective actions if necessary.												
11	<p>BAT is to appropriately monitor emissions to air and/or to water during OTNOC.</p> <p>Description</p> <p>The monitoring can be carried out by direct measurement of emissions or by monitoring of surrogate parameters if this proves to be of equal or better scientific quality than the direct measurement of emissions. Emissions during start-up and shutdown (SU/SD) may be assessed based on a detailed emission measurement carried out for a typical SU/SD procedure at least once every year, and using the results of this measurement to estimate the emissions for each and every SU/SD throughout the year.</p>	CC	Continuous monitoring is in place at the installation. Monitoring will be taking place during OTNOC.										
12	<p>In order to increase the energy efficiency of combustion, gasification and/or IGCC units operated $\geq 1\,500$ h/yr, BAT is to use an appropriate combination of the techniques given below.</p> <table border="1" data-bbox="255 842 1236 1302"> <thead> <tr> <th data-bbox="255 842 474 879">Technique</th> <th data-bbox="474 842 875 879">Description</th> <th data-bbox="875 842 1236 879">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="255 879 474 1011">a. Combustion optimisation</td> <td data-bbox="474 879 875 1011">See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues</td> <td data-bbox="875 879 1236 1302" rowspan="3">Generally applicable</td> </tr> <tr> <td data-bbox="255 1011 474 1171">b. Optimisation of the working medium conditions</td> <td data-bbox="474 1011 875 1171">Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO_x emissions or the characteristics of energy demanded</td> </tr> <tr> <td data-bbox="255 1171 474 1302">c. Optimisation of the steam cycle</td> <td data-bbox="474 1171 875 1302">Operate with lower turbine exhaust pressure by utilisation of the lowest possible temperature of the condenser cooling water, within the design conditions</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Combustion optimisation	See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues	Generally applicable	b. Optimisation of the working medium conditions	Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO _x emissions or the characteristics of energy demanded	c. Optimisation of the steam cycle	Operate with lower turbine exhaust pressure by utilisation of the lowest possible temperature of the condenser cooling water, within the design conditions	CC	<p>Energy Efficiency is optimised through the application of the following measures:</p> <p>A - Combustion is optimised as described under BAT 6.</p> <p>B – The plant is designed to be run at base load running at optimum pressure and temperature whilst controlling NO_x.</p> <p>C – An air cooled condenser is used to optimise conditions for low pressure steam exhaust.</p> <p>E – Combustion air is pre-heated.</p> <p>H – The boiler feedwater is preheated.</p>
Technique	Description	Applicability											
a. Combustion optimisation	See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues	Generally applicable											
b. Optimisation of the working medium conditions	Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO _x emissions or the characteristics of energy demanded												
c. Optimisation of the steam cycle	Operate with lower turbine exhaust pressure by utilisation of the lowest possible temperature of the condenser cooling water, within the design conditions												

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	d.	Minimisation of energy consumption	Minimising the internal energy consumption (e.g. greater efficiency of the feed-water pump)		
	e.	Preheating of combustion air	Reuse of part of the heat recovered from the combustion flue-gas to preheat the air used in combustion	Generally applicable within the constraints related to the need to control NO _x emissions	
	f.	Fuel preheating	Preheating of fuel using recovered heat	Generally applicable within the constraints associated with the boiler design and the need to control NO _x emissions	
	g.	Advanced control system	See description in Section 8.2. Computerised control of the main combustion parameters enables the combustion efficiency to be improved	Generally applicable to new units. The applicability to old units may be constrained by the need to retrofit the combustion system and/or control command system	
	h.	Feed-water preheating using recovered heat	Preheat water coming out of the steam condenser with recovered heat, before reusing it in the boiler	Only applicable to steam circuits and not to hot boilers. Applicability to existing units may be limited due to constraints associated with the plant configuration and the amount of recoverable heat	
	i.	Heat recovery by cogeneration (CHP)	Recovery of heat (mainly from the steam system) for producing hot water/steam to be used in industrial processes/activities or in a public network for district heating. Additional heat recovery is possible from: <ul style="list-style-type: none"> — flue-gas — grate cooling — circulating fluidised bed 	Applicable within the constraints associated with the local heat and power demand. The applicability may be limited in the case of gas compressors with an unpredictable operational heat profile	
	j.	CHP readiness	See description in Section 8.2.	Only applicable to new units where there is a realistic potential for the	

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	
				future use of heat in the vicinity of the unit		
	k.	Flue-gas condenser	See description in Section 8.2.	Generally applicable to CHP units provided there is enough demand for low-temperature heat		
	l.	Heat accumulation	Heat accumulation storage in CHP mode	Only applicable to CHP plants. The applicability may be limited in the case of low heat load demand		
	m.	Wet stack	See description in Section 8.2.	Generally applicable to new and existing units fitted with wet FGD		
	n.	Cooling tower discharge	The release of emissions to air through a cooling tower and not via a dedicated stack	Only applicable to units fitted with wet FGD where reheating of the flue-gas is necessary before release, and where the unit cooling system is a cooling tower		
	o.	Fuel pre-drying	The reduction of fuel moisture content before combustion to improve combustion conditions	Applicable to the combustion of biomass and/or peat within the constraints associated with spontaneous combustion risks (e.g. the moisture content of peat is kept above 40 % throughout the delivery chain). The retrofit of existing plants may be restricted by the extra calorific value that can be obtained from the drying operation and by the limited retrofit possibilities offered by some boiler designs or plant configurations		
	p.	Minimisation of heat losses	Minimising residual heat losses, e.g. those that occur via the slag or those that can be reduced by insulating radiating sources	Only applicable to solid-fuel-fired combustion units and to gasification/IGCC units		

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	q.	Advanced materials	Use of advanced materials proven to be capable of withstanding high operating temperatures and pressures and thus to achieve increased steam/combustion process efficiencies	Only applicable to new plants	
	r.	Steam turbine upgrades	This includes techniques such as increasing the temperature and pressure of medium-pressure steam, addition of a low-pressure turbine, and modifications to the geometry of the turbine rotor blades	The applicability may be restricted by demand, steam conditions and/or limited plant lifetime	
	s.	Supercritical and ultra-supercritical steam conditions	Use of a steam circuit, including steam reheating systems, in which steam can reach pressures above 220,6 bar and temperatures above 374 °C in the case of supercritical conditions, and above 250 – 300 bar and temperatures above 580 – 600 °C in the case of ultra-supercritical conditions	Only applicable to new units of $\geq 600 \text{ MW}_{\text{th}}$ operated $> 4\,000 \text{ h/yr}$. Not applicable when the purpose of the unit is to produce low steam temperatures and/or pressures in process industries. Not applicable to gas turbines and engines generating steam in CHP mode. For units combusting biomass, the applicability may be constrained by high-temperature corrosion in the case of certain biomasses	
13	In order to reduce water usage and the volume of contaminated waste water discharged, BAT is to use one or both of the techniques given below.			CC	Grey water recovery in place at the installation. Wet ash water is recovered via a slag pit. A Waste Treatment Plant and boiler blowdown recovery are to be installed on site.
	Technique	Description	Applicability		
	a.	Water recycling	Residual aqueous streams, including run-off water, from the plant are reused for other purposes. The degree of recycling is limited by the quality requirements of the recipient water stream and the water balance of the plant		

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																		
	b. Dry bottom ash handling	Dry, hot bottom ash falls from the furnace onto a mechanical conveyor system and is cooled down by ambient air. No water is used in the process.	Only applicable to plants combusting solid fuels. There may be technical restrictions that prevent retrofitting to existing combustion plants																				
14	<p>In order to prevent the contamination of uncontaminated waste water and to reduce emissions to water, BAT is to segregate waste water streams and to treat them separately, depending on the pollutant content.</p> <p>Description Waste water streams that are typically segregated and treated include surface run-off water, cooling water, and waste water from flue-gas treatment.</p> <p>Applicability The applicability may be restricted in the case of existing plants due to the configuration of the drainage systems.</p>			CC	Site trade effluent/foul water and surface water are already separated. Grey water is also recovered from 60% of the roof area.																		
15	<p>In order to reduce emissions to water from flue-gas treatment, BAT is to use an appropriate combination of the techniques given below, and to use secondary techniques as close as possible to the source in order to avoid dilution.</p> <table border="1" data-bbox="255 943 1243 1327"> <thead> <tr> <th data-bbox="255 943 584 1007">Technique</th> <th data-bbox="591 943 846 1007">Typical pollutants prevented/abated</th> <th data-bbox="853 943 1243 1007">Applicability</th> </tr> </thead> <tbody> <tr> <td colspan="3" data-bbox="255 1011 1243 1038" style="text-align: center;">Primary techniques</td> </tr> <tr> <td data-bbox="255 1043 584 1150">a. Optimised combustion (see BAT 6) and flue-gas treatment systems (e.g. SCR/SNCR, see BAT 7)</td> <td data-bbox="591 1043 846 1150">Organic compounds, ammonia (NH₃)</td> <td data-bbox="853 1043 1243 1150">Generally applicable</td> </tr> <tr> <td colspan="3" data-bbox="255 1155 1243 1182" style="text-align: center;">Secondary techniques ⁽²⁹⁾</td> </tr> <tr> <td data-bbox="255 1187 584 1246">b. Adsorption on activated carbon</td> <td data-bbox="591 1187 846 1246">Organic compounds, mercury (Hg)</td> <td data-bbox="853 1187 1243 1246">Generally applicable</td> </tr> <tr> <td data-bbox="255 1251 584 1327">c. Aerobic biological treatment</td> <td data-bbox="591 1251 846 1327">Biodegradable organic compounds, ammonium (NH₄⁺)</td> <td data-bbox="853 1251 1243 1327">Generally applicable for the treatment of organic compounds. Aerobic biological treatment of ammonium</td> </tr> </tbody> </table>			Technique	Typical pollutants prevented/abated	Applicability	Primary techniques			a. Optimised combustion (see BAT 6) and flue-gas treatment systems (e.g. SCR/SNCR, see BAT 7)	Organic compounds, ammonia (NH ₃)	Generally applicable	Secondary techniques ⁽²⁹⁾			b. Adsorption on activated carbon	Organic compounds, mercury (Hg)	Generally applicable	c. Aerobic biological treatment	Biodegradable organic compounds, ammonium (NH ₄ ⁺)	Generally applicable for the treatment of organic compounds. Aerobic biological treatment of ammonium	NA	Flue gas treatment is not used at this installation.
Technique	Typical pollutants prevented/abated	Applicability																					
Primary techniques																							
a. Optimised combustion (see BAT 6) and flue-gas treatment systems (e.g. SCR/SNCR, see BAT 7)	Organic compounds, ammonia (NH ₃)	Generally applicable																					
Secondary techniques ⁽²⁹⁾																							
b. Adsorption on activated carbon	Organic compounds, mercury (Hg)	Generally applicable																					
c. Aerobic biological treatment	Biodegradable organic compounds, ammonium (NH ₄ ⁺)	Generally applicable for the treatment of organic compounds. Aerobic biological treatment of ammonium																					

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
			(NH ₄ ⁺) may not be applicable in the case of high chloride concentrations (i.e. around 10 g/l)		
d.	Anoxic/anaerobic biological treatment	Mercury (Hg), nitrate (NO ₃ ⁻), nitrite (NO ₂ ⁻)	Generally applicable		
e.	Coagulation and flocculation	Suspended solids	Generally applicable		
f.	Crystallisation	Metals and metalloids, sulphate (SO ₄ ²⁻), fluoride (F ⁻)	Generally applicable		
g.	Filtration (e.g. sand filtration, microfiltration, ultrafiltration)	Suspended solids, metals	Generally applicable		
h.	Flotation	Suspended solids, free oil	Generally applicable		
i.	Ion exchange	Metals	Generally applicable		
j.	Neutralisation	Acids, alkalis	Generally applicable		
k.	Oxidation	Sulphide (S ²⁻), sulphite (SO ₃ ²⁻)	Generally applicable		
l.	Precipitation	Metals and metalloids, sulphate (SO ₄ ²⁻), fluoride (F ⁻)	Generally applicable		
m.	Sedimentation	Suspended solids	Generally applicable		
n.	Stripping	Ammonia (NH ₃)	Generally applicable		
The BAT-AELs refer to direct discharges to a receiving water body at the point where the emission leaves the installation.					
BAT-AELs for direct discharges to a receiving water body from flue-gas treatment					
Substance/Parameter		BAT-AELs			
		Daily average			
Total organic carbon (TOC)		20–50 mg/l _(³⁰) _(³¹) _(³²)			
Chemical oxygen demand (COD)		60–150 mg/l _(³⁰) _(³¹) _(³²)			
Total suspended solids (TSS)		10–30 mg/l			

BAT Conc. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																	
	<table border="1"> <tr> <td data-bbox="255 442 719 475">Fluoride (F⁻)</td> <td data-bbox="719 442 1234 475">10–25 mg/l⁽³²⁾</td> </tr> <tr> <td data-bbox="255 475 719 509">Sulphate (SO₄²⁻)</td> <td data-bbox="719 475 1234 509">1,3–2,0 g/l⁽³²⁾ ⁽³³⁾ ⁽³⁴⁾ ⁽³⁵⁾</td> </tr> <tr> <td data-bbox="255 509 719 542">Sulphide (S²⁻), easily released</td> <td data-bbox="719 509 1234 542">0,1–0,2 mg/l⁽³²⁾</td> </tr> <tr> <td data-bbox="255 542 719 576">Sulphite (SO₃²⁻)</td> <td data-bbox="719 542 1234 576">1–20 mg/l⁽³²⁾</td> </tr> <tr> <td data-bbox="255 576 719 858" rowspan="7">Metals and metalloids</td> <td data-bbox="719 576 1234 609">As 10–50 µg/l</td> </tr> <tr> <td data-bbox="719 609 1234 643">Cd 2–5 µg/l</td> </tr> <tr> <td data-bbox="719 643 1234 676">Cr 10–50 µg/l</td> </tr> <tr> <td data-bbox="719 676 1234 710">Cu 10–50 µg/l</td> </tr> <tr> <td data-bbox="719 710 1234 743">Hg 0,2–3 µg/l</td> </tr> <tr> <td data-bbox="719 743 1234 777">Ni 10–50 µg/l</td> </tr> <tr> <td data-bbox="719 777 1234 810">Pb 10–20 µg/l</td> </tr> <tr> <td data-bbox="719 810 1234 858">Zn 50–200 µg/l</td> </tr> </table>	Fluoride (F ⁻)	10–25 mg/l ⁽³²⁾	Sulphate (SO ₄ ²⁻)	1,3–2,0 g/l ⁽³²⁾ ⁽³³⁾ ⁽³⁴⁾ ⁽³⁵⁾	Sulphide (S ²⁻), easily released	0,1–0,2 mg/l ⁽³²⁾	Sulphite (SO ₃ ²⁻)	1–20 mg/l ⁽³²⁾	Metals and metalloids	As 10–50 µg/l	Cd 2–5 µg/l	Cr 10–50 µg/l	Cu 10–50 µg/l	Hg 0,2–3 µg/l	Ni 10–50 µg/l	Pb 10–20 µg/l	Zn 50–200 µg/l		
Fluoride (F ⁻)	10–25 mg/l ⁽³²⁾																			
Sulphate (SO ₄ ²⁻)	1,3–2,0 g/l ⁽³²⁾ ⁽³³⁾ ⁽³⁴⁾ ⁽³⁵⁾																			
Sulphide (S ²⁻), easily released	0,1–0,2 mg/l ⁽³²⁾																			
Sulphite (SO ₃ ²⁻)	1–20 mg/l ⁽³²⁾																			
Metals and metalloids	As 10–50 µg/l																			
	Cd 2–5 µg/l																			
	Cr 10–50 µg/l																			
	Cu 10–50 µg/l																			
	Hg 0,2–3 µg/l																			
	Ni 10–50 µg/l																			
	Pb 10–20 µg/l																			
Zn 50–200 µg/l																				
16	<p>In order to reduce the quantity of waste sent for disposal from the combustion and/or gasification process and abatement techniques, BAT is to organise operations so as to maximise, in order of priority and taking into account life-cycle thinking:</p> <p>(a) waste prevention, e.g. maximise the proportion of residues which arise as by-products;</p> <p>(b) waste preparation for reuse, e.g. according to the specific requested quality criteria;</p> <p>(c) waste recycling;</p> <p>(d) other waste recovery (e.g. energy recovery), by implementing an appropriate combination of techniques such as:</p> <table border="1" data-bbox="255 1225 1234 1262"> <thead> <tr> <th data-bbox="255 1225 472 1262">Technique</th> <th data-bbox="472 1225 891 1262">Description</th> <th data-bbox="891 1225 1234 1262">Applicability</th> </tr> </thead> <tbody> <tr> <td> </td> <td> </td> <td> </td> </tr> </tbody> </table>	Technique	Description	Applicability				CC	<p>The waste hierarchy is applied to all site waste and is under continual review.</p> <p>The following techniques are applied at the installation.</p> <p>b) Bottom ash is either recovered and used within the construction industry.</p> <p>Fly ash is currently sent to landfill. Options for its use as an agricultural fertiliser are being progressed as part of preoperational conditions in the permit.</p> <p>d) A Catalyst Management Plan is also being produced.</p>											
Technique	Description	Applicability																		

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	a.	Generation of gypsum as a by-product	Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g. as raw material in the plasterboard industry). The quality of limestone used in the wet FGD influences the purity of the gypsum produced	Generally applicable within the constraints associated with the required gypsum quality, the health requirements associated to each specific use, and by the market conditions	
	b.	Recycling or recovery of residues in the construction sector	Recycling or recovery of residues (e.g. from semi-dry desulphurisation processes, fly ash, bottom ash) as a construction material (e.g. in road building, to replace sand in concrete production, or in the cement industry)	Generally applicable within the constraints associated with the required material quality (e.g. physical properties, content of harmful substances) associated to each specific use, and by the market conditions	
	c.	Energy recovery by using waste in the fuel mix	The residual energy content of carbon-rich ash and sludges generated by the combustion of coal, lignite, heavy fuel oil, peat or biomass can be recovered for example by mixing with the fuel	Generally applicable where plants can accept waste in the fuel mix and are technically able to feed the fuels into the combustion chamber	
	d.	Preparation of spent catalyst for reuse	Preparation of catalyst for reuse (e.g. up to four times for SCR catalysts) restores some or all of the original performance, extending the service life of the catalyst to several decades. Preparation of spent catalyst for reuse is integrated in a catalyst management scheme	The applicability may be limited by the mechanical condition of the catalyst and the required performance with respect to controlling NO _x and NH ₃ emissions	
17	In order to reduce noise emissions, BAT is to use one or a combination of the techniques given below.			CC	In order to reduce noise at the installation the following techniques are in place: a) Operational measures are in place including: closing of doors, experienced staff, avoidance of noisy activities at night.
	Technique	Description	Applicability		
	a.	Operational measures	These include:		

BAT Concn. Number	Summary of BAT Conclusion requirement				Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
			<ul style="list-style-type: none"> — improved inspection and maintenance of equipment — closing of doors and windows of enclosed areas, if possible — equipment operated by experienced staff — avoidance of noisy activities at night, if possible — provisions for noise control during maintenance activities 			<p>b) Equipment is housed inside a building. The plan equipment is also of modern design.</p> <p>c) Noise attenuation is provided through embankments which are built around the perimeter of the site.</p> <p>d) Noisy equipment is within an enclosed area. Equipment is also insulated in order to minimise noise.</p>
	b.	Low-noise equipment	This potentially includes compressors, pumps and disks	Generally applicable when the equipment is new or replaced		
	c.	Noise attenuation	Noise propagation can be reduced by inserting obstacles between the emitter and the receiver. Appropriate obstacles include protection walls, embankments and buildings	Generally applicable to new plants. In the case of existing plants, the insertion of obstacles may be restricted by lack of space		
	d.	Noise-control equipment	This includes: <ul style="list-style-type: none"> — noise-reducers — equipment insulation — enclosure of noisy equipment — soundproofing of buildings 	The applicability may be restricted by lack of space		
	e.	Appropriate location of equipment and buildings	Noise levels can be reduced by increasing the distance between the emitter and the receiver and by using buildings as noise screens	Generally applicable to new plant		
2.2.1 Table 8	BAT-associated energy efficiency levels (BAT-AEELs) for the combustion of solid biomass and/or peat				CC	The energy efficiency of the plant is 34.6% based upon a contractual performance test conducted on 12/09/17.

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																		
	<table border="1"> <thead> <tr> <th data-bbox="255 442 488 611" rowspan="3">Type of combustion unit</th> <th colspan="4" data-bbox="495 442 1243 480">BAT-AEELs ⁽⁷³⁾ ⁽⁷⁴⁾</th> </tr> <tr> <th colspan="2" data-bbox="495 485 902 539">Net electrical efficiency (%) ⁽⁷⁵⁾</th> <th colspan="2" data-bbox="909 485 1236 539">Net total fuel utilisation (%) ⁽⁷⁶⁾ ⁽⁷⁷⁾</th> </tr> <tr> <th data-bbox="495 544 696 611">New unit ⁽⁷⁸⁾</th> <th data-bbox="703 544 902 611">Existing unit</th> <th data-bbox="909 544 1066 611">New unit</th> <th data-bbox="1072 544 1236 611">Existing unit</th> </tr> </thead> <tbody> <tr> <td data-bbox="255 616 488 676">Solid biomass and/or peat boiler</td> <td data-bbox="495 616 696 676">33,5–to > 38</td> <td data-bbox="703 616 902 676">28–38</td> <td data-bbox="909 616 1066 676">73–99</td> <td data-bbox="1072 616 1236 676">73–99</td> </tr> </tbody> </table>	Type of combustion unit	BAT-AEELs ⁽⁷³⁾ ⁽⁷⁴⁾				Net electrical efficiency (%) ⁽⁷⁵⁾		Net total fuel utilisation (%) ⁽⁷⁶⁾ ⁽⁷⁷⁾		New unit ⁽⁷⁸⁾	Existing unit	New unit	Existing unit	Solid biomass and/or peat boiler	33,5–to > 38	28–38	73–99	73–99		
Type of combustion unit	BAT-AEELs ⁽⁷³⁾ ⁽⁷⁴⁾																				
	Net electrical efficiency (%) ⁽⁷⁵⁾		Net total fuel utilisation (%) ⁽⁷⁶⁾ ⁽⁷⁷⁾																		
	New unit ⁽⁷⁸⁾	Existing unit	New unit	Existing unit																	
Solid biomass and/or peat boiler	33,5–to > 38	28–38	73–99	73–99																	
24	<p>In order to prevent or reduce NO_x emissions to air while limiting CO and N₂O emissions to air from the combustion of solid biomass and/or peat, BAT is to use one or a combination of the techniques given below.</p> <table border="1"> <thead> <tr> <th data-bbox="255 778 528 817">Technique</th> <th data-bbox="535 778 808 817">Description</th> <th data-bbox="815 778 1243 817">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="255 821 293 882">a</td> <td data-bbox="300 821 528 882">Combustion optimisation</td> <td data-bbox="815 821 1243 882" rowspan="5">Generally applicable</td> </tr> <tr> <td data-bbox="255 887 293 948">b</td> <td data-bbox="300 887 528 948">Low-NO_x burners (LNB)</td> </tr> <tr> <td data-bbox="255 952 293 1013">c</td> <td data-bbox="300 952 528 1013">Air staging</td> </tr> <tr> <td data-bbox="255 1018 293 1078">d</td> <td data-bbox="300 1018 528 1078">Fuel staging</td> </tr> <tr> <td data-bbox="255 1083 293 1144">e</td> <td data-bbox="300 1083 528 1144">Flue-gas recirculation</td> </tr> <tr> <td data-bbox="255 1149 293 1318">f</td> <td data-bbox="300 1149 528 1318">Selective non-catalytic reduction (SNCR)</td> <td data-bbox="815 1149 1243 1318">See description in Section 8.3. Can be applied with 'slip' SCR Not applicable to combustion plants operated < 500 h/yr with highly variable boiler loads. The applicability may be limited in the case of combustion plants operated between 500 h/yr and 1 500 h/yr with highly variable boiler loads.</td> </tr> </tbody> </table>	Technique	Description	Applicability	a	Combustion optimisation	Generally applicable	b	Low-NO _x burners (LNB)	c	Air staging	d	Fuel staging	e	Flue-gas recirculation	f	Selective non-catalytic reduction (SNCR)	See description in Section 8.3. Can be applied with 'slip' SCR Not applicable to combustion plants operated < 500 h/yr with highly variable boiler loads. The applicability may be limited in the case of combustion plants operated between 500 h/yr and 1 500 h/yr with highly variable boiler loads.	CC	<p>A Selective Catalytic Reduction (SCR) system is installed in order to control NO_x emissions.</p> <p>See key issues section for more information on AELs.</p>	
Technique	Description	Applicability																			
a	Combustion optimisation	Generally applicable																			
b	Low-NO _x burners (LNB)																				
c	Air staging																				
d	Fuel staging																				
e	Flue-gas recirculation																				
f	Selective non-catalytic reduction (SNCR)	See description in Section 8.3. Can be applied with 'slip' SCR Not applicable to combustion plants operated < 500 h/yr with highly variable boiler loads. The applicability may be limited in the case of combustion plants operated between 500 h/yr and 1 500 h/yr with highly variable boiler loads.																			

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																												
				<p>For existing combustion plants, applicable within the constraints associated with the required temperature window and residence time for the injected reactants</p> <p>g . Selective catalytic reduction (SCR)</p> <p>See description in Section 8.3. The use of high-alkali fuels (e.g. straw) may require the SCR to be installed downstream of the dust abatement system</p> <p>Not applicable to combustion plants operated < 500 h/yr. There may be economic restrictions for retrofitting existing combustion plants of < 300 MW_{th}. Not generally applicable to existing combustion plants of < 100 MW_{th}</p>																													
BAT-associated emission levels (BAT-AELs) for NO_x emissions to air from the combustion of solid biomass and/or peat																																	
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="3" style="text-align: center;">Combustion plant total rated thermal input (MW_{th})</th> <th colspan="4" style="text-align: center;">BAT-AELs (mg/Nm³)</th> </tr> <tr> <th colspan="2" style="text-align: center;">Yearly average</th> <th colspan="2" style="text-align: center;">Daily average or average over the sampling period</th> </tr> <tr> <th style="text-align: center;">New plant</th> <th style="text-align: center;">Existing plant ⁽⁷⁹⁾</th> <th style="text-align: center;">New plant</th> <th style="text-align: center;">Existing plant ⁽⁸⁰⁾</th> </tr> </thead> <tbody> <tr> <td style="text-align: center;">50–100</td> <td style="text-align: center;">70–150 ⁽⁸¹⁾</td> <td style="text-align: center;">70–225 ⁽⁸²⁾</td> <td style="text-align: center;">120–200 ⁽⁸³⁾</td> <td style="text-align: center;">120–275 ⁽⁸⁴⁾</td> </tr> <tr> <td style="text-align: center;">100–300</td> <td style="text-align: center;">50–140</td> <td style="text-align: center;">50–180</td> <td style="text-align: center;">100–200</td> <td style="text-align: center;">100–220</td> </tr> <tr> <td style="text-align: center;">≥ 300</td> <td style="text-align: center;">40–140</td> <td style="text-align: center;">40–150 ⁽⁸⁵⁾</td> <td style="text-align: center;">65–150</td> <td style="text-align: center;">95–165 ⁽⁸⁶⁾</td> </tr> </tbody> </table> <p>As an indication, the yearly average CO emission levels will generally be:</p> <p>— < 30–250 mg/Nm³ for existing combustion plants of 50–100 MW_{th} operated ≥ 1 500 h/yr, or new combustion plants of 50–100 MW_{th},</p>						Combustion plant total rated thermal input (MW _{th})	BAT-AELs (mg/Nm ³)				Yearly average		Daily average or average over the sampling period		New plant	Existing plant ⁽⁷⁹⁾	New plant	Existing plant ⁽⁸⁰⁾	50–100	70–150 ⁽⁸¹⁾	70–225 ⁽⁸²⁾	120–200 ⁽⁸³⁾	120–275 ⁽⁸⁴⁾	100–300	50–140	50–180	100–200	100–220	≥ 300	40–140	40–150 ⁽⁸⁵⁾	65–150	95–165 ⁽⁸⁶⁾
Combustion plant total rated thermal input (MW _{th})	BAT-AELs (mg/Nm ³)																																
	Yearly average		Daily average or average over the sampling period																														
	New plant	Existing plant ⁽⁷⁹⁾	New plant	Existing plant ⁽⁸⁰⁾																													
50–100	70–150 ⁽⁸¹⁾	70–225 ⁽⁸²⁾	120–200 ⁽⁸³⁾	120–275 ⁽⁸⁴⁾																													
100–300	50–140	50–180	100–200	100–220																													
≥ 300	40–140	40–150 ⁽⁸⁵⁾	65–150	95–165 ⁽⁸⁶⁾																													

BAT Conc. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																						
	<p>— < 30–160 mg/Nm³ for existing combustion plants of 100–300 MW_{th} operated ≥ 1 500 h/yr, or new combustion plants of 100–300 MW_{th},</p> <p>— < 30–80 mg/Nm³ for existing combustion plants of ≥ 300 MW_{th} operated ≥ 1 500 h/yr, or new combustion plants of ≥ 300 MW_{th}.</p>																								
25	<p>In order to prevent or reduce SO_x, HCl and HF emissions to air from the combustion of solid biomass and/or peat, BAT is to use one or a combination of the techniques given below.</p> <table border="1" data-bbox="255 651 1236 1281"> <thead> <tr> <th data-bbox="255 651 286 683"></th> <th data-bbox="286 651 528 683">Technique</th> <th data-bbox="528 651 707 683">Description</th> <th data-bbox="707 651 1236 683">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="255 683 286 778">a</td> <td data-bbox="286 683 528 778">Boiler sorbent injection (in-furnace or in-bed)</td> <td data-bbox="528 683 707 778" rowspan="6">See descriptions in Section 8.4</td> <td data-bbox="707 683 1236 1114" rowspan="6">Generally applicable</td> </tr> <tr> <td data-bbox="255 778 286 842">b</td> <td data-bbox="286 778 528 842">Duct sorbent injection (DSI)</td> </tr> <tr> <td data-bbox="255 842 286 906">c</td> <td data-bbox="286 842 528 906">Spray dry absorber (SDA)</td> </tr> <tr> <td data-bbox="255 906 286 1002">d</td> <td data-bbox="286 906 528 1002">Circulating fluidised bed (CFB) dry scrubber</td> </tr> <tr> <td data-bbox="255 1002 286 1066">e</td> <td data-bbox="286 1002 528 1066">Wet scrubbing</td> </tr> <tr> <td data-bbox="255 1066 286 1114">f.</td> <td data-bbox="286 1066 528 1114">Flue-gas condenser</td> </tr> <tr> <td data-bbox="255 1114 286 1281">g</td> <td data-bbox="286 1114 528 1281">Wet flue-gas desulphurisation (wet FGD)</td> <td data-bbox="528 1114 707 1281"></td> <td data-bbox="707 1114 1236 1281">Not applicable to combustion plants operated < 500 h/yr. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr</td> </tr> </tbody> </table>		Technique	Description	Applicability	a	Boiler sorbent injection (in-furnace or in-bed)	See descriptions in Section 8.4	Generally applicable	b	Duct sorbent injection (DSI)	c	Spray dry absorber (SDA)	d	Circulating fluidised bed (CFB) dry scrubber	e	Wet scrubbing	f.	Flue-gas condenser	g	Wet flue-gas desulphurisation (wet FGD)		Not applicable to combustion plants operated < 500 h/yr. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr	CC	<p>The installation uses Duct sorbent injection (DSI) as per point b. in the BAT conclusions.</p> <p>The system used is lime dosing in conjunction with a bag filter.</p> <p>See key issues section for more information on AELs.</p>
	Technique	Description	Applicability																						
a	Boiler sorbent injection (in-furnace or in-bed)	See descriptions in Section 8.4	Generally applicable																						
b	Duct sorbent injection (DSI)																								
c	Spray dry absorber (SDA)																								
d	Circulating fluidised bed (CFB) dry scrubber																								
e	Wet scrubbing																								
f.	Flue-gas condenser																								
g	Wet flue-gas desulphurisation (wet FGD)		Not applicable to combustion plants operated < 500 h/yr. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr																						

BAT Concn. Number	Summary of BAT Conclusion requirement				Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	h Fuel choice		Applicable within the constraints associated with the availability of different types of fuel, which may be impacted by the energy policy of the Member State			
BAT-associated emission levels (BAT-AELs) for SO₂ emissions to air from the combustion of solid biomass and/or peat						
Combustion plant total rated thermal input (MW_{th})		BAT-AELs for SO₂ (mg/Nm³)				
		Yearly average		Daily average or average over the sampling period		
		New plant	Existing plant ⁽⁸⁷⁾	New plant	Existing plant ⁽⁸⁸⁾	
< 100		15–70	15–100	30–175	30–215	
100–300		< 10–50	< 10–70 ⁽⁸⁹⁾	< 20–85	< 20–175 ⁽⁹⁰⁾	
≥ 300		< 10–35	< 10–50 ⁽⁸⁹⁾	< 20–70	< 20–85 ⁽⁹¹⁾	
BAT-associated emission levels (BAT-AELs) for HCl and HF emissions to air from the combustion of solid biomass and/or peat						
Combustion plant total rated thermal input (MW_{th})		BAT-AELs for HCl (mg/Nm³) ⁽⁹²⁾ ⁽⁹³⁾			BAT-AELs for HF (mg/Nm³)	
		Yearly average or average of samples obtained during one year		Daily average or average over the sampling period		Average over the sampling period
		New plant	Existing plant ⁽⁹⁴⁾ ⁽⁹⁵⁾	New plant	Existing plant ⁽⁹⁶⁾	New plant

BAT Conc. Number	Summary of BAT Conclusion requirement							Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																																							
	< 100	1–7	1–15	1–12	1–35	< 1	< 1,5																																									
	100–300	1–5	1–9	1–12	1–12	< 1	< 1																																									
	≥ 300	1–5	1–5	1–12	1–12	< 1	< 1																																									
26	<p>In order to reduce dust and particulate-bound metal emissions to air from the combustion of solid biomass and/or peat, BAT is to use one or a combination of the techniques given below.</p> <table border="1" data-bbox="255 628 1234 1077"> <thead> <tr> <th data-bbox="255 628 286 663"></th> <th data-bbox="293 628 506 663">Technique</th> <th data-bbox="512 628 757 663">Description</th> <th data-bbox="763 628 1234 663">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="255 668 286 703">a</td> <td data-bbox="293 668 506 735">Electrostatic precipitator (ESP)</td> <td data-bbox="512 668 757 735" rowspan="2">See description in Section 8.5</td> <td data-bbox="763 668 1234 735" rowspan="2">Generally applicable</td> </tr> <tr> <td data-bbox="255 740 286 775">b</td> <td data-bbox="293 740 506 775">Bag filter</td> </tr> <tr> <td data-bbox="255 801 286 836">c</td> <td data-bbox="293 801 506 868">Dry or semi-dry FGD system</td> <td data-bbox="512 801 757 868">See descriptions in Section 8.5</td> <td data-bbox="763 801 1234 868" rowspan="2">See applicability in BAT 25</td> </tr> <tr> <td data-bbox="255 873 286 940">d</td> <td data-bbox="293 873 506 940">Wet flue-gas desulphurisation (wet FGD)</td> <td data-bbox="512 873 757 940">The techniques are mainly used for SO_x, HCl and/or HF control</td> </tr> <tr> <td data-bbox="255 960 286 995">e</td> <td data-bbox="293 960 506 995">Fuel choice</td> <td data-bbox="512 960 757 995">See description in Section 8.5</td> <td data-bbox="763 960 1234 1077">Applicable within the constraints associated with the availability of different types of fuel, which may be impacted by the energy policy of the Member State</td> </tr> </tbody> </table> <p data-bbox="293 1107 1196 1161">BAT-associated emission levels (BAT-AELs) for dust emissions to air from the combustion of solid biomass and/or peat</p> <table border="1" data-bbox="255 1161 1234 1331"> <thead> <tr> <th data-bbox="255 1161 584 1331" rowspan="3">Combustion plant total rated thermal input (MW_{th})</th> <th colspan="4" data-bbox="591 1161 1234 1197">BAT-AELs for dust (mg/Nm³)</th> </tr> <tr> <th colspan="2" data-bbox="591 1201 846 1236">Yearly average</th> <th colspan="2" data-bbox="853 1201 1234 1265">Daily average or average over the sampling period</th> </tr> <tr> <th data-bbox="591 1270 689 1331">New plant</th> <th data-bbox="696 1270 846 1331">Existing plant ⁽⁹⁷⁾</th> <th data-bbox="853 1270 1003 1331">New plant</th> <th data-bbox="1010 1270 1234 1331">Existing plant ⁽⁹⁸⁾</th> </tr> </thead> <tbody> <tr> <td data-bbox="255 1335 584 1335"></td> <td data-bbox="591 1335 689 1335"></td> <td data-bbox="696 1335 846 1335"></td> <td data-bbox="853 1335 1003 1335"></td> <td data-bbox="1010 1335 1234 1335"></td> </tr> </tbody> </table>								Technique	Description	Applicability	a	Electrostatic precipitator (ESP)	See description in Section 8.5	Generally applicable	b	Bag filter	c	Dry or semi-dry FGD system	See descriptions in Section 8.5	See applicability in BAT 25	d	Wet flue-gas desulphurisation (wet FGD)	The techniques are mainly used for SO _x , HCl and/or HF control	e	Fuel choice	See description in Section 8.5	Applicable within the constraints associated with the availability of different types of fuel, which may be impacted by the energy policy of the Member State	Combustion plant total rated thermal input (MW _{th})	BAT-AELs for dust (mg/Nm ³)				Yearly average		Daily average or average over the sampling period		New plant	Existing plant ⁽⁹⁷⁾	New plant	Existing plant ⁽⁹⁸⁾						CC	Dust emissions are controlled through the use of a bag filter.
	Technique	Description	Applicability																																													
a	Electrostatic precipitator (ESP)	See description in Section 8.5	Generally applicable																																													
b	Bag filter																																															
c	Dry or semi-dry FGD system	See descriptions in Section 8.5	See applicability in BAT 25																																													
d	Wet flue-gas desulphurisation (wet FGD)	The techniques are mainly used for SO _x , HCl and/or HF control																																														
e	Fuel choice	See description in Section 8.5	Applicable within the constraints associated with the availability of different types of fuel, which may be impacted by the energy policy of the Member State																																													
Combustion plant total rated thermal input (MW _{th})	BAT-AELs for dust (mg/Nm ³)																																															
	Yearly average		Daily average or average over the sampling period																																													
	New plant	Existing plant ⁽⁹⁷⁾	New plant	Existing plant ⁽⁹⁸⁾																																												

BAT Concn. Number	Summary of BAT Conclusion requirement					Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	< 100	2-5	2-15	2-10	2-22		
	100-300	2-5	2-12	2-10	2-18		
	≥ 300	2-5	2-10	2-10	2-16		
27	In order to prevent or reduce mercury emissions to air from the combustion of solid biomass and/or peat, BAT is to use one or a combination of the techniques given below.					CC	<p>The following techniques are in place at the installation in order to control mercury emissions.</p> <p>The operator plans to reduce mercury emissions through fuel choice. There is secondary abatement in place in the form of a bag filter.</p> <p>The installation does not currently measure mercury but will do so by June 2021 in order to comply with the BAT conclusions.</p>
Technique			Description		Applicability		
Specific techniques to reduce mercury emissions							
a	Carbon sorbent (e.g. activated carbon or halogenated activated carbon) injection in the flue-gas	See descriptions in Section 8.5	Generally applicable				
b	Use of halogenated additives in the fuel or injected in the furnace		Generally applicable in the case of a low halogen content in the fuel				
c	Fuel choice		Applicable within the constraints associated with the availability of different types of fuel, which may be impacted by the energy policy of the Member State				
Co-benefit from techniques primarily used to reduce emissions of other pollutants							
d	Electrostatic precipitator (ESP)	See descriptions in Section 8.5.	Generally applicable				
e	Bag filter	The techniques are mainly used for dust control					

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	f.	Dry or semi-dry FGD system	See descriptions in Section 8.5.		
	g.	Wet flue-gas desulphurisation (wet FGD)	The techniques are mainly used for SO _x , HCl and/or HF control	See applicability in BAT 25	
	The BAT-associated emission level (BAT-AEL) for mercury emissions to air from the combustion of solid biomass and/or peat is < 1–5 µg/Nm ³ as average over the sampling period.				

6. Review and assessment of derogation requests made by the operator in relation to BAT Conclusions which include an associated emission level (AEL) value

The IED enables a competent authority to allow derogations from BAT AELs stated in BAT Conclusions under specific circumstances as detailed under Article 15(4):

By way of derogation from paragraph 3, and without prejudice to Article 18, the competent authority may, in specific cases, set less strict emission limit values. Such a derogation may apply only where an assessment shows that the achievement of emission levels associated with the best available techniques as described in BAT conclusions would lead to disproportionately higher costs compared to the environmental benefits due to:

(a) the geographical location or the local environmental conditions of the installation concerned; or

(b) the technical characteristics of the installation concerned.

As part of their Regulation 61 Note response, the operator has not requested a derogation from compliance with any AEL values.

7. Emissions to Water

The consolidated permit incorporates the current discharge to controlled waters identified as W1 for process effluent and introduces W2 for uncontaminated surface water

The operator submitted proposals to change the discharge route for effluent from the sewer to surface water in variation EPR/AP3037FL/V004. The discharge to surface water was assessed for hazardous pollutants and sanitary determinands in accordance with Environment agency guidance for hazardous pollutants – following the same steps as the H1. The conclusion of the assessment was that there would be no significant deterioration of the receiving watercourse.

The Water Framework Directive was also taken into account and it was concluded that the level of pollutants would not exceed those required in order to main the "Good" ecological/Water Framework Directive status of the River Thet.

We have also identified that a discharge of surface water is also made to the ditch network to the North of the facility. Details of the discharge are documented in prior application documents however had not been formally incorporated into the permit. The Operator has confirmed that there is no process effluent discharging to this part of the drainage system, the water comprises rainwater run-off from roofs and roadways, and the generator SUT pit. Water from roadways and the SUT pit passes through an interceptor prior to entering a retention pond which subsequently discharges to a ditch via a hydrobrake. We are satisfied there is no significant risk to controlled waters, however have introduced a monthly visual inspection for oil/grease, which has been incorporated as W2 in table S3.2 of the permit.

8. Additional IED Chapter II requirements:

Black Start Operation

In the event of a black out National Grid would call on combustion plant to operate and may require them to do so outside their permitted conditions. We have dedicated black start plant and they are permitted to run as such but this scenario is relevant to the rest of the large combustion plant which could be called depending on the circumstances.

A risk assessment will be carried out by Energy UK/Joint Environmental Programme on behalf of Large Combustion Plant connected to the National Transmission System. Air emissions modelling will be based on generic black start scenarios to establish whether they have the potential to have local impact on the environment or not (on a national basis). If the modelling demonstrates that no significant impacts are likely, the plant can operate under condition 2.3.7. This conditions allows the hourly ELVs for plants operating under a black start instruction to be discounted for the purpose of reporting. We would also require there to be a procedure in place for minimisation of emissions in the case of a black start event and for reporting in the event of a black start. This modelling and the procedures have not been agreed in advance of the issue of the permit review and therefore a condition linking back to an improvement condition have been included in the permit.

Start up and shut down Criteria

Table S1.4 has been updated to reflect the temporary start up and shut down criteria agreed for the site. Improvement condition IC7 requires a future review of the criteria submitted.

9. Review and assessment of changes that are not part of the BAT Conclusions derived permit review.

This document should be read in conjunction with the application, supporting information and notice.

Aspect considered	Decision
Receipt of application	
Confidential information	A claim for commercial or industrial confidentiality has not been made.
Identifying confidential information	We have not identified information provided as part of the application that we consider to be confidential.
The facility	
The regulated facility	<p>We considered the extent and nature of the facility at the site in accordance with RGN2 'Understanding the meaning of regulated facility', Appendix 2 of RGN 2 'Defining the scope of the installation', Appendix 1 of RGN 2 'Interpretation of Schedule 1', guidance on waste recovery plans and permits.</p> <p>The extent of the facility is defined in the site plan and in the permit. We have updated the plan referred to in Schedule 7 to include the effluent pipeline to W1, and clearly labelled the emission points. The activities are defined in table S1.1 of the permit.</p> <p>The emergency diesel generator (477kW) has been incorporated under the S1.1 activity in the permit. It no longer appears as a Directly Associated Activity.</p>
Operating techniques	
General operating techniques	<p>We have reviewed the techniques used by the operator where they are relevant to the BAT Conclusions and compared these with the relevant guidance notes.</p> <p>The permit conditions ensure compliance with the relevant BREF, BAT Conclusions. The ELVs deliver compliance with the BAT-AELs.</p>
Improvement programme	<p>Based on the information on the application, we consider that we need to impose an improvement programme.</p> <p>We have imposed an improvement programme to ensure that:</p> <ul style="list-style-type: none"> the operator will have a plan in place to ensure that the fuel is characterised in line with BAT 9.

Aspect considered	Decision
	We have also removed the completed improvement conditions from the permit.
Permit conditions	
Updating permit conditions during consolidation	We have updated permit conditions to those in the current generic permit template as part of permit consolidation. The conditions will provide at least the same level of protection as those in the previous permit and in some cases will provide a higher level of protection to those in the previous permit.
Changes to the permit conditions due to an Environment Agency initiated variation	We have varied the permit as stated in the variation notice.
Improvement programme	<p>Based on the information on the application, we consider that we need to impose an improvement condition.</p> <p>We have imposed an improvement condition to ensure that: The operator complies with the requirements of BAT9. The parameters F, K, Na and Metals and Metalloids (As, Cd, Co, Cr, Cu, Mn, Ni, Pb, Sb, Se, Tl, V and Zn) are not currently monitored. The operator is required to submit a procedure for approval outlining how they will be monitored.</p>
Emission limits	<p>We have decided that emission limits should be set for the parameters listed in the permit.</p> <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p> <p>It is considered that the ELVs/equivalent parameters or technical measures described above will ensure that significant pollution of the environment is prevented and a high level of protection for the environment is secured.</p>
Monitoring	<p>We have decided that monitoring should be carried out for the parameters listed in the permit, using the methods detailed and to the frequencies specified.</p> <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p> <p>Table S3.3 Process monitoring requirements was added to include the requirement to monitor energy efficiency.</p>
Reporting	<p>We have specified reporting in the permit for the following parameters:</p> <ul style="list-style-type: none"> • Nitrogen dioxide • Carbon monoxide • Sulphur dioxide

Aspect considered	Decision
	<ul style="list-style-type: none"> • Hydrogen Chloride • Hydrogen Fluoride • Dust • Ammonia • Mercury <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p>
Operator competence	
Management system	There is no known reason to consider that the operator will not have the management system to enable it to comply with the permit conditions.
Growth Duty	
Section 108 Deregulation Act 2015 – Growth duty	<p>We have considered our duty to have regard to the desirability of promoting economic growth set out in section 108(1) of the Deregulation Act 2015 and the guidance issued under section 110 of that Act in deciding whether to grant this permit.</p> <p>Paragraph 1.3 of the guidance says:</p> <p>“The primary role of regulators, in delivering regulation, is to achieve the regulatory outcomes for which they are responsible. For a number of regulators, these regulatory outcomes include an explicit reference to development or growth. The growth duty establishes economic growth as a factor that all specified regulators should have regard to, alongside the delivery of the protections set out in the relevant legislation.”</p> <p>We have addressed the legislative requirements and environmental standards to be set for this operation in the body of the decision document above. The guidance is clear at paragraph 1.5 that the growth duty does not legitimise non-compliance and its purpose is not to achieve or pursue economic growth at the expense of necessary protections.</p> <p>We consider the requirements and standards we have set in this permit are reasonable and necessary to avoid a risk of an unacceptable level of pollution. This also promotes growth amongst legitimate operators because the standards applied to the operator are consistent across businesses in this sector and have been set to achieve the required legislative standards.</p>