

## Environment Agency

# **Review of an Environmental Permit for an Installation subject to Chapter II of the Industrial Emissions Directive under the Environmental Permitting (England & Wales) Regulations 2016**

## **Decision document recording our decision-making process following review of a permit**

The Permit number is: EPR/HP3939LN  
The Operator is: Medway Power Limited  
The Installation is: Medway Power Station  
This Variation Notice number is: EPR/HP3939LN/V004

### **What this document is about**

Article 21(3) of the Industrial Emissions Directive (IED) requires the Environment Agency to review conditions in permits that it has issued and to ensure that the permit delivers compliance with relevant standards, within four years of the publication of updated decisions on best available techniques (BAT) conclusions.

We have reviewed the permit for this installation against the revised BAT Conclusions for large combustion plant published on 17<sup>th</sup> August 2017. This is our decision document, which explains the reasoning for the consolidated variation notice that we are issuing.

It explains how we have reviewed and considered the techniques used by the Operator in the operation and control of the plant and activities of the installation. This review has been undertaken with reference to the decision made by the European Commission establishing best available techniques (BAT) conclusions ('BAT Conclusions') for large combustion plant as detailed in document reference IEDC-7-1. It is our record of our decision-making process and shows how we have taken into account all relevant factors in reaching our position. It also provides a justification for the inclusion of any specific conditions in the permit that are in addition to those included in our generic permit template.

As well as considering the review of the operating techniques used by the Operator for the operation of the plant and activities of the installation, the consolidated variation notice takes into account and brings together in a single document all previous variations that relate to the original permit

issued. It also modernises the entire permit to reflect the conditions contained in our current generic permit template.

The introduction of new template conditions makes the Permit consistent with our current general approach and philosophy and with other permits issued to installations in this sector. Although the wording of some conditions has changed, while others have been removed because of the new regulatory approach, it does not reduce the level of environmental protection achieved by the Permit in any way. In this document we therefore address only our determination of substantive issues relating to the new BAT Conclusions.

This is our record of our decision-making process and shows how we have taken into account all relevant factors in reaching our position.

We try to explain our decision as accurately, comprehensively and plainly as possible. We would welcome any feedback as to how we might improve our decision documents in future. A lot of technical terms and acronyms are inevitable in a document of this nature: we provide a glossary of acronyms near the front of the document, for ease of reference.

## How this document is structured

### Glossary of terms

- 1 Our decision
- 2 How we reached our decision
  - 2.1 Requesting information to demonstrate compliance with BAT Conclusions for Large Combustion Plant
  - 2.2 Review of our own information in respect to the capability of the installation to meet revised standards included in the BAT Conclusions document
- 3 The legal framework
- 4 Key Issues
  - 4.1 Emissions to air and the emission limits applied to the plant
  - 4.2 The energy efficiency levels associated with the Best Available Techniques Conclusions
  - 4.3 Effective Dry Low NO<sub>x</sub> point
  - 4.4 Characterisation of Fuel
- 5 Decision checklist regarding relevant BAT Conclusions
- 6 Emissions to Water
- 7 Additional IED Chapter II requirements
- 8 Review and assessment of changes that are not part of the BAT Conclusions derived permit review.

## Glossary of acronyms used in this document

(Please note that this glossary is standard for our decision documents and therefore not all these acronyms are necessarily used in this document.)

APC	Air Pollution Control
BAT	Best Available Technique(s)
BAT-AEEL	BAT Associated Energy Efficiency Level
BAT-AEL	BAT Associated Emission Level
BATc	BAT conclusion
BREF	Best available techniques reference document
CCGT	Combined Cycle Gas Turbine
CEM	Continuous emissions monitor
CHP	Combined heat and power
CV	Calorific value
DAA	Directly associated activity – Additional activities necessary to be carried out to allow the principal activity to be carried out
DLN	Dry Low NOx burners
DLN-E	Dry Low NOx effective
EIONET	European environment information and observation network is a partnership network of the European Environment Agency
ELV	Emission limit value derived under BAT or an emission limit value set out in IED
EMS	Environmental Management System
EPR	Environmental Permitting (England and Wales) Regulations 2016 (SI 2016 No. 1154)
EWC	European waste catalogue
FSA	Food Standards Agency
IC	Improvement Condition
IED	Industrial Emissions Directive (2010/75/EU)
IPPCD	Integrated Pollution Prevention and Control Directive (2008/1/EC) – now superseded by IED
LCP	Large Combustion Plant subject to Chapter III of IED
MSUL/MSDL	Minimum start up load/minimum shut-down load
NOx	Oxides of nitrogen (NO plus NO <sub>2</sub> expressed as NO <sub>2</sub> )
NPV	Net Present Value
PHE	Public Health England
SAC	Special Area of Conservation
SGN	Sector guidance note
TGN	Technical guidance note
TNP	Transitional National Plan
TOC	Total Organic Carbon
WFD	Water Framework Directive (2000/60/EC)

## 1 Our decision

We have decided to issue the consolidated variation notice to the Operator. This will allow it to continue to operate the Installation, subject to the conditions in the consolidated variation notice.

We consider that, in reaching that decision, we have taken into account all relevant considerations and legal requirements and that the varied permit will ensure that a high level of protection is provided for the environment and human health.

The consolidated variation notice contains many conditions taken from our standard Environmental Permit template including the relevant Annexes. We developed these conditions in consultation with industry, having regard to the legal requirements of the Environmental Permitting Regulations and other relevant legislation. This document does not therefore include an explanation for these standard conditions. Where they are included in the Notice, we have considered the techniques identified by the operator for the operation of their installation, and have accepted that the details are sufficient and satisfactory to make those standard conditions appropriate. This document does, however, provide an explanation of our use of “tailor-made” or installation-specific conditions, or where our Permit template provides two or more options.

## 2 How we reached our decision

### 2.1 Requesting information to demonstrate compliance with BAT Conclusions for Large Combustion Plant

We issued a Notice under Regulation 61(1) of the Environmental Permitting (England and Wales) Regulations 2016 (a Regulation 61 Notice) on 1<sup>st</sup> May 2018 requiring the Operator to provide information to demonstrate how the operation of their installation currently meets, or will subsequently meet, the revised standards described in the large combustion plant BAT Conclusions document. The Notice also required that where the revised standards are not currently met, the operator should provide information that:

- Describes the techniques that will be implemented before 17<sup>th</sup> August 2021, which will then ensure that operations meet the revised standard, or
- Justifies why standards will not be met by 17<sup>th</sup> August 2021, and confirmation of the date when the operation of those processes will cease within the installation or an explanation of why the revised BAT standard is not applicable to those processes, or
- Justifies why an alternative technique will achieve the same level of environmental protection equivalent to the revised standard described in the BAT Conclusions.

Where the Operator proposed that they were not intending to meet a BAT standard that also included a BAT Associated Emission Level (BAT AEL) described in the BAT Conclusions Document, the Regulation 61 Notice requested that the Operator make a formal request for derogation from compliance with that AEL (as provisioned by Article 15(4) of IED). In this circumstance, the Notice identified that any such request for derogation must be supported and justified by sufficient technical and commercial information that would enable us to determine acceptability of the derogation request.

The Regulation 61 Notice response from the Operator was received on 1<sup>st</sup> November 2018.

We considered that the response did not contain sufficient information for us to commence the permit review. We therefore issued a further information request to the Operator on 31/10/2019 and 25/02/20. Suitable further information was provided by the Operator on 29/11/19 and 03/03/20.

We have not received any information in relation to the Regulation 61 Notice response that appears to be confidential in relation to any party.

## **2.2 Review of our own information in respect to the capability of the installation to meet revised standards included in the BAT Conclusions document**

Based on our records and previous regulatory activities with the facility we have no reason to consider that the operator will not be able to comply with the conditions that we include in the permit.

In relation to BAT Conclusion 4 we agree with the operator in respect to their current stated capability as recorded in their Regulation 61 Notice response that improvements are required so that the requirements of the BAT Conclusion are delivered by 17 August 2021. This is discussed in more detail in the key issues section and/or in the decision checklist regarding relevant BAT Conclusions.

### 3 The legal framework

The consolidated variation notice will be issued under Regulation 20 of the EPR. The Environmental Permitting regime is a legal vehicle which delivers most of the relevant legal requirements for activities falling within its scope. In particular, the regulated facility is:

- an *installation* as described by the IED;
- subject to aspects of other relevant legislation which also have to be addressed.

We consider that the consolidated variation notice will ensure that the operation of the Installation complies with all relevant legal requirements and that a high level of protection will be delivered for the environment and human health.

We explain how we have addressed specific statutory requirements more fully in the rest of this document.

## 4 The key issues

The key issues arising during this permit review are:

- Emissions to air and the emission limits applied to the plant.
- The energy efficiency levels associated with the Best Available Techniques (BAT-AEELs)
- Effective Dry Low NO<sub>x</sub> point.
- Characterisation of fuel - gas turbines operating on gas oil

We therefore describe how we determined these issues in most detail in the relevant sections of this document.

### 4.1 Emissions to air and the emission limits applied to the plant

A number of general principles were applied during the permit review. These included:

- The upper value of the BAT AELs ranges specified were used unless use of the tighter limit was justified.
- The principle of no backsliding where if existing limits in the permit were already tighter than those specified in the BREF, the existing permit limits were retained.
- Where a limit was specified in both IED Annex V and the BAT Conclusions for a particular reference period, the tighter limit was applied and in the majority of cases this was from the BAT Conclusions.
- Where AELs are indicative in the BAT Conclusions, these were applied unless adequate justification was provided by the operator to demonstrate that an alternative limit was more appropriate.
- For gas turbines where the IED specified that limits applied over 70% load and the BAT Conclusions specified that AELs applied when dry low NO<sub>x</sub> is effective (DLN-E), we have used DLN-E as a default across all monitoring requirements for NO<sub>x</sub> and CO.

The LCPs on site consist of LCP 218 a 755MWth combined cycle gas turbine (CCGT) and LCP 219 a 755 MWth CCGT.

The plant was put into operation before IED came into force and therefore the existing limits in the permit are from Part 1 of IED Annex V applicable to existing plant.

The ELVs and AELs are based on the following operating regime:

- Unlimited hours operation
- >600MWth input; and
- <75% efficiency.



The following tables outline the limits that have been incorporated into the permit for LCP218 and LCP 219, where these were derived from and the reference periods at which they apply. The emission limits refer to concentrations, expressed as mass of emitted substance per volume of flue-gas under the following standard conditions: dry gas at a temperature of 273,15 K, pressure of 101,3 kPa and 15% volume reference oxygen concentration of flue gases. The emission limits and monitoring requirements have been incorporated into Schedule 3 of the permit.

An additional daily limit from start up/shut down to baseload has been added to the post BREF implementation table S3.1a. Although this is not a regulatory requirement, it was requested by the Emissions Methodology Working Group of the Joint Environmental Protocol to ensure consistency across the sites.

Annex V of IED states that the ELVs apply from 70% to baseload for gas turbines. As this site already complies with the limits from the end of start up to baseload we have not amended the references in table S3.1 as the limits are applicable at the end of start up which is equivalent to 35% load and therefore already compliant with IED.

The Operator is under the Transitional National Plan (TNP) route. By the end of the TNP on 30 June 2020, as a minimum plant must meet the limits set out in Annex V of the Industrial Emission Directive subject to BAT assessment and the principle of no backsliding. From the implementation date of the BAT Conclusion in 2021 the relevant AELs will also apply.

NOx limits (mg/Nm <sup>3</sup> ) when firing on gas							
Averaging	Current under TNP	IED (Annex V Part 1)	BREF (Table 24 BAT-c)	Expected permit limits	Basis	Limits apply	Monitoring
Annual	None	None	40	40	BREF	E-DLN	Continuous
Monthly	50	50	None	50	IED	E-DLN	
Daily	50	50	50	50	BREF/Existing	E-DLN	
95 <sup>th</sup> %ile of hr means	100	100	None	100	IED	E-DLN	

Annual NOx limit has been set as 40 mg/Nm<sup>3</sup>. This has been set based upon an energy efficiency figure of 54.2%.

Daily NOx limit has been set as 50 mg/Nm<sup>3</sup> for MSUL/MSDL to baseload and we accept that this is appropriate for this type of plant.

The monthly emission limit of 50 mg/m<sup>3</sup> was already set so that there is no backsliding in emission limits this has been retained in the permit.

CO limits (mg/Nm <sup>3</sup> ) when firing on Gas							
Averaging	Current	IED (Annex V Part 1) - Existing	BREF (after Table 24 BAT- c)	Expec- ted permit limits	Basis	Limits apply	Monitoring
<b>Annual</b>	None	None	30	50	Aligned to Monthly	E-DLN	Continuous
<b>Monthly</b>	50	50	None	50	Current/ No backsliding rule	E-DLN	
<b>Daily</b>	50	55	None	50	Current/ No backsliding rule	E-DLN	
<b>95<sup>th</sup> %ile of hr means</b>	100	100	None	100	IED	E-DLN	

The operator has requested an annual emission limit for emissions of CO of 100 mg/m<sup>3</sup>. This is higher than the indicative BAT-AEL of 30 mg/m<sup>3</sup>. The operator has provided a justification based on the technical characteristics of the installed GE gas turbines. We consider the technical justification provided is adequate but on the basis of no backsliding we have set the annual emission limit for CO at 50 mg/m<sup>3</sup> in the revised and consolidated permit. See section 4.3 for more details.

### LCP 218 and LCP219 – Firing on gas oil

The operator normally uses gas and has applied to retain the use of gas oil as an alternative fuel. Condition 2.3.6 allows gas oil to be used for periods of up to 10 days during times of interruption to the gas supply.

Joint Environmental Programme (JEP) produced a document 'BAT Assessment for Existing Gas and Liquid Fuel Fired OCGTs, CCGTs and Dual-fuel GTs with a Thermal Input Rating of 50MWth or Greater Operating <500 Hours Per Year' dated October 2018. The content of this document has been agreed in principle by the Environment Agency and we have therefore taken the document into account during our determination of this variation.

There are no BAT AEL's for NO<sub>2</sub> or CO and the current limits have been retained. In line with table 22 of BAT Conclusion 36 for existing plants operated < 500 h/yr we have set indicative BAT AEL's in Table 22 for SO<sub>2</sub> and dust.

The existing permit sets a dust limit of 20 mg/m<sup>3</sup> when operating on distillate fuel, we have reduced this to 10 mg/m<sup>3</sup> in the new permit. Continuous dust monitoring (for >100MWth plant) has been required when oil firing, and to be reported as a daily mean of validated hourly averages.

#### 4.2 The energy efficiency levels associated with the Best Available Techniques Conclusions

An energy efficiency level associated with the best available techniques (BAT-AEEL) refers to the ratio between the combustion unit's net energy output(s) and the combustion unit's fuel/feedstock energy input at actual unit design. The net energy output(s) is determined at the combustion unit boundaries, including auxiliary systems (e.g. flue-gas treatment systems), and for the unit operated at full load.

The table below sets out the BAT-AEELs specified in the LCP BAT Conclusions for the large combustion plant on the site and the energy efficiency levels confirmed through the Regulation 61 notice response. The evidence provided to demonstrate that the AEELs are met was in the form of the guarantee of performance test reports for the 2 gas turbines undertaken in 2016, Report "Medway: Baseload Output and Efficiency Benchmark March 2016 Technical Note No: TN-GEN-AM-COMM-477-019 issued 12/04/2016". We consider this plant is BAT in relation to the AEELs.

BAT AEELs (%)			Plant efficiency (%)		
Net electrical efficiency	Net total fuel utilisation	Net mechanical efficiency	Net electrical efficiency	Net total fuel utilisation	Net mechanical efficiency
<b>LCP218: &gt;=600 MWth CCGT – existing plant</b>					
50-60	None	None	54.2%	NA	NA
<b>LCP219: &gt;=600 MWth CCGT- existing plant</b>					
50-60	None	None	54.2%	NA	NA

#### BAT-associated energy efficiency levels (BAT-AEELs) for gas-oil-fired gas turbines

Table 21 of the LCP BAT Conclusions specifies that the BAT-AEELs for this type of plant are not applicable to plant operating less than 1500 hours per year.

### **4.3 Effective Dry Low NO<sub>x</sub> point.**

The operator provided Dry Low NO<sub>x</sub> (DLN) curves for NO<sub>x</sub> and CO. The eDLN point put forward by the operator was 90MW, 35%. We requested the operator justify retention of their current ELV's for CO for LCP 218 and 219 of 100 mg/m<sup>3</sup> as the curves suggested a lower limit was possible. The operator provided the following response on 03/03/20 to our request.

At Medway the combustion gas is preheated prior to firing in the combustion turbines; this is a major factor in reducing NO<sub>x</sub> emissions. Ambient conditions also play a role in NO<sub>x</sub> formation with higher winter emissions due to lower temperatures. This requires that combustion turbines are tuned to optimise their performance to deal with ambient conditions and to protect downstream assets e.g. the heat recovery steam generator (HRSG). Due to the extreme variation in heating and cooling rates, the temperature of the exhaust gas entering the HRSG can lead to metal fatigue and asset failure resulting in downtime to complete necessary repairs. CO levels are highly susceptible to the tuning process with the potential for significant increases in the exhaust gas in contrast to NO<sub>x</sub> levels which are relatively stable. When tuning it is essential that Medway has the latitude to operate and protect its assets, whilst meeting its environmental obligations.

### **4.4 Fuel characterisation -BAT Conclusion 9**

BAT 9 requires the operator to carry out fuel characterisation. We consider that for plants which burn natural gas from the National Grid as a fuel that it is not necessary for the operator to replicate the testing carried out by the National Grid. Where gas oil is used as a standby fuel then BAT 9 would apply.

We have therefore incorporated the Joint Environmental Programme (JEP) report – 'Characterisation of power plant fuels for compliance with LCP BREF Conclusion BAT 9' issued October 2019 into table S1.2 of the permit. This document sets out how this will be carried out prior to the implementation date for the BAT Conclusions.

The Operator confirmed in their response received 04/06/2020, that they will adhere to the requirements of this BAT Conclusion through application of the JEP report.

## 5 Decision checklist regarding relevant BAT Conclusions

BAT Conclusions for large combustion plant, were published by the European Commission on 17<sup>th</sup> August 2017. There are 75 BAT Conclusions. Only the BAT Conclusions relevant to the particular fuel type used on site have been replicated below.

This annex provides a record of decisions made in relation to each relevant BAT Conclusion applicable to the installation. This annex should be read in conjunction with the Consolidated Variation Notice.

The conditions in the permit through which the relevant BAT Conclusions are implemented include but are not limited to the following:

BAT Conclusion requirement topic	Permit condition(s)	Permit table(s)
Environmental Management System	1.1.1	S1.2
BAT AELs	3.1.1 and 3.5.1	S3.1a
Monitoring	2.3, 3.5 and 3.6	S1.2, S1.4, S1.5 and S3.1a
Energy efficiency	1.2 and 2.3	S3.4
Noise	3.4 and 2.3	S2.1
Other operating techniques	1.2	S1.2

The overall status of compliance with the BAT conclusion is indicated in the table as:

- NA Not Applicable
- CC Currently Compliant
- FC Compliant in the future (within 4 years of publication of BAT conclusions)
- NC Not Compliant
- PC Partially Compliant

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
<b>General</b>			
1	<p><b>In order to improve the overall environmental performance, BAT is to implement and adhere to an environmental management system (EMS) that incorporates all of the following features:</b></p> <ul style="list-style-type: none"> <li>i. commitment of the management, including senior management;</li> <li>ii. definition of an environmental policy that includes the continuous improvement of the installation by the management;</li> <li>iii. planning and establishing the necessary procedures, objectives and targets, in conjunction with financial planning and investment;</li> <li>iv. implementation of procedures <ul style="list-style-type: none"> <li>(a) Structure and responsibility</li> <li>(b) Training</li> <li>(c) Communication</li> <li>(d) Employee involvement</li> <li>(e) Documentation</li> <li>(f) Efficient process control</li> <li>(g) Maintenance programmes</li> <li>(h) Emergency preparedness and response</li> <li>(i) Safeguarding compliance with environmental legislation</li> </ul> </li> <li>v. checking performance and taking corrective action, paying particular attention to: <ul style="list-style-type: none"> <li>(a) monitoring and measurement (see also the Reference Document on the General Principles of Monitoring)</li> <li>(b) corrective and preventive action</li> <li>(c) maintenance of records</li> <li>(d) independent (where practicable) internal and external auditing in order to determine whether or not the EMS conforms to planned arrangements and has been properly implemented and maintained;</li> </ul> </li> <li>vi. review of the EMS and its continuing suitability, adequacy and effectiveness by senior management;</li> <li>vii. following the development of cleaner technologies;</li> <li>viii. consideration for the environmental impacts from the eventual decommissioning of the installation at the stage of designing a new plant, and throughout its operating life;</li> <li>viii. consideration for the environmental impacts from the eventual decommissioning of the installation at the stage of designing a new plant, and throughout its operating life;</li> </ul>	CC	<p>EMS in place registered to ISO 14001:2015, this standard meets the requirements of the BAT 1. Its scope and nature is appropriate to the Medway installation and its range of environmental impacts. Main certificate: GB 17/873624.00</p>

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement													
	ix. application of sectoral benchmarking on a regular basis. Etc - see BAT Conclusions  <b>Applicability.</b> The scope (e.g. level of detail) and nature of the EMS (e.g. standardised or non-standardised) will generally be related to the nature, scale and complexity of the installation, and the range of environmental impacts it may have.															
2	BAT is to determine the net electrical efficiency and/or the net total fuel utilisation and/or the net mechanical energy efficiency of the gasification, IGCC and/or combustion units by carrying out a performance test at full load (1), according to EN standards, after the commissioning of the unit and after each modification that could significantly affect the net electrical efficiency and/or the net total fuel utilisation and/or the net mechanical energy efficiency of the unit. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.	CC	Performance analysis from March 2016 determined station thermal efficiency at 54.2%. Tests are undertaken following works which are likely to impact efficiency or performance.  Testing is based on standards ISO 2314 and ASME PTC 46."													
3	<b>BAT is to monitor key process parameters relevant for emissions to air and water including those given below.</b> <table border="1" data-bbox="338 863 1117 1110"> <thead> <tr> <th data-bbox="338 863 580 895">Stream</th> <th data-bbox="580 863 871 895">Parameter(s)</th> <th data-bbox="871 863 1117 895">Monitoring</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 895 580 1050" rowspan="3">Flue-gas</td> <td data-bbox="580 895 871 954">Flow</td> <td data-bbox="871 895 1117 954">Periodic or continuous determination</td> </tr> <tr> <td data-bbox="580 954 871 1013">Oxygen content, temperature, and pressure</td> <td data-bbox="871 954 1117 1013">Periodic or continuous measurement</td> </tr> <tr> <td data-bbox="580 1013 871 1050">Water vapour content (%)</td> <td data-bbox="871 1013 1117 1050"></td> </tr> <tr> <td data-bbox="338 1050 580 1110">Waste water from flue-gas treatment</td> <td data-bbox="580 1050 871 1110">Flow, pH, and temperature</td> <td data-bbox="871 1050 1117 1110">Continuous measurement</td> </tr> </tbody> </table>	Stream	Parameter(s)	Monitoring	Flue-gas	Flow	Periodic or continuous determination	Oxygen content, temperature, and pressure	Periodic or continuous measurement	Water vapour content (%)		Waste water from flue-gas treatment	Flow, pH, and temperature	Continuous measurement	CC	<u>Process parameters for emissions to air:</u>  The applicant has confirmed that all the flue gas process parameters that are relevant to gas fired turbines as set out in BAT3 are undertaken and are set out in the current environmental permit Table S3.1.  Continuous monitoring of stack flow, oxygen, water vapour, stack gas temperature, and stack gas pressure for the CCGT gas turbines is specified in Table S3.1a  <u>In respect of process parameters for emissions to water</u>  The site does not have FG treatment fitted the parameters are not applicable.  No waste water from flue gas treatment"
Stream	Parameter(s)	Monitoring														
Flue-gas	Flow	Periodic or continuous determination														
	Oxygen content, temperature, and pressure	Periodic or continuous measurement														
	Water vapour content (%)															
Waste water from flue-gas treatment	Flow, pH, and temperature	Continuous measurement														
4	BAT is to monitor emissions to air with at least the frequency given below and in accordance with EN standards. If EN standards are not available,	CC	The operator confirmed that continuous monitoring of NOx and CO plus Oxygen is undertaken to EN14181 for the gas turbine when firing on gas. Other parameters are not applicable to this plant.													

BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.							<p>We agree with the Operator's stated compliance.</p> <p>However, the GT are able to burn gas oil should the gas supply be interrupted. Where gas oil fuel is used then continuous monitoring of sulphur dioxide and dust would be required.</p> <p>Continuous monitoring of dust is already specified in the permit is when gas turbines are fired on distillate fuel. SO<sub>2</sub> monitoring is currently required at least every 6 months by concentration by calculation, as agreed in writing with the Environment Agency and that this be retained in line with footnotes (8)</p> <p>(8) As an alternative to the continuous measurement in the case of plants combusting oil with a known sulphur content and where there is no flue- gas desulphurisation system, periodic measurements at least once every three months and/or other procedures ensuring the provision of data of an equivalent scientific quality may be used to determine the SO<sub>2</sub> emissions.</p> <p>We agree and have retained the current SO<sub>2</sub> monitoring regime See BAT 39.</p>
	Substance/Parameter	Fuel/Process/Type of combustion plant	Combustion plant total rated thermal input	Standard(s) <sup>(4)</sup>	Minimum monitoring frequency <sup>(5)</sup>	Monitoring associated with		
NH <sub>3</sub>	— When SCR and/or SNCR is used	All sizes	Generic EN standards	Continuous <sup>(6)</sup> <sub>(7)</sub>	BAT 7			
NO <sub>x</sub>	<ul style="list-style-type: none"> <li>— Coal and/or lignite including waste co-incineration</li> <li>— Solid biomass and/or peat including waste co-incineration</li> <li>— HFO- and/or gas-oil-fired boilers and engines</li> <li>— Gas-oil-fired gas turbines</li> <li>— Natural-gas-fired boilers, engines, and turbines</li> <li>— Iron and steel process gases</li> <li>— Process fuels from the chemical industry</li> <li>— IGCC plants</li> </ul>	All sizes	Generic EN standards	Continuous <sup>(6)</sup> <sub>(8)</sub>	BAT 20 BAT 24 BAT 28 BAT 32 BAT 37 BAT 41 BAT 42 BAT 43 BAT 47 BAT 48 BAT 56 BAT 64 BAT 65 BAT 73			
	— Combustion plants on offshore platforms	All sizes	EN 14792	Once every year <sup>(9)</sup>	BAT 53			



BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	N <sub>2</sub> O	<ul style="list-style-type: none"> <li>— Coal and/or lignite in circulating fluidised bed boilers</li> <li>— Solid biomass and/or peat in circulating fluidised bed boilers</li> </ul>	All sizes	EN 21258	Once every year <sup>(10)</sup>	BAT 20 BAT 24		
	CO	<ul style="list-style-type: none"> <li>— Coal and/or lignite including waste co-incineration</li> <li>— Solid biomass and/or peat including waste co-incineration</li> <li>— HFO- and/or gas-oil-fired boilers and engines</li> <li>— Gas-oil-fired gas turbines</li> <li>— Natural-gas-fired boilers, engines, and turbines</li> <li>— Iron and steel process gases</li> <li>— Process fuels from the chemical industry</li> <li>— IGCC plants</li> </ul>	All sizes	Generic EN standards	Continuous <sup>(6)</sup> (8)	BAT 20 BAT 24 BAT 28 BAT 33 BAT 38 BAT 44 BAT 49 BAT 56 BAT 64 BAT 65 BAT 73		
	<ul style="list-style-type: none"> <li>— Combustion plants on offshore platforms</li> </ul>	All sizes	EN 15058	Once every year <sup>(9)</sup>	BAT 54			

BAT Concn. Number	Summary of BAT Conclusion requirement					Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	SO <sub>2</sub>	<ul style="list-style-type: none"> <li>— Coal and/or lignite incl waste co-incineration</li> <li>— Solid biomass and/or peat incl waste co-incineration</li> <li>— HFO- and/or gas-oil-fired boilers</li> <li>— HFO- and/or gas-oil-fired engines</li> <li>— Gas-oil-fired gas turbines</li> <li>— Iron and steel process gases</li> <li>— Process fuels from the chemical industry in boilers</li> <li>— IGCC plants</li> </ul>	All sizes	Generic EN standards and EN 14791	Continuous <sub>(6)</sub> (11) (12)	BAT 21 BAT 25 BAT 29 BAT 34 BAT 39 BAT 50 BAT 57 BAT 66 BAT 67 BAT 74	
	SO <sub>3</sub>	<ul style="list-style-type: none"> <li>— When SCR is used</li> </ul>	All sizes	No EN standard available	Once every year	—	
	Gaseous chlorides, expressed as HCl	<ul style="list-style-type: none"> <li>— Coal and/or lignite</li> <li>— Process fuels from the chemical industry in boilers</li> </ul>	All sizes	EN 1911	Once every three months <sub>(6)</sub> (13) (14)	BAT 21 BAT 57	
		<ul style="list-style-type: none"> <li>— Solid biomass and/or peat</li> </ul>	All sizes	Generic EN standards	Continuous <sub>(15)</sub> (16)	BAT 25	
		<ul style="list-style-type: none"> <li>— Waste co-incineration</li> </ul>	All sizes	Generic EN standards	Continuous <sub>(6)</sub> (16)	BAT 66 BAT 67	

BAT Conc. Number	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	HF	— Coal and/or lignite	All sizes	No EN standard available	Once every three months <sup>(6)</sup> <sup>(13)</sup> <sup>(14)</sup>	BAT 21 BAT 57		
		— Solid biomass and/or peat	All sizes	No EN standard available	Once every year	BAT 25		
		— Waste co-incineration	All sizes	Generic EN standards	Continuous <sup>(6)</sup> <sup>(16)</sup>	BAT 66 BAT 67		
	Dust	— Coal and/or lignite	All sizes	Generic EN standards and EN 13284-1 and EN 13284-2	Continuous <sup>(6)</sup> <sup>(17)</sup>	BAT 22 BAT 26 BAT 30 BAT 35 BAT 39 BAT 51 BAT 58 BAT 75		
		— Solid biomass and/or peat						
		— HFO- and/or gas-oil-fired boilers						
		— Iron and steel process gases						
		— Process fuels from the chemical industry in boilers						
		— IGCC plants						
		— HFO- and/or gas-oil-fired engines						
		— Gas-oil-fired gas turbines						
5		— Waste co-incineration	All sizes	Generic EN standards and EN 13284-2	Continuous	BAT 68 BAT 69	NA	No flue-gas treatment plant installed

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																																						
	<p>standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.</p> <table border="1" data-bbox="349 419 1115 1361"> <thead> <tr> <th data-bbox="349 419 568 528">Substance/Parameter</th> <th data-bbox="568 419 808 528">Standard(s)</th> <th data-bbox="808 419 965 528">Minimum monitoring frequency</th> <th data-bbox="965 419 1115 528">Monitoring associated with</th> </tr> </thead> <tbody> <tr> <td data-bbox="349 528 568 587">Total organic carbon (TOC)<sub>(26)</sub></td> <td data-bbox="568 528 808 587">EN 1484</td> <td data-bbox="808 528 965 1361" rowspan="8">Once every month</td> <td data-bbox="965 528 1115 1361" rowspan="8">BAT 15</td> </tr> <tr> <td data-bbox="349 587 568 646">Chemical oxygen demand (COD)<sub>(26)</sub></td> <td data-bbox="568 587 808 646">No EN standard available</td> </tr> <tr> <td data-bbox="349 646 568 705">Total suspended solids (TSS)</td> <td data-bbox="568 646 808 705">EN 872</td> </tr> <tr> <td data-bbox="349 705 568 764">Fluoride (F<sup>-</sup>)</td> <td data-bbox="568 705 808 764">EN ISO 10304-1</td> </tr> <tr> <td data-bbox="349 764 568 823">Sulphate (SO<sub>4</sub><sup>2-</sup>)</td> <td data-bbox="568 764 808 823">EN ISO 10304-1</td> </tr> <tr> <td data-bbox="349 823 568 882">Sulphide, easily released (S<sup>2-</sup>)</td> <td data-bbox="568 823 808 882">No EN standard available</td> </tr> <tr> <td data-bbox="349 882 568 941">Sulphite (SO<sub>3</sub><sup>2-</sup>)</td> <td data-bbox="568 882 808 941">EN ISO 10304-3</td> </tr> <tr> <td data-bbox="349 941 568 1222">Metals and metalloids</td> <td data-bbox="568 941 808 1222"> <table border="1"> <tr><td data-bbox="524 941 568 975">As</td><td data-bbox="568 941 808 975" rowspan="7">Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)</td></tr> <tr><td data-bbox="524 975 568 1008">Cd</td></tr> <tr><td data-bbox="524 1008 568 1042">Cr</td></tr> <tr><td data-bbox="524 1042 568 1075">Cu</td></tr> <tr><td data-bbox="524 1075 568 1109">Ni</td></tr> <tr><td data-bbox="524 1109 568 1142">Pb</td></tr> <tr><td data-bbox="524 1142 568 1176">Zn</td></tr> <tr><td data-bbox="524 1176 568 1222">Hg</td><td data-bbox="568 1176 808 1222">Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)</td></tr> </table> </td> <td data-bbox="965 1222 1115 1361" rowspan="2">—</td> </tr> <tr> <td data-bbox="349 1222 568 1331">Chloride (Cl<sup>-</sup>)</td> <td data-bbox="568 1222 808 1331">Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)</td> </tr> <tr> <td data-bbox="349 1331 568 1361">Total nitrogen</td> <td data-bbox="568 1331 808 1361">EN 12260</td> <td data-bbox="965 1331 1115 1361">—</td> </tr> </tbody> </table>	Substance/Parameter	Standard(s)	Minimum monitoring frequency	Monitoring associated with	Total organic carbon (TOC) <sub>(26)</sub>	EN 1484	Once every month	BAT 15	Chemical oxygen demand (COD) <sub>(26)</sub>	No EN standard available	Total suspended solids (TSS)	EN 872	Fluoride (F <sup>-</sup> )	EN ISO 10304-1	Sulphate (SO <sub>4</sub> <sup>2-</sup> )	EN ISO 10304-1	Sulphide, easily released (S <sup>2-</sup> )	No EN standard available	Sulphite (SO <sub>3</sub> <sup>2-</sup> )	EN ISO 10304-3	Metals and metalloids	<table border="1"> <tr><td data-bbox="524 941 568 975">As</td><td data-bbox="568 941 808 975" rowspan="7">Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)</td></tr> <tr><td data-bbox="524 975 568 1008">Cd</td></tr> <tr><td data-bbox="524 1008 568 1042">Cr</td></tr> <tr><td data-bbox="524 1042 568 1075">Cu</td></tr> <tr><td data-bbox="524 1075 568 1109">Ni</td></tr> <tr><td data-bbox="524 1109 568 1142">Pb</td></tr> <tr><td data-bbox="524 1142 568 1176">Zn</td></tr> <tr><td data-bbox="524 1176 568 1222">Hg</td><td data-bbox="568 1176 808 1222">Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)</td></tr> </table>	As	Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)	Cd	Cr	Cu	Ni	Pb	Zn	Hg	Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)	—	Chloride (Cl <sup>-</sup> )	Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)	Total nitrogen	EN 12260	—		
Substance/Parameter	Standard(s)	Minimum monitoring frequency	Monitoring associated with																																						
Total organic carbon (TOC) <sub>(26)</sub>	EN 1484	Once every month	BAT 15																																						
Chemical oxygen demand (COD) <sub>(26)</sub>	No EN standard available																																								
Total suspended solids (TSS)	EN 872																																								
Fluoride (F <sup>-</sup> )	EN ISO 10304-1																																								
Sulphate (SO <sub>4</sub> <sup>2-</sup> )	EN ISO 10304-1																																								
Sulphide, easily released (S <sup>2-</sup> )	No EN standard available																																								
Sulphite (SO <sub>3</sub> <sup>2-</sup> )	EN ISO 10304-3																																								
Metals and metalloids	<table border="1"> <tr><td data-bbox="524 941 568 975">As</td><td data-bbox="568 941 808 975" rowspan="7">Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)</td></tr> <tr><td data-bbox="524 975 568 1008">Cd</td></tr> <tr><td data-bbox="524 1008 568 1042">Cr</td></tr> <tr><td data-bbox="524 1042 568 1075">Cu</td></tr> <tr><td data-bbox="524 1075 568 1109">Ni</td></tr> <tr><td data-bbox="524 1109 568 1142">Pb</td></tr> <tr><td data-bbox="524 1142 568 1176">Zn</td></tr> <tr><td data-bbox="524 1176 568 1222">Hg</td><td data-bbox="568 1176 808 1222">Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)</td></tr> </table>			As	Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)	Cd	Cr	Cu	Ni	Pb	Zn	Hg	Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)	—																											
As	Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)																																								
Cd																																									
Cr																																									
Cu																																									
Ni																																									
Pb																																									
Zn																																									
Hg	Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)																																								
Chloride (Cl <sup>-</sup> )	Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)																																								
Total nitrogen	EN 12260	—																																							

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																	
6	<p>In order to improve the general environmental performance of combustion plants and to reduce emissions to air of CO and unburnt substances, BAT is to ensure optimised combustion and to use an appropriate combination of the techniques given below.</p> <table border="1" data-bbox="349 448 1115 1342"> <thead> <tr> <th data-bbox="349 448 501 480">Technique</th> <th data-bbox="501 448 790 480">Description</th> <th data-bbox="790 448 1115 480">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="349 480 501 616">a Fuel blending and mixing</td> <td data-bbox="501 480 790 616">Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type</td> <td data-bbox="790 480 1115 616" rowspan="2">Generally applicable</td> </tr> <tr> <td data-bbox="349 616 501 722">b Maintenance of the combustion system</td> <td data-bbox="501 616 790 722">Regular planned maintenance according to suppliers' recommendations</td> </tr> <tr> <td data-bbox="349 722 501 858">c Advanced control system</td> <td data-bbox="501 722 790 858">See description in Section 8.1</td> <td data-bbox="790 722 1115 858">The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> <tr> <td data-bbox="349 858 501 994">d Good design of the combustion equipment</td> <td data-bbox="501 858 790 994">Good design of furnace, combustion chambers, burners and associated devices</td> <td data-bbox="790 858 1115 994">Generally applicable to new combustion plants</td> </tr> <tr> <td data-bbox="349 994 501 1342">e Fuel choice</td> <td data-bbox="501 994 790 1342">Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used</td> <td data-bbox="790 994 1115 1342">Applicable within the constraints associated with the availability of suitable types of fuel with a better environmental profile as a whole, which may be impacted by the energy policy of the Member State, or by the integrated site's fuel balance in the case of combustion of industrial process fuels. For existing combustion plants, the type of fuel chosen may be limited by the configuration and the design of the plant</td> </tr> </tbody> </table>	Technique	Description	Applicability	a Fuel blending and mixing	Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type	Generally applicable	b Maintenance of the combustion system	Regular planned maintenance according to suppliers' recommendations	c Advanced control system	See description in Section 8.1	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system	d Good design of the combustion equipment	Good design of furnace, combustion chambers, burners and associated devices	Generally applicable to new combustion plants	e Fuel choice	Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used	Applicable within the constraints associated with the availability of suitable types of fuel with a better environmental profile as a whole, which may be impacted by the energy policy of the Member State, or by the integrated site's fuel balance in the case of combustion of industrial process fuels. For existing combustion plants, the type of fuel chosen may be limited by the configuration and the design of the plant	CC	<p>The operator has confirmed that the environmental performance of the combustion plant is optimised through the use of techniques (b),(c),(d) and (e)</p> <p>(a) NA – only natural gas used.  (b) CC - Regular and planned maintenance is undertaken.  (c) An advanced control system is in place to automatically control and optimise combustion efficiency and manage prevention and reduction of emissions  (d) The combustion plant is a proven design.  (e) Only natural gas is used this includes for start-up and shut down.</p>
Technique	Description	Applicability																		
a Fuel blending and mixing	Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type	Generally applicable																		
b Maintenance of the combustion system	Regular planned maintenance according to suppliers' recommendations																			
c Advanced control system	See description in Section 8.1	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system																		
d Good design of the combustion equipment	Good design of furnace, combustion chambers, burners and associated devices	Generally applicable to new combustion plants																		
e Fuel choice	Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used	Applicable within the constraints associated with the availability of suitable types of fuel with a better environmental profile as a whole, which may be impacted by the energy policy of the Member State, or by the integrated site's fuel balance in the case of combustion of industrial process fuels. For existing combustion plants, the type of fuel chosen may be limited by the configuration and the design of the plant																		

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
7	<p>In order to reduce emissions of ammonia to air from the use of selective catalytic reduction (SCR) and/or selective non-catalytic reduction (SNCR) for the abatement of NO<sub>x</sub> emissions, BAT is to optimise the design and/or operation of SCR and/or SNCR (e.g. optimised reagent to NO<sub>x</sub> ratio, homogeneous reagent distribution and optimum size of the reagent drops).</p> <p><b>BAT-associated emission levels</b></p> <p>The BAT-associated emission level (BAT-AEL) for emissions of NH<sub>3</sub> to air from the use of SCR and/or SNCR is &lt; 3–10 mg/Nm<sup>3</sup> as a yearly average or average over the sampling period. The lower end of the range can be achieved when using SCR and the upper end of the range can be achieved when using SNCR without wet abatement techniques. In the case of plants combusting biomass and operating at variable loads as well as in the case of engines combusting HFO and/or gas oil, the higher end of the BAT-AEL range is 15 mg/Nm<sup>3</sup>.</p>	NA	No abatement for NO <sub>x</sub> emissions has been installed.
8	<p>In order to prevent or reduce emissions to air during normal operating conditions, BAT is to ensure, by appropriate design, operation and maintenance, that the emission abatement systems are used at optimal capacity and availability.</p>	NA	No abatement equipment is installed to prevent or reduce plant emissions during normal operating conditions.
9	<p>In order to improve the general environmental performance of combustion and/or gasification plants and to reduce emissions to air, BAT is to include the following elements in the quality assurance/quality control programmes for all the fuels used, as part of the environmental management system (see BAT 1):</p> <ul style="list-style-type: none"> <li>(i) Initial full characterisation of the fuel used including at least the parameters listed below and in accordance with EN standards. ISO, national or other international standards may be used provided they ensure the provision of data of an equivalent scientific quality;</li> <li>(ii) Regular testing of the fuel quality to check that it is consistent with the initial characterisation and according to the plant design specifications. The frequency of testing and the parameters chosen from the table below are based on the variability of the fuel and an assessment of the relevance of pollutant releases (e.g. concentration in fuel, flue-gas treatment employed);</li> <li>(iii) Subsequent adjustment of the plant settings as and when needed and practicable (e.g. integration of the fuel characterisation and control in the advanced control system (see description in Section 8.1)).</li> </ul> <p><b>Description</b></p>	CC	<p>The natural gas is supplied by the National Grid which already meets an appropriate standard.</p> <p>Natural gas supplied to site has been characterised to include the parameters listed. It is continuously tested using a Siemens MicroSAM gas chromatograph calibrated to ISO 10723:2012, providing the required parameters; data is recorded using the station logging system. Gas data is supplied to GE when the system is tuned.</p> <p>We agree that NO additional characterisation or testing is required.</p> <p><u>Gas Turbines Firing on Gas Oil</u></p> <p>The operator has confirmed that site gas oil consumption is low due to consistently firing on natural gas. They also state that there has been no recent deliveries of gas oil, as site has reduced stock to below COMAH reporting level. Analysis provided by supplier would be in line with Joint Environmental Programme (JEP) report – ‘Characterisation of</p>

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																						
	<p>Initial characterisation and regular testing of the fuel can be performed by the operator and/or the fuel supplier. If performed by the supplier, the full results are provided to the operator in the form of a product (fuel) supplier specification and/or guarantee.</p> <table border="1" data-bbox="338 440 1120 1326"> <thead> <tr> <th data-bbox="338 440 600 499">Fuel(s)</th> <th data-bbox="600 440 1120 499">Substances/Parameters subject to characterisation</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 499 600 727" rowspan="4">Biomass/peat</td> <td data-bbox="600 499 1120 544">— LHV</td> </tr> <tr> <td data-bbox="600 544 1120 588">— moisture</td> </tr> <tr> <td data-bbox="600 588 1120 633">— Ash</td> </tr> <tr> <td data-bbox="600 633 1120 727">— C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn)</td> </tr> <tr> <td data-bbox="338 727 600 967" rowspan="4">Coal/lignite</td> <td data-bbox="600 727 1120 772">— LHV</td> </tr> <tr> <td data-bbox="600 772 1120 817">— Moisture</td> </tr> <tr> <td data-bbox="600 817 1120 861">— Volatiles, ash, fixed carbon, C, H, N, O, S</td> </tr> <tr> <td data-bbox="600 861 1120 967">— Br, Cl, F — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Ti, V, Zn)</td> </tr> <tr> <td data-bbox="338 967 600 1050" rowspan="2">HFO</td> <td data-bbox="600 967 1120 1011">— Ash</td> </tr> <tr> <td data-bbox="600 1011 1120 1050">— C, S, N, Ni, V</td> </tr> <tr> <td data-bbox="338 1050 600 1133" rowspan="2">Gas oil</td> <td data-bbox="600 1050 1120 1094">— Ash</td> </tr> <tr> <td data-bbox="600 1094 1120 1133">— N, C, S</td> </tr> <tr> <td data-bbox="338 1133 600 1216">Natural gas</td> <td data-bbox="600 1133 1120 1216">— LHV — CH<sub>4</sub>, C<sub>2</sub>H<sub>6</sub>, C<sub>3</sub>, C<sub>4+</sub>, CO<sub>2</sub>, N<sub>2</sub>, Wobbe index</td> </tr> <tr> <td data-bbox="338 1216 600 1326">Process fuels from the chemical industry<sup>(27)</sup></td> <td data-bbox="600 1216 1120 1326">— Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Ti, V, Zn)</td> </tr> </tbody> </table>	Fuel(s)	Substances/Parameters subject to characterisation	Biomass/peat	— LHV	— moisture	— Ash	— C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn)	Coal/lignite	— LHV	— Moisture	— Volatiles, ash, fixed carbon, C, H, N, O, S	— Br, Cl, F — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Ti, V, Zn)	HFO	— Ash	— C, S, N, Ni, V	Gas oil	— Ash	— N, C, S	Natural gas	— LHV — CH <sub>4</sub> , C <sub>2</sub> H <sub>6</sub> , C <sub>3</sub> , C <sub>4+</sub> , CO <sub>2</sub> , N <sub>2</sub> , Wobbe index	Process fuels from the chemical industry <sup>(27)</sup>	— Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Ti, V, Zn)		power plant fuels for compliance with LCP BREF Conclusion BAT 9' issued October 2019.
Fuel(s)	Substances/Parameters subject to characterisation																								
Biomass/peat	— LHV																								
	— moisture																								
	— Ash																								
	— C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn)																								
Coal/lignite	— LHV																								
	— Moisture																								
	— Volatiles, ash, fixed carbon, C, H, N, O, S																								
	— Br, Cl, F — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Ti, V, Zn)																								
HFO	— Ash																								
	— C, S, N, Ni, V																								
Gas oil	— Ash																								
	— N, C, S																								
Natural gas	— LHV — CH <sub>4</sub> , C <sub>2</sub> H <sub>6</sub> , C <sub>3</sub> , C <sub>4+</sub> , CO <sub>2</sub> , N <sub>2</sub> , Wobbe index																								
Process fuels from the chemical industry <sup>(27)</sup>	— Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Ti, V, Zn)																								

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement				
	<table border="1"> <tr> <td data-bbox="338 328 600 400">Iron and steel process gases</td> <td data-bbox="600 328 1122 400">— LHV, CH<sub>4</sub> (for COG), C<sub>x</sub>H<sub>y</sub> (for COG), CO<sub>2</sub>, H<sub>2</sub>, N<sub>2</sub>, total sulphur, dust, Wobbe index</td> </tr> <tr> <td data-bbox="338 400 600 584">Waste<sup>(28)</sup></td> <td data-bbox="600 400 1122 584"> <ul style="list-style-type: none"> <li>— LHV</li> <li>— Moisture</li> <li>— Volatiles, ash, Br, C, Cl, F, H, N, O, S</li> <li>— Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Ti, V, Zn)</li> </ul> </td> </tr> </table>	Iron and steel process gases	— LHV, CH <sub>4</sub> (for COG), C <sub>x</sub> H <sub>y</sub> (for COG), CO <sub>2</sub> , H <sub>2</sub> , N <sub>2</sub> , total sulphur, dust, Wobbe index	Waste <sup>(28)</sup>	<ul style="list-style-type: none"> <li>— LHV</li> <li>— Moisture</li> <li>— Volatiles, ash, Br, C, Cl, F, H, N, O, S</li> <li>— Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Ti, V, Zn)</li> </ul>		
Iron and steel process gases	— LHV, CH <sub>4</sub> (for COG), C <sub>x</sub> H <sub>y</sub> (for COG), CO <sub>2</sub> , H <sub>2</sub> , N <sub>2</sub> , total sulphur, dust, Wobbe index						
Waste <sup>(28)</sup>	<ul style="list-style-type: none"> <li>— LHV</li> <li>— Moisture</li> <li>— Volatiles, ash, Br, C, Cl, F, H, N, O, S</li> <li>— Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Ti, V, Zn)</li> </ul>						
10	<p>In order to reduce emissions to air and/or to water during other than normal operating conditions (OTNOC), BAT is to set up and implement a management plan as part of the environmental management system (see BAT 1), commensurate with the relevance of potential pollutant releases, that includes the following elements:</p> <ul style="list-style-type: none"> <li>— appropriate design of the systems considered relevant in causing OTNOC that may have an impact on emissions to air, water and/or soil (e.g. low-load design concepts for reducing the minimum start-up and shutdown loads for stable generation in gas turbines),</li> <li>— set-up and implementation of a specific preventive maintenance plan for these relevant systems,</li> <li>— review and recording of emissions caused by OTNOC and associated circumstances and implementation of corrective actions if necessary,</li> <li>— periodic assessment of the overall emissions during OTNOC (e.g. frequency of events, duration, emissions quantification/estimation) and implementation of corrective actions if necessary.</li> </ul>	CC	<p>The operator has confirmed the following:</p> <p>The plant installed is highly sophisticated in terms of hardware and software.</p> <p>The fuel consumed is characterised continuously and is of a consistent high quality. If an “ other than normal operating condition “ event where to occur, it would most likely arise due to catastrophic equipment failure. This would necessitate plant shut-down to investigate and repair, for this reason it is not feasible to plan or conduct OTNOC events at Medway.</p> <p>The EMS incorporates consideration of “abnormal conditions, all OTNOC events are logged and subject to investigation.</p> <p>SSE operates a process to consider and review all proposed modifications to plant and processes (MPPC). The procedure seeks to identify all potential impacts of the intended change including health, safety and environment (SHE). For a modification to proceed it must be approved by the committee overseeing the MPPC’s review and assessment.</p> <p>SSE operates a process to identify all possible SHE critical tasks on-site and put controls in-place to manage and maintain them; this process is referred as the process hazard review. It seeks to identify and rank potential “other than normal operating conditions” and put controls in place to reduce the risk.</p>				



BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement						
			<p>Medway follows the guidance contained in M20 for quality assurance of continuous emissions monitoring systems. During SU/SD the emissions for NOx and CO are at all times within the range of the CEMS which is possible by dual measurement range. Mass release of emissions can be reported either with or without the SU/SD contribution.</p> <p>Procedures are in place to shutdown aqueous discharges should they deviate from permitted limits e.g. CW discharge. Site aqueous monitoring meets MCERTS requirements; site is certified for the self-monitoring of flow meeting the performance requirements of the installation and management system.</p> <p>Station start-up is controlled by defined procedures which must be followed and met.</p>						
11	<p>BAT is to appropriately monitor emissions to air and/or to water during OTNOC.</p> <p><b>Description</b> The monitoring can be carried out by direct measurement of emissions or by monitoring of surrogate parameters if this proves to be of equal or better scientific quality than the direct measurement of emissions. Emissions during start-up and shutdown (SU/SD) may be assessed based on a detailed emission measurement carried out for a typical SU/SD procedure at least once every year, and using the results of this measurement to estimate the emissions for each and every SU/SD throughout the year.</p>	CC	<p><b>Air Emissions</b> - CEMS are in place see response to BAT 4</p> <p><b>Water emissions</b> are monitored continuously for applicable parameters with relevant alarms to warn of approaching limits."</p>						
12	<p>In order to increase the energy efficiency of combustion, gasification and/or IGCC units operated <math>\geq 1\,500</math> h/yr, BAT is to use an appropriate combination of the techniques given below.</p> <table border="1" data-bbox="338 1193 1117 1385"> <thead> <tr> <th data-bbox="338 1193 512 1230">Technique</th> <th data-bbox="512 1193 831 1230">Description</th> <th data-bbox="831 1193 1117 1230">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 1230 512 1385">a. Combustion optimisation</td> <td data-bbox="512 1230 831 1385">See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues</td> <td data-bbox="831 1230 1117 1385">Generally applicable</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Combustion optimisation	See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues	Generally applicable	CC	<p>The operator has confirmed that combustion optimisation (a) is undertaken by GE DLN 2.6+ combustion system achieve minimum emissions of NOx and CO whilst delivering optimum environmental and operational performance. This is achieved through staged combustion modes from diffusion through to premixed where the fuel is distributed differently in the combustors.</p> <p>(b) Optimisation of the working medium conditions GE Mark VI control system. This control module is designed to run the DLN 2.6+ combustion system. Combined together they deliver optimal</p>
Technique	Description	Applicability							
a. Combustion optimisation	See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues	Generally applicable							

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	b. Optimisation of the working medium conditions	Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO <sub>x</sub> emissions or the characteristics of energy demanded			<p>environmental performance, operability, availability and turbine performance. Have continuous monitoring at the SSE Engineering Centre via the Smart Signal connection to ensure system is operating at its optimum. Combustion turbines are re-tuned to account for seasonal temperature variation.</p> <p>(c) Optimisation of the working steam cycle Medway is continually monitored at the SSE Engineering Centre via the Smart Signal connection to ensure system is operating at its optimum. The condenser vacuum is operated to within the range 55 – 60 mBar. Condenser cooling water is supplied from on-site cooling tower, the temperature of which is effected by the rate of blowdown and number of cooling tower fans running.</p> <p>(f) Fuel preheating Incoming gas is preheated in heat exchangers supplied with water from the lower pressure economisers; this raises the gas temperature from approx. 5 °C to 140 °C.</p> <p>(g) Advanced Control System GE Mark VI control system is designed to run the DLN 2.6+ combustion system. Combined together they deliver optimal environmental performance, operability, availability and turbine performance.</p> <p>(h) Feed-water preheating using recovered heat Feedwater is deaerated by vacuum de-aeration using LP exhaust steam thereby leaving more steam for expansion in the turbine. This preheats the feedwater by approximately 10 °C.</p> <p>Site efficiency determined at 54.2 % and reported in SSE Engineering Centre Technical Report Medway: Baseload Output and Efficiency Benchmark March 2016.</p> <p>Preheating of combustion air: this technique is not appropriate to combustion turbines.</p>
c. Optimisation of the steam cycle	Operate with lower turbine exhaust pressure by utilisation of the lowest possible temperature of the condenser cooling water, within the design conditions				
d. Minimisation of energy consumption	Minimising the internal energy consumption (e.g. greater efficiency of the feed-water pump)				
e. Preheating of combustion air	Reuse of part of the heat recovered from the combustion flue-gas to preheat the air used in combustion	Generally applicable within the constraints related to the need to control NO <sub>x</sub> emissions			
f. Fuel preheating	Preheating of fuel using recovered heat	Generally applicable within the constraints associated with the boiler design and the need to control NO <sub>x</sub> emissions			
g. Advanced control system	See description in Section 8.2. Computerised control of the main combustion parameters enables the combustion efficiency to be improved	Generally applicable to new units. The applicability to old units may be constrained by the need to retrofit the combustion system and/or control command system			
h. Feed-water preheating using recovered heat	Preheat water coming out of the steam condenser with recovered heat, before reusing it in the boiler	Only applicable to steam circuits and not to hot boilers. Applicability to existing units may be limited due to constraints associated with the plant configuration and			

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
			the amount of recoverable heat		<p>CHP/CHP readiness: no local heat and power demand, station not designed/construction for CHP.</p> <p>Flue-gas condenser: no CHP demand. Wet stack: station does not have FGD installed.</p> <p>Cooling water discharge: station does not have FGD installed.</p> <p>Fuel pre-drying: not applicable to natural gas or gas oil.</p> <p>Minimisation of heat losses: not applicable to natural gas or gas oil.</p> <p>Advanced materials: plant commissioned in 1995.</p> <p>Steam turbine upgrades: limited plant lifetime. Supercritical and ultra-supercritical steam conditions: plant commissioned in 1995.</p>
	i.	Heat recovery by cogeneration (CHP)	Recovery of heat (mainly from the steam system) for producing hot water/steam to be used in industrial processes/activities or in a public network for district heating. Additional heat recovery is possible from: <ul style="list-style-type: none"> <li>— flue-gas</li> <li>— grate cooling</li> <li>— circulating fluidised bed</li> </ul>	Applicable within the constraints associated with the local heat and power demand. The applicability may be limited in the case of gas compressors with an unpredictable operational heat profile	
	j.	CHP readiness	See description in Section 8.2.	Only applicable to new units where there is a realistic potential for the future use of heat in the vicinity of the unit	
	k.	Flue-gas condenser	See description in Section 8.2.	Generally applicable to CHP units provided there is enough demand for low-temperature heat	
	l.	Heat accumulation	Heat accumulation storage in CHP mode	Only applicable to CHP plants. The applicability may be limited in the case of low heat load demand	
	m.	Wet stack	See description in Section 8.2.	Generally applicable to new and existing units fitted with wet FGD	
	n.	Cooling tower discharge	The release of emissions to air through a cooling tower and not via a dedicated stack	Only applicable to units fitted with wet FGD where reheating of the flue-gas is necessary before release, and where the unit cooling system is a cooling tower	
	o.	Fuel pre-drying	The reduction of fuel moisture content before combustion to improve combustion conditions	Applicable to the combustion of biomass and/or peat within the constraints	

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	
				<p>associated with spontaneous combustion risks (e.g. the moisture content of peat is kept above 40 % throughout the delivery chain). The retrofit of existing plants may be restricted by the extra calorific value that can be obtained from the drying operation and by the limited retrofit possibilities offered by some boiler designs or plant configurations</p>		
	p.	Minimisation of heat losses	Minimising residual heat losses, e.g. those that occur via the slag or those that can be reduced by insulating radiating sources	Only applicable to solid-fuel-fired combustion units and to gasification/IGCC units		
	q.	Advanced materials	Use of advanced materials proven to be capable of withstanding high operating temperatures and pressures and thus to achieve increased steam/combustion process efficiencies	Only applicable to new plants		
	r.	Steam turbine upgrades	This includes techniques such as increasing the temperature and pressure of medium-pressure steam, addition of a low-pressure turbine, and modifications to the geometry of the turbine rotor blades	The applicability may be restricted by demand, steam conditions and/or limited plant lifetime		
	s.	Supercritical and ultra-supercritical steam conditions	Use of a steam circuit, including steam reheating systems, in which steam can reach pressures above 220,6 bar and temperatures above 374 °C in the case of supercritical conditions, and above 250 – 300 bar and temperatures above	Only applicable to new units of $\geq 600$ MW <sub>th</sub> operated > 4 000 h/yr. Not applicable when the purpose of the unit is to produce low steam temperatures and/or pressures in process industries.		

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement									
		580 – 600 °C in the case of ultra-supercritical conditions	Not applicable to gas turbines and engines generating steam in CHP mode. For units combusting biomass, the applicability may be constrained by high-temperature corrosion in the case of certain biomasses											
13	<p>In order to reduce water usage and the volume of contaminated waste water discharged, BAT is to use one or both of the techniques given below.</p> <table border="1" data-bbox="338 635 1120 1034"> <thead> <tr> <th data-bbox="338 635 479 695">Technique</th> <th data-bbox="479 635 837 695">Description</th> <th data-bbox="837 635 1120 695">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 695 479 874">a Water recycling</td> <td data-bbox="479 695 837 874">Residual aqueous streams, including run-off water, from the plant are reused for other purposes. The degree of recycling is limited by the quality requirements of the recipient water stream and the water balance of the plant</td> <td data-bbox="837 695 1120 874">Not applicable to waste water from cooling systems when water treatment chemicals and/or high concentrations of salts from seawater are present</td> </tr> <tr> <td data-bbox="338 874 479 1034">b Dry bottom ash handling</td> <td data-bbox="479 874 837 1034">Dry, hot bottom ash falls from the furnace onto a mechanical conveyor system and is cooled down by ambient air. No water is used in the process.</td> <td data-bbox="837 874 1120 1034">Only applicable to plants combusting solid fuels. There may be technical restrictions that prevent retrofitting to existing combustion plants</td> </tr> </tbody> </table>			Technique	Description	Applicability	a Water recycling	Residual aqueous streams, including run-off water, from the plant are reused for other purposes. The degree of recycling is limited by the quality requirements of the recipient water stream and the water balance of the plant	Not applicable to waste water from cooling systems when water treatment chemicals and/or high concentrations of salts from seawater are present	b Dry bottom ash handling	Dry, hot bottom ash falls from the furnace onto a mechanical conveyor system and is cooled down by ambient air. No water is used in the process.	Only applicable to plants combusting solid fuels. There may be technical restrictions that prevent retrofitting to existing combustion plants	CC	<p>Operator has confirmed that water usage is optimised and minimised where plant design allows; limiting recycling opportunities.</p> <p>Blowdown from the HRSGs is diverted to the cooling tower where it dilutes the seawater concentration.</p> <p>Water Treatment Plant effluent High purity water for boiler use is produced in the water treatment plant using a series of ion exchange beds. Effluents are mixed in a holding tank and the pH adjusted until within the permit discharge pH limits when it is then pumped to the site trade effluent tank.</p> <p>Site trade effluent All internal building drains and external areas where there is potential for oil contamination are discharged through a site oil interceptor and pumped to the site trade effluent tank. In this tank, site drainage and effluent from the WTP are combined. Prior to discharge a sample is tested to ensure the discharge is within the permit limits. There is no opportunity to recycle this stream due to quality.</p> <p>Cooling water The cooling water system is not of suitable quality to be re-used in other processes on-site. Water usage within the cooling system is optimised through management of cooling tower cycles of concentration.</p>
Technique	Description	Applicability												
a Water recycling	Residual aqueous streams, including run-off water, from the plant are reused for other purposes. The degree of recycling is limited by the quality requirements of the recipient water stream and the water balance of the plant	Not applicable to waste water from cooling systems when water treatment chemicals and/or high concentrations of salts from seawater are present												
b Dry bottom ash handling	Dry, hot bottom ash falls from the furnace onto a mechanical conveyor system and is cooled down by ambient air. No water is used in the process.	Only applicable to plants combusting solid fuels. There may be technical restrictions that prevent retrofitting to existing combustion plants												

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
14	<p>In order to prevent the contamination of uncontaminated waste water and to reduce emissions to water, BAT is to segregate waste water streams and to treat them separately, depending on the pollutant content.</p> <p><b>Description</b> Waste water streams that are typically segregated and treated include surface run-off water, cooling water, and waste water from flue-gas treatment.</p> <p><b>Applicability</b> The applicability may be restricted in the case of existing plants due to the configuration of the drainage systems.</p>	CC	<p>Site effluent streams are segregated with no cross contamination before treatment.</p> <p><b>Cooling Water</b> Site extracts water from the Medway estuary which is then used in the cooling tower. During operation the water is cycled up in concentration to typically 1.3. Water is pumped to the cooling tower and then returned directly to the estuary.</p> <p><b>Boiler blowdown</b> Blowdown from the HRSGs is diverted to the cooling tower where it dilutes the seawater concentration.</p> <p><b>Water Treatment Plant effluent</b> All waste water flows from the water treatment plant are collected in a sump from where they are pumped to the neutralisation tank. Here the effluent is mixed in a holding tank and the pH adjusted through chemical addition. The contents are circulated through the tank to ensure they are well mixed and the site permit discharge pH limits are achieved. It is then that the contents are pumped to the site trade effluent tank and discharged to the estuary.</p> <p><b>Internal &amp; external drains</b> The flow from all internal building drains and those external areas where there is potential for oil contamination (e.g. car park, tank bunds and black start sump ) is discharged through a site oil interceptor and pumped to the site trade effluent tank.</p> <p><b>Sewage effluent</b> Site sewage is treated on-site in an aerobic treatment plant, the effluent from this plant is diverted to trade effluent tank. This comprises the waste water from kitchen and wash areas.</p> <p><b>Site trade effluent</b> This tank collects the flows from the various effluent streams detailed above. All flows have been treated before entering this tank where they are mixed and tested to ensure the discharge complies with the site permit limits. Effluent is monitored and tested to ensure discharge</p>

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement						
			<p>quality.</p> <p>External drains Site storm water is collected via the surface water drains, a number of interceptors have been installed to protect against potential oil contaminated run-off from car parks.</p>						
15	In order to reduce emissions to water from flue-gas treatment, BAT is to use an appropriate combination of the techniques given in BAT 15, and to use secondary techniques as close as possible to the source in order to avoid dilution.	NA	No flue gas treatment installed						
16	<p>In order to reduce the quantity of waste sent for disposal from the combustion and/or gasification process and abatement techniques, BAT is to organise operations so as to maximise, in order of priority and taking into account life-cycle thinking:</p> <p>(a) waste prevention, e.g. maximise the proportion of residues which ) arise as by-products;</p> <p>(b) waste preparation for reuse, e.g. according to the specific requested ) quality criteria;</p> <p>(c) waste recycling;</p> <p>(d) other waste recovery (e.g. energy recovery),</p> <p>by implementing an appropriate combination of techniques such as:</p> <table border="1" data-bbox="338 1050 1120 1345"> <thead> <tr> <th data-bbox="338 1050 510 1086">Technique</th> <th data-bbox="510 1050 846 1086">Description</th> <th data-bbox="846 1050 1120 1086">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 1086 510 1345">a . Generation of gypsum as a by-product</td> <td data-bbox="510 1086 846 1345">Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g. as raw material in the plasterboard industry). The quality of limestone used in the wet FGD influences the purity of the gypsum produced</td> <td data-bbox="846 1086 1120 1345">Generally applicable within the constraints associated with the required gypsum quality, the health requirements associated to each specific use, and by the market conditions</td> </tr> </tbody> </table>	Technique	Description	Applicability	a . Generation of gypsum as a by-product	Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g. as raw material in the plasterboard industry). The quality of limestone used in the wet FGD influences the purity of the gypsum produced	Generally applicable within the constraints associated with the required gypsum quality, the health requirements associated to each specific use, and by the market conditions	NA	No flue gas treatment undertaken so no waste streams for treatment
Technique	Description	Applicability							
a . Generation of gypsum as a by-product	Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g. as raw material in the plasterboard industry). The quality of limestone used in the wet FGD influences the purity of the gypsum produced	Generally applicable within the constraints associated with the required gypsum quality, the health requirements associated to each specific use, and by the market conditions							

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement						
	b . Recycling or recovery of residues in the construction sector	Recycling or recovery of residues (e.g. from semi-dry desulphurisation processes, fly ash, bottom ash) as a construction material (e.g. in road building, to replace sand in concrete production, or in the cement industry)	Generally applicable within the constraints associated with the required material quality (e.g. physical properties, content of harmful substances) associated to each specific use, and by the market conditions								
	c . Energy recovery by using waste in the fuel mix	The residual energy content of carbon-rich ash and sludges generated by the combustion of coal, lignite, heavy fuel oil, peat or biomass can be recovered for example by mixing with the fuel	Generally applicable where plants can accept waste in the fuel mix and are technically able to feed the fuels into the combustion chamber								
	d . Preparation of spent catalyst for reuse	Preparation of catalyst for reuse (e.g. up to four times for SCR catalysts) restores some or all of the original performance, extending the service life of the catalyst to several decades. Preparation of spent catalyst for reuse is integrated in a catalyst management scheme	The applicability may be limited by the mechanical condition of the catalyst and the required performance with respect to controlling NO <sub>x</sub> and NH <sub>3</sub> emissions								
17	In order to reduce noise emissions, BAT is to use one or a combination of the techniques given below.			CC	<p>The operator has confirmed that the following operational measures are undertaken start-ups</p> <p>Coil steam generator used to initiate warming of system and provide steam to turbine glands. This reduces start-up time by enabling the plant to establish vacuum earlier.</p> <p>Start-up vents: minimise use, installation of silencers, avoidance of long periods of use at night.</p> <p>Building Doors: doors to generation buildings are kept closed.</p> <p>Noise: attenuation &amp; control equipment</p> <p>All noisy equipment is housed within enclosures and buildings. Silencers are installed on steam release points. Buildings include soundproofing material on the inside. Noise sources are shielded from receptors using buildings.</p>						
	<table border="1"> <thead> <tr> <th data-bbox="331 1029 510 1054">Technique</th> <th data-bbox="510 1029 846 1054">Description</th> <th data-bbox="846 1029 1133 1054">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="331 1054 510 1383">a . Operational measures</td> <td data-bbox="510 1054 846 1383">           These include:           <ul style="list-style-type: none"> <li>— improved inspection and maintenance of equipment</li> <li>— closing of doors and windows of enclosed areas, if possible</li> <li>— equipment operated by experienced staff</li> <li>— avoidance of noisy activities at night, if possible</li> </ul> </td> <td data-bbox="846 1054 1133 1383">Generally applicable</td> </tr> </tbody> </table>			Technique	Description	Applicability	a . Operational measures	These include: <ul style="list-style-type: none"> <li>— improved inspection and maintenance of equipment</li> <li>— closing of doors and windows of enclosed areas, if possible</li> <li>— equipment operated by experienced staff</li> <li>— avoidance of noisy activities at night, if possible</li> </ul>	Generally applicable		
Technique	Description	Applicability									
a . Operational measures	These include: <ul style="list-style-type: none"> <li>— improved inspection and maintenance of equipment</li> <li>— closing of doors and windows of enclosed areas, if possible</li> <li>— equipment operated by experienced staff</li> <li>— avoidance of noisy activities at night, if possible</li> </ul>	Generally applicable									



BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
		— provisions for noise control during maintenance activities			<p>Location Medway power station is situated at a location removed from potential receptors; all neighbouring sites are industrial, nearest village is approximately 2 miles.</p> <p>Medway has a regular programme of noise measurements.</p>
	b . Low-noise equipment	This potentially includes compressors, pumps and disks	Generally applicable when the equipment is new or replaced		
	c . Noise attenuation	Noise propagation can be reduced by inserting obstacles between the emitter and the receiver. Appropriate obstacles include protection walls, embankments and buildings	Generally applicable to new plants. In the case of existing plants, the insertion of obstacles may be restricted by lack of space		
	d . Noise-control equipment	This includes: <ul style="list-style-type: none"> <li>— noise-reducers</li> <li>— equipment insulation</li> <li>— enclosure of noisy equipment</li> <li>— soundproofing of buildings</li> </ul>	The applicability may be restricted by lack of space		
	e . Appropriate location of equipment and buildings	Noise levels can be reduced by increasing the distance between the emitter and the receiver and by using buildings as noise screens	Generally applicable to new plant		
<b>BAT Conclusions 18 to 23 for the combustion of coal and/or lignite (solid fuels only)</b> <b>BAT Conclusions 24 to 27 for the combustion of solid biomass and/or peat (solid fuels only)</b>					
<b>Combustion of liquid fuels -</b>					
28	In order to prevent or reduce NO <sub>x</sub> emissions to air while limiting CO emissions to air from the combustion of HFO and/or gas oil in boilers, BAT is to use one or a combination of the techniques given in BAT 28.			NA	Not undertaken on site
29	In order to prevent or reduce SO <sub>x</sub> , HCl and HF emissions to air from the combustion of HFO and/or gas oil in boilers, BAT is to use one or a combination of the techniques given in BAT 29.			NA	Not undertaken on site

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																				
30	In order to reduce dust and particulate-bound metal emissions to air from the combustion of HFO and/or gas oil in boilers, BAT is to use one or a combination of the techniques given in BAT 30.	NA	Not undertaken on site																				
31	<p>In order to increase the energy efficiency of HFO and/or gas oil combustion in reciprocating engines, BAT is to use an appropriate combination of the techniques given in BAT 12 and below.</p> <table border="1" data-bbox="338 512 1117 754"> <thead> <tr> <th data-bbox="338 512 468 571">Technique</th> <th data-bbox="468 512 633 571">Description</th> <th data-bbox="633 512 1117 571">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 571 468 754">a Combined cycle</td> <td data-bbox="468 571 633 754">See description in Section 8.2</td> <td data-bbox="633 571 1117 754">Generally applicable to new units operated <math>\geq 1\,500</math> h/yr. Applicable to existing units within the constraints associated with the steam cycle design and the space availability. Not applicable to existing units operated <math>&lt; 1\,500</math> h/yr</td> </tr> </tbody> </table> <p><b>BAT-associated energy efficiency levels (BAT-AEELs) for the combustion of HFO and/or gas oil in reciprocating engines</b></p> <table border="1" data-bbox="338 839 1117 1114"> <thead> <tr> <th data-bbox="338 839 848 994" rowspan="2">Type of combustion unit</th> <th colspan="2" data-bbox="848 839 1117 874">BAT-AEELs <sup>(119)</sup></th> </tr> <tr> <th colspan="2" data-bbox="848 874 1117 935">Net electrical efficiency (%) <sup>(120)</sup></th> </tr> <tr> <th data-bbox="338 935 848 994"></th> <th data-bbox="848 935 978 994">New unit</th> <th data-bbox="978 935 1117 994">Existing unit</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 994 848 1054">HFO- and/or gas-oil-fired reciprocating engine — single cycle</td> <td data-bbox="848 994 978 1054">41,5–44,5 <sup>(121)</sup></td> <td data-bbox="978 994 1117 1054">38,3–44,5 <sup>(121)</sup></td> </tr> <tr> <td data-bbox="338 1054 848 1114">HFO- and/or gas-oil-fired reciprocating engine — combined cycle</td> <td data-bbox="848 1054 978 1114">&gt; 48 <sup>(122)</sup></td> <td data-bbox="978 1054 1117 1114">No BAT-AEEL</td> </tr> </tbody> </table>	Technique	Description	Applicability	a Combined cycle	See description in Section 8.2	Generally applicable to new units operated $\geq 1\,500$ h/yr. Applicable to existing units within the constraints associated with the steam cycle design and the space availability. Not applicable to existing units operated $< 1\,500$ h/yr	Type of combustion unit	BAT-AEELs <sup>(119)</sup>		Net electrical efficiency (%) <sup>(120)</sup>			New unit	Existing unit	HFO- and/or gas-oil-fired reciprocating engine — single cycle	41,5–44,5 <sup>(121)</sup>	38,3–44,5 <sup>(121)</sup>	HFO- and/or gas-oil-fired reciprocating engine — combined cycle	> 48 <sup>(122)</sup>	No BAT-AEEL	NA	The station has installed 6 Wartsila Series 200 V18 engines each connected to an electrical generator producing 3 MW electrical power and currently operate less than 1,500 hours/yr in single cycle.
Technique	Description	Applicability																					
a Combined cycle	See description in Section 8.2	Generally applicable to new units operated $\geq 1\,500$ h/yr. Applicable to existing units within the constraints associated with the steam cycle design and the space availability. Not applicable to existing units operated $< 1\,500$ h/yr																					
Type of combustion unit	BAT-AEELs <sup>(119)</sup>																						
	Net electrical efficiency (%) <sup>(120)</sup>																						
	New unit	Existing unit																					
HFO- and/or gas-oil-fired reciprocating engine — single cycle	41,5–44,5 <sup>(121)</sup>	38,3–44,5 <sup>(121)</sup>																					
HFO- and/or gas-oil-fired reciprocating engine — combined cycle	> 48 <sup>(122)</sup>	No BAT-AEEL																					
32	<p>In order to prevent or reduce NO<sub>x</sub> emissions to air from the combustion of HFO and/or gas oil in reciprocating engines, BAT is to use one or a combination of the techniques given below.</p> <table border="1" data-bbox="338 1214 1117 1382"> <thead> <tr> <th data-bbox="338 1214 551 1273">Technique</th> <th data-bbox="551 1214 698 1273">Description</th> <th data-bbox="698 1214 1117 1273">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 1273 551 1382">a Low-NO<sub>x</sub> combustion concept in diesel engines</td> <td data-bbox="551 1273 698 1382">See descriptions in Section 8.3</td> <td data-bbox="698 1273 1117 1382">Generally applicable</td> </tr> </tbody> </table>	Technique	Description	Applicability	a Low-NO <sub>x</sub> combustion concept in diesel engines	See descriptions in Section 8.3	Generally applicable	NA	The operator has confirmed that there are no LCP reciprocating gas engines on site.														
Technique	Description	Applicability																					
a Low-NO <sub>x</sub> combustion concept in diesel engines	See descriptions in Section 8.3	Generally applicable																					

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement										
	b Exhaust-gas recirculation (EGR)		Not applicable to four-stroke engines												
	c Water/steam addition		Applicable within the constraints of water availability. The applicability may be limited where no retrofit package is available												
	d Selective catalytic reduction (SCR)		Not applicable to combustion plants operated < 500 h/yr. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr. Retrofitting existing combustion plants may be constrained by the availability of sufficient space												
33	In order to prevent or reduce emissions of CO and volatile organic compounds to air from the combustion of HFO and/or gas oil in reciprocating engines, BAT is to use one or both of the techniques given in BAT 33.			NA	None applicable.										
34	In order to prevent or reduce SO <sub>x</sub> , HCl and HF emissions to air from the combustion of HFO and/or gas oil in reciprocating engines, BAT is to use one or a combination of the techniques given below.			NA	Engines fired using gas oil with sulphur content less than 0.1% w/w.										
	<table border="1"> <thead> <tr> <th data-bbox="331 991 546 1038">Technique</th> <th data-bbox="546 991 689 1038">Description</th> <th data-bbox="689 991 1124 1038">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="331 1038 546 1150">a Fuel choice</td> <td data-bbox="546 1038 689 1347" rowspan="3">See descriptions in Section 8.4</td> <td data-bbox="689 1038 1124 1150">Applicable within the constraints associated with the availability of different types of fuel, which may be impacted by the energy policy of the Member State</td> </tr> <tr> <td data-bbox="331 1150 546 1262">b Duct sorbent injection (DSI)</td> <td data-bbox="689 1150 1124 1262">There may be technical restrictions in the case of existing combustion plants Not applicable to combustion plants operated &lt; 500 h/yr</td> </tr> <tr> <td data-bbox="331 1262 546 1347">c Wet flue-gas desulphurisation (wet FGD)</td> <td data-bbox="689 1262 1124 1347">There may be technical and economic restrictions for applying the technique to combustion plants of &lt; 300 MW<sub>th</sub>.</td> </tr> </tbody> </table>	Technique	Description	Applicability	a Fuel choice	See descriptions in Section 8.4	Applicable within the constraints associated with the availability of different types of fuel, which may be impacted by the energy policy of the Member State	b Duct sorbent injection (DSI)	There may be technical restrictions in the case of existing combustion plants Not applicable to combustion plants operated < 500 h/yr	c Wet flue-gas desulphurisation (wet FGD)	There may be technical and economic restrictions for applying the technique to combustion plants of < 300 MW <sub>th</sub> .				
Technique	Description	Applicability													
a Fuel choice	See descriptions in Section 8.4	Applicable within the constraints associated with the availability of different types of fuel, which may be impacted by the energy policy of the Member State													
b Duct sorbent injection (DSI)		There may be technical restrictions in the case of existing combustion plants Not applicable to combustion plants operated < 500 h/yr													
c Wet flue-gas desulphurisation (wet FGD)		There may be technical and economic restrictions for applying the technique to combustion plants of < 300 MW <sub>th</sub> .													

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																						
	<table border="1" style="width: 100%;"> <tr> <td style="width: 15%;"></td> <td style="width: 15%;"></td> <td style="width: 15%;"></td> <td style="width: 55%;">Not applicable to combustion plants operated &lt; 500 h/yr. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr</td> </tr> </table> <p style="text-align: center;"><b>BAT-associated emission levels (BAT-AELs) for SO<sub>2</sub> emissions to air from the combustion of HFO and/or gas oil in reciprocating engines</b></p> <table border="1" style="width: 100%;"> <tr> <th rowspan="3" style="width: 20%;">Combustion plant total rated thermal input (MW<sub>th</sub>)</th> <th colspan="4">BAT-AELs for SO<sub>2</sub> (mg/Nm<sup>3</sup>)</th> </tr> <tr> <th colspan="2">Yearly average</th> <th colspan="2">Daily average or average over the sampling period</th> </tr> <tr> <th>New plant</th> <th>Existing plant <sup>(127)</sup></th> <th>New plant</th> <th>Existing plant <sup>(128)</sup></th> </tr> <tr> <td>All sizes</td> <td>45–100</td> <td>100–200 <sup>(129)</sup></td> <td>60–110</td> <td>105–235 <sup>(129)</sup></td> </tr> </table>				Not applicable to combustion plants operated < 500 h/yr. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr	Combustion plant total rated thermal input (MW <sub>th</sub> )	BAT-AELs for SO <sub>2</sub> (mg/Nm <sup>3</sup> )				Yearly average		Daily average or average over the sampling period		New plant	Existing plant <sup>(127)</sup>	New plant	Existing plant <sup>(128)</sup>	All sizes	45–100	100–200 <sup>(129)</sup>	60–110	105–235 <sup>(129)</sup>		
			Not applicable to combustion plants operated < 500 h/yr. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr																						
Combustion plant total rated thermal input (MW <sub>th</sub> )	BAT-AELs for SO <sub>2</sub> (mg/Nm <sup>3</sup> )																								
	Yearly average		Daily average or average over the sampling period																						
	New plant	Existing plant <sup>(127)</sup>	New plant	Existing plant <sup>(128)</sup>																					
All sizes	45–100	100–200 <sup>(129)</sup>	60–110	105–235 <sup>(129)</sup>																					
35	<p>In order to prevent or reduce dust and particulate-bound metal emissions from the combustion of HFO and/or gas oil in reciprocating engines, BAT is to use one or a combination of the techniques given below.</p> <table border="1" style="width: 100%;"> <thead> <tr> <th style="width: 10%;">Technique</th> <th style="width: 20%;">Description</th> <th style="width: 70%;">Applicability</th> </tr> </thead> <tbody> <tr> <td>a</td> <td rowspan="3">See descriptions in Section 8.5</td> <td>Applicable within the constraints associated with the availability of different types of fuel, which may be impacted by the energy policy of the Member State</td> </tr> <tr> <td>b</td> <td rowspan="2">Not applicable to combustion plants operated &lt; 500 h/yr</td> </tr> <tr> <td>c</td> </tr> </tbody> </table> <p style="text-align: center;"><b>BAT-associated emission levels (BAT-AELs) for dust emissions to air from the combustion of HFO and/or gas oil in reciprocating engines</b></p>	Technique	Description	Applicability	a	See descriptions in Section 8.5	Applicable within the constraints associated with the availability of different types of fuel, which may be impacted by the energy policy of the Member State	b	Not applicable to combustion plants operated < 500 h/yr	c	NA	Engines fired using gas oil with sulphur content less than 0.1% w/w.													
Technique	Description	Applicability																							
a	See descriptions in Section 8.5	Applicable within the constraints associated with the availability of different types of fuel, which may be impacted by the energy policy of the Member State																							
b		Not applicable to combustion plants operated < 500 h/yr																							
c																									

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																			
	<table border="1"> <tr> <td data-bbox="338 331 595 507" rowspan="3">Combustion plant total rated thermal input (MW<sub>th</sub>)</td> <td colspan="4" data-bbox="595 331 1117 363">BAT-AELs for dust (mg/Nm<sup>3</sup>)</td> </tr> <tr> <td colspan="2" data-bbox="595 363 808 424">Yearly average</td> <td colspan="2" data-bbox="808 363 1117 424">Daily average or average over the sampling period</td> </tr> <tr> <td data-bbox="595 424 680 507">New plant</td> <td data-bbox="680 424 808 507">Existing plant <sup>(130)</sup></td> <td data-bbox="808 424 938 507">New plant</td> <td data-bbox="938 424 1117 507">Existing plant <sup>(131)</sup></td> </tr> <tr> <td data-bbox="338 507 595 544">≥ 50</td> <td data-bbox="595 507 680 544">5–10</td> <td data-bbox="680 507 808 544">5–35</td> <td data-bbox="808 507 938 544">10–20</td> <td data-bbox="938 507 1117 544">10–45</td> </tr> </table>	Combustion plant total rated thermal input (MW <sub>th</sub> )	BAT-AELs for dust (mg/Nm <sup>3</sup> )				Yearly average		Daily average or average over the sampling period		New plant	Existing plant <sup>(130)</sup>	New plant	Existing plant <sup>(131)</sup>	≥ 50	5–10	5–35	10–20	10–45			
Combustion plant total rated thermal input (MW <sub>th</sub> )	BAT-AELs for dust (mg/Nm <sup>3</sup> )																					
	Yearly average		Daily average or average over the sampling period																			
	New plant	Existing plant <sup>(130)</sup>	New plant	Existing plant <sup>(131)</sup>																		
≥ 50	5–10	5–35	10–20	10–45																		
36	<p>In order to increase the energy efficiency of gas oil combustion in gas turbines, BAT is to use an appropriate combination of the techniques given in BAT 12 and below.</p> <table border="1"> <thead> <tr> <th data-bbox="338 644 468 705">Technique</th> <th data-bbox="468 644 633 705">Description</th> <th data-bbox="633 644 1117 705">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 705 360 887">a</td> <td data-bbox="360 705 468 887">Combined cycle</td> <td data-bbox="468 705 1117 887">See description in Section 8.2 Generally applicable to new units operated ≥ 1 500 h/yr. Applicable to existing units within the constraints associated with the steam cycle design and the space availability. Not applicable to existing units operated &lt; 1 500 h/yr</td> </tr> </tbody> </table> <p><b>BAT-associated energy efficiency levels (BAT-AEELs) for gas-oil-fired gas turbines</b></p> <table border="1"> <thead> <tr> <th data-bbox="338 970 770 1102" rowspan="3">Type of combustion unit</th> <th colspan="2" data-bbox="770 970 1117 1002">BAT-AEELs <sup>(132)</sup></th> </tr> <tr> <th colspan="2" data-bbox="770 1002 1117 1062">Net electrical efficiency (%) <sup>(133)</sup></th> </tr> <tr> <th data-bbox="770 1062 920 1102">New unit</th> <th data-bbox="920 1062 1117 1102">Existing unit</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 1102 770 1134">Gas-oil-fired open-cycle gas turbine</td> <td data-bbox="770 1102 920 1134">&gt; 33</td> <td data-bbox="920 1102 1117 1134">25–35,7</td> </tr> <tr> <td data-bbox="338 1134 770 1166">Gas-oil-fired combined cycle gas turbine</td> <td data-bbox="770 1134 920 1166">&gt; 40</td> <td data-bbox="920 1134 1117 1166">33–44</td> </tr> </tbody> </table>	Technique	Description	Applicability	a	Combined cycle	See description in Section 8.2 Generally applicable to new units operated ≥ 1 500 h/yr. Applicable to existing units within the constraints associated with the steam cycle design and the space availability. Not applicable to existing units operated < 1 500 h/yr	Type of combustion unit	BAT-AEELs <sup>(132)</sup>		Net electrical efficiency (%) <sup>(133)</sup>		New unit	Existing unit	Gas-oil-fired open-cycle gas turbine	> 33	25–35,7	Gas-oil-fired combined cycle gas turbine	> 40	33–44	CC	BAT AEL for efficiency is 33 – 44% in line with BAT36
Technique	Description	Applicability																				
a	Combined cycle	See description in Section 8.2 Generally applicable to new units operated ≥ 1 500 h/yr. Applicable to existing units within the constraints associated with the steam cycle design and the space availability. Not applicable to existing units operated < 1 500 h/yr																				
Type of combustion unit	BAT-AEELs <sup>(132)</sup>																					
	Net electrical efficiency (%) <sup>(133)</sup>																					
	New unit	Existing unit																				
Gas-oil-fired open-cycle gas turbine	> 33	25–35,7																				
Gas-oil-fired combined cycle gas turbine	> 40	33–44																				
37	<p>In order to prevent or reduce NO<sub>x</sub> emissions to air from the combustion of gas oil in gas turbines, BAT is to use one or a combination of the techniques given below.</p> <table border="1"> <thead> <tr> <th data-bbox="338 1270 521 1331">Technique</th> <th data-bbox="521 1270 674 1331">Description</th> <th data-bbox="674 1270 1117 1331">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 1331 360 1390">a</td> <td data-bbox="360 1331 521 1390">Water/steam addition</td> <td data-bbox="521 1331 1117 1390">The applicability may be limited due to water availability</td> </tr> </tbody> </table>	Technique	Description	Applicability	a	Water/steam addition	The applicability may be limited due to water availability	CC	No BAT AEL exists for NO <sub>x</sub> . Permit ELVs are 125 mg/m <sup>3</sup> monthly mean, 125 mg/m <sup>3</sup> 95% daily means, 250 mg/m <sup>3</sup> 95% hourly means. These have been carried forward and are specified in table S3.1(a)													
Technique	Description	Applicability																				
a	Water/steam addition	The applicability may be limited due to water availability																				

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement									
	<table border="1"> <tr> <td data-bbox="344 331 367 387">b</td> <td data-bbox="367 331 521 387">Low-NO<sub>x</sub> burners (LNB)</td> <td data-bbox="521 331 674 387"></td> <td data-bbox="674 331 1111 387">Only applicable to turbine models for which low-NO<sub>x</sub> burners are available on the market</td> </tr> <tr> <td data-bbox="344 387 367 443">c</td> <td data-bbox="367 387 521 443">Selective catalytic reduction (SCR)</td> <td data-bbox="521 387 674 443">See description in Section 8.3</td> <td data-bbox="674 387 1111 443">Not applicable to combustion plants operated &lt; 500 h/yr. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr. Retrofitting existing combustion plants may be constrained by the availability of sufficient space</td> </tr> </table>	b	Low-NO <sub>x</sub> burners (LNB)		Only applicable to turbine models for which low-NO <sub>x</sub> burners are available on the market	c	Selective catalytic reduction (SCR)	See description in Section 8.3	Not applicable to combustion plants operated < 500 h/yr. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr. Retrofitting existing combustion plants may be constrained by the availability of sufficient space			
b	Low-NO <sub>x</sub> burners (LNB)		Only applicable to turbine models for which low-NO <sub>x</sub> burners are available on the market									
c	Selective catalytic reduction (SCR)	See description in Section 8.3	Not applicable to combustion plants operated < 500 h/yr. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr. Retrofitting existing combustion plants may be constrained by the availability of sufficient space									
38	<p>In order to prevent or reduce CO emissions to air from the combustion of gas oil in gas turbines, BAT is to use one or a combination of the techniques given below.</p> <table border="1"> <thead> <tr> <th data-bbox="344 730 367 754">Technique</th> <th data-bbox="367 730 521 754">Description</th> <th data-bbox="521 730 1111 754">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="344 762 367 818">a</td> <td data-bbox="367 762 521 818">Combustion optimisation</td> <td data-bbox="521 762 1111 818">See description in Section 8.3 Generally applicable</td> </tr> <tr> <td data-bbox="344 826 367 882">b</td> <td data-bbox="367 826 521 882">Oxidation catalysts</td> <td data-bbox="521 826 1111 882">Not applicable to combustion plants operated &lt; 500 h/yr. Retrofitting existing combustion plants may be constrained by the availability of sufficient space</td> </tr> </tbody> </table> <p>As an indication, the emission level for NO<sub>x</sub> emissions to air from the combustion of gas oil in dual fuel gas turbines for emergency use operated &lt; 500 h/yr will generally be 145–250 mg/Nm<sup>3</sup> as a daily average or average over the sampling period.</p>	Technique	Description	Applicability	a	Combustion optimisation	See description in Section 8.3 Generally applicable	b	Oxidation catalysts	Not applicable to combustion plants operated < 500 h/yr. Retrofitting existing combustion plants may be constrained by the availability of sufficient space	CC	<p><u>Gas Turbines Firing on Gas Oil</u></p> <p>BAT sets an indicative ELV of 145 – 250 mg/m<sup>3</sup> CO but only for emergency units operating &lt;500hrs/year. The current permit restricts use of standby fuel distillate oil to no more than 2400 hours per year, we have reduced this down to 500 hours as the gas oil is a standby fuel. We have reduced this to 10 days. It is accepted in line with jep protocol that any gas fired plant, when firing standby fuel for individual periods of ≤ 10 days, due to a sudden interruption of the gas supply, shall be exempt from ELV compliance.</p> <p>Refer to Section 4.1 above.</p>
Technique	Description	Applicability										
a	Combustion optimisation	See description in Section 8.3 Generally applicable										
b	Oxidation catalysts	Not applicable to combustion plants operated < 500 h/yr. Retrofitting existing combustion plants may be constrained by the availability of sufficient space										
39	<p>In order to prevent or reduce SO<sub>x</sub> and dust emissions to air from the combustion of gas oil in gas turbines, BAT is to use the technique given below.</p> <table border="1"> <thead> <tr> <th data-bbox="344 1177 445 1233">Technique</th> <th data-bbox="445 1177 600 1233">Description</th> <th data-bbox="600 1177 1111 1233">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="344 1241 367 1297">a</td> <td data-bbox="367 1241 600 1297">Fuel choice</td> <td data-bbox="600 1241 1111 1297">See description in Section 8.4 Applicable within the constraints associated with the availability of different types of fuel, which may be impacted by the energy policy of the Member State</td> </tr> </tbody> </table>	Technique	Description	Applicability	a	Fuel choice	See description in Section 8.4 Applicable within the constraints associated with the availability of different types of fuel, which may be impacted by the energy policy of the Member State	CC	<p>The operator has confirmed that they are able to meet both the SO<sub>x</sub> (Yearly Average 60 mg/m<sup>3</sup>, Daily Average 66 mg/m<sup>3</sup>) BAT AEL's</p> <p>And Dust (Yearly Average 5 mg/m<sup>3</sup>, Daily Average 10 mg/m<sup>3</sup> when undertaking the combustion of gas oil in the GT's.</p> <p>Monitoring is to be undertaken in accordance with BAT4. The relevant BAT AELs and monitoring are specified in table S3.1(a)</p>			
Technique	Description	Applicability										
a	Fuel choice	See description in Section 8.4 Applicable within the constraints associated with the availability of different types of fuel, which may be impacted by the energy policy of the Member State										

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																		
	<p align="center"><b>BAT-associated emission levels for SO<sub>2</sub> and dust emissions to air from the combustion of gas oil in gas turbines, including dual fuel gas turbines</b></p> <table border="1" data-bbox="338 411 1117 699"> <thead> <tr> <th rowspan="3">Type of combustion on plant</th> <th colspan="4">BAT-AELs (mg/Nm<sup>3</sup>)</th> </tr> <tr> <th colspan="2">SO<sub>2</sub></th> <th colspan="2">Dust</th> </tr> <tr> <th>Yearly average <sup>(134)</sup></th> <th>Daily average or average over the sampling period <sup>(135)</sup></th> <th>Yearly average <sup>(134)</sup></th> <th>Daily average or average over the sampling period <sup>(135)</sup></th> </tr> </thead> <tbody> <tr> <td>New and existing plants</td> <td>35–60</td> <td>50–66</td> <td>2–5</td> <td>2–10</td> </tr> </tbody> </table>	Type of combustion on plant	BAT-AELs (mg/Nm <sup>3</sup> )				SO <sub>2</sub>		Dust		Yearly average <sup>(134)</sup>	Daily average or average over the sampling period <sup>(135)</sup>	Yearly average <sup>(134)</sup>	Daily average or average over the sampling period <sup>(135)</sup>	New and existing plants	35–60	50–66	2–5	2–10		
Type of combustion on plant	BAT-AELs (mg/Nm <sup>3</sup> )																				
	SO <sub>2</sub>		Dust																		
	Yearly average <sup>(134)</sup>	Daily average or average over the sampling period <sup>(135)</sup>	Yearly average <sup>(134)</sup>	Daily average or average over the sampling period <sup>(135)</sup>																	
New and existing plants	35–60	50–66	2–5	2–10																	
<b>Combustion of gaseous fuels</b>																					
40	<p>In order to increase the energy efficiency of natural gas combustion, BAT is to use an appropriate combination of the techniques given in BAT 12 and below.</p> <table border="1" data-bbox="338 847 1117 1193"> <thead> <tr> <th>Technique</th> <th>Description</th> <th>Applicability</th> </tr> </thead> <tbody> <tr> <td>a</td> <td>Combined cycle</td> <td>See description in Section 8.2</td> </tr> </tbody> </table> <p><b>BAT-associated energy efficiency levels (BAT-AEELs) for the combustion of natural gas</b></p> <table border="1" data-bbox="338 1251 1117 1369"> <thead> <tr> <th rowspan="2">Type of combustion unit</th> <th colspan="3">BAT-AEELs <sup>(136)</sup> <sup>(137)</sup></th> </tr> <tr> <th>Net electrical efficiency (%)</th> <th>Net total fuel utilisation (%) <sup>(138)</sup> <sup>(139)</sup></th> <th>Net mechanical energy efficiency (%) <sup>(139)</sup> <sup>(140)</sup></th> </tr> </thead> <tbody> <tr> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>	Technique	Description	Applicability	a	Combined cycle	See description in Section 8.2	Type of combustion unit	BAT-AEELs <sup>(136)</sup> <sup>(137)</sup>			Net electrical efficiency (%)	Net total fuel utilisation (%) <sup>(138)</sup> <sup>(139)</sup>	Net mechanical energy efficiency (%) <sup>(139)</sup> <sup>(140)</sup>					CC	<p>The installations uses a combination of techniques a, b, c, d, f, g and h.</p> <p>Optimisation of the working medium conditions GE Mark VI control system This control module is designed to run the DLN 2.6+ combustion system. Combined together they deliver optimal environmental performance, operability, availability and turbine performance. Medway is continually monitored at the SSE Engineering Centre via the Smart Signal connection to ensure system is operating at its optimum. Combustion turbines are re-tuned to account for seasonal temperature variation.</p> <p>Optimisation of the working steam cycle Medway is continually monitored at the SSE Engineering Centre via the Smart Signal connection to ensure system is operating at its optimum. The condenser vacuum is operated to within the range 55 – 60 mBar. Condenser cooling water is supplied from on-site cooling tower, the temperature of which is effected by the rate of blowdown and number of cooling tower fans running. Combustion turbines are tuned to account for seasonal temperature variation.</p> <p>Advanced Control System</p>	
Technique	Description	Applicability																			
a	Combined cycle	See description in Section 8.2																			
Type of combustion unit	BAT-AEELs <sup>(136)</sup> <sup>(137)</sup>																				
	Net electrical efficiency (%)	Net total fuel utilisation (%) <sup>(138)</sup> <sup>(139)</sup>	Net mechanical energy efficiency (%) <sup>(139)</sup> <sup>(140)</sup>																		

BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
		New unit	Existing unit		New unit	Existing unit	<p>GE Mark VI control system is designed to run the DLN 2.6+ combustion system. Combined together they deliver optimal environmental and turbine performance, operability and availability.</p> <p>Fuel preheating Incoming gas is preheated in heat exchangers supplied with water from the lower pressure economisers; this raises the gas temperature from approx. 5 °C to 140 °C.</p> <p>Combined cycle Medway power station is a combined cycle plant comprising (1) Brayton cycle: two GE 9FA combustion turbines (CT) and generators, and (2) Rankine cycle: a triple-pressure reheat steam cycle comprising two heat recovery steam generator (HRSG) feeding a single steam turbine and generator.</p> <p>Site efficiency determined at 54.2 % and reported in SSE Engineering Centre Technical Report Medway: Baseload Output and Efficiency Benchmark March 2016.</p> <p>The BAT AEEL for each of the gas turbines are within the specified range of 50-60% as require for an existing CCGT greater than or equal to 600MWe. See section 4.2 of this document.</p>	
Gas engine	39,5–44 <sup>(141)</sup>	35–44 <sup>(141)</sup>	56–85 <sup>(141)</sup>	No BAT-AEEL.				
Gas-fired boiler	39–42,5	38–40	78–95	No BAT-AEEL.				
Open cycle gas turbine, ≥ 50 MWth	36–41,5	33–41,5	No BAT-AEEL	36,5–41	33,5–41			
<b>Combined cycle gas turbine (CCGT)</b>								
CCGT, 50–600 MW <sub>th</sub>	53–58,5	46–54	No BAT-AEEL	No BAT-AEEL				
CCGT, ≥ 600 MW <sub>th</sub>	57–60,5	50–60	No BAT-AEEL	No BAT-AEEL				
CHP CCGT, 50–600 MW <sub>th</sub>	53–58,5	46–54	65–95	No BAT-AEEL				
CHP CCGT, ≥ 600 MW <sub>th</sub>	57–60,5	50–60	65–95	No BAT-AEEL				
41	In order to prevent or reduce NO <sub>x</sub> emissions to air from the combustion of natural gas in boilers, BAT is to use one or a combination of the techniques given below.						CC	The operator has confirmed that they have an auxiliary boiler for the supply of superheated steam during station start-up to supply gland steam at 6,000 kg/hr, 7 Bar and 260 °C. The plant is designed for quick response and intermittent operation.
	<b>Technique</b>		<b>Description</b>		<b>Applicability</b>			
	a	Air and/or fuel staging	See descriptions in Section 8.3. Air staging is often associated with low-NO <sub>x</sub> burners		Generally applicable			
	b	Flue-gas recirculation	See description in Section 8.3					
	c	Low-NO <sub>x</sub> burners (LNB)						



BAT Conc. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement							
	d . Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system									
	e . Reduction of the combustion air temperature	See description in Section 8.3	Generally applicable within the constraints associated with the process needs									
	f . Selective non-catalytic reduction (SNCR)		Not applicable to combustion plants operated < 500 h/yr with highly variable boiler loads. The applicability may be limited in the case of combustion plants operated between 500 h/yr and 1 500 h/yr with highly variable boiler loads									
	g . Selective catalytic reduction (SCR)		Not applicable to combustion plants operated < 500 h/yr. Not generally applicable to combustion plants of < 100 MW <sub>th</sub> . There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr									
42	In order to prevent or reduce NO <sub>x</sub> emissions to air from the combustion of natural gas in gas turbines, BAT is to use one or a combination of the techniques given below.			CC	<p>The operator confirmed that the following techniques are used</p> <p>a. Advanced control system GE Mark VI control system is in place This control module is designed to run the DLN 2.6+ combustion system. Combined together they deliver optimal environmental and turbine performance, operability and availability.</p> <p>c. Combustion optimisation, Dry low-NO<sub>x</sub> burners (DLN) GE DLN 2.6+ combustion system</p>							
	<table border="1"> <thead> <tr> <th data-bbox="322 1209 512 1246">Technique</th> <th data-bbox="512 1209 808 1246">Description</th> <th data-bbox="808 1209 1133 1246">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 1246 512 1386">a . Advanced control system</td> <td data-bbox="512 1246 808 1386">See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated &lt; 500 h/yr</td> <td data-bbox="808 1246 1133 1386">The applicability to old combustion plants may be constrained by the need to retrofit the combustion</td> </tr> </tbody> </table>	Technique	Description	Applicability	a . Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion					
Technique	Description	Applicability										
a . Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion										

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
				system and/or control command system	<p>Emissions of NO<sub>x</sub> and CO are minimised to deliver optimum operational and environmental performance. This is achieved through staged combustion modes from diffusion through to premixed where the fuel is distributed differently in the combustors and the fuel flow is modulated as a function of the combustion temperature.</p> <p>Combustion hardware and control system is current state of the art supplied by GE for combustion turbines installed at Medway.</p> <p>DLN is effective at (i) 90 MW output load, and (ii) 57% rated thermal output based on DLN curves provided with the Reg61 response and email of 03/03/20 as evidence. See section 4.3</p>
b.	Water/steam addition	See description in Section 8.3	The applicability may be limited due to water availability		
c.	Dry low-NO <sub>x</sub> burners (DLN)		The applicability may be limited in the case of turbines where a retrofit package is not available or when water/steam addition systems are installed		
d.	Low-load design concept	Adaptation of the process control and related equipment to maintain good combustion efficiency when the demand in energy varies, e.g. by improving the inlet airflow control capability or by splitting the combustion process into decoupled combustion stages	The applicability may be limited by the gas turbine design		
e.	Low-NO <sub>x</sub> burners (LNB)	See description in Section 8.3	Generally applicable to supplementary firing for heat recovery steam generators (HRSGs) in the case of combined-cycle gas turbine (CCGT) combustion plants		
f.	Selective catalytic reduction (SCR)		Not applicable in the case of combustion plants operated < 500 h/yr. Not generally applicable to existing combustion plants of < 100 MW <sub>th</sub> . Retrofitting existing combustion plants may be constrained by the availability of sufficient space. There may be technical and economic restrictions		

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																																						
	<table border="1"> <tr> <td data-bbox="338 331 488 437"></td> <td data-bbox="488 331 853 437"></td> <td data-bbox="853 331 1122 437">for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr</td> </tr> </table>			for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr																																					
		for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr																																							
43	In order to prevent or reduce NO <sub>x</sub> emissions to air from the combustion of natural gas in engines, BAT is to use one or a combination of the techniques given in BAT 43.	N/A	There are no natural gas engines on site.																																						
44	<p>In order to prevent or reduce CO emissions to air from the combustion of natural gas, BAT is to ensure optimised combustion and/or to use oxidation catalysts.</p> <p><b>Description - See descriptions in Section 8.3.</b></p> <p><b>BAT-associated emission levels (BAT-AELs) for NO<sub>x</sub> emissions to air from the combustion of natural gas in gas turbines</b></p> <table border="1"> <thead> <tr> <th data-bbox="338 724 645 943" rowspan="2">Type of combustion plant</th> <th data-bbox="645 724 808 943" rowspan="2">Combustion plant total rated thermal input (MW<sub>th</sub>)</th> <th colspan="2" data-bbox="808 724 1122 783">BAT-AELs (mg/Nm<sup>3</sup>) <sup>(142)</sup> <sup>(143)</sup></th> </tr> <tr> <th data-bbox="808 783 954 943">Yearly average <sup>(144)</sup> <sup>(145)</sup></th> <th data-bbox="954 783 1122 943">Daily average or average over the sampling period</th> </tr> </thead> <tbody> <tr> <td colspan="4" data-bbox="338 943 1122 979" style="text-align: center;"><b>Open-cycle gas turbines (OCGTs) <sup>(146)</sup> <sup>(147)</sup></b></td> </tr> <tr> <td data-bbox="338 979 645 1018">New OCGT</td> <td data-bbox="645 979 808 1018">≥ 50</td> <td data-bbox="808 979 954 1018">15–35</td> <td data-bbox="954 979 1122 1018">25–50</td> </tr> <tr> <td data-bbox="338 1018 645 1129">Existing OCGT (excluding turbines for mechanical drive applications) — All but plants operated &lt; 500 h/yr</td> <td data-bbox="645 1018 808 1129">≥ 50</td> <td data-bbox="808 1018 954 1129">15–50</td> <td data-bbox="954 1018 1122 1129">25–55 <sup>(148)</sup></td> </tr> <tr> <td colspan="4" data-bbox="338 1129 1122 1166" style="text-align: center;"><b>Combined-cycle gas turbines (CCGTs) <sup>(146)</sup> <sup>(149)</sup></b></td> </tr> <tr> <td data-bbox="338 1166 645 1204">New CCGT</td> <td data-bbox="645 1166 808 1204">≥ 50</td> <td data-bbox="808 1166 954 1204">10–30</td> <td data-bbox="954 1166 1122 1204">15–40</td> </tr> <tr> <td data-bbox="338 1204 645 1268">Existing CCGT with a net total fuel utilisation of &lt; 75 %</td> <td data-bbox="645 1204 808 1268">≥ 600</td> <td data-bbox="808 1204 954 1268">10–40</td> <td data-bbox="954 1204 1122 1268">18–50</td> </tr> <tr> <td data-bbox="338 1268 645 1332">Existing CCGT with a net total fuel utilisation of ≥ 75 %</td> <td data-bbox="645 1268 808 1332">≥ 600</td> <td data-bbox="808 1268 954 1332">10–50</td> <td data-bbox="954 1268 1122 1332">18–55 <sup>(150)</sup></td> </tr> <tr> <td data-bbox="338 1332 645 1390">Existing CCGT with a net total fuel utilisation of &lt; 75 %</td> <td data-bbox="645 1332 808 1390">50–600</td> <td data-bbox="808 1332 954 1390">10–45</td> <td data-bbox="954 1332 1122 1390">35–55</td> </tr> </tbody> </table>	Type of combustion plant	Combustion plant total rated thermal input (MW <sub>th</sub> )	BAT-AELs (mg/Nm <sup>3</sup> ) <sup>(142)</sup> <sup>(143)</sup>		Yearly average <sup>(144)</sup> <sup>(145)</sup>	Daily average or average over the sampling period	<b>Open-cycle gas turbines (OCGTs) <sup>(146)</sup> <sup>(147)</sup></b>				New OCGT	≥ 50	15–35	25–50	Existing OCGT (excluding turbines for mechanical drive applications) — All but plants operated < 500 h/yr	≥ 50	15–50	25–55 <sup>(148)</sup>	<b>Combined-cycle gas turbines (CCGTs) <sup>(146)</sup> <sup>(149)</sup></b>				New CCGT	≥ 50	10–30	15–40	Existing CCGT with a net total fuel utilisation of < 75 %	≥ 600	10–40	18–50	Existing CCGT with a net total fuel utilisation of ≥ 75 %	≥ 600	10–50	18–55 <sup>(150)</sup>	Existing CCGT with a net total fuel utilisation of < 75 %	50–600	10–45	35–55	CC	<p>As per the response to BAT 42 above:</p> <p>An Advanced control system GE Mark VI control system is in place Combustion optimisation, Dry low-NO<sub>x</sub> burners (DLN) GE DLN 2.6+ combustion system to minimise emissions of NO<sub>x</sub> and CO are minimised to deliver optimum operational and environmental performance. However, the operator has pointed out that unlike NO<sub>x</sub>, CO increases exponentially as the gas turbine approaches the emission compliance boundary defined by the combustion system. For this reason, hourly CO emissions are often close to the current 100mg/m<sup>3</sup> ELV when the plant is operating at its stable operating limit (SEL) and gas turbine load is at its minimum. The operator has therefore requested a BAT-AEL to 100 mg/m<sup>3</sup>, higher than indicative CO Annual BAT-AEL of 30 mg/m<sup>3</sup> to allow for the combustion characteristics of this gas turbine and potential combustor degradation relating to combustor air in-leakage. See section 4.3 for details of the limit as specified in table S3.1a of the permit</p>
Type of combustion plant	Combustion plant total rated thermal input (MW <sub>th</sub> )			BAT-AELs (mg/Nm <sup>3</sup> ) <sup>(142)</sup> <sup>(143)</sup>																																					
		Yearly average <sup>(144)</sup> <sup>(145)</sup>	Daily average or average over the sampling period																																						
<b>Open-cycle gas turbines (OCGTs) <sup>(146)</sup> <sup>(147)</sup></b>																																									
New OCGT	≥ 50	15–35	25–50																																						
Existing OCGT (excluding turbines for mechanical drive applications) — All but plants operated < 500 h/yr	≥ 50	15–50	25–55 <sup>(148)</sup>																																						
<b>Combined-cycle gas turbines (CCGTs) <sup>(146)</sup> <sup>(149)</sup></b>																																									
New CCGT	≥ 50	10–30	15–40																																						
Existing CCGT with a net total fuel utilisation of < 75 %	≥ 600	10–40	18–50																																						
Existing CCGT with a net total fuel utilisation of ≥ 75 %	≥ 600	10–50	18–55 <sup>(150)</sup>																																						
Existing CCGT with a net total fuel utilisation of < 75 %	50–600	10–45	35–55																																						

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	
	Existing CCGT with a net total fuel utilisation of $\geq 75\%$	50–600	25–50 <sup>(151)</sup>	35–55 <sup>(152)</sup>		
	<b>Open- and combined-cycle gas turbines</b>					
	Gas turbine put into operation no later than 27 November 2003, or existing gas turbine for emergency use and operated $< 500$ h/yr	$\geq 50$	No BAT-AEL	60–140 <sup>(153)</sup> <sup>(154)</sup>		
	Existing gas turbine for mechanical drive applications — All but plants operated $< 500$ h/yr	$\geq 50$	15–50 <sup>(155)</sup>	25–55 <sup>(156)</sup>		
	<p>As an indication, the yearly average CO emission levels for each type of existing combustion plant operated <math>\geq 1\,500</math> h/yr and for each type of new combustion plant will generally be as follows:</p> <ul style="list-style-type: none"> <li>— New OCGT of <math>\geq 50</math> MW<sub>th</sub>: <math>&lt; 5\text{--}40</math> mg/Nm<sup>3</sup>. For plants with a net electrical efficiency (EE) greater than 39 %, a correction factor may be applied to the higher end of this range, corresponding to [higher end] <math>\times</math> EE/39, where EE is the net electrical energy efficiency or net mechanical energy efficiency of the plant determined at ISO baseload conditions.</li> <li>— Existing OCGT of <math>\geq 50</math> MW<sub>th</sub> (excluding turbines for mechanical drive applications): <math>&lt; 5\text{--}40</math> mg/Nm<sup>3</sup>. The higher end of this range will generally be 80 mg/Nm<sup>3</sup> in the case of existing plants that cannot be fitted with dry techniques for NO<sub>x</sub> reduction, or 50 mg/Nm<sup>3</sup> for plants that operate at low load.</li> <li>— New CCGT of <math>\geq 50</math> MW<sub>th</sub>: <math>&lt; 5\text{--}30</math> mg/Nm<sup>3</sup>. For plants with a net electrical efficiency (EE) greater than 55 %, a correction factor may be applied to the higher end of the range, corresponding to [higher end] <math>\times</math> EE/55, where EE is the net electrical energy efficiency of the plant determined at ISO baseload conditions.</li> <li>— Existing CCGT of <math>\geq 50</math> MW<sub>th</sub>: <math>&lt; 5\text{--}30</math> mg/Nm<sup>3</sup>. The higher end of this range will generally be 50 mg/Nm<sup>3</sup> for plants that operate at low load.</li> <li>— Existing gas turbines of <math>\geq 50</math> MW<sub>th</sub> for mechanical drive applications: <math>&lt; 5\text{--}40</math> mg/Nm<sup>3</sup>. The higher end of the range will generally be 50 mg/Nm<sup>3</sup> when plants operate at low load.</li> </ul> <p>In the case of a gas turbine equipped with DLN burners, these indicative levels correspond to when the DLN operation is effective.</p>					

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																							
	<p><b>BAT-associated emission levels (BAT-AELs) for NO<sub>x</sub> emissions to air from the combustion of natural gas in boilers and engines</b></p> <table border="1" data-bbox="338 384 1117 608"> <thead> <tr> <th rowspan="3">Type of combustion plant</th> <th colspan="4">BAT-AELs (mg/Nm<sup>3</sup>)</th> </tr> <tr> <th colspan="2">Yearly average <sup>(157)</sup></th> <th colspan="2">Daily average or average over the sampling period</th> </tr> <tr> <th>New plant</th> <th>Existing plant <sup>(158)</sup></th> <th>New plant</th> <th>Existing plant <sup>(159)</sup></th> </tr> </thead> <tbody> <tr> <td>Boiler</td> <td>10–60</td> <td>50–100</td> <td>30–85</td> <td>85–110</td> </tr> <tr> <td>Engine <sup>(160)</sup></td> <td>20–75</td> <td>20–100</td> <td>55–85</td> <td>55–110 <sup>(161)</sup></td> </tr> </tbody> </table> <p>As an indication, the yearly average CO emission levels will generally be:</p> <ul style="list-style-type: none"> <li>— &lt; 5–40 mg/Nm<sup>3</sup> for existing boilers operated ≥ 1 500 h/yr,</li> <li>— &lt; 5–15 mg/Nm<sup>3</sup> for new boilers,</li> <li>— 30–100 mg/Nm<sup>3</sup> for existing engines operated ≥ 1 500 h/yr and for new engines.</li> </ul>	Type of combustion plant	BAT-AELs (mg/Nm <sup>3</sup> )				Yearly average <sup>(157)</sup>		Daily average or average over the sampling period		New plant	Existing plant <sup>(158)</sup>	New plant	Existing plant <sup>(159)</sup>	Boiler	10–60	50–100	30–85	85–110	Engine <sup>(160)</sup>	20–75	20–100	55–85	55–110 <sup>(161)</sup>		
Type of combustion plant	BAT-AELs (mg/Nm <sup>3</sup> )																									
	Yearly average <sup>(157)</sup>		Daily average or average over the sampling period																							
	New plant	Existing plant <sup>(158)</sup>	New plant	Existing plant <sup>(159)</sup>																						
Boiler	10–60	50–100	30–85	85–110																						
Engine <sup>(160)</sup>	20–75	20–100	55–85	55–110 <sup>(161)</sup>																						
<p><b>BAT Conclusions 46 to 51 for iron and steel process gases.</b>  <b>BAT Conclusions 52 to 54 for offshore platforms.</b>  <b>BAT Conclusions 55 to 59 for chemical process gases.</b>  <b>BAT Conclusions 60 to 71 for co-incineration.</b>  <b>BAT Conclusions 72 to 75 for gasification.</b>  <b>These BAT Conclusions are not applicable to the activities carried out at the installation.</b></p>																										

## 6. Emissions to Water

The consolidated permit incorporates the 3 current discharges to controlled waters identified as W1 to W3. W1 (cooling water including boiler blow down from HRSG and auxiliary boiler) and W2 (effluent tank consisting of water treatment plant effluent, treated site sewage effluent, condensate from the deodorising compound and site drainage) discharge to the River Medway at NGR TQ 868739 and NGR TQ 867739 respectively. W3 (surface water run-off and storm water from roofs and roadways) discharges via an interceptor to the River Medway at NGR TQ 873347.

There are no BAT AELs specified in the BAT Conclusions for this type of plant. There are also no additional treatment options identified as BAT for the installation. We have therefore not carried out any additional assessment of the emissions to water as part of this review.

The Operator also requested that the limits for mercury and cadmium are removed from the surface water discharge monitoring requirements, emission point W1 (Table S3.2). Currently the permit specifies weekly spot sample. The Operator states that the monitoring results have always been below the limit of detection.

Mercury and cadmium were originally included in the permit as they were identified as being potentially minor constituents in two products used in regenerating the water treatment plant (hydrochloric acid and sodium hydroxide). However, the Operator has confirmed that the water treatment plant now uses caustic soda. The supplier of the caustic soda confirmed that they use purified brine to produce the caustic soda solution. They also carry out biannual analysis of the caustic soda produced, both mercury and cadmium are included in the analysis suite. They are routinely shown to be at very low levels or none is detected.

We agree with the Operators justification and have removed mercury and cadmium from Table S3.2 in the consolidated permit.

## **7. Additional IED Chapter II requirements:**

### **Black start operations**

In the event of a black out National Grid would call on combustion plant to operate and may require them to do so outside their permitted conditions. We have dedicated black start plant and they are permitted to run as such but this scenario is relevant to the rest of the large combustion plant which could be called depending on the circumstances.

A risk assessment will be carried out by Energy UK/Joint Environmental Programme on behalf of Large Combustion Plant connected to the National Transmission System. Air emissions modelling will be based on generic black start scenarios to establish whether they have the potential to have local impact on the environment or not (on a national basis). If the modelling demonstrates that no significant impacts are likely, the plant can operate under condition 2.3.9. This conditions allows the hourly ELVs for plants operating under a black start instruction to be discounted for the purpose of reporting. We would also require there to be a procedure in place for minimisation of emissions in the case of a black start event and for reporting in the event of a black start. This modelling and the procedures have not been agreed in advance of the issue of the permit review and therefore a condition linking back to an improvement condition have been included in the permit.

## 8. Review and assessment of changes that are not part of the BAT Conclusions derived permit review.

This document should be read in conjunction with the application, supporting information and notice.

Aspect considered	Decision
<b>Receipt of application</b>	
Confidential information	A claim for commercial or industrial confidentiality has not been made.
Identifying confidential information	We have not identified information provided as part of the application that we consider to be confidential.
<b>Operating techniques</b>	
General operating techniques	<p>We have reviewed the techniques used by the operator where they are relevant to the BAT Conclusions and compared these with the relevant guidance notes.</p> <p>The permit conditions ensure compliance with the relevant BREF, BAT Conclusions. The ELVs deliver compliance with the BAT-AELs.</p>
<b>Permit conditions</b>	
Updating permit conditions during consolidation	We have updated permit conditions to those in the current generic permit template as part of permit consolidation. The conditions will provide at least the same level of protection as those in the previous permit and in some cases will provide a higher level of protection to those in the previous permit.
Changes to the permit conditions due to an Environment Agency initiated variation	We have varied the permit as stated in the variation notice.
Improvement programme	<p>We have imposed an improvement programme (IC14) to ensure that the operator provides a report that assesses the impact of emissions during operation under Black Start and provides a methodology for minimising impact during Black Start operation and for reporting instances of Black Start operation.</p> <p>We have also removed the completed improvement conditions from the permit.</p>
Emission limits	<p>We have decided that emission limits should be set for the parameters listed in the permit.</p> <ul style="list-style-type: none"> <li>• Nitrogen Dioxide</li> <li>• Carbon Monoxide</li> </ul>



Aspect considered	Decision
	<p>And when using standby fuel gas oil</p> <ul style="list-style-type: none"> <li>• Sulphur dioxide</li> <li>• Dust</li> </ul> <p>These are described in the relevant BAT Conclusions in Sections 4.1 and 5 of this document.</p> <p>It is considered that the ELVs/equivalent parameters or technical measures described above will ensure that significant pollution of the environment is prevented and a high level of protection for the environment is secured.</p>
Monitoring	<p>We have decided that monitoring should be carried out for the parameters listed in the permit, using the methods detailed and to the frequencies specified.</p> <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p> <p>Table S3.4 Process monitoring requirements was amended to include the requirement to monitor energy efficiency after overhauls on site in line with BAT2.</p> <p>Based on the information in the application we are satisfied that the operator's techniques, personnel and equipment have either MCERTS certification or MCERTS accreditation as appropriate.</p>
Reporting	<p>We have specified reporting in the permit for the following parameters:</p> <ul style="list-style-type: none"> <li>• Nitrogen dioxide</li> <li>• Carbon monoxide</li> <li>• Sulphur dioxide</li> <li>• Dust</li> </ul> <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p>
<b>Operator competence</b>	
Management system	<p>There is no known reason to consider that the operator will not have the management system to enable it to comply with the permit conditions.</p>
<b>Growth Duty</b>	
Section 108 Deregulation Act 2015 – Growth duty	<p>We have considered our duty to have regard to the desirability of promoting economic growth set out in section 108(1) of the Deregulation Act 2015 and the guidance issued under section 110 of that Act in deciding whether to grant this permit.</p> <p>Paragraph 1.3 of the guidance says:</p> <p>“The primary role of regulators, in delivering regulation, is to achieve the regulatory outcomes for which they are</p>

Aspect considered	Decision
	<p>responsible. For a number of regulators, these regulatory outcomes include an explicit reference to development or growth. The growth duty establishes economic growth as a factor that all specified regulators should have regard to, alongside the delivery of the protections set out in the relevant legislation.”</p> <p>We have addressed the legislative requirements and environmental standards to be set for this operation in the body of the decision document above. The guidance is clear at paragraph 1.5 that the growth duty does not legitimise non-compliance and its purpose is not to achieve or pursue economic growth at the expense of necessary protections.</p> <p>We consider the requirements and standards we have set in this permit are reasonable and necessary to avoid a risk of an unacceptable level of pollution. This also promotes growth amongst legitimate operators because the standards applied to the operator are consistent across businesses in this sector and have been set to achieve the required legislative standards.</p>