

## Environment Agency

# **Review of an Environmental Permit for an Installation subject to Chapter II of the Industrial Emissions Directive under the Environmental Permitting (England & Wales) Regulations 2016**

## **Decision document recording our decision-making process following review of a permit**

The Permit number is: EPR/QP3632TF  
The Operator is: Whitetower Energy Limited  
The Installation is: Heartlands Plant  
This Variation Notice number is: EPR/QP3632TF/V004

### **What this document is about**

Article 21(3) of the Industrial Emissions Directive (IED) requires the Environment Agency to review conditions in permits that it has issued and to ensure that the permit delivers compliance with relevant standards, within four years of the publication of updated decisions on best available techniques (BAT) conclusions.

We have reviewed the permit for this installation against the revised BAT Conclusions for large combustion plant published on 17<sup>th</sup> August 2017. This is our decision document, which explains the reasoning for the consolidated variation notice that we are issuing.

It explains how we have reviewed and considered the techniques used by the Operator in the operation and control of the plant and activities of the installation. This review has been undertaken with reference to the decision made by the European Commission establishing best available techniques (BAT) conclusions ('BAT Conclusions') for large combustion plant as detailed in document reference IEDC-7-1. It is our record of our decision-making process and shows how we have taken into account all relevant factors in reaching our position. It also provides a justification for the inclusion of any specific conditions in the permit that are in addition to those included in our generic permit template.

As well as considering the review of the operating techniques used by the Operator for the operation of the plant and activities of the installation, the consolidated variation notice takes into account and brings together in a single document all previous variations that relate to the original permit

issued. It also modernises the entire permit to reflect the conditions contained in our current generic permit template.

The introduction of new template conditions makes the Permit consistent with our current general approach and philosophy and with other permits issued to installations in this sector. Although the wording of some conditions has changed, while others have been removed because of the new regulatory approach, it does not reduce the level of environmental protection achieved by the Permit in any way. In this document we therefore address only our determination of substantive issues relating to the new BAT Conclusions.

Throughout this document we will use a number of expressions. These are as referred to in the glossary and have the same meaning as described in “Schedule 6 Interpretation” of the Permit.

We try to explain our decision as accurately, comprehensively and plainly as possible. We would welcome any feedback as to how we might improve our decision documents in future. A lot of technical terms and acronyms are inevitable in a document of this nature: we provide a glossary of acronyms near the front of the document, for ease of reference.

## How this document is structured

### Glossary of terms

- 1 Our decision
- 2 How we reached our decision
- 2.1 Requesting information to demonstrate compliance with BAT Conclusions for Large Combustion Plant
- 2.2 Review of our own information in respect to the capability of the installation to meet revised standards included in the BAT Conclusions document
- 3 The legal framework
- 4 Key Issues
- 5 Decision checklist regarding relevant BAT Conclusions
- 6 Review and assessment of derogation requests made by the operator in relation to BAT Conclusions which include an associated emission level (AEL) value
- 7 Emissions to Water
- 8 Additional IED Chapter II requirements
- 9 Review and assessment of changes that are not part of the BAT Conclusions derived permit review.

## Glossary of acronyms used in this document

(Please note that this glossary is standard for our decision documents and therefore not all these acronyms are necessarily used in this document.)

APC	Air Pollution Control
BAT	Best Available Technique(s)
BAT-AEEL	BAT Associated Energy Efficiency Level
BAT-AEL	BAT Associated Emission Level
BATc	BAT conclusion
BREF	Best available techniques reference document
CCGT	Combined Cycle Gas Turbine
CEM	Continuous emissions monitor
CHP	Combined heat and power
CV	Calorific value
DAA	Directly associated activity – Additional activities necessary to be carried out to allow the principal activity to be carried out
DLN	Dry Low NOx burners
DLN-E	Dry Low NOx effective
EIONET	European environment information and observation network is a partnership network of the European Environment Agency
ELV	Emission limit value derived under BAT or an emission limit value set out in IED
EMS	Environmental Management System
EPR	Environmental Permitting (England and Wales) Regulations 2016 (SI 2016 No. 1154)
EWC	European waste catalogue
FSA	Food Standards Agency
IC	Improvement Condition
IED	Industrial Emissions Directive (2010/75/EU)
IPPCD	Integrated Pollution Prevention and Control Directive (2008/1/EC) – now superseded by IED
LCP	Large Combustion Plant subject to Chapter III of IED
MSUL/MSDL	Minimum start up load/minimum shut-down load
NOx	Oxides of nitrogen (NO plus NO <sub>2</sub> expressed as NO <sub>2</sub> )
NPV	Net Present Value
OCGT	Open Cycle Gas Turbine
PHE	Public Health England
SAC	Special Area of Conservation
SGN	Sector guidance note
TGN	Technical guidance note
TNP	Transitional National Plan
TOC	Total Organic Carbon
WFD	Water Framework Directive (2000/60/EC)

## **1 Our decision**

We have decided to issue the consolidated variation notice to the Operator. This will allow it to continue to operate the Installation, subject to the conditions in the consolidated variation notice.

We consider that, in reaching that decision, we have taken into account all relevant considerations and legal requirements and that the varied permit will ensure that a high level of protection is provided for the environment and human health.

The consolidated variation notice contains many conditions taken from our standard Environmental Permit template including the relevant Annexes. We developed these conditions in consultation with industry, having regard to the legal requirements of the Environmental Permitting Regulations and other relevant legislation. This document does not therefore include an explanation for these standard conditions. Where they are included in the Notice, we have considered the techniques identified by the operator for the operation of their installation, and have accepted that the details are sufficient and satisfactory to make those standard conditions appropriate. This document does, however, provide an explanation of our use of “tailor-made” or installation-specific conditions, or where our Permit template provides two or more options.

## **2 How we reached our decision**

### **2.1 Requesting information to demonstrate compliance with BAT Conclusions for Large Combustion Plant**

We issued a Notice under Regulation 61(1) of the Environmental Permitting (England and Wales) Regulations 2016 (a Regulation 61 Notice) on 1<sup>st</sup> May 2018 requiring the Operator to provide information to demonstrate how the operation of their installation currently meets, or will subsequently meet, the revised standards described in the large combustion plant BAT Conclusions document. The Notice also required that where the revised standards are not currently met, the operator should provide information that:

- Describes the techniques that will be implemented before 17<sup>th</sup> August 2021, which will then ensure that operations meet the revised standard, or
- Justifies why standards will not be met by 17<sup>th</sup> August 2021, and confirmation of the date when the operation of those processes will cease within the installation or an explanation of why the revised BAT standard is not applicable to those processes, or
- Justifies why an alternative technique will achieve the same level of environmental protection equivalent to the revised standard described in the BAT Conclusions.

Where the Operator proposed that they were not intending to meet a BAT standard that also included a BAT Associated Emission Level (BAT AEL) described in the BAT Conclusions Document, the Regulation 61 Notice requested that the Operator make a formal request for derogation from compliance with that AEL (as provisioned by Article 15(4) of IED). In this circumstance, the Notice identified that any such request for derogation must be supported and justified by sufficient technical and commercial information that would enable us to determine acceptability of the derogation request.

The Regulation 61 Notice response from the Operator was received on 30/10/2018.

We considered it was in the correct form and contained sufficient information for us to begin our determination of the permit review but not that it necessarily contained all the information we would need to complete that review: see below.

An updated Regulation 61 Notice response from the Operator was received on 12 May 2020. This response contains additional information and supersedes the previous Regulation 61 response. We have based our review on this submission.

## **2.2 Review of our own information in respect to the capability of the installation to meet revised standards included in the BAT Conclusions document**

Based on our records and previous regulatory activities with the facility we have no reason to consider that the operator will not be able to comply with the conditions that we include in the permit.

### 3 The legal framework

The consolidated variation notice will be issued under Regulation 20 of the EPR. The Environmental Permitting regime is a legal vehicle which delivers most of the relevant legal requirements for activities falling within its scope. In particular, the regulated facility is:

- an *installation* as described by the IED;
- subject to aspects of other relevant legislation which also have to be addressed.

We consider that the consolidated variation notice will ensure that the operation of the Installation complies with all relevant legal requirements and that a high level of protection will be delivered for the environment and human health.

We explain how we have addressed specific statutory requirements more fully in the rest of this document.

## 4 The key issues

The key issues arising during this permit review are:

- Emissions to air and the emission limits applied to the plant.
- The energy efficiency levels associated with the Best Available Techniques (BAT-AEELs)

We therefore describe how we determined these issues in most detail in the relevant sections of this document.

### 4.1 Emissions to air and the emission limits applied to the plant

A number of general principles were applied during the permit review. These included:

- The upper value of the BAT AELs ranges specified were used unless use of the tighter limit was justified.
- The principle of no backsliding where if existing limits in the permit were already tighter than those specified in the BREF, the existing permit limits were retained.
- Where a limit was specified in both IED Annex V and the BAT Conclusions for a particular reference period, the tighter limit was applied and in the majority of cases this was from the BAT Conclusions.
- Where AELs are indicative in the BAT Conclusions, these were applied unless adequate justification was provided by the operator to demonstrate that an alternative limit was more appropriate.
- For gas turbines where the IED specified that limits applied over 70% load and the BAT Conclusions specified that AELs applied when dry low NO<sub>x</sub> is effective (DLN-E), we have used DLN-E as a default across all monitoring requirements for NO<sub>x</sub> and CO.

The LCP173 on site consist of two open cycle gas turbines (OCGT) unit 1 has a net rated thermal input of 128.2 MWth and unit 2 has a net rated thermal input of 128.2 MWth.

The plant was put into operation before IED came into force and therefore the existing limits in the permit are from Part 1 of IED Annex V applicable to existing plant.

The ELVs and AELs are based on the following operating regime:

- OCGT existing plant
- <1500 hours operation
- Combustion plant total rated thermal input (MWth)  $\geq$  50

The following tables outline the limits that have been incorporated into the permit for LCP173, where these were derived from and the reference periods



at which they apply. The emission limits refer to concentrations, expressed as mass of emitted substance per volume of flue-gas under the following standard conditions:

- dry gas at a temperature of 273,15 K,
- pressure of 101,3 kPa and 15% volume reference oxygen concentration if flue gases.

The emission limits and monitoring requirements have been incorporated into Schedule 3 of the permit.

NOx limits (mg/Nm <sup>3</sup> )							
Averaging	IED (Annex V Part 1) - Existing	BREF (Table 24 BAT-c)	Current	Expected permit limits	Basis	Limits apply	Monitoring
Monthly	50	None	50	50	IED	E-DLN	Continuous
Daily	55	55	55	55	BREF/IED	E-DLN and MSUL/MSDL to baseload	
95 <sup>th</sup> %ile of hr means	100	None	60	60	Current No backsliding	E-DLN	

CO limits (mg/Nm <sup>3</sup> ) indicative							
Averaging	IED (Annex V Part 1) - Existing	BREF (Table 24 BAT-c)	Current	Expected permit limits	Basis	Limits apply	Monitoring
Monthly	100	None	50	<b>50</b>	Current No backsliding	E-DLN	Continuous
Daily	110	85	50	<b>50</b>	Current No backsliding	E-DLN and MSUL/MSDL to baseload	
95 <sup>th</sup> %ile of hr means	200	None	50	<b>50</b>	Current No backsliding	E-DLN	

## 4.2 The energy efficiency levels associated with the Best Available Techniques Conclusions

An energy efficiency level associated with the best available techniques (BAT-AEEL) refers to the ratio between the combustion unit's net energy output(s) and the combustion unit's fuel/feedstock energy input at actual unit design. The net energy output(s) is determined at the combustion unit boundaries, including auxiliary systems (e.g. flue-gas treatment systems), and for the unit operated at full load.

The existing permit has no restriction on operating hours and the Regulation 61 response was based on unlimited operational hours. During the permit review, we have introduced a limit on operating hours in Open Cycle Mode for the LCP in line with our guidance 'BAT for Balancing Plant' (refer to section 8 of this document) as we do not consider this mode of operation as BAT for plant operating over 1,500 hours/year.

Footnote 1 of Table 23 of the LCP BAT Conclusions specifies that the BAT AEELs for this type of plant are not applicable as the plant will operate for <1,500 hours/year. Whilst the BAT AEELs do not apply to this plant, we have included the information provided by the Operator.

The table below sets out the BAT AEELs specified in the LCP BAT Conclusions for LCP operating >1,500 hours/year and the energy efficiency levels confirmed through the Regulation 61 notice response. Although not applicable, we consider this plant is BAT in relation to the AEELs.

BAT AEELs (%)			Plant efficiency (%)		
Net electrical efficiency	Net total fuel utilisation	Net mechanical efficiency	Net electrical efficiency	Net total fuel utilisation	Net mechanical efficiency
<b>LCP 85: Open cycle gas turbine ≥ 50 MWth</b>					
33-41.5	None	NA	GT1 39.0 GT2 38.8	NA	NA

We have included a process monitoring requirement in table S3.4 of the consolidated variation notice. This is required to demonstrate that efficiency levels are maintained following any significant overhauls of equipment in order to fulfil the requirement of BAT Conclusion 2. If the plant operates for <500 hours/year we have specified that the assessment of efficiency can be based on calculation. This is because we will not require plant to fire up with the sole purpose of carrying out an assessment of efficiency.

## 5 Decision checklist regarding relevant BAT Conclusions

BAT Conclusions for large combustion plant, were published by the European Commission on 17<sup>th</sup> August 2017. There are 75 BAT Conclusions. Only the BAT Conclusions relevant to the particular fuel type used on site have been replicated below.

This annex provides a record of decisions made in relation to each relevant BAT Conclusion applicable to the installation. This annex should be read in conjunction with the Consolidated Variation Notice.

The conditions in the permit through which the relevant BAT Conclusions are implemented include but are not limited to the following:

BAT Conclusion requirement topic	Permit condition(s)	Permit table(s)
Environmental Management System	1.1.1	S1.2
BAT AELs	3.1.1 and 3.5.1	S3.1a
Monitoring	2.3, 3.5 and 3.6	S1.2, S1.4, S1.5 and S3.1a
Energy efficiency	1.2 and 2.3	S3.4
Noise	3.4 and 2.3	S1.2
Other operating techniques	2.3	S1.2

The overall status of compliance with the BAT conclusion is indicated in the table as:

- NA Not Applicable
- CC Currently Compliant
- FC Compliant in the future (within 4 years of publication of BAT conclusions)
- NC Not Compliant
- PC Partially Compliant

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
<b>General</b>			
1	<p><b>In order to improve the overall environmental performance, BAT is to implement and adhere to an environmental management system (EMS) that incorporates all of the following features:</b></p> <ul style="list-style-type: none"> <li>i. commitment of the management, including senior management;</li> <li>ii. definition of an environmental policy that includes the continuous improvement of the installation by the management;</li> <li>iii. planning and establishing the necessary procedures, objectives and targets, in conjunction with financial planning and investment;</li> <li>iv. implementation of procedures <ul style="list-style-type: none"> <li>(a) Structure and responsibility</li> <li>(b) Training</li> <li>(c) Communication</li> <li>(d) Employee involvement</li> <li>(e) Documentation</li> <li>(f) Efficient process control</li> <li>(g) Maintenance programmes</li> <li>(h) Emergency preparedness and response</li> <li>(i) Safeguarding compliance with environmental legislation</li> </ul> </li> <li>v. checking performance and taking corrective action, paying particular attention to: <ul style="list-style-type: none"> <li>(a) monitoring and measurement (see also the Reference Document on the General Principles of Monitoring)</li> <li>(b) corrective and preventive action</li> <li>(c) maintenance of records</li> <li>(d) independent (where practicable) internal and external auditing in order to determine whether or not the EMS conforms to planned arrangements and has been properly implemented and maintained;</li> </ul> </li> <li>vi. review of the EMS and its continuing suitability, adequacy and effectiveness by senior management;</li> <li>vii. following the development of cleaner technologies;</li> <li>viii. consideration for the environmental impacts from the eventual decommissioning of the installation at the stage of designing a new plant, and throughout its operating life;</li> <li>viii. consideration for the environmental impacts from the eventual decommissioning of the installation at the stage of designing a new plant, and throughout its operating life;</li> <li>ix. application of sectoral benchmarking on a regular basis.</li> </ul> <p>Etc - see BAT Conclusions</p>	FC	<p>The Operator confirmed that:</p> <p>RWE &amp; RRPD EMS are to 14001 standards.</p> <p>From 1 June 2020 the site operations and therefore the EMS will be provided by the new operations and maintenance (O &amp; M) provider, NAES Power Solutions Limited.</p> <p>The existing RWE EMS is compliant with ISO 14001. This EMS is currently in compliance with features i through to xvi of this BAT Conclusion.</p> <p>The Operator has confirmed that, when fully implemented, the NAES EMS will also meet all requirements of BAT Conclusion 1.</p> <p>Due to the change of EMS and the expected implementation timescales, we do not agree with the Operator's stated compliance of CC and have changed the status to FC. We do not consider it necessary to set an improvement condition as we will track progress via compliance. It</p>

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	<p><b>Applicability.</b> The scope (e.g. level of detail) and nature of the EMS (e.g. standardised or non-standardised) will generally be related to the nature, scale and complexity of the installation, and the range of environmental impacts it may have.</p>		<p>is expected that the NAES EMS will be implemented by 17 August 2021 and that the site will be compliant with BAT Conclusion 1.</p>
2	<p>BAT is to determine the net electrical efficiency and/or the net total fuel utilisation and/or the net mechanical energy efficiency of the gasification, IGCC and/or combustion units by carrying out a performance test at full load (1), according to EN standards, after the commissioning of the unit and after each modification that could significantly affect the net electrical efficiency and/or the net total fuel utilisation and/or the net mechanical energy efficiency of the unit. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.</p>	CC	<p>The Operator confirmed that:</p> <p>Heartlands Unit 1 Thermal Efficiency based on measurements taken 14 June 2015 @ 20:30 that the Thermal Efficiency = <math>39.0 \pm 1.1\%</math></p> <p>At 50MWe the Thermal Input to the site can be expressed as <math>100/\eta \times 50 = 128.2 \pm 2.6</math> MW.</p> <p>The overall uncertainty of the total energy input is pessimistically based on <math>\pm 3\%</math> of point individual fuel mass flow accuracy (3 stage combustion), and <math>\pm 0.5</math> MW gas fuel LHV variation.</p> <p>Heartlands Unit 2 Thermal Efficiency. Measurements taken 14 June 2015 @ 20:30</p> <p>Thermal Efficiency = <math>38.8 \pm</math></p>

BAT Concn. Numbe r	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement													
			<p>1.1%</p> <p>At 50MWe the Thermal Input to the site can be expressed as <math>100/\eta \times 50</math> = 128.8 ± 2.6 MW.</p> <p>The overall uncertainty of the total energy input is pessimistically based on ± 3% of point individual fuel mass flow accuracy (3 stage combustion), and ± 0.5 MW gas fuel LHV variation.</p> <p>A process monitoring requirement has been set in table S3.4 which requires energy efficiency monitoring after an overhaul.</p> <p>We agree with the Operator's stated compliance.</p>													
3	<p><b>BAT is to monitor key process parameters relevant for emissions to air and water including those given below.</b></p> <table border="1" data-bbox="320 1166 1494 1342"> <thead> <tr> <th data-bbox="320 1166 687 1201">Stream</th> <th data-bbox="687 1166 1122 1201">Parameter(s)</th> <th data-bbox="1122 1166 1494 1201">Monitoring</th> </tr> </thead> <tbody> <tr> <td data-bbox="320 1201 687 1305" rowspan="3">Flue-gas</td> <td data-bbox="687 1201 1122 1236">Flow</td> <td data-bbox="1122 1201 1494 1236">Periodic or continuous determination</td> </tr> <tr> <td data-bbox="687 1236 1122 1272">Oxygen content, temperature, and pressure</td> <td data-bbox="1122 1236 1494 1272">Periodic or continuous measurement</td> </tr> <tr> <td data-bbox="687 1272 1122 1305">Water vapour content (%)</td> <td data-bbox="1122 1272 1494 1305"></td> </tr> <tr> <td data-bbox="320 1305 687 1342">Waste water from flue-gas treatment</td> <td data-bbox="687 1305 1122 1342">Flow, pH, and temperature</td> <td data-bbox="1122 1305 1494 1342">Continuous measurement</td> </tr> </tbody> </table>	Stream	Parameter(s)	Monitoring	Flue-gas	Flow	Periodic or continuous determination	Oxygen content, temperature, and pressure	Periodic or continuous measurement	Water vapour content (%)		Waste water from flue-gas treatment	Flow, pH, and temperature	Continuous measurement	CC	<p>The Operator confirmed that a MCERT installed CEMS systems is in place.</p> <p>Parameters are continuously monitored as required by BAT 3.</p> <p>Flow, Temperature, and Pressure are measured by instruments</p>
Stream	Parameter(s)	Monitoring														
Flue-gas	Flow	Periodic or continuous determination														
	Oxygen content, temperature, and pressure	Periodic or continuous measurement														
	Water vapour content (%)															
Waste water from flue-gas treatment	Flow, pH, and temperature	Continuous measurement														

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																		
			<p>installed on the Gas Turbine Air system and Gas Fuel system. Oxygen is measured on a continuous basis by the CEMS analyser.</p> <p>The site does not carry out flue-gas treatment</p>																		
4	<p>BAT is to monitor emissions to air with at least the frequency given below and in accordance with EN standards. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.</p> <table border="1" data-bbox="322 735 1494 1370"> <thead> <tr> <th data-bbox="322 735 474 852">Substance/P arameter</th> <th data-bbox="474 735 790 852">Fuel/Process/Type of combustion plant</th> <th data-bbox="790 735 949 852">Combustion plant total rated thermal input</th> <th data-bbox="949 735 1128 852">Standard(s)<sup>(4)</sup></th> <th data-bbox="1128 735 1346 852">Minimum monitoring frequency<sup>(5)</sup></th> <th data-bbox="1346 735 1494 852">Monitoring associated with</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 852 474 919">NH<sub>3</sub></td> <td data-bbox="474 852 790 919">— When SCR and/or SNCR is used</td> <td data-bbox="790 852 949 919">All sizes</td> <td data-bbox="949 852 1128 919">Generic EN standards</td> <td data-bbox="1128 852 1346 919">Continuous<sup>(6)</sup>/<sup>(7)</sup></td> <td data-bbox="1346 852 1494 919">BAT 7</td> </tr> <tr> <td data-bbox="322 919 474 1370">NO<sub>x</sub></td> <td data-bbox="474 919 790 1370"> <ul style="list-style-type: none"> <li>— Coal and/or lignite including waste co-incineration</li> <li>— Solid biomass and/or peat including waste co-incineration</li> <li>— HFO- and/or gas-oil-fired boilers and engines</li> <li>— Gas-oil-fired gas turbines</li> <li>— Natural-gas-fired boilers, engines, and turbines</li> <li>— Iron and steel process gases</li> <li>— Process fuels from the chemical industry</li> <li>— IGCC plants</li> </ul> </td> <td data-bbox="790 919 949 1370">All sizes</td> <td data-bbox="949 919 1128 1370">Generic EN standards</td> <td data-bbox="1128 919 1346 1370">Continuous<sup>(6)</sup>/<sup>(8)</sup></td> <td data-bbox="1346 919 1494 1370">           BAT 20            BAT 24            BAT 28            BAT 32            BAT 37            BAT 41            BAT 42            BAT 43            BAT 47            BAT 48            BAT 56            BAT 64            BAT 65            BAT 73         </td> </tr> </tbody> </table>	Substance/P arameter	Fuel/Process/Type of combustion plant	Combustion plant total rated thermal input	Standard(s) <sup>(4)</sup>	Minimum monitoring frequency <sup>(5)</sup>	Monitoring associated with	NH <sub>3</sub>	— When SCR and/or SNCR is used	All sizes	Generic EN standards	Continuous <sup>(6)</sup> / <sup>(7)</sup>	BAT 7	NO <sub>x</sub>	<ul style="list-style-type: none"> <li>— Coal and/or lignite including waste co-incineration</li> <li>— Solid biomass and/or peat including waste co-incineration</li> <li>— HFO- and/or gas-oil-fired boilers and engines</li> <li>— Gas-oil-fired gas turbines</li> <li>— Natural-gas-fired boilers, engines, and turbines</li> <li>— Iron and steel process gases</li> <li>— Process fuels from the chemical industry</li> <li>— IGCC plants</li> </ul>	All sizes	Generic EN standards	Continuous <sup>(6)</sup> / <sup>(8)</sup>	BAT 20 BAT 24 BAT 28 BAT 32 BAT 37 BAT 41 BAT 42 BAT 43 BAT 47 BAT 48 BAT 56 BAT 64 BAT 65 BAT 73	CC	<p>The operator has confirmed that They have a MCERT installed CEMS systems for measuring NOX (see BAT 42) and CO (see BAT 44).</p> <p>Continuous Monitoring Servicing is carried out to the requirements of EN14181 by the maintenance contractors</p>
Substance/P arameter	Fuel/Process/Type of combustion plant	Combustion plant total rated thermal input	Standard(s) <sup>(4)</sup>	Minimum monitoring frequency <sup>(5)</sup>	Monitoring associated with																
NH <sub>3</sub>	— When SCR and/or SNCR is used	All sizes	Generic EN standards	Continuous <sup>(6)</sup> / <sup>(7)</sup>	BAT 7																
NO <sub>x</sub>	<ul style="list-style-type: none"> <li>— Coal and/or lignite including waste co-incineration</li> <li>— Solid biomass and/or peat including waste co-incineration</li> <li>— HFO- and/or gas-oil-fired boilers and engines</li> <li>— Gas-oil-fired gas turbines</li> <li>— Natural-gas-fired boilers, engines, and turbines</li> <li>— Iron and steel process gases</li> <li>— Process fuels from the chemical industry</li> <li>— IGCC plants</li> </ul>	All sizes	Generic EN standards	Continuous <sup>(6)</sup> / <sup>(8)</sup>	BAT 20 BAT 24 BAT 28 BAT 32 BAT 37 BAT 41 BAT 42 BAT 43 BAT 47 BAT 48 BAT 56 BAT 64 BAT 65 BAT 73																

BAT Concn. Numbe r	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
		— Combustion plants on offshore platforms	All sizes	EN 14792	Once every year <sup>(9)</sup>	BAT 53		
N <sub>2</sub> O		— Coal and/or lignite in circulating fluidised bed boilers — Solid biomass and/or peat in circulating fluidised bed boilers	All sizes	EN 21258	Once every year <sup>(10)</sup>	BAT 20 BAT 24		
CO		— Coal and/or lignite including waste co-incineration — Solid biomass and/or peat including waste co-incineration — HFO- and/or gas-oil-fired boilers and engines — Gas-oil-fired gas turbines — Natural-gas-fired boilers, engines, and turbines — Iron and steel process gases — Process fuels from the chemical industry — IGCC plants	All sizes	Generic EN standards	Continuous <sup>(6)</sup> <sup>(8)</sup>	BAT 20 BAT 24 BAT 28 BAT 33 BAT 38 BAT 44 BAT 49 BAT 56 BAT 64 BAT 65 BAT 73		
		— Combustion plants on offshore platforms	All sizes	EN 15058	Once every year <sup>(9)</sup>	BAT 54		
SO <sub>2</sub>		— Coal and/or lignite incl waste co-incineration — Solid biomass and/or peat incl waste co-incineration — HFO- and/or gas-oil-fired boilers — HFO- and/or gas-oil-fired engines	All sizes	Generic EN standards and EN 14791	Continuous <sup>(6)</sup> <sup>(11)</sup> <sup>(12)</sup>	BAT 21 BAT 25 BAT 29 BAT 34 BAT 39 BAT 50 BAT 57 BAT 66 BAT 67 BAT 74		



BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
		<ul style="list-style-type: none"> <li>— Gas-oil-fired gas turbines</li> <li>— Iron and steel process gases</li> <li>— Process fuels from the chemical industry in boilers</li> <li>— IGCC plants</li> </ul>						
SO <sub>3</sub>		<ul style="list-style-type: none"> <li>— When SCR is used</li> </ul>	All sizes	No EN standard available	Once every year	—		
Gaseous chlorides, expressed as HCl		<ul style="list-style-type: none"> <li>— Coal and/or lignite</li> <li>— Process fuels from the chemical industry in boilers</li> </ul>	All sizes	EN 1911	Once every three months <sup>(6)</sup> <sup>(13)</sup> <sup>(14)</sup>	BAT 21 BAT 57		
		<ul style="list-style-type: none"> <li>— Solid biomass and/or peat</li> </ul>	All sizes	Generic EN standards	Continuous <sup>(15)</sup> <sup>(16)</sup>	BAT 25		
		<ul style="list-style-type: none"> <li>— Waste co-incineration</li> </ul>	All sizes	Generic EN standards	Continuous <sup>(6)</sup> <sup>(16)</sup>	BAT 66 BAT 67		
HF		<ul style="list-style-type: none"> <li>— Coal and/or lignite</li> <li>— Process fuels from the chemical industry in boilers</li> </ul>	All sizes	No EN standard available	Once every three months <sup>(6)</sup> <sup>(13)</sup> <sup>(14)</sup>	BAT 21 BAT 57		
		<ul style="list-style-type: none"> <li>— Solid biomass and/or peat</li> </ul>	All sizes	No EN standard available	Once every year	BAT 25		
		<ul style="list-style-type: none"> <li>— Waste co-incineration</li> </ul>	All sizes	Generic EN standards	Continuous <sup>(6)</sup> <sup>(16)</sup>	BAT 66 BAT 67		
Dust		<ul style="list-style-type: none"> <li>— Coal and/or lignite</li> <li>— Solid biomass and/or peat</li> <li>— HFO- and/or gas-oil-fired boilers</li> <li>— Iron and steel process gases</li> <li>— Process fuels from the chemical industry in boilers</li> </ul>	All sizes	Generic EN standards and EN 13284-1 and EN 13284-2	Continuous <sup>(6)</sup> <sup>(17)</sup>	BAT 22 BAT 26 BAT 30 BAT 35 BAT 39 BAT 51 BAT 58 BAT 75		

BAT Concn. Number	Summary of BAT Conclusion requirement					Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	<ul style="list-style-type: none"> <li>— IGCC plants</li> <li>— HFO- and/or gas-oil-fired engines</li> <li>— Gas-oil-fired gas turbines</li> </ul>						
	<ul style="list-style-type: none"> <li>— Waste co-incineration</li> </ul>	All sizes	Generic EN standards and EN 13284-2	Continuous	BAT 68 BAT 69		
	Metals and metalloids except mercury (As, Cd, Co, Cr, Cu, Mn, Ni, Pb, Sb, Se, Ti, V, Zn)	<ul style="list-style-type: none"> <li>— Coal and/or lignite</li> <li>— Solid biomass and/or peat</li> <li>— HFO- and/or gas-oil-fired boilers and engines</li> </ul>	All sizes	EN 14385	Once every year <sup>(18)</sup>	BAT 22 BAT 26 BAT 30	
	<ul style="list-style-type: none"> <li>— Waste co-incineration</li> </ul>	< 300 MW <sub>th</sub>	EN 14385	Once every six months <sup>(13)</sup>	BAT 68 BAT 69		
	<ul style="list-style-type: none"> <li>— IGCC plants</li> </ul>	≥ 300 MW <sub>th</sub>	EN 14385	Once every three months <sup>(19)</sup> <sup>(13)</sup>			
	Hg	<ul style="list-style-type: none"> <li>— Coal and/or lignite including waste co-incineration</li> </ul>	< 300 MW <sub>th</sub>	EN 13211	Once every three months <sup>(13)</sup> <sup>(20)</sup>	BAT 23	
	<ul style="list-style-type: none"> <li>— Solid biomass and/or peat</li> </ul>	All sizes	EN 13211	Continuous <sup>(16)</sup> <sup>(21)</sup>	BAT 27		
	<ul style="list-style-type: none"> <li>— Waste co-incineration with solid biomass and/or peat</li> </ul>	All sizes	EN 13211	Once every year <sup>(22)</sup>	BAT 70		
	<ul style="list-style-type: none"> <li>— IGCC plants</li> </ul>	≥ 100 MW <sub>th</sub>	EN 13211	Once every three months <sup>(13)</sup>	BAT 75		
	TVOC	<ul style="list-style-type: none"> <li>— HFO- and/or gas-oil-fired engines</li> <li>— Process fuels from chemical industry in boilers</li> </ul>	All sizes	EN 12619	Once every six months <sup>(13)</sup>	BAT 33 BAT 59	
	<ul style="list-style-type: none"> <li>— Waste co-incineration with coal, lignite, solid biomass and/or peat</li> </ul>	All sizes	Generic EN standards	Continuous	BAT 71		

BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																																				
	Formaldehyde	— Natural-gas in spark-ignited lean-burn gas and dual fuel engines	All sizes	No EN standard available	Once every year	BAT 45																																						
	CH <sub>4</sub>	— Natural-gas-fired engines	All sizes	EN ISO 25139	Once every year <sup>(24)</sup>	BAT 45																																						
	PCDD/F	— Process fuels from chemical industry in boilers — Waste co-incineration	All sizes	EN 1948-1, EN 1948-2, EN 1948-3	Once every six months <sup>(13)</sup> <sup>(25)</sup>	BAT 59 BAT 71																																						
5	<p>BAT is to monitor emissions to water from flue-gas treatment with at least the frequency given below and in accordance with EN standards. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.</p> <table border="1" data-bbox="315 743 1491 1334"> <thead> <tr> <th data-bbox="327 743 663 823">Substance/Parameter</th> <th data-bbox="674 743 1021 823">Standard(s)</th> <th data-bbox="1032 743 1267 823">Minimum monitoring frequency</th> <th data-bbox="1279 743 1480 823">Monitoring associated with</th> </tr> </thead> <tbody> <tr> <td data-bbox="327 831 663 863">Total organic carbon (TOC)<sup>(26)</sup></td> <td data-bbox="674 831 1021 863">EN 1484</td> <td data-bbox="1032 831 1267 863" rowspan="8">Once every month</td> <td data-bbox="1279 831 1480 863" rowspan="8">BAT 15</td> </tr> <tr> <td data-bbox="327 871 663 919">Chemical oxygen demand (COD)<sup>(26)</sup></td> <td data-bbox="674 871 1021 919">No EN standard available</td> </tr> <tr> <td data-bbox="327 927 663 959">Total suspended solids (TSS)</td> <td data-bbox="674 927 1021 959">EN 872</td> </tr> <tr> <td data-bbox="327 967 663 999">Fluoride (F<sup>-</sup>)</td> <td data-bbox="674 967 1021 999">EN ISO 10304-1</td> </tr> <tr> <td data-bbox="327 1007 663 1038">Sulphate (SO<sub>4</sub><sup>2-</sup>)</td> <td data-bbox="674 1007 1021 1038">EN ISO 10304-1</td> </tr> <tr> <td data-bbox="327 1046 663 1078">Sulphide, easily released (S<sup>2-</sup>)</td> <td data-bbox="674 1046 1021 1078">No EN standard available</td> </tr> <tr> <td data-bbox="327 1086 663 1118">Sulphite (SO<sub>3</sub><sup>2-</sup>)</td> <td data-bbox="674 1086 1021 1118">EN ISO 10304-3</td> </tr> <tr> <td data-bbox="327 1126 663 1334">Metals and metalloids</td> <td data-bbox="674 1126 1021 1334">Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)</td> </tr> <tr> <td data-bbox="595 1126 663 1158">As</td> <td data-bbox="674 1126 1021 1158"></td> </tr> <tr> <td data-bbox="595 1166 663 1198">Cd</td> <td data-bbox="674 1166 1021 1198"></td> </tr> <tr> <td data-bbox="595 1206 663 1238">Cr</td> <td data-bbox="674 1206 1021 1238"></td> </tr> <tr> <td data-bbox="595 1246 663 1278">Cu</td> <td data-bbox="674 1246 1021 1278"></td> </tr> <tr> <td data-bbox="595 1286 663 1318">Ni</td> <td data-bbox="674 1286 1021 1318"></td> </tr> <tr> <td data-bbox="595 1326 663 1358">Pb</td> <td data-bbox="674 1326 1021 1358"></td> </tr> <tr> <td data-bbox="595 1366 663 1398">Zn</td> <td data-bbox="674 1366 1021 1398"></td> </tr> </tbody> </table>						Substance/Parameter	Standard(s)	Minimum monitoring frequency	Monitoring associated with	Total organic carbon (TOC) <sup>(26)</sup>	EN 1484	Once every month	BAT 15	Chemical oxygen demand (COD) <sup>(26)</sup>	No EN standard available	Total suspended solids (TSS)	EN 872	Fluoride (F <sup>-</sup> )	EN ISO 10304-1	Sulphate (SO <sub>4</sub> <sup>2-</sup> )	EN ISO 10304-1	Sulphide, easily released (S <sup>2-</sup> )	No EN standard available	Sulphite (SO <sub>3</sub> <sup>2-</sup> )	EN ISO 10304-3	Metals and metalloids	Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)	As		Cd		Cr		Cu		Ni		Pb		Zn		NA	We agree this BAT Conclusion is not applicable to the activities carried out at the installation as the site does not carry out flue-gas treatment..
Substance/Parameter	Standard(s)	Minimum monitoring frequency	Monitoring associated with																																									
Total organic carbon (TOC) <sup>(26)</sup>	EN 1484	Once every month	BAT 15																																									
Chemical oxygen demand (COD) <sup>(26)</sup>	No EN standard available																																											
Total suspended solids (TSS)	EN 872																																											
Fluoride (F <sup>-</sup> )	EN ISO 10304-1																																											
Sulphate (SO <sub>4</sub> <sup>2-</sup> )	EN ISO 10304-1																																											
Sulphide, easily released (S <sup>2-</sup> )	No EN standard available																																											
Sulphite (SO <sub>3</sub> <sup>2-</sup> )	EN ISO 10304-3																																											
Metals and metalloids	Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)																																											
As																																												
Cd																																												
Cr																																												
Cu																																												
Ni																																												
Pb																																												
Zn																																												

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																	
	<table border="1"> <tr> <td data-bbox="331 389 595 448"></td> <td data-bbox="595 389 663 448">Hg</td> <td data-bbox="663 389 1025 448">Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)</td> <td data-bbox="1025 389 1267 448"></td> </tr> <tr> <td data-bbox="331 448 663 512">Chloride (Cl<sup>-</sup>)</td> <td data-bbox="663 448 1025 512"></td> <td data-bbox="663 448 1025 512">Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)</td> <td data-bbox="1025 448 1267 512">—</td> </tr> <tr> <td data-bbox="331 512 663 544">Total nitrogen</td> <td data-bbox="663 512 1025 544"></td> <td data-bbox="663 512 1025 544">EN 12260</td> <td data-bbox="1025 512 1267 544">—</td> </tr> </table>		Hg	Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)		Chloride (Cl <sup>-</sup> )		Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)	—	Total nitrogen		EN 12260	—							
	Hg	Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)																		
Chloride (Cl <sup>-</sup> )		Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)	—																	
Total nitrogen		EN 12260	—																	
6	<p>In order to improve the general environmental performance of combustion plants and to reduce emissions to air of CO and unburnt substances, BAT is to ensure optimised combustion and to use an appropriate combination of the techniques given below.</p> <table border="1"> <thead> <tr> <th data-bbox="331 655 555 687">Technique</th> <th data-bbox="555 655 994 687">Description</th> <th data-bbox="994 655 1487 687">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="331 687 555 775">a. Fuel blending and mixing</td> <td data-bbox="555 687 994 775">Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type</td> <td data-bbox="994 687 1487 775" rowspan="2">Generally applicable</td> </tr> <tr> <td data-bbox="331 775 555 855">b. Maintenance of the combustion system</td> <td data-bbox="555 775 994 855">Regular planned maintenance according to suppliers' recommendations</td> </tr> <tr> <td data-bbox="331 855 555 935">c. Advanced control system</td> <td data-bbox="555 855 994 935">See description in Section 8.1</td> <td data-bbox="994 855 1487 935">The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> <tr> <td data-bbox="331 935 555 1015">d. Good design of the combustion equipment</td> <td data-bbox="555 935 994 1015">Good design of furnace, combustion chambers, burners and associated devices</td> <td data-bbox="994 935 1487 1015">Generally applicable to new combustion plants</td> </tr> <tr> <td data-bbox="331 1015 555 1254">e. Fuel choice</td> <td data-bbox="555 1015 994 1254">Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used</td> <td data-bbox="994 1015 1487 1254">Applicable within the constraints associated with the availability of suitable types of fuel with a better environmental profile as a whole, which may be impacted by the energy policy of the Member State, or by the integrated site's fuel balance in the case of combustion of industrial process fuels. For existing combustion plants, the type of fuel chosen may be limited by the configuration and the design of the plant</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Fuel blending and mixing	Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type	Generally applicable	b. Maintenance of the combustion system	Regular planned maintenance according to suppliers' recommendations	c. Advanced control system	See description in Section 8.1	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system	d. Good design of the combustion equipment	Good design of furnace, combustion chambers, burners and associated devices	Generally applicable to new combustion plants	e. Fuel choice	Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used	Applicable within the constraints associated with the availability of suitable types of fuel with a better environmental profile as a whole, which may be impacted by the energy policy of the Member State, or by the integrated site's fuel balance in the case of combustion of industrial process fuels. For existing combustion plants, the type of fuel chosen may be limited by the configuration and the design of the plant	CC	<p>The Operator confirmed that:</p> <p>a) Fuel blending - not applicable</p> <p>b) Maintenance of combustion system - maintenance of the gas turbine is undertaken to maintain environmental performance. This includes camera inspections and combustion tuning, with improvements carried out through a service agreement.</p> <p>c) Advanced control system – the gas turbine is controlled with an engine management system which is maintained through a service agreement.</p> <p>d) Good design of combustion equipment – the gas turbine is fitted with a three stage DLN combustion system to provide combustion stability and emissions performance.</p> <p>e) Fuel choice – the gas turbine can only operate on natural gas.</p>
Technique	Description	Applicability																		
a. Fuel blending and mixing	Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type	Generally applicable																		
b. Maintenance of the combustion system	Regular planned maintenance according to suppliers' recommendations																			
c. Advanced control system	See description in Section 8.1	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system																		
d. Good design of the combustion equipment	Good design of furnace, combustion chambers, burners and associated devices	Generally applicable to new combustion plants																		
e. Fuel choice	Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used	Applicable within the constraints associated with the availability of suitable types of fuel with a better environmental profile as a whole, which may be impacted by the energy policy of the Member State, or by the integrated site's fuel balance in the case of combustion of industrial process fuels. For existing combustion plants, the type of fuel chosen may be limited by the configuration and the design of the plant																		

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
7	<p>In order to reduce emissions of ammonia to air from the use of selective catalytic reduction (SCR) and/or selective non-catalytic reduction (SNCR) for the abatement of NO<sub>x</sub> emissions, BAT is to optimise the design and/or operation of SCR and/or SNCR (e.g. optimised reagent to NO<sub>x</sub> ratio, homogeneous reagent distribution and optimum size of the reagent drops).</p> <p><b>BAT-associated emission levels</b></p> <p>The BAT-associated emission level (BAT-AEL) for emissions of NH<sub>3</sub> to air from the use of SCR and/or SNCR is &lt; 3–10 mg/Nm<sup>3</sup> as a yearly average or average over the sampling period. The lower end of the range can be achieved when using SCR and the upper end of the range can be achieved when using SNCR without wet abatement techniques. In the case of plants combusting biomass and operating at variable loads as well as in the case of engines combusting HFO and/or gas oil, the higher end of the BAT-AEL range is 15 mg/Nm<sup>3</sup>.</p>	NA	<p>The Operator confirmed that this BAT Conclusion is not applicable to the installation, no SCR or SNCR on site.</p> <p>We agree this BAT Conclusion is not applicable to the activities carried out at the installation.</p>
8	<p>In order to prevent or reduce emissions to air during normal operating conditions, BAT is to ensure, by appropriate design, operation and maintenance, that the emission abatement systems are used at optimal capacity and availability.</p>	NA	<p>The Operator confirmed that: No abatement systems are fitted.</p> <p>Gas turbine servicing and engine tuning is undertaken. No abatement systems are installed. Engines run at full load capacity, therefore most efficient running. They do not run at reduced load.</p> <p>We agree with the Operator's stated compliance.</p>
9	<p>In order to improve the general environmental performance of combustion and/or gasification plants and to reduce emissions to air, BAT is to include the following elements in the quality assurance/quality control programmes for all the fuels used, as part of the environmental management system (see BAT 1):</p> <ul style="list-style-type: none"> <li>(i) Initial full characterisation of the fuel used including at least the parameters listed below and in accordance with EN standards. ISO, national or other international standards may be used provided they ensure the provision of data of an equivalent scientific quality;</li> <li>(ii) Regular testing of the fuel quality to check that it is consistent with the initial characterisation and according to the plant design specifications. The frequency of testing and the parameters chosen from the table below are based on the variability of the fuel and an assessment of the relevance of pollutant releases (e.g. concentration in fuel, flue-gas treatment employed);</li> </ul>	CC	<p>The Operator confirmed that:</p> <p>i) and ii) All fuel gas is supplied through the national gas networks. National inventory data is used for quality measurement. There are no alternative fuels for the gas turbine.</p>

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																						
	<p>(iii) Subsequent adjustment of the plant settings as and when needed and practicable (e.g. integration of the fuel characterisation and control in the advanced control system (see description in Section 8.1)).</p> <p><b>Description</b> Initial characterisation and regular testing of the fuel can be performed by the operator and/or the fuel supplier. If performed by the supplier, the full results are provided to the operator in the form of a product (fuel) supplier specification and/or guarantee.</p> <table border="1" data-bbox="322 555 1491 1342"> <thead> <tr> <th data-bbox="322 555 712 592">Fuel(s)</th> <th data-bbox="712 555 1491 592">Substances/Parameters subject to characterisation</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 592 712 794" rowspan="4">Biomass/peat</td> <td data-bbox="712 592 1491 628">— LHV</td> </tr> <tr> <td data-bbox="712 628 1491 671">— moisture</td> </tr> <tr> <td data-bbox="712 671 1491 715">— Ash</td> </tr> <tr> <td data-bbox="712 715 1491 794">— C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn)</td> </tr> <tr> <td data-bbox="322 794 712 1007" rowspan="4">Coal/lignite</td> <td data-bbox="712 794 1491 837">— LHV</td> </tr> <tr> <td data-bbox="712 837 1491 880">— Moisture</td> </tr> <tr> <td data-bbox="712 880 1491 924">— Volatiles, ash, fixed carbon, C, H, N, O, S</td> </tr> <tr> <td data-bbox="712 924 1491 1007">— Br, Cl, F — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)</td> </tr> <tr> <td data-bbox="322 1007 712 1091" rowspan="2">HFO</td> <td data-bbox="712 1007 1491 1050">— Ash</td> </tr> <tr> <td data-bbox="712 1050 1491 1091">— C, S, N, Ni, V</td> </tr> <tr> <td data-bbox="322 1091 712 1176" rowspan="2">Gas oil</td> <td data-bbox="712 1091 1491 1134">— Ash</td> </tr> <tr> <td data-bbox="712 1134 1491 1176">— N, C, S</td> </tr> <tr> <td data-bbox="322 1176 712 1260">Natural gas</td> <td data-bbox="712 1176 1491 1260">— LHV — CH<sub>4</sub>, C<sub>2</sub>H<sub>6</sub>, C<sub>3</sub>, C<sub>4</sub>+, CO<sub>2</sub>, N<sub>2</sub>, Wobbe index</td> </tr> <tr> <td data-bbox="322 1260 712 1342">Process fuels from the chemical industry<sup>[27]</sup></td> <td data-bbox="712 1260 1491 1342">— Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)</td> </tr> </tbody> </table>	Fuel(s)	Substances/Parameters subject to characterisation	Biomass/peat	— LHV	— moisture	— Ash	— C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn)	Coal/lignite	— LHV	— Moisture	— Volatiles, ash, fixed carbon, C, H, N, O, S	— Br, Cl, F — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)	HFO	— Ash	— C, S, N, Ni, V	Gas oil	— Ash	— N, C, S	Natural gas	— LHV — CH <sub>4</sub> , C <sub>2</sub> H <sub>6</sub> , C <sub>3</sub> , C <sub>4</sub> +, CO <sub>2</sub> , N <sub>2</sub> , Wobbe index	Process fuels from the chemical industry <sup>[27]</sup>	— Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)		<p>iii) Gas turbine engine tuning is carried out by the O &amp; M service provider.</p> <p>We consider that for plants which burn natural gas from the National Grid as a fuel that it is not necessary for the operator to replicate the testing carried out by the National Grid</p>
Fuel(s)	Substances/Parameters subject to characterisation																								
Biomass/peat	— LHV																								
	— moisture																								
	— Ash																								
	— C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn)																								
Coal/lignite	— LHV																								
	— Moisture																								
	— Volatiles, ash, fixed carbon, C, H, N, O, S																								
	— Br, Cl, F — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)																								
HFO	— Ash																								
	— C, S, N, Ni, V																								
Gas oil	— Ash																								
	— N, C, S																								
Natural gas	— LHV — CH <sub>4</sub> , C <sub>2</sub> H <sub>6</sub> , C <sub>3</sub> , C <sub>4</sub> +, CO <sub>2</sub> , N <sub>2</sub> , Wobbe index																								
Process fuels from the chemical industry <sup>[27]</sup>	— Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)																								

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement				
	<table border="1"> <tr> <td data-bbox="322 384 712 453">Iron and steel process gases</td> <td data-bbox="712 384 1491 453">— LHV, CH<sub>4</sub> (for COG), C<sub>x</sub>H<sub>y</sub> (for COG), CO<sub>2</sub>, H<sub>2</sub>, N<sub>2</sub>, total sulphur, dust, Wobbe index</td> </tr> <tr> <td data-bbox="322 453 712 608">Waste<sup>(28)</sup></td> <td data-bbox="712 453 1491 608"> <ul style="list-style-type: none"> <li>— LHV</li> <li>— Moisture</li> <li>— Volatiles, ash, Br, C, Cl, F, H, N, O, S</li> <li>— Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Ti, V, Zn)</li> </ul> </td> </tr> </table>	Iron and steel process gases	— LHV, CH <sub>4</sub> (for COG), C <sub>x</sub> H <sub>y</sub> (for COG), CO <sub>2</sub> , H <sub>2</sub> , N <sub>2</sub> , total sulphur, dust, Wobbe index	Waste <sup>(28)</sup>	<ul style="list-style-type: none"> <li>— LHV</li> <li>— Moisture</li> <li>— Volatiles, ash, Br, C, Cl, F, H, N, O, S</li> <li>— Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Ti, V, Zn)</li> </ul>		
Iron and steel process gases	— LHV, CH <sub>4</sub> (for COG), C <sub>x</sub> H <sub>y</sub> (for COG), CO <sub>2</sub> , H <sub>2</sub> , N <sub>2</sub> , total sulphur, dust, Wobbe index						
Waste <sup>(28)</sup>	<ul style="list-style-type: none"> <li>— LHV</li> <li>— Moisture</li> <li>— Volatiles, ash, Br, C, Cl, F, H, N, O, S</li> <li>— Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Ti, V, Zn)</li> </ul>						
10	<p>In order to reduce emissions to air and/or to water during other than normal operating conditions (OTNOC), BAT is to set up and implement a management plan as part of the environmental management system (see BAT 1), commensurate with the relevance of potential pollutant releases, that includes the following elements:</p> <ul style="list-style-type: none"> <li>— appropriate design of the systems considered relevant in causing OTNOC that may have an impact on emissions to air, water and/or soil (e.g. low-load design concepts for reducing the minimum start-up and shutdown loads for stable generation in gas turbines),</li> <li>— set-up and implementation of a specific preventive maintenance plan for these relevant systems,</li> <li>— review and recording of emissions caused by OTNOC and associated circumstances and implementation of corrective actions if necessary,</li> <li>— periodic assessment of the overall emissions during OTNOC (e.g. frequency of events, duration, emissions quantification/estimation) and implementation of corrective actions if necessary.</li> </ul>	CC	<p>The Operator confirmed that:</p> <p>The gas turbine is operated to keep start-up times to a minimum. Engine testing is kept to minimum durations.</p> <p>The energy supply contracts are for peaking operations, which reduces operational hours. The engine is shut-down for investigation in the event of abnormal emissions.</p> <p>We agree with the Operator's stated compliance.</p>				
11	<p>BAT is to appropriately monitor emissions to air and/or to water during OTNOC.</p> <p><b>Description</b></p> <p>The monitoring can be carried out by direct measurement of emissions or by monitoring of surrogate parameters if this proves to be of equal or better scientific quality than the direct measurement of emissions. Emissions during start-up and shutdown (SU/SD) may be assessed based on a detailed emission measurement carried out for a typical SU/SD procedure at least once every year, and using the results of this measurement to estimate the emissions for each and every SU/SD throughout the year.</p>	CC	<p>The Operator confirmed that:</p> <p>The plant is not operated when the CEMS is out of service. There is no alternative method of analysis available.</p> <p>We agree with the Operator's stated compliance.</p>				

BAT Concn. Numbe r	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																																				
12	<p>In order to increase the energy efficiency of combustion, gasification and/or IGCC units operated <math>\geq 1\,500</math> h/yr, BAT is to use an appropriate combination of the techniques given below.</p> <table border="1" data-bbox="320 440 1494 1375"> <thead> <tr> <th data-bbox="320 440 577 475">Technique</th> <th data-bbox="577 440 1057 475">Description</th> <th data-bbox="1057 440 1494 475">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="320 475 365 584">a.</td> <td data-bbox="365 475 577 584">Combustion optimisation</td> <td data-bbox="577 475 1057 584">See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues</td> <td data-bbox="1057 475 1494 584" rowspan="4">Generally applicable</td> </tr> <tr> <td data-bbox="320 584 365 719">b.</td> <td data-bbox="365 584 577 719">Optimisation of the working medium conditions</td> <td data-bbox="577 584 1057 719">Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO<sub>x</sub> emissions or the characteristics of energy demanded</td> </tr> <tr> <td data-bbox="320 719 365 828">c.</td> <td data-bbox="365 719 577 828">Optimisation of the steam cycle</td> <td data-bbox="577 719 1057 828">Operate with lower turbine exhaust pressure by utilisation of the lowest possible temperature of the condenser cooling water, within the design conditions</td> </tr> <tr> <td data-bbox="320 828 365 884">d.</td> <td data-bbox="365 828 577 884">Minimisation of energy consumption</td> <td data-bbox="577 828 1057 884">Minimising the internal energy consumption (e.g. greater efficiency of the feed-water pump)</td> </tr> <tr> <td data-bbox="320 884 365 970">e.</td> <td data-bbox="365 884 577 970">Preheating of combustion air</td> <td data-bbox="577 884 1057 970">Reuse of part of the heat recovered from the combustion flue-gas to preheat the air used in combustion</td> <td data-bbox="1057 884 1494 970">Generally applicable within the constraints related to the need to control NO<sub>x</sub> emissions</td> </tr> <tr> <td data-bbox="320 970 365 1056">f.</td> <td data-bbox="365 970 577 1056">Fuel preheating</td> <td data-bbox="577 970 1057 1056">Preheating of fuel using recovered heat</td> <td data-bbox="1057 970 1494 1056">Generally applicable within the constraints associated with the boiler design and the need to control NO<sub>x</sub> emissions</td> </tr> <tr> <td data-bbox="320 1056 365 1163">g.</td> <td data-bbox="365 1056 577 1163">Advanced control system</td> <td data-bbox="577 1056 1057 1163">See description in Section 8.2. Computerised control of the main combustion parameters enables the combustion efficiency to be improved</td> <td data-bbox="1057 1056 1494 1163">Generally applicable to new units. The applicability to old units may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> <tr> <td data-bbox="320 1163 365 1323">h.</td> <td data-bbox="365 1163 577 1323">Feed-water preheating using recovered heat</td> <td data-bbox="577 1163 1057 1323">Preheat water coming out of the steam condenser with recovered heat, before reusing it in the boiler</td> <td data-bbox="1057 1163 1494 1323">Only applicable to steam circuits and not to hot boilers. Applicability to existing units may be limited due to constraints associated with the plant configuration and the amount of recoverable heat</td> </tr> <tr> <td data-bbox="320 1323 365 1375">i.</td> <td data-bbox="365 1323 577 1375">Heat recovery by cogeneration (CHP)</td> <td data-bbox="577 1323 1057 1375">Recovery of heat (mainly from the steam system) for producing hot water/steam to be used in</td> <td data-bbox="1057 1323 1494 1375">Applicable within the constraints associated with the local heat and power demand.</td> </tr> </tbody> </table>	Technique	Description	Applicability	a.	Combustion optimisation	See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues	Generally applicable	b.	Optimisation of the working medium conditions	Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO <sub>x</sub> emissions or the characteristics of energy demanded	c.	Optimisation of the steam cycle	Operate with lower turbine exhaust pressure by utilisation of the lowest possible temperature of the condenser cooling water, within the design conditions	d.	Minimisation of energy consumption	Minimising the internal energy consumption (e.g. greater efficiency of the feed-water pump)	e.	Preheating of combustion air	Reuse of part of the heat recovered from the combustion flue-gas to preheat the air used in combustion	Generally applicable within the constraints related to the need to control NO <sub>x</sub> emissions	f.	Fuel preheating	Preheating of fuel using recovered heat	Generally applicable within the constraints associated with the boiler design and the need to control NO <sub>x</sub> emissions	g.	Advanced control system	See description in Section 8.2. Computerised control of the main combustion parameters enables the combustion efficiency to be improved	Generally applicable to new units. The applicability to old units may be constrained by the need to retrofit the combustion system and/or control command system	h.	Feed-water preheating using recovered heat	Preheat water coming out of the steam condenser with recovered heat, before reusing it in the boiler	Only applicable to steam circuits and not to hot boilers. Applicability to existing units may be limited due to constraints associated with the plant configuration and the amount of recoverable heat	i.	Heat recovery by cogeneration (CHP)	Recovery of heat (mainly from the steam system) for producing hot water/steam to be used in	Applicable within the constraints associated with the local heat and power demand.	CC	<p>The Operator confirmed that:</p> <p>a) Combustion optimisation - gas turbine performance is monitored by the O &amp; M provider who recommend any actions to maintain / improve performance.</p> <p>b) Optimisation of working medium conditions – the gas turbine engine is controlled with an engine management system which is maintained through a service agreement.</p> <p>d) Minimisation of energy consumption - routine checks of the fuel usage are carried out to compare historic data to measure gas turbine performance technically and commercially.</p> <p>p) Minimisation of heat loss - gas fuel pipe-work is insulated after the gas compression.</p> <p>q) Advanced materials – the gas turbine is engineered from aero derivative based</p>
Technique	Description	Applicability																																					
a.	Combustion optimisation	See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues	Generally applicable																																				
b.	Optimisation of the working medium conditions	Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO <sub>x</sub> emissions or the characteristics of energy demanded																																					
c.	Optimisation of the steam cycle	Operate with lower turbine exhaust pressure by utilisation of the lowest possible temperature of the condenser cooling water, within the design conditions																																					
d.	Minimisation of energy consumption	Minimising the internal energy consumption (e.g. greater efficiency of the feed-water pump)																																					
e.	Preheating of combustion air	Reuse of part of the heat recovered from the combustion flue-gas to preheat the air used in combustion	Generally applicable within the constraints related to the need to control NO <sub>x</sub> emissions																																				
f.	Fuel preheating	Preheating of fuel using recovered heat	Generally applicable within the constraints associated with the boiler design and the need to control NO <sub>x</sub> emissions																																				
g.	Advanced control system	See description in Section 8.2. Computerised control of the main combustion parameters enables the combustion efficiency to be improved	Generally applicable to new units. The applicability to old units may be constrained by the need to retrofit the combustion system and/or control command system																																				
h.	Feed-water preheating using recovered heat	Preheat water coming out of the steam condenser with recovered heat, before reusing it in the boiler	Only applicable to steam circuits and not to hot boilers. Applicability to existing units may be limited due to constraints associated with the plant configuration and the amount of recoverable heat																																				
i.	Heat recovery by cogeneration (CHP)	Recovery of heat (mainly from the steam system) for producing hot water/steam to be used in	Applicable within the constraints associated with the local heat and power demand.																																				



BAT Concn. Numbe r	Summary of BAT Conclusion requirement				Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
			industrial processes/activities or in a public network for district heating. Additional heat recovery is possible from: <ul style="list-style-type: none"> <li>— flue-gas</li> <li>— grate cooling</li> <li>— circulating fluidised bed</li> </ul>	The applicability may be limited in the case of gas compressors with an unpredictable operational heat profile		<p>technology and uses the same materials and technologies.</p> <p>The site operates in open cycle mode only and is not capable of CCGT/ CHP operations so some techniques do not apply.</p> <p>We agree with the Operator's stated compliance that an appropriate combination of techniques are being used.</p>
	j.	CHP readiness	See description in Section 8.2.	Only applicable to new units where there is a realistic potential for the future use of heat in the vicinity of the unit		
	k.	Flue-gas condenser	See description in Section 8.2.	Generally applicable to CHP units provided there is enough demand for low-temperature heat		
	l.	Heat accumulation	Heat accumulation storage in CHP mode	Only applicable to CHP plants. The applicability may be limited in the case of low heat load demand		
	m.	Wet stack	See description in Section 8.2.	Generally applicable to new and existing units fitted with wet FGD		
	n.	Cooling tower discharge	The release of emissions to air through a cooling tower and not via a dedicated stack	Only applicable to units fitted with wet FGD where reheating of the flue-gas is necessary before release, and where the unit cooling system is a cooling tower		
	o.	Fuel pre-drying	The reduction of fuel moisture content before combustion to improve combustion conditions	Applicable to the combustion of biomass and/or peat within the constraints associated with spontaneous combustion risks (e.g. the moisture content of peat is kept above 40 % throughout the delivery chain). The retrofit of existing plants may be restricted by the extra calorific value that can be obtained from the drying operation and by the limited retrofit possibilities offered by some boiler designs or plant configurations		
	p.	Minimisation of heat losses	Minimising residual heat losses, e.g. those that occur via the slag or those that can be reduced by insulating radiating sources	Only applicable to solid-fuel-fired combustion units and to gasification/IGCC units		

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	q.	Advanced materials	Use of advanced materials proven to be capable of withstanding high operating temperatures and pressures and thus to achieve increased steam/combustion process efficiencies	Only applicable to new plants	
	r.	Steam turbine upgrades	This includes techniques such as increasing the temperature and pressure of medium-pressure steam, addition of a low-pressure turbine, and modifications to the geometry of the turbine rotor blades	The applicability may be restricted by demand, steam conditions and/or limited plant lifetime	
	s.	Supercritical and ultra-supercritical steam conditions	Use of a steam circuit, including steam reheating systems, in which steam can reach pressures above 220,6 bar and temperatures above 374 °C in the case of supercritical conditions, and above 250 – 300 bar and temperatures above 580 – 600 °C in the case of ultra-supercritical conditions	Only applicable to new units of $\geq 600 \text{ MW}_{th}$ operated $> 4\,000 \text{ h/yr}$ . Not applicable when the purpose of the unit is to produce low steam temperatures and/or pressures in process industries. Not applicable to gas turbines and engines generating steam in CHP mode. For units combusting biomass, the applicability may be constrained by high-temperature corrosion in the case of certain biomasses	
13	In order to reduce water usage and the volume of contaminated waste water discharged, BAT is to use one or both of the techniques given below.			CC	The Operator confirmed that contents of plant blind sumps are removed on alarm, tankered off site as required for recycling. Volume about 12 tonnes per year routinely collected annually.
	<b>Technique</b>	<b>Description</b>	<b>Applicability</b>		
a.	Water recycling	Residual aqueous streams, including run-off water, from the plant are reused for other purposes. The degree of recycling is limited by the quality requirements of the recipient water stream and the water balance of the plant	Not applicable to waste water from cooling systems when water treatment chemicals and/or high concentrations of salts from seawater are present		
b.	Dry bottom ash handling	Dry, hot bottom ash falls from the furnace onto a mechanical conveyor system and is cooled down by ambient air. No water is used in the process.	Only applicable to plants combusting solid fuels. There may be technical restrictions that prevent retrofitting to existing combustion plants		
14	In order to prevent the contamination of uncontaminated waste water and to reduce emissions to water, BAT is to segregate waste water streams and to treat them separately, depending on the pollutant content. <b>Description</b>			CC	The Operator confirmed that foul Water is piped off site through local sewage network.

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																																										
	<p>Waste water streams that are typically segregated and treated include surface run-off water, cooling water, and waste water from flue-gas treatment.</p> <p><b>Applicability</b> The applicability may be restricted in the case of existing plants due to the configuration of the drainage systems.</p>		<p>Rain water run off is via an interceptor to site outlet point, site sumps are visually inspected for condition before discharge.</p>																																										
15	<p>In order to reduce emissions to water from flue-gas treatment, BAT is to use an appropriate combination of the techniques given below, and to use secondary techniques as close as possible to the source in order to avoid dilution.</p> <table border="1" data-bbox="322 596 1491 1361"> <thead> <tr> <th data-bbox="322 596 712 655">Technique</th> <th data-bbox="712 596 1025 655">Typical pollutants prevented/abated</th> <th data-bbox="1025 596 1491 655">Applicability</th> </tr> </thead> <tbody> <tr> <td colspan="3" data-bbox="322 655 1491 691" style="text-align: center;"><b>Primary techniques</b></td> </tr> <tr> <td data-bbox="322 691 371 778">a.</td> <td data-bbox="371 691 712 778">Optimised combustion (see BAT 6) and flue-gas treatment systems (e.g. SCR/SNCR, see BAT 7)</td> <td data-bbox="712 691 1491 778">Organic compounds, ammonia (NH<sub>3</sub>) Generally applicable</td> </tr> <tr> <td colspan="3" data-bbox="322 778 1491 810" style="text-align: center;"><b>Secondary techniques <sup>(29)</sup></b></td> </tr> <tr> <td data-bbox="322 810 371 874">b.</td> <td data-bbox="371 810 712 874">Adsorption on activated carbon</td> <td data-bbox="712 810 1491 874">Organic compounds, mercury (Hg) Generally applicable</td> </tr> <tr> <td data-bbox="322 874 371 1007">c.</td> <td data-bbox="371 874 712 1007">Aerobic biological treatment</td> <td data-bbox="712 874 1491 1007">Biodegradable organic compounds, ammonium (NH<sub>4</sub><sup>+</sup>) Generally applicable for the treatment of organic compounds. Aerobic biological treatment of ammonium (NH<sub>4</sub><sup>+</sup>) may not be applicable in the case of high chloride concentrations (i.e. around 10 g/l)</td> </tr> <tr> <td data-bbox="322 1007 371 1066">d.</td> <td data-bbox="371 1007 712 1066">Anoxic/anaerobic biological treatment</td> <td data-bbox="712 1007 1491 1066">Mercury (Hg), nitrate (NO<sub>3</sub><sup>-</sup>), nitrite (NO<sub>2</sub><sup>-</sup>) Generally applicable</td> </tr> <tr> <td data-bbox="322 1066 371 1098">e.</td> <td data-bbox="371 1066 712 1098">Coagulation and flocculation</td> <td data-bbox="712 1066 1491 1098">Suspended solids Generally applicable</td> </tr> <tr> <td data-bbox="322 1098 371 1161">f.</td> <td data-bbox="371 1098 712 1161">Crystallisation</td> <td data-bbox="712 1098 1491 1161">Metals and metalloids, sulphate (SO<sub>4</sub><sup>2-</sup>), fluoride (F<sup>-</sup>) Generally applicable</td> </tr> <tr> <td data-bbox="322 1161 371 1225">g.</td> <td data-bbox="371 1161 712 1225">Filtration (e.g. sand filtration, microfiltration, ultrafiltration)</td> <td data-bbox="712 1161 1491 1225">Suspended solids, metals Generally applicable</td> </tr> <tr> <td data-bbox="322 1225 371 1257">h.</td> <td data-bbox="371 1225 712 1257">Flotation</td> <td data-bbox="712 1225 1491 1257">Suspended solids, free oil Generally applicable</td> </tr> <tr> <td data-bbox="322 1257 371 1289">i.</td> <td data-bbox="371 1257 712 1289">Ion exchange</td> <td data-bbox="712 1257 1491 1289">Metals Generally applicable</td> </tr> <tr> <td data-bbox="322 1289 371 1321">j.</td> <td data-bbox="371 1289 712 1321">Neutralisation</td> <td data-bbox="712 1289 1491 1321">Acids, alkalis Generally applicable</td> </tr> <tr> <td data-bbox="322 1321 371 1361">k.</td> <td data-bbox="371 1321 712 1361">Oxidation</td> <td data-bbox="712 1321 1491 1361">Sulphide (S<sup>2-</sup>), sulphite (SO<sub>3</sub><sup>2-</sup>) Generally applicable</td> </tr> </tbody> </table>	Technique	Typical pollutants prevented/abated	Applicability	<b>Primary techniques</b>			a.	Optimised combustion (see BAT 6) and flue-gas treatment systems (e.g. SCR/SNCR, see BAT 7)	Organic compounds, ammonia (NH <sub>3</sub> ) Generally applicable	<b>Secondary techniques <sup>(29)</sup></b>			b.	Adsorption on activated carbon	Organic compounds, mercury (Hg) Generally applicable	c.	Aerobic biological treatment	Biodegradable organic compounds, ammonium (NH <sub>4</sub> <sup>+</sup> ) Generally applicable for the treatment of organic compounds. Aerobic biological treatment of ammonium (NH <sub>4</sub> <sup>+</sup> ) may not be applicable in the case of high chloride concentrations (i.e. around 10 g/l)	d.	Anoxic/anaerobic biological treatment	Mercury (Hg), nitrate (NO <sub>3</sub> <sup>-</sup> ), nitrite (NO <sub>2</sub> <sup>-</sup> ) Generally applicable	e.	Coagulation and flocculation	Suspended solids Generally applicable	f.	Crystallisation	Metals and metalloids, sulphate (SO <sub>4</sub> <sup>2-</sup> ), fluoride (F <sup>-</sup> ) Generally applicable	g.	Filtration (e.g. sand filtration, microfiltration, ultrafiltration)	Suspended solids, metals Generally applicable	h.	Flotation	Suspended solids, free oil Generally applicable	i.	Ion exchange	Metals Generally applicable	j.	Neutralisation	Acids, alkalis Generally applicable	k.	Oxidation	Sulphide (S <sup>2-</sup> ), sulphite (SO <sub>3</sub> <sup>2-</sup> ) Generally applicable	NA	<p>The Operator confirmed that this BAT Conclusion is not applicable to the installation, No flue gas treatment undertaken.</p> <p>We agree this BAT Conclusion is not applicable to the activities carried out at the installation.</p>
Technique	Typical pollutants prevented/abated	Applicability																																											
<b>Primary techniques</b>																																													
a.	Optimised combustion (see BAT 6) and flue-gas treatment systems (e.g. SCR/SNCR, see BAT 7)	Organic compounds, ammonia (NH <sub>3</sub> ) Generally applicable																																											
<b>Secondary techniques <sup>(29)</sup></b>																																													
b.	Adsorption on activated carbon	Organic compounds, mercury (Hg) Generally applicable																																											
c.	Aerobic biological treatment	Biodegradable organic compounds, ammonium (NH <sub>4</sub> <sup>+</sup> ) Generally applicable for the treatment of organic compounds. Aerobic biological treatment of ammonium (NH <sub>4</sub> <sup>+</sup> ) may not be applicable in the case of high chloride concentrations (i.e. around 10 g/l)																																											
d.	Anoxic/anaerobic biological treatment	Mercury (Hg), nitrate (NO <sub>3</sub> <sup>-</sup> ), nitrite (NO <sub>2</sub> <sup>-</sup> ) Generally applicable																																											
e.	Coagulation and flocculation	Suspended solids Generally applicable																																											
f.	Crystallisation	Metals and metalloids, sulphate (SO <sub>4</sub> <sup>2-</sup> ), fluoride (F <sup>-</sup> ) Generally applicable																																											
g.	Filtration (e.g. sand filtration, microfiltration, ultrafiltration)	Suspended solids, metals Generally applicable																																											
h.	Flotation	Suspended solids, free oil Generally applicable																																											
i.	Ion exchange	Metals Generally applicable																																											
j.	Neutralisation	Acids, alkalis Generally applicable																																											
k.	Oxidation	Sulphide (S <sup>2-</sup> ), sulphite (SO <sub>3</sub> <sup>2-</sup> ) Generally applicable																																											

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																																																						
	<table border="1"> <tr> <td data-bbox="324 387 360 411">l.</td> <td data-bbox="371 387 698 411">Precipitation</td> <td data-bbox="710 387 1021 440">Metals and metalloids, sulphate (SO<sub>4</sub><sup>2-</sup>), fluoride (F<sup>-</sup>)</td> <td data-bbox="1032 387 1494 411">Generally applicable</td> </tr> <tr> <td data-bbox="324 448 360 472">m.</td> <td data-bbox="371 448 698 472">Sedimentation</td> <td data-bbox="710 448 1021 472">Suspended solids</td> <td data-bbox="1032 448 1494 472">Generally applicable</td> </tr> <tr> <td data-bbox="324 480 360 504">n.</td> <td data-bbox="371 480 698 504">Stripping</td> <td data-bbox="710 480 1021 504">Ammonia (NH<sub>3</sub>)</td> <td data-bbox="1032 480 1494 504">Generally applicable</td> </tr> </table>	l.	Precipitation	Metals and metalloids, sulphate (SO <sub>4</sub> <sup>2-</sup> ), fluoride (F <sup>-</sup> )	Generally applicable	m.	Sedimentation	Suspended solids	Generally applicable	n.	Stripping	Ammonia (NH <sub>3</sub> )	Generally applicable																																														
l.	Precipitation	Metals and metalloids, sulphate (SO <sub>4</sub> <sup>2-</sup> ), fluoride (F <sup>-</sup> )	Generally applicable																																																								
m.	Sedimentation	Suspended solids	Generally applicable																																																								
n.	Stripping	Ammonia (NH <sub>3</sub> )	Generally applicable																																																								
16	<p>The BAT-AELs refer to direct discharges to a receiving water body at the point where the emission leaves the installation.</p> <p style="text-align: center;"><b>BAT-AELs for direct discharges to a receiving water body from flue-gas treatment</b></p> <table border="1"> <thead> <tr> <th colspan="2" data-bbox="324 600 976 624">Substance/Parameter</th> <th colspan="2" data-bbox="987 600 1494 624">BAT-AELs</th> </tr> <tr> <th colspan="2"></th> <th colspan="2" data-bbox="987 639 1494 663">Daily average</th> </tr> </thead> <tbody> <tr> <td colspan="2" data-bbox="324 671 976 695">Total organic carbon (TOC)</td> <td colspan="2" data-bbox="987 671 1494 695">20–50 mg/l <sup>(30)</sup> <sup>(31)</sup> <sup>(32)</sup></td> </tr> <tr> <td colspan="2" data-bbox="324 703 976 727">Chemical oxygen demand (COD)</td> <td colspan="2" data-bbox="987 703 1494 727">60–150 mg/l <sup>(30)</sup> <sup>(31)</sup> <sup>(32)</sup></td> </tr> <tr> <td colspan="2" data-bbox="324 735 976 759">Total suspended solids (TSS)</td> <td colspan="2" data-bbox="987 735 1494 759">10–30 mg/l</td> </tr> <tr> <td colspan="2" data-bbox="324 767 976 791">Fluoride (F<sup>-</sup>)</td> <td colspan="2" data-bbox="987 767 1494 791">10–25 mg/l <sup>(32)</sup></td> </tr> <tr> <td colspan="2" data-bbox="324 799 976 823">Sulphate (SO<sub>4</sub><sup>2-</sup>)</td> <td colspan="2" data-bbox="987 799 1494 823">1,3–2,0 g/l <sup>(32)</sup> <sup>(33)</sup> <sup>(34)</sup> <sup>(35)</sup></td> </tr> <tr> <td colspan="2" data-bbox="324 831 976 855">Sulphide (S<sup>2-</sup>), easily released</td> <td colspan="2" data-bbox="987 831 1494 855">0,1–0,2 mg/l <sup>(32)</sup></td> </tr> <tr> <td colspan="2" data-bbox="324 863 976 887">Sulphite (SO<sub>3</sub><sup>2-</sup>)</td> <td colspan="2" data-bbox="987 863 1494 887">1–20 mg/l <sup>(32)</sup></td> </tr> <tr> <td colspan="2" data-bbox="324 895 875 919" rowspan="8">Metals and metalloids</td> <td data-bbox="887 895 976 919">As</td> <td data-bbox="987 895 1494 919">10–50 µg/l</td> </tr> <tr> <td data-bbox="887 927 976 951">Cd</td> <td data-bbox="987 927 1494 951">2–5 µg/l</td> </tr> <tr> <td data-bbox="887 959 976 983">Cr</td> <td data-bbox="987 959 1494 983">10–50 µg/l</td> </tr> <tr> <td data-bbox="887 991 976 1015">Cu</td> <td data-bbox="987 991 1494 1015">10–50 µg/l</td> </tr> <tr> <td data-bbox="887 1023 976 1046">Hg</td> <td data-bbox="987 1023 1494 1046">0,2–3 µg/l</td> </tr> <tr> <td data-bbox="887 1054 976 1078">Ni</td> <td data-bbox="987 1054 1494 1078">10–50 µg/l</td> </tr> <tr> <td data-bbox="887 1086 976 1110">Pb</td> <td data-bbox="987 1086 1494 1110">10–20 µg/l</td> </tr> <tr> <td data-bbox="887 1118 976 1142">Zn</td> <td data-bbox="987 1118 1494 1142">50–200 µg/l</td> </tr> </tbody> </table>			Substance/Parameter		BAT-AELs				Daily average		Total organic carbon (TOC)		20–50 mg/l <sup>(30)</sup> <sup>(31)</sup> <sup>(32)</sup>		Chemical oxygen demand (COD)		60–150 mg/l <sup>(30)</sup> <sup>(31)</sup> <sup>(32)</sup>		Total suspended solids (TSS)		10–30 mg/l		Fluoride (F <sup>-</sup> )		10–25 mg/l <sup>(32)</sup>		Sulphate (SO <sub>4</sub> <sup>2-</sup> )		1,3–2,0 g/l <sup>(32)</sup> <sup>(33)</sup> <sup>(34)</sup> <sup>(35)</sup>		Sulphide (S <sup>2-</sup> ), easily released		0,1–0,2 mg/l <sup>(32)</sup>		Sulphite (SO <sub>3</sub> <sup>2-</sup> )		1–20 mg/l <sup>(32)</sup>		Metals and metalloids		As	10–50 µg/l	Cd	2–5 µg/l	Cr	10–50 µg/l	Cu	10–50 µg/l	Hg	0,2–3 µg/l	Ni	10–50 µg/l	Pb	10–20 µg/l	Zn	50–200 µg/l	CC	<p>The Operator confirmed that:</p> <p>Disposal of waste where possible is via recycling processes with contractors. Volumes of waste are</p>
Substance/Parameter		BAT-AELs																																																									
		Daily average																																																									
Total organic carbon (TOC)		20–50 mg/l <sup>(30)</sup> <sup>(31)</sup> <sup>(32)</sup>																																																									
Chemical oxygen demand (COD)		60–150 mg/l <sup>(30)</sup> <sup>(31)</sup> <sup>(32)</sup>																																																									
Total suspended solids (TSS)		10–30 mg/l																																																									
Fluoride (F <sup>-</sup> )		10–25 mg/l <sup>(32)</sup>																																																									
Sulphate (SO <sub>4</sub> <sup>2-</sup> )		1,3–2,0 g/l <sup>(32)</sup> <sup>(33)</sup> <sup>(34)</sup> <sup>(35)</sup>																																																									
Sulphide (S <sup>2-</sup> ), easily released		0,1–0,2 mg/l <sup>(32)</sup>																																																									
Sulphite (SO <sub>3</sub> <sup>2-</sup> )		1–20 mg/l <sup>(32)</sup>																																																									
Metals and metalloids		As	10–50 µg/l																																																								
		Cd	2–5 µg/l																																																								
		Cr	10–50 µg/l																																																								
		Cu	10–50 µg/l																																																								
		Hg	0,2–3 µg/l																																																								
		Ni	10–50 µg/l																																																								
		Pb	10–20 µg/l																																																								
		Zn	50–200 µg/l																																																								

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement															
	<p>(c) waste recycling;</p> <p>(d) other waste recovery (e.g. energy recovery),</p> <p>by implementing an appropriate combination of techniques such as:</p> <table border="1" data-bbox="322 493 1494 1086"> <thead> <tr> <th data-bbox="322 493 573 528">Technique</th> <th data-bbox="573 493 1081 528">Description</th> <th data-bbox="1081 493 1494 528">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 528 573 687">a. Generation of gypsum as a by-product</td> <td data-bbox="573 528 1081 687">Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g. as raw material in the plasterboard industry). The quality of limestone used in the wet FGD influences the purity of the gypsum produced</td> <td data-bbox="1081 528 1494 687">Generally applicable within the constraints associated with the required gypsum quality, the health requirements associated to each specific use, and by the market conditions</td> </tr> <tr> <td data-bbox="322 687 573 820">b. Recycling or recovery of residues in the construction sector</td> <td data-bbox="573 687 1081 820">Recycling or recovery of residues (e.g. from semi-dry desulphurisation processes, fly ash, bottom ash) as a construction material (e.g. in road building, to replace sand in concrete production, or in the cement industry)</td> <td data-bbox="1081 687 1494 820">Generally applicable within the constraints associated with the required material quality (e.g. physical properties, content of harmful substances) associated to each specific use, and by the market conditions</td> </tr> <tr> <td data-bbox="322 820 573 927">c. Energy recovery by using waste in the fuel mix</td> <td data-bbox="573 820 1081 927">The residual energy content of carbon-rich ash and sludges generated by the combustion of coal, lignite, heavy fuel oil, peat or biomass can be recovered for example by mixing with the fuel</td> <td data-bbox="1081 820 1494 927">Generally applicable where plants can accept waste in the fuel mix and are technically able to feed the fuels into the combustion chamber</td> </tr> <tr> <td data-bbox="322 927 573 1086">d. Preparation of spent catalyst for reuse</td> <td data-bbox="573 927 1081 1086">Preparation of catalyst for reuse (e.g. up to four times for SCR catalysts) restores some or all of the original performance, extending the service life of the catalyst to several decades. Preparation of spent catalyst for reuse is integrated in a catalyst management scheme</td> <td data-bbox="1081 927 1494 1086">The applicability may be limited by the mechanical condition of the catalyst and the required performance with respect to controlling NO<sub>x</sub> and NH<sub>3</sub> emissions</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Generation of gypsum as a by-product	Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g. as raw material in the plasterboard industry). The quality of limestone used in the wet FGD influences the purity of the gypsum produced	Generally applicable within the constraints associated with the required gypsum quality, the health requirements associated to each specific use, and by the market conditions	b. Recycling or recovery of residues in the construction sector	Recycling or recovery of residues (e.g. from semi-dry desulphurisation processes, fly ash, bottom ash) as a construction material (e.g. in road building, to replace sand in concrete production, or in the cement industry)	Generally applicable within the constraints associated with the required material quality (e.g. physical properties, content of harmful substances) associated to each specific use, and by the market conditions	c. Energy recovery by using waste in the fuel mix	The residual energy content of carbon-rich ash and sludges generated by the combustion of coal, lignite, heavy fuel oil, peat or biomass can be recovered for example by mixing with the fuel	Generally applicable where plants can accept waste in the fuel mix and are technically able to feed the fuels into the combustion chamber	d. Preparation of spent catalyst for reuse	Preparation of catalyst for reuse (e.g. up to four times for SCR catalysts) restores some or all of the original performance, extending the service life of the catalyst to several decades. Preparation of spent catalyst for reuse is integrated in a catalyst management scheme	The applicability may be limited by the mechanical condition of the catalyst and the required performance with respect to controlling NO <sub>x</sub> and NH <sub>3</sub> emissions		<p>very low due to activity levels on site.</p> <p>We agree with the Operator's stated compliance.</p>
Technique	Description	Applicability																
a. Generation of gypsum as a by-product	Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g. as raw material in the plasterboard industry). The quality of limestone used in the wet FGD influences the purity of the gypsum produced	Generally applicable within the constraints associated with the required gypsum quality, the health requirements associated to each specific use, and by the market conditions																
b. Recycling or recovery of residues in the construction sector	Recycling or recovery of residues (e.g. from semi-dry desulphurisation processes, fly ash, bottom ash) as a construction material (e.g. in road building, to replace sand in concrete production, or in the cement industry)	Generally applicable within the constraints associated with the required material quality (e.g. physical properties, content of harmful substances) associated to each specific use, and by the market conditions																
c. Energy recovery by using waste in the fuel mix	The residual energy content of carbon-rich ash and sludges generated by the combustion of coal, lignite, heavy fuel oil, peat or biomass can be recovered for example by mixing with the fuel	Generally applicable where plants can accept waste in the fuel mix and are technically able to feed the fuels into the combustion chamber																
d. Preparation of spent catalyst for reuse	Preparation of catalyst for reuse (e.g. up to four times for SCR catalysts) restores some or all of the original performance, extending the service life of the catalyst to several decades. Preparation of spent catalyst for reuse is integrated in a catalyst management scheme	The applicability may be limited by the mechanical condition of the catalyst and the required performance with respect to controlling NO <sub>x</sub> and NH <sub>3</sub> emissions																
17	<p>In order to reduce noise emissions, BAT is to use one or a combination of the techniques given below.</p> <table border="1" data-bbox="322 1131 1494 1362"> <thead> <tr> <th data-bbox="322 1131 573 1166">Technique</th> <th data-bbox="573 1131 1081 1166">Description</th> <th data-bbox="1081 1131 1494 1166">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 1166 573 1362">a. Operational measures</td> <td data-bbox="573 1166 1081 1362">           These include:           <ul style="list-style-type: none"> <li>— improved inspection and maintenance of equipment</li> <li>— closing of doors and windows of enclosed areas, if possible</li> <li>— equipment operated by experienced staff</li> </ul> </td> <td data-bbox="1081 1166 1494 1362">Generally applicable</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Operational measures	These include: <ul style="list-style-type: none"> <li>— improved inspection and maintenance of equipment</li> <li>— closing of doors and windows of enclosed areas, if possible</li> <li>— equipment operated by experienced staff</li> </ul>	Generally applicable	CC	<p>The Operator confirmed that:</p> <ul style="list-style-type: none"> <li>- Maintaining site noise prevention devices / sound proofing.</li> <li>- Low levels of operating hours during the year.</li> <li>- Regular maintenance of plant.</li> <li>- Plant is as designed and operated remotely with no new</li> </ul>									
Technique	Description	Applicability																
a. Operational measures	These include: <ul style="list-style-type: none"> <li>— improved inspection and maintenance of equipment</li> <li>— closing of doors and windows of enclosed areas, if possible</li> <li>— equipment operated by experienced staff</li> </ul>	Generally applicable																

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
		<ul style="list-style-type: none"> <li>— avoidance of noisy activities at night, if possible</li> <li>— provisions for noise control during maintenance activities</li> </ul>			<p>plant items requiring new noise assessments.</p> <p>- O&amp;M to plan in noise survey for check against historic levels.</p> <p>a) Plant is only operated with existing enclosures and doors closed</p> <p>b) gas compressors are not in enclosure as design.</p> <p>c) All enclosures are maintained to design.</p> <p>d) All auxiliary equipment that could cause noise issues are housed in enclosures, such as fire pumps.</p> <p>e) not applicable</p> <p>We agree this BAT Conclusion is not applicable to the activities carried out at the installation.</p>
	b.	Low-noise equipment	This potentially includes compressors, pumps and disks	Generally applicable when the equipment is new or replaced	
	c.	Noise attenuation	Noise propagation can be reduced by inserting obstacles between the emitter and the receiver. Appropriate obstacles include protection walls, embankments and buildings	Generally applicable to new plants. In the case of existing plants, the insertion of obstacles may be restricted by lack of space	
	d.	Noise-control equipment	This includes: <ul style="list-style-type: none"> <li>— noise-reducers</li> <li>— equipment insulation</li> <li>— enclosure of noisy equipment</li> <li>— soundproofing of buildings</li> </ul>	The applicability may be restricted by lack of space	
	e.	Appropriate location of equipment and buildings	Noise levels can be reduced by increasing the distance between the emitter and the receiver and by using buildings as noise screens	Generally applicable to new plant	
<p><b>BAT Conclusions 18 to 23 for the combustion of coal and/or lignite (solid fuels only)</b>  <b>BAT Conclusions 24 to 27 for the combustion of solid biomass and/or peat (solid fuels only)</b>  <b>BAT Conclusions 28 to 30 for the combustion of HFO and/or gas-oil in boilers (liquid fuels only)</b>  <b>BAT Conclusions 31 to 35 for the combustion of HFO and/or gas-oil in engines (liquid fuels only)</b>  <b>BAT Conclusions 36 to 39 for the combustion of gas oil in gas turbines (liquid fuels only)</b></p> <p><b>These BAT Conclusions are not applicable to the activities carried out at the installation.</b></p>					
<p><b>Combustion of gaseous fuels</b></p>					
40	In order to increase the energy efficiency of natural gas combustion, BAT is to use an appropriate combination of the techniques given in BAT 12 and below.			CC	The station uses techniques a, b, d, p and q given in BAT 12. See above for further details.
	Technique	Description	Applicability		

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	
	a. Combined cycle	See description in Section 8.2	Generally applicable to new gas turbines and engines except when operated < 1 500 h/yr. Applicable to existing gas turbines and engines within the constraints associated with the steam cycle design and the space availability. Not applicable to existing gas turbines and engines operated < 1 500 h/yr. Not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns. Not applicable to boilers		<p>The plant only operates as an OCGT, during the permit review, we have introduced a limit on operating hours in line with our guidance 'BAT for Balancing Plant' (refer to section 8 of this document) as we do not consider this mode of operation as BAT for plant operating over 1,500 hours/year.</p> <p>Footnote 1 of Table 23 of the LCP BAT Conclusions specifies that the BAT AEELs for this type of plant are not applicable as the plant will operate for &lt;1,500 hours/year. Whilst the BAT AEELs do not apply to this plant, the Operator provided details of the plant efficiency calculations. The Operator has confirmed that based on thermal efficiency measurements taken on 23 June 2015</p> <p>The overall uncertainty of the total energy input is pessimistically based on ± 3% of point individual fuel mass flow accuracy (2 stage combustion), and ± 0.5 MW gas fuel LHV variation.</p> <p>The efficiency of GT1 - 39.0 ± 1.1% and GT2 - 38.8 ± 1.1% to the higher end of the BAT AEEL range of 33 to 41.5%.</p>	
<b>BAT-associated energy efficiency levels (BAT-AEELs) for the combustion of natural gas</b>						
Type of combustion unit		BAT-AEELs <sup>(136)</sup> <sup>(137)</sup>				
		Net electrical efficiency (%)		Net total fuel utilisation (%) <sup>(138)</sup> <sup>(139)</sup>	Net mechanical energy efficiency (%) <sup>(139)</sup> <sup>(140)</sup>	
		New unit	Existing unit		New unit	Existing unit
Gas engine		39,5–44 <sup>(141)</sup>	35–44 <sup>(141)</sup>	56–85 <sup>(141)</sup>	No BAT-AEEL.	
Gas-fired boiler		39–42,5	38–40	78–95	No BAT-AEEL.	
Open cycle gas turbine, ≥ 50 MW <sub>th</sub>		36–41,5	33–41,5	No BAT-AEEL	36,5–41	33,5–41
<b>Combined cycle gas turbine (CCGT)</b>						
CCGT, 50–600 MW <sub>th</sub>		53–58,5	46–54	No BAT-AEEL	No BAT-AEEL	
CCGT, ≥ 600 MW <sub>th</sub>		57–60,5	50–60	No BAT-AEEL	No BAT-AEEL	
CHP CCGT, 50–600 MW <sub>th</sub>		53–58,5	46–54	65–95	No BAT-AEEL	
CHP CCGT, ≥ 600 MW <sub>th</sub>		57–60,5	50–60	65–95	No BAT-AEEL	

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																				
			<p>Also refer to section 4.2 of this document.</p> <p>We agree with the Operator's stated compliance.</p>																				
41	<p>In order to prevent or reduce NO<sub>x</sub> emissions to air from the combustion of natural gas in boilers, BAT is to use one or a combination of the techniques given below.</p> <table border="1" data-bbox="320 651 1494 1347"> <thead> <tr> <th data-bbox="320 651 580 683">Technique</th> <th data-bbox="580 651 1021 683">Description</th> <th data-bbox="1021 651 1494 683">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="320 683 580 767">a. Air and/or fuel staging</td> <td data-bbox="580 683 1021 767">See descriptions in Section 8.3. Air staging is often associated with low-NO<sub>x</sub> burners</td> <td data-bbox="1021 683 1494 767" rowspan="3">Generally applicable</td> </tr> <tr> <td data-bbox="320 767 580 799">b. Flue-gas recirculation</td> <td data-bbox="580 767 1021 799">See description in Section 8.3</td> </tr> <tr> <td data-bbox="320 799 580 863">c. Low-NO<sub>x</sub> burners (LNB)</td> <td data-bbox="580 799 1021 863"></td> </tr> <tr> <td data-bbox="320 863 580 970">d. Advanced control system</td> <td data-bbox="580 863 1021 970">See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated &lt; 500 h/yr</td> <td data-bbox="1021 863 1494 970">The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> <tr> <td data-bbox="320 970 580 1054">e. Reduction of the combustion air temperature</td> <td data-bbox="580 970 1021 1054" rowspan="3">See description in Section 8.3</td> <td data-bbox="1021 970 1494 1054">Generally applicable within the constraints associated with the process needs</td> </tr> <tr> <td data-bbox="320 1054 580 1187">f. Selective non-catalytic reduction (SNCR)</td> <td data-bbox="1021 1054 1494 1187">Not applicable to combustion plants operated &lt; 500 h/yr with highly variable boiler loads. The applicability may be limited in the case of combustion plants operated between 500 h/yr and 1 500 h/yr with highly variable boiler loads</td> </tr> <tr> <td data-bbox="320 1187 580 1347">g. Selective catalytic reduction (SCR)</td> <td data-bbox="1021 1187 1494 1347">Not applicable to combustion plants operated &lt; 500 h/yr. Not generally applicable to combustion plants of &lt; 100 MW<sub>th</sub>. There may be technical and economic restrictions for retrofitting existing combustion</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Air and/or fuel staging	See descriptions in Section 8.3. Air staging is often associated with low-NO <sub>x</sub> burners	Generally applicable	b. Flue-gas recirculation	See description in Section 8.3	c. Low-NO <sub>x</sub> burners (LNB)		d. Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system	e. Reduction of the combustion air temperature	See description in Section 8.3	Generally applicable within the constraints associated with the process needs	f. Selective non-catalytic reduction (SNCR)	Not applicable to combustion plants operated < 500 h/yr with highly variable boiler loads. The applicability may be limited in the case of combustion plants operated between 500 h/yr and 1 500 h/yr with highly variable boiler loads	g. Selective catalytic reduction (SCR)	Not applicable to combustion plants operated < 500 h/yr. Not generally applicable to combustion plants of < 100 MW <sub>th</sub> . There may be technical and economic restrictions for retrofitting existing combustion	NA	<p>The Operator confirmed that this BAT Conclusion is not applicable to the installation, despite stating that they are currently compliant.</p> <p>We have set the status to NA instead of CC.</p> <p>We agree this BAT Conclusion is not applicable to the activities carried out at the installation. Combustion of gas in boiler does not take place on site</p>
Technique	Description	Applicability																					
a. Air and/or fuel staging	See descriptions in Section 8.3. Air staging is often associated with low-NO <sub>x</sub> burners	Generally applicable																					
b. Flue-gas recirculation	See description in Section 8.3																						
c. Low-NO <sub>x</sub> burners (LNB)																							
d. Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system																					
e. Reduction of the combustion air temperature	See description in Section 8.3	Generally applicable within the constraints associated with the process needs																					
f. Selective non-catalytic reduction (SNCR)		Not applicable to combustion plants operated < 500 h/yr with highly variable boiler loads. The applicability may be limited in the case of combustion plants operated between 500 h/yr and 1 500 h/yr with highly variable boiler loads																					
g. Selective catalytic reduction (SCR)		Not applicable to combustion plants operated < 500 h/yr. Not generally applicable to combustion plants of < 100 MW <sub>th</sub> . There may be technical and economic restrictions for retrofitting existing combustion																					



BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																			
			plants operated between 500 h/yr and 1 500 h/yr																					
42	In order to prevent or reduce NO <sub>x</sub> emissions to air from the combustion of natural gas in gas turbines, BAT is to use one or a combination of the techniques given below.			CC	<p>The operator has confirmed the following:</p> <p>(a) An advanced electronic control system is used to automatically control and optimise combustion efficiency and manage prevention and reduction of emissions.  (b) NA water steam addition systems are not installed  (c) Dry low NO<sub>x</sub> burners &amp; are fitted.  (d) NA as Low load design is not used  (e) NA -OCGT  (f) NA as no SCR fitted.</p> <p>We accept that as this OCGT is an existing plant and the DLN-E definition is accepted</p> <p>i. The output load @ 35MWe or  ii. This output load @70% Thermal</p> <p>We agree with the Operator's stated compliance.</p>																			
<table border="1"> <thead> <tr> <th data-bbox="318 520 353 552">Technique</th> <th data-bbox="353 520 1093 552">Description</th> <th data-bbox="1093 520 1496 552">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="318 552 353 663">a. Advanced control system</td> <td data-bbox="353 552 1093 663">See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated &lt; 500 h/yr</td> <td data-bbox="1093 552 1496 663">The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> <tr> <td data-bbox="318 663 353 719">b. Water/steam addition</td> <td data-bbox="353 663 1093 719" rowspan="2">See description in Section 8.3</td> <td data-bbox="1093 663 1496 719">The applicability may be limited due to water availability</td> </tr> <tr> <td data-bbox="318 719 353 831">c. Dry low-NO<sub>x</sub> burners (DLN)</td> <td data-bbox="1093 719 1496 831">The applicability may be limited in the case of turbines where a retrofit package is not available or when water/steam addition systems are installed</td> </tr> <tr> <td data-bbox="318 831 353 967">d. Low-load design concept</td> <td data-bbox="353 831 1093 967">Adaptation of the process control and related equipment to maintain good combustion efficiency when the demand in energy varies, e.g. by improving the inlet airflow control capability or by splitting the combustion process into decoupled combustion stages</td> <td data-bbox="1093 831 1496 967">The applicability may be limited by the gas turbine design</td> </tr> <tr> <td data-bbox="318 967 353 1070">e. Low-NO<sub>x</sub> burners (LNB)</td> <td data-bbox="353 967 1093 1070" rowspan="2">See description in Section 8.3</td> <td data-bbox="1093 967 1496 1070">Generally applicable to supplementary firing for heat recovery steam generators (HRSGs) in the case of combined-cycle gas turbine (CCGT) combustion plants</td> </tr> <tr> <td data-bbox="318 1070 353 1361">f. Selective catalytic reduction (SCR)</td> <td data-bbox="1093 1070 1496 1361">Not applicable in the case of combustion plants operated &lt; 500 h/yr. Not generally applicable to existing combustion plants of &lt; 100 MW<sub>th</sub>. Retrofitting existing combustion plants may be constrained by the availability of sufficient space. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr</td> </tr> </tbody> </table>						Technique	Description	Applicability	a. Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system	b. Water/steam addition	See description in Section 8.3	The applicability may be limited due to water availability	c. Dry low-NO <sub>x</sub> burners (DLN)	The applicability may be limited in the case of turbines where a retrofit package is not available or when water/steam addition systems are installed	d. Low-load design concept	Adaptation of the process control and related equipment to maintain good combustion efficiency when the demand in energy varies, e.g. by improving the inlet airflow control capability or by splitting the combustion process into decoupled combustion stages	The applicability may be limited by the gas turbine design	e. Low-NO <sub>x</sub> burners (LNB)	See description in Section 8.3	Generally applicable to supplementary firing for heat recovery steam generators (HRSGs) in the case of combined-cycle gas turbine (CCGT) combustion plants	f. Selective catalytic reduction (SCR)	Not applicable in the case of combustion plants operated < 500 h/yr. Not generally applicable to existing combustion plants of < 100 MW <sub>th</sub> . Retrofitting existing combustion plants may be constrained by the availability of sufficient space. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr
Technique	Description	Applicability																						
a. Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system																						
b. Water/steam addition	See description in Section 8.3	The applicability may be limited due to water availability																						
c. Dry low-NO <sub>x</sub> burners (DLN)		The applicability may be limited in the case of turbines where a retrofit package is not available or when water/steam addition systems are installed																						
d. Low-load design concept	Adaptation of the process control and related equipment to maintain good combustion efficiency when the demand in energy varies, e.g. by improving the inlet airflow control capability or by splitting the combustion process into decoupled combustion stages	The applicability may be limited by the gas turbine design																						
e. Low-NO <sub>x</sub> burners (LNB)	See description in Section 8.3	Generally applicable to supplementary firing for heat recovery steam generators (HRSGs) in the case of combined-cycle gas turbine (CCGT) combustion plants																						
f. Selective catalytic reduction (SCR)		Not applicable in the case of combustion plants operated < 500 h/yr. Not generally applicable to existing combustion plants of < 100 MW <sub>th</sub> . Retrofitting existing combustion plants may be constrained by the availability of sufficient space. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr																						

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																						
43	<p>In order to prevent or reduce NO<sub>x</sub> emissions to air from the combustion of natural gas in engines, BAT is to use one or a combination of the techniques given below.</p> <table border="1" data-bbox="322 440 1491 884"> <thead> <tr> <th data-bbox="322 440 358 472">Technique</th> <th data-bbox="358 440 999 472">Description</th> <th data-bbox="999 440 1491 472">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 472 358 584">a. Advanced control system</td> <td data-bbox="358 472 999 584">See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated &lt; 500 h/yr</td> <td data-bbox="999 472 1491 584">The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> <tr> <td data-bbox="322 584 358 647">b. Lean-burn concept</td> <td data-bbox="358 584 999 647">See description in Section 8.3. Generally used in combination with SCR</td> <td data-bbox="999 584 1491 647">Only applicable to new gas-fired engines</td> </tr> <tr> <td data-bbox="322 647 358 711">c. Advanced lean-burn concept</td> <td data-bbox="358 647 999 711" rowspan="2">See descriptions in Section 8.3</td> <td data-bbox="999 647 1491 711">Only applicable to new spark plug ignited engines</td> </tr> <tr> <td data-bbox="322 711 358 884">d. Selective catalytic reduction (SCR)</td> <td data-bbox="999 711 1491 884">Retrofitting existing combustion plants may be constrained by the availability of sufficient space. Not applicable to combustion plants operated &lt; 500 h/yr. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system	b. Lean-burn concept	See description in Section 8.3. Generally used in combination with SCR	Only applicable to new gas-fired engines	c. Advanced lean-burn concept	See descriptions in Section 8.3	Only applicable to new spark plug ignited engines	d. Selective catalytic reduction (SCR)	Retrofitting existing combustion plants may be constrained by the availability of sufficient space. Not applicable to combustion plants operated < 500 h/yr. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr	NA	<p>No engines are used on site</p> <p>We agree this BAT Conclusion is not applicable to the activities carried out at the installation.</p>								
Technique	Description	Applicability																							
a. Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system																							
b. Lean-burn concept	See description in Section 8.3. Generally used in combination with SCR	Only applicable to new gas-fired engines																							
c. Advanced lean-burn concept	See descriptions in Section 8.3	Only applicable to new spark plug ignited engines																							
d. Selective catalytic reduction (SCR)		Retrofitting existing combustion plants may be constrained by the availability of sufficient space. Not applicable to combustion plants operated < 500 h/yr. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr																							
44	<p>In order to prevent or reduce CO emissions to air from the combustion of natural gas, BAT is to ensure optimised combustion and/or to use oxidation catalysts.</p> <p><b>Description - See descriptions in Section 8.3.</b></p> <p><b>BAT-associated emission levels (BAT-AELs) for NO<sub>x</sub> emissions to air from the combustion of natural gas in gas turbines</b></p> <table border="1" data-bbox="322 1043 1491 1369"> <thead> <tr> <th data-bbox="322 1043 786 1161" rowspan="2">Type of combustion plant</th> <th data-bbox="786 1043 1028 1161" rowspan="2">Combustion plant total rated thermal input (MW<sub>th</sub>)</th> <th colspan="2" data-bbox="1028 1043 1491 1075">BAT-AELs (mg/Nm<sup>3</sup>) <sup>(142)</sup> <sup>(143)</sup></th> </tr> <tr> <th data-bbox="1028 1075 1252 1161">Yearly average <sup>(144)</sup> <sup>(145)</sup></th> <th data-bbox="1252 1075 1491 1161">Daily average or average over the sampling period</th> </tr> </thead> <tbody> <tr> <td colspan="4" data-bbox="322 1161 1491 1203" style="text-align: center;"><b>Open-cycle gas turbines (OCGTs) <sup>(146)</sup> <sup>(147)</sup></b></td> </tr> <tr> <td data-bbox="322 1203 786 1241">New OCGT</td> <td data-bbox="786 1203 1028 1241">≥ 50</td> <td data-bbox="1028 1203 1252 1241">15–35</td> <td data-bbox="1252 1203 1491 1241">25–50</td> </tr> <tr> <td data-bbox="322 1241 786 1324">Existing OCGT (excluding turbines for mechanical drive applications) — All but plants operated &lt; 500 h/yr</td> <td data-bbox="786 1241 1028 1324">≥ 50</td> <td data-bbox="1028 1241 1252 1324">15–50</td> <td data-bbox="1252 1241 1491 1324">25–55 <sup>(148)</sup></td> </tr> <tr> <td colspan="4" data-bbox="322 1324 1491 1369" style="text-align: center;"><b>Combined-cycle gas turbines (CCGTs) <sup>(146)</sup> <sup>(149)</sup></b></td> </tr> </tbody> </table>	Type of combustion plant	Combustion plant total rated thermal input (MW <sub>th</sub> )	BAT-AELs (mg/Nm <sup>3</sup> ) <sup>(142)</sup> <sup>(143)</sup>		Yearly average <sup>(144)</sup> <sup>(145)</sup>	Daily average or average over the sampling period	<b>Open-cycle gas turbines (OCGTs) <sup>(146)</sup> <sup>(147)</sup></b>				New OCGT	≥ 50	15–35	25–50	Existing OCGT (excluding turbines for mechanical drive applications) — All but plants operated < 500 h/yr	≥ 50	15–50	25–55 <sup>(148)</sup>	<b>Combined-cycle gas turbines (CCGTs) <sup>(146)</sup> <sup>(149)</sup></b>				CC	<p>The Operator confirmed that: CO emissions are reduced as far as possible by optimising combustion. Gas Turbine is a DLN Combustion system.</p> <p>Historic engine CO emissions are below ELVs as required in the permit. This is a characteristic of the Trent GTs. The Operator states that they would be compliant with CO yearly ELV of 40mg/Nm<sup>3</sup>. However, as we have introduced a restriction on operating hours for the OCGT to &lt;1,500 hours per year, the yearly BAT-AEL for NO<sub>x</sub> and the yearly</p>
Type of combustion plant	Combustion plant total rated thermal input (MW <sub>th</sub> )			BAT-AELs (mg/Nm <sup>3</sup> ) <sup>(142)</sup> <sup>(143)</sup>																					
		Yearly average <sup>(144)</sup> <sup>(145)</sup>	Daily average or average over the sampling period																						
<b>Open-cycle gas turbines (OCGTs) <sup>(146)</sup> <sup>(147)</sup></b>																									
New OCGT	≥ 50	15–35	25–50																						
Existing OCGT (excluding turbines for mechanical drive applications) — All but plants operated < 500 h/yr	≥ 50	15–50	25–55 <sup>(148)</sup>																						
<b>Combined-cycle gas turbines (CCGTs) <sup>(146)</sup> <sup>(149)</sup></b>																									

BAT Concn. Numbe r	Summary of BAT Conclusion requirement				Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																				
	<table border="1"> <tr> <td>New CCGT</td> <td>≥ 50</td> <td>10–30</td> <td>15–40</td> </tr> <tr> <td>Existing CCGT with a net total fuel utilisation of &lt; 75 %</td> <td>≥ 600</td> <td>10–40</td> <td>18–50</td> </tr> <tr> <td>Existing CCGT with a net total fuel utilisation of ≥ 75 %</td> <td>≥ 600</td> <td>10–50</td> <td>18–55 <sup>(150)</sup></td> </tr> <tr> <td>Existing CCGT with a net total fuel utilisation of &lt; 75 %</td> <td>50–600</td> <td>10–45</td> <td>35–55</td> </tr> <tr> <td>Existing CCGT with a net total fuel utilisation of ≥ 75 %</td> <td>50–600</td> <td>25–50 <sup>(151)</sup></td> <td>35–55 <sup>(152)</sup></td> </tr> </table>	New CCGT	≥ 50	10–30	15–40	Existing CCGT with a net total fuel utilisation of < 75 %	≥ 600	10–40	18–50	Existing CCGT with a net total fuel utilisation of ≥ 75 %	≥ 600	10–50	18–55 <sup>(150)</sup>	Existing CCGT with a net total fuel utilisation of < 75 %	50–600	10–45	35–55	Existing CCGT with a net total fuel utilisation of ≥ 75 %	50–600	25–50 <sup>(151)</sup>	35–55 <sup>(152)</sup>					<p>indicative emission limit for CO are not applicable.</p> <p>As an existing OCGT plant the applicable NO<sub>x</sub> BAT-AEL is 55 mg/m<sup>3</sup> (daily). This limit is applicable when the DLN system is fully effective.</p> <p>The existing permit also sets monthly, daily and hourly average emission limits for carbon monoxide and NO<sub>x</sub>. Under the principal of “no backsliding”, the current emission limits will be retained unless tighter limits are set by the BREF.</p> <p>Refer to section 4.1 of this document for further details of the limits set in the consolidated permit.</p> <p>NO<sub>x</sub> and CO emissions are continuously monitored.</p>
New CCGT	≥ 50	10–30	15–40																							
Existing CCGT with a net total fuel utilisation of < 75 %	≥ 600	10–40	18–50																							
Existing CCGT with a net total fuel utilisation of ≥ 75 %	≥ 600	10–50	18–55 <sup>(150)</sup>																							
Existing CCGT with a net total fuel utilisation of < 75 %	50–600	10–45	35–55																							
Existing CCGT with a net total fuel utilisation of ≥ 75 %	50–600	25–50 <sup>(151)</sup>	35–55 <sup>(152)</sup>																							
	<b>Open- and combined-cycle gas turbines</b>																									
	Gas turbine put into operation no later than 27 November 2003, or existing gas turbine for emergency use and operated < 500 h/yr	≥ 50	No BAT-AEL	60–140 <sup>(153)</sup> <sup>(154)</sup>																						
	Existing gas turbine for mechanical drive applications — All but plants operated < 500 h/yr	≥ 50	15–50 <sup>(155)</sup>	25–55 <sup>(156)</sup>																						
	<p>As an indication, the yearly average CO emission levels for each type of existing combustion plant operated ≥ 1 500 h/yr and for each type of new combustion plant will generally be as follows:</p> <ul style="list-style-type: none"> <li>— New OCGT of ≥ 50 MW<sub>th</sub>: &lt; 5–40 mg/Nm<sup>3</sup>. For plants with a net electrical efficiency (EE) greater than 39 %, a correction factor may be applied to the higher end of this range, corresponding to [higher end] × EE/39, where EE is the net electrical energy efficiency or net mechanical energy efficiency of the plant determined at ISO baseload conditions.</li> <li>— Existing OCGT of ≥ 50 MW<sub>th</sub> (excluding turbines for mechanical drive applications): &lt; 5–40 mg/Nm<sup>3</sup>. The higher end of this range will generally be 80 mg/Nm<sup>3</sup> in the case of existing plants that cannot be fitted with dry techniques for NO<sub>x</sub> reduction, or 50 mg/Nm<sup>3</sup> for plants that operate at low load.</li> <li>— New CCGT of ≥ 50 MW<sub>th</sub>: &lt; 5–30 mg/Nm<sup>3</sup>. For plants with a net electrical efficiency (EE) greater than 55 %, a correction factor may be applied to the higher end of the range, corresponding to [higher end] × EE/55, where EE is the net electrical energy efficiency of the plant determined at ISO baseload conditions.</li> <li>— Existing CCGT of ≥ 50 MW<sub>th</sub>: &lt; 5–30 mg/Nm<sup>3</sup>. The higher end of this range will generally be 50 mg/Nm<sup>3</sup> for plants that operate at low load.</li> <li>— Existing gas turbines of ≥ 50 MW<sub>th</sub> for mechanical drive applications: &lt; 5–40 mg/Nm<sup>3</sup>. The higher end of the range will generally be 50 mg/Nm<sup>3</sup> when plants operate at low load.</li> </ul> <p>In the case of a gas turbine equipped with DLN burners, these indicative levels correspond to when the DLN operation is effective.</p>																									

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																							
	<p><b>BAT-associated emission levels (BAT-AELs) for NO<sub>x</sub> emissions to air from the combustion of natural gas in boilers and engines</b></p> <table border="1" data-bbox="322 440 1491 663"> <thead> <tr> <th rowspan="3">Type of combustion plant</th> <th colspan="4">BAT-AELs (mg/Nm<sup>3</sup>)</th> </tr> <tr> <th colspan="2">Yearly average <sup>(157)</sup></th> <th colspan="2">Daily average or average over the sampling period</th> </tr> <tr> <th>New plant</th> <th>Existing plant <sup>(158)</sup></th> <th>New plant</th> <th>Existing plant <sup>(159)</sup></th> </tr> </thead> <tbody> <tr> <td>Boiler</td> <td>10–60</td> <td>50–100</td> <td>30–85</td> <td>85–110</td> </tr> <tr> <td>Engine <sup>(160)</sup></td> <td>20–75</td> <td>20–100</td> <td>55–85</td> <td>55–110 <sup>(161)</sup></td> </tr> </tbody> </table> <p>As an indication, the yearly average CO emission levels will generally be:</p> <ul style="list-style-type: none"> <li>— &lt; 5–40 mg/Nm<sup>3</sup> for existing boilers operated ≥ 1 500 h/yr,</li> <li>— &lt; 5–15 mg/Nm<sup>3</sup> for new boilers,</li> <li>— 30–100 mg/Nm<sup>3</sup> for existing engines operated ≥ 1 500 h/yr and for new engines.</li> </ul>	Type of combustion plant	BAT-AELs (mg/Nm <sup>3</sup> )				Yearly average <sup>(157)</sup>		Daily average or average over the sampling period		New plant	Existing plant <sup>(158)</sup>	New plant	Existing plant <sup>(159)</sup>	Boiler	10–60	50–100	30–85	85–110	Engine <sup>(160)</sup>	20–75	20–100	55–85	55–110 <sup>(161)</sup>		
Type of combustion plant	BAT-AELs (mg/Nm <sup>3</sup> )																									
	Yearly average <sup>(157)</sup>		Daily average or average over the sampling period																							
	New plant	Existing plant <sup>(158)</sup>	New plant	Existing plant <sup>(159)</sup>																						
Boiler	10–60	50–100	30–85	85–110																						
Engine <sup>(160)</sup>	20–75	20–100	55–85	55–110 <sup>(161)</sup>																						
45	<p>In order to reduce non-methane volatile organic compounds (NMVOC) and methane (CH<sub>4</sub>) emissions to air from the combustion of natural gas in spark-ignited lean-burn gas engines, BAT is to ensure optimised combustion and/or to use oxidation catalysts.</p> <p><b>Description</b></p> <p>See descriptions in Section 8.3. Oxidation catalysts are not effective at reducing the emissions of saturated hydrocarbons containing less than four carbon atoms.</p> <p><b>BAT-associated emission levels (BAT-AELs) for formaldehyde and CH<sub>4</sub> emissions to air from the combustion of natural gas in a spark-ignited lean-burn gas engine</b></p> <table border="1" data-bbox="322 1050 1491 1225"> <thead> <tr> <th rowspan="4">Combustion plant total rated thermal input (MW<sub>th</sub>)</th> <th colspan="3">BAT-AELs (mg/Nm<sup>3</sup>)</th> </tr> <tr> <th>Formaldehyde</th> <th colspan="2">CH<sub>4</sub></th> </tr> <tr> <th colspan="3">Average over the sampling period</th> </tr> <tr> <th>New or existing plant</th> <th>New plant</th> <th>Existing plant</th> </tr> </thead> <tbody> <tr> <td>≥ 50</td> <td>5–15 <sup>(162)</sup></td> <td>215–500 <sup>(163)</sup></td> <td>215–560 <sup>(162)</sup> <sup>(163)</sup></td> </tr> </tbody> </table>	Combustion plant total rated thermal input (MW <sub>th</sub> )	BAT-AELs (mg/Nm <sup>3</sup> )			Formaldehyde	CH <sub>4</sub>		Average over the sampling period			New or existing plant	New plant	Existing plant	≥ 50	5–15 <sup>(162)</sup>	215–500 <sup>(163)</sup>	215–560 <sup>(162)</sup> <sup>(163)</sup>	NA	<p>The Operator confirmed that this BAT Conclusion is not applicable to the installation, despite stating that they are currently compliant.</p> <p>We have set the status to NA instead of CC.</p> <p>We agree this BAT Conclusion is not applicable to the activities carried out at the installation. Spark-ignited lean-burn gas engine are not used on site.</p>						
Combustion plant total rated thermal input (MW <sub>th</sub> )	BAT-AELs (mg/Nm <sup>3</sup> )																									
	Formaldehyde		CH <sub>4</sub>																							
	Average over the sampling period																									
	New or existing plant	New plant	Existing plant																							
≥ 50	5–15 <sup>(162)</sup>	215–500 <sup>(163)</sup>	215–560 <sup>(162)</sup> <sup>(163)</sup>																							
<p><b>BAT Conclusions 46 to 51 for iron and steel process gases.</b>  <b>BAT Conclusions 52 to 54 for offshore platforms.</b>  <b>BAT Conclusions 55 to 59 for chemical process gases.</b>  <b>BAT Conclusions 60 to 71 for co-incineration.</b>  <b>BAT Conclusions 72 to 75 for gasification.</b></p>																										

BAT Concn. Numbe r	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
These BAT Conclusions are not applicable to the activities carried out at the installation.			

## **6. Review and assessment of derogation requests made by the operator in relation to BAT Conclusions which include an associated emission level (AEL) value**

The IED enables a competent authority to allow derogations from BAT AELs stated in BAT Conclusions under specific circumstances as detailed under Article 15(4):

By way of derogation from paragraph 3, and without prejudice to Article 18, the competent authority may, in specific cases, set less strict emission limit values. Such a derogation may apply only where an assessment shows that the achievement of emission levels associated with the best available techniques as described in BAT conclusions would lead to disproportionately higher costs compared to the environmental benefits due to:

*(a) the geographical location or the local environmental conditions of the installation concerned; or*

*(b) the technical characteristics of the installation concerned.*

As part of their Regulation 61 Note response, the operator has not requested a derogation from compliance with any AEL values.

## **7. Emissions to Water**

The consolidated permit incorporates one discharge to controlled waters identified as SW1 of uncontaminated surface water run-off.

There are no BAT AELs specified in the BAT Conclusions for this type of plant. There are also no additional treatment options identified as BAT for the installation. We have therefore not carried out any additional assessment of the emissions to water as part of this review.

## 8 Additional IED Chapter II requirements:

Permit condition/table	Justification
Site Name & Address	Operator requested name was changed to Heartlands Plant & site address updated
2.3.5 and tables S1.1 and S4.3	<p>We have introduced a limit on operating hours in Open Cycle Mode for the LCP in line with our guidance 'BAT for Balancing Plant' (see below) as we do not consider this mode of operation as BAT for plant operating over 1,500 hours.</p> <p>We have amended the reporting requirements in the permit. We have added in a reporting requirement for operating hours to be reported over a five year rolling average to demonstrate compliance with the less than 1,500 hour operational limit.</p> <p>The OCGTs in the permits have previously operated with no restriction on hours. However, we are not satisfied that there is sufficient evidence available to demonstrate that OCGTs represent best available techniques (BAT) for plants operating for more than 1,500 hours per year. Therefore, we have specified 1,500 hours as a limit on operational hours in the permit.</p> <p>Article 11 of the Industrial Emissions Directive 2010/75/EU states that BAT are applied. BAT requires the use of the most effective and advanced techniques to prevent or minimise emissions and impacts on the environment.</p> <p>Relevant guidance that we have drawn on, for BAT, includes the Department of Energy and Climate Change '<i>Developing best available techniques (BAT) for combustion plants operating in the balancing market</i>' and Chapter III of IED and the BAT conclusions all of which specifically identify two categories of combustion plant operating in the balancing market as peaking plant: those that operate less than 500 hours and those that operate from 500 hours up to 1,500 hours. Within these documents no other categories of operational regimes are recognised other than base load operation.</p> <p>Furthermore, draft Environment Agency guidance '<i>BAT guidance for &gt;50 MWth gas and liquid fuel combustion plant exporting electricity under commercial arrangements for &lt;1,500 hours per annum</i>' consolidates our position on the above and stipulates</p>



	<p>that combustion plants operating in a single cycle, will be limited to 1,500 hours per annum on a rolling average.</p> <p>OCGTs operating as peaking plant are classed as fast start, lower efficiency and would generally have higher emissions of oxides of nitrogen (NOx) per megawatt hour of energy produced than would be expected for natural gas fired base load plant. Therefore, OCGTs are better suited to fast reserve running for short periods of time in comparison to base load plants which are more appropriate for steady state running operations.</p> <p>The use of fast start closed circuit gas turbines (CCGT) aero derivative, gas turbine combined heat and power (GT-CHP) or a large gas engine with combined heat and power would be considered to be a more favourable alternative, in terms of energy efficiency, than the proposal presented in this application.</p> <p>The National Emissions Ceiling Directive (NECD) sets national targets for reductions in pollutants including NOx. Restrictions on plants with higher NOx intensity directly contributes to achieving the NECD targets.</p> <p>For this reason the variation restricts the hours of operation of the plant to no more than 1,500 hours per engine per year as a rolling average over a 5 year period and with operation of an engine in any individual year limited to a maximum of 2,250 hours.</p>
Table S1.1	Water treatment is no longer undertaken, Directly associated activity removed from the table S1.1
2.3.8 and IC6 in table S1.3	<p>In the event of a black out National Grid would call on combustion plant to operate and may require them to do so outside their permitted conditions. We have dedicated black start plant and they are permitted to run as such but this scenario is relevant to the rest of the LCP which could be called depending on the circumstances.</p> <p>A risk assessment will be carried out by Energy UK/Joint Environmental Programme on behalf of LCP connected to the National Transmission System. Air emissions modelling will be based on generic black start scenarios to establish whether they have the potential to have a local impact on the environment or not (on a national basis). If the modelling demonstrates that no significant impacts are likely, the plant can operate under condition 2.3.8. This condition allows</p>

	<p>the hourly ELVs for plants operating under a black start instruction to be discounted for the purpose of reporting. We would also require there to be a procedure in place for minimisation of emissions in the case of a black start event and for reporting in the event of a black start. This modelling and the procedures have not been agreed in advance of the issue of the permit review and therefore a condition linking back to an improvement condition has been included in the permit.</p>
Table S1.3 amended	To remove completed improvement conditions IC1 to IC5.

## 9 Review and assessment of changes that are not part of the BAT Conclusions derived permit review.

This document should be read in conjunction with the application, supporting information and notice.

Aspect considered	Decision
<b>Receipt of application</b>	
Confidential information	A claim for commercial or industrial confidentiality has not been made.
Identifying confidential information	We have not identified information provided as part of the application that we consider to be confidential.  The decision was taken in accordance with our guidance on confidentiality.
<b>The site</b>	
Biodiversity, heritage, landscape and nature conservation	The application is within the relevant distance criteria of a site of heritage, landscape or nature conservation, and/or protected species or habitat.  A full assessment of the application and its potential to affect the site(s)/species/habitat has not been carried out as part of the permit review process. We consider that the review will not affect the features of the site(s)/species/habitat as the conditions will provide at least the same level of protection as those in the previous permit and in some cases will provide a higher level of protection to those in the previous permit.  We have not consulted Natural England on the application. The decision was taken in accordance with our guidance.
<b>Operating techniques</b>	
General operating techniques	We have reviewed the techniques used by the operator where they are relevant to the BAT Conclusions and compared these with the relevant guidance notes.  The permit conditions ensure compliance with the relevant BREF, BAT Conclusions. The ELVs deliver compliance with the BAT-AELs.  We have introduced a limit on operating hours in Open Cycle Mode for the LCP in line with our guidance 'BAT for Balancing Plant' as we do not consider this mode of operation as BAT for plant operating over 1,500 hours. See section 8 for further information.

Aspect considered	Decision
<b>Permit conditions</b>	
Updating permit conditions during consolidation	We have updated permit conditions to those in the current generic permit template as part of permit consolidation. The conditions will provide at least the same level of protection as those in the previous permit and in some cases will provide a higher level of protection to those in the previous permit.
Changes to the permit conditions due to an Environment Agency initiated variation	We have varied the permit as stated in the variation notice.
Improvement programme	<p>Based on the information on the application, we consider that we need to impose an improvement programme.</p> <p>Permit condition 2.3.8 has been included in the permit with corresponding improvement condition IC6 requiring the operator to submit a report in relation to potential black start operation of the plant. See Section 8 for further information.</p> <p>We have also removed the completed improvement conditions from the permit.</p>
Emission limits	<p>We have decided that emission limits should be set for the parameters listed in the permit.</p> <p>These are described in the relevant BAT Conclusions in Sections 4.1 and 5 of this document.</p> <p>It is considered that the ELVs/equivalent parameters or technical measures described above will ensure that significant pollution of the environment is prevented and a high level of protection for the environment is secured.</p>
Monitoring	<p>We have decided that monitoring should be carried out for the parameters listed in the permit, using the methods detailed and to the frequencies specified.</p> <p>These are described in the relevant BAT Conclusions in Sections 4.1 and 5 of this document.</p> <p>Table S3.4 Process monitoring requirements was amended to include the requirement to monitor energy efficiency after overhauls on site in line with BAT2.</p> <p>Based on the information in the application we are satisfied that the operator's techniques, personnel and equipment have either MCERTS certification or MCERTS accreditation as appropriate.</p>
Reporting	<p>We have specified reporting in the permit for the following parameters:</p> <ul style="list-style-type: none"> <li>• Nitrogen dioxide</li> </ul>

Aspect considered	Decision
	<ul style="list-style-type: none"> <li>• Carbon monoxide</li> </ul> <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p>
<b>Operator competence</b>	
Management system	There is no known reason to consider that the operator will not have the management system to enable it to comply with the permit conditions.
<b>Growth Duty</b>	
Section 108 Deregulation Act 2015 – Growth duty	<p>We have considered our duty to have regard to the desirability of promoting economic growth set out in section 108(1) of the Deregulation Act 2015 and the guidance issued under section 110 of that Act in deciding whether to grant this permit.</p> <p>Paragraph 1.3 of the guidance says:</p> <p>“The primary role of regulators, in delivering regulation, is to achieve the regulatory outcomes for which they are responsible. For a number of regulators, these regulatory outcomes include an explicit reference to development or growth. The growth duty establishes economic growth as a factor that all specified regulators should have regard to, alongside the delivery of the protections set out in the relevant legislation.”</p> <p>We have addressed the legislative requirements and environmental standards to be set for this operation in the body of the decision document above. The guidance is clear at paragraph 1.5 that the growth duty does not legitimise non-compliance and its purpose is not to achieve or pursue economic growth at the expense of necessary protections.</p> <p>We consider the requirements and standards we have set in this permit are reasonable and necessary to avoid a risk of an unacceptable level of pollution. This also promotes growth amongst legitimate operators because the standards applied to the operator are consistent across businesses in this sector and have been set to achieve the required legislative standards.</p>