

## Environment Agency

# Review of an Environmental Permit for an Installation subject to Chapter II of the Industrial Emissions Directive under the Environmental Permitting (England & Wales) Regulations 2016

## Decision document recording our decision-making process following review of a permit

The Permit number is: EPR/RP3936YG  
The Operator is: Whitetower Energy Limited  
The Installation is: Derby Plant  
This Variation Notice number is: EPR/RP3936YG/V003

### What this document is about

Article 21(3) of the Industrial Emissions Directive (IED) requires the Environment Agency to review conditions in permits that it has issued and to ensure that the permit delivers compliance with relevant standards, within four years of the publication of updated decisions on best available techniques (BAT) conclusions.

We have reviewed the permit for this installation against the revised BAT Conclusions for large combustion plant published on 17<sup>th</sup> August 2017. This is our decision document, which explains the reasoning for the consolidated variation notice that we are issuing.

It explains how we have reviewed and considered the techniques used by the Operator in the operation and control of the plant and activities of the installation. This review has been undertaken with reference to the decision made by the European Commission establishing best available techniques (BAT) conclusions ('BAT Conclusions') for large combustion plant as detailed in document reference IEDC-7-1. It is our record of our decision-making process and shows how we have taken into account all relevant factors in reaching our position. It also provides a justification for the inclusion of any specific conditions in the permit that are in addition to those included in our generic permit template.

As well as considering the review of the operating techniques used by the Operator for the operation of the plant and activities of the installation, the consolidated variation notice takes into account and brings together in a single document all previous variations that relate to the original permit issued. It also modernises the entire permit to reflect the conditions contained in our current generic permit template.

The introduction of new template conditions makes the Permit consistent with our current general approach and philosophy and with other permits issued to installations in this sector. Although the wording of some conditions has changed, while others have been removed because of the new regulatory approach, it does not reduce the level of environmental protection achieved by the Permit in any way. In this document we therefore address only our determination of substantive issues relating to the new BAT Conclusions.

Throughout this document we will use a number of expressions. These are as referred to in the glossary and have the same meaning as described in “Schedule 6 Interpretation” of the Permit.

We try to explain our decision as accurately, comprehensively and plainly as possible. We would welcome any feedback as to how we might improve our decision documents in future. A lot of technical terms and acronyms are inevitable in a document of this nature: we provide a glossary of acronyms near the front of the document, for ease of reference.

## How this document is structured

### Glossary of terms

- 1 Our decision
- 2 How we reached our decision
- 2.1 Requesting information to demonstrate compliance with BAT Conclusions for Large Combustion Plant
- 2.2 Review of our own information in respect to the capability of the installation to meet revised standards included in the BAT Conclusions document
- 3 The legal framework
- 4 Key Issues
- 5 Decision checklist regarding relevant BAT Conclusions
- 6 Review and assessment of derogation requests made by the operator in relation to BAT Conclusions which include an associated emission level (AEL) value
- 7 Emissions to Water
- 8 Additional IED Chapter II requirements
- 9 Review and assessment of changes that are not part of the BAT Conclusions derived permit review.

## Glossary of acronyms used in this document

(Please note that this glossary is standard for our decision documents and therefore not all these acronyms are necessarily used in this document.)

APC	Air Pollution Control
BAT	Best Available Technique(s)
BAT-AEEL	BAT Associated Energy Efficiency Level
BAT-AEL	BAT Associated Emission Level
BATc	BAT conclusion
BREF	Best available techniques reference document
CEM	Continuous emissions monitor
CHP	Combined heat and power
CV	Calorific value
DAA	Directly associated activity – Additional activities necessary to be carried out to allow the principal activity to be carried out
DLN	Dry Low NOx burners
DLN-E	Dry Low NOx effective
EIONET	European environment information and observation network is a partnership network of the European Environment Agency
ELV	Emission limit value derived under BAT or an emission limit value set out in IED
EMS	Environmental Management System
EPR	Environmental Permitting (England and Wales) Regulations 2016 (SI 2016 No. 1154)
EWC	European waste catalogue
FSA	Food Standards Agency
IC	Improvement Condition
IED	Industrial Emissions Directive (2010/75/EU)
IPPCD	Integrated Pollution Prevention and Control Directive (2008/1/EC) – now superseded by IED
LCP	Large Combustion Plant subject to Chapter III of IED
MSUL/MSDL	Minimum start up load/minimum shut-down load
NOx	Oxides of nitrogen (NO plus NO <sub>2</sub> expressed as NO <sub>2</sub> )
NPV	Net Present Value
OCGT	Open Cycle Gas Turbine
PHE	Public Health England
SAC	Special Area of Conservation
SGN	Sector guidance note
TGN	Technical guidance note
TNP	Transitional National Plan
TOC	Total Organic Carbon
WFD	Water Framework Directive (2000/60/EC)

## 1 Our decision

We have decided to issue the consolidated variation notice to the Operator. This will allow it to continue to operate the Installation, subject to the conditions in the consolidated variation notice.

We consider that, in reaching that decision, we have taken into account all relevant considerations and legal requirements and that the varied permit will ensure that a high level of protection is provided for the environment and human health.

The consolidated variation notice contains many conditions taken from our standard Environmental Permit template including the relevant Annexes. We developed these conditions in consultation with industry, having regard to the legal requirements of the Environmental Permitting Regulations and other relevant legislation. This document does not therefore include an explanation for these standard conditions. Where they are included in the Notice, we have considered the techniques identified by the operator for the operation of their installation, and have accepted that the details are sufficient and satisfactory to make those standard conditions appropriate. This document does, however, provide an explanation of our use of “tailor-made” or installation-specific conditions, or where our Permit template provides two or more options.

## 2 How we reached our decision

### 2.1 Requesting information to demonstrate compliance with BAT Conclusions for Large Combustion Plant

We issued a Notice under Regulation 61(1) of the Environmental Permitting (England and Wales) Regulations 2016 (a Regulation 61 Notice) on 1<sup>st</sup> May 2018 requiring the Operator to provide information to demonstrate how the operation of their installation currently meets, or will subsequently meet, the revised standards described in the large combustion plant BAT Conclusions document. The Notice also required that where the revised standards are not currently met, the operator should provide information that:

- Describes the techniques that will be implemented before 17<sup>th</sup> August 2021, which will then ensure that operations meet the revised standard, or
- Justifies why standards will not be met by 17<sup>th</sup> August 2021, and confirmation of the date when the operation of those processes will cease within the installation or an explanation of why the revised BAT standard is not applicable to those processes, or
- Justifies why an alternative technique will achieve the same level of environmental protection equivalent to the revised standard described in the BAT Conclusions.

Where the Operator proposed that they were not intending to meet a BAT standard that also included a BAT Associated Emission Level (BAT AEL) described in the BAT Conclusions Document, the Regulation 61 Notice requested that the Operator make a formal request for derogation from compliance with that AEL (as provisioned by Article 15(4) of IED). In this circumstance, the Notice identified that any such request for derogation must be supported and justified by sufficient technical and commercial information that would enable us to determine acceptability of the derogation request.

The Regulation 61 Notice response from the Operator was received on 30/10/2018

We considered it was in the correct form and contained sufficient information for us to begin our determination of the permit review but not that it necessarily contained all the information we would need to complete that review.

An updated Regulation 61 Notice response from the Operator was received on 12 May 2020. This response contains additional information and supersedes the previous Regulation 61 response. We have based our review on this submission.

## **2.2 Review of our own information in respect to the capability of the installation to meet revised standards included in the BAT Conclusions document**

Based on our records and previous regulatory activities with the facility we have no reason to consider that the operator will not be able to comply with the conditions that we include in the permit.

### 3 The legal framework

The consolidated variation notice will be issued under Regulation 20 of the EPR. The Environmental Permitting regime is a legal vehicle which delivers most of the relevant legal requirements for activities falling within its scope. In particular, the regulated facility is:

- an *installation* as described by the IED;
- subject to aspects of other relevant legislation which also have to be addressed.

We consider that the consolidated variation notice will ensure that the operation of the Installation complies with all relevant legal requirements and that a high level of protection will be delivered for the environment and human health.

We explain how we have addressed specific statutory requirements more fully in the rest of this document.

## 4 The key issues

The key issues arising during this permit review are:

- Emissions to air and the emission limits applied to the plant.
- The energy efficiency levels associated with the Best Available Techniques (BAT-AEELs)

We therefore describe how we determined these issues in most detail in the relevant sections of this document.

### 4.1 Emissions to air and the emission limits applied to the plant

A number of general principles were applied during the permit review. These included:

- The upper value of the BAT AELs ranges specified were used unless use of the tighter limit was justified.
- The principle of no backsliding where if existing limits in the permit were already tighter than those specified in the BREF, the existing permit limits were retained.
- Where a limit was specified in both IED Annex V and the BAT Conclusions for a particular reference period, the tighter limit was applied and in the majority of cases this was from the BAT Conclusions.
- Where AELs are indicative in the BAT Conclusions, these were applied unless adequate justification was provided by the operator to demonstrate that an alternative limit was more appropriate.
- For gas turbines where the IED specified that limits applied over 70% load and the BAT Conclusions specified that AELs applied when dry low NO<sub>x</sub> is effective (DLN-E), we have used DLN-E as a default across all monitoring requirements for NO<sub>x</sub> and CO.

LCP 85 consists of a single open cycle gas turbine (OCGT) with a net thermal input of 120.2 MWth, which operates with a thermal efficiency of 41.6%.

The plant was put into operation before IED came into force and therefore the existing limits in the permit are from Part 1 of IED Annex V applicable to existing plant.

The ELVs and AELs are based on the following operating regime:

- OCGT existing plant
- <1500 hours operation
- $\geq 50$  MWth

The following tables outline the limits that have been incorporated into the permit for LCP85, where these were derived from and the reference periods at which they apply. The emission limits refer to concentrations, expressed as



mass of emitted substance per volume of flue-gas under the following standard conditions: dry gas at a temperature of 273,15 K, pressure of 101,3 kPa and 15%volume reference oxygen concentration if flue gases. The emission limits and monitoring requirements have been incorporated into Schedule 3 of the permit.

NOx limits (mg/Nm <sup>3</sup> )							
Averaging	IED (Annex V Part 1) Existing	BREF (Table 24 BAT-c)	Current	Expected permit limits	Basis	Limits apply	Monitoring
Monthly	50	None	50	50	IED	E-DLN	Continuous
Daily	55	55	55	55	BREF/IED	E-DLN and MSUL/MSDL to baseload	
95 <sup>th</sup> %ile of hr means	100	None	60	60	Current No backsliding	E-DLN	

CO limits (mg/Nm <sup>3</sup> ) indicative							
Averaging	IED (Annex V Part 1) - Existing	BREF (Table 24 BAT-c)	Current	Expected permit limits	Basis	Limits apply	Monitoring
Monthly	100	None	50	50	Current No backsliding	E-DLN	Continuous
Daily	110	85	50	50	Current No backsliding	E-DLN and MSUL/MSDL to baseload	
95 <sup>th</sup> %ile of hr means	200	None	50	50	Current No backsliding	E-DLN	

#### 4.2 The energy efficiency levels associated with the Best Available Techniques Conclusions

An energy efficiency level associated with the best available techniques (BAT-AEEL) refers to the ratio between the combustion unit's net energy output(s) and the combustion unit's fuel/feedstock energy input at actual unit design. The net energy output(s) is determined at the combustion unit boundaries, including auxiliary systems (e.g. flue-gas treatment systems), and for the unit operated at full load.

The existing permit has no restriction on operating hours and the Regulation 61 response was based on unlimited operational hours. During the permit review, we have introduced a limit on operating hours in Open Cycle Mode for the LCP in line with our guidance 'BAT for Balancing Plant' (refer to section 8 of this document) as we do not consider this mode of operation as BAT for plant operating over 1,500 hours/year.

Footnote 1 of Table 23 of the LCP BAT Conclusions specifies that the BAT AEELs for this type of plant are not applicable as the plant will operate for <1,500 hours/year. Whilst the BAT AEELs do not apply to this plant, we have included the information provided by the Operator.

The table below sets out the BAT AEELs specified in the LCP BAT Conclusions for LCP operating >1,500 hours/year and the energy efficiency levels confirmed through the Regulation 61 notice response. Although not applicable, we consider this plant is BAT in relation to the AEELs.

BAT AEELs (%)			Plant efficiency (%)		
Net electrical efficiency	Net total fuel utilisation	Net mechanical efficiency	Net electrical efficiency	Net total fuel utilisation	Net mechanical efficiency
<b>LCP 85: Open cycle gas turbine ≥ 50 MWth</b>					
33-41.5	None	NA	41.6	NA	NA

We have included a process monitoring requirement in table S3.2 of the consolidated variation notice. This is required to demonstrate that efficiency levels are maintained following any significant overhauls of equipment in order to fulfil the requirement of BAT Conclusion 2. If the plant operates for <500 hours/year we have specified that the assessment of efficiency can be based on calculation. This is because we will not require plant to fire up with the sole purpose of carrying out an assessment of efficiency.

## 5 Decision checklist regarding relevant BAT Conclusions

BAT Conclusions for large combustion plant, were published by the European Commission on 17<sup>th</sup> August 2017. There are 75 BAT Conclusions. Only the BAT Conclusions relevant to the particular fuel type used on site have been replicated below.

This annex provides a record of decisions made in relation to each relevant BAT Conclusion applicable to the installation. This annex should be read in conjunction with the Consolidated Variation Notice.

The conditions in the permit through which the relevant BAT Conclusions are implemented include but are not limited to the following:

BAT Conclusion requirement topic	Permit condition(s)	Permit table(s)
Environmental Management System	1.1.1	S1.2
BAT AELs	3.1.1 and 3.5.1	S3.1a
Monitoring	2.3, 3.5 and 3.6	S1.2, S1.4, S1.5, S3.1a
Energy efficiency	1.2 and 2.3	S3.2
Noise	3.4 and 2.3	S1.2
Other operating techniques	2.3	S1.2

The overall status of compliance with the BAT conclusion is indicated in the table as:

- NA Not Applicable
- CC Currently Compliant
- FC Compliant in the future (within 4 years of publication of BAT conclusions)
- NC Not Compliant
- PC Partially Compliant

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
<b>General</b>			
1	<p><b>In order to improve the overall environmental performance, BAT is to implement and adhere to an environmental management system (EMS) that incorporates all of the following features:</b></p> <ul style="list-style-type: none"> <li>i. commitment of the management, including senior management;</li> <li>ii. definition of an environmental policy that includes the continuous improvement of the installation by the management;</li> <li>iii. planning and establishing the necessary procedures, objectives and targets, in conjunction with financial planning and investment;</li> <li>iv. implementation of procedures <ul style="list-style-type: none"> <li>(a) Structure and responsibility</li> <li>(b) Training</li> <li>(c) Communication</li> <li>(d) Employee involvement</li> <li>(e) Documentation</li> <li>(f) Efficient process control</li> <li>(g) Maintenance programmes</li> <li>(h) Emergency preparedness and response</li> <li>(i) Safeguarding compliance with environmental legislation</li> </ul> </li> <li>v. checking performance and taking corrective action, paying particular attention to: <ul style="list-style-type: none"> <li>(a) monitoring and measurement (see also the Reference Document on the General Principles of Monitoring)</li> <li>(b) corrective and preventive action</li> <li>(c) maintenance of records</li> <li>(d) independent (where practicable) internal and external auditing in order to determine whether or not the EMS conforms to planned arrangements and has been properly implemented and maintained;</li> </ul> </li> <li>vi. review of the EMS and its continuing suitability, adequacy and effectiveness by senior management;</li> <li>vii. following the development of cleaner technologies;</li> <li>viii. consideration for the environmental impacts from the eventual decommissioning of the installation at the stage of designing a new plant, and throughout its operating life;</li> <li>viii. consideration for the environmental impacts from the eventual decommissioning of the installation at the stage of designing a new plant, and throughout its operating life;</li> <li>ix. application of sectoral benchmarking on a regular basis.</li> </ul> <p>BAT Conclusions <b>Applicability</b>. The scope (e.g. level of detail) and nature of the EMS (e.g. standardised or non-standardised) will generally be related to the nature, scale and complexity of the installation, and the range of environmental impacts it may have.</p>	FC	<p>From 1 June 2020 the site operations and therefore the EMS will be provided by the new operations and maintenance (O &amp; M) provider, NAES Power Solutions Limited.</p> <p>The existing RWE EMS is compliant with ISO 14001. This EMS is currently in compliance with features i through to xvi of this BAT Conclusion.</p> <p>The Operator has confirmed that, when fully implemented, the NAES EMS will also meet all requirements of BAT Conclusion 1.</p> <p>Due to the change of EMS and the expected implementation timescales, we do not agree with the Operator's stated compliance of CC and have changed the status to FC.</p> <p>We do not consider it necessary to set an improvement condition as we will track progress via compliance. It is expected that the NAES EMS will be implemented by 17 August 2021 and that the site will be compliant with BAT Conclusion 1.</p>

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement													
2	<p>BAT is to determine the net electrical efficiency and/or the net total fuel utilisation and/or the net mechanical energy efficiency of the gasification, IGCC and/or combustion units by carrying out a performance test at full load (1), according to EN standards, after the commissioning of the unit and after each modification that could significantly affect the net electrical efficiency and/or the net total fuel utilisation and/or the net mechanical energy efficiency of the unit. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.</p>	CC	<p>An assessment of efficiency was calculated based on efficiency data and determined to be 41.6 (± 1.1%).</p> <p>Specific data will be reviewed by the O &amp; M provider and Siemens. Siemens will provide engine performance data. O &amp; M to provide a site efficiency report as a review of historic site data and improvements.</p> <p>A process monitoring requirement has been set in table S3.2 which requires energy efficiency monitoring after an overhaul.</p> <p>Reg60 Data submitted 21st July 2015 Calculations of Industrial Trent Efficiency</p>													
3	<p><b>BAT is to monitor key process parameters relevant for emissions to air and water including those given below.</b></p> <table border="1" data-bbox="320 1038 1494 1214"> <thead> <tr> <th data-bbox="320 1038 689 1074">Stream</th> <th data-bbox="689 1038 1124 1074">Parameter(s)</th> <th data-bbox="1124 1038 1494 1074">Monitoring</th> </tr> </thead> <tbody> <tr> <td data-bbox="320 1074 689 1177" rowspan="3">Flue-gas</td> <td data-bbox="689 1074 1124 1109">Flow</td> <td data-bbox="1124 1074 1494 1109">Periodic or continuous determination</td> </tr> <tr> <td data-bbox="689 1109 1124 1144">Oxygen content, temperature, and pressure</td> <td data-bbox="1124 1109 1494 1144">Periodic or continuous measurement</td> </tr> <tr> <td data-bbox="689 1144 1124 1177">Water vapour content (%)</td> <td data-bbox="1124 1144 1494 1177"></td> </tr> <tr> <td data-bbox="320 1177 689 1214">Waste water from flue-gas treatment</td> <td data-bbox="689 1177 1124 1214">Flow, pH, and temperature</td> <td data-bbox="1124 1177 1494 1214">Continuous measurement</td> </tr> </tbody> </table>	Stream	Parameter(s)	Monitoring	Flue-gas	Flow	Periodic or continuous determination	Oxygen content, temperature, and pressure	Periodic or continuous measurement	Water vapour content (%)		Waste water from flue-gas treatment	Flow, pH, and temperature	Continuous measurement	CC	<p>The operator has confirmed that operation of the GT is to keep Start up times to minimum, keep engine testing to minimum durations, Energy Supply contracts as peaking operations reduces run hours. The Engine is shut down for investigation in the event of abnormal emissions. GT instrumentation is routinely serviced and calibrated by the ECSA contract by Siemens.</p>
Stream	Parameter(s)	Monitoring														
Flue-gas	Flow	Periodic or continuous determination														
	Oxygen content, temperature, and pressure	Periodic or continuous measurement														
	Water vapour content (%)															
Waste water from flue-gas treatment	Flow, pH, and temperature	Continuous measurement														

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																		
			<p>Parameters are continuously monitored as required by BAT 3.</p> <p>Flow, Temperature, and Pressure are measured by instruments installed on the Gas Turbine Air system and Gas Fuel system. Oxygen is measured on a continuous basis by the CEMS analyser.</p> <p>The site does not carry out flue-gas treatment</p>																		
4	<p>BAT is to monitor emissions to air with at least the frequency given below and in accordance with EN standards. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.</p> <table border="1" data-bbox="320 842 1494 1390"> <thead> <tr> <th data-bbox="320 842 474 962">Substance/Parameter</th> <th data-bbox="474 842 790 962">Fuel/Process/Type of combustion plant</th> <th data-bbox="790 842 947 962">Combustion plant total rated thermal input</th> <th data-bbox="947 842 1126 962">Standard(s)<sup>(4)</sup></th> <th data-bbox="1126 842 1346 962">Minimum monitoring frequency<sup>(5)</sup></th> <th data-bbox="1346 842 1494 962">Monitoring associated with</th> </tr> </thead> <tbody> <tr> <td data-bbox="320 962 474 1027">NH<sub>3</sub></td> <td data-bbox="474 962 790 1027">— When SCR and/or SNCR is used</td> <td data-bbox="790 962 947 1027">All sizes</td> <td data-bbox="947 962 1126 1027">Generic EN standards</td> <td data-bbox="1126 962 1346 1027">Continuous<sup>(6)</sup><sub>(7)</sub></td> <td data-bbox="1346 962 1494 1027">BAT 7</td> </tr> <tr> <td data-bbox="320 1027 474 1390">NO<sub>x</sub></td> <td data-bbox="474 1027 790 1390"> <ul style="list-style-type: none"> <li>— Coal and/or lignite including waste co-incineration</li> <li>— Solid biomass and/or peat including waste co-incineration</li> <li>— HFO- and/or gas-oil-fired boilers and engines</li> <li>— Gas-oil-fired gas turbines</li> <li>— Natural-gas-fired boilers, engines, and turbines</li> <li>— Iron and steel process gases</li> </ul> </td> <td data-bbox="790 1027 947 1390">All sizes</td> <td data-bbox="947 1027 1126 1390">Generic EN standards</td> <td data-bbox="1126 1027 1346 1390">Continuous<sup>(6)</sup><sub>(8)</sub></td> <td data-bbox="1346 1027 1494 1390">           BAT 20            BAT 24            BAT 28            BAT 32            BAT 37            BAT 41            BAT 42            BAT 43            BAT 47            BAT 48            BAT 56            BAT 64            BAT 65            BAT 73         </td> </tr> </tbody> </table>	Substance/Parameter	Fuel/Process/Type of combustion plant	Combustion plant total rated thermal input	Standard(s) <sup>(4)</sup>	Minimum monitoring frequency <sup>(5)</sup>	Monitoring associated with	NH <sub>3</sub>	— When SCR and/or SNCR is used	All sizes	Generic EN standards	Continuous <sup>(6)</sup> <sub>(7)</sub>	BAT 7	NO <sub>x</sub>	<ul style="list-style-type: none"> <li>— Coal and/or lignite including waste co-incineration</li> <li>— Solid biomass and/or peat including waste co-incineration</li> <li>— HFO- and/or gas-oil-fired boilers and engines</li> <li>— Gas-oil-fired gas turbines</li> <li>— Natural-gas-fired boilers, engines, and turbines</li> <li>— Iron and steel process gases</li> </ul>	All sizes	Generic EN standards	Continuous <sup>(6)</sup> <sub>(8)</sub>	BAT 20 BAT 24 BAT 28 BAT 32 BAT 37 BAT 41 BAT 42 BAT 43 BAT 47 BAT 48 BAT 56 BAT 64 BAT 65 BAT 73	CC	<p>The operator has confirmed that MCERT installed CEMS systems. Continuous Monitoring Servicing is carried out to the requirements of EN14181 by the maintenance contractors.</p>
Substance/Parameter	Fuel/Process/Type of combustion plant	Combustion plant total rated thermal input	Standard(s) <sup>(4)</sup>	Minimum monitoring frequency <sup>(5)</sup>	Monitoring associated with																
NH <sub>3</sub>	— When SCR and/or SNCR is used	All sizes	Generic EN standards	Continuous <sup>(6)</sup> <sub>(7)</sub>	BAT 7																
NO <sub>x</sub>	<ul style="list-style-type: none"> <li>— Coal and/or lignite including waste co-incineration</li> <li>— Solid biomass and/or peat including waste co-incineration</li> <li>— HFO- and/or gas-oil-fired boilers and engines</li> <li>— Gas-oil-fired gas turbines</li> <li>— Natural-gas-fired boilers, engines, and turbines</li> <li>— Iron and steel process gases</li> </ul>	All sizes	Generic EN standards	Continuous <sup>(6)</sup> <sub>(8)</sub>	BAT 20 BAT 24 BAT 28 BAT 32 BAT 37 BAT 41 BAT 42 BAT 43 BAT 47 BAT 48 BAT 56 BAT 64 BAT 65 BAT 73																

BAT Concn. Numbe r	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	<ul style="list-style-type: none"> <li>— Process fuels from the chemical industry</li> <li>— IGCC plants</li> </ul>							
	<ul style="list-style-type: none"> <li>— Combustion plants on offshore platforms</li> </ul>	All sizes	EN 14792	Once every year <sup>(9)</sup>	BAT 53			
N <sub>2</sub> O	<ul style="list-style-type: none"> <li>— Coal and/or lignite in circulating fluidised bed boilers</li> <li>— Solid biomass and/or peat in circulating fluidised bed boilers</li> </ul>	All sizes	EN 21258	Once every year <sup>(10)</sup>	BAT 20 BAT 24			
CO	<ul style="list-style-type: none"> <li>— Coal and/or lignite including waste co-incineration</li> <li>— Solid biomass and/or peat including waste co-incineration</li> <li>— HFO- and/or gas-oil-fired boilers and engines</li> <li>— Gas-oil-fired gas turbines</li> <li>— Natural-gas-fired boilers, engines, and turbines</li> <li>— Iron and steel process gases</li> <li>— Process fuels from the chemical industry</li> <li>— IGCC plants</li> </ul>	All sizes	Generic EN standards	Continuous <sup>(6)</sup> <sup>(8)</sup>	BAT 20 BAT 24 BAT 28 BAT 33 BAT 38 BAT 44 BAT 49 BAT 56 BAT 64 BAT 65 BAT 73			
	<ul style="list-style-type: none"> <li>— Combustion plants on offshore platforms</li> </ul>	All sizes	EN 15058	Once every year <sup>(9)</sup>	BAT 54			
SO <sub>2</sub>	<ul style="list-style-type: none"> <li>— Coal and/or lignite incl waste co-incineration</li> <li>— Solid biomass and/or peat incl waste co-incineration</li> </ul>	All sizes	Generic EN standards and EN 14791	Continuous <sup>(6)</sup> <sup>(11)</sup> <sup>(12)</sup>	BAT 21 BAT 25 BAT 29 BAT 34 BAT 39 BAT 50 BAT 57			

BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
		<ul style="list-style-type: none"> <li>— HFO- and/or gas-oil-fired boilers</li> <li>— HFO- and/or gas-oil-fired engines</li> <li>— Gas-oil-fired gas turbines</li> <li>— Iron and steel process gases</li> <li>— Process fuels from the chemical industry in boilers</li> <li>— IGCC plants</li> </ul>				BAT 66 BAT 67 BAT 74		
	SO <sub>3</sub>	— When SCR is used	All sizes	No EN standard available	Once every year	—		
	Gaseous chlorides, expressed as HCl	<ul style="list-style-type: none"> <li>— Coal and/or lignite</li> <li>— Process fuels from the chemical industry in boilers</li> </ul>	All sizes	EN 1911	Once every three months <sup>(6)</sup> <sup>(13)</sup> <sup>(14)</sup>	BAT 21 BAT 57		
		— Solid biomass and/or peat	All sizes	Generic EN standards	Continuous <sup>(15)</sup> <sup>(16)</sup>	BAT 25		
		— Waste co-incineration	All sizes	Generic EN standards	Continuous <sup>(6)</sup> <sup>(16)</sup>	BAT 66 BAT 67		
	HF	<ul style="list-style-type: none"> <li>— Coal and/or lignite</li> <li>— Process fuels from the chemical industry in boilers</li> </ul>	All sizes	No EN standard available	Once every three months <sup>(6)</sup> <sup>(13)</sup> <sup>(14)</sup>	BAT 21 BAT 57		
		— Solid biomass and/or peat	All sizes	No EN standard available	Once every year	BAT 25		
		— Waste co-incineration	All sizes	Generic EN standards	Continuous <sup>(6)</sup> <sup>(16)</sup>	BAT 66 BAT 67		
	Dust	<ul style="list-style-type: none"> <li>— Coal and/or lignite</li> <li>— Solid biomass and/or peat</li> <li>— HFO- and/or gas-oil-fired boilers</li> </ul>	All sizes	Generic EN standards and EN 13284-1 and EN 13284-2	Continuous <sup>(6)</sup> <sup>(17)</sup>	BAT 22 BAT 26 BAT 30 BAT 35 BAT 39 BAT 51 BAT 58		



BAT Concn. Number	Summary of BAT Conclusion requirement					Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
		<ul style="list-style-type: none"> <li>— Iron and steel process gases</li> <li>— Process fuels from the chemical industry in boilers</li> <li>— IGCC plants</li> <li>— HFO- and/or gas-oil-fired engines</li> <li>— Gas-oil-fired gas turbines</li> </ul>				BAT 75	
		<ul style="list-style-type: none"> <li>— Waste co-incineration</li> </ul>	All sizes	Generic EN standards and EN 13284-2	Continuous	BAT 68 BAT 69	
	Metals and metalloids except mercury (As, Cd, Co, Cr, Cu, Mn, Ni, Pb, Sb, Se, Ti, V, Zn)	<ul style="list-style-type: none"> <li>— Coal and/or lignite</li> <li>— Solid biomass and/or peat</li> <li>— HFO- and/or gas-oil-fired boilers and engines</li> </ul>	All sizes	EN 14385	Once every year <sub>(18)</sub>	BAT 22 BAT 26 BAT 30	
	<ul style="list-style-type: none"> <li>— Waste co-incineration</li> </ul>	< 300 MW <sub>th</sub>	EN 14385	Once every six months <sub>(13)</sub>	BAT 68 BAT 69		
		≥ 300 MW <sub>th</sub>	EN 14385	Once every three months <sub>(19)</sub> <sub>(13)</sub>			
	<ul style="list-style-type: none"> <li>— IGCC plants</li> </ul>	≥ 100 MW <sub>th</sub>	EN 14385	Once every year <sub>(18)</sub>	BAT 75		
	Hg	<ul style="list-style-type: none"> <li>— Coal and/or lignite including waste co-incineration</li> </ul>	< 300 MW <sub>th</sub>	EN 13211	Once every three months <sub>(13)</sub> <sub>(20)</sub>	BAT 23	
			≥ 300 MW <sub>th</sub>	Generic EN standards and EN 14884	Continuous <sub>(16)</sub> <sub>(21)</sub>		
		<ul style="list-style-type: none"> <li>— Solid biomass and/or peat</li> </ul>	All sizes	EN 13211	Once every year <sub>(22)</sub>	BAT 27	
		<ul style="list-style-type: none"> <li>— Waste co-incineration with solid biomass and/or peat</li> </ul>	All sizes	EN 13211	Once every three months <sub>(13)</sub>	BAT 70	
		<ul style="list-style-type: none"> <li>— IGCC plants</li> </ul>	≥ 100 MW <sub>th</sub>	EN 13211	Once every year <sub>(23)</sub>	BAT 75	
	TVOC	<ul style="list-style-type: none"> <li>— HFO- and/or gas-oil-fired engines</li> </ul>	All sizes	EN 12619	Once every six months <sub>(13)</sub>	BAT 33 BAT 59	

BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
		— Process fuels from chemical industry in boilers						
		— Waste co-incineration with coal, lignite, solid biomass and/or peat	All sizes	Generic EN standards	Continuous	BAT 71		
Formaldehyde		— Natural-gas in spark-ignited lean-burn gas and dual fuel engines	All sizes	No EN standard available	Once every year	BAT 45		
CH <sub>4</sub>		— Natural-gas-fired engines	All sizes	EN ISO 25139	Once every year <sup>(24)</sup>	BAT 45		
PCDD/F		— Process fuels from chemical industry in boilers — Waste co-incineration	All sizes	EN 1948-1, EN 1948-2, EN 1948-3	Once every six months <sup>(13)</sup> <sup>(25)</sup>	BAT 59 BAT 71		
5	BAT is to monitor emissions to water from flue-gas treatment with at least the frequency given below and in accordance with EN standards. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.						NA	Not Applicable to the installation as the site does not carry out flue-gas treatment.
	<b>Substance/Parameter</b>		<b>Standard(s)</b>		<b>Minimum monitoring frequency</b>	<b>Monitoring associated with</b>		
Total organic carbon (TOC) <sup>(26)</sup>	EN 1484				Once every month	BAT 15		
Chemical oxygen demand (COD) <sup>(26)</sup>	No EN standard available							
Total suspended solids (TSS)	EN 872							
Fluoride (F <sup>-</sup> )	EN ISO 10304-1							
Sulphate (SO <sub>4</sub> <sup>2-</sup> )	EN ISO 10304-1							
Sulphide, easily released (S <sup>2-</sup> )	No EN standard available							
Sulphite (SO <sub>3</sub> <sup>2-</sup> )	EN ISO 10304-3							
Metals and metalloids	As	Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)						
	Cd							
	Cr							

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																												
	<table border="1"> <tr> <td data-bbox="331 389 595 531"></td> <td data-bbox="595 389 663 416">Cu</td> <td data-bbox="663 389 1025 531"></td> <td data-bbox="1025 389 1267 531"></td> </tr> <tr> <td></td> <td data-bbox="595 416 663 443">Ni</td> <td></td> <td></td> </tr> <tr> <td></td> <td data-bbox="595 443 663 470">Pb</td> <td></td> <td></td> </tr> <tr> <td></td> <td data-bbox="595 470 663 497">Zn</td> <td></td> <td></td> </tr> <tr> <td></td> <td data-bbox="595 497 663 531">Hg</td> <td data-bbox="663 497 1025 531">Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)</td> <td></td> </tr> <tr> <td data-bbox="331 531 595 587">Chloride (Cl<sup>-</sup>)</td> <td></td> <td data-bbox="663 531 1025 587">Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)</td> <td data-bbox="1025 531 1267 587">—</td> </tr> <tr> <td data-bbox="331 587 595 683">Total nitrogen</td> <td></td> <td data-bbox="663 587 1025 683">EN 12260</td> <td data-bbox="1025 587 1267 683">—</td> </tr> </table>		Cu				Ni				Pb				Zn				Hg	Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)		Chloride (Cl <sup>-</sup> )		Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)	—	Total nitrogen		EN 12260	—		
	Cu																														
	Ni																														
	Pb																														
	Zn																														
	Hg	Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)																													
Chloride (Cl <sup>-</sup> )		Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)	—																												
Total nitrogen		EN 12260	—																												
6	<p>In order to improve the general environmental performance of combustion plants and to reduce emissions to air of CO and unburnt substances, BAT is to ensure optimised combustion and to use an appropriate combination of the techniques given below.</p> <table border="1"> <thead> <tr> <th data-bbox="331 794 555 821">Technique</th> <th data-bbox="555 794 994 821">Description</th> <th data-bbox="994 794 1487 821">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="331 821 555 917">a. Fuel blending and mixing</td> <td data-bbox="555 821 994 917">Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type</td> <td data-bbox="994 821 1487 917" rowspan="2">Generally applicable</td> </tr> <tr> <td data-bbox="331 917 555 997">b. Maintenance of the combustion system</td> <td data-bbox="555 917 994 997">Regular planned maintenance according to suppliers' recommendations</td> </tr> <tr> <td data-bbox="331 997 555 1077">c. Advanced control system</td> <td data-bbox="555 997 994 1077">See description in Section 8.1</td> <td data-bbox="994 997 1487 1077">The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> <tr> <td data-bbox="331 1077 555 1173">d. Good design of the combustion equipment</td> <td data-bbox="555 1077 994 1173">Good design of furnace, combustion chambers, burners and associated devices</td> <td data-bbox="994 1077 1487 1173">Generally applicable to new combustion plants</td> </tr> <tr> <td data-bbox="331 1173 555 1332">e. Fuel choice</td> <td data-bbox="555 1173 994 1332">Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used</td> <td data-bbox="994 1173 1487 1332">Applicable within the constraints associated with the availability of suitable types of fuel with a better environmental profile as a whole, which may be impacted by the energy policy of the Member State, or by the integrated site's fuel balance in the case of combustion of industrial process fuels.</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Fuel blending and mixing	Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type	Generally applicable	b. Maintenance of the combustion system	Regular planned maintenance according to suppliers' recommendations	c. Advanced control system	See description in Section 8.1	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system	d. Good design of the combustion equipment	Good design of furnace, combustion chambers, burners and associated devices	Generally applicable to new combustion plants	e. Fuel choice	Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used	Applicable within the constraints associated with the availability of suitable types of fuel with a better environmental profile as a whole, which may be impacted by the energy policy of the Member State, or by the integrated site's fuel balance in the case of combustion of industrial process fuels.	CC	<p>The Operator confirmed that:</p> <p>a) Fuel blending - not applicable</p> <p>b) Maintenance of combustion system - maintenance of the gas turbine is undertaken to maintain environmental performance. This includes camera inspections and combustion tuning, with improvements carried out through a service agreement.</p> <p>c) Advanced control system – the gas turbine is controlled with an engine management system which is maintained through a service agreement.</p> <p>d) Good design of combustion equipment – the gas turbine is fitted with a three stage DLN combustion system to provide</p>											
Technique	Description	Applicability																													
a. Fuel blending and mixing	Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type	Generally applicable																													
b. Maintenance of the combustion system	Regular planned maintenance according to suppliers' recommendations																														
c. Advanced control system	See description in Section 8.1	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system																													
d. Good design of the combustion equipment	Good design of furnace, combustion chambers, burners and associated devices	Generally applicable to new combustion plants																													
e. Fuel choice	Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used	Applicable within the constraints associated with the availability of suitable types of fuel with a better environmental profile as a whole, which may be impacted by the energy policy of the Member State, or by the integrated site's fuel balance in the case of combustion of industrial process fuels.																													

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement			
	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 15%;"></td> <td style="width: 15%;"></td> <td style="width: 70%; padding: 5px;">For existing combustion plants, the type of fuel chosen may be limited by the configuration and the design of the plant</td> </tr> </table>			For existing combustion plants, the type of fuel chosen may be limited by the configuration and the design of the plant		<p>combustion stability and emissions performance.</p> <p>e) Fuel choice – the gas turbine can only operate on natural gas.</p>
		For existing combustion plants, the type of fuel chosen may be limited by the configuration and the design of the plant				
7	<p>In order to reduce emissions of ammonia to air from the use of selective catalytic reduction (SCR) and/or selective non-catalytic reduction (SNCR) for the abatement of NO<sub>x</sub> emissions, BAT is to optimise the design and/or operation of SCR and/or SNCR (e.g. optimised reagent to NO<sub>x</sub> ratio, homogeneous reagent distribution and optimum size of the reagent drops).</p> <p><b>BAT-associated emission levels</b></p> <p>The BAT-associated emission level (BAT-AEL) for emissions of NH<sub>3</sub> to air from the use of SCR and/or SNCR is &lt; 3–10 mg/Nm<sup>3</sup> as a yearly average or average over the sampling period. The lower end of the range can be achieved when using SCR and the upper end of the range can be achieved when using SNCR without wet abatement techniques. In the case of plants combusting biomass and operating at variable loads as well as in the case of engines combusting HFO and/or gas oil, the higher end of the BAT-AEL range is 15 mg/Nm<sup>3</sup>.</p>	NA	Not applicable - no SCR or SNCR on site.			
8	<p>In order to prevent or reduce emissions to air during normal operating conditions, BAT is to ensure, by appropriate design, operation and maintenance, that the emission abatement systems are used at optimal capacity and availability.</p>	NA	<p>Not applicable - no abatement systems are installed.</p> <p>The Operator confirmed that, gas turbine servicing and engine tuning is undertaken. Also, engines are run at full load capacity, therefore most efficient running. They do not run at reduced load.</p>			
9	<p>In order to improve the general environmental performance of combustion and/or gasification plants and to reduce emissions to air, BAT is to include the following elements in the quality assurance/quality control programmes for all the fuels used, as part of the environmental management system (see BAT 1):</p>	CC	<p>The Operator confirmed that:</p> <p>i) and ii) All fuel gas is supplied through the national gas networks. National inventory data is used for</p>			

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																		
	<p>(i) Initial full characterisation of the fuel used including at least the parameters listed below and in accordance with EN standards. ISO, national or other international standards may be used provided they ensure the provision of data of an equivalent scientific quality;</p> <p>(ii) Regular testing of the fuel quality to check that it is consistent with the initial characterisation and according to the plant design specifications. The frequency of testing and the parameters chosen from the table below are based on the variability of the fuel and an assessment of the relevance of pollutant releases (e.g. concentration in fuel, flue-gas treatment employed);</p> <p>(iii) Subsequent adjustment of the plant settings as and when needed and practicable (e.g. integration of the fuel characterisation and control in the advanced control system (see description in Section 8.1)).</p> <p><b>Description</b> Initial characterisation and regular testing of the fuel can be performed by the operator and/or the fuel supplier. If performed by the supplier, the full results are provided to the operator in the form of a product (fuel) supplier specification and/or guarantee.</p> <table border="1" data-bbox="322 754 1494 1374"> <thead> <tr> <th data-bbox="322 754 712 788">Fuel(s)</th> <th data-bbox="712 754 1494 788">Substances/Parameters subject to characterisation</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 788 712 994" rowspan="4">Biomass/peat</td> <td data-bbox="712 788 1494 831">— LHV</td> </tr> <tr> <td data-bbox="712 831 1494 874">— moisture</td> </tr> <tr> <td data-bbox="712 874 1494 917">— Ash</td> </tr> <tr> <td data-bbox="712 917 1494 994">— C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn)</td> </tr> <tr> <td data-bbox="322 994 712 1206" rowspan="4">Coal/lignite</td> <td data-bbox="712 994 1494 1037">— LHV</td> </tr> <tr> <td data-bbox="712 1037 1494 1080">— Moisture</td> </tr> <tr> <td data-bbox="712 1080 1494 1123">— Volatiles, ash, fixed carbon, C, H, N, O, S</td> </tr> <tr> <td data-bbox="712 1123 1494 1206">— Br, Cl, F — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Ti, V, Zn)</td> </tr> <tr> <td data-bbox="322 1206 712 1291" rowspan="2">HFO</td> <td data-bbox="712 1206 1494 1249">— Ash</td> </tr> <tr> <td data-bbox="712 1249 1494 1291">— C, S, N, Ni, V</td> </tr> <tr> <td data-bbox="322 1291 712 1374" rowspan="2">Gas oil</td> <td data-bbox="712 1291 1494 1334">— Ash</td> </tr> <tr> <td data-bbox="712 1334 1494 1374">— N, C, S</td> </tr> </tbody> </table>	Fuel(s)	Substances/Parameters subject to characterisation	Biomass/peat	— LHV	— moisture	— Ash	— C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn)	Coal/lignite	— LHV	— Moisture	— Volatiles, ash, fixed carbon, C, H, N, O, S	— Br, Cl, F — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Ti, V, Zn)	HFO	— Ash	— C, S, N, Ni, V	Gas oil	— Ash	— N, C, S		<p>quality measurement. There are no alternative fuels for the gas turbine.</p> <p>iii) Gas turbine engine tuning is carried out by the O &amp; M service provider.</p> <p>We consider that for plants which burn natural gas from the National Grid as a fuel that it is not necessary for the operator to replicate the testing carried out by the National Grid</p>
Fuel(s)	Substances/Parameters subject to characterisation																				
Biomass/peat	— LHV																				
	— moisture																				
	— Ash																				
	— C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn)																				
Coal/lignite	— LHV																				
	— Moisture																				
	— Volatiles, ash, fixed carbon, C, H, N, O, S																				
	— Br, Cl, F — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Ti, V, Zn)																				
HFO	— Ash																				
	— C, S, N, Ni, V																				
Gas oil	— Ash																				
	— N, C, S																				

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement								
	<table border="1"> <tr> <td data-bbox="322 384 712 469">Natural gas</td> <td data-bbox="712 384 1491 469"> <ul style="list-style-type: none"> <li>— LHV</li> <li>— CH<sub>4</sub>, C<sub>2</sub>H<sub>6</sub>, C<sub>3</sub>, C<sub>4+</sub>, CO<sub>2</sub>, N<sub>2</sub>, Wobbe index</li> </ul> </td> </tr> <tr> <td data-bbox="322 469 712 553">Process fuels from the chemical industry<sup>[27]</sup></td> <td data-bbox="712 469 1491 553"> <ul style="list-style-type: none"> <li>— Br, C, Cl, F, H, N, O, S</li> <li>— Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)</li> </ul> </td> </tr> <tr> <td data-bbox="322 553 712 622">Iron and steel process gases</td> <td data-bbox="712 553 1491 622"> <ul style="list-style-type: none"> <li>— LHV, CH<sub>4</sub> (for COG), C<sub>x</sub>H<sub>y</sub> (for COG), CO<sub>2</sub>, H<sub>2</sub>, N<sub>2</sub>, total sulphur, dust, Wobbe index</li> </ul> </td> </tr> <tr> <td data-bbox="322 622 712 777">Waste<sup>[28]</sup></td> <td data-bbox="712 622 1491 777"> <ul style="list-style-type: none"> <li>— LHV</li> <li>— Moisture</li> <li>— Volatiles, ash, Br, C, Cl, F, H, N, O, S</li> <li>— Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)</li> </ul> </td> </tr> </table>	Natural gas	<ul style="list-style-type: none"> <li>— LHV</li> <li>— CH<sub>4</sub>, C<sub>2</sub>H<sub>6</sub>, C<sub>3</sub>, C<sub>4+</sub>, CO<sub>2</sub>, N<sub>2</sub>, Wobbe index</li> </ul>	Process fuels from the chemical industry <sup>[27]</sup>	<ul style="list-style-type: none"> <li>— Br, C, Cl, F, H, N, O, S</li> <li>— Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)</li> </ul>	Iron and steel process gases	<ul style="list-style-type: none"> <li>— LHV, CH<sub>4</sub> (for COG), C<sub>x</sub>H<sub>y</sub> (for COG), CO<sub>2</sub>, H<sub>2</sub>, N<sub>2</sub>, total sulphur, dust, Wobbe index</li> </ul>	Waste <sup>[28]</sup>	<ul style="list-style-type: none"> <li>— LHV</li> <li>— Moisture</li> <li>— Volatiles, ash, Br, C, Cl, F, H, N, O, S</li> <li>— Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)</li> </ul>		
Natural gas	<ul style="list-style-type: none"> <li>— LHV</li> <li>— CH<sub>4</sub>, C<sub>2</sub>H<sub>6</sub>, C<sub>3</sub>, C<sub>4+</sub>, CO<sub>2</sub>, N<sub>2</sub>, Wobbe index</li> </ul>										
Process fuels from the chemical industry <sup>[27]</sup>	<ul style="list-style-type: none"> <li>— Br, C, Cl, F, H, N, O, S</li> <li>— Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)</li> </ul>										
Iron and steel process gases	<ul style="list-style-type: none"> <li>— LHV, CH<sub>4</sub> (for COG), C<sub>x</sub>H<sub>y</sub> (for COG), CO<sub>2</sub>, H<sub>2</sub>, N<sub>2</sub>, total sulphur, dust, Wobbe index</li> </ul>										
Waste <sup>[28]</sup>	<ul style="list-style-type: none"> <li>— LHV</li> <li>— Moisture</li> <li>— Volatiles, ash, Br, C, Cl, F, H, N, O, S</li> <li>— Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)</li> </ul>										
10	<p>In order to reduce emissions to air and/or to water during other than normal operating conditions (OTNOC), BAT is to set up and implement a management plan as part of the environmental management system (see BAT 1), commensurate with the relevance of potential pollutant releases, that includes the following elements:</p> <ul style="list-style-type: none"> <li>— appropriate design of the systems considered relevant in causing OTNOC that may have an impact on emissions to air, water and/or soil (e.g. low-load design concepts for reducing the minimum start-up and shutdown loads for stable generation in gas turbines),</li> <li>— set-up and implementation of a specific preventive maintenance plan for these relevant systems,</li> <li>— review and recording of emissions caused by OTNOC and associated circumstances and implementation of corrective actions if necessary,</li> <li>— periodic assessment of the overall emissions during OTNOC (e.g. frequency of events, duration, emissions quantification/estimation) and implementation of corrective actions if necessary.</li> </ul>	CC	<p>The OCGT is shut down for investigation in the event of abnormal emissions.</p> <p>Operation of the Gas Turbine is designed to keep start up times and to engine testing durations to a minimum.</p> <p>The energy supply contracts are for peaking operations, which reduces operational hours.</p>								
11	<p>BAT is to appropriately monitor emissions to air and/or to water during OTNOC.</p> <p><b>Description</b></p> <p>The monitoring can be carried out by direct measurement of emissions or by monitoring of surrogate parameters if this proves to be of equal or better scientific quality than the direct measurement of emissions. Emissions during start-up and shutdown (SU/SD) may be assessed based on a detailed emission measurement carried out for a typical SU/SD procedure at least once every year, and using the results of this measurement to estimate the emissions for each and every SU/SD throughout the year.</p>	CC	<p>The OCGT is shut down for investigation in the event of abnormal emissions.</p> <p>The plant is not operated when the CEMS is out of service as no</p>								

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																																	
			alternative method of analysis is available.																																	
12	<p>In order to increase the energy efficiency of combustion, gasification and/or IGCC units operated <math>\geq 1\,500</math> h/yr, BAT is to use an appropriate combination of the techniques given below.</p> <table border="1" data-bbox="320 512 1494 1342"> <thead> <tr> <th data-bbox="320 512 365 544"></th> <th data-bbox="365 512 577 544">Technique</th> <th data-bbox="577 512 1059 544">Description</th> <th data-bbox="1059 512 1494 544">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="320 544 365 655">a.</td> <td data-bbox="365 544 577 655">Combustion optimisation</td> <td data-bbox="577 544 1059 655">See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues</td> <td data-bbox="1059 544 1494 655" rowspan="4">Generally applicable</td> </tr> <tr> <td data-bbox="320 655 365 791">b.</td> <td data-bbox="365 655 577 791">Optimisation of the working medium conditions</td> <td data-bbox="577 655 1059 791">Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO<sub>x</sub> emissions or the characteristics of energy demanded</td> </tr> <tr> <td data-bbox="320 791 365 903">c.</td> <td data-bbox="365 791 577 903">Optimisation of the steam cycle</td> <td data-bbox="577 791 1059 903">Operate with lower turbine exhaust pressure by utilisation of the lowest possible temperature of the condenser cooling water, within the design conditions</td> </tr> <tr> <td data-bbox="320 903 365 959">d.</td> <td data-bbox="365 903 577 959">Minimisation of energy consumption</td> <td data-bbox="577 903 1059 959">Minimising the internal energy consumption (e.g. greater efficiency of the feed-water pump)</td> </tr> <tr> <td data-bbox="320 959 365 1038">e.</td> <td data-bbox="365 959 577 1038">Preheating of combustion air</td> <td data-bbox="577 959 1059 1038">Reuse of part of the heat recovered from the combustion flue-gas to preheat the air used in combustion</td> <td data-bbox="1059 959 1494 1038">Generally applicable within the constraints related to the need to control NO<sub>x</sub> emissions</td> </tr> <tr> <td data-bbox="320 1038 365 1126">f.</td> <td data-bbox="365 1038 577 1126">Fuel preheating</td> <td data-bbox="577 1038 1059 1126">Preheating of fuel using recovered heat</td> <td data-bbox="1059 1038 1494 1126">Generally applicable within the constraints associated with the boiler design and the need to control NO<sub>x</sub> emissions</td> </tr> <tr> <td data-bbox="320 1126 365 1238">g.</td> <td data-bbox="365 1126 577 1238">Advanced control system</td> <td data-bbox="577 1126 1059 1238">See description in Section 8.2. Computerised control of the main combustion parameters enables the combustion efficiency to be improved</td> <td data-bbox="1059 1126 1494 1238">Generally applicable to new units. The applicability to old units may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> <tr> <td data-bbox="320 1238 365 1342">h.</td> <td data-bbox="365 1238 577 1342">Feed-water preheating using recovered heat</td> <td data-bbox="577 1238 1059 1342">Preheat water coming out of the steam condenser with recovered heat, before reusing it in the boiler</td> <td data-bbox="1059 1238 1494 1342">Only applicable to steam circuits and not to hot boilers. Applicability to existing units may be limited due to constraints associated with the plant</td> </tr> </tbody> </table>		Technique	Description	Applicability	a.	Combustion optimisation	See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues	Generally applicable	b.	Optimisation of the working medium conditions	Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO <sub>x</sub> emissions or the characteristics of energy demanded	c.	Optimisation of the steam cycle	Operate with lower turbine exhaust pressure by utilisation of the lowest possible temperature of the condenser cooling water, within the design conditions	d.	Minimisation of energy consumption	Minimising the internal energy consumption (e.g. greater efficiency of the feed-water pump)	e.	Preheating of combustion air	Reuse of part of the heat recovered from the combustion flue-gas to preheat the air used in combustion	Generally applicable within the constraints related to the need to control NO <sub>x</sub> emissions	f.	Fuel preheating	Preheating of fuel using recovered heat	Generally applicable within the constraints associated with the boiler design and the need to control NO <sub>x</sub> emissions	g.	Advanced control system	See description in Section 8.2. Computerised control of the main combustion parameters enables the combustion efficiency to be improved	Generally applicable to new units. The applicability to old units may be constrained by the need to retrofit the combustion system and/or control command system	h.	Feed-water preheating using recovered heat	Preheat water coming out of the steam condenser with recovered heat, before reusing it in the boiler	Only applicable to steam circuits and not to hot boilers. Applicability to existing units may be limited due to constraints associated with the plant	CC	<p>The Operator confirmed that:</p> <p>a) Combustion optimisation - gas turbine performance is monitored by the O &amp; M provider who recommend any actions to maintain / improve performance.</p> <p>b) Optimisation of working medium conditions – the gas turbine engine is controlled with an engine management system which is maintained through a service agreement.</p> <p>d) Minimisation of energy consumption - routine checks of the fuel usage are carried out to compare historic data to measure gas turbine performance technically and commercially.</p> <p>p) Minimisation of heat loss - gas fuel pipe-work is insulated after the gas compression.</p> <p>q) Advanced materials – the gas turbine is engineered from aero derivative based technology and uses the same materials and technologies.</p>
	Technique	Description	Applicability																																	
a.	Combustion optimisation	See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues	Generally applicable																																	
b.	Optimisation of the working medium conditions	Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO <sub>x</sub> emissions or the characteristics of energy demanded																																		
c.	Optimisation of the steam cycle	Operate with lower turbine exhaust pressure by utilisation of the lowest possible temperature of the condenser cooling water, within the design conditions																																		
d.	Minimisation of energy consumption	Minimising the internal energy consumption (e.g. greater efficiency of the feed-water pump)																																		
e.	Preheating of combustion air	Reuse of part of the heat recovered from the combustion flue-gas to preheat the air used in combustion	Generally applicable within the constraints related to the need to control NO <sub>x</sub> emissions																																	
f.	Fuel preheating	Preheating of fuel using recovered heat	Generally applicable within the constraints associated with the boiler design and the need to control NO <sub>x</sub> emissions																																	
g.	Advanced control system	See description in Section 8.2. Computerised control of the main combustion parameters enables the combustion efficiency to be improved	Generally applicable to new units. The applicability to old units may be constrained by the need to retrofit the combustion system and/or control command system																																	
h.	Feed-water preheating using recovered heat	Preheat water coming out of the steam condenser with recovered heat, before reusing it in the boiler	Only applicable to steam circuits and not to hot boilers. Applicability to existing units may be limited due to constraints associated with the plant																																	

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
				configuration and the amount of recoverable heat	<p>The site operates in open cycle mode only and is not capable of CCGT/ CHP operations so some techniques do not apply.</p> <p>We agree with the Operator's stated compliance that an appropriate combination of techniques are being used.</p>
i.	Heat recovery by cogeneration (CHP)	Recovery of heat (mainly from the steam system) for producing hot water/steam to be used in industrial processes/activities or in a public network for district heating. Additional heat recovery is possible from: <ul style="list-style-type: none"> <li>— flue-gas</li> <li>— grate cooling</li> <li>— circulating fluidised bed</li> </ul>	Applicable within the constraints associated with the local heat and power demand. The applicability may be limited in the case of gas compressors with an unpredictable operational heat profile		
j.	CHP readiness	See description in Section 8.2.	Only applicable to new units where there is a realistic potential for the future use of heat in the vicinity of the unit		
k.	Flue-gas condenser	See description in Section 8.2.	Generally applicable to CHP units provided there is enough demand for low-temperature heat		
l.	Heat accumulation	Heat accumulation storage in CHP mode	Only applicable to CHP plants. The applicability may be limited in the case of low heat load demand		
m.	Wet stack	See description in Section 8.2.	Generally applicable to new and existing units fitted with wet FGD		
n.	Cooling tower discharge	The release of emissions to air through a cooling tower and not via a dedicated stack	Only applicable to units fitted with wet FGD where reheating of the flue-gas is necessary before release, and where the unit cooling system is a cooling tower		
o.	Fuel pre-drying	The reduction of fuel moisture content before combustion to improve combustion conditions	Applicable to the combustion of biomass and/or peat within the constraints associated with spontaneous combustion risks (e.g. the moisture content of peat is kept above 40 % throughout the delivery chain). The retrofit of existing plants may be restricted by the extra calorific value that can be obtained from the drying operation and by the limited retrofit possibilities offered by some boiler designs or plant configurations		



BAT Concn. Number	Summary of BAT Conclusion requirement				Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	p.	Minimisation of heat losses	Minimising residual heat losses, e.g. those that occur via the slag or those that can be reduced by insulating radiating sources	Only applicable to solid-fuel-fired combustion units and to gasification/IGCC units		
	q.	Advanced materials	Use of advanced materials proven to be capable of withstanding high operating temperatures and pressures and thus to achieve increased steam/combustion process efficiencies	Only applicable to new plants		
	r.	Steam turbine upgrades	This includes techniques such as increasing the temperature and pressure of medium-pressure steam, addition of a low-pressure turbine, and modifications to the geometry of the turbine rotor blades	The applicability may be restricted by demand, steam conditions and/or limited plant lifetime		
	s.	Supercritical and ultra-supercritical steam conditions	Use of a steam circuit, including steam reheating systems, in which steam can reach pressures above 220,6 bar and temperatures above 374 °C in the case of supercritical conditions, and above 250 – 300 bar and temperatures above 580 – 600 °C in the case of ultra-supercritical conditions	Only applicable to new units of $\geq 600 \text{ MW}_{\text{th}}$ operated $> 4\,000 \text{ h/yr}$ . Not applicable when the purpose of the unit is to produce low steam temperatures and/or pressures in process industries. Not applicable to gas turbines and engines generating steam in CHP mode. For units combusting biomass, the applicability may be constrained by high-temperature corrosion in the case of certain biomasses		
13	In order to reduce water usage and the volume of contaminated waste water discharged, BAT is to use one or both of the techniques given below.				CC	The operator has confirmed the following: Waste Water volumes are significantly reduced due to open cycle operation only. Steam cycle plant has been mothballed since 2013. Contents of plant blind sumps and interceptors are removed on alarm, tankered off site as required for recycling. Volume
	<b>Technique</b>	<b>Description</b>	<b>Applicability</b>			
a.	Water recycling	Residual aqueous streams, including run-off water, from the plant are reused for other purposes. The degree of recycling is limited by the quality requirements of the recipient water stream and the water balance of the plant	Not applicable to waste water from cooling systems when water treatment chemicals and/or high concentrations of salts from seawater are present			
b.	Dry bottom ash handling	Dry, hot bottom ash falls from the furnace onto a mechanical conveyor system and is cooled down by ambient air. No water is used in the process.	Only applicable to plants combusting solid fuels. There may be technical restrictions that prevent retrofitting to existing combustion plants			

BAT Concn. Numbe r	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
			<p>about 4 tonnes per year is collected.</p> <p>Station Discharge Sump: Cooling water purge water or drainage are discharged via station discharge sump to the Rolls Royce host site waste effluent systems.</p> <p>Oil contaminated surface drains go to the Station discharge Sump via an oil interceptor</p> <p>The operator provided a revised site map on the 22/06/2020 showing the location of the interceptors. Confirming that cooling water purge water or drainage are discharged via station discharge sump to the Rolls Royce host site waste effluent systems. Oil contaminated surface drains go to the Station Discharge Sump via an oil interceptor, S1</p>
14	<p>In order to prevent the contamination of uncontaminated waste water and to reduce emissions to water, BAT is to segregate waste water streams and to treat them separately, depending on the pollutant content.</p> <p><b>Description</b> Waste water streams that are typically segregated and treated include surface run-off water, cooling water, and waste water from flue-gas treatment.</p> <p><b>Applicability</b></p>	CC	<p>The operator has confirmed that foul Water is piped off site through local sewage network, via the Rolls Royce main site system.</p>

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																																							
	The applicability may be restricted in the case of existing plants due to the configuration of the drainage systems.		Rain water run off is via an interceptor to site outlet point and all surface water drainage systems are identified by colour on site.																																							
15	<p>In order to reduce emissions to water from flue-gas treatment, BAT is to use an appropriate combination of the techniques given below, and to use secondary techniques as close as possible to the source in order to avoid dilution.</p> <table border="1" data-bbox="320 635 1494 1369"> <thead> <tr> <th data-bbox="320 635 712 699">Technique</th> <th data-bbox="712 635 1025 699">Typical pollutants prevented/abated</th> <th data-bbox="1025 635 1494 699">Applicability</th> </tr> </thead> <tbody> <tr> <td colspan="3" data-bbox="320 699 1494 730" style="text-align: center;"><b>Primary techniques</b></td> </tr> <tr> <td data-bbox="320 730 365 818">a.</td> <td data-bbox="365 730 712 818">Optimised combustion (see BAT 6) and flue-gas treatment systems (e.g. SCR/SNCR, see BAT 7)</td> <td data-bbox="712 730 1025 818">Organic compounds, ammonia (NH<sub>3</sub>)</td> </tr> <tr> <td colspan="3" data-bbox="320 818 1494 850" style="text-align: center;"><b>Secondary techniques <sup>(29)</sup></b></td> </tr> <tr> <td data-bbox="320 850 365 914">b.</td> <td data-bbox="365 850 712 914">Adsorption on activated carbon</td> <td data-bbox="712 850 1025 914">Organic compounds, mercury (Hg)</td> </tr> <tr> <td data-bbox="320 914 365 1050">c.</td> <td data-bbox="365 914 712 1050">Aerobic biological treatment</td> <td data-bbox="712 914 1025 1050">Biodegradable organic compounds, ammonium (NH<sub>4</sub><sup>+</sup>)</td> </tr> <tr> <td data-bbox="320 1050 365 1114">d.</td> <td data-bbox="365 1050 712 1114">Anoxic/anaerobic biological treatment</td> <td data-bbox="712 1050 1025 1114">Mercury (Hg), nitrate (NO<sub>3</sub><sup>-</sup>), nitrite (NO<sub>2</sub><sup>-</sup>)</td> </tr> <tr> <td data-bbox="320 1114 365 1145">e.</td> <td data-bbox="365 1114 712 1145">Coagulation and flocculation</td> <td data-bbox="712 1114 1025 1145">Suspended solids</td> </tr> <tr> <td data-bbox="320 1145 365 1201">f.</td> <td data-bbox="365 1145 712 1201">Crystallisation</td> <td data-bbox="712 1145 1025 1201">Metals and metalloids, sulphate (SO<sub>4</sub><sup>2-</sup>), fluoride (F<sup>-</sup>)</td> </tr> <tr> <td data-bbox="320 1201 365 1265">g.</td> <td data-bbox="365 1201 712 1265">Filtration (e.g. sand filtration, microfiltration, ultrafiltration)</td> <td data-bbox="712 1201 1025 1265">Suspended solids, metals</td> </tr> <tr> <td data-bbox="320 1265 365 1297">h.</td> <td data-bbox="365 1265 712 1297">Flotation</td> <td data-bbox="712 1265 1025 1297">Suspended solids, free oil</td> </tr> <tr> <td data-bbox="320 1297 365 1329">i.</td> <td data-bbox="365 1297 712 1329">Ion exchange</td> <td data-bbox="712 1297 1025 1329">Metals</td> </tr> <tr> <td data-bbox="320 1329 365 1369">j.</td> <td data-bbox="365 1329 712 1369">Neutralisation</td> <td data-bbox="712 1329 1025 1369">Acids, alkalis</td> </tr> </tbody> </table>	Technique	Typical pollutants prevented/abated	Applicability	<b>Primary techniques</b>			a.	Optimised combustion (see BAT 6) and flue-gas treatment systems (e.g. SCR/SNCR, see BAT 7)	Organic compounds, ammonia (NH <sub>3</sub> )	<b>Secondary techniques <sup>(29)</sup></b>			b.	Adsorption on activated carbon	Organic compounds, mercury (Hg)	c.	Aerobic biological treatment	Biodegradable organic compounds, ammonium (NH <sub>4</sub> <sup>+</sup> )	d.	Anoxic/anaerobic biological treatment	Mercury (Hg), nitrate (NO <sub>3</sub> <sup>-</sup> ), nitrite (NO <sub>2</sub> <sup>-</sup> )	e.	Coagulation and flocculation	Suspended solids	f.	Crystallisation	Metals and metalloids, sulphate (SO <sub>4</sub> <sup>2-</sup> ), fluoride (F <sup>-</sup> )	g.	Filtration (e.g. sand filtration, microfiltration, ultrafiltration)	Suspended solids, metals	h.	Flotation	Suspended solids, free oil	i.	Ion exchange	Metals	j.	Neutralisation	Acids, alkalis	NA	Not Applicable to the installation. No flue gas treatment undertaken
Technique	Typical pollutants prevented/abated	Applicability																																								
<b>Primary techniques</b>																																										
a.	Optimised combustion (see BAT 6) and flue-gas treatment systems (e.g. SCR/SNCR, see BAT 7)	Organic compounds, ammonia (NH <sub>3</sub> )																																								
<b>Secondary techniques <sup>(29)</sup></b>																																										
b.	Adsorption on activated carbon	Organic compounds, mercury (Hg)																																								
c.	Aerobic biological treatment	Biodegradable organic compounds, ammonium (NH <sub>4</sub> <sup>+</sup> )																																								
d.	Anoxic/anaerobic biological treatment	Mercury (Hg), nitrate (NO <sub>3</sub> <sup>-</sup> ), nitrite (NO <sub>2</sub> <sup>-</sup> )																																								
e.	Coagulation and flocculation	Suspended solids																																								
f.	Crystallisation	Metals and metalloids, sulphate (SO <sub>4</sub> <sup>2-</sup> ), fluoride (F <sup>-</sup> )																																								
g.	Filtration (e.g. sand filtration, microfiltration, ultrafiltration)	Suspended solids, metals																																								
h.	Flotation	Suspended solids, free oil																																								
i.	Ion exchange	Metals																																								
j.	Neutralisation	Acids, alkalis																																								

BAT Concn. Number	Summary of BAT Conclusion requirement				Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	k.	Oxidation	Sulphide (S <sup>2-</sup> ), sulphite (SO <sub>3</sub> <sup>2-</sup> )	Generally applicable		
	l.	Precipitation	Metals and metalloids, sulphate (SO <sub>4</sub> <sup>2-</sup> ), fluoride (F <sup>-</sup> )	Generally applicable		
	m.	Sedimentation	Suspended solids	Generally applicable		
	n.	Stripping	Ammonia (NH <sub>3</sub> )	Generally applicable		
	The BAT-AELs refer to direct discharges to a receiving water body at the point where the emission leaves the installation.					
	<b>BAT-AELs for direct discharges to a receiving water body from flue-gas treatment</b>					
	<b>Substance/Parameter</b>		<b>BAT-AELs</b>			
			<b>Daily average</b>			
	Total organic carbon (TOC)		20–50 mg/l <sup>(30)</sup> <sup>(31)</sup> <sup>(32)</sup>			
	Chemical oxygen demand (COD)		60–150 mg/l <sup>(30)</sup> <sup>(31)</sup> <sup>(32)</sup>			
	Total suspended solids (TSS)		10–30 mg/l			
	Fluoride (F <sup>-</sup> )		10–25 mg/l <sup>(32)</sup>			
	Sulphate (SO <sub>4</sub> <sup>2-</sup> )		1,3–2,0 g/l <sup>(32)</sup> <sup>(33)</sup> <sup>(34)</sup> <sup>(35)</sup>			
	Sulphide (S <sup>2-</sup> ), easily released		0,1–0,2 mg/l <sup>(32)</sup>			
	Sulphite (SO <sub>3</sub> <sup>2-</sup> )		1–20 mg/l <sup>(32)</sup>			
	Metals and metalloids		As	10–50 µg/l		
			Cd	2–5 µg/l		
			Cr	10–50 µg/l		
			Cu	10–50 µg/l		
			Hg	0,2–3 µg/l		
			Ni	10–50 µg/l		
			Pb	10–20 µg/l		
			Zn	50–200 µg/l		
16	<p>In order to reduce the quantity of waste sent for disposal from the combustion and/or gasification process and abatement techniques, BAT is to organise operations so as to maximise, in order of priority and taking into account life-cycle thinking:</p> <p>(a) waste prevention, e.g. maximise the proportion of residues which arise as by-products;</p>				CC	<p>Operator confirmed the following:</p> <p>Recycling is undertaken where possible via recycling processes with contractors. Volumes of</p>

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement															
	<p>(b) waste preparation for reuse, e.g. according to the specific requested quality criteria;</p> <p>(c) waste recycling;</p> <p>(d) other waste recovery (e.g. energy recovery),</p> <p>by implementing an appropriate combination of techniques such as:</p> <table border="1" data-bbox="322 528 1496 1123"> <thead> <tr> <th data-bbox="322 528 573 560">Technique</th> <th data-bbox="573 528 1081 560">Description</th> <th data-bbox="1081 528 1496 560">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 560 573 719">a. Generation of gypsum as a by-product</td> <td data-bbox="573 560 1081 719">Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g. as raw material in the plasterboard industry). The quality of limestone used in the wet FGD influences the purity of the gypsum produced</td> <td data-bbox="1081 560 1496 719">Generally applicable within the constraints associated with the required gypsum quality, the health requirements associated to each specific use, and by the market conditions</td> </tr> <tr> <td data-bbox="322 719 573 855">b. Recycling or recovery of residues in the construction sector</td> <td data-bbox="573 719 1081 855">Recycling or recovery of residues (e.g. from semi-dry desulphurisation processes, fly ash, bottom ash) as a construction material (e.g. in road building, to replace sand in concrete production, or in the cement industry)</td> <td data-bbox="1081 719 1496 855">Generally applicable within the constraints associated with the required material quality (e.g. physical properties, content of harmful substances) associated to each specific use, and by the market conditions</td> </tr> <tr> <td data-bbox="322 855 573 963">c. Energy recovery by using waste in the fuel mix</td> <td data-bbox="573 855 1081 963">The residual energy content of carbon-rich ash and sludges generated by the combustion of coal, lignite, heavy fuel oil, peat or biomass can be recovered for example by mixing with the fuel</td> <td data-bbox="1081 855 1496 963">Generally applicable where plants can accept waste in the fuel mix and are technically able to feed the fuels into the combustion chamber</td> </tr> <tr> <td data-bbox="322 963 573 1123">d. Preparation of spent catalyst for reuse</td> <td data-bbox="573 963 1081 1123">Preparation of catalyst for reuse (e.g. up to four times for SCR catalysts) restores some or all of the original performance, extending the service life of the catalyst to several decades. Preparation of spent catalyst for reuse is integrated in a catalyst management scheme</td> <td data-bbox="1081 963 1496 1123">The applicability may be limited by the mechanical condition of the catalyst and the required performance with respect to controlling NO<sub>x</sub> and NH<sub>3</sub> emissions</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Generation of gypsum as a by-product	Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g. as raw material in the plasterboard industry). The quality of limestone used in the wet FGD influences the purity of the gypsum produced	Generally applicable within the constraints associated with the required gypsum quality, the health requirements associated to each specific use, and by the market conditions	b. Recycling or recovery of residues in the construction sector	Recycling or recovery of residues (e.g. from semi-dry desulphurisation processes, fly ash, bottom ash) as a construction material (e.g. in road building, to replace sand in concrete production, or in the cement industry)	Generally applicable within the constraints associated with the required material quality (e.g. physical properties, content of harmful substances) associated to each specific use, and by the market conditions	c. Energy recovery by using waste in the fuel mix	The residual energy content of carbon-rich ash and sludges generated by the combustion of coal, lignite, heavy fuel oil, peat or biomass can be recovered for example by mixing with the fuel	Generally applicable where plants can accept waste in the fuel mix and are technically able to feed the fuels into the combustion chamber	d. Preparation of spent catalyst for reuse	Preparation of catalyst for reuse (e.g. up to four times for SCR catalysts) restores some or all of the original performance, extending the service life of the catalyst to several decades. Preparation of spent catalyst for reuse is integrated in a catalyst management scheme	The applicability may be limited by the mechanical condition of the catalyst and the required performance with respect to controlling NO <sub>x</sub> and NH <sub>3</sub> emissions		waste are very low due to nature and activity levels on site.
Technique	Description	Applicability																
a. Generation of gypsum as a by-product	Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g. as raw material in the plasterboard industry). The quality of limestone used in the wet FGD influences the purity of the gypsum produced	Generally applicable within the constraints associated with the required gypsum quality, the health requirements associated to each specific use, and by the market conditions																
b. Recycling or recovery of residues in the construction sector	Recycling or recovery of residues (e.g. from semi-dry desulphurisation processes, fly ash, bottom ash) as a construction material (e.g. in road building, to replace sand in concrete production, or in the cement industry)	Generally applicable within the constraints associated with the required material quality (e.g. physical properties, content of harmful substances) associated to each specific use, and by the market conditions																
c. Energy recovery by using waste in the fuel mix	The residual energy content of carbon-rich ash and sludges generated by the combustion of coal, lignite, heavy fuel oil, peat or biomass can be recovered for example by mixing with the fuel	Generally applicable where plants can accept waste in the fuel mix and are technically able to feed the fuels into the combustion chamber																
d. Preparation of spent catalyst for reuse	Preparation of catalyst for reuse (e.g. up to four times for SCR catalysts) restores some or all of the original performance, extending the service life of the catalyst to several decades. Preparation of spent catalyst for reuse is integrated in a catalyst management scheme	The applicability may be limited by the mechanical condition of the catalyst and the required performance with respect to controlling NO <sub>x</sub> and NH <sub>3</sub> emissions																
17	<p>In order to reduce noise emissions, BAT is to use one or a combination of the techniques given below.</p> <table border="1" data-bbox="322 1166 1496 1362"> <thead> <tr> <th data-bbox="322 1166 573 1198">Technique</th> <th data-bbox="573 1166 1081 1198">Description</th> <th data-bbox="1081 1166 1496 1198">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 1198 573 1362">a. Operational measures</td> <td data-bbox="573 1198 1081 1362">           These include:           <ul style="list-style-type: none"> <li>— improved inspection and maintenance of equipment</li> <li>— closing of doors and windows of enclosed areas, if possible</li> </ul> </td> <td data-bbox="1081 1198 1496 1362">Generally applicable</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Operational measures	These include: <ul style="list-style-type: none"> <li>— improved inspection and maintenance of equipment</li> <li>— closing of doors and windows of enclosed areas, if possible</li> </ul>	Generally applicable	CC	<p>The Operator confirmed that the following steps are taken to control/ reduce noise emissions:</p> <ul style="list-style-type: none"> <li>- Maintaining site noise prevention devices / sound proofing.</li> <li>- Low levels of operating hours during the year.</li> </ul>									
Technique	Description	Applicability																
a. Operational measures	These include: <ul style="list-style-type: none"> <li>— improved inspection and maintenance of equipment</li> <li>— closing of doors and windows of enclosed areas, if possible</li> </ul>	Generally applicable																

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement						
		<ul style="list-style-type: none"> <li>— equipment operated by experienced staff</li> <li>— avoidance of noisy activities at night, if possible</li> <li>— provisions for noise control during maintenance activities</li> </ul>			<ul style="list-style-type: none"> <li>- Regular maintenance of plant.</li> <li>- The plant is as design and operated remotely with no new plant items requiring new noise assessments.</li> <li>- O &amp; M plan noise surveys to check against historic levels.</li> </ul>						
	b. Low-noise equipment	This potentially includes compressors, pumps and disks	Generally applicable when the equipment is new or replaced								
	c. Noise attenuation	Noise propagation can be reduced by inserting obstacles between the emitter and the receiver. Appropriate obstacles include protection walls, embankments and buildings	Generally applicable to new plants. In the case of existing plants, the insertion of obstacles may be restricted by lack of space								
	d. Noise-control equipment	This includes: <ul style="list-style-type: none"> <li>— noise-reducers</li> <li>— equipment insulation</li> <li>— enclosure of noisy equipment</li> <li>— soundproofing of buildings</li> </ul>	The applicability may be restricted by lack of space								
	e. Appropriate location of equipment and buildings	Noise levels can be reduced by increasing the distance between the emitter and the receiver and by using buildings as noise screens	Generally applicable to new plant								
<b>Combustion of gaseous fuels</b>											
40	In order to increase the energy efficiency of natural gas combustion, BAT is to use an appropriate combination of the techniques given in BAT 12 and below.			CC	<p>The operator confirmed the following:</p> <p>The station uses techniques a, b, d, p and q given in BAT 12. See above for further details.</p> <p>The plant only operates as an OCGT, during the permit review, we have introduced a limit on operating hours in line with our guidance 'BAT for Balancing</p>						
	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 15%;">Technique</th> <th style="width: 25%;">Description</th> <th style="width: 60%;">Applicability</th> </tr> </thead> <tbody> <tr> <td>a. Combined cycle</td> <td>See description in Section 8.2</td> <td>           Generally applicable to new gas turbines and engines except when operated &lt; 1 500 h/yr.            Applicable to existing gas turbines and engines within the constraints associated with the steam cycle design and the space availability.            Not applicable to existing gas turbines and engines operated &lt; 1 500 h/yr.            Not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns.            Not applicable to boilers         </td> </tr> </tbody> </table>	Technique	Description			Applicability	a. Combined cycle	See description in Section 8.2	Generally applicable to new gas turbines and engines except when operated < 1 500 h/yr. Applicable to existing gas turbines and engines within the constraints associated with the steam cycle design and the space availability. Not applicable to existing gas turbines and engines operated < 1 500 h/yr. Not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns. Not applicable to boilers		
Technique	Description	Applicability									
a. Combined cycle	See description in Section 8.2	Generally applicable to new gas turbines and engines except when operated < 1 500 h/yr. Applicable to existing gas turbines and engines within the constraints associated with the steam cycle design and the space availability. Not applicable to existing gas turbines and engines operated < 1 500 h/yr. Not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns. Not applicable to boilers									
	<b>BAT-associated energy efficiency levels (BAT-AEELs) for the combustion of natural gas</b>										

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																																																														
	<table border="1"> <thead> <tr> <th rowspan="3">Type of combustion unit</th> <th colspan="4">BAT-AEELs <sup>(136)</sup> <sup>(137)</sup></th> </tr> <tr> <th colspan="2">Net electrical efficiency (%)</th> <th rowspan="2">Net total fuel utilisation (%) <sup>(138)</sup> <sup>(139)</sup></th> <th colspan="2">Net mechanical energy efficiency (%) <sup>(139)</sup> <sup>(140)</sup></th> </tr> <tr> <th>New unit</th> <th>Existing unit</th> <th>New unit</th> <th>Existing unit</th> </tr> </thead> <tbody> <tr> <td>Gas engine</td> <td>39,5–44 <sup>(141)</sup></td> <td>35–44 <sup>(141)</sup></td> <td>56–85 <sup>(141)</sup></td> <td colspan="2">No BAT-AEEL.</td> </tr> <tr> <td>Gas-fired boiler</td> <td>39–42,5</td> <td>38–40</td> <td>78–95</td> <td colspan="2">No BAT-AEEL.</td> </tr> <tr> <td>Open cycle gas turbine, ≥ 50 MW<sub>th</sub></td> <td>36–41,5</td> <td>33–41,5</td> <td>No BAT-AEEL</td> <td>36,5–41</td> <td>33,5–41</td> </tr> <tr> <td colspan="6" style="text-align: center;"><b>Combined cycle gas turbine (CCGT)</b></td> </tr> <tr> <td>CCGT, 50–600 MW<sub>th</sub></td> <td>53–58,5</td> <td>46–54</td> <td>No BAT-AEEL</td> <td colspan="2">No BAT-AEEL</td> </tr> <tr> <td>CCGT, ≥ 600 MW<sub>th</sub></td> <td>57–60,5</td> <td>50–60</td> <td>No BAT-AEEL</td> <td colspan="2">No BAT-AEEL</td> </tr> <tr> <td>CHP CCGT, 50–600 MW<sub>th</sub></td> <td>53–58,5</td> <td>46–54</td> <td>65–95</td> <td colspan="2">No BAT-AEEL</td> </tr> <tr> <td>CHP CCGT, ≥ 600 MW<sub>th</sub></td> <td>57–60,5</td> <td>50–60</td> <td>65–95</td> <td colspan="2">No BAT-AEEL</td> </tr> </tbody> </table>	Type of combustion unit	BAT-AEELs <sup>(136)</sup> <sup>(137)</sup>				Net electrical efficiency (%)		Net total fuel utilisation (%) <sup>(138)</sup> <sup>(139)</sup>	Net mechanical energy efficiency (%) <sup>(139)</sup> <sup>(140)</sup>		New unit	Existing unit	New unit	Existing unit	Gas engine	39,5–44 <sup>(141)</sup>	35–44 <sup>(141)</sup>	56–85 <sup>(141)</sup>	No BAT-AEEL.		Gas-fired boiler	39–42,5	38–40	78–95	No BAT-AEEL.		Open cycle gas turbine, ≥ 50 MW <sub>th</sub>	36–41,5	33–41,5	No BAT-AEEL	36,5–41	33,5–41	<b>Combined cycle gas turbine (CCGT)</b>						CCGT, 50–600 MW <sub>th</sub>	53–58,5	46–54	No BAT-AEEL	No BAT-AEEL		CCGT, ≥ 600 MW <sub>th</sub>	57–60,5	50–60	No BAT-AEEL	No BAT-AEEL		CHP CCGT, 50–600 MW <sub>th</sub>	53–58,5	46–54	65–95	No BAT-AEEL		CHP CCGT, ≥ 600 MW <sub>th</sub>	57–60,5	50–60	65–95	No BAT-AEEL			<p>Plant' (refer to section 8 of this document) as we do not consider this mode of operation as BAT for plant operating over 1,500 hours/year.</p> <p>Footnote 1 of Table 23 of the LCP BAT Conclusions specifies that the BAT AEELs for this type of plant are not applicable as the plant will operate for &lt;1,500 hours/year. Whilst the BAT AEELs do not apply to this plant, the Operator provided details of the plant efficiency calculations. The Operator has confirmed that the efficiency for LCP85 is 46.1%± 1.1%. This is within the BAT-AEEL range for existing open cycle gas turbines.</p> <p>Derby Thermal Efficiency. 41.6 ± 1.1% this is based on measurements taken 17 June 2015 @ 21:31</p> <p>Total gas fuel mass flow rate is 5495pph + 12590pph (2 Stage Combustion) = 2.28 ± 0.05 Kg/sec.</p> <p>Total energy input = 105.7 ± 2.6MW (LHV).</p>
Type of combustion unit	BAT-AEELs <sup>(136)</sup> <sup>(137)</sup>																																																																
	Net electrical efficiency (%)		Net total fuel utilisation (%) <sup>(138)</sup> <sup>(139)</sup>	Net mechanical energy efficiency (%) <sup>(139)</sup> <sup>(140)</sup>																																																													
	New unit	Existing unit		New unit	Existing unit																																																												
Gas engine	39,5–44 <sup>(141)</sup>	35–44 <sup>(141)</sup>	56–85 <sup>(141)</sup>	No BAT-AEEL.																																																													
Gas-fired boiler	39–42,5	38–40	78–95	No BAT-AEEL.																																																													
Open cycle gas turbine, ≥ 50 MW <sub>th</sub>	36–41,5	33–41,5	No BAT-AEEL	36,5–41	33,5–41																																																												
<b>Combined cycle gas turbine (CCGT)</b>																																																																	
CCGT, 50–600 MW <sub>th</sub>	53–58,5	46–54	No BAT-AEEL	No BAT-AEEL																																																													
CCGT, ≥ 600 MW <sub>th</sub>	57–60,5	50–60	No BAT-AEEL	No BAT-AEEL																																																													
CHP CCGT, 50–600 MW <sub>th</sub>	53–58,5	46–54	65–95	No BAT-AEEL																																																													
CHP CCGT, ≥ 600 MW <sub>th</sub>	57–60,5	50–60	65–95	No BAT-AEEL																																																													

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																		
			<p>Generator Power (Gross) is 44.0 ± 0.5 MWe</p> <p>At 50MWe the Thermal Input to the site can be expressed as <math>100/\eta \times 50 = 120.2 \pm 2.6</math> MW.</p> <p>The overall uncertainty of the total energy input is pessimistically based on ± 3% of point individual fuel mass flow accuracy (2 stage combustion), and ± 0.5 MW gas fuel LHV variation.</p>																		
41	<p>In order to prevent or reduce NO<sub>x</sub> emissions to air from the combustion of natural gas in boilers, BAT is to use one or a combination of the techniques given below.</p> <table border="1" data-bbox="320 900 1494 1390"> <thead> <tr> <th data-bbox="320 900 580 935">Technique</th> <th data-bbox="580 900 1021 935">Description</th> <th data-bbox="1021 900 1494 935">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="320 935 580 1018">a. Air and/or fuel staging</td> <td data-bbox="580 935 1021 1018">See descriptions in Section 8.3. Air staging is often associated with low-NO<sub>x</sub> burners</td> <td data-bbox="1021 935 1494 1018" rowspan="3">Generally applicable</td> </tr> <tr> <td data-bbox="320 1018 580 1053">b. Flue-gas recirculation</td> <td data-bbox="580 1018 1021 1053">See description in Section 8.3</td> </tr> <tr> <td data-bbox="320 1053 580 1114">c. Low-NO<sub>x</sub> burners (LNB)</td> <td data-bbox="580 1053 1021 1114"></td> </tr> <tr> <td data-bbox="320 1114 580 1222">d. Advanced control system</td> <td data-bbox="580 1114 1021 1222">See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated &lt; 500 h/yr</td> <td data-bbox="1021 1114 1494 1222">The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> <tr> <td data-bbox="320 1222 580 1305">e. Reduction of the combustion air temperature</td> <td data-bbox="580 1222 1021 1305" rowspan="2">See description in Section 8.3</td> <td data-bbox="1021 1222 1494 1305">Generally applicable within the constraints associated with the process needs</td> </tr> <tr> <td data-bbox="320 1305 580 1390">f. Selective non-catalytic reduction (SNCR)</td> <td data-bbox="1021 1305 1494 1390">Not applicable to combustion plants operated &lt; 500 h/yr with highly variable boiler loads.</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Air and/or fuel staging	See descriptions in Section 8.3. Air staging is often associated with low-NO <sub>x</sub> burners	Generally applicable	b. Flue-gas recirculation	See description in Section 8.3	c. Low-NO <sub>x</sub> burners (LNB)		d. Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system	e. Reduction of the combustion air temperature	See description in Section 8.3	Generally applicable within the constraints associated with the process needs	f. Selective non-catalytic reduction (SNCR)	Not applicable to combustion plants operated < 500 h/yr with highly variable boiler loads.	NA	Combustion of gas in boiler does not take place on site
Technique	Description	Applicability																			
a. Air and/or fuel staging	See descriptions in Section 8.3. Air staging is often associated with low-NO <sub>x</sub> burners	Generally applicable																			
b. Flue-gas recirculation	See description in Section 8.3																				
c. Low-NO <sub>x</sub> burners (LNB)																					
d. Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system																			
e. Reduction of the combustion air temperature	See description in Section 8.3	Generally applicable within the constraints associated with the process needs																			
f. Selective non-catalytic reduction (SNCR)		Not applicable to combustion plants operated < 500 h/yr with highly variable boiler loads.																			



BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																			
		g. Selective catalytic reduction (SCR)		<p>The applicability may be limited in the case of combustion plants operated between 500 h/yr and 1 500 h/yr with highly variable boiler loads</p> <p>Not applicable to combustion plants operated &lt; 500 h/yr. Not generally applicable to combustion plants of &lt; 100 MW<sub>th</sub>. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr</p>																				
42	In order to prevent or reduce NO <sub>x</sub> emissions to air from the combustion of natural gas in gas turbines, BAT is to use one or a combination of the techniques given below.			CC	<p>The operator has confirmed the following:</p> <p>(a) An advanced electronic control system is used to automatically control and optimise combustion efficiency and manage prevention and reduction of emissions. (b) NA water steam addition systems are not installed (c) Dry low NO<sub>x</sub> burners are fitted. (d) NA as Low load design is not used (e) NA -OCGT (f) NA as no SCR fitted.</p> <p>We accept that as this OCGT is an existing plant and the DLN-E definition is accepted</p> <p>i. The output load @ 35MWe or ii. This output load @70% Thermal</p>																			
<table border="1"> <thead> <tr> <th data-bbox="320 746 539 783">Technique</th> <th data-bbox="539 746 1093 783">Description</th> <th data-bbox="1093 746 1503 783">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="320 783 539 895">a. Advanced control system</td> <td data-bbox="539 783 1093 895">See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated &lt; 500 h/yr</td> <td data-bbox="1093 783 1503 895">The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> <tr> <td data-bbox="320 895 539 951">b. Water/steam addition</td> <td data-bbox="539 895 1093 951" rowspan="2">See description in Section 8.3</td> <td data-bbox="1093 895 1503 951">The applicability may be limited due to water availability</td> </tr> <tr> <td data-bbox="320 951 539 1062">c. Dry low-NO<sub>x</sub> burners (DLN)</td> <td data-bbox="1093 951 1503 1062">The applicability may be limited in the case of turbines where a retrofit package is not available or when water/steam addition systems are installed</td> </tr> <tr> <td data-bbox="320 1062 539 1198">d. Low-load design concept</td> <td data-bbox="539 1062 1093 1198">Adaptation of the process control and related equipment to maintain good combustion efficiency when the demand in energy varies, e.g. by improving the inlet airflow control capability or by splitting the combustion process into decoupled combustion stages</td> <td data-bbox="1093 1062 1503 1198">The applicability may be limited by the gas turbine design</td> </tr> <tr> <td data-bbox="320 1198 539 1302">e. Low-NO<sub>x</sub> burners (LNB)</td> <td data-bbox="539 1198 1093 1302" rowspan="2">See description in Section 8.3</td> <td data-bbox="1093 1198 1503 1302">Generally applicable to supplementary firing for heat recovery steam generators (HRSGs) in the case of combined-cycle gas turbine (CCGT) combustion plants</td> </tr> <tr> <td data-bbox="320 1302 539 1390">f. Selective catalytic reduction (SCR)</td> <td data-bbox="1093 1302 1503 1390">Not applicable in the case of combustion plants operated &lt; 500 h/yr.</td> </tr> </tbody> </table>						Technique	Description	Applicability	a. Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system	b. Water/steam addition	See description in Section 8.3	The applicability may be limited due to water availability	c. Dry low-NO <sub>x</sub> burners (DLN)	The applicability may be limited in the case of turbines where a retrofit package is not available or when water/steam addition systems are installed	d. Low-load design concept	Adaptation of the process control and related equipment to maintain good combustion efficiency when the demand in energy varies, e.g. by improving the inlet airflow control capability or by splitting the combustion process into decoupled combustion stages	The applicability may be limited by the gas turbine design	e. Low-NO <sub>x</sub> burners (LNB)	See description in Section 8.3	Generally applicable to supplementary firing for heat recovery steam generators (HRSGs) in the case of combined-cycle gas turbine (CCGT) combustion plants	f. Selective catalytic reduction (SCR)	Not applicable in the case of combustion plants operated < 500 h/yr.
Technique	Description	Applicability																						
a. Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system																						
b. Water/steam addition	See description in Section 8.3	The applicability may be limited due to water availability																						
c. Dry low-NO <sub>x</sub> burners (DLN)		The applicability may be limited in the case of turbines where a retrofit package is not available or when water/steam addition systems are installed																						
d. Low-load design concept	Adaptation of the process control and related equipment to maintain good combustion efficiency when the demand in energy varies, e.g. by improving the inlet airflow control capability or by splitting the combustion process into decoupled combustion stages	The applicability may be limited by the gas turbine design																						
e. Low-NO <sub>x</sub> burners (LNB)	See description in Section 8.3	Generally applicable to supplementary firing for heat recovery steam generators (HRSGs) in the case of combined-cycle gas turbine (CCGT) combustion plants																						
f. Selective catalytic reduction (SCR)		Not applicable in the case of combustion plants operated < 500 h/yr.																						

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement														
	<table border="1"> <tr> <td data-bbox="322 384 356 616"></td> <td data-bbox="356 384 535 616"></td> <td data-bbox="535 384 1093 616"></td> <td data-bbox="1093 384 1496 616">           Not generally applicable to existing combustion plants of &lt; 100 MW<sub>th</sub>. Retrofitting existing combustion plants may be constrained by the availability of sufficient space. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr         </td> </tr> </table>				Not generally applicable to existing combustion plants of < 100 MW <sub>th</sub> . Retrofitting existing combustion plants may be constrained by the availability of sufficient space. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr												
			Not generally applicable to existing combustion plants of < 100 MW <sub>th</sub> . Retrofitting existing combustion plants may be constrained by the availability of sufficient space. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr														
43	<p>In order to prevent or reduce NO<sub>x</sub> emissions to air from the combustion of natural gas in engines, BAT is to use one or a combination of the techniques given below.</p> <table border="1"> <thead> <tr> <th data-bbox="322 691 356 722">Technique</th> <th data-bbox="356 691 535 722">Description</th> <th data-bbox="535 691 994 722">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 722 356 834">a. Advanced control system</td> <td data-bbox="356 722 535 834">See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated &lt; 500 h/yr</td> <td data-bbox="535 722 994 834">The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> <tr> <td data-bbox="322 834 356 898">b. Lean-burn concept</td> <td data-bbox="356 834 535 898">See description in Section 8.3. Generally used in combination with SCR</td> <td data-bbox="535 834 994 898">Only applicable to new gas-fired engines</td> </tr> <tr> <td data-bbox="322 898 356 962">c. Advanced lean-burn concept</td> <td data-bbox="356 898 535 962" rowspan="2">See descriptions in Section 8.3</td> <td data-bbox="535 898 994 962">Only applicable to new spark plug ignited engines</td> </tr> <tr> <td data-bbox="322 962 356 1134">d. Selective catalytic reduction (SCR)</td> <td data-bbox="535 962 994 1134">Retrofitting existing combustion plants may be constrained by the availability of sufficient space. Not applicable to combustion plants operated &lt; 500 h/yr. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system	b. Lean-burn concept	See description in Section 8.3. Generally used in combination with SCR	Only applicable to new gas-fired engines	c. Advanced lean-burn concept	See descriptions in Section 8.3	Only applicable to new spark plug ignited engines	d. Selective catalytic reduction (SCR)	Retrofitting existing combustion plants may be constrained by the availability of sufficient space. Not applicable to combustion plants operated < 500 h/yr. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr	NA	Engines are not in use at the site
Technique	Description	Applicability															
a. Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system															
b. Lean-burn concept	See description in Section 8.3. Generally used in combination with SCR	Only applicable to new gas-fired engines															
c. Advanced lean-burn concept	See descriptions in Section 8.3	Only applicable to new spark plug ignited engines															
d. Selective catalytic reduction (SCR)		Retrofitting existing combustion plants may be constrained by the availability of sufficient space. Not applicable to combustion plants operated < 500 h/yr. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr															
44	<p>In order to prevent or reduce CO emissions to air from the combustion of natural gas, BAT is to ensure optimised combustion and/or to use oxidation catalysts.</p> <p><b>Description - See descriptions in Section 8.3.</b></p> <p><b>BAT-associated emission levels (BAT-AELs) for NO<sub>x</sub> emissions to air from the combustion of natural gas in gas turbines</b></p> <table border="1"> <thead> <tr> <th data-bbox="322 1294 786 1326">Type of combustion plant</th> <th data-bbox="786 1294 1496 1326">BAT-AELs (mg/Nm<sup>3</sup>) <sup>(142)</sup> <sup>(143)</sup></th> </tr> </thead> <tbody> <tr> <td data-bbox="322 1326 786 1380"></td> <td data-bbox="786 1326 1496 1380"></td> </tr> </tbody> </table>	Type of combustion plant	BAT-AELs (mg/Nm <sup>3</sup> ) <sup>(142)</sup> <sup>(143)</sup>			CC	<p>The operator has confirmed that CO emissions are reduced as far as possible by optimising combustion. Gas Turbine is a DLN Combustion system.</p> <p>They also confirm that they would be compliant with a yearly CO</p>										
Type of combustion plant	BAT-AELs (mg/Nm <sup>3</sup> ) <sup>(142)</sup> <sup>(143)</sup>																

BAT Concn. Number	Summary of BAT Conclusion requirement				Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
		<b>Combustion plant total rated thermal input (MW<sub>th</sub>)</b>	<b>Yearly average <sup>(144)</sup> <sup>(145)</sup></b>	<b>Daily average or average over the sampling period</b>		<p>emission limit of 50 mg/Nm<sup>3</sup>. However, as we have introduced a restriction on operating hours for the OCGT to &lt;1,500 hours per year, the yearly BAT-AEL for NO<sub>x</sub> and the yearly indicative emission limit for CO are not applicable.</p> <p>As an existing OCGT plant the applicable NO<sub>x</sub> BAT-AEL is 55 mg/m<sup>3</sup> (daily). This limit is applicable when the DLN system is fully effective.</p> <p>The existing permit already sets monthly, daily and hourly average emission limits for carbon monoxide and NO<sub>x</sub>. Under the principal of “no backsliding”, the current emission limits will be retained unless tighter limits are set by the BREF.</p> <p>Refer to section 4.1 of this document for further details of the limits set in the consolidated permit</p> <p>NO<sub>x</sub> and CO emissions are continuously monitored.</p>
<b>Open-cycle gas turbines (OCGTs) <sup>(146)</sup> <sup>(147)</sup></b>						
New OCGT	≥ 50	15–35	25–50			
Existing OCGT (excluding turbines for mechanical drive applications) — All but plants operated < 500 h/yr	≥ 50	15–50	25–55 <sup>(148)</sup>			
<b>Combined-cycle gas turbines (CCGTs) <sup>(146)</sup> <sup>(149)</sup></b>						
New CCGT	≥ 50	10–30	15–40			
Existing CCGT with a net total fuel utilisation of < 75 %	≥ 600	10–40	18–50			
Existing CCGT with a net total fuel utilisation of ≥ 75 %	≥ 600	10–50	18–55 <sup>(150)</sup>			
Existing CCGT with a net total fuel utilisation of < 75 %	50–600	10–45	35–55			
Existing CCGT with a net total fuel utilisation of ≥ 75 %	50–600	25–50 <sup>(151)</sup>	35–55 <sup>(152)</sup>			
<b>Open- and combined-cycle gas turbines</b>						
Gas turbine put into operation no later than 27 November 2003, or existing gas turbine for emergency use and operated < 500 h/yr	≥ 50	No BAT-AEL	60–140 <sup>(153)</sup> <sup>(154)</sup>			
Existing gas turbine for mechanical drive applications — All but plants operated < 500 h/yr	≥ 50	15–50 <sup>(155)</sup>	25–55 <sup>(156)</sup>			
<p>As an indication, the yearly average CO emission levels for each type of existing combustion plant operated ≥ 1 500 h/yr and for each type of new combustion plant will generally be as follows:</p> <ul style="list-style-type: none"> <li>— New OCGT of ≥ 50 MW<sub>th</sub>: &lt; 5–40 mg/Nm<sup>3</sup>. For plants with a net electrical efficiency (EE) greater than 39 %, a correction factor may be applied to the higher end of this range, corresponding to [higher end] × EE/39, where EE is the net electrical energy efficiency or net mechanical energy efficiency of the plant determined at ISO baseload conditions.</li> </ul>						

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																							
	<p>— Existing OCGT of <math>\geq 50 \text{ MW}_{th}</math> (excluding turbines for mechanical drive applications): <math>&lt; 5\text{--}40 \text{ mg/Nm}^3</math>. The higher end of this range will generally be <math>80 \text{ mg/Nm}^3</math> in the case of existing plants that cannot be fitted with dry techniques for <math>\text{NO}_x</math> reduction, or <math>50 \text{ mg/Nm}^3</math> for plants that operate at low load.</p> <p>— New CCGT of <math>\geq 50 \text{ MW}_{th}</math>: <math>&lt; 5\text{--}30 \text{ mg/Nm}^3</math>. For plants with a net electrical efficiency (EE) greater than 55 %, a correction factor may be applied to the higher end of the range, corresponding to [higher end] <math>\times \text{EE}/55</math>, where EE is the net electrical energy efficiency of the plant determined at ISO baseload conditions.</p> <p>— Existing CCGT of <math>\geq 50 \text{ MW}_{th}</math>: <math>&lt; 5\text{--}30 \text{ mg/Nm}^3</math>. The higher end of this range will generally be <math>50 \text{ mg/Nm}^3</math> for plants that operate at low load.</p> <p>— Existing gas turbines of <math>\geq 50 \text{ MW}_{th}</math> for mechanical drive applications: <math>&lt; 5\text{--}40 \text{ mg/Nm}^3</math>. The higher end of the range will generally be <math>50 \text{ mg/Nm}^3</math> when plants operate at low load.</p> <p>In the case of a gas turbine equipped with DLN burners, these indicative levels correspond to when the DLN operation is effective.</p> <p><b>BAT-associated emission levels (BAT-AELs) for <math>\text{NO}_x</math> emissions to air from the combustion of natural gas in boilers and engines</b></p> <table border="1" data-bbox="322 791 1496 1015"> <thead> <tr> <th rowspan="3">Type of combustion plant</th> <th colspan="4">BAT-AELs (<math>\text{mg/Nm}^3</math>)</th> </tr> <tr> <th colspan="2">Yearly average <sup>(157)</sup></th> <th colspan="2">Daily average or average over the sampling period</th> </tr> <tr> <th>New plant</th> <th>Existing plant <sup>(158)</sup></th> <th>New plant</th> <th>Existing plant <sup>(159)</sup></th> </tr> </thead> <tbody> <tr> <td>Boiler</td> <td>10–60</td> <td>50–100</td> <td>30–85</td> <td>85–110</td> </tr> <tr> <td>Engine <sup>(160)</sup></td> <td>20–75</td> <td>20–100</td> <td>55–85</td> <td>55–110 <sup>(161)</sup></td> </tr> </tbody> </table> <p>As an indication, the yearly average CO emission levels will generally be:</p> <ul style="list-style-type: none"> <li>— <math>&lt; 5\text{--}40 \text{ mg/Nm}^3</math> for existing boilers operated <math>\geq 1\,500 \text{ h/yr}</math>,</li> <li>— <math>&lt; 5\text{--}15 \text{ mg/Nm}^3</math> for new boilers,</li> <li>— <math>30\text{--}100 \text{ mg/Nm}^3</math> for existing engines operated <math>\geq 1\,500 \text{ h/yr}</math> and for new engines.</li> </ul>	Type of combustion plant	BAT-AELs ( $\text{mg/Nm}^3$ )				Yearly average <sup>(157)</sup>		Daily average or average over the sampling period		New plant	Existing plant <sup>(158)</sup>	New plant	Existing plant <sup>(159)</sup>	Boiler	10–60	50–100	30–85	85–110	Engine <sup>(160)</sup>	20–75	20–100	55–85	55–110 <sup>(161)</sup>		
Type of combustion plant	BAT-AELs ( $\text{mg/Nm}^3$ )																									
	Yearly average <sup>(157)</sup>		Daily average or average over the sampling period																							
	New plant	Existing plant <sup>(158)</sup>	New plant	Existing plant <sup>(159)</sup>																						
Boiler	10–60	50–100	30–85	85–110																						
Engine <sup>(160)</sup>	20–75	20–100	55–85	55–110 <sup>(161)</sup>																						
45	<p>In order to reduce non-methane volatile organic compounds (NMVOC) and methane (<math>\text{CH}_4</math>) emissions to air from the combustion of natural gas in spark-ignited lean-burn gas engines, BAT is to ensure optimised combustion and/or to use oxidation catalysts.</p> <p><b>Description</b></p> <p>See descriptions in Section 8.3. Oxidation catalysts are not effective at reducing the emissions of saturated hydrocarbons containing less than four carbon atoms.</p>	NA	Spark-ignited lean-burn gas engine are not used on site																							

BAT Concn. Numbe r	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																			
	<p align="center"><b>BAT-associated emission levels (BAT-AELs) for formaldehyde and CH<sub>4</sub> emissions to air from the combustion of natural gas in a spark-ignited lean-burn gas engine</b></p> <table border="1" data-bbox="322 440 1491 612"> <thead> <tr> <th data-bbox="322 440 884 480" rowspan="2">Combustion plant total rated thermal input (MW<sub>th</sub>)</th> <th colspan="3" data-bbox="884 440 1491 475">BAT-AELs (mg/Nm<sup>3</sup>)</th> </tr> <tr> <th data-bbox="884 475 1151 507">Formaldehyde</th> <th colspan="2" data-bbox="1151 475 1491 507">CH<sub>4</sub></th> </tr> <tr> <td colspan="4" data-bbox="884 507 1491 544" style="text-align: center;">Average over the sampling period</td> </tr> <tr> <td data-bbox="322 544 884 576"></td> <th data-bbox="884 544 1151 576">New or existing plant</th> <th data-bbox="1151 544 1296 576">New plant</th> <th data-bbox="1296 544 1491 576">Existing plant</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 576 884 612">≥ 50</td> <td data-bbox="884 576 1151 612">5–15 <sup>(162)</sup></td> <td data-bbox="1151 576 1296 612">215–500 <sup>(163)</sup></td> <td data-bbox="1296 576 1491 612">215–560 <sup>(162)</sup> <sup>(163)</sup></td> </tr> </tbody> </table>	Combustion plant total rated thermal input (MW <sub>th</sub> )	BAT-AELs (mg/Nm <sup>3</sup> )			Formaldehyde	CH <sub>4</sub>		Average over the sampling period					New or existing plant	New plant	Existing plant	≥ 50	5–15 <sup>(162)</sup>	215–500 <sup>(163)</sup>	215–560 <sup>(162)</sup> <sup>(163)</sup>		
Combustion plant total rated thermal input (MW <sub>th</sub> )	BAT-AELs (mg/Nm <sup>3</sup> )																					
	Formaldehyde	CH <sub>4</sub>																				
Average over the sampling period																						
	New or existing plant	New plant	Existing plant																			
≥ 50	5–15 <sup>(162)</sup>	215–500 <sup>(163)</sup>	215–560 <sup>(162)</sup> <sup>(163)</sup>																			

## **6. Review and assessment of derogation requests made by the operator in relation to BAT Conclusions which include an associated emission level (AEL) value**

The IED enables a competent authority to allow derogations from BAT AELs stated in BAT Conclusions under specific circumstances as detailed under Article 15(4):

By way of derogation from paragraph 3, and without prejudice to Article 18, the competent authority may, in specific cases, set less strict emission limit values. Such a derogation may apply only where an assessment shows that the achievement of emission levels associated with the best available techniques as described in BAT conclusions would lead to disproportionately higher costs compared to the environmental benefits due to:

*(a) the geographical location or the local environmental conditions of the installation concerned; or*

*(b) the technical characteristics of the installation concerned.*

As part of their Regulation 61 Note response, the operator has not requested a derogation from compliance with any AEL values.

## **7. Emissions to Water**

There are no direct emissions to water. Waste water is either tankered off site or transferred for treatment by Rolls Royce host Site via points S1 and W1 on map in Schedule 7 of the permit.

There are no BAT AELs specified in the BAT Conclusions for this type of plant. There are also no additional treatment options identified as BAT for the installation. We have therefore not carried out any additional assessment of the emissions to water as part of this review.

## 8 Additional IED Chapter II requirements

Name Changed - to Derby Plant

### Operating Hours

We have introduced a limit on operating hours in open cycle mode for the LCP in line with our guidance 'BAT for Balancing Plant' (see below) as we do not consider this mode of operation as BAT for plant operating over 1,500 hours/year.

We have amended the reporting requirements in the permit. We have added in a reporting requirement for operating hours to be reported over a five year rolling average to demonstrate compliance with the less than 1,500 hours/year operational limit.

The OCGT was previously permitted to operate unlimited. However, we are not satisfied that there is sufficient evidence available to demonstrate that OCGTs represent BAT for plants operating for more than 1,500 hours/year. Therefore, we have specified 1,500 hours as a limit on operational hours in the permit.

Article 11 of the IED 2010/75/EU states that BAT are applied. BAT requires the use of the most effective and advanced techniques to prevent or minimise emissions and impacts on the environment.

Relevant guidance that we have drawn on, for BAT, includes the Department of Energy and Climate Change '*Developing best available techniques (BAT) for combustion plants operating in the balancing market*' and Chapter III of IED and the BAT Conclusions, all of which specifically identify two categories of combustion plant operating in the balancing market as peaking plant: those that operate less than 500 hours and those that operate from 500 hours up to 1,500 hours. Within these documents no other categories of operational regimes are recognised other than base load operation.

Furthermore, draft Environment Agency guidance '*BAT guidance for >50 MWth gas and liquid fuel combustion plant exporting electricity under commercial arrangements for <1,500 hours per annum*' consolidates our position on the above and stipulates that combustion plants operating in a single cycle, will be limited to 1,500 hours per annum on a rolling average.

OCGTs operating as peaking plant are classed as fast start, lower efficiency and would generally have higher emissions of oxides of nitrogen (NOx) per megawatt hour of energy produced than would be expected for natural gas fired base load plant. Therefore, OCGTs are better suited to fast reserve running for short periods of time in comparison to base load plants which are more appropriate for steady state running operations.



The use of fast start combined cycle gas turbines (CCGT) aero derivative, gas turbine combined heat and power (GT-CHP) or a large gas engine with combined heat and power would be considered to be a more favourable alternative, in terms of energy efficiency, than the proposal presented in this Regulation 61 response.

The National Emissions Ceiling Directive (NECD) sets national targets for reductions in pollutants including NOx. Restrictions on plants with higher NOx intensity directly contributes to achieving the NECD targets.

For this reason the variation restricts the hours of operation of the plant to no more than 1,500 hours/year as a rolling average over a 5 year period and with operation of the turbine in any individual year limited to a maximum of 2,250 hours. We have included permit condition 2.3.6 and updated tables S1.1 and S4.3 to reflect the permitted hours of operation.

### Black Start Operation

In the event of a black out National Grid would call on combustion plant to operate and may require them to do so outside their permitted conditions. We have dedicated black start plant and they are permitted to run as such but this scenario is relevant to the rest of the large combustion plant which could be called depending on the circumstances.

A risk assessment will be carried out by Energy UK/Joint Environmental Programme on behalf of Large Combustion Plant connected to the National Transmission System. Air emissions modelling will be based on generic black start scenarios to establish whether they have the potential to have local impact on the environment or not (on a national basis). If the modelling demonstrates that no significant impacts are likely, the plant can operate under condition 2.3.8. This conditions allows the hourly ELVs for plants operating under a black start instruction to be discounted for the purpose of reporting. We would also require there to be a procedure in place for minimisation of emissions in the case of a black start event and for reporting in the event of a black start. This modelling and the procedures have not been agreed in advance of the issue of the permit review and therefore a condition linking back to an improvement condition have been included in the permit.

## 9 Review and assessment of changes that are not part of the BAT Conclusions derived permit review.

This document should be read in conjunction with the application, supporting information and notice.

Aspect considered	Decision
<b>Receipt of application</b>	
Confidential information	A claim for commercial or industrial confidentiality has not been made.
Identifying confidential information	We have not identified information provided as part of the application that we consider to be confidential.
<b>The site</b>	
Biodiversity, heritage, landscape and nature conservation	<p>The application is within the relevant distance criteria of a site of heritage, landscape or nature conservation, and/or protected species or habitat.</p> <p>A full assessment of the application and its potential to affect the site(s)/species/habitat has not been carried out as part of the permit review process. We consider that the review will not affect the features of the site(s)/species/habitat as the conditions will provide at least the same level of protection as those in the previous permit and in some cases will provide a higher level of protection to those in the previous permit.</p> <p>We have not consulted Natural England on the application. The decision was taken in accordance with our guidance.</p>
<b>Operating techniques</b>	
General operating techniques	<p>We have reviewed the techniques used by the operator where they are relevant to the BAT Conclusions and compared these with the relevant guidance notes.</p> <p>The permit conditions ensure compliance with the relevant BREF, BAT Conclusions. The ELVs deliver compliance with the BAT-AELs.</p> <p>We have introduced a limit on operating hours in Open Cycle Mode for the LCP in line with our guidance 'BAT for Balancing Plant' as we do not consider this mode of operation as BAT for plant operating over 1,500 hours. See section 8 for further information.</p>

Aspect considered	Decision
<b>Permit conditions</b>	
Updating permit conditions during consolidation	We have updated permit conditions to those in the current generic permit template as part of permit consolidation. The conditions will provide at least the same level of protection as those in the previous permit and in some cases will provide a higher level of protection to those in the previous permit.
Changes to the permit conditions due to an Environment Agency initiated variation	We have varied the permit as stated in the variation notice.
Improvement programme	<p>Permit condition 2.3.8 has been included in the permit with corresponding improvement condition IC8 requiring the operator to submit a report in relation to potential black start operation of the plant. See Section 8 for further information.</p> <p>We have also removed the completed improvement conditions from the permit.</p>
Emission limits	<p>We have decided that emission limits should be set for the parameters listed in the permit.</p> <p>These are described in the relevant BAT Conclusions in Sections 4.1 and 5 of this document.</p> <p>It is considered that the ELVs/equivalent parameters or technical measures described above will ensure that significant pollution of the environment is prevented and a high level of protection for the environment is secured.</p>
Monitoring	<p>We have decided that monitoring should be carried out for the parameters listed in the permit, using the methods detailed and to the frequencies specified.</p> <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p> <p>Table S3.2 Process monitoring requirements was amended to include the requirement to monitor energy efficiency after overhauls on site in line with BAT2.</p> <p>Based on the information in the application we are fully satisfied that the operator's techniques, personnel and equipment have either MCERTS certification or MCERTS accreditation as appropriate.</p>
Reporting	<p>We have specified reporting in the permit for the following parameters:</p> <ul style="list-style-type: none"> <li>• Nitrogen dioxide</li> <li>• Carbon monoxide</li> </ul>

Aspect considered	Decision
	These are described in the relevant BAT Conclusions in Section 5 of this document.
<b>Operator competence</b>	
Management system	There is no known reason to consider that the operator will not have the management system to enable it to comply with the permit conditions.
<b>Growth Duty</b>	
Section 108 Deregulation Act 2015 – Growth duty	<p>We have considered our duty to have regard to the desirability of promoting economic growth set out in section 108(1) of the Deregulation Act 2015 and the guidance issued under section 110 of that Act in deciding whether to grant this permit.</p> <p>Paragraph 1.3 of the guidance says:</p> <p>“The primary role of regulators, in delivering regulation, is to achieve the regulatory outcomes for which they are responsible. For a number of regulators, these regulatory outcomes include an explicit reference to development or growth. The growth duty establishes economic growth as a factor that all specified regulators should have regard to, alongside the delivery of the protections set out in the relevant legislation.”</p> <p>We have addressed the legislative requirements and environmental standards to be set for this operation in the body of the decision document above. The guidance is clear at paragraph 1.5 that the growth duty does not legitimise non-compliance and its purpose is not to achieve or pursue economic growth at the expense of necessary protections.</p> <p>We consider the requirements and standards we have set in this permit are reasonable and necessary to avoid a risk of an unacceptable level of pollution. This also promotes growth amongst legitimate operators because the standards applied to the operator are consistent across businesses in this sector and have been set to achieve the required legislative standards.</p>