

## Environment Agency

# **Review of an Environmental Permit for an Installation subject to Chapter II of the Industrial Emissions Directive under the Environmental Permitting (England & Wales) Regulations 2016**

## **Decision document recording our decision-making process following review of a permit**

The Permit number is: EPR/AP3233LU  
The Operator is: Centrica PB Limited  
The Installation is: Peterborough Power Station  
This Variation Notice number is: EPR/AP3233LU/V006

### **What this document is about**

Article 21(3) of the Industrial Emissions Directive (IED) requires the Environment Agency to review conditions in permits that it has issued and to ensure that the permit delivers compliance with relevant standards, within four years of the publication of updated decisions on best available techniques (BAT) conclusions.

We have reviewed the permit for this installation against the revised BAT Conclusions for large combustion plant published on 17<sup>th</sup> August 2017. This is our decision document, which explains the reasoning for the consolidated variation notice that we are issuing.

It explains how we have reviewed and considered the techniques used by the Operator in the operation and control of the plant and activities of the installation. This review has been undertaken with reference to the decision made by the European Commission establishing best available techniques (BAT) conclusions ('BAT Conclusions') for large combustion plant as detailed in document reference IEDC-7-1. It is our record of our decision-making process and shows how we have taken into account all relevant factors in reaching our position. It also provides a justification for the inclusion of any specific conditions in the permit that are in addition to those included in our generic permit template.

As well as considering the review of the operating techniques used by the Operator for the operation of the plant and activities of the installation, the consolidated variation notice takes into account and brings together in a single document all previous variations that relate to the original permit

issued. It also modernises the entire permit to reflect the conditions contained in our current generic permit template.

The introduction of new template conditions makes the Permit consistent with our current general approach and philosophy and with other permits issued to installations in this sector. Although the wording of some conditions has changed, while others have been removed because of the new regulatory approach, it does not reduce the level of environmental protection achieved by the Permit in any way. In this document we therefore address only our determination of substantive issues relating to the new BAT Conclusions.

Throughout this document we will use a number of expressions. These are as referred to in the glossary and have the same meaning as described in “Schedule 6 Interpretation” of the Permit.

We try to explain our decision as accurately, comprehensively and plainly as possible. We would welcome any feedback as to how we might improve our decision documents in future. A lot of technical terms and acronyms are inevitable in a document of this nature: we provide a glossary of acronyms near the front of the document, for ease of reference.

## How this document is structured

### Glossary of terms

- 1 Our decision
- 2 How we reached our decision
- 2.1 Requesting information to demonstrate compliance with BAT Conclusions for Large Combustion Plant
- 2.2 Review of our own information in respect to the capability of the installation to meet revised standards included in the BAT Conclusions document
- 3 The legal framework
- 4 Key Issues
- 4.1 Emissions to air and the emission limits applied to the plant
- 4.2 The energy efficiency levels associated with the BAT Conclusions
- 4.3 Review and assessment of BAT for turbines <500 hours
- 5 Decision checklist regarding relevant BAT Conclusions
- 6 Review and assessment of derogation requests made by the operator in relation to BAT Conclusions which include an associated emission level (AEL) value
- 7 Emissions to Water
- 8 Additional IED Chapter II requirements
- 9 Review and assessment of changes that are not part of the BAT Conclusions derived permit review.

## Glossary of acronyms used in this document

(Please note that this glossary is standard for our decision documents and therefore not all these acronyms are necessarily used in this document.)

APC	Air Pollution Control
BAT	Best Available Technique(s)
BAT-AEEL	BAT Associated Energy Efficiency Level
BAT-AEL	BAT Associated Emission Level
BATc	BAT conclusion
BREF	Best available techniques reference document
CEM	Continuous emissions monitor
CHP	Combined heat and power
CV	Calorific value
DAA	Directly associated activity – Additional activities necessary to be carried out to allow the principal activity to be carried out
DLN	Dry Low NOx burners
DLN-E	Dry Low NOx effective
EIONET	European environment information and observation network is a partnership network of the European Environment Agency
ELV	Emission limit value derived under BAT or an emission limit value set out in IED
EMS	Environmental Management System
EPR	Environmental Permitting (England and Wales) Regulations 2016 (SI 2016 No. 1154)
EWC	European waste catalogue
FSA	Food Standards Agency
IC	Improvement Condition
IED	Industrial Emissions Directive (2010/75/EU)
IPPCD	Integrated Pollution Prevention and Control Directive (2008/1/EC) – now superseded by IED
LCP	Large Combustion Plant subject to Chapter III of IED
MSUL/MSDL	Minimum start up load/minimum shut-down load
NOx	Oxides of nitrogen (NO plus NO <sub>2</sub> expressed as NO <sub>2</sub> )
NPV	Net Present Value
OCGT	Open Cycle Gas Turbine
PHE	Public Health England
SAC	Special Area of Conservation
SGN	Sector guidance note
TGN	Technical guidance note
TNP	Transitional National Plan
TOC	Total Organic Carbon
WFD	Water Framework Directive (2000/60/EC)

## **1 Our decision**

We have decided to issue the consolidated variation notice to the Operator. This will allow it to continue to operate the Installation, subject to the conditions in the consolidated variation notice.

We consider that, in reaching that decision, we have taken into account all relevant considerations and legal requirements and that the varied permit will ensure that a high level of protection is provided for the environment and human health.

The consolidated variation notice contains many conditions taken from our standard Environmental Permit template including the relevant Annexes. We developed these conditions in consultation with industry, having regard to the legal requirements of the Environmental Permitting Regulations and other relevant legislation. This document does not therefore include an explanation for these standard conditions. Where they are included in the Notice, we have considered the techniques identified by the operator for the operation of their installation, and have accepted that the details are sufficient and satisfactory to make those standard conditions appropriate. This document does, however, provide an explanation of our use of “tailor-made” or installation-specific conditions, or where our Permit template provides two or more options.

## **2 How we reached our decision**

### **2.1 Requesting information to demonstrate compliance with BAT Conclusions for Large Combustion Plant**

We issued a Notice under Regulation 61(1) of the Environmental Permitting (England and Wales) Regulations 2016 (a Regulation 61 Notice) on 1<sup>st</sup> May 2018 requiring the Operator to provide information to demonstrate how the operation of their installation currently meets, or will subsequently meet, the revised standards described in the large combustion plant BAT Conclusions document. The Notice also required that where the revised standards are not currently met, the operator should provide information that:

- Describes the techniques that will be implemented before 17<sup>th</sup> August 2021, which will then ensure that operations meet the revised standard, or
- Justifies why standards will not be met by 17<sup>th</sup> August 2021, and confirmation of the date when the operation of those processes will cease within the installation or an explanation of why the revised BAT standard is not applicable to those processes, or
- Justifies why an alternative technique will achieve the same level of environmental protection equivalent to the revised standard described in the BAT Conclusions.

Where the Operator proposed that they were not intending to meet a BAT standard that also included a BAT Associated Emission Level (BAT AEL) described in the BAT Conclusions Document, the Regulation 61 Notice requested that the Operator make a formal request for derogation from compliance with that AEL (as provisioned by Article 15(4) of IED). In this circumstance, the Notice identified that any such request for derogation must be supported and justified by sufficient technical and commercial information that would enable us to determine acceptability of the derogation request.

The Regulation 61 Notice response from the Operator was received on 14<sup>th</sup> November 2018.

We considered it was in the correct form and contained sufficient information for us to begin our determination of the permit review but not that it necessarily contained all the information we would need to complete that review. We requested further information on 30 April 2020, as follows:

- Confirmation of all combustion plant on the site and thermal input.

## **2.2 Review of our own information in respect to the capability of the installation to meet revised standards included in the BAT Conclusions document**

Based on our records and previous regulatory activities with the facility we have no reason to consider that the operator will not be able to comply with the conditions that we include in the permit.

### 3 The legal framework

The consolidated variation notice will be issued under Regulation 20 of the EPR. The Environmental Permitting regime is a legal vehicle which delivers most of the relevant legal requirements for activities falling within its scope. In particular, the regulated facility is:

- an *installation* as described by the IED;
- subject to aspects of other relevant legislation which also have to be addressed.

We consider that the consolidated variation notice will ensure that the operation of the Installation complies with all relevant legal requirements and that a high level of protection will be delivered for the environment and human health.

We explain how we have addressed specific statutory requirements more fully in the rest of this document.

## 4 The key issues

The key issues arising during this permit review are:

- Emissions to air and the emission limits applied to the plant.
- The energy efficiency levels associated with the Best Available Techniques (BAT-AEELs).
- The review and assessment of the availability of BAT for gas turbines operating <500 hours per year.

We therefore describe how we determined these issues in most detail in the relevant sections of this document.

### 4.1 Emissions to air and the emission limits applied to the plant

A number of general principles were applied during the permit review. These included:

- The upper value of the BAT AELs ranges specified were used unless use of the tighter limit was justified.
- The principle of no backsliding where if existing limits in the permit were already tighter than those specified in the BREF, the existing permit limits were retained.
- Where a limit was specified in both IED Annex V and the BAT Conclusions for a particular reference period, the tighter limit was applied and in the majority of cases this was from the BAT Conclusions.
- Where AELs are indicative in the BAT Conclusions, these were applied unless adequate justification was provided by the operator to demonstrate that an alternative limit was more appropriate.

The LCPs on site consist of:

- LCP55 – 339MWth open cycle gas turbine, fuelled on natural gas, operating for no more than 500 hours per year; and
- LCP56 – 346MWth open cycle gas turbine, fuelled on natural gas, operating for no more than 500 hours per year

The plant was put into operation before IED came into force and therefore the existing limits in the permit are from Part 1 of IED Annex V applicable to existing plant.

The ELVs and AELs are based on the following operating regime:

- <500 hours.

The following tables outline the limits that have been incorporated into the permit for LCP55 and LCP56, where these were derived from and the



reference periods at which they apply. The emission limits and monitoring requirements have been incorporated into Schedule 3 of the permit.

Under Chapter III gas turbines and gas engines operating for less than 500 hours per year are considered to be emergency plant and therefore were not covered by the emission limits set out in IED Annex V. However, for the purposes of the LCP BAT review, plants operated for emergency use may only be defined as plants which operate for the sole purpose of providing power at a site during an onsite emergency and/or during a black start and which do not provide balancing services or demand side response services. As this site runs commercially on an intermittent basis to support the Grid, it is not considered emergency plant and therefore indicative BAT applies. However, there are no indicative BAT AELs for either NO<sub>x</sub> or CO for open cycle gas turbines fuelled on natural gas, which operate for <500 hours per year and which were permitted before the publication of the Bref but put into operation after 27 November 2003. Therefore, on this basis we have not set any emission limits for these LCPs as part of this review.

#### **4.2 The energy efficiency levels associated with the Best Available Techniques Conclusions**

An energy efficiency level associated with the best available techniques (BAT-AEEL) refers to the ratio between the combustion unit's net energy output(s) and the combustion unit's fuel/feedstock energy input at actual unit design. The net energy output(s) is determined at the combustion unit boundaries, including auxiliary systems (e.g. flue-gas treatment systems), and for the unit operated at full load.

Table 23 of the LCP BAT Conclusions specifies that the BAT-AEELs for this type of plant are not applicable to plant operating less than 1500 hours per year. We have not, therefore, assessed this operational aspect of the plant. We have however included a process monitoring requirement in table S3.4 of the consolidated variation notice. This is required to demonstrate that efficiency levels are maintained following any significant overhauls of equipment in order to fulfil the requirement of BAT Conclusion 2. For <500 hour plant we have specified that the assessment of efficiency can be based on calculation. This is because we will not require plant to fire up with the sole purpose of carrying out an assessment of efficiency.

#### **4.3 The review and assessment of BAT for gas turbines operating <500 hours per year**

The Joint Environmental Programme (JEP) produced a document '*BAT Assessment for Existing Gas and Liquid Fuel Fired OCGTs, CCGTs and Dual-fuel GTs with a Thermal Input Rating of 50MWth or Greater Operating <500 Hours Per Year*' dated October 2018. The content of this document has been agreed in principle by the Environment Agency and we have therefore taken the document into account during our determination of this variation.

The LCPs at the site are of a type that is included in the JEP document, GE Frame 9, although the operator has not specified if they are from 1988 or 1993. For each type there are measures that could be fitted to reduce the level of NOx. The operator has completed the flow chart in the JEP document and has concluded that although there are technologies available to reduce NOx emissions, the cost of retro-fitting either dry low NOx or water injection NOx reduction measures outweighs the benefits that would be derived from the reduction in NOx. This is the case for either the 1988 or 1993 GE Frame 9 equipment.

The cost benefit analysis (Appendix A to the JEP document) concludes that retrofitting Dry Low NOx and Wet Low Emissions to existing OCGTs firing natural gas or gas oil, and operating for less than 500 hour per year, is not justified from a cost-benefit perspective, meaning there is insufficient environmental benefit in reducing the already low annual mass emission, when considering the high conversion costs.

Therefore, we agree with the operator's conclusion that the minimum BAT requirements are considered to be:

- i) the continued compliance with any permit requirements already in place to protect air quality; and
- ii) the demonstration of an appropriate maintenance regime to maintain plant emissions performance.

## 5 Decision checklist regarding relevant BAT Conclusions

BAT Conclusions for large combustion plant, were published by the European Commission on 17<sup>th</sup> August 2017. There are 75 BAT Conclusions. Only the BAT Conclusions relevant to the particular fuel type used on site have been replicated below.

This annex provides a record of decisions made in relation to each relevant BAT Conclusion applicable to the installation. This annex should be read in conjunction with the Consolidated Variation Notice.

The conditions in the permit through which the relevant BAT Conclusions are implemented include but are not limited to the following:

BAT Conclusion requirement topic	Permit condition(s)	Permit table(s)
Environmental Management System	1.1.1	S1.2
BAT AELs	N/A	N/A
Monitoring	2.3, 3.5 and 3.6	S1.4 and S1.2
Energy efficiency	1.2 and 2.3	S3.4
Noise	3.4 and 2.3	S1.2
Other operating techniques	2.3	S1.2

The overall status of compliance with the BAT conclusion is indicated in the table as:

- NA Not Applicable
- CC Currently Compliant
- FC Compliant in the future (within 4 years of publication of BAT conclusions)
- NC Not Compliant
- PC Partially Compliant

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
<b>General</b>			
1	<p><b>In order to improve the overall environmental performance, BAT is to implement and adhere to an environmental management system (EMS) that incorporates all of the following features:</b></p> <ul style="list-style-type: none"> <li>i. commitment of the management, including senior management;</li> <li>ii. definition of an environmental policy that includes the continuous improvement of the installation by the management;</li> <li>iii. planning and establishing the necessary procedures, objectives and targets, in conjunction with financial planning and investment;</li> <li>iv. implementation of procedures <ul style="list-style-type: none"> <li>(a) Structure and responsibility</li> <li>(b) Training</li> <li>(c) Communication</li> <li>(d) Employee involvement</li> <li>(e) Documentation</li> <li>(f) Efficient process control</li> <li>(g) Maintenance programmes</li> <li>(h) Emergency preparedness and response</li> <li>(i) Safeguarding compliance with environmental legislation</li> </ul> </li> <li>v. checking performance and taking corrective action, paying particular attention to: <ul style="list-style-type: none"> <li>(a) monitoring and measurement (see also the Reference Document on the General Principles of Monitoring)</li> <li>(b) corrective and preventive action</li> <li>(c) maintenance of records</li> <li>(d) independent (where practicable) internal and external auditing in order to determine whether or not the EMS conforms to planned arrangements and has been properly implemented and maintained;</li> </ul> </li> <li>vi. review of the EMS and its continuing suitability, adequacy and effectiveness by senior management;</li> <li>vii. following the development of cleaner technologies;</li> <li>viii. consideration for the environmental impacts from the eventual decommissioning of the installation at the stage of designing a new plant, and throughout its operating life;</li> <li>viii. consideration for the environmental impacts from the eventual decommissioning of the installation at the stage of designing a new plant, and throughout its operating life;</li> <li>ix. application of sectoral benchmarking on a regular basis.</li> </ul>	CC	<p>The operator provided the following response:</p> <p>The station operates an EMS which is fully integrated and certified to ISO14001: 2015 Certificate No: 246955/2017/AE/GBR/UKAS. The EMS incorporates all the features described in BAT1 (i to Xiii), and the site has site specific procedures and systems in place to address relevant topics listed in BAT1 x to xvi where practicable to do so.</p> <p>xi - see response to BAT 10/11.</p> <p>xiv - It is not considered necessary to have a dust management plan as the fuel used is natural gas and therefore it is not considered to be an environmental risk. However, there are procedures in place to review any complaints received which could be used if issues related to dust were to arise.</p> <p>xv - Noise nuisance is not expected nor sustained at sensitive receptors. The site has specific procedures and systems in place to address noise.</p> <p>xvi - It is not considered necessary to have an odour management plan as the operation does not involve the combustion of malodorous substances, therefore this is not considered to be an environmental risk. However, there are procedures in place to review any complaints received which could be used if issues related to odour were to arise.</p> <p>We agree with the operator's assessment of compliance.</p>

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC/ FC/ NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement													
	<p>Etc - see BAT Conclusions</p> <p><b>Applicability.</b> The scope (e.g. level of detail) and nature of the EMS (e.g. standardised or non-standardised) will generally be related to the nature, scale and complexity of the installation, and the range of environmental impacts it may have.</p>															
2	<p>BAT is to determine the net electrical efficiency and/or the net total fuel utilisation and/or the net mechanical energy efficiency of the gasification, IGCC and/or combustion units by carrying out a performance test at full load (1), according to EN standards, after the commissioning of the unit and after each modification that could significantly affect the net electrical efficiency and/or the net total fuel utilisation and/or the net mechanical energy efficiency of the unit. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.</p>	CC	<p>The operator provided the following response:</p> <p>The site has a net electrical efficiency of 32.05%, determined by a performance test at full load to ISO conditions. Performance tests will be carried out after any modification that could significantly affect the net electrical efficiency. Further details are in the BAT 40 response.</p> <p>We agree with the operator's assessment of compliance.</p> <p>A process monitoring requirement has been set in table S3.4 which requires energy efficiency monitoring after an overhaul.</p>													
3	<p><b>BAT is to monitor key process parameters relevant for emissions to air and water including those given below.</b></p> <table border="1" data-bbox="338 1027 1285 1276"> <thead> <tr> <th data-bbox="338 1027 633 1062">Stream</th> <th data-bbox="633 1027 987 1062">Parameter(s)</th> <th data-bbox="987 1027 1285 1062">Monitoring</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 1062 633 1219" rowspan="3">Flue-gas</td> <td data-bbox="633 1062 987 1123">Flow</td> <td data-bbox="987 1062 1285 1123">Periodic or continuous determination</td> </tr> <tr> <td data-bbox="633 1123 987 1184">Oxygen content, temperature, and pressure</td> <td data-bbox="987 1123 1285 1184">Periodic or continuous measurement</td> </tr> <tr> <td data-bbox="633 1184 987 1219">Water vapour content (2)</td> <td data-bbox="987 1184 1285 1219"></td> </tr> <tr> <td data-bbox="338 1219 633 1276">Waste water from flue-gas treatment</td> <td data-bbox="633 1219 987 1276">Flow, pH, and temperature</td> <td data-bbox="987 1219 1285 1276">Continuous measurement</td> </tr> </tbody> </table>	Stream	Parameter(s)	Monitoring	Flue-gas	Flow	Periodic or continuous determination	Oxygen content, temperature, and pressure	Periodic or continuous measurement	Water vapour content (2)		Waste water from flue-gas treatment	Flow, pH, and temperature	Continuous measurement	NA	<p>We do not require monitoring of these parameters where no periodic or continuous monitoring is required. There is no flue gas treatment at the site.</p>
Stream	Parameter(s)	Monitoring														
Flue-gas	Flow	Periodic or continuous determination														
	Oxygen content, temperature, and pressure	Periodic or continuous measurement														
	Water vapour content (2)															
Waste water from flue-gas treatment	Flow, pH, and temperature	Continuous measurement														
4	<p>BAT is to monitor emissions to air with at least the frequency given below and in accordance with EN standards. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.</p>	CC	<p>The operator states that this is not applicable as the current permit does not require monitoring; the site does not monitor CO and NOx continuously, as the BAT-AELs</p>													

BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC/ FC/ NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement					
Substance /Parameter	Fuel/Process/Type of combustion plant	Combustion plant total rated thermal input	Standard(s) <sup>(4)</sup>	Minimum monitoring frequency <sup>(5)</sup>	Monitoring associated with	<p>do not apply to plants operated &lt; 500 h/yr and that annual limits do not apply and daily limits for NOx are indicative only.</p> <p>We agree with the operator's assessment, although not that daily limits of NOx are indicative. Indicative limits for NOx apply to plant put into operation before November 2003, which is not the case for these LCPs. The monitoring frequencies described in BAT 4 do not apply where plant operation would be for the sole purpose of performing an emission measurement. As the plant operates for &lt;500 hours per year, continuous monitoring is therefore, not required. Concentrations of NOx, CO and SO<sub>2</sub> are calculated every 2 years based on fuel usage and emissions factors.</p>							
NH <sub>3</sub>	— When SCR and/or SNCR is used	All sizes	Generic EN standards	Continuous <sup>(6)</sup> <sup>(7)</sup>	BAT 7								
NO <sub>x</sub>	<ul style="list-style-type: none"> <li>— Coal and/or lignite including waste co-incineration</li> <li>— Solid biomass and/or peat including waste co-incineration</li> <li>— HFO- and/or gas-oil-fired boilers and engines</li> <li>— Gas-oil-fired gas turbines</li> <li>— Natural-gas-fired boilers, engines, and turbines</li> <li>— Iron and steel process gases</li> <li>— Process fuels from the chemical industry</li> <li>— IGCC plants</li> </ul>	All sizes	Generic EN standards	Continuous <sup>(6)</sup> <sup>(8)</sup>	BAT 20 BAT 24 BAT 28 BAT 32 BAT 37 BAT 41 BAT 42 BAT 43 BAT 47 BAT 48 BAT 56 BAT 64 BAT 65 BAT 73								
N <sub>2</sub> O	<ul style="list-style-type: none"> <li>— Coal and/or lignite in circulating fluidised bed boilers</li> <li>— Solid biomass and/or peat in</li> </ul>	All sizes	EN 21258	Once every year <sup>(10)</sup>	BAT 20 BAT 24								
	— Combustion plants on offshore platforms	All sizes	EN 14792	Once every year <sup>(9)</sup>	BAT 53								

BAT Concn. Number	Summary of BAT Conclusion requirement					Status NA/ CC/ FC/ NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
		circulating fluidised bed boilers					
	CO	<ul style="list-style-type: none"> <li>— Coal and/or lignite including waste co-incineration</li> <li>— Solid biomass and/or peat including waste co-incineration</li> <li>— HFO- and/or gas-oil-fired boilers and engines</li> <li>— Gas-oil-fired gas turbines</li> <li>— Natural-gas-fired boilers, engines, and turbines</li> <li>— Iron and steel process gases</li> <li>— Process fuels from the chemical industry</li> <li>— IGCC plants</li> </ul>	All sizes	Generic EN standards	Continuous <sup>(6)</sup> <sup>(8)</sup>	BAT 20 BAT 24 BAT 28 BAT 33 BAT 38 BAT 44 BAT 49 BAT 56 BAT 64 BAT 65 BAT 73	
		— Combustion plants on offshore platforms	All sizes	EN 15058	Once every year <sup>(9)</sup>	BAT 54	
	SO <sub>2</sub>	<ul style="list-style-type: none"> <li>— Coal and/or lignite incl waste co-incineration</li> <li>— Solid biomass and/or peat incl waste co-incineration</li> <li>— HFO- and/or gas-oil-fired boilers</li> </ul>	All sizes	Generic EN standards and EN 14791	Continuous <sup>(6)</sup> <sup>(11)</sup> <sup>(12)</sup>	BAT 21 BAT 25 BAT 29 BAT 34 BAT 39 BAT 50 BAT 57 BAT 66 BAT 67 BAT 74	

BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC/ FC/ NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
		<ul style="list-style-type: none"> <li>— HFO- and/or gas-oil-fired engines</li> <li>— Gas-oil-fired gas turbines</li> <li>— Iron and steel process gases</li> <li>— Process fuels from the chemical industry in boilers</li> <li>— IGCC plants</li> </ul>						
	SO <sub>3</sub>	— When SCR is used	All sizes	No EN standard available	Once every year	—		
	Gaseous chlorides, expressed as HCl	<ul style="list-style-type: none"> <li>— Coal and/or lignite</li> <li>— Process fuels from the chemical industry in boilers</li> </ul>	All sizes	EN 1911	Once every three months <sup>(6)</sup> <sup>(13)</sup> <sup>(14)</sup>	BAT 21 BAT 57		
		— Solid biomass and/or peat	All sizes	Generic EN standards	Continuous <sup>(15)</sup> <sup>(16)</sup>	BAT 25		
		— Waste co-incineration	All sizes	Generic EN standards	Continuous <sup>(6)</sup> <sup>(16)</sup>	BAT 66 BAT 67		
	HF	<ul style="list-style-type: none"> <li>— Coal and/or lignite</li> <li>— Process fuels from the chemical industry in boilers</li> </ul>	All sizes	No EN standard available	Once every three months <sup>(6)</sup> <sup>(13)</sup> <sup>(14)</sup>	BAT 21 BAT 57		
		— Solid biomass and/or peat	All sizes	No EN standard available	Once every year	BAT 25		
		— Waste co-incineration	All sizes	Generic EN standards	Continuous <sup>(6)</sup> <sup>(16)</sup>	BAT 66 BAT 67		
	Dust	<ul style="list-style-type: none"> <li>— Coal and/or lignite</li> <li>— Solid biomass and/or peat</li> </ul>	All sizes	Generic EN standards and EN 13284-1 and EN 13284-2	Continuous <sup>(6)</sup> <sup>(17)</sup>	BAT 22 BAT 26 BAT 30 BAT 35 BAT 39		



BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC/ FC/ NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
		<ul style="list-style-type: none"> <li>— HFO- and/or gas-oil-fired boilers</li> <li>— Iron and steel process gases</li> <li>— Process fuels from the chemical industry in boilers</li> <li>— IGCC plants</li> <li>— HFO- and/or gas-oil-fired engines</li> <li>— Gas-oil-fired gas turbines</li> </ul>				BAT 51 BAT 58 BAT 75		
		<ul style="list-style-type: none"> <li>— Waste co-incineration</li> </ul>	All sizes	Generic EN standards and EN 13284-2	Continuous	BAT 68 BAT 69		
Metals and metalloids except mercury (As, Cd, Co, Cr, Cu, Mn, Ni, Pb, Sb, Se, Tl, V, Zn)		<ul style="list-style-type: none"> <li>— Coal and/or lignite</li> <li>— Solid biomass and/or peat</li> <li>— HFO- and/or gas-oil-fired boilers and engines</li> </ul>	All sizes	EN 14385	Once every year <sup>(18)</sup>	BAT 22 BAT 26 BAT 30		
		<ul style="list-style-type: none"> <li>— Waste co-incineration</li> </ul>	< 300 MW <sub>th</sub>	EN 14385	Once every six months <sup>(13)</sup>	BAT 68 BAT 69		
			≥ 300 MW <sub>th</sub>	EN 14385	Once every three months <sup>(19)</sup> <sub>(13)</sub>			
		<ul style="list-style-type: none"> <li>— IGCC plants</li> </ul>	≥ 100 MW <sub>th</sub>	EN 14385	Once every year <sup>(18)</sup>	BAT 75		
Hg		<ul style="list-style-type: none"> <li>— Coal and/or lignite including waste co-incineration</li> </ul>	< 300 MW <sub>th</sub>	EN 13211	Once every three months <sup>(13)</sup> <sub>(20)</sub>	BAT 23		
			≥ 300 MW <sub>th</sub>	Generic EN standards and EN 14884	Continuous <sup>(16)</sup> <sub>(21)</sub>			
		<ul style="list-style-type: none"> <li>— Solid biomass and/or peat</li> </ul>	All sizes	EN 13211	Once every year <sup>(22)</sup>	BAT 27		

BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC/ FC/ NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement								
		— Waste co-incineration with solid biomass and/or peat	All sizes	EN 13211	Once every three months <sup>(13)</sup>	BAT 70										
		— IGCC plants	≥ 100 MW <sub>th</sub>	EN 13211	Once every year <sup>(23)</sup>	BAT 75										
	TVOC	— HFO- and/or gas-oil-fired engines — Process fuels from chemical industry in boilers	All sizes	EN 12619	Once every six months <sup>(13)</sup>	BAT 33 BAT 59										
		— Waste co-incineration with coal, lignite, solid biomass and/or peat	All sizes	Generic EN standards	Continuous	BAT 71										
	Formaldehyde	— Natural-gas in spark-ignited lean-burn gas and dual fuel engines	All sizes	No EN standard available	Once every year	BAT 45										
	CH <sub>4</sub>	— Natural-gas-fired engines	All sizes	EN ISO 25139	Once every year <sup>(24)</sup>	BAT 45										
	PCDD/F	— Process fuels from chemical industry in boilers — Waste co-incineration	All sizes	EN 1948-1, EN 1948-2, EN 1948-3	Once every six months <sup>(13)</sup> <sup>(25)</sup>	BAT 59 BAT 71										
5	<p>BAT is to monitor emissions to water from flue-gas treatment with at least the frequency given below and in accordance with EN standards. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.</p> <table border="1" data-bbox="349 1270 1285 1353"> <thead> <tr> <th data-bbox="349 1270 618 1353">Substance/Parameter</th> <th data-bbox="618 1270 909 1353">Standard(s)</th> <th data-bbox="909 1270 1099 1353">Minimum monitoring frequency</th> <th data-bbox="1099 1270 1285 1353">Monitoring associated with</th> </tr> </thead> <tbody> <tr> <td> </td> <td> </td> <td> </td> <td> </td> </tr> </tbody> </table>						Substance/Parameter	Standard(s)	Minimum monitoring frequency	Monitoring associated with					NA	There is no treatment of flue gas so this is not applicable.
Substance/Parameter	Standard(s)	Minimum monitoring frequency	Monitoring associated with													

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC/ FC/ NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																																	
	<table border="1"> <tr> <td>Total organic carbon (TOC)<sub>(26)</sub></td> <td>EN 1484</td> <td rowspan="10">Once every month</td> <td rowspan="10">BAT 15</td> </tr> <tr> <td>Chemical oxygen demand (COD)<sub>(26)</sub></td> <td>No EN standard available</td> </tr> <tr> <td>Total suspended solids (TSS)</td> <td>EN 872</td> </tr> <tr> <td>Fluoride (F<sup>-</sup>)</td> <td>EN ISO 10304-1</td> </tr> <tr> <td>Sulphate (SO<sub>4</sub><sup>2-</sup>)</td> <td>EN ISO 10304-1</td> </tr> <tr> <td>Sulphide, easily released (S<sup>2-</sup>)</td> <td>No EN standard available</td> </tr> <tr> <td>Sulphite (SO<sub>3</sub><sup>2-</sup>)</td> <td>EN ISO 10304-3</td> </tr> <tr> <td rowspan="7">Metals and metalloids</td> <td>As</td> <td rowspan="7">Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)</td> </tr> <tr> <td>Cd</td> </tr> <tr> <td>Cr</td> </tr> <tr> <td>Cu</td> </tr> <tr> <td>Ni</td> </tr> <tr> <td>Pb</td> </tr> <tr> <td>Zn</td> </tr> <tr> <td>Hg</td> <td>Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)</td> </tr> <tr> <td>Chloride (Cl<sup>-</sup>)</td> <td>Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)</td> <td>—</td> </tr> <tr> <td>Total nitrogen</td> <td>EN 12260</td> <td>—</td> </tr> </table>	Total organic carbon (TOC) <sub>(26)</sub>	EN 1484	Once every month	BAT 15	Chemical oxygen demand (COD) <sub>(26)</sub>	No EN standard available	Total suspended solids (TSS)	EN 872	Fluoride (F <sup>-</sup> )	EN ISO 10304-1	Sulphate (SO <sub>4</sub> <sup>2-</sup> )	EN ISO 10304-1	Sulphide, easily released (S <sup>2-</sup> )	No EN standard available	Sulphite (SO <sub>3</sub> <sup>2-</sup> )	EN ISO 10304-3	Metals and metalloids	As	Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)	Cd	Cr	Cu	Ni	Pb	Zn	Hg	Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)	Chloride (Cl <sup>-</sup> )	Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)	—	Total nitrogen	EN 12260	—		
Total organic carbon (TOC) <sub>(26)</sub>	EN 1484	Once every month	BAT 15																																	
Chemical oxygen demand (COD) <sub>(26)</sub>	No EN standard available																																			
Total suspended solids (TSS)	EN 872																																			
Fluoride (F <sup>-</sup> )	EN ISO 10304-1																																			
Sulphate (SO <sub>4</sub> <sup>2-</sup> )	EN ISO 10304-1																																			
Sulphide, easily released (S <sup>2-</sup> )	No EN standard available																																			
Sulphite (SO <sub>3</sub> <sup>2-</sup> )	EN ISO 10304-3																																			
Metals and metalloids	As					Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)																														
	Cd																																			
	Cr																																			
	Cu																																			
	Ni																																			
	Pb																																			
	Zn																																			
Hg	Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)																																			
Chloride (Cl <sup>-</sup> )	Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)	—																																		
Total nitrogen	EN 12260	—																																		
6	<p>In order to improve the general environmental performance of combustion plants and to reduce emissions to air of CO and unburnt substances, BAT is to ensure optimised combustion and to use an appropriate combination of the techniques given below.</p> <table border="1"> <thead> <tr> <th>Technique</th> <th>Description</th> <th>Applicability</th> </tr> </thead> <tbody> <tr> <td></td> <td></td> <td></td> </tr> </tbody> </table>	Technique	Description	Applicability				CC	<p>The operator has responded as follows:</p> <p>a) Stable combustion conditions are achieved as natural gas is used for the fuel and this is sourced from the national transmission system with composition &amp;</p>																											
Technique	Description	Applicability																																		

BAT Concn. Number	Summary of BAT Conclusion requirement				Statu s NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	a	Fuel blending and mixing	Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type	Generally applicable		<p>uniformity which is controlled in line with national standards.</p> <p>b) Regular planned maintenance is carried out according to manufacturer's recommendations. Hot gas path inspections and minor and major maintenance outages are based on factored fired starts. Periodic invasive inspections are completed to monitor condition of the combustion components.</p> <p>c) The site has an advanced control and monitoring system. This automated control system optimises combustion temperature and efficiency during running. There is also a PI system for high-performance monitoring.</p> <p>d) The plant was designed by the OEM (original equipment manufacturer). The BREF document notes that this is generally only applicable to new combustion plants.</p> <p>e) Natural gas is used for the site. Low sulphur fuel. This is compliant with the BAT.</p> <p>We agree with the operator's assessment of compliance.</p>
b	Maintenance of the combustion system	Regular planned maintenance according to suppliers' recommendations				
c.	Advanced control system	See description in Section 8.1	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system			
d	Good design of the combustion equipment	Good design of furnace, combustion chambers, burners and associated devices	Generally applicable to new combustion plants			
e	Fuel choice	Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used	Applicable within the constraints associated with the availability of suitable types of fuel with a better environmental profile as a whole, which may be impacted by the energy policy of the Member State, or by the integrated site's fuel balance in the case of combustion of industrial process fuels. For existing combustion plants, the type of fuel chosen may be limited by the configuration and the design of the plant			

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC/ FC/ NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
7	<p>In order to reduce emissions of ammonia to air from the use of selective catalytic reduction (SCR) and/or selective non-catalytic reduction (SNCR) for the abatement of NO<sub>x</sub> emissions, BAT is to optimise the design and/or operation of SCR and/or SNCR (e.g. optimised reagent to NO<sub>x</sub> ratio, homogeneous reagent distribution and optimum size of the reagent drops).</p> <p><b>BAT-associated emission levels</b> The BAT-associated emission level (BAT-AEL) for emissions of NH<sub>3</sub> to air from the use of SCR and/or SNCR is &lt; 3–10 mg/Nm<sup>3</sup> as a yearly average or average over the sampling period. The lower end of the range can be achieved when using SCR and the upper end of the range can be achieved when using SNCR without wet abatement techniques. In the case of plants combusting biomass and operating at variable loads as well as in the case of engines combusting HFO and/or gas oil, the higher end of the BAT-AEL range is 15 mg/Nm<sup>3</sup>.</p>	NA	This is not applicable as no abatement of emissions using SCR or SNCR is required.
8	<p>In order to prevent or reduce emissions to air during normal operating conditions, BAT is to ensure, by appropriate design, operation and maintenance, that the emission abatement systems are used at optimal capacity and availability.</p>	NA	<p>The operator has responded as follows:</p> <p>In order to reduce emissions during normal operating conditions, fuel air mixes are optimised, and maintenance programmes are carried out. Units are under constant monitoring and periodical invasive sample inspections to monitor condition of the combustion components. As noted in BAT 42, an assessment has shown that it is not appropriate to retrofit low NO<sub>x</sub> combustors for an OCGT that operates for &lt; 500 h/yr.</p> <p>We do not agree with the operator's assessment of compliance. There is no abatement fitted to the LCPs so this BAT Conclusion is not applicable.</p>
9	<p>In order to improve the general environmental performance of combustion and/or gasification plants and to reduce emissions to air, BAT is to include the following elements in the quality assurance/quality control programmes for all the fuels used, as part of the environmental management system (see BAT 1):</p> <p>(i) Initial full characterisation of the fuel used including at least the parameters listed below and in accordance with EN standards. ISO, national or other international standards may be used provided they ensure the provision of data of an equivalent scientific quality;</p>	CC	<p>The operator responded as follows:</p> <p>N/A - The site uses natural gas supplied via the national Transmission System and the fuel supplied is controlled in line with national standards.</p>

BAT Concn. Number	Summary of BAT Conclusion requirement	Statu s NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																			
	<p>(ii) Regular testing of the fuel quality to check that it is consistent with the initial characterisation and according to the plant design specifications. The frequency of testing and the parameters chosen from the table below are based on the variability of the fuel and an assessment of the relevance of pollutant releases (e.g. concentration in fuel, flue-gas treatment employed);</p> <p>(iii) Subsequent adjustment of the plant settings as and when needed and practicable (e.g. integration of the fuel characterisation and control in the advanced control system (see description in Section 8.1)).</p> <p><b>Description</b> Initial characterisation and regular testing of the fuel can be performed by the operator and/or the fuel supplier. If performed by the supplier, the full results are provided to the operator in the form of a product (fuel) supplier specification and/or guarantee.</p> <table border="1" data-bbox="338 691 1285 1382"> <thead> <tr> <th data-bbox="338 691 656 722">Fuel(s)</th> <th data-bbox="656 691 1285 722">Substances/Parameters subject to characterisation</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 722 656 932" rowspan="3">Biomass/peat</td> <td data-bbox="656 722 1285 767">— LHV</td> </tr> <tr> <td data-bbox="656 767 1285 812">— moisture</td> </tr> <tr> <td data-bbox="656 812 1285 932">— Ash — C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn)</td> </tr> <tr> <td data-bbox="338 932 656 1169" rowspan="4">Coal/lignite</td> <td data-bbox="656 932 1285 976">— LHV</td> </tr> <tr> <td data-bbox="656 976 1285 1021">— Moisture</td> </tr> <tr> <td data-bbox="656 1021 1285 1066">— Volatiles, ash, fixed carbon, C, H, N, O, S</td> </tr> <tr> <td data-bbox="656 1066 1285 1169">— Br, Cl, F — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Ti, V, Zn)</td> </tr> <tr> <td data-bbox="338 1169 656 1252" rowspan="2">HFO</td> <td data-bbox="656 1169 1285 1214">— Ash</td> </tr> <tr> <td data-bbox="656 1214 1285 1252">— C, S, N, Ni, V</td> </tr> <tr> <td data-bbox="338 1252 656 1335" rowspan="2">Gas oil</td> <td data-bbox="656 1252 1285 1297">— Ash</td> </tr> <tr> <td data-bbox="656 1297 1285 1335">— N, C, S</td> </tr> <tr> <td data-bbox="338 1335 656 1382">Natural gas</td> <td data-bbox="656 1335 1285 1382">— LHV</td> </tr> </tbody> </table>	Fuel(s)	Substances/Parameters subject to characterisation	Biomass/peat	— LHV	— moisture	— Ash — C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn)	Coal/lignite	— LHV	— Moisture	— Volatiles, ash, fixed carbon, C, H, N, O, S	— Br, Cl, F — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Ti, V, Zn)	HFO	— Ash	— C, S, N, Ni, V	Gas oil	— Ash	— N, C, S	Natural gas	— LHV		<p>We agree that no further characterisation is required above that provided by the supplier, however, we do not agree that BAT 9 is not applicable to the site. Characterisation of natural gas is included in BAT 9.</p> <p>We consider that for plants which burn natural gas from the National Grid as a fuel that it is not necessary for the operator to replicate the testing carried out by the National Grid.</p>
Fuel(s)	Substances/Parameters subject to characterisation																					
Biomass/peat	— LHV																					
	— moisture																					
	— Ash — C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn)																					
Coal/lignite	— LHV																					
	— Moisture																					
	— Volatiles, ash, fixed carbon, C, H, N, O, S																					
	— Br, Cl, F — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Ti, V, Zn)																					
HFO	— Ash																					
	— C, S, N, Ni, V																					
Gas oil	— Ash																					
	— N, C, S																					
Natural gas	— LHV																					

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC/ FC/ NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement								
	<table border="1"> <tr> <td data-bbox="338 384 658 432"></td> <td data-bbox="658 384 1285 432">— CH<sub>4</sub>, C<sub>2</sub>H<sub>6</sub>, C<sub>3</sub>, C<sub>4+</sub>, CO<sub>2</sub>, N<sub>2</sub>, Wobbe index</td> </tr> <tr> <td data-bbox="338 432 658 539">Process fuels from the chemical industry<sup>[27]</sup></td> <td data-bbox="658 432 1285 539">— Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Ti, V, Zn)</td> </tr> <tr> <td data-bbox="338 539 658 611">Iron and steel process gases</td> <td data-bbox="658 539 1285 611">— LHV, CH<sub>4</sub> (for COG), C<sub>x</sub>H<sub>y</sub> (for COG), CO<sub>2</sub>, H<sub>2</sub>, N<sub>2</sub>, total sulphur, dust, Wobbe index</td> </tr> <tr> <td data-bbox="338 611 658 791">Waste<sup>[28]</sup></td> <td data-bbox="658 611 1285 791">— LHV — Moisture — Volatiles, ash, Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Ti, V, Zn)</td> </tr> </table>		— CH <sub>4</sub> , C <sub>2</sub> H <sub>6</sub> , C <sub>3</sub> , C <sub>4+</sub> , CO <sub>2</sub> , N <sub>2</sub> , Wobbe index	Process fuels from the chemical industry <sup>[27]</sup>	— Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Ti, V, Zn)	Iron and steel process gases	— LHV, CH <sub>4</sub> (for COG), C <sub>x</sub> H <sub>y</sub> (for COG), CO <sub>2</sub> , H <sub>2</sub> , N <sub>2</sub> , total sulphur, dust, Wobbe index	Waste <sup>[28]</sup>	— LHV — Moisture — Volatiles, ash, Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Ti, V, Zn)		
	— CH <sub>4</sub> , C <sub>2</sub> H <sub>6</sub> , C <sub>3</sub> , C <sub>4+</sub> , CO <sub>2</sub> , N <sub>2</sub> , Wobbe index										
Process fuels from the chemical industry <sup>[27]</sup>	— Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Ti, V, Zn)										
Iron and steel process gases	— LHV, CH <sub>4</sub> (for COG), C <sub>x</sub> H <sub>y</sub> (for COG), CO <sub>2</sub> , H <sub>2</sub> , N <sub>2</sub> , total sulphur, dust, Wobbe index										
Waste <sup>[28]</sup>	— LHV — Moisture — Volatiles, ash, Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Ti, V, Zn)										
10	<p>In order to reduce emissions to air and/or to water during other than normal operating conditions (OTNOC), BAT is to set up and implement a management plan as part of the environmental management system (see BAT 1), commensurate with the relevance of potential pollutant releases, that includes the following elements:</p> <ul style="list-style-type: none"> <li>— appropriate design of the systems considered relevant in causing OTNOC that may have an impact on emissions to air, water and/or soil (e.g. low-load design concepts for reducing the minimum start-up and shutdown loads for stable generation in gas turbines),</li> <li>— set-up and implementation of a specific preventive maintenance plan for these relevant systems,</li> <li>— review and recording of emissions caused by OTNOC and associated circumstances and implementation of corrective actions if necessary,</li> <li>— periodic assessment of the overall emissions during OTNOC (e.g. frequency of events, duration, emissions quantification/estimation) and implementation of corrective actions if necessary.</li> </ul>	CC	<p>The operator responded as follows:</p> <p>Sites do not have a specific OTNOC management plan, however the EMS incorporates many of the key aspects of BAT 10 &amp; 11. The site operates a risk based review with the EMS (Aspects and impacts) which includes a review of potential impacts of OTNOC. A) Gas turbine starts are optimised based on plant condition to minimise emissions during start-up. B) All plant components are included within the site specific preventative maintenance programmes, the frequency of maintenance is dependent on operation of the site.</p> <p>We agree with the operator's assessment of compliance.</p>								
11	<p>BAT is to appropriately monitor emissions to air and/or to water during OTNOC.</p> <p><b>Description</b></p> <p>The monitoring can be carried out by direct measurement of emissions or by monitoring of surrogate parameters if this proves to be of equal or better scientific quality than the direct measurement of emissions. Emissions during start-up and shutdown (SU/SD) may be assessed based on a detailed emission measurement carried out for a typical SU/SD</p>	CC	<p>The operator has responded as follows:</p> <p>Emissions during start up and shut down operations are surrogately monitored by gas usage. This is reviewed to identify if corrective actions are required. Start up and shut down gas usage is assessed. In the event of an</p>								

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																		
	procedure at least once every year, and using the results of this measurement to estimate the emissions for each and every SU/SD throughout the year.		<p>accident or environmental incident, we would review the emissions, cause etc as part of our incident investigation process and ensure any relevant corrective and / or preventive action is implemented.</p> <p>We agree with the operator's assessment of compliance.</p>																		
12	<p>In order to increase the energy efficiency of combustion, gasification and/or IGCC units operated <math>\geq 1\,500</math> h/yr, BAT is to use an appropriate combination of the techniques given below.</p> <table border="1" data-bbox="338 679 1285 1390"> <thead> <tr> <th data-bbox="338 679 551 715">Technique</th> <th data-bbox="551 679 936 715">Description</th> <th data-bbox="936 679 1285 715">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 715 551 847">a. Combustion optimisation</td> <td data-bbox="551 715 936 847">See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues</td> <td data-bbox="936 715 1285 1390" rowspan="4">Generally applicable</td> </tr> <tr> <td data-bbox="338 847 551 1031">b. Optimisation of the working medium conditions</td> <td data-bbox="551 847 936 1031">Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO<sub>x</sub> emissions or the characteristics of energy demanded</td> </tr> <tr> <td data-bbox="338 1031 551 1166">c. Optimisation of the steam cycle</td> <td data-bbox="551 1031 936 1166">Operate with lower turbine exhaust pressure by utilisation of the lowest possible temperature of the condenser cooling water, within the design conditions</td> </tr> <tr> <td data-bbox="338 1166 551 1246">d. Minimisation of energy consumption</td> <td data-bbox="551 1166 936 1246">Minimising the internal energy consumption (e.g. greater efficiency of the feed-water pump)</td> </tr> <tr> <td data-bbox="338 1246 551 1334">e. Preheating of combustion air</td> <td data-bbox="551 1246 936 1334">Reuse of part of the heat recovered from the combustion flue-gas to preheat the air used in combustion</td> <td data-bbox="936 1246 1285 1334">Generally applicable within the constraints related to the need to control NO<sub>x</sub> emissions</td> </tr> <tr> <td data-bbox="338 1334 551 1390">f. Fuel preheating</td> <td data-bbox="551 1334 936 1390">Preheating of fuel using recovered heat</td> <td data-bbox="936 1334 1285 1390">Generally applicable within the constraints associated with the</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Combustion optimisation	See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues	Generally applicable	b. Optimisation of the working medium conditions	Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO <sub>x</sub> emissions or the characteristics of energy demanded	c. Optimisation of the steam cycle	Operate with lower turbine exhaust pressure by utilisation of the lowest possible temperature of the condenser cooling water, within the design conditions	d. Minimisation of energy consumption	Minimising the internal energy consumption (e.g. greater efficiency of the feed-water pump)	e. Preheating of combustion air	Reuse of part of the heat recovered from the combustion flue-gas to preheat the air used in combustion	Generally applicable within the constraints related to the need to control NO <sub>x</sub> emissions	f. Fuel preheating	Preheating of fuel using recovered heat	Generally applicable within the constraints associated with the	NA	We agree with the operator's assessment that this is not applicable as the plant does not operate for more than 1500 hours per year.
Technique	Description	Applicability																			
a. Combustion optimisation	See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues	Generally applicable																			
b. Optimisation of the working medium conditions	Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO <sub>x</sub> emissions or the characteristics of energy demanded																				
c. Optimisation of the steam cycle	Operate with lower turbine exhaust pressure by utilisation of the lowest possible temperature of the condenser cooling water, within the design conditions																				
d. Minimisation of energy consumption	Minimising the internal energy consumption (e.g. greater efficiency of the feed-water pump)																				
e. Preheating of combustion air	Reuse of part of the heat recovered from the combustion flue-gas to preheat the air used in combustion	Generally applicable within the constraints related to the need to control NO <sub>x</sub> emissions																			
f. Fuel preheating	Preheating of fuel using recovered heat	Generally applicable within the constraints associated with the																			



BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
				boiler design and the need to control NO <sub>x</sub> emissions	
	g.	Advanced control system	See description in Section 8.2. Computerised control of the main combustion parameters enables the combustion efficiency to be improved	Generally applicable to new units. The applicability to old units may be constrained by the need to retrofit the combustion system and/or control command system	
	h.	Feed-water preheating using recovered heat	Preheat water coming out of the steam condenser with recovered heat, before reusing it in the boiler	Only applicable to steam circuits and not to hot boilers. Applicability to existing units may be limited due to constraints associated with the plant configuration and the amount of recoverable heat	
	i.	Heat recovery by cogeneration (CHP)	Recovery of heat (mainly from the steam system) for producing hot water/steam to be used in industrial processes/activities or in a public network for district heating. Additional heat recovery is possible from: <ul style="list-style-type: none"> <li>— flue-gas</li> <li>— grate cooling</li> <li>— circulating fluidised bed</li> </ul>	Applicable within the constraints associated with the local heat and power demand. The applicability may be limited in the case of gas compressors with an unpredictable operational heat profile	
	j.	CHP readiness	See description in Section 8.2.	Only applicable to new units where there is a realistic potential for the future use of heat in the vicinity of the unit	
	k.	Flue-gas condenser	See description in Section 8.2.	Generally applicable to CHP units provided there is enough demand for low-temperature heat	
	l.	Heat accumulation	Heat accumulation storage in CHP mode	Only applicable to CHP plants. The applicability may be limited in the case of low heat load demand	
	m.	Wet stack	See description in Section 8.2.	Generally applicable to new and existing units fitted with wet FGD	

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	n.	Cooling tower discharge	The release of emissions to air through a cooling tower and not via a dedicated stack	Only applicable to units fitted with wet FGD where reheating of the flue-gas is necessary before release, and where the unit cooling system is a cooling tower	
	o.	Fuel pre-drying	The reduction of fuel moisture content before combustion to improve combustion conditions	Applicable to the combustion of biomass and/or peat within the constraints associated with spontaneous combustion risks (e.g. the moisture content of peat is kept above 40 % throughout the delivery chain). The retrofit of existing plants may be restricted by the extra calorific value that can be obtained from the drying operation and by the limited retrofit possibilities offered by some boiler designs or plant configurations	
	p.	Minimisation of heat losses	Minimising residual heat losses, e.g. those that occur via the slag or those that can be reduced by insulating radiating sources	Only applicable to solid-fuel-fired combustion units and to gasification/IGCC units	
	q.	Advanced materials	Use of advanced materials proven to be capable of withstanding high operating temperatures and pressures and thus to achieve increased steam/combustion process efficiencies	Only applicable to new plants	
	r.	Steam turbine upgrades	This includes techniques such as increasing the temperature and pressure of medium-pressure steam, addition of a low-pressure turbine, and modifications to the geometry of the turbine rotor blades	The applicability may be restricted by demand, steam conditions and/or limited plant lifetime	
	s.	Supercritical and ultra-supercritical	Use of a steam circuit, including steam reheating systems, in which steam can reach pressures above 220,6 bar and temperatures above 374 °C in the case	Only applicable to new units of $\geq 600 \text{ MW}_{th}$ operated $> 4\,000 \text{ h/yr}$ . Not applicable when the purpose of the unit is to produce low steam	

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement												
		steam conditions	of supercritical conditions, and above 250 – 300 bar and temperatures above 580 – 600 °C in the case of ultra-supercritical conditions	temperatures and/or pressures in process industries. Not applicable to gas turbines and engines generating steam in CHP mode. For units combusting biomass, the applicability may be constrained by high-temperature corrosion in the case of certain biomasses													
13	In order to reduce water usage and the volume of contaminated waste water discharged, BAT is to use one or both of the techniques given below.			CC	<p>The operator responded as follows:</p> <p>The site has minimal water usage and closed circuit cooling water systems are used which have minimal consumption. Water usage is optimised and minimised where plant design allows.</p> <p>We agree with the operator's assessment of compliance and, in addition, as natural gas is used as the fuel, no ash is produced.</p>												
	<table border="1"> <thead> <tr> <th data-bbox="322 687 376 719"></th> <th data-bbox="376 687 501 719">Technique</th> <th data-bbox="501 687 943 719">Description</th> <th data-bbox="943 687 1301 719">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 719 376 879">a.</td> <td data-bbox="376 719 501 879">Water recycling</td> <td data-bbox="501 719 943 879">Residual aqueous streams, including run-off water, from the plant are reused for other purposes. The degree of recycling is limited by the quality requirements of the recipient water stream and the water balance of the plant</td> <td data-bbox="943 719 1301 879">Not applicable to waste water from cooling systems when water treatment chemicals and/or high concentrations of salts from seawater are present</td> </tr> <tr> <td data-bbox="322 879 376 1023">b.</td> <td data-bbox="376 879 501 1023">Dry bottom ash handling</td> <td data-bbox="501 879 943 1023">Dry, hot bottom ash falls from the furnace onto a mechanical conveyor system and is cooled down by ambient air. No water is used in the process.</td> <td data-bbox="943 879 1301 1023">Only applicable to plants combusting solid fuels. There may be technical restrictions that prevent retrofitting to existing combustion plants</td> </tr> </tbody> </table>		Technique	Description	Applicability	a.	Water recycling	Residual aqueous streams, including run-off water, from the plant are reused for other purposes. The degree of recycling is limited by the quality requirements of the recipient water stream and the water balance of the plant	Not applicable to waste water from cooling systems when water treatment chemicals and/or high concentrations of salts from seawater are present	b.	Dry bottom ash handling	Dry, hot bottom ash falls from the furnace onto a mechanical conveyor system and is cooled down by ambient air. No water is used in the process.	Only applicable to plants combusting solid fuels. There may be technical restrictions that prevent retrofitting to existing combustion plants				
	Technique	Description	Applicability														
a.	Water recycling	Residual aqueous streams, including run-off water, from the plant are reused for other purposes. The degree of recycling is limited by the quality requirements of the recipient water stream and the water balance of the plant	Not applicable to waste water from cooling systems when water treatment chemicals and/or high concentrations of salts from seawater are present														
b.	Dry bottom ash handling	Dry, hot bottom ash falls from the furnace onto a mechanical conveyor system and is cooled down by ambient air. No water is used in the process.	Only applicable to plants combusting solid fuels. There may be technical restrictions that prevent retrofitting to existing combustion plants														
14	<p>In order to prevent the contamination of uncontaminated waste water and to reduce emissions to water, BAT is to segregate waste water streams and to treat them separately, depending on the pollutant content.</p> <p><b>Description</b> Waste water streams that are typically segregated and treated include surface run-off water, cooling water, and waste water from flue-gas treatment.</p> <p><b>Applicability</b> The applicability may be restricted in the case of existing plants due to the configuration of the drainage systems.</p>			CC	<p>The operator has responded as follows:</p> <p>Peterborough Power Station does not have a process waste water discharge. Surface water run off is discharged via the surface water drains and does not require any treatment. There are a number of interceptors on the site.</p> <p>We agree with the operator's assessment of compliance.</p>												
15	In order to reduce emissions to water from flue-gas treatment, BAT is to use an appropriate combination of the techniques given below, and to use secondary techniques as close as possible to the source in order to avoid dilution.			NA	There is no requirement for treatment of flue gas.												

BAT Concn. Number	Summary of BAT Conclusion requirement			Statu s NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																																										
	<table border="1"> <thead> <tr> <th data-bbox="338 384 656 443">Technique</th> <th data-bbox="656 384 909 443">Typical pollutants prevented/abated</th> <th data-bbox="909 384 1281 443">Applicability</th> </tr> </thead> <tbody> <tr> <td colspan="3" data-bbox="338 443 1281 480" style="text-align: center;"><b>Primary techniques</b></td> </tr> <tr> <td data-bbox="338 480 656 592">a. Optimised combustion (see BAT 6) and flue-gas treatment systems (e.g. SCR/SNCR, see BAT 7)</td> <td data-bbox="656 480 909 592">Organic compounds, ammonia (NH<sub>3</sub>)</td> <td data-bbox="909 480 1281 592">Generally applicable</td> </tr> <tr> <td colspan="3" data-bbox="338 592 1281 628" style="text-align: center;"><b>Secondary techniques<sup>(29)</sup></b></td> </tr> <tr> <td data-bbox="338 628 656 683">b. Adsorption on activated carbon</td> <td data-bbox="656 628 909 683">Organic compounds, mercury (Hg)</td> <td data-bbox="909 628 1281 683">Generally applicable</td> </tr> <tr> <td data-bbox="338 683 656 842">c. Aerobic biological treatment</td> <td data-bbox="656 683 909 842">Biodegradable organic compounds, ammonium (NH<sub>4</sub><sup>+</sup>)</td> <td data-bbox="909 683 1281 842">Generally applicable for the treatment of organic compounds. Aerobic biological treatment of ammonium (NH<sub>4</sub><sup>+</sup>) may not be applicable in the case of high chloride concentrations (i.e. around 10 g/l)</td> </tr> <tr> <td data-bbox="338 842 656 896">d. Anoxic/anaerobic biological treatment</td> <td data-bbox="656 842 909 896">Mercury (Hg), nitrate (NO<sub>3</sub><sup>-</sup>), nitrite (NO<sub>2</sub><sup>-</sup>)</td> <td data-bbox="909 842 1281 896">Generally applicable</td> </tr> <tr> <td data-bbox="338 896 656 951">e. Coagulation and flocculation</td> <td data-bbox="656 896 909 951">Suspended solids</td> <td data-bbox="909 896 1281 951">Generally applicable</td> </tr> <tr> <td data-bbox="338 951 656 1046">f. Crystallisation</td> <td data-bbox="656 951 909 1046">Metals and metalloids, sulphate (SO<sub>4</sub><sup>2-</sup>), fluoride (F<sup>-</sup>)</td> <td data-bbox="909 951 1281 1046">Generally applicable</td> </tr> <tr> <td data-bbox="338 1046 656 1142">g. Filtration (e.g. sand filtration, microfiltration, ultrafiltration)</td> <td data-bbox="656 1046 909 1142">Suspended solids, metals</td> <td data-bbox="909 1046 1281 1142">Generally applicable</td> </tr> <tr> <td data-bbox="338 1142 656 1197">h. Flotation</td> <td data-bbox="656 1142 909 1197">Suspended solids, free oil</td> <td data-bbox="909 1142 1281 1197">Generally applicable</td> </tr> <tr> <td data-bbox="338 1197 656 1251">i. Ion exchange</td> <td data-bbox="656 1197 909 1251">Metals</td> <td data-bbox="909 1197 1281 1251">Generally applicable</td> </tr> <tr> <td data-bbox="338 1251 656 1305">j. Neutralisation</td> <td data-bbox="656 1251 909 1305">Acids, alkalis</td> <td data-bbox="909 1251 1281 1305">Generally applicable</td> </tr> <tr> <td data-bbox="338 1305 656 1318">k. Oxidation</td> <td data-bbox="656 1305 909 1318">Sulphide (S<sup>2-</sup>), sulphite (SO<sub>3</sub><sup>2-</sup>)</td> <td data-bbox="909 1305 1281 1318">Generally applicable</td> </tr> </tbody> </table>			Technique	Typical pollutants prevented/abated	Applicability	<b>Primary techniques</b>			a. Optimised combustion (see BAT 6) and flue-gas treatment systems (e.g. SCR/SNCR, see BAT 7)	Organic compounds, ammonia (NH <sub>3</sub> )	Generally applicable	<b>Secondary techniques<sup>(29)</sup></b>			b. Adsorption on activated carbon	Organic compounds, mercury (Hg)	Generally applicable	c. Aerobic biological treatment	Biodegradable organic compounds, ammonium (NH <sub>4</sub> <sup>+</sup> )	Generally applicable for the treatment of organic compounds. Aerobic biological treatment of ammonium (NH <sub>4</sub> <sup>+</sup> ) may not be applicable in the case of high chloride concentrations (i.e. around 10 g/l)	d. Anoxic/anaerobic biological treatment	Mercury (Hg), nitrate (NO <sub>3</sub> <sup>-</sup> ), nitrite (NO <sub>2</sub> <sup>-</sup> )	Generally applicable	e. Coagulation and flocculation	Suspended solids	Generally applicable	f. Crystallisation	Metals and metalloids, sulphate (SO <sub>4</sub> <sup>2-</sup> ), fluoride (F <sup>-</sup> )	Generally applicable	g. Filtration (e.g. sand filtration, microfiltration, ultrafiltration)	Suspended solids, metals	Generally applicable	h. Flotation	Suspended solids, free oil	Generally applicable	i. Ion exchange	Metals	Generally applicable	j. Neutralisation	Acids, alkalis	Generally applicable	k. Oxidation	Sulphide (S <sup>2-</sup> ), sulphite (SO <sub>3</sub> <sup>2-</sup> )	Generally applicable		
Technique	Typical pollutants prevented/abated	Applicability																																													
<b>Primary techniques</b>																																															
a. Optimised combustion (see BAT 6) and flue-gas treatment systems (e.g. SCR/SNCR, see BAT 7)	Organic compounds, ammonia (NH <sub>3</sub> )	Generally applicable																																													
<b>Secondary techniques<sup>(29)</sup></b>																																															
b. Adsorption on activated carbon	Organic compounds, mercury (Hg)	Generally applicable																																													
c. Aerobic biological treatment	Biodegradable organic compounds, ammonium (NH <sub>4</sub> <sup>+</sup> )	Generally applicable for the treatment of organic compounds. Aerobic biological treatment of ammonium (NH <sub>4</sub> <sup>+</sup> ) may not be applicable in the case of high chloride concentrations (i.e. around 10 g/l)																																													
d. Anoxic/anaerobic biological treatment	Mercury (Hg), nitrate (NO <sub>3</sub> <sup>-</sup> ), nitrite (NO <sub>2</sub> <sup>-</sup> )	Generally applicable																																													
e. Coagulation and flocculation	Suspended solids	Generally applicable																																													
f. Crystallisation	Metals and metalloids, sulphate (SO <sub>4</sub> <sup>2-</sup> ), fluoride (F <sup>-</sup> )	Generally applicable																																													
g. Filtration (e.g. sand filtration, microfiltration, ultrafiltration)	Suspended solids, metals	Generally applicable																																													
h. Flotation	Suspended solids, free oil	Generally applicable																																													
i. Ion exchange	Metals	Generally applicable																																													
j. Neutralisation	Acids, alkalis	Generally applicable																																													
k. Oxidation	Sulphide (S <sup>2-</sup> ), sulphite (SO <sub>3</sub> <sup>2-</sup> )	Generally applicable																																													

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement												
	<table border="1"> <tr> <td data-bbox="338 384 376 411">l.</td> <td data-bbox="383 384 645 411">Precipitation</td> <td data-bbox="656 384 909 467">Metals and metalloids, sulphate (SO<sub>4</sub><sup>2-</sup>), fluoride (F<sup>-</sup>)</td> <td data-bbox="909 384 1285 411">Generally applicable</td> </tr> <tr> <td data-bbox="338 467 376 494">m.</td> <td data-bbox="383 467 645 494">Sedimentation</td> <td data-bbox="656 467 909 494">Suspended solids</td> <td data-bbox="909 467 1285 494">Generally applicable</td> </tr> <tr> <td data-bbox="338 494 376 539">n.</td> <td data-bbox="383 494 645 539">Stripping</td> <td data-bbox="656 494 909 539">Ammonia (NH<sub>3</sub>)</td> <td data-bbox="909 494 1285 539">Generally applicable</td> </tr> </table>	l.	Precipitation	Metals and metalloids, sulphate (SO <sub>4</sub> <sup>2-</sup> ), fluoride (F <sup>-</sup> )	Generally applicable	m.	Sedimentation	Suspended solids	Generally applicable	n.	Stripping	Ammonia (NH <sub>3</sub> )	Generally applicable				
l.	Precipitation	Metals and metalloids, sulphate (SO <sub>4</sub> <sup>2-</sup> ), fluoride (F <sup>-</sup> )	Generally applicable														
m.	Sedimentation	Suspended solids	Generally applicable														
n.	Stripping	Ammonia (NH <sub>3</sub> )	Generally applicable														
16	<p>In order to reduce the quantity of waste sent for disposal from the combustion and/or gasification process and abatement techniques, BAT is to organise operations so as to maximise, in order of priority and taking into account life-cycle thinking:</p> <p>(a) waste prevention, e.g. maximise the proportion of residues which arise as by-products;</p>			CC	<p>The operator has responded as follows:</p> <p>The waste hierarchy is implemented on site, and steps for waste reduction continue to be taken where applicable. None of the four techniques in the BAT are relevant to the</p>												

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC/ FC/ NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement															
	<p>(b) waste preparation for reuse, e.g. according to the specific requested quality criteria;</p> <p>(c) waste recycling;</p> <p>(d) other waste recovery (e.g. energy recovery),</p> <p>by implementing an appropriate combination of techniques such as:</p> <table border="1" data-bbox="338 533 1285 1273"> <thead> <tr> <th data-bbox="338 533 546 564">Technique</th> <th data-bbox="546 533 958 564">Description</th> <th data-bbox="958 533 1285 564">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 564 546 775">a. Generation of gypsum as a by-product</td> <td data-bbox="546 564 958 775">Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g. as raw material in the plasterboard industry). The quality of limestone used in the wet FGD influences the purity of the gypsum produced</td> <td data-bbox="958 564 1285 775">Generally applicable within the constraints associated with the required gypsum quality, the health requirements associated to each specific use, and by the market conditions</td> </tr> <tr> <td data-bbox="338 775 546 954">b. Recycling or recovery of residues in the construction sector</td> <td data-bbox="546 775 958 954">Recycling or recovery of residues (e.g. from semi-dry desulphurisation processes, fly ash, bottom ash) as a construction material (e.g. in road building, to replace sand in concrete production, or in the cement industry)</td> <td data-bbox="958 775 1285 954">Generally applicable within the constraints associated with the required material quality (e.g. physical properties, content of harmful substances) associated to each specific use, and by the market conditions</td> </tr> <tr> <td data-bbox="338 954 546 1091">c. Energy recovery by using waste in the fuel mix</td> <td data-bbox="546 954 958 1091">The residual energy content of carbon-rich ash and sludges generated by the combustion of coal, lignite, heavy fuel oil, peat or biomass can be recovered for example by mixing with the fuel</td> <td data-bbox="958 954 1285 1091">Generally applicable where plants can accept waste in the fuel mix and are technically able to feed the fuels into the combustion chamber</td> </tr> <tr> <td data-bbox="338 1091 546 1273">d. Preparation of spent catalyst for reuse</td> <td data-bbox="546 1091 958 1273">Preparation of catalyst for reuse (e.g. up to four times for SCR catalysts) restores some or all of the original performance, extending the service life of the catalyst to several decades. Preparation of spent catalyst for reuse is integrated in a catalyst management scheme</td> <td data-bbox="958 1091 1285 1273">The applicability may be limited by the mechanical condition of the catalyst and the required performance with respect to controlling NO<sub>x</sub> and NH<sub>3</sub> emissions</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Generation of gypsum as a by-product	Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g. as raw material in the plasterboard industry). The quality of limestone used in the wet FGD influences the purity of the gypsum produced	Generally applicable within the constraints associated with the required gypsum quality, the health requirements associated to each specific use, and by the market conditions	b. Recycling or recovery of residues in the construction sector	Recycling or recovery of residues (e.g. from semi-dry desulphurisation processes, fly ash, bottom ash) as a construction material (e.g. in road building, to replace sand in concrete production, or in the cement industry)	Generally applicable within the constraints associated with the required material quality (e.g. physical properties, content of harmful substances) associated to each specific use, and by the market conditions	c. Energy recovery by using waste in the fuel mix	The residual energy content of carbon-rich ash and sludges generated by the combustion of coal, lignite, heavy fuel oil, peat or biomass can be recovered for example by mixing with the fuel	Generally applicable where plants can accept waste in the fuel mix and are technically able to feed the fuels into the combustion chamber	d. Preparation of spent catalyst for reuse	Preparation of catalyst for reuse (e.g. up to four times for SCR catalysts) restores some or all of the original performance, extending the service life of the catalyst to several decades. Preparation of spent catalyst for reuse is integrated in a catalyst management scheme	The applicability may be limited by the mechanical condition of the catalyst and the required performance with respect to controlling NO <sub>x</sub> and NH <sub>3</sub> emissions		<p>site. The site uses a clean fuel source and no solid waste is generated from the natural gas.</p> <p>We agree with the operator's assessment of compliance.</p>
Technique	Description	Applicability																
a. Generation of gypsum as a by-product	Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g. as raw material in the plasterboard industry). The quality of limestone used in the wet FGD influences the purity of the gypsum produced	Generally applicable within the constraints associated with the required gypsum quality, the health requirements associated to each specific use, and by the market conditions																
b. Recycling or recovery of residues in the construction sector	Recycling or recovery of residues (e.g. from semi-dry desulphurisation processes, fly ash, bottom ash) as a construction material (e.g. in road building, to replace sand in concrete production, or in the cement industry)	Generally applicable within the constraints associated with the required material quality (e.g. physical properties, content of harmful substances) associated to each specific use, and by the market conditions																
c. Energy recovery by using waste in the fuel mix	The residual energy content of carbon-rich ash and sludges generated by the combustion of coal, lignite, heavy fuel oil, peat or biomass can be recovered for example by mixing with the fuel	Generally applicable where plants can accept waste in the fuel mix and are technically able to feed the fuels into the combustion chamber																
d. Preparation of spent catalyst for reuse	Preparation of catalyst for reuse (e.g. up to four times for SCR catalysts) restores some or all of the original performance, extending the service life of the catalyst to several decades. Preparation of spent catalyst for reuse is integrated in a catalyst management scheme	The applicability may be limited by the mechanical condition of the catalyst and the required performance with respect to controlling NO <sub>x</sub> and NH <sub>3</sub> emissions																
17	<p>In order to reduce noise emissions, BAT is to use one or a combination of the techniques given below.</p> <table border="1" data-bbox="338 1347 1285 1378"> <thead> <tr> <th data-bbox="338 1347 546 1378">Technique</th> <th data-bbox="546 1347 958 1378">Description</th> <th data-bbox="958 1347 1285 1378">Applicability</th> </tr> </thead> <tbody> </tbody> </table>	Technique	Description	Applicability	CC	The operator responded as follows:												
Technique	Description	Applicability																

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	a. Operational measures	These include: — improved inspection and maintenance of equipment — closing of doors and windows of enclosed areas, if possible — equipment operated by experienced staff — avoidance of noisy activities at night, if possible — provisions for noise control during maintenance activities	Generally applicable		<p>Noise is reduced through operational measures including all those detailed in a). Where possible, low-noise equipment is utilised. High-noise equipment is contained within buildings and equipment insulation is used where applicable. The GTs are within an enclosure within the building designed for noise attenuation.</p> <p>We agree with the operator's assessment of compliance.</p>
b. Low-noise equipment	This potentially includes compressors, pumps and disks	Generally applicable when the equipment is new or replaced			
c. Noise attenuation	Noise propagation can be reduced by inserting obstacles between the emitter and the receiver. Appropriate obstacles include protection walls, embankments and buildings	Generally applicable to new plants. In the case of existing plants, the insertion of obstacles may be restricted by lack of space			
d. Noise-control equipment	This includes: — noise-reducers — equipment insulation — enclosure of noisy equipment — soundproofing of buildings	The applicability may be restricted by lack of space			
e. Appropriate location of equipment and buildings	Noise levels can be reduced by increasing the distance between the emitter and the receiver and by using buildings as noise screens	Generally applicable to new plant			
<b>Combustion of solid fuels only</b>					
18 - 27	Not applicable – the LCPs burn natural gas				
<b>Combustion of liquid fuels</b>					

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC/ FC/ NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																																																			
Table 13, 28 - 39	Not applicable – the LCPs burn natural gas																																																					
<b>Combustion of gaseous fuels</b>																																																						
40	<p>In order to increase the energy efficiency of natural gas combustion, BAT is to use an appropriate combination of the techniques given in BAT 12 and below.</p> <table border="1" data-bbox="338 555 1285 903"> <thead> <tr> <th data-bbox="338 555 488 619">Technique</th> <th data-bbox="488 555 672 619">Description</th> <th data-bbox="672 555 1285 619">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 619 488 903">a. Combined cycle</td> <td data-bbox="488 619 672 903">See description in Section 8.2</td> <td data-bbox="672 619 1285 903">Generally applicable to new gas turbines and engines except when operated &lt; 1 500 h/yr. Applicable to existing gas turbines and engines within the constraints associated with the steam cycle design and the space availability. Not applicable to existing gas turbines and engines operated &lt; 1 500 h/yr. Not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns. Not applicable to boilers</td> </tr> </tbody> </table> <p><b>BAT-associated energy efficiency levels (BAT-AEELs) for the combustion of natural gas</b></p> <table border="1" data-bbox="338 959 1285 1358"> <thead> <tr> <th data-bbox="338 959 555 1118" rowspan="3">Type of combustion unit</th> <th colspan="5" data-bbox="555 959 1285 995">BAT-AEELs <sup>(136)</sup> <sup>(137)</sup></th> </tr> <tr> <th colspan="2" data-bbox="555 995 770 1054">Net electrical efficiency (%)</th> <th data-bbox="770 995 994 1054" rowspan="2">Net total fuel utilisation (%) <sup>(138)</sup> <sup>(139)</sup></th> <th colspan="2" data-bbox="994 995 1285 1054">Net mechanical energy efficiency (%) <sup>(139)</sup> <sup>(140)</sup></th> </tr> <tr> <th data-bbox="555 1054 651 1118">New unit</th> <th data-bbox="651 1054 770 1118">Existing unit</th> <th data-bbox="994 1054 1122 1118">New unit</th> <th data-bbox="1122 1054 1285 1118">Existing unit</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 1118 555 1177">Gas engine</td> <td data-bbox="555 1118 651 1177">39,5–44 <sup>(141)</sup></td> <td data-bbox="651 1118 770 1177">35–44 <sup>(141)</sup></td> <td data-bbox="770 1118 994 1177">56–85 <sup>(141)</sup></td> <td colspan="2" data-bbox="994 1118 1285 1177">No BAT-AEEL.</td> </tr> <tr> <td data-bbox="338 1177 555 1214">Gas-fired boiler</td> <td data-bbox="555 1177 651 1214">39–42,5</td> <td data-bbox="651 1177 770 1214">38–40</td> <td data-bbox="770 1177 994 1214">78–95</td> <td colspan="2" data-bbox="994 1177 1285 1214">No BAT-AEEL.</td> </tr> <tr> <td data-bbox="338 1214 555 1278">Open cycle gas turbine, ≥ 50 MW<sub>th</sub></td> <td data-bbox="555 1214 651 1278">36–41,5</td> <td data-bbox="651 1214 770 1278">33–41,5</td> <td data-bbox="770 1214 994 1278">No BAT-AEEL</td> <td data-bbox="994 1214 1122 1278">36,5–41</td> <td data-bbox="1122 1214 1285 1278">33,5–41</td> </tr> <tr> <td colspan="6" data-bbox="338 1278 1285 1315" style="text-align: center;"><b>Combined cycle gas turbine (CCGT)</b></td> </tr> <tr> <td data-bbox="338 1315 555 1358">CCGT, 50–600 MW<sub>th</sub></td> <td data-bbox="555 1315 651 1358">53–58,5</td> <td data-bbox="651 1315 770 1358">46–54</td> <td data-bbox="770 1315 994 1358">No BAT-AEEL</td> <td colspan="2" data-bbox="994 1315 1285 1358">No BAT-AEEL</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Combined cycle	See description in Section 8.2	Generally applicable to new gas turbines and engines except when operated < 1 500 h/yr. Applicable to existing gas turbines and engines within the constraints associated with the steam cycle design and the space availability. Not applicable to existing gas turbines and engines operated < 1 500 h/yr. Not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns. Not applicable to boilers	Type of combustion unit	BAT-AEELs <sup>(136)</sup> <sup>(137)</sup>					Net electrical efficiency (%)		Net total fuel utilisation (%) <sup>(138)</sup> <sup>(139)</sup>	Net mechanical energy efficiency (%) <sup>(139)</sup> <sup>(140)</sup>		New unit	Existing unit	New unit	Existing unit	Gas engine	39,5–44 <sup>(141)</sup>	35–44 <sup>(141)</sup>	56–85 <sup>(141)</sup>	No BAT-AEEL.		Gas-fired boiler	39–42,5	38–40	78–95	No BAT-AEEL.		Open cycle gas turbine, ≥ 50 MW <sub>th</sub>	36–41,5	33–41,5	No BAT-AEEL	36,5–41	33,5–41	<b>Combined cycle gas turbine (CCGT)</b>						CCGT, 50–600 MW <sub>th</sub>	53–58,5	46–54	No BAT-AEEL	No BAT-AEEL		NA	<p>Although the operator states that this is not applicable as the LCPs operate for less than 1500 hours, they have provided the following response:</p> <p>The site has a net electrical efficiency of 32.05%, determined by a performance test at full load to ISO conditions. The plant efficiency is greater than the efficiency threshold of 29.7% for existing OCGT &amp; gas fuel plant shown in table 2 of the Environment Agency document “BAT guidance for &gt;50MW<sub>th</sub> gas and liquid fuel combustion plant exporting electricity under commercial arrangements for &lt;1500 hours per annum” (Working draft ver 1.0 17/08/2018). Table 1 of this document (Plant operational constraints) shows the plant to be a category B plant, with NO<sub>x</sub> emissions below the threshold value and efficiency above the threshold value therefore allowing a maximum period of commercial generation per annum of 500 hours. Performance tests will be carried out after any modification that could significantly affect the net electrical efficiency.</p> <p>We agree with the operator’s assessment and have included a requirement in table S3.4 of the permit for performance tests to be carried out following any modifications to the plant. In addition, the gas turbines at the facility are open cycle, operated for less than 500 hours, therefore the techniques specified in BAT 12 and BAT 40 are not applicable. These BAT-AEELs do not apply to units operated less than 1500 hours per year.</p>
Technique	Description	Applicability																																																				
a. Combined cycle	See description in Section 8.2	Generally applicable to new gas turbines and engines except when operated < 1 500 h/yr. Applicable to existing gas turbines and engines within the constraints associated with the steam cycle design and the space availability. Not applicable to existing gas turbines and engines operated < 1 500 h/yr. Not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns. Not applicable to boilers																																																				
Type of combustion unit	BAT-AEELs <sup>(136)</sup> <sup>(137)</sup>																																																					
	Net electrical efficiency (%)		Net total fuel utilisation (%) <sup>(138)</sup> <sup>(139)</sup>	Net mechanical energy efficiency (%) <sup>(139)</sup> <sup>(140)</sup>																																																		
	New unit	Existing unit		New unit	Existing unit																																																	
Gas engine	39,5–44 <sup>(141)</sup>	35–44 <sup>(141)</sup>	56–85 <sup>(141)</sup>	No BAT-AEEL.																																																		
Gas-fired boiler	39–42,5	38–40	78–95	No BAT-AEEL.																																																		
Open cycle gas turbine, ≥ 50 MW <sub>th</sub>	36–41,5	33–41,5	No BAT-AEEL	36,5–41	33,5–41																																																	
<b>Combined cycle gas turbine (CCGT)</b>																																																						
CCGT, 50–600 MW <sub>th</sub>	53–58,5	46–54	No BAT-AEEL	No BAT-AEEL																																																		



BAT Concn. Number	Summary of BAT Conclusion requirement					Status NA/ CC/ FC/ NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																			
	CCGT, $\geq 600 \text{ MW}_{th}$	57–60,5	50–60	No BAT-AEEL	No BAT-AEEL																					
	CHP CCGT, 50–600 $\text{MW}_{th}$	53–58,5	46–54	65–95	No BAT-AEEL																					
	CHP CCGT, $\geq 600 \text{ MW}_{th}$	57–60,5	50–60	65–95	No BAT-AEEL		The LCPs at the site are gas turbines and not boilers.																			
41	In order to prevent or reduce $\text{NO}_x$ emissions to air from the combustion of natural gas in boilers, BAT is to use one or a combination of the techniques given below.					NA	The LCPs at the site are gas turbines and not boilers.																			
	<table border="1"> <thead> <tr> <th data-bbox="322 608 557 647">Technique</th> <th data-bbox="557 608 909 647">Description</th> <th data-bbox="909 608 1294 647">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 647 557 727">a Air and/or fuel staging</td> <td data-bbox="557 647 909 727">See descriptions in Section 8.3. Air staging is often associated with low-<math>\text{NO}_x</math> burners</td> <td data-bbox="909 647 1294 727" rowspan="3">Generally applicable</td> </tr> <tr> <td data-bbox="322 727 557 791">b Flue-gas recirculation</td> <td data-bbox="557 727 909 791">See description in Section 8.3</td> </tr> <tr> <td data-bbox="322 791 557 855">c Low-<math>\text{NO}_x</math> burners (LNB)</td> <td data-bbox="557 791 909 855"></td> </tr> <tr> <td data-bbox="322 855 557 1007">d Advanced control system</td> <td data-bbox="557 855 909 1007">See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated &lt; 500 h/yr</td> <td data-bbox="909 855 1294 1007">The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> <tr> <td data-bbox="322 1007 557 1094">e Reduction of the combustion air temperature</td> <td data-bbox="557 1007 909 1094" rowspan="3">See description in Section 8.3</td> <td data-bbox="909 1007 1294 1094">Generally applicable within the constraints associated with the process needs</td> </tr> <tr> <td data-bbox="322 1094 557 1278">f Selective non-catalytic reduction (SNCR)</td> <td data-bbox="909 1094 1294 1278">Not applicable to combustion plants operated &lt; 500 h/yr with highly variable boiler loads. The applicability may be limited in the case of combustion plants operated between 500 h/yr and 1 500 h/yr with highly variable boiler loads</td> </tr> <tr> <td data-bbox="322 1278 557 1390">g Selective catalytic reduction (SCR)</td> <td data-bbox="909 1278 1294 1390">Not applicable to combustion plants operated &lt; 500 h/yr. Not generally applicable to combustion plants of &lt; 100 <math>\text{MW}_{th}</math>.</td> </tr> </tbody> </table>						Technique	Description	Applicability	a Air and/or fuel staging	See descriptions in Section 8.3. Air staging is often associated with low- $\text{NO}_x$ burners	Generally applicable	b Flue-gas recirculation	See description in Section 8.3	c Low- $\text{NO}_x$ burners (LNB)		d Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system	e Reduction of the combustion air temperature	See description in Section 8.3	Generally applicable within the constraints associated with the process needs	f Selective non-catalytic reduction (SNCR)	Not applicable to combustion plants operated < 500 h/yr with highly variable boiler loads. The applicability may be limited in the case of combustion plants operated between 500 h/yr and 1 500 h/yr with highly variable boiler loads	g Selective catalytic reduction (SCR)	Not applicable to combustion plants operated < 500 h/yr. Not generally applicable to combustion plants of < 100 $\text{MW}_{th}$ .
Technique	Description	Applicability																								
a Air and/or fuel staging	See descriptions in Section 8.3. Air staging is often associated with low- $\text{NO}_x$ burners	Generally applicable																								
b Flue-gas recirculation	See description in Section 8.3																									
c Low- $\text{NO}_x$ burners (LNB)																										
d Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system																								
e Reduction of the combustion air temperature	See description in Section 8.3	Generally applicable within the constraints associated with the process needs																								
f Selective non-catalytic reduction (SNCR)		Not applicable to combustion plants operated < 500 h/yr with highly variable boiler loads. The applicability may be limited in the case of combustion plants operated between 500 h/yr and 1 500 h/yr with highly variable boiler loads																								
g Selective catalytic reduction (SCR)		Not applicable to combustion plants operated < 500 h/yr. Not generally applicable to combustion plants of < 100 $\text{MW}_{th}$ .																								

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC/ FC/ NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																							
			There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr																									
42	In order to prevent or reduce NO <sub>x</sub> emissions to air from the combustion of natural gas in gas turbines, BAT is to use one or a combination of the techniques given below.			CC	<p>The operator responded as follows:</p> <p>The site does not monitor CO and NO<sub>x</sub> continuously, as the BAT-AELs do not apply to plants operated &lt; 500 h/yr. Annual limits do not apply and daily limits for NO<sub>x</sub> are indicative only.</p> <p>Emissions performance of the OCGT remains stable, and the power station runs to site specific BAT in reference to the following two JEP documents: "BAT Assessment for Existing Gas &amp; Liquid Fuel Fired OCGTs, CCGTs &amp; Dual-fuel GTs with a Thermal Input Rating of 50 MWth or Greater Operating &lt;500 Hours Per Year" (JEP19AIB08 Issued October 2018) and "Maintaining the Emissions Performance of Open Cycle Gas Turbines that Operate for Less Than 500 Hours Per Year" (JEP17EMG02 Issued October 2018).</p> <p>Utilising the JEP screening approach and associated documents, BAT is equivalent to the currently permitted performance combined with an appropriate maintenance regime. The JEP screening approach flow diagram is included in the response to the Regulation 61 notice, and annotated to indicate the assessment route taken. Whilst a water injection system or a Dry Low NO<sub>x</sub> (DLN) combustor could (subject to a detailed technical assessment) potentially be retrofitted to reduce the NO<sub>x</sub> emissions, the BAT assessment given in the JEP document "Maintaining the Emissions Performance of Open Cycle Gas Turbines that operate for less than 500 hours per year" has shown that it is not appropriate to retrofit low NO<sub>x</sub> combustors for an OCGT that operates for &lt; 500 h/yr. The site operates GE Frame 9 gas</p>																							
	<table border="1"> <thead> <tr> <th data-bbox="338 568 371 600">Technique</th> <th data-bbox="517 568 965 600">Description</th> <th data-bbox="965 568 1301 600">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 600 371 735">a</td> <td data-bbox="371 600 517 735">Advanced control system</td> <td data-bbox="517 600 965 735">See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated &lt; 500 h/yr</td> <td data-bbox="965 600 1301 735">The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> <tr> <td data-bbox="338 735 371 799">b</td> <td data-bbox="371 735 517 799">Water/steam addition</td> <td data-bbox="517 735 965 799" rowspan="2">See description in Section 8.3</td> <td data-bbox="965 735 1301 799">The applicability may be limited due to water availability</td> </tr> <tr> <td data-bbox="338 799 371 927">c</td> <td data-bbox="371 799 517 927">Dry low-NO<sub>x</sub> burners (DLN)</td> <td data-bbox="965 799 1301 927">The applicability may be limited in the case of turbines where a retrofit package is not available or when water/steam addition systems are installed</td> </tr> <tr> <td data-bbox="338 927 371 1086">d</td> <td data-bbox="371 927 517 1086">Low-load design concept</td> <td data-bbox="517 927 965 1086">Adaptation of the process control and related equipment to maintain good combustion efficiency when the demand in energy varies, e.g. by improving the inlet airflow control capability or by splitting the combustion process into decoupled combustion stages</td> <td data-bbox="965 927 1301 1086">The applicability may be limited by the gas turbine design</td> </tr> <tr> <td data-bbox="338 1086 371 1246">e</td> <td data-bbox="371 1086 517 1246">Low-NO<sub>x</sub> burners (LNB)</td> <td data-bbox="517 1086 965 1246" rowspan="2">See description in Section 8.3</td> <td data-bbox="965 1086 1301 1246">Generally applicable to supplementary firing for heat recovery steam generators (HRSGs) in the case of combined-cycle gas turbine (CCGT) combustion plants</td> </tr> <tr> <td data-bbox="338 1246 371 1375">f</td> <td data-bbox="371 1246 517 1375">Selective catalytic reduction (SCR)</td> <td data-bbox="965 1246 1301 1375">Not applicable in the case of combustion plants operated &lt; 500 h/yr.</td> </tr> </tbody> </table>	Technique	Description	Applicability	a	Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system	b	Water/steam addition	See description in Section 8.3	The applicability may be limited due to water availability	c	Dry low-NO <sub>x</sub> burners (DLN)	The applicability may be limited in the case of turbines where a retrofit package is not available or when water/steam addition systems are installed	d	Low-load design concept	Adaptation of the process control and related equipment to maintain good combustion efficiency when the demand in energy varies, e.g. by improving the inlet airflow control capability or by splitting the combustion process into decoupled combustion stages	The applicability may be limited by the gas turbine design	e	Low-NO <sub>x</sub> burners (LNB)	See description in Section 8.3	Generally applicable to supplementary firing for heat recovery steam generators (HRSGs) in the case of combined-cycle gas turbine (CCGT) combustion plants	f	Selective catalytic reduction (SCR)	Not applicable in the case of combustion plants operated < 500 h/yr.		
Technique	Description	Applicability																										
a	Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system																									
b	Water/steam addition	See description in Section 8.3	The applicability may be limited due to water availability																									
c	Dry low-NO <sub>x</sub> burners (DLN)		The applicability may be limited in the case of turbines where a retrofit package is not available or when water/steam addition systems are installed																									
d	Low-load design concept	Adaptation of the process control and related equipment to maintain good combustion efficiency when the demand in energy varies, e.g. by improving the inlet airflow control capability or by splitting the combustion process into decoupled combustion stages	The applicability may be limited by the gas turbine design																									
e	Low-NO <sub>x</sub> burners (LNB)	See description in Section 8.3	Generally applicable to supplementary firing for heat recovery steam generators (HRSGs) in the case of combined-cycle gas turbine (CCGT) combustion plants																									
f	Selective catalytic reduction (SCR)		Not applicable in the case of combustion plants operated < 500 h/yr.																									

BAT Concn. Number	Summary of BAT Conclusion requirement			Statu s NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement						
			<p>Not generally applicable to existing combustion plants of &lt; 100 MW<sub>th</sub>. Retrofitting existing combustion plants may be constrained by the availability of sufficient space.</p> <p>There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr</p>		<p>turbines which are included in the data set for the study and hence, there is insufficient environmental benefit in reducing the already low annual mass emission, when considering the high conversion costs.</p> <p>CO formation is less than 100 mg/m<sup>3</sup> during normal operation and there is no BAT-AEL defined. Other emissions can be neglected since Natural Gas is an ash-free fuel, the combustion system is non-sooting and the residual fuel sulphur content is very low. Emissions reporting will continue to be based on Emission Factors and fixed emission concentrations which will be kept under review. The diffusion flame combustion system produces very stable NO<sub>x</sub> emissions that are determined by the, essentially invariant, peak stoichiometric flame temperature. A maintenance based approach will therefore continue to be used to maintain the general emissions performance of the combustor. Maintenance includes periodic hot gas path inspections and maintenance based on factored fired starts.</p> <p>We agree with the operator's assessment of compliance. The equipment at the site is one which is included in the JEP document and whilst we don't completely agree with the flow diagram, we do agree with the outcome. Therefore, BAT can be demonstrated from permitted performance and appropriate maintenance.</p> <p>We don't agree that daily NO<sub>x</sub> ELVs are indicative as this only applies to plant operating for &lt;500 hours which were put into operation before November 2003 which is not the case for these LCPs.</p>						
43	In order to prevent or reduce NO <sub>x</sub> emissions to air from the combustion of natural gas in engines, BAT is to use one or a combination of the techniques given below.			NA	The LCPs are gas turbines and not engines.						
<table border="1"> <thead> <tr> <th data-bbox="322 1316 510 1358">Technique</th> <th data-bbox="510 1316 887 1358">Description</th> <th data-bbox="887 1316 1290 1358">Applicability</th> </tr> </thead> <tbody> <tr> <td> </td> <td> </td> <td> </td> </tr> </tbody> </table>						Technique	Description	Applicability			
Technique	Description	Applicability									

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC/ FC/ NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement														
	a Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system																
	b Lean-burn concept	See description in Section 8.3. Generally used in combination with SCR	Only applicable to new gas-fired engines																
	c. Advanced lean-burn concept	See descriptions in Section 8.3	Only applicable to new spark plug ignited engines																
	d Selective catalytic reduction (SCR)		Retrofitting existing combustion plants may be constrained by the availability of sufficient space. Not applicable to combustion plants operated < 500 h/yr. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr																
44	<p>In order to prevent or reduce CO emissions to air from the combustion of natural gas, BAT is to ensure optimised combustion and/or to use oxidation catalysts.</p> <p><b>Description - See descriptions in Section 8.3.</b></p> <p><b>BAT-associated emission levels (BAT-AELs) for NO<sub>x</sub> emissions to air from the combustion of natural gas in gas turbines</b></p> <table border="1" data-bbox="338 1074 1285 1326"> <thead> <tr> <th rowspan="2">Type of combustion plant</th> <th rowspan="2">Combustion plant total rated thermal input (MW<sub>th</sub>)</th> <th colspan="2">BAT-AELs (mg/Nm<sup>3</sup>) <sup>(142)</sup> <sup>(143)</sup></th> </tr> <tr> <th>Yearly average <sup>(144)</sup> <sub>(145)</sub></th> <th>Daily average or average over the sampling period</th> </tr> </thead> <tbody> <tr> <td colspan="4" style="text-align: center;"><b>Open-cycle gas turbines (OCGTs) <sup>(146)</sup> <sup>(147)</sup></b></td> </tr> <tr> <td>New OCGT</td> <td>≥ 50</td> <td>15–35</td> <td>25–50</td> </tr> </tbody> </table>			Type of combustion plant	Combustion plant total rated thermal input (MW <sub>th</sub> )	BAT-AELs (mg/Nm <sup>3</sup> ) <sup>(142)</sup> <sup>(143)</sup>		Yearly average <sup>(144)</sup> <sub>(145)</sub>	Daily average or average over the sampling period	<b>Open-cycle gas turbines (OCGTs) <sup>(146)</sup> <sup>(147)</sup></b>				New OCGT	≥ 50	15–35	25–50	NA	<p>The operator responded as follows:</p> <p>The BAT-AELs do not apply as Peterborough is operated &lt; 500 h/yr.</p> <p>We agree that BAT-AELs do not apply to Peterborough but for wider reasons than given by the operator. As the plant was put into operation after 27 November 2003, the indicative BAT-AEL for NO<sub>x</sub> of 140 mg/Nm<sup>3</sup> does not apply. In addition, the equipment at the site is one that is included in the JEP document "Maintaining the Emissions Performance of Open Cycle Gas Turbines that operate for less than 500 hours per year" and, as shown in table 6 of the document the emissions of NO<sub>x</sub> are below and the efficiency is above the benchmarks as specified in tables</p>
Type of combustion plant	Combustion plant total rated thermal input (MW <sub>th</sub> )	BAT-AELs (mg/Nm <sup>3</sup> ) <sup>(142)</sup> <sup>(143)</sup>																	
		Yearly average <sup>(144)</sup> <sub>(145)</sub>	Daily average or average over the sampling period																
<b>Open-cycle gas turbines (OCGTs) <sup>(146)</sup> <sup>(147)</sup></b>																			
New OCGT	≥ 50	15–35	25–50																

BAT Concn. Number	Summary of BAT Conclusion requirement				Status NA/ CC/ FC/ NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	Existing OCGT (excluding turbines for mechanical drive applications) — All but plants operated < 500 h/yr	≥ 50	15–50	25–55 <sup>(148)</sup>		1 and 2 of our draft guidance on BAT for the balancing market. Therefore, no ELVs are applicable.
<b>Combined-cycle gas turbines (CCGTs) <sup>(146)</sup> <sup>(149)</sup></b>						
New CCGT	≥ 50	10–30	15–40			
Existing CCGT with a net total fuel utilisation of < 75 %	≥ 600	10–40	18–50			
Existing CCGT with a net total fuel utilisation of ≥ 75 %	≥ 600	10–50	18–55 <sup>(150)</sup>			
Existing CCGT with a net total fuel utilisation of < 75 %	50–600	10–45	35–55			
Existing CCGT with a net total fuel utilisation of ≥ 75 %	50–600	25–50 <sup>(151)</sup>	35–55 <sup>(152)</sup>			
<b>Open- and combined-cycle gas turbines</b>						
Gas turbine put into operation no later than 27 November 2003, or existing gas turbine for emergency use and operated < 500 h/yr	≥ 50	No BAT-AEL	60–140 <sup>(153)</sup> <sup>(154)</sup>			
Existing gas turbine for mechanical drive applications — All but plants operated < 500 h/yr	≥ 50	15–50 <sup>(155)</sup>	25–55 <sup>(156)</sup>			
<p>As an indication, the yearly average CO emission levels for each type of existing combustion plant operated ≥ 1 500 h/yr and for each type of new combustion plant will generally be as follows:</p> <ul style="list-style-type: none"> <li>— New OCGT of ≥ 50 MW<sub>th</sub>; &lt; 5–40 mg/Nm<sup>3</sup>. For plants with a net electrical efficiency (EE) greater than 39 %, a correction factor may be applied to the higher end of this range, corresponding to [higher end] × EE/39, where EE is the net electrical energy efficiency or net mechanical energy efficiency of the plant determined at ISO baseload conditions.</li> <li>— Existing OCGT of ≥ 50 MW<sub>th</sub> (excluding turbines for mechanical drive applications); &lt; 5–40 mg/Nm<sup>3</sup>. The higher end of this range will generally be 80 mg/Nm<sup>3</sup> in the case of existing plants that cannot be fitted with dry techniques for NO<sub>x</sub> reduction, or 50 mg/Nm<sup>3</sup> for plants that operate at low load.</li> <li>— New CCGT of ≥ 50 MW<sub>th</sub>; &lt; 5–30 mg/Nm<sup>3</sup>. For plants with a net electrical efficiency (EE) greater than 55 %, a correction factor may be applied to the higher end of the range, corresponding to</li> </ul>						

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC/ FC/ NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																							
	<p>[higher end] × EE/55, where EE is the net electrical energy efficiency of the plant determined at ISO baseload conditions.</p> <ul style="list-style-type: none"> <li>Existing CCGT of ≥ 50 MW<sub>th</sub>: &lt; 5–30 mg/Nm<sup>3</sup>. The higher end of this range will generally be 50 mg/Nm<sup>3</sup> for plants that operate at low load.</li> <li>Existing gas turbines of ≥ 50 MW<sub>th</sub> for mechanical drive applications: &lt; 5–40 mg/Nm<sup>3</sup>. The higher end of the range will generally be 50 mg/Nm<sup>3</sup> when plants operate at low load.</li> </ul> <p>In the case of a gas turbine equipped with DLN burners, these indicative levels correspond to when the DLN operation is effective.</p> <p><b>BAT-associated emission levels (BAT-AELs) for NO<sub>x</sub> emissions to air from the combustion of natural gas in boilers and engines</b></p> <table border="1" data-bbox="338 679 1285 903"> <thead> <tr> <th rowspan="3">Type of combustion plant</th> <th colspan="4">BAT-AELs (mg/Nm<sup>3</sup>)</th> </tr> <tr> <th colspan="2">Yearly average <sup>(157)</sup></th> <th colspan="2">Daily average or average over the sampling period</th> </tr> <tr> <th>New plant</th> <th>Existing plant <sup>(158)</sup></th> <th>New plant</th> <th>Existing plant <sup>(159)</sup></th> </tr> </thead> <tbody> <tr> <td>Boiler</td> <td>10–60</td> <td>50–100</td> <td>30–85</td> <td>85–110</td> </tr> <tr> <td>Engine <sup>(160)</sup></td> <td>20–75</td> <td>20–100</td> <td>55–85</td> <td>55–110 <sup>(161)</sup></td> </tr> </tbody> </table> <p>As an indication, the yearly average CO emission levels will generally be:</p> <ul style="list-style-type: none"> <li>&lt; 5–40 mg/Nm<sup>3</sup> for existing boilers operated ≥ 1 500 h/yr,</li> <li>&lt; 5–15 mg/Nm<sup>3</sup> for new boilers,</li> <li>30–100 mg/Nm<sup>3</sup> for existing engines operated ≥ 1 500 h/yr and for new engines.</li> </ul>	Type of combustion plant	BAT-AELs (mg/Nm <sup>3</sup> )				Yearly average <sup>(157)</sup>		Daily average or average over the sampling period		New plant	Existing plant <sup>(158)</sup>	New plant	Existing plant <sup>(159)</sup>	Boiler	10–60	50–100	30–85	85–110	Engine <sup>(160)</sup>	20–75	20–100	55–85	55–110 <sup>(161)</sup>		
Type of combustion plant	BAT-AELs (mg/Nm <sup>3</sup> )																									
	Yearly average <sup>(157)</sup>		Daily average or average over the sampling period																							
	New plant	Existing plant <sup>(158)</sup>	New plant	Existing plant <sup>(159)</sup>																						
Boiler	10–60	50–100	30–85	85–110																						
Engine <sup>(160)</sup>	20–75	20–100	55–85	55–110 <sup>(161)</sup>																						
45	<p>In order to reduce non-methane volatile organic compounds (NMVOC) and methane (CH<sub>4</sub>) emissions to air from the combustion of natural gas in spark-ignited lean-burn gas engines, BAT is to ensure optimised combustion and/or to use oxidation catalysts.</p> <p><b>Description</b></p> <p>See descriptions in Section 8.3. Oxidation catalysts are not effective at reducing the emissions of saturated hydrocarbons containing less than four carbon atoms.</p> <p><b>BAT-associated emission levels (BAT-AELs) for formaldehyde and CH<sub>4</sub> emissions to air from the combustion of natural gas in a spark-ignited lean-burn gas engine</b></p> <table border="1" data-bbox="338 1289 1285 1361"> <thead> <tr> <th rowspan="2">Combustion plant total rated thermal input (MW<sub>th</sub>)</th> <th colspan="2">BAT-AELs (mg/Nm<sup>3</sup>)</th> </tr> <tr> <th>Formaldehyde</th> <th>CH<sub>4</sub></th> </tr> </thead> <tbody> <tr> <td></td> <td></td> <td></td> </tr> </tbody> </table>	Combustion plant total rated thermal input (MW <sub>th</sub> )	BAT-AELs (mg/Nm <sup>3</sup> )		Formaldehyde	CH <sub>4</sub>				NA	The LCPs are gas turbines and not engines.															
Combustion plant total rated thermal input (MW <sub>th</sub> )	BAT-AELs (mg/Nm <sup>3</sup> )																									
	Formaldehyde	CH <sub>4</sub>																								

BAT Concn. Number	Summary of BAT Conclusion requirement	Statu s NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement												
	<table border="1"> <thead> <tr> <th data-bbox="322 376 792 480"></th> <th colspan="3" data-bbox="792 376 1301 416">Average over the sampling period</th> </tr> <tr> <th data-bbox="322 480 792 549"></th> <th data-bbox="792 416 1005 480">New or existing plant</th> <th data-bbox="1005 416 1128 480">New plant</th> <th data-bbox="1128 416 1301 480">Existing plant</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 480 792 549">≥ 50</td> <td data-bbox="792 480 1005 549">5-15 <sup>(162)</sup></td> <td data-bbox="1005 480 1128 549">215-500 <sup>(163)</sup></td> <td data-bbox="1128 480 1301 549">215-560 <sup>(162)</sup> <sup>(163)</sup></td> </tr> </tbody> </table>		Average over the sampling period				New or existing plant	New plant	Existing plant	≥ 50	5-15 <sup>(162)</sup>	215-500 <sup>(163)</sup>	215-560 <sup>(162)</sup> <sup>(163)</sup>		
	Average over the sampling period														
	New or existing plant	New plant	Existing plant												
≥ 50	5-15 <sup>(162)</sup>	215-500 <sup>(163)</sup>	215-560 <sup>(162)</sup> <sup>(163)</sup>												
46 - 51	Not applicable - the LCPs combust natural gas and not gas from iron or steel processes.														
52 - 54	Not applicable – the LCPs are not on off-shore platforms														
<b>Combustion for multi-fuel-fired plants</b>															
55 - 59	Not applicable – only natural gas is used as the fuel														
<b>Co-incineration of waste</b>															
60 - 71	Not applicable – only natural gas is used as the fuel														
<b>Gasification</b>															
72 - 75	Not applicable – the LCPs are OCGTs not gasifiers														

## **6. Review and assessment of derogation requests made by the operator in relation to BAT Conclusions which include an associated emission level (AEL) value**

The IED enables a competent authority to allow derogations from BAT AELs stated in BAT Conclusions under specific circumstances as detailed under Article 15(4):

By way of derogation from paragraph 3, and without prejudice to Article 18, the competent authority may, in specific cases, set less strict emission limit values. Such a derogation may apply only where an assessment shows that the achievement of emission levels associated with the best available techniques as described in BAT conclusions would lead to disproportionately higher costs compared to the environmental benefits due to:

*(a) the geographical location or the local environmental conditions of the installation concerned; or*

*(b) the technical characteristics of the installation concerned.*

As part of their Regulation 61 Note response, the operator has not requested a derogation from compliance with any AEL values.



## **7. Emissions to Water**

The consolidated permit incorporates the current discharge to controlled waters identified as W1. The discharge to surface water is run-off from roads, roofs and hardstanding areas.

There are no BAT AELs specified in the BAT Conclusions for this type of plant. There are also no additional treatment options identified as BAT for the installation. We have therefore not carried out any additional assessment of the emissions to water as part of this review.

## **8 Additional IED Chapter II requirements:**

### **Energy efficiency**

The BAT for balancing plant guidance (Working draft, 2018) sets out additional restrictions on hours for <1500 hour non-emergency plant which are low efficiency. Table 1 of the guidance sets out categories for LCP peaking plant. The LCP at Peterborough Power Station falls into category B because its NO<sub>x</sub> emissions are below 500 mg/m<sup>3</sup> and its efficiency, at 32.05%, is above that set out in table 2 of the guidance for this type of plant and fuel. Table 1 therefore confirms that there are no additional restrictions applied to the hours of operation.

### **Black Start**

In the event of a black out National Grid would call on combustion plant to operate and may require them to do so outside their permitted conditions. We have dedicated black start plant and they are permitted to run as such but this scenario is relevant to the rest of the large combustion plant which could be called depending on the circumstances.

A risk assessment will be carried out by Energy UK/Joint Environmental Programme on behalf of Large Combustion Plant connected to the National Transmission System. Air emissions modelling will be based on generic black start scenarios to establish whether they have the potential to have local impact on the environment or not (on a national basis). If the modelling demonstrates that no significant impacts are likely, the plant can operate under condition 2.3.7. This conditions allows the hourly ELVs for plants operating under a black start instruction to be discounted for the purpose of reporting. We would also require there to be a procedure in place for minimisation of emissions in the case of a black start event and for reporting in the event of a black start. This modelling and the procedures have not been agreed in advance of the issue of the permit review and therefore a condition linking back to an improvement condition have been included in the permit.

## 9 Review and assessment of changes that are not part of the BAT Conclusions derived permit review.

This document should be read in conjunction with the application, supporting information and notice.

Aspect considered	Decision
<b>Receipt of application</b>	
Confidential information	A claim for commercial or industrial confidentiality has not been made.
Identifying confidential information	We have not identified information provided as part of the application that we consider to be confidential.  The decision was taken in accordance with our guidance on confidentiality.
<b>The site</b>	
Biodiversity, heritage, landscape and nature conservation	The application is within the relevant distance criteria of a site of heritage, landscape or nature conservation, and/or protected species or habitat.  A full assessment of the application and its potential to affect the site(s)/species/habitat has not been carried out as part of the permit review process. We consider that the review will not affect the features of the site(s)/species/habitat as the conditions will provide at least the same level of protection as those in the previous permit and in some cases will provide a higher level of protection to those in the previous permit.  We have not consulted Natural England on the application. The decision was taken in accordance with our guidance.
<b>Operating techniques</b>	
General operating techniques	We have reviewed the techniques used by the operator where they are relevant to the BAT Conclusions and compared these with the relevant guidance notes.  The permit conditions ensure compliance with the relevant BREF and BAT Conclusions.
<b>Permit conditions</b>	
Updating permit conditions during consolidation	We have updated permit conditions to those in the current generic permit template as part of permit consolidation. The conditions will provide at least the same level of protection as those in the previous permit and in some cases will provide a higher level of protection to those in the previous permit.

Aspect considered	Decision
Changes to the permit conditions due to an Environment Agency initiated variation	We have varied the permit as stated in the variation notice.
Improvement programme	<p>Based on the information on the application, we consider that we need to impose an improvement programme.</p> <p>We have imposed an improvement programme to ensure that:</p> <ul style="list-style-type: none"> <li>• the operator will have assessed the impact of emissions during a Black Start event.</li> </ul> <p>We have also removed the completed improvement conditions from the permit.</p>
Emission limits	<p>We have decided that emission limits should not be set.</p> <p>This is described in the relevant BAT Conclusions in Section 5 of this document. There are no BAT-AELs or indicative BAT-AELs for plant operating for less than 500 hours, which were put into operation after 27 November 2003 and which comply with the benchmarks for NOx emissions and efficiency as set out in our BAT for balancing market guidance.</p> <p>We have removed emission point A5 from table S3.1 as the operator confirmed that the auxiliary boiler is no longer present at the site.</p>
Monitoring	<p>We have decided that monitoring should be carried out for the parameters listed in the permit, using the methods detailed and to the frequencies specified.</p> <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p> <p>Table S3.4 Process monitoring requirements was amended to include the requirement to monitor energy efficiency after overhauls on site in line with BAT2.</p>
Reporting	<p>We have specified reporting in the permit for the following parameters:</p> <ul style="list-style-type: none"> <li>• Nitrogen dioxide</li> <li>• Carbon monoxide</li> <li>• Sulphur dioxide</li> </ul> <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p>

Aspect considered	Decision
<b>Operator competence</b>	
Management system	There is no known reason to consider that the operator will not have the management system to enable it to comply with the permit conditions.
<b>Growth Duty</b>	
Section 108 Deregulation Act 2015 – Growth duty	<p>We have considered our duty to have regard to the desirability of promoting economic growth set out in section 108(1) of the Deregulation Act 2015 and the guidance issued under section 110 of that Act in deciding whether to grant this permit.</p> <p>Paragraph 1.3 of the guidance says:</p> <p>“The primary role of regulators, in delivering regulation, is to achieve the regulatory outcomes for which they are responsible. For a number of regulators, these regulatory outcomes include an explicit reference to development or growth. The growth duty establishes economic growth as a factor that all specified regulators should have regard to, alongside the delivery of the protections set out in the relevant legislation.”</p> <p>We have addressed the legislative requirements and environmental standards to be set for this operation in the body of the decision document above. The guidance is clear at paragraph 1.5 that the growth duty does not legitimise non-compliance and its purpose is not to achieve or pursue economic growth at the expense of necessary protections.</p> <p>We consider the requirements and standards we have set in this permit are reasonable and necessary to avoid a risk of an unacceptable level of pollution. This also promotes growth amongst legitimate operators because the standards applied to the operator are consistent across businesses in this sector and have been set to achieve the required legislative standards.</p>