

## Environment Agency

# Review of an Environmental Permit for an Installation subject to Chapter II of the Industrial Emissions Directive under the Environmental Permitting (England & Wales) Regulations 2016

## Decision document recording our decision-making process following review of a permit

The Permit number is: EPR/AP3139LE  
The Operator is: National Grid Gas PLC  
The Installation is: Aylesbury Compressor Station  
This Variation Notice number is: EPR/AP3139LE/V005

### What this document is about

Article 21(3) of the Industrial Emissions Directive (IED) requires the Environment Agency to review conditions in permits that it has issued and to ensure that the permit delivers compliance with relevant standards, within four years of the publication of updated decisions on best available techniques (BAT) conclusions.

We have reviewed the permit for this installation against the revised BAT Conclusions for large combustion plant published on 17<sup>th</sup> August 2017. This is our decision document, which explains the reasoning for the consolidated variation notice that we are issuing.

It explains how we have reviewed and considered the techniques used by the Operator in the operation and control of the plant and activities of the installation. This review has been undertaken with reference to the decision made by the European Commission establishing best available techniques (BAT) conclusions ('BAT Conclusions') for large combustion plant as detailed in document reference IEDC-7-1. It is our record of our decision-making process and shows how we have taken into account all relevant factors in reaching our position. It also provides a justification for the inclusion of any specific conditions in the permit that are in addition to those included in our generic permit template.

As well as considering the review of the operating techniques used by the Operator for the operation of the plant and activities of the installation, the consolidated variation notice takes into account and brings together in a

single document all previous variations that relate to the original permit issued. It also modernises the entire permit to reflect the conditions contained in our current generic permit template.

The introduction of new template conditions makes the Permit consistent with our current general approach and philosophy and with other permits issued to installations in this sector. Although the wording of some conditions has changed, while others have been removed because of the new regulatory approach, it does not reduce the level of environmental protection achieved by the Permit in any way. In this document we therefore address only our determination of substantive issues relating to the new BAT Conclusions.

Throughout this document we will use a number of expressions. These are as referred to in the glossary and have the same meaning as described in “Schedule 6 Interpretation” of the Permit.

We try to explain our decision as accurately, comprehensively and plainly as possible. We would welcome any feedback as to how we might improve our decision documents in future. A lot of technical terms and acronyms are inevitable in a document of this nature: we provide a glossary of acronyms near the front of the document, for ease of reference.

## How this document is structured

### Glossary of terms

- 1 Our decision
- 2 How we reached our decision
- 2.1 Requesting information to demonstrate compliance with BAT Conclusions for Large Combustion Plant
- 2.2 Review of our own information in respect to the capability of the installation to meet revised standards included in the BAT Conclusions document
- 3 The legal framework
- 4 Key Issues
- 5 Decision checklist regarding relevant BAT Conclusions
- 6 Review and assessment of derogation requests made by the operator in relation to BAT Conclusions which include an associated emission level (AEL) value
- 7 Emissions to Water
- 8 Additional IED Chapter II requirements
- 9 Review and assessment of changes that are not part of the BAT Conclusions derived permit review.

## Glossary of acronyms used in this document

(Please note that this glossary is standard for our decision documents and therefore not all these acronyms are necessarily used in this document.)

APC	Air Pollution Control
BAT	Best Available Technique(s)
BAT-AEEL	BAT Associated Energy Efficiency Level
BAT-AEL	BAT Associated Emission Level
BATc	BAT conclusion
BREF	Best available techniques reference document
CEM	Continuous emissions monitor
CHP	Combined heat and power
CV	Calorific value
DAA	Directly associated activity – Additional activities necessary to be carried out to allow the principal activity to be carried out
DLN	Dry Low NOx burners
DLN-E	Dry Low NOx effective
EIONET	European environment information and observation network is a partnership network of the European Environment Agency
ELV	Emission limit value derived under BAT or an emission limit value set out in IED
EMS	Environmental Management System
EPR	Environmental Permitting (England and Wales) Regulations 2016 (SI 2016 No. 1154)
EWC	European waste catalogue
FSA	Food Standards Agency
IC	Improvement Condition
IED	Industrial Emissions Directive (2010/75/EU)
IPPCD	Integrated Pollution Prevention and Control Directive (2008/1/EC) – now superseded by IED
LCP	Large Combustion Plant subject to Chapter III of IED
MSUL/MSDL	Minimum start up load/minimum shut-down load
NOx	Oxides of nitrogen (NO plus NO <sub>2</sub> expressed as NO <sub>2</sub> )
NPV	Net Present Value
OCGT	Open Cycle Gas Turbine
PHE	Public Health England
SAC	Special Area of Conservation
SGN	Sector guidance note
TGN	Technical guidance note
TOC	Total Organic Carbon
WFD	Water Framework Directive (2000/60/EC)

## 1 Our decision

We have decided to issue the consolidated variation notice to the Operator. This will allow it to continue to operate the Installation, subject to the conditions in the consolidated variation notice.

We consider that, in reaching that decision, we have taken into account all relevant considerations and legal requirements and that the varied permit will ensure that a high level of protection is provided for the environment and human health.

The consolidated variation notice contains many conditions taken from our standard Environmental Permit template including the relevant Annexes. We developed these conditions in consultation with industry, having regard to the legal requirements of the Environmental Permitting Regulations and other relevant legislation. This document does not therefore include an explanation for these standard conditions. Where they are included in the Notice, we have considered the techniques identified by the operator for the operation of their installation, and have accepted that the details are sufficient and satisfactory to make those standard conditions appropriate. This document does, however, provide an explanation of our use of “tailor-made” or installation-specific conditions, or where our Permit template provides two or more options.

## 2 How we reached our decision

### 2.1 Requesting information to demonstrate compliance with BAT Conclusions for Large Combustion Plant

We issued a Notice under Regulation 61(1) of the Environmental Permitting (England and Wales) Regulations 2016 (a Regulation 61 Notice) on 1<sup>st</sup> May 2018 requiring the Operator to provide information to demonstrate how the operation of their installation currently meets, or will subsequently meet, the revised standards described in the large combustion plant BAT Conclusions document. The Notice also required that where the revised standards are not currently met, the operator should provide information that:

- Describes the techniques that will be implemented before 17<sup>th</sup> August 2021, which will then ensure that operations meet the revised standard, or
- Justifies why standards will not be met by 17<sup>th</sup> August 2021, and confirmation of the date when the operation of those processes will cease within the installation or an explanation of why the revised BAT standard is not applicable to those processes, or
- Justifies why an alternative technique will achieve the same level of environmental protection equivalent to the revised standard described in the BAT Conclusions.

Where the Operator proposed that they were not intending to meet a BAT standard that also included a BAT Associated Emission Level (BAT AEL) described in the BAT Conclusions Document, the Regulation 61 Notice requested that the Operator make a formal request for derogation from compliance with that AEL (as provisioned by Article 15(4) of IED). In this circumstance, the Notice identified that any such request for derogation must be supported and justified by sufficient technical and commercial information that would enable us to determine acceptability of the derogation request.

The Regulation 61 Notice response from the Operator was received on 30<sup>th</sup> November 2018.

We considered it was in the correct form and contained sufficient information for us to begin our determination of the permit review but not that it necessarily contained all the information we would need to complete that review.

## **2.2 Review of our own information in respect to the capability of the installation to meet revised standards included in the BAT Conclusions document**

Based on our records and previous regulatory activities with the facility we have no reason to consider that the operator will not be able to comply with the conditions that we include in the permit.

### 3 The legal framework

The consolidated variation notice will be issued under Regulation 20 of the EPR. The Environmental Permitting regime is a legal vehicle which delivers most of the relevant legal requirements for activities falling within its scope. In particular, the regulated facility is:

- an *installation* as described by the IED;
- subject to aspects of other relevant legislation which also have to be addressed.

We consider that the consolidated variation notice will ensure that the operation of the Installation complies with all relevant legal requirements and that a high level of protection will be delivered for the environment and human health.

We explain how we have addressed specific statutory requirements more fully in the rest of this document.

## 4 The key issues

The key issues arising during this permit review are:

- Emissions to air and the emission limits applied to the plant.
- The energy efficiency levels associated with the Best Available Techniques (BAT-AEELs)

We therefore describe how we determined these issues in most detail in the relevant sections of this document.

### 4.1 Emissions to air and the emission limits applied to the plant

A number of general principles were applied during the permit review. These included:

- The upper value of the BAT AELs ranges specified were used unless use of the tighter limit was justified.
- The principle of no backsliding where if existing limits in the permit were already tighter than those specified in the BREF, the existing permit limits were retained.
- Where a limit was specified in both IED Annex V and the BAT Conclusions for a particular reference period, the tighter limit was applied and in the majority of cases this was from the BAT Conclusions.
- Where AELs are indicative in the BAT Conclusions, these were applied unless adequate justification was provided by the operator to demonstrate that an alternative limit was more appropriate.
- For gas turbines where the IED specified that limits applied over 70% load and the BAT Conclusions specified that AELs applied when dry low NO<sub>x</sub> is effective (DLN-E), we have used DLN-E as a default across all monitoring requirements for NO<sub>x</sub> and carbon monoxide (CO).

The LCP(s) on site consist of:

LCP231: This LCP consists of a single 50.5 MWth OCGT which vents via a single windshield at emission point A1. The unit burns natural gas.

LCP232: This LCP consists of a single 52.6 MWth OCGT which vents via a single windshield at emission point A2. The unit burns natural gas.

The plant was put into operation before IED came into force and therefore the existing limits in the permit are from Part 1 of IED Annex V applicable to existing plant.

The ELVs and AELs are based on the following operating regime:

- Unlimited hours operation



The previous permit set limits which applied over 70% load and between MSUL/MSDUL to baseload. For gas turbines where the IED specified that limits applied over 70% load and the BAT Conclusions specified that AELs applied when dry low NOx is effective (DLN-E), our standard approach is to use DLN-E as a default across all monitoring requirements for NOx and CO.

During the permit review the Operator requested that limits should apply from 55% Maximum Continuous Rating (MCR). This is in line with the Operator's other LCP sites and is also the approach that was taken at Aylesbury Compressor Station prior to the 2015 Chapter III permit review. We agree with the Operator's request. From 17 August 2021 limits will apply from 55% MCR as a proxy for DLN-E.

The Operator submitted the operational performance emissions data for NOx and CO for each individual turbine as part of the original permit application in 2006. This excluded any data collected when the plant was operating at <55% Maximum Continuous Rating (MCR). These figures provided the realistic emission values that individual turbines could achieve at >55% MCR and were the basis on which emission limit values for Carbon Monoxide (CO) and NOx were set in the original permit.

On this site the plant is required by the gas grid to operate at low load for usually only short periods of time. In order to ensure that emissions between MSUL and 55% are monitored we have the option of either setting additional ELVs or recording the hours below 55% operation and including a note that the limits are excluded at operation <55%. From 17 August 2021 the Operator is required to record hours of operation below 55% MCR. The environmental risk associated with this approach is low and we have decided to specify monitoring using the number of operating hours in this mode as a proxy. This is consistent with the monitoring requirements set for the other LCP gas compressor stations operated by National Grid Gas Plc.

We have included a note in table S3.1a for all National Grid Gas sites that states 'excluding start up, shut down and operation at loads <55% of MCR'. A requirement for the hours of operation below 55% to be recorded is included in Schedule 4 of the permit.

The following tables outline the limits that have been incorporated into the permit for LCP231 and LCP232, where these were derived from and the reference periods at which they apply. The emission limits refer to concentrations, expressed as mass of emitted substance per volume of flue-gas under the following standard conditions: dry gas at a temperature of 273,15 K, pressure of 101,3 kPa and 15% volume reference oxygen concentration if flue gases. The emission limits and monitoring requirements have been incorporated into Schedule 3 of the permit.

NOx limits (mg/Nm <sup>3</sup> )						
Averaging	IED (Annex V Part 1) - Existing	BREF (Table 24 BAT-c)	Expected permit limits	Basis	Limits apply	Monitoring
Annual	None	60 <sup>Note 1</sup>	60	BREF	>55% of MCR <sup>Note 3</sup>	Continuous (Predicative Emission Monitoring System)
Monthly	75	None	65 <sup>Note 2</sup>	Note 2	>55% of MCR <sup>Note 3</sup>	
Daily	82	65 <sup>Note 1</sup>	65	BREF	>55% of MCR <sup>Note 3</sup>	
95 <sup>th</sup> %ile of hr means	150	None	150	IED	>55% of MCR <sup>Note 3</sup>	

Note 1: As an existing OCGT Mechanical Drive plant put into operation no later than 7 January 2014, footnotes 14 and 15 to Table 24 of the BAT Conclusions apply, these footnote specify the applicable BAT-AELs.

Note 2: This limit is tighter than the IED annex V limit (75mg/m<sup>3</sup>) which was previously set in the permit. The monthly limit cannot be higher than the daily limit, therefore we have set a monthly limit which matches the daily limit given in the BREF.

Note 3: The BAT Conclusions specify that AELs apply when dry low NOx is effective (DLN-E). For NGG permits, 55% MCR is used as a proxy for DLN-E.

CO limits (mg/Nm <sup>3</sup> )						
Averaging	IED (Annex V Part 1) - Existing	BREF	Expected permit limits	Basis	Limits apply	Monitoring
Annual	None	40	40	BREF	>55% of MCR <sup>Note 1</sup>	Continuous (Predicative Emission Monitoring System)
Monthly	100	None	100	IED	>55% of MCR <sup>Note 1</sup>	
Daily	110	None	110	IED	>55% of MCR <sup>Note 1</sup>	
95 <sup>th</sup> %ile of hr means	200	None	200	IED	>55% of MCR <sup>Note 1</sup>	

Note 1: The BAT Conclusions specify that AELs apply when dry low NOx is effective (DLN-E). For NGG permits, 55% MCR is used as a proxy for DLN-E.

#### 4.2 The energy efficiency levels associated with the Best Available Techniques Conclusions

An energy efficiency level associated with the best available techniques (BAT-AEEL) refers to the ratio between the combustion unit's net energy output(s) and the combustion unit's fuel/feedstock energy input at actual unit design. The net energy output(s) is determined at the combustion unit boundaries, including auxiliary systems (e.g. flue-gas treatment systems), and for the unit operated at full load.

The Operator confirmed that the original equipment manufacturer provided a calculation based on their internal product data for the equipment installed in order to determine the net mechanical efficiency.

The table below sets out the BAT-AEELs specified in the LCP BAT Conclusions for the large combustion plant on the site and the energy efficiency levels confirmed through the Regulation 61 notice response.

BAT AEELs (%)			Plant efficiency (%)		
Net electrical efficiency	Net total fuel utilisation	Net mechanical efficiency	Net electrical efficiency	Net total fuel utilisation	Net mechanical efficiency
LCP231: Open cycle gas turbine, ≥ 50 MWth, Existing unit, Mechanical Drive					
NA	None	33.5-41	NA	NA	30.06
LCP232: Open cycle gas turbine, ≥ 50 MWth, Existing unit, Mechanical Drive					
NA	None	33.5-41	NA	NA	30.06

The installation does not meet the BAT-AEEL range for this type of plant. This is mainly due to the initial efficiency of the gas turbine/drive configuration.

National Grid Gas (NGG) is required to investigate then implement environmental improvements at strategic parts of the network on sites which are subject to high utilisation and operate older machinery. NGG's proposed expenditure for compressor investment and relevant associated equipment is assessed and agreed by Ofgem for the duration of a price control period. This ensures compliance with environmental obligations is done in an economic and efficient manner.

Significant investments have already been made at this site in order to reduce emissions. The oxidising catalysts were fitted in order to control CO emissions and allow the plant to meet the IED ELVs. The Operator has stated that the oxidising catalysts have also decreased overall efficiency, however assessment and installation of the catalysts took place in 2015 prior to the publication of the LCP BREF.

We are satisfied that no further upgrades are currently planned for this plant and that the current net mechanical efficiency is BAT. A formal derogation is not required from the BAT-AEELs under Article 15(4) where it is proven that alternative values can be regarded as BAT.

## 5 Decision checklist regarding relevant BAT Conclusions

BAT Conclusions for large combustion plant, were published by the European Commission on 17<sup>th</sup> August 2017. There are 75 BAT Conclusions. Only the BAT Conclusions relevant to the particular fuel type used on site have been replicated below.

This annex provides a record of decisions made in relation to each relevant BAT Conclusion applicable to the installation. This annex should be read in conjunction with the Consolidated Variation Notice.

The conditions in the permit through which the relevant BAT Conclusions are implemented include but are not limited to the following:

BAT Conclusion requirement topic	Permit condition(s)	Permit table(s)
Environmental Management System	1.1.1	S1.2
BAT AELs	3.1.1 and 3.5.1	S3.1a
Monitoring	2.3, 3.5 and 3.6	S1.3, S1.4, S1.2, S3.1a
Energy efficiency	1.2 and 2.3	S3.3
Noise	3.4 and 2.3	S1.2
Other operating techniques	2.3	S1.2

The overall status of compliance with the BAT conclusion is indicated in the table as:

- NA Not Applicable
- CC Currently Compliant
- FC Compliant in the future (within 4 years of publication of BAT conclusions)
- NC Not Compliant
- PC Partially Compliant

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
<b>General</b>			
1	<p><b>In order to improve the overall environmental performance, BAT is to implement and adhere to an environmental management system (EMS) that incorporates all of the following features:</b></p> <ul style="list-style-type: none"> <li>i. commitment of the management, including senior management;</li> <li>ii. definition of an environmental policy that includes the continuous improvement of the installation by the management;</li> <li>iii. planning and establishing the necessary procedures, objectives and targets, in conjunction with financial planning and investment;</li> <li>iv. implementation of procedures <ul style="list-style-type: none"> <li>(a) Structure and responsibility</li> <li>(b) Training</li> <li>(c) Communication</li> <li>(d) Employee involvement</li> <li>(e) Documentation</li> <li>(f) Efficient process control</li> <li>(g) Maintenance programmes</li> <li>(h) Emergency preparedness and response</li> <li>(i) Safeguarding compliance with environmental legislation</li> </ul> </li> <li>v. checking performance and taking corrective action, paying particular attention to: <ul style="list-style-type: none"> <li>(a) monitoring and measurement (see also the Reference Document on the General Principles of Monitoring)</li> <li>(b) corrective and preventive action</li> <li>(c) maintenance of records</li> <li>(d) independent (where practicable) internal and external auditing in order to determine whether or not the EMS conforms to planned arrangements and has been properly implemented and maintained;</li> </ul> </li> <li>vi. review of the EMS and its continuing suitability, adequacy and effectiveness by senior management;</li> <li>vii. following the development of cleaner technologies;</li> <li>viii. consideration for the environmental impacts from the eventual decommissioning of the installation at the stage of designing a new plant, and throughout its operating life;</li> <li>viii. consideration for the environmental impacts from the eventual decommissioning of the installation at the stage of designing a new plant, and throughout its operating life;</li> <li>ix. application of sectoral benchmarking on a regular basis.</li> </ul> <p>Etc - see BAT Conclusions</p>	CC	<p>National Grid operates an ISO14001 certified EMS.</p> <p>The operator has confirmed that National Grid Plc operates a corporate EMS for all its business units. National Grid Gas (Gas Transmission) has management procedures of its own to implement the requirements of the corporate EMS which are common to all installations. Each installation has its own site specific aspects and impacts register.</p>

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement													
	<p><b>Applicability.</b> The scope (e.g. level of detail) and nature of the EMS (e.g. standardised or non-standardised) will generally be related to the nature, scale and complexity of the installation, and the range of environmental impacts it may have.</p>															
2	<p>BAT is to determine the net electrical efficiency and/or the net total fuel utilisation and/or the net mechanical energy efficiency of the gasification, IGCC and/or combustion units by carrying out a performance test at full load (1), according to EN standards, after the commissioning of the unit and after each modification that could significantly affect the net electrical efficiency and/or the net total fuel utilisation and/or the net mechanical energy efficiency of the unit. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.</p>	CC	<p>The net mechanical efficiency of LCP231 and LCP232 is 30.06%. This is based on product data from the original equipment manufacturer.</p> <p>The installation does not meet the minimum BAT-AEEL of 33.5%. However, we are satisfied that no further upgrades are currently planned for this plant and that the current net mechanical efficiency is BAT. A formal derogation is not required from the BAT-AEELs under Article 15(4) where it is proven that alternative values can be regarded as BAT.</p>													
3	<p><b>BAT is to monitor key process parameters relevant for emissions to air and water including those given below.</b></p> <table border="1" data-bbox="322 1027 1487 1262"> <thead> <tr> <th data-bbox="322 1027 685 1062">Stream</th> <th data-bbox="685 1027 1120 1062">Parameter(s)</th> <th data-bbox="1120 1027 1487 1062">Monitoring</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 1062 685 1166" rowspan="3">Flue-gas</td> <td data-bbox="685 1062 1120 1098">Flow</td> <td data-bbox="1120 1062 1487 1098">Periodic or continuous determination</td> </tr> <tr> <td data-bbox="685 1098 1120 1133">Oxygen content, temperature, and pressure</td> <td data-bbox="1120 1098 1487 1133">Periodic or continuous measurement</td> </tr> <tr> <td data-bbox="685 1133 1120 1166">Water vapour content <sup>(1)</sup></td> <td data-bbox="1120 1133 1487 1166"></td> </tr> <tr> <td data-bbox="322 1166 685 1201">Waste water from flue-gas treatment</td> <td data-bbox="685 1166 1120 1201">Flow, pH, and temperature</td> <td data-bbox="1120 1166 1487 1201">Continuous measurement</td> </tr> </tbody> </table> <p>(1) The continuous measurement of the water vapour content of the flue-gas is not necessary if the sampled flue-gas is dried before analysis.</p>	Stream	Parameter(s)	Monitoring	Flue-gas	Flow	Periodic or continuous determination	Oxygen content, temperature, and pressure	Periodic or continuous measurement	Water vapour content <sup>(1)</sup>		Waste water from flue-gas treatment	Flow, pH, and temperature	Continuous measurement	CC	<p>Flow - Fuel gas usage is measured and flue-gas flow is determined by stoichiometric calculations.</p> <p>Oxygen content, temperature and pressure - NOx, CO and O<sub>2</sub> concentration content is measured via periodic measurements, conducted by UKAS ISO17025 laboratory to EN standards. Emissions measurements taken in this way are not affected by changes in temperature and pressure and these parameters are not required for correction to</p>
Stream	Parameter(s)	Monitoring														
Flue-gas	Flow	Periodic or continuous determination														
	Oxygen content, temperature, and pressure	Periodic or continuous measurement														
	Water vapour content <sup>(1)</sup>															
Waste water from flue-gas treatment	Flow, pH, and temperature	Continuous measurement														

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																		
			<p>reference conditions. We are satisfied with the Operators justification of why temperature and pressure are not measured.</p> <p>Water vapour content - Flue gas water vapour content is not measured as the flue gas is dried prior to measurement for periodic monitoring. This is in accordance with footnote one on the table under BAT 3.</p> <p>Waste water from flue-gas treatment - no waste water is generated from flue-gas treatment.</p>																		
4	<p>BAT is to monitor emissions to air with at least the frequency given below and in accordance with EN standards. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.</p> <table border="1" data-bbox="322 927 1487 1378"> <thead> <tr> <th data-bbox="322 927 474 1046">Substance/Parameter</th> <th data-bbox="474 927 788 1046">Fuel/Process/Type of combustion plant</th> <th data-bbox="788 927 943 1046">Combustion plant total rated thermal input</th> <th data-bbox="943 927 1122 1046">Standard(s)<sup>(4)</sup></th> <th data-bbox="1122 927 1339 1046">Minimum monitoring frequency<sup>(5)</sup></th> <th data-bbox="1339 927 1487 1046">Monitoring associated with</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 1046 474 1114">NH<sub>3</sub></td> <td data-bbox="474 1046 788 1114">— When SCR and/or SNCR is used</td> <td data-bbox="788 1046 943 1114">All sizes</td> <td data-bbox="943 1046 1122 1114">Generic EN standards</td> <td data-bbox="1122 1046 1339 1114">Continuous<sup>(6)</sup><sub>(7)</sub></td> <td data-bbox="1339 1046 1487 1114">BAT 7</td> </tr> <tr> <td data-bbox="322 1114 474 1378">NO<sub>x</sub></td> <td data-bbox="474 1114 788 1378"> <ul style="list-style-type: none"> <li>— Coal and/or lignite including waste co-incineration</li> <li>— Solid biomass and/or peat including waste co-incineration</li> <li>— HFO- and/or gas-oil-fired boilers and engines</li> <li>— Gas-oil-fired gas turbines</li> </ul> </td> <td data-bbox="788 1114 943 1378">All sizes</td> <td data-bbox="943 1114 1122 1378">Generic EN standards</td> <td data-bbox="1122 1114 1339 1378">Continuous<sup>(6)</sup><sub>(8)</sub></td> <td data-bbox="1339 1114 1487 1378">           BAT 20            BAT 24            BAT 28            BAT 32            BAT 37            BAT 41            BAT 42            BAT 43            BAT 47            BAT 48            BAT 56            BAT 64         </td> </tr> </tbody> </table>	Substance/Parameter	Fuel/Process/Type of combustion plant	Combustion plant total rated thermal input	Standard(s) <sup>(4)</sup>	Minimum monitoring frequency <sup>(5)</sup>	Monitoring associated with	NH <sub>3</sub>	— When SCR and/or SNCR is used	All sizes	Generic EN standards	Continuous <sup>(6)</sup> <sub>(7)</sub>	BAT 7	NO <sub>x</sub>	<ul style="list-style-type: none"> <li>— Coal and/or lignite including waste co-incineration</li> <li>— Solid biomass and/or peat including waste co-incineration</li> <li>— HFO- and/or gas-oil-fired boilers and engines</li> <li>— Gas-oil-fired gas turbines</li> </ul>	All sizes	Generic EN standards	Continuous <sup>(6)</sup> <sub>(8)</sub>	BAT 20 BAT 24 BAT 28 BAT 32 BAT 37 BAT 41 BAT 42 BAT 43 BAT 47 BAT 48 BAT 56 BAT 64	CC	<p>A Predicative Emission Monitoring System (PEMS) is used for monitoring of NO<sub>x</sub> validated by periodic measurement. Footnote 5 to BAT 4 confirms that PEMS may be used for existing OCGTs.</p> <p>A continuous emission monitoring system (CEMS) is used for measurement of CO and O<sub>2</sub> (O<sub>2</sub> CEMS used for correction of CO measurements to reference conditions only).</p> <p>CEMS are EN15267-1, 2, 3 certified and QAL1 certified as defined in EN14181.</p>
Substance/Parameter	Fuel/Process/Type of combustion plant	Combustion plant total rated thermal input	Standard(s) <sup>(4)</sup>	Minimum monitoring frequency <sup>(5)</sup>	Monitoring associated with																
NH <sub>3</sub>	— When SCR and/or SNCR is used	All sizes	Generic EN standards	Continuous <sup>(6)</sup> <sub>(7)</sub>	BAT 7																
NO <sub>x</sub>	<ul style="list-style-type: none"> <li>— Coal and/or lignite including waste co-incineration</li> <li>— Solid biomass and/or peat including waste co-incineration</li> <li>— HFO- and/or gas-oil-fired boilers and engines</li> <li>— Gas-oil-fired gas turbines</li> </ul>	All sizes	Generic EN standards	Continuous <sup>(6)</sup> <sub>(8)</sub>	BAT 20 BAT 24 BAT 28 BAT 32 BAT 37 BAT 41 BAT 42 BAT 43 BAT 47 BAT 48 BAT 56 BAT 64																

BAT Concn. Numbe r	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
		<ul style="list-style-type: none"> <li>— Natural-gas-fired boilers, engines, and turbines</li> <li>— Iron and steel process gases</li> <li>— Process fuels from the chemical industry</li> <li>— IGCC plants</li> </ul>				BAT 65 BAT 73		
		<ul style="list-style-type: none"> <li>— Combustion plants on offshore platforms</li> </ul>	All sizes	EN 14792	Once every year <sup>(9)</sup>	BAT 53		
N <sub>2</sub> O		<ul style="list-style-type: none"> <li>— Coal and/or lignite in circulating fluidised bed boilers</li> <li>— Solid biomass and/or peat in circulating fluidised bed boilers</li> </ul>	All sizes	EN 21258	Once every year <sup>(10)</sup>	BAT 20 BAT 24		
CO		<ul style="list-style-type: none"> <li>— Coal and/or lignite including waste co-incineration</li> <li>— Solid biomass and/or peat including waste co-incineration</li> <li>— HFO- and/or gas-oil-fired boilers and engines</li> <li>— Gas-oil-fired gas turbines</li> <li>— Natural-gas-fired boilers, engines, and turbines</li> <li>— Iron and steel process gases</li> <li>— Process fuels from the chemical industry</li> <li>— IGCC plants</li> </ul>	All sizes	Generic EN standards	Continuous <sup>(6)</sup> <sup>(8)</sup>	BAT 20 BAT 24 BAT 28 BAT 33 BAT 38 BAT 44 BAT 49 BAT 56 BAT 64 BAT 65 BAT 73		
		<ul style="list-style-type: none"> <li>— Combustion plants on offshore platforms</li> </ul>	All sizes	EN 15058	Once every year <sup>(9)</sup>	BAT 54		



BAT Concn. Numbe r	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	SO <sub>2</sub>	<ul style="list-style-type: none"> <li>— Coal and/or lignite incl waste co-incineration</li> <li>— Solid biomass and/or peat incl waste co-incineration</li> <li>— HFO- and/or gas-oil-fired boilers</li> <li>— HFO- and/or gas-oil-fired engines</li> <li>— Gas-oil-fired gas turbines</li> <li>— Iron and steel process gases</li> <li>— Process fuels from the chemical industry in boilers</li> <li>— IGCC plants</li> </ul>	All sizes	Generic EN standards and EN 14791	Continuous <sub>(6)</sub> <sup>(11)</sup> <sup>(12)</sup>	BAT 21 BAT 25 BAT 29 BAT 34 BAT 39 BAT 50 BAT 57 BAT 66 BAT 67 BAT 74		
	SO <sub>3</sub>	<ul style="list-style-type: none"> <li>— When SCR is used</li> </ul>	All sizes	No EN standard available	Once every year	—		
	Gaseous chlorides, expressed as HCl	<ul style="list-style-type: none"> <li>— Coal and/or lignite</li> <li>— Process fuels from the chemical industry in boilers</li> </ul>	All sizes	EN 1911	Once every three months <sub>(6)</sub> <sup>(13)</sup> <sup>(14)</sup>	BAT 21 BAT 57		
		<ul style="list-style-type: none"> <li>— Solid biomass and/or peat</li> </ul>	All sizes	Generic EN standards	Continuous <sub>(15)</sub> <sup>(16)</sup>	BAT 25		
		<ul style="list-style-type: none"> <li>— Waste co-incineration</li> </ul>	All sizes	Generic EN standards	Continuous <sub>(6)</sub> <sup>(16)</sup>	BAT 66 BAT 67		
	HF	<ul style="list-style-type: none"> <li>— Coal and/or lignite</li> <li>— Process fuels from the chemical industry in boilers</li> </ul>	All sizes	No EN standard available	Once every three months <sub>(6)</sub> <sup>(13)</sup> <sup>(14)</sup>	BAT 21 BAT 57		
		<ul style="list-style-type: none"> <li>— Solid biomass and/or peat</li> </ul>	All sizes	No EN standard available	Once every year	BAT 25		
		<ul style="list-style-type: none"> <li>— Waste co-incineration</li> </ul>	All sizes	Generic EN standards	Continuous <sub>(6)</sub> <sup>(16)</sup>	BAT 66 BAT 67		
	Dust	<ul style="list-style-type: none"> <li>— Coal and/or lignite</li> </ul>	All sizes	Generic EN standards and	Continuous <sub>(6)</sub> <sup>(17)</sup>	BAT 22 BAT 26		

BAT Concn. Numbe r	Summary of BAT Conclusion requirement					Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
		<ul style="list-style-type: none"> <li>— Solid biomass and/or peat</li> <li>— HFO- and/or gas-oil-fired boilers</li> <li>— Iron and steel process gases</li> <li>— Process fuels from the chemical industry in boilers</li> <li>— IGCC plants</li> <li>— HFO- and/or gas-oil-fired engines</li> <li>— Gas-oil-fired gas turbines</li> </ul>		EN 13284-1 and EN 13284-2		BAT 30 BAT 35 BAT 39 BAT 51 BAT 58 BAT 75	
		— Waste co-incineration	All sizes	Generic EN standards and EN 13284-2	Continuous	BAT 68 BAT 69	
	Metals and metalloids except mercury (As, Cd, Co, Cr, Cu, Mn, Ni, Pb, Sb, Se, Ti, V, Zn)	<ul style="list-style-type: none"> <li>— Coal and/or lignite</li> <li>— Solid biomass and/or peat</li> <li>— HFO- and/or gas-oil-fired boilers and engines</li> </ul>	All sizes	EN 14385	Once every year <sub>(18)</sub>	BAT 22 BAT 26 BAT 30	
		— Waste co-incineration	< 300 MW <sub>th</sub>	EN 14385	Once every six months <sub>(13)</sub>	BAT 68 BAT 69	
			≥ 300 MW <sub>th</sub>	EN 14385	Once every three months <sub>(19)</sub> <sub>(13)</sub>		
		— IGCC plants	≥ 100 MW <sub>th</sub>	EN 14385	Once every year <sub>(18)</sub>	BAT 75	
	Hg	— Coal and/or lignite including waste co-incineration	< 300 MW <sub>th</sub>	EN 13211	Once every three months <sub>(13)</sub> <sub>(20)</sub>	BAT 23	
			≥ 300 MW <sub>th</sub>	Generic EN standards and EN 14884	Continuous <sub>(16)</sub> <sub>(21)</sub>		
		— Solid biomass and/or peat	All sizes	EN 13211	Once every year <sub>(22)</sub>	BAT 27	
		— Waste co-incineration with solid biomass and/or peat	All sizes	EN 13211	Once every three months <sub>(13)</sub>	BAT 70	
		— IGCC plants	≥ 100 MW <sub>th</sub>	EN 13211	Once every year <sub>(23)</sub>	BAT 75	

BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																						
	TVOC	<ul style="list-style-type: none"> <li>— HFO- and/or gas-oil-fired engines</li> <li>— Process fuels from chemical industry in boilers</li> </ul>	All sizes	EN 12619	Once every six months <sup>[13]</sup>	BAT 33 BAT 59																								
		<ul style="list-style-type: none"> <li>— Waste co-incineration with coal, lignite, solid biomass and/or peat</li> </ul>	All sizes	Generic EN standards	Continuous	BAT 71																								
	Formaldehyde	<ul style="list-style-type: none"> <li>— Natural-gas in spark-ignited lean-burn gas and dual fuel engines</li> </ul>	All sizes	No EN standard available	Once every year	BAT 45																								
	CH <sub>4</sub>	<ul style="list-style-type: none"> <li>— Natural-gas-fired engines</li> </ul>	All sizes	EN ISO 25139	Once every year <sup>[24]</sup>	BAT 45																								
	PCDD/F	<ul style="list-style-type: none"> <li>— Process fuels from chemical industry in boilers</li> <li>— Waste co-incineration</li> </ul>	All sizes	EN 1948-1, EN 1948-2, EN 1948-3	Once every six months <sup>[13]</sup> <sup>[25]</sup>	BAT 59 BAT 71																								
5	<p>BAT is to monitor emissions to water from flue-gas treatment with at least the frequency given below and in accordance with EN standards. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.</p>						NA	No emissions to water result from flue-gas treatment.																						
	<table border="1"> <thead> <tr> <th data-bbox="331 975 595 1058">Substance/Parameter</th> <th data-bbox="663 975 1021 1058">Standard(s)</th> <th data-bbox="1021 975 1261 1058">Minimum monitoring frequency</th> <th data-bbox="1261 975 1485 1058">Monitoring associated with</th> </tr> </thead> <tbody> <tr> <td data-bbox="331 1058 663 1094">Total organic carbon (TOC)<sup>[26]</sup></td> <td data-bbox="663 1058 1021 1094">EN 1484</td> <td data-bbox="1021 1058 1261 1361" rowspan="8">Once every month</td> <td data-bbox="1261 1058 1485 1361" rowspan="8">BAT 15</td> </tr> <tr> <td data-bbox="331 1094 663 1153">Chemical oxygen demand (COD)<sup>[26]</sup></td> <td data-bbox="663 1094 1021 1153">No EN standard available</td> </tr> <tr> <td data-bbox="331 1153 663 1190">Total suspended solids (TSS)</td> <td data-bbox="663 1153 1021 1190">EN 872</td> </tr> <tr> <td data-bbox="331 1190 663 1227">Fluoride (F<sup>-</sup>)</td> <td data-bbox="663 1190 1021 1227">EN ISO 10304-1</td> </tr> <tr> <td data-bbox="331 1227 663 1264">Sulphate (SO<sub>4</sub><sup>2-</sup>)</td> <td data-bbox="663 1227 1021 1264">EN ISO 10304-1</td> </tr> <tr> <td data-bbox="331 1264 663 1300">Sulphide, easily released (S<sup>2-</sup>)</td> <td data-bbox="663 1264 1021 1300">No EN standard available</td> </tr> <tr> <td data-bbox="331 1300 663 1337">Sulphite (SO<sub>3</sub><sup>2-</sup>)</td> <td data-bbox="663 1300 1021 1337">EN ISO 10304-3</td> </tr> <tr> <td data-bbox="331 1337 663 1361">Metals and metalloids</td> <td data-bbox="663 1337 1021 1361">As</td> </tr> </tbody> </table>		Substance/Parameter	Standard(s)	Minimum monitoring frequency	Monitoring associated with	Total organic carbon (TOC) <sup>[26]</sup>	EN 1484	Once every month	BAT 15	Chemical oxygen demand (COD) <sup>[26]</sup>	No EN standard available	Total suspended solids (TSS)	EN 872	Fluoride (F <sup>-</sup> )	EN ISO 10304-1	Sulphate (SO <sub>4</sub> <sup>2-</sup> )	EN ISO 10304-1	Sulphide, easily released (S <sup>2-</sup> )	No EN standard available	Sulphite (SO <sub>3</sub> <sup>2-</sup> )	EN ISO 10304-3	Metals and metalloids	As						
Substance/Parameter	Standard(s)	Minimum monitoring frequency	Monitoring associated with																											
Total organic carbon (TOC) <sup>[26]</sup>	EN 1484	Once every month	BAT 15																											
Chemical oxygen demand (COD) <sup>[26]</sup>	No EN standard available																													
Total suspended solids (TSS)	EN 872																													
Fluoride (F <sup>-</sup> )	EN ISO 10304-1																													
Sulphate (SO <sub>4</sub> <sup>2-</sup> )	EN ISO 10304-1																													
Sulphide, easily released (S <sup>2-</sup> )	No EN standard available																													
Sulphite (SO <sub>3</sub> <sup>2-</sup> )	EN ISO 10304-3																													
Metals and metalloids	As																													

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																														
	<table border="1"> <tr> <td data-bbox="331 392 595 683"></td> <td data-bbox="595 392 663 416">Cd</td> <td data-bbox="663 392 1021 683" rowspan="6">Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)</td> <td data-bbox="1021 392 1256 683" rowspan="6"></td> <td data-bbox="1256 392 1480 683" rowspan="6"></td> </tr> <tr> <td></td> <td>Cr</td> </tr> <tr> <td></td> <td>Cu</td> </tr> <tr> <td></td> <td>Ni</td> </tr> <tr> <td></td> <td>Pb</td> </tr> <tr> <td></td> <td>Zn</td> </tr> <tr> <td></td> <td>Hg</td> <td data-bbox="663 603 1021 683">Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)</td> <td></td> <td></td> </tr> <tr> <td data-bbox="331 683 595 767">Chloride (Cl<sup>-</sup>)</td> <td data-bbox="595 683 1021 767"></td> <td data-bbox="663 683 1021 767">Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)</td> <td></td> <td data-bbox="1256 683 1480 767">—</td> </tr> <tr> <td data-bbox="331 767 595 807">Total nitrogen</td> <td data-bbox="595 767 1021 807"></td> <td data-bbox="663 767 1021 807">EN 12260</td> <td></td> <td data-bbox="1256 767 1480 807">—</td> </tr> </table>		Cd	Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)				Cr		Cu		Ni		Pb		Zn		Hg	Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)			Chloride (Cl <sup>-</sup> )		Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)		—	Total nitrogen		EN 12260		—		
	Cd	Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)																															
	Cr																																
	Cu																																
	Ni																																
	Pb																																
	Zn																																
	Hg	Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)																															
Chloride (Cl <sup>-</sup> )		Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)		—																													
Total nitrogen		EN 12260		—																													
6	<p>In order to improve the general environmental performance of combustion plants and to reduce emissions to air of CO and unburnt substances, BAT is to ensure optimised combustion and to use an appropriate combination of the techniques given below.</p> <table border="1"> <thead> <tr> <th data-bbox="331 919 555 943">Technique</th> <th data-bbox="555 919 987 943">Description</th> <th data-bbox="987 919 1480 943">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="331 951 555 1031">a. Fuel blending and mixing</td> <td data-bbox="555 951 987 1031">Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type</td> <td data-bbox="987 951 1480 1031" rowspan="2">Generally applicable</td> </tr> <tr> <td data-bbox="331 1031 555 1110">b. Maintenance of the combustion system</td> <td data-bbox="555 1031 987 1110">Regular planned maintenance according to suppliers' recommendations</td> </tr> <tr> <td data-bbox="331 1110 555 1198">c. Advanced control system</td> <td data-bbox="555 1110 987 1198">See description in Section 8.1</td> <td data-bbox="987 1110 1480 1198">The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> <tr> <td data-bbox="331 1198 555 1286">d. Good design of the combustion equipment</td> <td data-bbox="555 1198 987 1286">Good design of furnace, combustion chambers, burners and associated devices</td> <td data-bbox="987 1198 1480 1286">Generally applicable to new combustion plants</td> </tr> <tr> <td data-bbox="331 1286 555 1366">e. Fuel choice</td> <td data-bbox="555 1286 987 1366">Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury)</td> <td data-bbox="987 1286 1480 1366">Applicable within the constraints associated with the availability of suitable types of fuel with a better environmental profile as a whole, which may</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Fuel blending and mixing	Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type	Generally applicable	b. Maintenance of the combustion system	Regular planned maintenance according to suppliers' recommendations	c. Advanced control system	See description in Section 8.1	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system	d. Good design of the combustion equipment	Good design of furnace, combustion chambers, burners and associated devices	Generally applicable to new combustion plants	e. Fuel choice	Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury)	Applicable within the constraints associated with the availability of suitable types of fuel with a better environmental profile as a whole, which may	CC	<p>Fuel blending and mixing - the plant is run on natural gas, there are no backup or start up fuels. There is no requirement to blend or mix fuels.</p> <p>Maintenance of the combustion system - National Grid operates a preventative maintenance management system which is certified to both PAS 55 and ISO 55001. The maintenance system identifies all site plant and equipment and details the frequency and requirements for the maintenance set by the manufacturer, British and international standards and input from incidents and failures.</p>													
Technique	Description	Applicability																															
a. Fuel blending and mixing	Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type	Generally applicable																															
b. Maintenance of the combustion system	Regular planned maintenance according to suppliers' recommendations																																
c. Advanced control system	See description in Section 8.1	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system																															
d. Good design of the combustion equipment	Good design of furnace, combustion chambers, burners and associated devices	Generally applicable to new combustion plants																															
e. Fuel choice	Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury)	Applicable within the constraints associated with the availability of suitable types of fuel with a better environmental profile as a whole, which may																															

BAT Concn. Number	Summary of BAT Conclusion requirement		Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
		content) amongst the available fuels, including in start-up situations or when back- up fuels are used	be impacted by the energy policy of the Member State, or by the integrated site's fuel balance in the case of combustion of industrial process fuels. For existing combustion plants, the type of fuel chosen may be limited by the configuration and the design of the plant	<p>Advanced Control Systems – The control system controls parameters on the combustion system to reduce emissions to within the required limits.</p> <p>Good design of the combustion equipment – All units are more than 20 years old and of a design that maximises the combustion system. The operator confirms that the units are able to achieve the relevant emission limits.</p> <p>Fuel Choice – The plant is operated using natural gas, there are no backup or start up fuels. Natural gas quality is determined by the Gas Supply and Management Regulations (GSMR) and requires the gas to be controlled with in tight limits for quality, contents (low sulphur) and combustion characteristics. Natural gas is considered to represent the fuel with the best environmental profile for this installation.</p>

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
7	<p>In order to reduce emissions of ammonia to air from the use of selective catalytic reduction (SCR) and/or selective non-catalytic reduction (SNCR) for the abatement of NO<sub>x</sub> emissions, BAT is to optimise the design and/or operation of SCR and/or SNCR (e.g. optimised reagent to NO<sub>x</sub> ratio, homogeneous reagent distribution and optimum size of the reagent drops).</p> <p><b>BAT-associated emission levels</b></p> <p>The BAT-associated emission level (BAT-AEL) for emissions of NH<sub>3</sub> to air from the use of SCR and/or SNCR is &lt; 3–10 mg/Nm<sup>3</sup> as a yearly average or average over the sampling period. The lower end of the range can be achieved when using SCR and the upper end of the range can be achieved when using SNCR without wet abatement techniques. In the case of plants combusting biomass and operating at variable loads as well as in the case of engines combusting HFO and/or gas oil, the higher end of the BAT-AEL range is 15 mg/Nm<sup>3</sup>.</p>	NA	Not applicable - no SCR or SNCR on site.
8	<p>In order to prevent or reduce emissions to air during normal operating conditions, BAT is to ensure, by appropriate design, operation and maintenance, that the emission abatement systems are used at optimal capacity and availability.</p>	CC	<p>An operator training programme supports the usage and routine maintenance of the systems. Certain activities such as catalyst bed replacement are undertaken by specialist contractors.</p> <p>A planned preventative maintenance system ensures that equipment is prevented from unplanned stoppages, especially where this may have environmentally significant consequences. Unintended operations and slow changes in plant performance will trigger investigation and any necessary preventative maintenance.</p>
9	<p>In order to improve the general environmental performance of combustion and/or gasification plants and to reduce emissions to air, BAT is to include the following elements in the quality assurance/quality control programmes for all the fuels used, as part of the environmental management system (see BAT 1):</p> <p>(i) Initial full characterisation of the fuel used including at least the parameters listed below and in accordance with EN standards. ISO, national or other international standards may be used provided they ensure the provision of data of an equivalent scientific quality;</p>	CC	<p>LCPs are fired on Natural Gas only. This gas has to meet a nationally agreed specification for all the parameters listed. We consider that for plants which burn natural gas from the National Grid as a fuel that</p>

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																					
	<p>(ii) Regular testing of the fuel quality to check that it is consistent with the initial characterisation and according to the plant design specifications. The frequency of testing and the parameters chosen from the table below are based on the variability of the fuel and an assessment of the relevance of pollutant releases (e.g. concentration in fuel, flue-gas treatment employed);</p> <p>(iii) Subsequent adjustment of the plant settings as and when needed and practicable (e.g. integration of the fuel characterisation and control in the advanced control system (see description in Section 8.1)).</p> <p><b>Description</b> Initial characterisation and regular testing of the fuel can be performed by the operator and/or the fuel supplier. If performed by the supplier, the full results are provided to the operator in the form of a product (fuel) supplier specification and/or guarantee.</p> <table border="1" data-bbox="322 667 1487 1369"> <thead> <tr> <th data-bbox="322 667 712 703">Fuel(s)</th> <th data-bbox="712 667 1487 703">Substances/Parameters subject to characterisation</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 703 712 906" rowspan="4">Biomass/peat</td> <td data-bbox="712 703 1487 740">— LHV</td> </tr> <tr> <td data-bbox="712 740 1487 777">— moisture</td> </tr> <tr> <td data-bbox="712 777 1487 813">— Ash</td> </tr> <tr> <td data-bbox="712 813 1487 906">— C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn)</td> </tr> <tr> <td data-bbox="322 906 712 1120" rowspan="4">Coal/lignite</td> <td data-bbox="712 906 1487 943">— LHV</td> </tr> <tr> <td data-bbox="712 943 1487 979">— Moisture</td> </tr> <tr> <td data-bbox="712 979 1487 1016">— Volatiles, ash, fixed carbon, C, H, N, O, S</td> </tr> <tr> <td data-bbox="712 1016 1487 1120">— Br, Cl, F — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)</td> </tr> <tr> <td data-bbox="322 1120 712 1203" rowspan="2">HFO</td> <td data-bbox="712 1120 1487 1157">— Ash</td> </tr> <tr> <td data-bbox="712 1157 1487 1203">— C, S, N, Ni, V</td> </tr> <tr> <td data-bbox="322 1203 712 1286" rowspan="2">Gas oil</td> <td data-bbox="712 1203 1487 1240">— Ash</td> </tr> <tr> <td data-bbox="712 1240 1487 1286">— N, C, S</td> </tr> <tr> <td data-bbox="322 1286 712 1369" rowspan="2">Natural gas</td> <td data-bbox="712 1286 1487 1323">— LHV</td> </tr> <tr> <td data-bbox="712 1323 1487 1369">— CH<sub>4</sub>, C<sub>2</sub>H<sub>6</sub>, C<sub>3</sub>, C<sub>4</sub>+, CO<sub>2</sub>, N<sub>2</sub>, Wobbe index</td> </tr> </tbody> </table>	Fuel(s)	Substances/Parameters subject to characterisation	Biomass/peat	— LHV	— moisture	— Ash	— C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn)	Coal/lignite	— LHV	— Moisture	— Volatiles, ash, fixed carbon, C, H, N, O, S	— Br, Cl, F — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)	HFO	— Ash	— C, S, N, Ni, V	Gas oil	— Ash	— N, C, S	Natural gas	— LHV	— CH <sub>4</sub> , C <sub>2</sub> H <sub>6</sub> , C <sub>3</sub> , C <sub>4</sub> +, CO <sub>2</sub> , N <sub>2</sub> , Wobbe index		it is not necessary for the operator to replicate the testing carried out by the National Grid
Fuel(s)	Substances/Parameters subject to characterisation																							
Biomass/peat	— LHV																							
	— moisture																							
	— Ash																							
	— C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn)																							
Coal/lignite	— LHV																							
	— Moisture																							
	— Volatiles, ash, fixed carbon, C, H, N, O, S																							
	— Br, Cl, F — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)																							
HFO	— Ash																							
	— C, S, N, Ni, V																							
Gas oil	— Ash																							
	— N, C, S																							
Natural gas	— LHV																							
	— CH <sub>4</sub> , C <sub>2</sub> H <sub>6</sub> , C <sub>3</sub> , C <sub>4</sub> +, CO <sub>2</sub> , N <sub>2</sub> , Wobbe index																							

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement						
	<table border="1"> <tr> <td data-bbox="322 384 712 469">Process fuels from the chemical industry<sup>(27)</sup></td> <td data-bbox="712 384 1485 469"> <ul style="list-style-type: none"> <li>— Br, C, Cl, F, H, N, O, S</li> <li>— Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)</li> </ul> </td> </tr> <tr> <td data-bbox="322 469 712 539">Iron and steel process gases</td> <td data-bbox="712 469 1485 539"> <ul style="list-style-type: none"> <li>— LHV, CH<sub>4</sub> (for COG), C<sub>x</sub>H<sub>y</sub> (for COG), CO<sub>2</sub>, H<sub>2</sub>, N<sub>2</sub>, total sulphur, dust, Wobbe index</li> </ul> </td> </tr> <tr> <td data-bbox="322 539 712 695">Waste<sup>(28)</sup></td> <td data-bbox="712 539 1485 695"> <ul style="list-style-type: none"> <li>— LHV</li> <li>— Moisture</li> <li>— Volatiles, ash, Br, C, Cl, F, H, N, O, S</li> <li>— Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)</li> </ul> </td> </tr> </table>	Process fuels from the chemical industry <sup>(27)</sup>	<ul style="list-style-type: none"> <li>— Br, C, Cl, F, H, N, O, S</li> <li>— Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)</li> </ul>	Iron and steel process gases	<ul style="list-style-type: none"> <li>— LHV, CH<sub>4</sub> (for COG), C<sub>x</sub>H<sub>y</sub> (for COG), CO<sub>2</sub>, H<sub>2</sub>, N<sub>2</sub>, total sulphur, dust, Wobbe index</li> </ul>	Waste <sup>(28)</sup>	<ul style="list-style-type: none"> <li>— LHV</li> <li>— Moisture</li> <li>— Volatiles, ash, Br, C, Cl, F, H, N, O, S</li> <li>— Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)</li> </ul>		
Process fuels from the chemical industry <sup>(27)</sup>	<ul style="list-style-type: none"> <li>— Br, C, Cl, F, H, N, O, S</li> <li>— Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)</li> </ul>								
Iron and steel process gases	<ul style="list-style-type: none"> <li>— LHV, CH<sub>4</sub> (for COG), C<sub>x</sub>H<sub>y</sub> (for COG), CO<sub>2</sub>, H<sub>2</sub>, N<sub>2</sub>, total sulphur, dust, Wobbe index</li> </ul>								
Waste <sup>(28)</sup>	<ul style="list-style-type: none"> <li>— LHV</li> <li>— Moisture</li> <li>— Volatiles, ash, Br, C, Cl, F, H, N, O, S</li> <li>— Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)</li> </ul>								
10	<p>In order to reduce emissions to air and/or to water during other than normal operating conditions (OTNOC), BAT is to set up and implement a management plan as part of the environmental management system (see BAT 1), commensurate with the relevance of potential pollutant releases, that includes the following elements:</p> <ul style="list-style-type: none"> <li>— appropriate design of the systems considered relevant in causing OTNOC that may have an impact on emissions to air, water and/or soil (e.g. low-load design concepts for reducing the minimum start-up and shutdown loads for stable generation in gas turbines),</li> <li>— set-up and implementation of a specific preventive maintenance plan for these relevant systems,</li> <li>— review and recording of emissions caused by OTNOC and associated circumstances and implementation of corrective actions if necessary,</li> <li>— periodic assessment of the overall emissions during OTNOC (e.g. frequency of events, duration, emissions quantification/estimation) and implementation of corrective actions if necessary.</li> </ul>	CC	The LCPs control systems monitor critical gas turbine running parameters and shut down in case of malfunction and OTNOC.						
11	<p>BAT is to appropriately monitor emissions to air and/or to water during OTNOC.</p> <p><b>Description</b></p> <p>The monitoring can be carried out by direct measurement of emissions or by monitoring of surrogate parameters if this proves to be of equal or better scientific quality than the direct measurement of emissions. Emissions during start-up and shutdown (SU/SD) may be assessed based on a detailed emission measurement carried out for a typical SU/SD procedure at least once every year, and using the results of this measurement to estimate the emissions for each and every SU/SD throughout the year.</p>	CC	The LCPs control systems monitor critical gas turbine running parameters and shut down in case of malfunction and OTNOC.						
12	<p>In order to increase the energy efficiency of combustion, gasification and/or IGCC units operated ≥ 1 500 h/yr, BAT is to use an appropriate combination of the techniques given below.</p> <table border="1" data-bbox="322 1326 1485 1366"> <thead> <tr> <th data-bbox="322 1326 577 1366">Technique</th> <th data-bbox="577 1326 1055 1366">Description</th> <th data-bbox="1055 1326 1485 1366">Applicability</th> </tr> </thead> <tbody> <tr> <td> </td> <td> </td> <td> </td> </tr> </tbody> </table>	Technique	Description	Applicability				CC	Combustion optimisation -Dry Low Emission (DLE) lean burn pre-mixed combustion system ensures that fuel and air are pre-mixed prior
Technique	Description	Applicability							



BAT Concn. Numbe r	Summary of BAT Conclusion requirement				Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	a.	Combustion optimisation	See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues	Generally applicable		<p>to combustion to give a more homogenous reaction (flame) temperature below the temperatures at which thermal NO<sub>x</sub> production rates are elevated</p> <p>Optimisation of the working medium conditions - Operation of compressor units are aimed to be at optimum efficiency with the constraints of the system and supply/demand gas patterns, all medium used is pre-defined in the Gas Safety management Regulations (GSMR)</p> <p>Minimisation of energy consumption - Gas turbine, Power Turbine, and Gas Compressor are sized and optimised for the duty required</p> <p>Pre-heating of combustion air - Only used where anti, icing techniques are employed at low ambient temperatures.</p> <p>Fuel pre-heating - preheating by electric heat exchanger.</p> <p>Advanced control system - The DLE system is governed by the overall automatic combustion control system, which is controlled and monitored by programmable logic controllers (PLC)</p>
b.	Optimisation of the working medium conditions	Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO <sub>x</sub> emissions or the characteristics of energy demanded				
c.	Optimisation of the steam cycle	Operate with lower turbine exhaust pressure by utilisation of the lowest possible temperature of the condenser cooling water, within the design conditions				
d.	Minimisation of energy consumption	Minimising the internal energy consumption (e.g. greater efficiency of the feed-water pump)				
e.	Preheating of combustion air	Reuse of part of the heat recovered from the combustion flue-gas to preheat the air used in combustion	Generally applicable within the constraints related to the need to control NO <sub>x</sub> emissions			
f.	Fuel preheating	Preheating of fuel using recovered heat	Generally applicable within the constraints associated with the boiler design and the need to control NO <sub>x</sub> emissions			
g.	Advanced control system	See description in Section 8.2. Computerised control of the main combustion parameters enables the combustion efficiency to be improved	Generally applicable to new units. The applicability to old units may be constrained by the need to retrofit the combustion system and/or control command system			
h.	Feed-water preheating using recovered heat	Preheat water coming out of the steam condenser with recovered heat, before reusing it in the boiler	Only applicable to steam circuits and not to hot boilers. Applicability to existing units may be limited due to constraints associated with the plant configuration and the amount of recoverable heat			
i.	Heat recovery by cogeneration (CHP)	Recovery of heat (mainly from the steam system) for producing hot water/steam to be used in industrial processes/activities or in a public network for district heating. Additional heat recovery is possible from:	Applicable within the constraints associated with the local heat and power demand. The applicability may be limited in the case of gas compressors with an unpredictable operational heat profile			

BAT Concn. Numbe r	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
		<ul style="list-style-type: none"> <li>— flue-gas</li> <li>— grate cooling</li> <li>— circulating fluidised bed</li> </ul>			
	j.	CHP readiness	See description in Section 8.2.	Only applicable to new units where there is a realistic potential for the future use of heat in the vicinity of the unit	
	k.	Flue-gas condenser	See description in Section 8.2.	Generally applicable to CHP units provided there is enough demand for low-temperature heat	
	l.	Heat accumulation	Heat accumulation storage in CHP mode	Only applicable to CHP plants. The applicability may be limited in the case of low heat load demand	
	m.	Wet stack	See description in Section 8.2.	Generally applicable to new and existing units fitted with wet FGD	
	n.	Cooling tower discharge	The release of emissions to air through a cooling tower and not via a dedicated stack	Only applicable to units fitted with wet FGD where reheating of the flue-gas is necessary before release, and where the unit cooling system is a cooling tower	
	o.	Fuel pre-drying	The reduction of fuel moisture content before combustion to improve combustion conditions	Applicable to the combustion of biomass and/or peat within the constraints associated with spontaneous combustion risks (e.g. the moisture content of peat is kept above 40 % throughout the delivery chain). The retrofit of existing plants may be restricted by the extra calorific value that can be obtained from the drying operation and by the limited retrofit possibilities offered by some boiler designs or plant configurations	
	p.	Minimisation of heat losses	Minimising residual heat losses, e.g. those that occur via the slag or those that can be reduced by insulating radiating sources	Only applicable to solid-fuel-fired combustion units and to gasification/IGCC units	
	q.	Advanced materials	Use of advanced materials proven to be capable of withstanding high operating temperatures and	Only applicable to new plants	

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement												
	r.	Steam turbine upgrades	pressures and thus to achieve increased steam/combustion process efficiencies This includes techniques such as increasing the temperature and pressure of medium-pressure steam, addition of a low-pressure turbine, and modifications to the geometry of the turbine rotor blades	The applicability may be restricted by demand, steam conditions and/or limited plant lifetime													
	s.	Supercritical and ultra-supercritical steam conditions	Use of a steam circuit, including steam reheating systems, in which steam can reach pressures above 220,6 bar and temperatures above 374 °C in the case of supercritical conditions, and above 250 – 300 bar and temperatures above 580 – 600 °C in the case of ultra-supercritical conditions	Only applicable to new units of $\geq 600 \text{ MW}_{\text{th}}$ operated $> 4\,000 \text{ h/yr}$ . Not applicable when the purpose of the unit is to produce low steam temperatures and/or pressures in process industries. Not applicable to gas turbines and engines generating steam in CHP mode. For units combusting biomass, the applicability may be constrained by high-temperature corrosion in the case of certain biomasses													
13	In order to reduce water usage and the volume of contaminated waste water discharged, BAT is to use one or both of the techniques given below.			NA	Water is not used in the process of gas turbine driven mechanical drive gas compression in operation at the installation.												
	<table border="1"> <thead> <tr> <th data-bbox="322 932 367 963">Technique</th> <th data-bbox="367 932 519 963"></th> <th data-bbox="519 932 1055 963">Description</th> <th data-bbox="1055 932 1491 963">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 963 367 1102">a.</td> <td data-bbox="367 963 519 1102">Water recycling</td> <td data-bbox="519 963 1055 1102">Residual aqueous streams, including run-off water, from the plant are reused for other purposes. The degree of recycling is limited by the quality requirements of the recipient water stream and the water balance of the plant</td> <td data-bbox="1055 963 1491 1102">Not applicable to waste water from cooling systems when water treatment chemicals and/or high concentrations of salts from seawater are present</td> </tr> <tr> <td data-bbox="322 1102 367 1241">b.</td> <td data-bbox="367 1102 519 1241">Dry bottom ash handling</td> <td data-bbox="519 1102 1055 1241">Dry, hot bottom ash falls from the furnace onto a mechanical conveyor system and is cooled down by ambient air. No water is used in the process.</td> <td data-bbox="1055 1102 1491 1241">Only applicable to plants combusting solid fuels. There may be technical restrictions that prevent retrofitting to existing combustion plants</td> </tr> </tbody> </table>			Technique		Description	Applicability	a.	Water recycling	Residual aqueous streams, including run-off water, from the plant are reused for other purposes. The degree of recycling is limited by the quality requirements of the recipient water stream and the water balance of the plant	Not applicable to waste water from cooling systems when water treatment chemicals and/or high concentrations of salts from seawater are present	b.	Dry bottom ash handling	Dry, hot bottom ash falls from the furnace onto a mechanical conveyor system and is cooled down by ambient air. No water is used in the process.	Only applicable to plants combusting solid fuels. There may be technical restrictions that prevent retrofitting to existing combustion plants		
Technique		Description	Applicability														
a.	Water recycling	Residual aqueous streams, including run-off water, from the plant are reused for other purposes. The degree of recycling is limited by the quality requirements of the recipient water stream and the water balance of the plant	Not applicable to waste water from cooling systems when water treatment chemicals and/or high concentrations of salts from seawater are present														
b.	Dry bottom ash handling	Dry, hot bottom ash falls from the furnace onto a mechanical conveyor system and is cooled down by ambient air. No water is used in the process.	Only applicable to plants combusting solid fuels. There may be technical restrictions that prevent retrofitting to existing combustion plants														
14	<p>In order to prevent the contamination of uncontaminated waste water and to reduce emissions to water, BAT is to segregate waste water streams and to treat them separately, depending on the pollutant content.</p> <p><b>Description</b> Waste water streams that are typically segregated and treated include surface run-off water, cooling water, and waste water from flue-gas treatment.</p>			CC	Water is not used in the process and there is no direct water based effluent from the operation of the gas turbines on site.												

BAT Concn. Numbe r	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	<p><b>Applicability</b> The applicability may be restricted in the case of existing plants due to the configuration of the drainage systems.</p>		<p>A small amount of water (20 to 50 litres) is used with detergent to complete a "wash" of the gas turbine, to clean out combustion and airborne debris from the turbine internals. This is done on a monitored condition basis and frequency is determined by the run time of the plant. All of the water used to complete washing is contaminated. it is collected, segregated and disposed of as hazardous waste.</p> <p>There are no discharges to sewer from the installation. Domestic discharges from the facilities in the control building are directed to a bio-disc for treatment. The contents of the bio-disc are pumped out, by a third-party contractor, on a regular basis.</p> <p>All surface water and treated water from the bio-disc passes through the installation's main interceptor to remove any residual oil collected from site run-off, prior to being discharged to W1.</p> <p>No process effluent is discharged from emission point W1.</p> <p>A programme of visual inspection of the discharge, for oil and grease, is</p>

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																																													
			in place to ensure efficiency of the oil interceptor.																																													
15	<p>In order to reduce emissions to water from flue-gas treatment, BAT is to use an appropriate combination of the techniques given below, and to use secondary techniques as close as possible to the source in order to avoid dilution.</p> <table border="1" data-bbox="322 539 1487 1385"> <thead> <tr> <th data-bbox="322 539 707 600">Technique</th> <th data-bbox="707 539 1019 600">Typical pollutants prevented/abated</th> <th data-bbox="1019 539 1487 600">Applicability</th> </tr> </thead> <tbody> <tr> <td colspan="3" data-bbox="322 600 1487 635" style="text-align: center;"><b>Primary techniques</b></td> </tr> <tr> <td data-bbox="322 635 367 746">a.</td> <td data-bbox="367 635 707 746">Optimised combustion (see BAT 6) and flue-gas treatment systems (e.g. SCR/SNCR, see BAT 7)</td> <td data-bbox="707 635 1019 746">Organic compounds, ammonia (NH<sub>3</sub>)</td> </tr> <tr> <td colspan="3" data-bbox="322 746 1487 782" style="text-align: center;"><b>Secondary techniques <sup>(29)</sup></b></td> </tr> <tr> <td data-bbox="322 782 367 842">b.</td> <td data-bbox="367 782 707 842">Adsorption on activated carbon</td> <td data-bbox="707 782 1019 842">Organic compounds, mercury (Hg)</td> </tr> <tr> <td data-bbox="322 842 367 976">c.</td> <td data-bbox="367 842 707 976">Aerobic biological treatment</td> <td data-bbox="707 842 1019 976">Biodegradable organic compounds, ammonium (NH<sub>4</sub><sup>+</sup>)</td> </tr> <tr> <td data-bbox="322 976 367 1037">d.</td> <td data-bbox="367 976 707 1037">Anoxic/anaerobic biological treatment</td> <td data-bbox="707 976 1019 1037">Mercury (Hg), nitrate (NO<sub>3</sub><sup>-</sup>), nitrite (NO<sub>2</sub><sup>-</sup>)</td> </tr> <tr> <td data-bbox="322 1037 367 1066">e.</td> <td data-bbox="367 1037 707 1066">Coagulation and flocculation</td> <td data-bbox="707 1037 1019 1066">Suspended solids</td> </tr> <tr> <td data-bbox="322 1066 367 1126">f.</td> <td data-bbox="367 1066 707 1126">Crystallisation</td> <td data-bbox="707 1066 1019 1126">Metals and metalloids, sulphate (SO<sub>4</sub><sup>2-</sup>), fluoride (F<sup>-</sup>)</td> </tr> <tr> <td data-bbox="322 1126 367 1187">g.</td> <td data-bbox="367 1126 707 1187">Filtration (e.g. sand filtration, microfiltration, ultrafiltration)</td> <td data-bbox="707 1126 1019 1187">Suspended solids, metals</td> </tr> <tr> <td data-bbox="322 1187 367 1216">h.</td> <td data-bbox="367 1187 707 1216">Flotation</td> <td data-bbox="707 1187 1019 1216">Suspended solids, free oil</td> </tr> <tr> <td data-bbox="322 1216 367 1244">i.</td> <td data-bbox="367 1216 707 1244">Ion exchange</td> <td data-bbox="707 1216 1019 1244">Metals</td> </tr> <tr> <td data-bbox="322 1244 367 1273">j.</td> <td data-bbox="367 1244 707 1273">Neutralisation</td> <td data-bbox="707 1244 1019 1273">Acids, alkalis</td> </tr> <tr> <td data-bbox="322 1273 367 1302">k.</td> <td data-bbox="367 1273 707 1302">Oxidation</td> <td data-bbox="707 1273 1019 1302">Sulphide (S<sup>2-</sup>), sulphite (SO<sub>3</sub><sup>2-</sup>)</td> </tr> <tr> <td data-bbox="322 1302 367 1331">l.</td> <td data-bbox="367 1302 707 1331">Precipitation</td> <td data-bbox="707 1302 1019 1331">Metals and metalloids, sulphate (SO<sub>4</sub><sup>2-</sup>), fluoride (F<sup>-</sup>)</td> </tr> </tbody> </table>	Technique	Typical pollutants prevented/abated	Applicability	<b>Primary techniques</b>			a.	Optimised combustion (see BAT 6) and flue-gas treatment systems (e.g. SCR/SNCR, see BAT 7)	Organic compounds, ammonia (NH <sub>3</sub> )	<b>Secondary techniques <sup>(29)</sup></b>			b.	Adsorption on activated carbon	Organic compounds, mercury (Hg)	c.	Aerobic biological treatment	Biodegradable organic compounds, ammonium (NH <sub>4</sub> <sup>+</sup> )	d.	Anoxic/anaerobic biological treatment	Mercury (Hg), nitrate (NO <sub>3</sub> <sup>-</sup> ), nitrite (NO <sub>2</sub> <sup>-</sup> )	e.	Coagulation and flocculation	Suspended solids	f.	Crystallisation	Metals and metalloids, sulphate (SO <sub>4</sub> <sup>2-</sup> ), fluoride (F <sup>-</sup> )	g.	Filtration (e.g. sand filtration, microfiltration, ultrafiltration)	Suspended solids, metals	h.	Flotation	Suspended solids, free oil	i.	Ion exchange	Metals	j.	Neutralisation	Acids, alkalis	k.	Oxidation	Sulphide (S <sup>2-</sup> ), sulphite (SO <sub>3</sub> <sup>2-</sup> )	l.	Precipitation	Metals and metalloids, sulphate (SO <sub>4</sub> <sup>2-</sup> ), fluoride (F <sup>-</sup> )	NA	Not applicable as no emissions to water from flue-gas treatment.
Technique	Typical pollutants prevented/abated	Applicability																																														
<b>Primary techniques</b>																																																
a.	Optimised combustion (see BAT 6) and flue-gas treatment systems (e.g. SCR/SNCR, see BAT 7)	Organic compounds, ammonia (NH <sub>3</sub> )																																														
<b>Secondary techniques <sup>(29)</sup></b>																																																
b.	Adsorption on activated carbon	Organic compounds, mercury (Hg)																																														
c.	Aerobic biological treatment	Biodegradable organic compounds, ammonium (NH <sub>4</sub> <sup>+</sup> )																																														
d.	Anoxic/anaerobic biological treatment	Mercury (Hg), nitrate (NO <sub>3</sub> <sup>-</sup> ), nitrite (NO <sub>2</sub> <sup>-</sup> )																																														
e.	Coagulation and flocculation	Suspended solids																																														
f.	Crystallisation	Metals and metalloids, sulphate (SO <sub>4</sub> <sup>2-</sup> ), fluoride (F <sup>-</sup> )																																														
g.	Filtration (e.g. sand filtration, microfiltration, ultrafiltration)	Suspended solids, metals																																														
h.	Flotation	Suspended solids, free oil																																														
i.	Ion exchange	Metals																																														
j.	Neutralisation	Acids, alkalis																																														
k.	Oxidation	Sulphide (S <sup>2-</sup> ), sulphite (SO <sub>3</sub> <sup>2-</sup> )																																														
l.	Precipitation	Metals and metalloids, sulphate (SO <sub>4</sub> <sup>2-</sup> ), fluoride (F <sup>-</sup> )																																														

BAT Concn. Number	Summary of BAT Conclusion requirement				Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	m.	Sedimentation	Suspended solids	Generally applicable		
	n.	Stripping	Ammonia (NH <sub>3</sub> )	Generally applicable		
	The BAT-AELs refer to direct discharges to a receiving water body at the point where the emission leaves the installation.					
	<b>BAT-AELs for direct discharges to a receiving water body from flue-gas treatment</b>					
	<b>Substance/Parameter</b>		<b>BAT-AELs</b>			
			<b>Daily average</b>			
	Total organic carbon (TOC)		20–50 mg/l <sup>(30)</sup> <sub>1</sub> <sup>(31)</sup> <sub>1</sub> <sup>(32)</sup> <sub>1</sub>			
	Chemical oxygen demand (COD)		60–150 mg/l <sup>(30)</sup> <sub>1</sub> <sup>(31)</sup> <sub>1</sub> <sup>(32)</sup> <sub>1</sub>			
	Total suspended solids (TSS)		10–30 mg/l			
	Fluoride (F <sup>-</sup> )		10–25 mg/l <sup>(32)</sup> <sub>1</sub>			
	Sulphate (SO <sub>4</sub> <sup>2-</sup> )		1,3–2,0 g/l <sup>(32)</sup> <sub>1</sub> <sup>(33)</sup> <sub>1</sub> <sup>(34)</sup> <sub>1</sub> <sup>(35)</sup> <sub>1</sub>			
	Sulphide (S <sup>2-</sup> ), easily released		0,1–0,2 mg/l <sup>(32)</sup> <sub>1</sub>			
	Sulphite (SO <sub>3</sub> <sup>2-</sup> )		1–20 mg/l <sup>(32)</sup> <sub>1</sub>			
	Metals and metalloids		As	10–50 µg/l		
			Cd	2–5 µg/l		
			Cr	10–50 µg/l		
			Cu	10–50 µg/l		
			Hg	0,2–3 µg/l		
			Ni	10–50 µg/l		
			Pb	10–20 µg/l		
			Zn	50–200 µg/l		
16	<p>In order to reduce the quantity of waste sent for disposal from the combustion and/or gasification process and abatement techniques, BAT is to organise operations so as to maximise, in order of priority and taking into account life-cycle thinking:</p> <ul style="list-style-type: none"> <li>(a) waste prevention, e.g. maximise the proportion of residues which arise as by-products;</li> <li>(b) waste preparation for reuse, e.g. according to the specific requested quality criteria;</li> <li>(c) waste recycling;</li> <li>(d) other waste recovery (e.g. energy recovery),</li> </ul>				CC	<p>Not applicable as there is no waste generated from combustion process.</p> <p>The oxidising catalyst is a stainless steel matrix fused with platinum. There is no cleaning/maintenance</p>

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																				
	<p>by implementing an appropriate combination of techniques such as:</p> <table border="1" data-bbox="322 411 1485 1031"> <thead> <tr> <th data-bbox="322 411 360 443"></th> <th data-bbox="360 411 573 443">Technique</th> <th data-bbox="573 411 1077 443">Description</th> <th data-bbox="1077 411 1485 443">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 443 360 608">a.</td> <td data-bbox="360 443 573 608">Generation of gypsum as a by-product</td> <td data-bbox="573 443 1077 608">Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g. as raw material in the plasterboard industry). The quality of limestone used in the wet FGD influences the purity of the gypsum produced</td> <td data-bbox="1077 443 1485 608">Generally applicable within the constraints associated with the required gypsum quality, the health requirements associated to each specific use, and by the market conditions</td> </tr> <tr> <td data-bbox="322 608 360 762">b.</td> <td data-bbox="360 608 573 762">Recycling or recovery of residues in the construction sector</td> <td data-bbox="573 608 1077 762">Recycling or recovery of residues (e.g. from semi-dry desulphurisation processes, fly ash, bottom ash) as a construction material (e.g. in road building, to replace sand in concrete production, or in the cement industry)</td> <td data-bbox="1077 608 1485 762">Generally applicable within the constraints associated with the required material quality (e.g. physical properties, content of harmful substances) associated to each specific use, and by the market conditions</td> </tr> <tr> <td data-bbox="322 762 360 874">c.</td> <td data-bbox="360 762 573 874">Energy recovery by using waste in the fuel mix</td> <td data-bbox="573 762 1077 874">The residual energy content of carbon-rich ash and sludges generated by the combustion of coal, lignite, heavy fuel oil, peat or biomass can be recovered for example by mixing with the fuel</td> <td data-bbox="1077 762 1485 874">Generally applicable where plants can accept waste in the fuel mix and are technically able to feed the fuels into the combustion chamber</td> </tr> <tr> <td data-bbox="322 874 360 1031">d.</td> <td data-bbox="360 874 573 1031">Preparation of spent catalyst for reuse</td> <td data-bbox="573 874 1077 1031">Preparation of catalyst for reuse (e.g. up to four times for SCR catalysts) restores some or all of the original performance, extending the service life of the catalyst to several decades. Preparation of spent catalyst for reuse is integrated in a catalyst management scheme</td> <td data-bbox="1077 874 1485 1031">The applicability may be limited by the mechanical condition of the catalyst and the required performance with respect to controlling NO<sub>x</sub> and NH<sub>3</sub> emissions</td> </tr> </tbody> </table>		Technique	Description	Applicability	a.	Generation of gypsum as a by-product	Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g. as raw material in the plasterboard industry). The quality of limestone used in the wet FGD influences the purity of the gypsum produced	Generally applicable within the constraints associated with the required gypsum quality, the health requirements associated to each specific use, and by the market conditions	b.	Recycling or recovery of residues in the construction sector	Recycling or recovery of residues (e.g. from semi-dry desulphurisation processes, fly ash, bottom ash) as a construction material (e.g. in road building, to replace sand in concrete production, or in the cement industry)	Generally applicable within the constraints associated with the required material quality (e.g. physical properties, content of harmful substances) associated to each specific use, and by the market conditions	c.	Energy recovery by using waste in the fuel mix	The residual energy content of carbon-rich ash and sludges generated by the combustion of coal, lignite, heavy fuel oil, peat or biomass can be recovered for example by mixing with the fuel	Generally applicable where plants can accept waste in the fuel mix and are technically able to feed the fuels into the combustion chamber	d.	Preparation of spent catalyst for reuse	Preparation of catalyst for reuse (e.g. up to four times for SCR catalysts) restores some or all of the original performance, extending the service life of the catalyst to several decades. Preparation of spent catalyst for reuse is integrated in a catalyst management scheme	The applicability may be limited by the mechanical condition of the catalyst and the required performance with respect to controlling NO <sub>x</sub> and NH <sub>3</sub> emissions		required and no waste generated by the abatement system.
	Technique	Description	Applicability																				
a.	Generation of gypsum as a by-product	Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g. as raw material in the plasterboard industry). The quality of limestone used in the wet FGD influences the purity of the gypsum produced	Generally applicable within the constraints associated with the required gypsum quality, the health requirements associated to each specific use, and by the market conditions																				
b.	Recycling or recovery of residues in the construction sector	Recycling or recovery of residues (e.g. from semi-dry desulphurisation processes, fly ash, bottom ash) as a construction material (e.g. in road building, to replace sand in concrete production, or in the cement industry)	Generally applicable within the constraints associated with the required material quality (e.g. physical properties, content of harmful substances) associated to each specific use, and by the market conditions																				
c.	Energy recovery by using waste in the fuel mix	The residual energy content of carbon-rich ash and sludges generated by the combustion of coal, lignite, heavy fuel oil, peat or biomass can be recovered for example by mixing with the fuel	Generally applicable where plants can accept waste in the fuel mix and are technically able to feed the fuels into the combustion chamber																				
d.	Preparation of spent catalyst for reuse	Preparation of catalyst for reuse (e.g. up to four times for SCR catalysts) restores some or all of the original performance, extending the service life of the catalyst to several decades. Preparation of spent catalyst for reuse is integrated in a catalyst management scheme	The applicability may be limited by the mechanical condition of the catalyst and the required performance with respect to controlling NO <sub>x</sub> and NH <sub>3</sub> emissions																				
17	<p>In order to reduce noise emissions, BAT is to use one or a combination of the techniques given below.</p> <table border="1" data-bbox="322 1074 1485 1366"> <thead> <tr> <th data-bbox="322 1074 360 1106"></th> <th data-bbox="360 1074 573 1106">Technique</th> <th data-bbox="573 1074 1077 1106">Description</th> <th data-bbox="1077 1074 1485 1106">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 1106 360 1366">a.</td> <td data-bbox="360 1106 573 1366">Operational measures</td> <td data-bbox="573 1106 1077 1366">           These include:           <ul style="list-style-type: none"> <li>— improved inspection and maintenance of equipment</li> <li>— closing of doors and windows of enclosed areas, if possible</li> <li>— equipment operated by experienced staff</li> <li>— avoidance of noisy activities at night, if possible</li> </ul> </td> <td data-bbox="1077 1106 1485 1366">Generally applicable</td> </tr> </tbody> </table>		Technique	Description	Applicability	a.	Operational measures	These include: <ul style="list-style-type: none"> <li>— improved inspection and maintenance of equipment</li> <li>— closing of doors and windows of enclosed areas, if possible</li> <li>— equipment operated by experienced staff</li> <li>— avoidance of noisy activities at night, if possible</li> </ul>	Generally applicable	CC	<p>Equipment is operated by experienced staff and scheduled preventative maintenance in place.</p> <p>The gas turbine intake and exhaust systems are housed in an acoustically insulated building. Compressors are in the same building as gas turbine with acoustically lagged compressor pipework.</p>												
	Technique	Description	Applicability																				
a.	Operational measures	These include: <ul style="list-style-type: none"> <li>— improved inspection and maintenance of equipment</li> <li>— closing of doors and windows of enclosed areas, if possible</li> <li>— equipment operated by experienced staff</li> <li>— avoidance of noisy activities at night, if possible</li> </ul>	Generally applicable																				

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement											
		— provisions for noise control during maintenance activities			Depressurisation valves and vents; high velocity vents are required for atmospheric dispersion (safety requirement). However their use, including running for maintenance, is infrequent.											
	b. Low-noise equipment	This potentially includes compressors, pumps and disks	Generally applicable when the equipment is new or replaced													
	c. Noise attenuation	Noise propagation can be reduced by inserting obstacles between the emitter and the receiver. Appropriate obstacles include protection walls, embankments and buildings	Generally applicable to new plants. In the case of existing plants, the insertion of obstacles may be restricted by lack of space													
	d. Noise-control equipment	This includes: — noise-reducers — equipment insulation — enclosure of noisy equipment — soundproofing of buildings	The applicability may be restricted by lack of space													
	e. Appropriate location of equipment and buildings	Noise levels can be reduced by increasing the distance between the emitter and the receiver and by using buildings as noise screens	Generally applicable to new plant													
<b>Combustion of gaseous fuels</b>																
40	In order to increase the energy efficiency of natural gas combustion, BAT is to use an appropriate combination of the techniques given in BAT 12 and below.				<p>BAT 12: a, b, d, f, g, h, p and q.</p> <p>Combined cycle is not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns.</p> <p>The installation does not meet the minimum BAT-AEEL of 33.5% due to the initial efficiency of gas turbine/drive configuration along with the oxidising catalyst and weather hoods which decrease overall efficiency. The decision to</p>											
	<table border="1"> <thead> <tr> <th data-bbox="315 1011 488 1043">Technique</th> <th data-bbox="488 1011 723 1043">Description</th> <th data-bbox="723 1011 1491 1043">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="315 1043 488 1249">a. Combined cycle</td> <td data-bbox="488 1043 723 1249">See description in Section 8.2</td> <td data-bbox="723 1043 1491 1249">           Generally applicable to new gas turbines and engines except when operated &lt; 1 500 h/yr.            Applicable to existing gas turbines and engines within the constraints associated with the steam cycle design and the space availability.            Not applicable to existing gas turbines and engines operated &lt; 1 500 h/yr.            Not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns.            Not applicable to boilers         </td> </tr> </tbody> </table>	Technique	Description	Applicability		a. Combined cycle	See description in Section 8.2	Generally applicable to new gas turbines and engines except when operated < 1 500 h/yr. Applicable to existing gas turbines and engines within the constraints associated with the steam cycle design and the space availability. Not applicable to existing gas turbines and engines operated < 1 500 h/yr. Not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns. Not applicable to boilers								
Technique	Description	Applicability														
a. Combined cycle	See description in Section 8.2	Generally applicable to new gas turbines and engines except when operated < 1 500 h/yr. Applicable to existing gas turbines and engines within the constraints associated with the steam cycle design and the space availability. Not applicable to existing gas turbines and engines operated < 1 500 h/yr. Not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns. Not applicable to boilers														
	<b>BAT-associated energy efficiency levels (BAT-AEELs) for the combustion of natural gas</b>															
	<table border="1"> <thead> <tr> <th data-bbox="315 1291 584 1380" rowspan="2">Type of combustion unit</th> <th colspan="3" data-bbox="584 1291 1491 1323">BAT-AEELs <sup>(136)</sup> <sup>(137)</sup></th> </tr> <tr> <th data-bbox="584 1323 853 1380">Net electrical efficiency (%)</th> <th data-bbox="853 1323 1133 1380">Net total fuel utilisation (%) <sup>(138)</sup> <sup>(139)</sup></th> <th data-bbox="1133 1323 1491 1380">Net mechanical energy efficiency (%) <sup>(139)</sup> <sup>(140)</sup></th> </tr> </thead> <tbody> <tr> <td data-bbox="315 1380 584 1385"></td> <td data-bbox="584 1380 853 1385"></td> <td data-bbox="853 1380 1133 1385"></td> <td data-bbox="1133 1380 1491 1385"></td> </tr> </tbody> </table>	Type of combustion unit	BAT-AEELs <sup>(136)</sup> <sup>(137)</sup>			Net electrical efficiency (%)	Net total fuel utilisation (%) <sup>(138)</sup> <sup>(139)</sup>	Net mechanical energy efficiency (%) <sup>(139)</sup> <sup>(140)</sup>								
Type of combustion unit	BAT-AEELs <sup>(136)</sup> <sup>(137)</sup>															
	Net electrical efficiency (%)	Net total fuel utilisation (%) <sup>(138)</sup> <sup>(139)</sup>	Net mechanical energy efficiency (%) <sup>(139)</sup> <sup>(140)</sup>													



BAT Concn. Numbe r	Summary of BAT Conclusion requirement					Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																																																		
	<table border="1"> <thead> <tr> <th></th> <th>New unit</th> <th>Existing unit</th> <th></th> <th>New unit</th> <th>Existing unit</th> </tr> </thead> <tbody> <tr> <td>Gas engine</td> <td>39,5–44<sup>(141)</sup></td> <td>35–44<sup>(141)</sup></td> <td>56–85<sup>(141)</sup></td> <td colspan="2">No BAT-AEEL.</td> </tr> <tr> <td>Gas-fired boiler</td> <td>39–42,5</td> <td>38–40</td> <td>78–95</td> <td colspan="2">No BAT-AEEL.</td> </tr> <tr> <td>Open cycle gas turbine, ≥ 50 MW<sub>th</sub></td> <td>36–41,5</td> <td>33–41,5</td> <td>No BAT-AEEL</td> <td>36,5–41</td> <td>33,5–41</td> </tr> </tbody> </table>		New unit	Existing unit		New unit	Existing unit	Gas engine	39,5–44 <sup>(141)</sup>	35–44 <sup>(141)</sup>	56–85 <sup>(141)</sup>	No BAT-AEEL.		Gas-fired boiler	39–42,5	38–40	78–95	No BAT-AEEL.		Open cycle gas turbine, ≥ 50 MW <sub>th</sub>	36–41,5	33–41,5	No BAT-AEEL	36,5–41	33,5–41	<p style="text-align: center;"><b>Combined cycle gas turbine (CCGT)</b></p> <table border="1"> <tbody> <tr> <td>CCGT, 50–600 MW<sub>th</sub></td> <td>53–58,5</td> <td>46–54</td> <td>No BAT-AEEL</td> <td colspan="2">No BAT-AEEL</td> </tr> <tr> <td>CCGT, ≥ 600 MW<sub>th</sub></td> <td>57–60,5</td> <td>50–60</td> <td>No BAT-AEEL</td> <td colspan="2">No BAT-AEEL</td> </tr> <tr> <td>CHP CCGT, 50–600 MW<sub>th</sub></td> <td>53–58,5</td> <td>46–54</td> <td>65–95</td> <td colspan="2">No BAT-AEEL</td> </tr> <tr> <td>CHP CCGT, ≥ 600 MW<sub>th</sub></td> <td>57–60,5</td> <td>50–60</td> <td>65–95</td> <td colspan="2">No BAT-AEEL</td> </tr> </tbody> </table>	CCGT, 50–600 MW <sub>th</sub>	53–58,5	46–54	No BAT-AEEL	No BAT-AEEL		CCGT, ≥ 600 MW <sub>th</sub>	57–60,5	50–60	No BAT-AEEL	No BAT-AEEL		CHP CCGT, 50–600 MW <sub>th</sub>	53–58,5	46–54	65–95	No BAT-AEEL		CHP CCGT, ≥ 600 MW <sub>th</sub>	57–60,5	50–60	65–95	No BAT-AEEL								<p>install the oxidising catalyst at the site was made using the National Grid's Formal Environmental Assessment process for the identification and justification of BAT. These assessments were undertaken before the LCP BRef BAT-AEEL's had been published. The BAT assessments and subsequent EPR permit variation for the changes have been assessed and agreed by the EA and the project has now completed the installation. Significant investments have already been made at this site in order to reduce emissions. The oxidising catalysts were fitted in order to control CO emissions and allow the plant to meet the IED ELVs. The Operator has stated that the oxidising catalysts have also decreased overall efficiency, however assessment and installation of the catalysts took place in 2015 prior to the publication of the LCP BREF.</p> <p>We are satisfied that no further upgrades are currently planned for this plant and that the current net mechanical efficiency is BAT. A formal derogation is not required from the BAT-AEELs under Article 15(4) where it is proven that alternative values can be regarded as BAT.</p>
	New unit	Existing unit		New unit	Existing unit																																																				
Gas engine	39,5–44 <sup>(141)</sup>	35–44 <sup>(141)</sup>	56–85 <sup>(141)</sup>	No BAT-AEEL.																																																					
Gas-fired boiler	39–42,5	38–40	78–95	No BAT-AEEL.																																																					
Open cycle gas turbine, ≥ 50 MW <sub>th</sub>	36–41,5	33–41,5	No BAT-AEEL	36,5–41	33,5–41																																																				
CCGT, 50–600 MW <sub>th</sub>	53–58,5	46–54	No BAT-AEEL	No BAT-AEEL																																																					
CCGT, ≥ 600 MW <sub>th</sub>	57–60,5	50–60	No BAT-AEEL	No BAT-AEEL																																																					
CHP CCGT, 50–600 MW <sub>th</sub>	53–58,5	46–54	65–95	No BAT-AEEL																																																					
CHP CCGT, ≥ 600 MW <sub>th</sub>	57–60,5	50–60	65–95	No BAT-AEEL																																																					

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																						
			A process monitoring requirement has been set in table S3.3 which requires energy efficiency monitoring after an overhaul.																						
41	<p>In order to prevent or reduce NO<sub>x</sub> emissions to air from the combustion of natural gas in boilers, BAT is to use one or a combination of the techniques given below.</p> <table border="1" data-bbox="320 678 1487 1374"> <thead> <tr> <th data-bbox="320 678 577 715">Technique</th> <th data-bbox="577 678 1016 715">Description</th> <th data-bbox="1016 678 1487 715">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="320 715 577 799">a. Air and/or fuel staging</td> <td data-bbox="577 715 1016 799">See descriptions in Section 8.3. Air staging is often associated with low-NO<sub>x</sub> burners</td> <td data-bbox="1016 715 1487 799" rowspan="3">Generally applicable</td> </tr> <tr> <td data-bbox="320 799 577 836">b. Flue-gas recirculation</td> <td data-bbox="577 799 1016 836">See description in Section 8.3</td> </tr> <tr> <td data-bbox="320 836 577 890">c. Low-NO<sub>x</sub> burners (LNB)</td> <td data-bbox="577 836 1016 890"></td> </tr> <tr> <td data-bbox="320 890 577 1002">d. Advanced control system</td> <td data-bbox="577 890 1016 1002">See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated &lt; 500 h/yr</td> <td data-bbox="1016 890 1487 1002">The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> <tr> <td data-bbox="320 1002 577 1086">e. Reduction of the combustion air temperature</td> <td data-bbox="577 1002 1016 1086" rowspan="4">See description in Section 8.3</td> <td data-bbox="1016 1002 1487 1086">Generally applicable within the constraints associated with the process needs</td> </tr> <tr> <td data-bbox="320 1086 577 1219">f. Selective non-catalytic reduction (SNCR)</td> <td data-bbox="1016 1086 1487 1219">Not applicable to combustion plants operated &lt; 500 h/yr with highly variable boiler loads. The applicability may be limited in the case of combustion plants operated between 500 h/yr and 1 500 h/yr with highly variable boiler loads</td> </tr> <tr> <td data-bbox="320 1219 577 1374">g. Selective catalytic reduction (SCR)</td> <td data-bbox="1016 1219 1487 1374">Not applicable to combustion plants operated &lt; 500 h/yr. Not generally applicable to combustion plants of &lt; 100 MW<sub>th</sub>. There may be technical and economic restrictions for retrofitting existing combustion</td> </tr> <tr> <td data-bbox="320 1374 577 1380"></td> <td data-bbox="1016 1374 1487 1380"></td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Air and/or fuel staging	See descriptions in Section 8.3. Air staging is often associated with low-NO <sub>x</sub> burners	Generally applicable	b. Flue-gas recirculation	See description in Section 8.3	c. Low-NO <sub>x</sub> burners (LNB)		d. Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system	e. Reduction of the combustion air temperature	See description in Section 8.3	Generally applicable within the constraints associated with the process needs	f. Selective non-catalytic reduction (SNCR)	Not applicable to combustion plants operated < 500 h/yr with highly variable boiler loads. The applicability may be limited in the case of combustion plants operated between 500 h/yr and 1 500 h/yr with highly variable boiler loads	g. Selective catalytic reduction (SCR)	Not applicable to combustion plants operated < 500 h/yr. Not generally applicable to combustion plants of < 100 MW <sub>th</sub> . There may be technical and economic restrictions for retrofitting existing combustion			NA	Not applicable to Gas Turbines
Technique	Description	Applicability																							
a. Air and/or fuel staging	See descriptions in Section 8.3. Air staging is often associated with low-NO <sub>x</sub> burners	Generally applicable																							
b. Flue-gas recirculation	See description in Section 8.3																								
c. Low-NO <sub>x</sub> burners (LNB)																									
d. Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system																							
e. Reduction of the combustion air temperature	See description in Section 8.3	Generally applicable within the constraints associated with the process needs																							
f. Selective non-catalytic reduction (SNCR)		Not applicable to combustion plants operated < 500 h/yr with highly variable boiler loads. The applicability may be limited in the case of combustion plants operated between 500 h/yr and 1 500 h/yr with highly variable boiler loads																							
g. Selective catalytic reduction (SCR)		Not applicable to combustion plants operated < 500 h/yr. Not generally applicable to combustion plants of < 100 MW <sub>th</sub> . There may be technical and economic restrictions for retrofitting existing combustion																							

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																			
			plants operated between 500 h/yr and 1 500 h/yr																					
42	In order to prevent or reduce NO <sub>x</sub> emissions to air from the combustion of natural gas in gas turbines, BAT is to use one or a combination of the techniques given below.			CC	Operator confirms they are Compliant with the BAT AELs for NO <sub>x</sub> . The plant is fitted with a low NO <sub>x</sub> combustion system.																			
<table border="1"> <thead> <tr> <th data-bbox="322 517 353 555">Technique</th> <th data-bbox="353 517 1088 555">Description</th> <th data-bbox="1088 517 1489 555">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 555 353 660">a. Advanced control system</td> <td data-bbox="353 555 1088 660">See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated &lt; 500 h/yr</td> <td data-bbox="1088 555 1489 660">The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> <tr> <td data-bbox="322 660 353 719">b. Water/steam addition</td> <td data-bbox="353 660 1088 719" rowspan="2">See description in Section 8.3</td> <td data-bbox="1088 660 1489 719">The applicability may be limited due to water availability</td> </tr> <tr> <td data-bbox="322 719 353 855">c. Dry low-NO<sub>x</sub> burners (DLN)</td> <td data-bbox="1088 719 1489 855">The applicability may be limited in the case of turbines where a retrofit package is not available or when water/steam addition systems are installed</td> </tr> <tr> <td data-bbox="322 855 353 991">d. Low-load design concept</td> <td data-bbox="353 855 1088 991">Adaptation of the process control and related equipment to maintain good combustion efficiency when the demand in energy varies, e.g. by improving the inlet airflow control capability or by splitting the combustion process into decoupled combustion stages</td> <td data-bbox="1088 855 1489 991">The applicability may be limited by the gas turbine design</td> </tr> <tr> <td data-bbox="322 991 353 1096">e. Low-NO<sub>x</sub> burners (LNB)</td> <td data-bbox="353 991 1088 1096" rowspan="2">See description in Section 8.3</td> <td data-bbox="1088 991 1489 1096">Generally applicable to supplementary firing for heat recovery steam generators (HRSGs) in the case of combined-cycle gas turbine (CCGT) combustion plants</td> </tr> <tr> <td data-bbox="322 1096 353 1383">f. Selective catalytic reduction (SCR)</td> <td data-bbox="1088 1096 1489 1383">Not applicable in the case of combustion plants operated &lt; 500 h/yr. Not generally applicable to existing combustion plants of &lt; 100 MW<sub>th</sub>. Retrofitting existing combustion plants may be constrained by the availability of sufficient space. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr</td> </tr> </tbody> </table>						Technique	Description	Applicability	a. Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system	b. Water/steam addition	See description in Section 8.3	The applicability may be limited due to water availability	c. Dry low-NO <sub>x</sub> burners (DLN)	The applicability may be limited in the case of turbines where a retrofit package is not available or when water/steam addition systems are installed	d. Low-load design concept	Adaptation of the process control and related equipment to maintain good combustion efficiency when the demand in energy varies, e.g. by improving the inlet airflow control capability or by splitting the combustion process into decoupled combustion stages	The applicability may be limited by the gas turbine design	e. Low-NO <sub>x</sub> burners (LNB)	See description in Section 8.3	Generally applicable to supplementary firing for heat recovery steam generators (HRSGs) in the case of combined-cycle gas turbine (CCGT) combustion plants	f. Selective catalytic reduction (SCR)	Not applicable in the case of combustion plants operated < 500 h/yr. Not generally applicable to existing combustion plants of < 100 MW <sub>th</sub> . Retrofitting existing combustion plants may be constrained by the availability of sufficient space. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr
Technique	Description	Applicability																						
a. Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system																						
b. Water/steam addition	See description in Section 8.3	The applicability may be limited due to water availability																						
c. Dry low-NO <sub>x</sub> burners (DLN)		The applicability may be limited in the case of turbines where a retrofit package is not available or when water/steam addition systems are installed																						
d. Low-load design concept	Adaptation of the process control and related equipment to maintain good combustion efficiency when the demand in energy varies, e.g. by improving the inlet airflow control capability or by splitting the combustion process into decoupled combustion stages	The applicability may be limited by the gas turbine design																						
e. Low-NO <sub>x</sub> burners (LNB)	See description in Section 8.3	Generally applicable to supplementary firing for heat recovery steam generators (HRSGs) in the case of combined-cycle gas turbine (CCGT) combustion plants																						
f. Selective catalytic reduction (SCR)		Not applicable in the case of combustion plants operated < 500 h/yr. Not generally applicable to existing combustion plants of < 100 MW <sub>th</sub> . Retrofitting existing combustion plants may be constrained by the availability of sufficient space. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr																						

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																						
43	<p>In order to prevent or reduce NO<sub>x</sub> emissions to air from the combustion of natural gas in engines, BAT is to use one or a combination of the techniques given below.</p> <table border="1" data-bbox="322 440 1485 884"> <thead> <tr> <th data-bbox="322 440 353 472">Technique</th> <th data-bbox="353 440 994 472">Description</th> <th data-bbox="994 440 1485 472">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 472 353 584">a. Advanced control system</td> <td data-bbox="353 472 994 584">See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated &lt; 500 h/yr</td> <td data-bbox="994 472 1485 584">The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> <tr> <td data-bbox="322 584 353 644">b. Lean-burn concept</td> <td data-bbox="353 584 994 644">See description in Section 8.3. Generally used in combination with SCR</td> <td data-bbox="994 584 1485 644">Only applicable to new gas-fired engines</td> </tr> <tr> <td data-bbox="322 644 353 705">c. Advanced lean-burn concept</td> <td data-bbox="353 644 994 705" rowspan="2">See descriptions in Section 8.3</td> <td data-bbox="994 644 1485 705">Only applicable to new spark plug ignited engines</td> </tr> <tr> <td data-bbox="322 705 353 884">d. Selective catalytic reduction (SCR)</td> <td data-bbox="994 705 1485 884">Retrofitting existing combustion plants may be constrained by the availability of sufficient space. Not applicable to combustion plants operated &lt; 500 h/yr. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system	b. Lean-burn concept	See description in Section 8.3. Generally used in combination with SCR	Only applicable to new gas-fired engines	c. Advanced lean-burn concept	See descriptions in Section 8.3	Only applicable to new spark plug ignited engines	d. Selective catalytic reduction (SCR)	Retrofitting existing combustion plants may be constrained by the availability of sufficient space. Not applicable to combustion plants operated < 500 h/yr. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr	NA	Not applicable to Gas Turbines								
Technique	Description	Applicability																							
a. Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system																							
b. Lean-burn concept	See description in Section 8.3. Generally used in combination with SCR	Only applicable to new gas-fired engines																							
c. Advanced lean-burn concept	See descriptions in Section 8.3	Only applicable to new spark plug ignited engines																							
d. Selective catalytic reduction (SCR)		Retrofitting existing combustion plants may be constrained by the availability of sufficient space. Not applicable to combustion plants operated < 500 h/yr. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr																							
44	<p>In order to prevent or reduce CO emissions to air from the combustion of natural gas, BAT is to ensure optimised combustion and/or to use oxidation catalysts.</p> <p><b>Description - See descriptions in Section 8.3.</b>  <b>BAT-associated emission levels (BAT-AELs) for NO<sub>x</sub> emissions to air from the combustion of natural gas in gas turbines</b></p> <table border="1" data-bbox="322 1070 1485 1394"> <thead> <tr> <th data-bbox="322 1070 786 1190" rowspan="2">Type of combustion plant</th> <th data-bbox="786 1070 1025 1190" rowspan="2">Combustion plant total rated thermal input (MW<sub>th</sub>)</th> <th colspan="2" data-bbox="1025 1070 1485 1102">BAT-AELs (mg/Nm<sup>3</sup>)<sup>(142)</sup> <sup>(143)</sup></th> </tr> <tr> <th data-bbox="1025 1102 1249 1190">Yearly average<sup>(144)</sup> <sup>(145)</sup></th> <th data-bbox="1249 1102 1485 1190">Daily average or average over the sampling period</th> </tr> </thead> <tbody> <tr> <td colspan="4" data-bbox="322 1190 1485 1222" style="text-align: center;"><b>Open-cycle gas turbines (OCGTs)</b><sup>(146)</sup> <sup>(147)</sup></td> </tr> <tr> <td data-bbox="322 1222 786 1270">New OCGT</td> <td data-bbox="786 1222 1025 1270">≥ 50</td> <td data-bbox="1025 1222 1249 1270">15–35</td> <td data-bbox="1249 1222 1485 1270">25–50</td> </tr> <tr> <td data-bbox="322 1270 786 1350">Existing OCGT (excluding turbines for mechanical drive applications) — All but plants operated &lt; 500 h/yr</td> <td data-bbox="786 1270 1025 1350">≥ 50</td> <td data-bbox="1025 1270 1249 1350">15–50</td> <td data-bbox="1249 1270 1485 1350">25–55<sup>(148)</sup></td> </tr> <tr> <td colspan="4" data-bbox="322 1350 1485 1394" style="text-align: center;"><b>Combined-cycle gas turbines (CCGTs)</b><sup>(146)</sup> <sup>(149)</sup></td> </tr> </tbody> </table>	Type of combustion plant	Combustion plant total rated thermal input (MW <sub>th</sub> )	BAT-AELs (mg/Nm <sup>3</sup> ) <sup>(142)</sup> <sup>(143)</sup>		Yearly average <sup>(144)</sup> <sup>(145)</sup>	Daily average or average over the sampling period	<b>Open-cycle gas turbines (OCGTs)</b> <sup>(146)</sup> <sup>(147)</sup>				New OCGT	≥ 50	15–35	25–50	Existing OCGT (excluding turbines for mechanical drive applications) — All but plants operated < 500 h/yr	≥ 50	15–50	25–55 <sup>(148)</sup>	<b>Combined-cycle gas turbines (CCGTs)</b> <sup>(146)</sup> <sup>(149)</sup>				CC	<p>Operator confirms they are compliant with the BAT AELs for CO. Plant is fitted with an oxidation catalyst to reduce CO levels.</p> <p>There has been limited running post catalyst installation. However, the Operator confirms that initial testing indicates the plant will operate at CO levels of less than 20mg/m<sup>3</sup>.</p> <p>Limits for CO and NO<sub>x</sub> are applicable above 55% MCR. See the key issues section for further information.</p>
Type of combustion plant	Combustion plant total rated thermal input (MW <sub>th</sub> )			BAT-AELs (mg/Nm <sup>3</sup> ) <sup>(142)</sup> <sup>(143)</sup>																					
		Yearly average <sup>(144)</sup> <sup>(145)</sup>	Daily average or average over the sampling period																						
<b>Open-cycle gas turbines (OCGTs)</b> <sup>(146)</sup> <sup>(147)</sup>																									
New OCGT	≥ 50	15–35	25–50																						
Existing OCGT (excluding turbines for mechanical drive applications) — All but plants operated < 500 h/yr	≥ 50	15–50	25–55 <sup>(148)</sup>																						
<b>Combined-cycle gas turbines (CCGTs)</b> <sup>(146)</sup> <sup>(149)</sup>																									

BAT Concn. Number	Summary of BAT Conclusion requirement				Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																				
	<table border="1"> <tr> <td>New CCGT</td> <td>≥ 50</td> <td>10–30</td> <td>15–40</td> </tr> <tr> <td>Existing CCGT with a net total fuel utilisation of &lt; 75 %</td> <td>≥ 600</td> <td>10–40</td> <td>18–50</td> </tr> <tr> <td>Existing CCGT with a net total fuel utilisation of ≥ 75 %</td> <td>≥ 600</td> <td>10–50</td> <td>18–55 <sup>(150)</sup></td> </tr> <tr> <td>Existing CCGT with a net total fuel utilisation of &lt; 75 %</td> <td>50–600</td> <td>10–45</td> <td>35–55</td> </tr> <tr> <td>Existing CCGT with a net total fuel utilisation of ≥ 75 %</td> <td>50–600</td> <td>25–50 <sup>(151)</sup></td> <td>35–55 <sup>(152)</sup></td> </tr> </table>	New CCGT	≥ 50	10–30	15–40	Existing CCGT with a net total fuel utilisation of < 75 %	≥ 600	10–40	18–50	Existing CCGT with a net total fuel utilisation of ≥ 75 %	≥ 600	10–50	18–55 <sup>(150)</sup>	Existing CCGT with a net total fuel utilisation of < 75 %	50–600	10–45	35–55	Existing CCGT with a net total fuel utilisation of ≥ 75 %	50–600	25–50 <sup>(151)</sup>	35–55 <sup>(152)</sup>					
New CCGT	≥ 50	10–30	15–40																							
Existing CCGT with a net total fuel utilisation of < 75 %	≥ 600	10–40	18–50																							
Existing CCGT with a net total fuel utilisation of ≥ 75 %	≥ 600	10–50	18–55 <sup>(150)</sup>																							
Existing CCGT with a net total fuel utilisation of < 75 %	50–600	10–45	35–55																							
Existing CCGT with a net total fuel utilisation of ≥ 75 %	50–600	25–50 <sup>(151)</sup>	35–55 <sup>(152)</sup>																							
	<b>Open- and combined-cycle gas turbines</b>																									
	Gas turbine put into operation no later than 27 November 2003, or existing gas turbine for emergency use and operated < 500 h/yr	≥ 50	No BAT-AEL	60–140 <sup>(153)</sup> <sup>(154)</sup>																						
	Existing gas turbine for mechanical drive applications — All but plants operated < 500 h/yr	≥ 50	15–50 <sup>(155)</sup>	25–55 <sup>(156)</sup>																						
	<p>As an indication, the yearly average CO emission levels for each type of existing combustion plant operated ≥ 1 500 h/yr and for each type of new combustion plant will generally be as follows:</p> <ul style="list-style-type: none"> <li>— New OCGT of ≥ 50 MW<sub>th</sub>: &lt; 5–40 mg/Nm<sup>3</sup>. For plants with a net electrical efficiency (EE) greater than 39 %, a correction factor may be applied to the higher end of this range, corresponding to [higher end] × EE/39, where EE is the net electrical energy efficiency or net mechanical energy efficiency of the plant determined at ISO baseload conditions.</li> <li>— Existing OCGT of ≥ 50 MW<sub>th</sub> (excluding turbines for mechanical drive applications): &lt; 5–40 mg/Nm<sup>3</sup>. The higher end of this range will generally be 80 mg/Nm<sup>3</sup> in the case of existing plants that cannot be fitted with dry techniques for NO<sub>x</sub> reduction, or 50 mg/Nm<sup>3</sup> for plants that operate at low load.</li> <li>— New CCGT of ≥ 50 MW<sub>th</sub>: &lt; 5–30 mg/Nm<sup>3</sup>. For plants with a net electrical efficiency (EE) greater than 55 %, a correction factor may be applied to the higher end of the range, corresponding to [higher end] × EE/55, where EE is the net electrical energy efficiency of the plant determined at ISO baseload conditions.</li> <li>— Existing CCGT of ≥ 50 MW<sub>th</sub>: &lt; 5–30 mg/Nm<sup>3</sup>. The higher end of this range will generally be 50 mg/Nm<sup>3</sup> for plants that operate at low load.</li> <li>— Existing gas turbines of ≥ 50 MW<sub>th</sub> for mechanical drive applications: &lt; 5–40 mg/Nm<sup>3</sup>. The higher end of the range will generally be 50 mg/Nm<sup>3</sup> when plants operate at low load.</li> </ul> <p>In the case of a gas turbine equipped with DLN burners, these indicative levels correspond to when the DLN operation is effective.</p>																									

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																							
	<p><b>BAT-associated emission levels (BAT-AELs) for NO<sub>x</sub> emissions to air from the combustion of natural gas in boilers and engines</b></p> <table border="1" data-bbox="322 440 1485 663"> <thead> <tr> <th rowspan="3">Type of combustion plant</th> <th colspan="4">BAT-AELs (mg/Nm<sup>3</sup>)</th> </tr> <tr> <th colspan="2">Yearly average <sup>(157)</sup></th> <th colspan="2">Daily average or average over the sampling period</th> </tr> <tr> <th>New plant</th> <th>Existing plant <sup>(158)</sup></th> <th>New plant</th> <th>Existing plant <sup>(159)</sup></th> </tr> </thead> <tbody> <tr> <td>Boiler</td> <td>10–60</td> <td>50–100</td> <td>30–85</td> <td>85–110</td> </tr> <tr> <td>Engine <sup>(160)</sup></td> <td>20–75</td> <td>20–100</td> <td>55–85</td> <td>55–110 <sup>(161)</sup></td> </tr> </tbody> </table> <p>As an indication, the yearly average CO emission levels will generally be:</p> <ul style="list-style-type: none"> <li>— &lt; 5–40 mg/Nm<sup>3</sup> for existing boilers operated ≥ 1 500 h/yr,</li> <li>— &lt; 5–15 mg/Nm<sup>3</sup> for new boilers,</li> <li>— 30–100 mg/Nm<sup>3</sup> for existing engines operated ≥ 1 500 h/yr and for new engines.</li> </ul>	Type of combustion plant	BAT-AELs (mg/Nm <sup>3</sup> )				Yearly average <sup>(157)</sup>		Daily average or average over the sampling period		New plant	Existing plant <sup>(158)</sup>	New plant	Existing plant <sup>(159)</sup>	Boiler	10–60	50–100	30–85	85–110	Engine <sup>(160)</sup>	20–75	20–100	55–85	55–110 <sup>(161)</sup>		
Type of combustion plant	BAT-AELs (mg/Nm <sup>3</sup> )																									
	Yearly average <sup>(157)</sup>		Daily average or average over the sampling period																							
	New plant	Existing plant <sup>(158)</sup>	New plant	Existing plant <sup>(159)</sup>																						
Boiler	10–60	50–100	30–85	85–110																						
Engine <sup>(160)</sup>	20–75	20–100	55–85	55–110 <sup>(161)</sup>																						
45	<p>In order to reduce non-methane volatile organic compounds (NMVOC) and methane (CH<sub>4</sub>) emissions to air from the combustion of natural gas in spark-ignited lean-burn gas engines, BAT is to ensure optimised combustion and/or to use oxidation catalysts.</p> <p><b>Description</b></p> <p>See descriptions in Section 8.3. Oxidation catalysts are not effective at reducing the emissions of saturated hydrocarbons containing less than four carbon atoms.</p> <p><b>BAT-associated emission levels (BAT-AELs) for formaldehyde and CH<sub>4</sub> emissions to air from the combustion of natural gas in a spark-ignited lean-burn gas engine</b></p> <table border="1" data-bbox="322 1050 1485 1225"> <thead> <tr> <th rowspan="4">Combustion plant total rated thermal input (MW<sub>th</sub>)</th> <th colspan="3">BAT-AELs (mg/Nm<sup>3</sup>)</th> </tr> <tr> <th>Formaldehyde</th> <th colspan="2">CH<sub>4</sub></th> </tr> <tr> <th colspan="3">Average over the sampling period</th> </tr> <tr> <th>New or existing plant</th> <th>New plant</th> <th>Existing plant</th> </tr> </thead> <tbody> <tr> <td>≥ 50</td> <td>5–15 <sup>(162)</sup></td> <td>215–500 <sup>(163)</sup></td> <td>215–560 <sup>(162)</sup> <sup>(163)</sup></td> </tr> </tbody> </table>	Combustion plant total rated thermal input (MW <sub>th</sub> )	BAT-AELs (mg/Nm <sup>3</sup> )			Formaldehyde	CH <sub>4</sub>		Average over the sampling period			New or existing plant	New plant	Existing plant	≥ 50	5–15 <sup>(162)</sup>	215–500 <sup>(163)</sup>	215–560 <sup>(162)</sup> <sup>(163)</sup>	NA	Not applicable to Gas Turbines						
Combustion plant total rated thermal input (MW <sub>th</sub> )	BAT-AELs (mg/Nm <sup>3</sup> )																									
	Formaldehyde		CH <sub>4</sub>																							
	Average over the sampling period																									
	New or existing plant	New plant	Existing plant																							
≥ 50	5–15 <sup>(162)</sup>	215–500 <sup>(163)</sup>	215–560 <sup>(162)</sup> <sup>(163)</sup>																							

## **6. Review and assessment of derogation requests made by the operator in relation to BAT Conclusions which include an associated emission level (AEL) value**

The IED enables a competent authority to allow derogations from BAT AELs stated in BAT Conclusions under specific circumstances as detailed under Article 15(4):

By way of derogation from paragraph 3, and without prejudice to Article 18, the competent authority may, in specific cases, set less strict emission limit values. Such a derogation may apply only where an assessment shows that the achievement of emission levels associated with the best available techniques as described in BAT conclusions would lead to disproportionately higher costs compared to the environmental benefits due to:

*(a) the geographical location or the local environmental conditions of the installation concerned; or*

*(b) the technical characteristics of the installation concerned.*

As part of their Regulation 61 Note response, the operator has not requested a derogation from compliance with any AEL values.

## **7. Emissions to Water**

The consolidated permit incorporates the ten current discharges to controlled waters identified as W1 (discharge to a tributary of the Tetchwick Brook).

There are no BAT AELs specified in the BAT Conclusions for this type of plant. There are also no additional treatment options identified as BAT for the installation. We have therefore not carried out any additional assessment of the emissions to water as part of this review.



## **8 Additional IED Chapter II requirements:**

Improvement condition 7 required the Operator to review of the emission limit for carbon monoxide that applies between Start-up/Shut-down and baseload. The limit was previously set at 1250 mg/Nm<sup>3</sup>. The Operator confirmed that the latest periodic emission data showed that emission performance meets the requirements of the IED. They therefore proposed a limit of 110 mg/Nm<sup>3</sup> for MSUL/MSDL to base load. We agree with the Operator's proposed limit and have updated Table S3.1 in the permit to reflect this.

## 9 Review and assessment of changes that are not part of the BAT Conclusions derived permit review.

This document should be read in conjunction with the application, supporting information and notice.

Aspect considered	Decision
<b>Receipt of application</b>	
Confidential information	A claim for commercial or industrial confidentiality has not been made.
Identifying confidential information	We have not identified information provided as part of the application that we consider to be confidential.
<b>The site</b>	
Biodiversity, heritage, landscape and nature conservation	<p>The application is within the relevant distance criteria of a site of heritage, landscape or nature conservation, and/or protected species or habitat.</p> <p>A full assessment of the application and its potential to affect the site(s)/species/habitat has not been carried out as part of the permit review process. We consider that the review will not affect the features of the site(s)/species/habitat as the conditions will provide at least the same level of protection as those in the previous permit and in some cases will provide a higher level of protection to those in the previous permit.</p> <p>We have not consulted Natural England on the application. The decision was taken in accordance with our guidance.</p>
<b>Operating techniques</b>	
General operating techniques	<p>We have reviewed the techniques used by the operator where they are relevant to the BAT Conclusions and compared these with the relevant guidance notes.</p> <p>The permit conditions ensure compliance with the relevant BREF, BAT Conclusions. The ELVs deliver compliance with the BAT-AELs.</p>
<b>Permit conditions</b>	
Updating permit conditions during consolidation	We have updated permit conditions to those in the current generic permit template as part of permit consolidation. The conditions will provide at least the same level of protection as those in the previous permit and in some cases will provide a higher level of protection to those in the previous permit.
Changes to the permit conditions due to an	We have varied the permit as stated in the variation notice.

<b>Aspect considered</b>	<b>Decision</b>
Environment Agency initiated variation	
Use of conditions other than those from the template	We have retained condition 2.3.10 relating to the annual Network Review. This is a condition of the permits for all National Grid Gas compressor stations.
Improvement programme	We have also removed the completed improvement conditions from the permit.
Emission limits	<p>We have decided that emission limits should be set for the parameters listed in the permit.</p> <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p> <p>It is considered that the ELVs/equivalent parameters or technical measures described above will ensure that significant pollution of the environment is prevented and a high level of protection for the environment is secured.</p>
Monitoring	<p>We have decided that monitoring should be carried out for the parameters listed in the permit, using the methods detailed and to the frequencies specified.</p> <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p> <p>Table S3.3 Process monitoring requirements was amended to include the requirement to monitor energy efficiency after overhauls on site in line with BAT2.</p> <p>From 17 August 2021 the Operator is required to record hours of operation below 55% MCR.</p> <p>Based on the information in the application we are satisfied that the operator's techniques, personnel and equipment have either MCERTS certification or MCERTS accreditation as appropriate.</p>
Reporting	<p>We have specified reporting in the permit for the following parameters:</p> <ul style="list-style-type: none"> <li>• Nitrogen dioxide</li> <li>• Carbon monoxide</li> </ul> <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p>
<b>Operator competence</b>	
Management system	There is no known reason to consider that the operator will not have the management system to enable it to comply with the permit conditions.

Aspect considered	Decision
<b>Growth Duty</b>	
<p>Section 108 Deregulation Act 2015 – Growth duty</p>	<p>We have considered our duty to have regard to the desirability of promoting economic growth set out in section 108(1) of the Deregulation Act 2015 and the guidance issued under section 110 of that Act in deciding whether to grant this permit.</p> <p>Paragraph 1.3 of the guidance says:</p> <p>“The primary role of regulators, in delivering regulation, is to achieve the regulatory outcomes for which they are responsible. For a number of regulators, these regulatory outcomes include an explicit reference to development or growth. The growth duty establishes economic growth as a factor that all specified regulators should have regard to, alongside the delivery of the protections set out in the relevant legislation.”</p> <p>We have addressed the legislative requirements and environmental standards to be set for this operation in the body of the decision document above. The guidance is clear at paragraph 1.5 that the growth duty does not legitimise non-compliance and its purpose is not to achieve or pursue economic growth at the expense of necessary protections.</p> <p>We consider the requirements and standards we have set in this permit are reasonable and necessary to avoid a risk of an unacceptable level of pollution. This also promotes growth amongst legitimate operators because the standards applied to the operator are consistent across businesses in this sector and have been set to achieve the required legislative standards.</p>