



EU Type Examination Certificate Number: **0120/SGS0342**

Smart Metering Solutions (Changsha) Co., Ltd

No.468 West Tongzipo Road
High-Tech Industrial Development Zone
410205
Changsha City
Hunan Province
China

Instrument Identification:
IM150

Single Phase, Active Import/Export (kWh), Electricity Meter

Instrument Traceable Number
0120/SGS0342

has been assessed and certified as meeting the requirements of

EU Directive 2014/32/EU **on Measuring Instruments Annex II, Module B**

It is certified that the manufacturer's technical design and specimen for the above instrument has been examined and, based on the evidence submitted, it is considered that the instrument conforms to the requirements of Annex V of EU Directive 2014/32/EU

This certificate must be used in conjunction with a certificate covering the product verification as required in Annex II, Module D or Annex II, Module F


This certificate is valid until 21st March 2028
Issue 3

Certification is based on report number(s) SHES171201205401 dated 15th March 2018
SHES190902294501 dated 25th October 2019
EMA251157/1
EMA251191/1

Authorised Signature


SGS United Kingdom Limited, Notified Body 0120
Unit 202B Worle Parkway, Weston-super-Mare, BS22 6WA, UK
t +44 (0)1934 522917 f +44 (0)1934 522137 www.sgs.com

Contact Address
SGS United Kingdom Limited, Units 12A & 12B, South Industrial Estate, Bowburn, Durham, DH6 5AD, UK
t +44 (0)191 377 2000 f +44 (0)191 377 2020 www.sgs.com


	EU-Type Examination Certificate Number:	
	0120/SGS0342	
	Issue Number: 3	Dated: 14 th February 2020

1. Technical Data


Manufacturer	Smart Metering Solutions (Changsha) Co., Ltd
Meter Type	IM150
Voltage Rating (U_n)	110V-240V
Current Rating (I_{min} – I_{ref} (I_{max}))	0.25-5(40)A, 0.25-5(60)A
Frequency (F_n)	50 Hz
Active Accuracy Class (kWh)	A or B (kWh)
Type of circuit	1p2w
Temperature Range	-40°C to +70°C
Software/ Firmware Version No	WSE150EL04020010
CRC Checksum	04703557EC7184FC264E7D880ACC1 FEF30A21DE72A89BE15CAF94552A3 AEF30A2E88949EE5B652C633C814C 63058A687B38878608537BF34ADEA4 309E57D7456
Identification Location	LCD & Communication Interface
Bill Of Materials No's	aMeter150V1.1, aMeter150V1.1.1, aMeter150V1.1.2
IP Rating	IP54
Insulation Protective Class	Class II
LED Pulse Constant	1000imp/kWh
Impulse Voltage Rating	6kV
AC Voltage Rating	4kV
Main Cover Sealing Type	Wire & Crimp
Integrity of meter	Inaccessible without breaking seals
Intended Location of the Meter	Indoor
Type of Register	LCD
Terminal Arrangement(s)	DIN
Location of Manufacturers Address	Nameplate


	EU-Type Examination Certificate Number:	
	0120/SGS0342	
	Issue Number: 3	Dated: 14 th February 2020

- The structure of the software of the meter is divided into two parts according to Welmec 7.2 software separation.
- The meter provides the possibility to update firmware (legally and non legally relevant parts).
- The meter provides following energy registers and tariff registers includes:
 - Active energy (|+A|+|-A|) total and 4 tariff register
 - Active energy import (+A) total and 4 tariff register
 - Active energy export (-A) total and 4 tariff register
 - Reactive energy import (+R) total and 4 tariff register, Reactive energy export (-R) total and 4 tariff register
 - Reactive energy QI (+Ri) register, Reactive energy QII (+Rc) register, Reactive energy QIII (-Ri) register, Reactive energy QIV (-Rc) register.
- The meter provides one phase bi-stable break which can be optional.
- The meter provides Pulse outputs (A, R, 15min) which can be optional.
- The meter provides one relay outputs which can be optional.
- The meter provides following Communication interfaces: G3 PLC interface, Consumer interface, optical service interface, MBUS interface.
- The meter provides two push buttons.


	EU-Type Examination Certificate Number:	
	0120/SGS0342	
	Issue Number: 3	Dated: 14 th February 2020


2. Photograph of Meter and Sealing Plan



	EU-Type Examination Certificate Number:	
	0120/SGS0342	
	Issue Number: 3	Dated: 14 th February 2020

3. Example of Nameplate



	EU-Type Examination Certificate Number:	
	0120/SGS0342	
	Issue Number: 3	Dated: 14 th February 2020

4. Calculation of the composite error/ MPE

During the type approval examination the influence factors for temperature, frequency and voltage are determined per load point. The table below represents the sum of the square values per load, determined via the following formula:-


$$\delta e(T, U, f) = \sqrt{(\delta e^2(T, I, \cos\phi) + \delta e^2(U, I, \cos\phi) + \delta e^2(f, I, \cos\phi))}$$

where

$\delta e(T, I, \cos\phi)$	=	Additional error due to variation of the temperature at the same load
$\delta e(U, I, \cos\phi)$	=	Additional error due to variation of the voltage at the same load
$\delta e(f, I, \cos\phi)$	=	Additional error due to variation of the frequency at the same load

		Influence Factors for temperature, frequency and voltage							
Current	PF Cos	-40°C	-25°C	-10°C	5°C	30°C	40°C	55°C	70°C
I _{min}	1.0	0.54	0.44	0.34	0.22	0.14	0.20	0.32	0.50
I _{tr}	1.0	0.48	0.38	0.29	0.16	0.10	0.19	0.32	0.49
10I _{tr}	1.0	0.46	0.36	0.26	0.13	0.08	0.19	0.33	0.48
I _{max}	1.0	0.30	0.24	0.18	0.09	0.08	0.17	0.29	0.43
I _{tr}	0.5ind	0.45	0.37	0.28	0.17	0.11	0.20	0.33	0.51
10I _{tr}	0.5ind	0.41	0.31	0.23	0.12	0.09	0.20	0.35	0.52
I _{max}	0.5ind	0.26	0.21	0.16	0.09	0.07	0.17	0.30	0.45
I _{tr}	0.8cap	0.52	0.41	0.31	0.20	0.13	0.20	0.34	0.47
10I _{tr}	0.8cap	0.48	0.37	0.26	0.14	0.09	0.19	0.34	0.48
I _{max}	0.8cap	0.33	0.27	0.20	0.11	0.07	0.16	0.29	0.41

All the test values of I_{max} can be taken in case of I_{max} smaller than or equal to certified and the I_{max} at least 5 times higher than the reference current.


	EU-Type Examination Certificate Number:	
	0120/SGS0342	
	Issue Number: 3	Dated: 14 th February 2020

5. Annex of Variants

Product Variant Identification Details:

Type Designation	Description of meter
IM150	110-240V, 0.25-5(60)A, 50Hz.
	Round terminals (BOM: aMeter150V1.1) or
	Square terminals (BOM: aMeter150V1.1.1)
	110-240V, 0.25-5(40)A, 50Hz.
	Round terminals (BOM: aMeter150V1.1) or
	Square terminals (BOM: aMeter150V1.1.1)

Modifications to the meter(s) described according to approval No.**0120/SGS0342** must be notified to the issuing body to confirm the meter(s) continuing compliance to the relevant pattern approval standard(s).

	EU-Type Examination Certificate Number:	
	0120/SGS0342	
	Issue Number: 3	Dated: 14 th February 2020

6. Document Revision History

Issue	Date	Comments
1	27/04/2018	Initial Issue
2	18/05/2018	New variant with square terminals (BOM: aMeter150V1.1.1) added to approval
3	14/02/2020	Non metrology component change. New BOM aMeter150V1.1.2.

This document is issued by the Company subject to its General Conditions for Certification Services, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx>.

Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Unless otherwise stated the results shown in this test report refer only to the sample(s) tested *and such sample(s) are retained for 28 days only*.

END OF CERTIFICATE