

EU Type Examination Certificate Number: 0120/SGS0431

Gacia Electrical Appliance Co., LTD.

No.1 Nanxijiang Road Daqiao Industrial Zone Yueqing, Wenzhou China

Instrument Identification: N8DM-34MCT Series

Polyphase, Active Import/ Export kWh, Indoor, Multi-Function, Transformer Operated, Electricity Meter

Instrument Traceable Number 0120/SGS0431

has been assessed and certified as meeting the requirements of

EU Directive 2014/32/EU

on Measuring Instruments Annex II, Module B

It is certified that the manufacturer's technical design and specimen for the above instrument has been examined and, based on the evidence submitted, it is considered that the instrument conforms to the requirements of Annex V of EU Directive 2014/32/EU

This certificate must be used in conjunction with a certificate covering the product verification as required in Annex II, Module D or Annex II, Module F

This certificate is valid until 9th March 2024 Issue 1

Certification is based on report number(s) EMA174647/1/MID dated 30th January 2014 EMA174647/1/MID/iss 2 dated 9th October 2019 EMA275962

Authorised Signature



SGS United Kingdom Limited, Notified Body 0120 Unit 202B Worle Parkway, Weston-super-Mare, BS22 6WA, UK t +44 (0)1934 522917 f +44 (0)1934 522137 www.sgs.com

Contact Address

SGS United Kingdom Limited, Units 12A & 12B, South Industrial Estate, Bowburn, Durham, DH6 5AD, UK t +44 (0)191 377 2000 f +44 (0)191 377 2020 www.sgs.com



EU-Type Examination Certificate Number:


0120/SGS0431

Issue Number: 1


Dated: 9th April 2020

1. Technical Data

Manufacturer	Gacia Electrical Appliance Co., LTD
Meter Type	N8DM-34MCT, N8DM-34MCT-Mbus, N8DM- 34MCT-MT, N8DM-34MCT-2T
Voltage Rating (Un)	3x230/400V
Current Rating (Imin – Iref (Imax))	0.25-5(6)A
Frequency (Fn)	50Hz
Active Accuracy Class (kWh)	B or C (kWh)
Type of circuit	3p4w, 3p3w, 1p2w
Temperature Range	-25°C to +55°C
Software/ Firmware Version No CRC Checksum Identification Location	N8DM-34MCT: V1.3 N8DM-34MCT-2T: V1.4 N8DM-34MCT-Mbus: V1.5 N8DM-34MCT-MT: V1.7 N8DM-34MCT: 0x0000D5C8 N8DM-34MCT-2T: 0x0000D279
Bill Of Materials Number	N8DM-34MCT-Mbus: 0x00001516 N8DM-34MCT-MT: 0x00597DE9 LCD N8DM-34MCT: DH-JS-150046-1.4
	N8DM-34MCT-Mbus: DH-JS-160008-1.4 N8DM-34MCT-2T: DH-JS-160004-1.4 N8DM-34MCT-MT: DH-JS-190004-V1.1
IP Rating	IP51
Insulation Protective Class	Class II
LED Pulse Constant	3200imp/ kWh
Impulse Voltage Rating	6kV
AC Voltage Rating	4kV
Main Cover Sealing Type	2 x Wire & Crimp
Integrity of meter	Inaccessible without breaking seals
Intended Location of the Meter	Indoor
Type of Register	LCD
Terminal Arrangement(s)	DIN
Location of Manufacturers Address	Side of meter



2. Photograph of Meter and Sealing Plan






EU-Type Examination Certificate Number:

0120/SGS0431

Issue Number: 1

Dated: 9th April 2020

3. Examples of Nameplates





0120/SGS0431

Issue Number: 1

Dated: 9th April 2020

4. Calculation of the composite error/ MPE

During the type approval examination the influence factors for temperature, frequency and voltage are determined per load point. The table below represents the sum of the square values per load, determined via the following formula:-

δ e (*T*, *U*, *f*) = $\sqrt{(\delta e^2(T, I, \cos \varphi), \delta e^2(U, I, \cos \varphi), \delta e^2(f, I, \cos \varphi))}$

where

$\delta \mathbf{e}(T, I, \cos \varphi)$	=	Additional error due to variation of the temperature at the same load
$\delta \mathbf{e}(U, I, \cos \varphi)$	=	Additional error due to variation of the voltage at the same load
$\delta \mathbf{e}(f, I, \cos \phi)$	=	Additional error due to variation of the frequency at the same load



EU-Type Examination Certificate Number:

0120/SGS0431

Issue Number: 1

Dated: 9th April 2020

		Influenc	e Factors	for Tempe	rature. Fre	equency &	Voltage
Current	PF Cos	-25°C	-10°C	5°C	30°C	40°C	55°C
Imin	1.0	0.85	0.50	0.07	0.12	0.13	0.15
ltr	1.0	0.91	0.54	0.25	0.10	0.14	0.16
10Itr	1.0	0.85	0.50	0.23	0.03	0.09	0.12
Imax	1.0	0.86	0.51	0.24	0.05	0.08	0.12
Itr	0.5ind	1.08	0.70	0.37	0.16	0.16	0.17
10ltr	0.5ind	0.79	0.43	0.17	0.09	0.13	0.18
Imax	0.5ind	0.79	0.43	0.18	0.10	0.15	0.17
Itr	0.8cap	0.85	0.48	0.21	0.06	0.10	0.15
10ltr	0.8cap	0.87	0.51	0.24	0.02	0.06	0.11
Imax	0.8cap	0.89	0.51	0.26	0.03	0.06	0.10
L1							
ltr	1.0	0.92	0.38	0.20	0.11	0.13	0.13
10ltr	1.0	0.85	0.48	0.22	0.05	0.12	0.17
Imax	1.0	0.87	0.50	0.24	0.05	0.10	0.16
Itr	0.5ind	0.90	0.48	0.17	0.31	0.21	0.13
10ltr	0.5ind	0.88	0.50	0.22	0.05	0.15	0.16
Imax	0.5ind	0.88	0.50	0.24	0.05	0.10	0.14
L2							
Itr	1.0	0.86	0.51	0.23	0.04	0.09	0.13
10ltr	1.0	0.82	0.47	0.21	0.04	0.08	0.12
Imax	1.0	0.83	0.48	0.22	0.04	0.08	0.11
Itr	0.5ind	1.03	0.61	0.26	0.14	0.22	0.23
10Itr	0.5ind	0.69	0.35	0.10	0.15	0.21	0.24
Imax	0.5ind	0.67	0.32	0.06	0.18	0.24	0.28
L3							
Itr	1.0	0.87	0.50	0.24	0.05	0.10	0.12
10ltr	1.0	0.85	0.48	0.22	0.04	0.09	0.11
Imax	1.0	0.84	0.48	0.22	0.05	0.09	0.12
ltr	0.5ind	0.97	0.56	0.27	0.09	0.13	0.13
10ltr	0.5ind	0.83	0.47	0.21	0.06	0.08	0.11
Imax	0.5ind	0.83	0.47	0.21	0.04	0.09	0.11



0120/SGS0431

Issue Number: 1

Dated: 9th April 2020

5. Annex of Variants

Product Variant Identification Details:

Type Designation	Description of meter
N8DM-34MCT	0.25-5(6)A – Polyphase, Active Import/Export kWh, Multifunction, Transformer Operated (Terminal 7 and 8 used as power output for next meter in daisy connection)
N8DM-34MCT-2T	0.25-5(6)A – Polyphase, Active Import/Export kWh, Multifunction, Transformer Operated (Terminal 7 and 8 is used as signal input for two tariff shifting)
N8DM-34MCT-Mbus	0.25-5(6)A – Polyphase, Active Import/Export kWh, Multifunction, Transformer Operated, Mbus communication
N8DM-34MCT-MT	0.25-5(6)A – Polyphase, Active Import/Export kWh, Multifunction, Multi-tariff, Transformer Operated, Modbus communication

Modifications to the meter(s) described according to approval No.**0120/SGS0431** must be notified to the issuing body to confirm the meter(s) continuing compliance to the relevant pattern approval standard(s).



0120/SGS0431

Issue Number: 1

Dated: 9th April 2020

6. Document Revision History

Issue	Date	Comments
1	09/04/2020	Initial Issue

This document is issued by the Company subject to its General Conditions for Certification Services, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions.aspx.

Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 28 days only.

END OF CERTIFICATE