

EU Type Examination Certificate Number: 0120/SGS0451

Hosaf Meter Industry Ltd.

9, Mohakhali C/A,High Tower (2nd floor) Bir Uttam A. K. Khandakar Sorok Dhaka-1212 Bangladesh

Instrument Identification:

HI-7

Single Phase, Active Import/Export (kWh), Smart, Prepay & Postpay, Electricity Meter

Instrument Traceable Number 0120/SGS0451

has been assessed and certified as meeting the requirements of

EU Directive 2014/32/EU

on Measuring Instruments Annex II, Module B

It is certified that the manufacturer's technical design and specimen for the above instrument has been examined and, based on the evidence submitted, it is considered that the instrument conforms to the requirements of Annex V of EU Directive 2014/32/EU

This certificate must be used in conjunction with a certificate covering the product verification as required in Annex II, Module D or Annex II, Module F

This certificate is valid until 8th February 2028 Issue 1

Certification is based on report number(s) SHES180100033301 dated 9th February 2018 SHES180400358401 dated 19th April 2018 SHES180500430601 dated 19th September 2018 SHES190802158501 dated 6th December 2019 EMA249904/1 EMA275854

Authorised Signature

#C

SGS United Kingdom Limited, Notified Body 0120 Unit 202B Worle Parkway, Weston-super-Mare, BS22 6WA, UK t +44 (0)1934 522917 f +44 (0)1934 522137 www.sqs.com

Contact Address

SGS United Kingdom Limited, Units 12A & 12B, South Industrial Estate, Bowburn, Durham, DH6 5AD, UK t +44 (0)191 377 2000 f +44 (0)191 377 2020 www.sgs.com

DU_CST-ME-002 Rev 2 EU Type Examination Cert.



0120/SGS0451

Issue Number: 1 Dated: 25th February 2020

1. Technical Data

Manufacturer	Hosaf Meter Industry Ltd.
Meter Type	HI-7
Voltage Rating (Un)	220-240 V
Current Rating (Imin – Iref (Imax))	0.25-5(30)A, 0.25-5(40)A, 0.25-5(60)A, 0.25-5(80)A, 0.25-5(100A), 0.5-10(40)A, 0.5-10(60)A, 0.5-10(80)A, 0.5-10(100)A
Frequency (Fn)	50 Hz & 60Hz (IEC only)
Active Accuracy Class (kWh)	A or B (kWh)
Type of circuit	1p2w
Temperature Range	-40°C to +70°C
Software/ Firmware Version No	BD_H5023_V0001_20180123
CRC Checksum	0x89CC9FB9
Identification Location	LCD
Bill Of Materials Number	LY7.303.001078MX-V01.01 LY5.365.001136MX-V01.01 LY5.528.001637MX-V01.01 LY5.528.001635MX-V01.01 LY5.528.001636MX-V1
IP Rating	IP54
Insulation Protective Class	Class II
LED Pulse Constant	1000imp/kWh
Impulse Voltage Rating	6kV
AC Voltage Rating	4kV
Main Cover Sealing Type	Wire & Crimp
Integrity of meter	Inaccessible without breaking seals
Intended Location of the Meter	Indoor
Type of Register	LCD
Terminal Arrangement(s)	BS
Location of Manufacturers Address	Associated Documents



Terminal cover seal

EU-Type Examination Certificate Number:

0120/SGS0451

Issue Number: 1 Dated: 25th February 2020

2. Photograph of Meter and Sealing Plan




Main cover seals




0120/SGS0451

Issue Number: 1 Dated: 25th February 2020

3. Examples of Nameplates







0120/SGS0451

Issue Number: 1 Dated: 25th February 2020

4. Calculation of the composite error/ MPE

During the type approval examination the influence factors for temperature, frequency and voltage are determined per load point. The table below represents the sum of the square values per load, determined via the following formula:-

$$\delta e(T, U, f) = \sqrt{(\delta e^2(T, I, \cos\varphi), \delta e^2(U, I, \cos\varphi), \delta e^2(f, I, \cos\varphi))}$$

where

 $\delta e(T, I, \cos \varphi) = Additional error due to variation of the temperature at the same load <math>\delta e(J, I, \cos \varphi) = Additional error due to variation of the voltage at the same load <math>\delta e(f, I, \cos \varphi) = Additional error due to variation of the frequency at the same load$

		Influence Factors for temperature, frequency and voltage							
Current	PF Cos	-40° C	-25° C	-10° C	5° C	30° C	40° C	55° C	70° C
Imin	1.0	1.15	0.96	0.74	0.49	0.15	0.12	0.26	0.49
Itr	1.0	1.13	0.92	0.69	0.46	0.12	0.12	0.29	0.50
10ltr	1.0	1.24	0.95	0.73	0.51	0.16	0.10	0.24	0.44
Imax	1.0	1.20	0.89	0.61	0.31	0.16	0.34	0.60	0.72
Itr	0.5ind	1.09	0.86	0.62	0.36	0.06	0.16	0.37	0.60
10ltr	0.5ind	1.20	0.89	0.65	0.40	0.08	0.15	0.35	0.56
Imax	0.5ind	1.19	0.83	0.54	0.27	0.24	0.18	0.71	0.86
Itr	0.8cap	1.11	0.91	0.69	0.46	0.16	0.15	0.31	0.51
10ltr	0.8cap	1.20	0.92	0.72	0.49	0.16	0.12	0.27	0.47
lmax	0.8cap	1.38	1.04	0.75	0.49	0.17	0.21	0.42	0.66




0120/SGS0451

Issue Number: 1 Dated: 25th February 2020

5. Annex of Variants

Product Variant Identification Details:



e.g: W41A4, Whole Current, 220V/50Hz, 5(60)A, with keypad and smart card.

Modifications to the meter(s) described according to approval No.0120/SGS0451 must be notified to the issuing body to confirm the meter(s) continuing compliance to the relevant pattern approval standard(s).



0120/SGS0451

Issue Number: 1 Dated: 25th February 2020

6. Document Revision History

Issue	Date	Comments
1	25/02/2020	Initial Issue

This document is issued by the Company subject to its General Conditions for Certification Services, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions.aspx.

Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 28 days only.

END OF CERTIFICATE