

Environment Agency

Review of an Environmental Permit for an Installation subject to Chapter II of the Industrial Emissions Directive under the Environmental Permitting (England & Wales) Regulations 2016

Decision document recording our decision-making process following review of a permit

The Permit number is: EPR/EP3208PD

The Operator is: Veolia Energy & Utility Services UK Plc

The Installation is: Huddersfield Chemical Works (Syngenta CHP)

This Variation Notice number is: EPR/EP3208PD/V002

What this document is about

Article 21(3) of the Industrial Emissions Directive (IED) requires the Environment Agency to review conditions in permits that it has issued and to ensure that the permit delivers compliance with relevant standards, within four years of the publication of updated decisions on best available techniques (BAT) conclusions.

We have reviewed the permit for this installation against the revised BAT Conclusions for large combustion plant published on 17th August 2017. This is our decision document, which explains the reasoning for the consolidated variation notice that we are issuing.

It explains how we have reviewed and considered the techniques used by the Operator in the operation and control of the plant and activities of the installation. This review has been undertaken with reference to the decision made by the European Commission establishing best available techniques (BAT) conclusions ('BAT Conclusions') for large combustion plant as detailed in document reference IEDC-7-1. It is our record of our decision-making process and shows how we have taken into account all relevant factors in reaching our position. It also provides a justification for the inclusion of any specific conditions in the permit that are in addition to those included in our generic permit template.

As well as considering the review of the operating techniques used by the Operator for the operation of the plant and activities of the installation, the consolidated variation notice takes into account and brings together in a single document all previous variations that relate to the original permit issued. It also

modernises the entire permit to reflect the conditions contained in our current generic permit template.

The introduction of new template conditions makes the Permit consistent with our current general approach and philosophy and with other permits issued to installations in this sector. Although the wording of some conditions has changed, while others have been removed because of the new regulatory approach, it does not reduce the level of environmental protection achieved by the Permit in any way. In this document we therefore address only our determination of substantive issues relating to the new BAT Conclusions.

Throughout this document we will use a number of expressions. These are as referred to in the glossary and have the same meaning as described in “Schedule 6 Interpretation” of the Permit.

We try to explain our decision as accurately, comprehensively and plainly as possible. We would welcome any feedback as to how we might improve our decision documents in future. A lot of technical terms and acronyms are inevitable in a document of this nature: we provide a glossary of acronyms near the front of the document, for ease of reference.

How this document is structured

Glossary of terms

- 1 Our decision
- 2 How we reached our decision
- 2.1 Requesting information to demonstrate compliance with BAT Conclusions for Large Combustion Plant
- 2.2 Review of our own information in respect to the capability of the installation to meet revised standards included in the BAT Conclusions document
- 3 The legal framework
- 4 Key Issues
- 5 Decision checklist regarding relevant BAT Conclusions
- 6 Review and assessment of derogation requests made by the operator in relation to BAT Conclusions which include an associated emission level (AEL) value
- 7 Emissions to Water
- 8 Additional IED Chapter II requirements
- 9 Review and assessment of changes that are not part of the BAT Conclusions derived permit review.

Glossary of acronyms used in this document

(Please note that this glossary is standard for our decision documents and therefore not all these acronyms are necessarily used in this document.)

APC	Air Pollution Control
BAT	Best Available Technique(s)
BAT-AEEL	BAT Associated Energy Efficiency Level
BAT-AEL	BAT Associated Emission Level
BATc	BAT conclusion
BREF	Best available techniques reference document
CCGT	Combined Cycle Gas Turbine
CEM	Continuous emissions monitor
CHP	Combined heat and power
CV	Calorific value
DAA	Directly associated activity – Additional activities necessary to be carried out to allow the principal activity to be carried out
DLN	Dry Low NOx burners
DLN-E	Dry Low NOx effective
EIONET	European environment information and observation network is a partnership network of the European Environment Agency
ELV	Emission limit value derived under BAT or an emission limit value set out in IED
EMS	Environmental Management System
EPR	Environmental Permitting (England and Wales) Regulations 2016 (SI 2016 No. 1154)
EWC	European waste catalogue
FSA	Food Standards Agency
IC	Improvement Condition
IED	Industrial Emissions Directive (2010/75/EU)
IPPCD	Integrated Pollution Prevention and Control Directive (2008/1/EC) – now superseded by IED
LCP	Large Combustion Plant subject to Chapter III of IED
MSUL/MSDL	Minimum start up load/minimum shut-down load
NOx	Oxides of nitrogen (NO plus NO ₂ expressed as NO ₂)
NPV	Net Present Value
OCGT	Open Cycle Gas Turbine
PHE	Public Health England
SAC	Special Area of Conservation
SGN	Sector guidance note
TGN	Technical guidance note
TOC	Total Organic Carbon
WFD	Water Framework Directive (2000/60/EC)

1 Our decision

We have decided to issue the consolidated variation notice to the Operator. This will allow it to continue to operate the Installation, subject to the conditions in the consolidated variation notice.

We consider that, in reaching that decision, we have taken into account all relevant considerations and legal requirements and that the varied permit will ensure that a high level of protection is provided for the environment and human health.

The consolidated variation notice contains many conditions taken from our standard Environmental Permit template including the relevant Annexes. We developed these conditions in consultation with industry, having regard to the legal requirements of the Environmental Permitting Regulations and other relevant legislation. This document does not therefore include an explanation for these standard conditions. Where they are included in the Notice, we have considered the techniques identified by the operator for the operation of their installation, and have accepted that the details are sufficient and satisfactory to make those standard conditions appropriate. This document does, however, provide an explanation of our use of “tailor-made” or installation-specific conditions, or where our Permit template provides two or more options.

2 How we reached our decision

2.1 Requesting information to demonstrate compliance with BAT Conclusions for Large Combustion Plant

We issued a Notice under Regulation 61(1) of the Environmental Permitting (England and Wales) Regulations 2016 (a Regulation 61 Notice) on 1st May 2018 requiring the Operator to provide information to demonstrate how the operation of their installation currently meets, or will subsequently meet, the revised standards described in the large combustion plant BAT Conclusions document. The Notice also required that where the revised standards are not currently met, the operator should provide information that:

- Describes the techniques that will be implemented before 17th August 2021, which will then ensure that operations meet the revised standard, or
- Justifies why standards will not be met by 17th August 2021, and confirmation of the date when the operation of those processes will cease within the installation or an explanation of why the revised BAT standard is not applicable to those processes, or
- Justifies why an alternative technique will achieve the same level of environmental protection equivalent to the revised standard described in the BAT Conclusions.

Where the Operator proposed that they were not intending to meet a BAT standard that also included a BAT Associated Emission Level (BAT AEL) described in the BAT Conclusions Document, the Regulation 61 Notice requested that the Operator make a formal request for derogation from compliance with that AEL (as provisioned by Article 15(4) of IED). In this circumstance, the Notice identified that any such request for derogation must be supported and justified by sufficient technical and commercial information that would enable us to determine acceptability of the derogation request.

The Regulation 61 Notice response from the Operator was received on 24 October 2018.

We considered it was in the correct form and contained sufficient information for us to begin our determination of the permit review but not that it necessarily contained all the information we would need to complete that review.

Additional information was received from the Operator in response to the following BAT Conclusions: 1, 2, 3, 6, 9, 10,12, 14, 16, 40, 41, 42 and 44 on 8 July 2020.

2.2 Review of our own information in respect to the capability of the installation to meet revised standards included in the BAT Conclusions document

Based on our records and previous regulatory activities with the facility we have no reason to consider that the operator will not be able to comply with the conditions that we include in the permit.

3 The legal framework

The consolidated variation notice will be issued under Regulation 20 of the EPR. The Environmental Permitting regime is a legal vehicle which delivers most of the relevant legal requirements for activities falling within its scope. In particular, the regulated facility is:

- an *installation* as described by the IED;
- subject to aspects of other relevant legislation which also have to be addressed.

We consider that the consolidated variation notice will ensure that the operation of the Installation complies with all relevant legal requirements and that a high level of protection will be delivered for the environment and human health.

We explain how we have addressed specific statutory requirements more fully in the rest of this document.

4 The key issues

The key issues arising during this permit review are:

- Emissions to air and the emission limits applied to the plant.
- The energy efficiency levels associated with the Best Available Techniques (BAT-AEELs)
- BAT 9 characterisation of fuel

We therefore describe how we determined these issues in most detail in the relevant sections of this document.

4.1 Emissions to air and the emission limits applied to the plant

A number of general principles were applied during the permit review. These included:

- The upper value of the BAT AELs ranges specified were used unless use of the tighter limit was justified.
- The principle of no backsliding where if existing limits in the permit were already tighter than those specified in the BREF, the existing permit limits were retained.
- Where a limit was specified in both IED Annex V and the BAT Conclusions for a particular reference period, the tighter limit was applied and in the majority of cases this was from the BAT Conclusions.
- Where AELs are indicative in the BAT Conclusions, these were applied unless adequate justification was provided by the operator to demonstrate that an alternative limit was more appropriate.
- For gas turbines where the IED specified that limits applied over 70% load and the BAT Conclusions specified that AELs applied when dry low NO_x is effective (DLN-E), we have used DLN-E as a default across all monitoring requirements for NO_x and CO.

LCP61 has a total net rated thermal input of 92MW and includes the following appliances within the same 45 metre windshield:

- A CHP unit (gas turbine, at 23.4MWth and a waste heat recovery boiler (WHRB) at 40MWth) – discharging via flue A1 and, when the gas turbine is in by-pass mode, flue A4.
- An intermediate pressure steam boiler (PB1) at 28.6MWth – discharging via flue A2.

The plant was put into operation before IED came into force and therefore the existing limits in the permit are from Part 1 of IED Annex V applicable to existing plant.

The ELVs and AELs are based on the following operating regimes:

- LCP61 – Release point A1 (gas turbine with the WHRB not firing and gas turbine with WHRB in supplementary mode, fired on natural gas) - Unlimited hours operation
- LCP61 – Release point A1 (WHRB in auxiliary mode, fired on natural gas) - Unlimited hours operation
- LCP61 – Release point A1 (WHRB in auxiliary mode, fired on Hydrotreated Vegetable Oil (HVO)) - <500 hours
- LCP61 – Release point A2 (intermediate pressure steam boiler, fired on natural gas) - Unlimited hours operation
- LCP61 – Release point A2 (intermediate pressure steam boiler, fired on Hydrotreated Vegetable Oil (HVO)) - <500 hours
- LCP61 - Release point A4 Gas turbine by-pass (OCGT) <300 hours

The following tables outline the limits that have been incorporated into the permit for LCP61, where these were derived from and the reference periods at which they apply. The emission limits refer to concentrations, expressed as mass of emitted substance per volume of flue-gas under the following standard conditions: dry gas at a temperature of 273,15 K, pressure of 101,3 kPa and

- 15% volume reference oxygen concentration in flue gases for gas turbines; and
- 3% volume reference oxygen concentration in flue gases for the boilers.

In supplementary mode the gas turbine and Waste Heat Recovery Boiler (WHRB) are operating together. In this mode of operation the LCP has more than one cycle, we therefore consider it to be a CCGT. The Gas Turbine can also operate independently in by-pass mode, this mode of operation is an OCGT.

The Operator also confirmed that they run the gas turbine with its exhaust gases going through the WHRB, so that heat can be recovered, but without the WHRB burners firing. This mode of operation also discharges through stack A1. Although the gas turbine on its own is <50MW, operating it in this way does not change the defined LCP. We therefore consider that the monitoring requirements and limits applicable to this mode of operation are the same as the gas turbine and WHRB in supplementary mode.

The Operator confirmed that Dry Low NO_x is effective from 70% load (4.41MWe). However, previously the permit defined MSUL/MSDL for the gas turbine as being 100% load. We have therefore changed the definition of MSUL/MSDL to match DLN-E. Table S1.4 of the permit has been updated. The Operator confirmed that above 70% the NO_x profile is relatively flat and that therefore the emission limits are achievable from 70% load.

The emission limits and monitoring requirements have been incorporated into Schedule 3 of the permit.

LCP61 – Release point A1 CCGT (Gas turbine with the WHRB not firing and gas turbine with WHRB in supplementary mode), fired on natural gas

NOx limits (mg/Nm ³)						
Averaging	IED (Annex V Part 1) – Existing	BREF (Table 24 BAT-c)	Permit limits from 17 August 2021	Basis	Limits apply	Monitoring
Annual	-	55 ^{Note 2}	55	Bref	DLN-E	Continuous ^{Note 1}
Monthly	75 ^{Note 2}	-	75	IED	DLN-E	
Daily	82.5	80 ^{Note 2}	80	Bref	DLN-E	
95 th %ile of hr means	150 ^{Note 2}	-	150	IED	DLN-E	
<p>Note 1: Previously the permit only set daily limits for this emission point with periodic monitoring. In line with the requirements of the LCP BAT conclusions we have specified continuous monitoring from 17 August 2021. Yearly, monthly, daily and hourly reference periods will also apply.</p> <p>Note 2: Limits based on overall plant efficiency, based on ‘net total fuel utilisation’, being greater than 75%</p>						

During the review we have applied the principle of no backsliding, so that if existing limits in the permit were already tighter than those specified in the BREF the existing permit limits were retained. However, our understanding of the plant in this configuration (Gas turbine with WHRB in supplementary mode) has changed, we therefore have the option to set a different limit. During determination the Operator submitted additional justification demonstrating that the overall plant efficiency, based on ‘net total fuel utilisation’, is greater than 75%. We are satisfied with their justification and have set NOx limits based on >75% efficiency. In line with the requirements of the LCP BAT conclusions we have also specified continuous monitoring from 17 August 2021. Previous limits were based on lower efficiency (<75%) and a periodic monitoring frequency, we therefore consider it is not appropriate to retain the previous daily NOx limit in this case.

CO limits (mg/Nm ³)							
Averaging	Permit limit/non IED – Existing	IED (Annex V Part 1) – Existing	BREF (Table 24 BAT-c)	Permit limits from 17 August 2021	Basis	Limits apply	Monitoring
Annual	-	-	30	TBC	Improvement condition	DLN-E	Continuous ^{Note 1}
Monthly	-	100	-	100	IED	DLN-E	
Daily	100	110	-	110	Permit	DLN-E	
95 th %ile of hr means	-	200	-	200	IED	DLN-E	

Note 1: Previously the permit only set daily limits for this emission point with periodic monitoring. In line with the requirements of the LCP BAT conclusions we have specified continuous monitoring from 17 August 2021. Yearly, monthly, daily and hourly reference periods will also apply.

We have included an improvement condition (IC15) specifying that the Operator is required to propose an achievable emission limit for carbon monoxide expressed as an annual mean of validated hourly averages. If the proposed ELV deviates from the indicative BAT AEL for CO of 30mg/m³ then an associated BAT justification shall also be submitted.

During the review we have applied the principle of no backsliding, so that if existing limits in the permit were already tighter than those specified in the BREF the existing permit limits were retained. However, where the operating mode has changed we have the option to set a different limit. Due to a decrease in demand, the site is currently operating at low load. We have therefore agreed to set 110mg/m³ as an interim daily ELV (110mg/m³ is the limit specified in the IED for this type of plant). We have included an improvement condition (IC16) requiring the Operator to review CO emissions and determine whether the higher limit of 110mg/m³ should be retained. The Operator is required to review this ELV and propose an achievable emission limit for carbon monoxide expressed as a daily mean of validated hourly averages. If the proposed ELV deviates from the previous ELV for CO of 100mg/m³ then a BAT justification shall also be submitted. Including a review of possible causes of the elevated CO emissions and an assessment of opportunities for mediation works to reduce emissions.

LCP61 – Release point A1 - Boiler (WHRB in auxiliary mode) fired on natural gas

Where periodic monitoring is specified we have only set the daily limits. This is our BAT position.

Parameter	Permit limit/non IED – Existing	IED (Annex V Part 1) – Existing	BREF (Table 25 BAT-c)	Permit limits from 17 August 2021	Basis	Limits apply	Monitoring
NO _x	-	110	110	110	Bref/IED	MSUL/MSDL to baseload	Periodic
CO	100	110	-	100	Existing permit – no backsliding		
SO ₂	-	38.5	-	38.5	IED		
Dust	-	5.5	-	5.5	IED		

LCP61 – Release point A2- Boiler (PB1) fired on natural gas

Where periodic monitoring is specified we have only set the daily limits. This is our BAT position.

Parameter	Permit limit/non IED – Existing	IED (Annex V Part 1) – Existing	BREF (Table 25 BAT-c)	Permit limits from 17 August 2021	Basis	Limits apply	Monitoring
NO _x	-	200	110	110	Bref	MSUL/MSDL to baseload	Periodic
CO	100	110	-	100	Existing permit – no backsliding		
SO ₂	-	38.5	-	38.5	IED		
Dust	-	5.5	-	5.5	IED		

LCP61 – Release point A1 - Boiler (WHRB in auxiliary mode) fired on Hydrotreated Vegetable Oil (HVO) and Release point A2- Boiler (PB1) fired on HVO

Natural gas is the primary fuel for LCP61. The boilers are permitted to use HVO as a standby fuel a limited period (500hours/year), we have not set BAT-AELs applicable to that fuel as the use is not considered significant.

We also reviewed the monitoring requirements included in the existing permit. The permit specified the requirement for periodic monitoring and concentration by calculation for the boilers in LCP61 when running on HVO as a standby fuel. We consider that in line with the Joint Emissions Protocol document ‘*BAT for existing Gas and Liquid fuel fired OCGTs, CCGTs, and Dual Fuel GTs with a Thermal Input Rating of 50MWth or more operating <500 Hours Per Year*’, we will not require <500 hour plant to run solely for the purpose of monitoring. We have taken the fact that HVO will only be used for standby fuel and for <500 hours per year to indicate that it is equivalent in risk to emergency plant running on HVO for <500 hour per year. We have therefore removed the periodic monitoring requirement and associated ELVs from Table S3.1a. In some instances we have specified the monitoring requirements after the implementation date for the LCP BAT Conclusions in 2021 to be determined through ‘concentration by calculation’, however, this is usually where the plant itself doesn’t run over >500 hours and we want to ensure that the plant is maintained with the emission limit in mind. For this particular plant the overall turbine runs more frequently and will be monitored and reported against existing limits for operation on natural gas which will ensure that it is maintained. We have therefore not included ELVs to be measured through concentration by calculation for operation on standby fuel for <500 hours.

Where a natural gas fired plant uses HVO as a standby fuel for less than 500 hours per year, we have not assessed the site against the BAT Conclusions applicable to that fuel as the use is not considered significant. We expect the site

to have demonstrated that the site will be operated in a manner such that use of the standby fuel is minimised.

LCP61 - Release point A4 Gas turbine by-pass (OCGT mode)

In circumstances where a CCGT is in frequent use but also has the capability to operate in OCGT mode for less than 500 hours per year we do not set limits for the OCGT mode specifically because we consider that the gas turbine maintenance carried out for the CCGT operation will be adequate. In this case operation of the gas turbine in by-pass mode is limited to less than 300 hours per year by condition 2.3.6 of the Environmental Permit.

4.2 The energy efficiency levels associated with the Best Available Techniques Conclusions

An energy efficiency level associated with the best available techniques (BAT-AEEL) refers to the ratio between the combustion unit's net energy output(s) and the combustion unit's fuel/feedstock energy input at actual unit design. The net energy output(s) is determined at the combustion unit boundaries, including auxiliary systems (e.g. flue-gas treatment systems), and for the unit operated at full load.

The configuration of the LCP does not correspond with Table 23 of the LCP BAT Conclusions. We are satisfied that the BAT-AEELs are not applicable. However, we considered that the Operator should confirm the total net fuel utilisation for the LCP running at full load (gas turbine and both boilers). During determination the Operator submitted additional justification demonstrating that the overall plant efficiency, based on 'net total fuel utilisation', is greater than 75%. We are satisfied with their justification and have set NO_x limits based on >75% efficiency.

Table 23 of the LCP BAT Conclusions specifies that the BAT-AEELs are not applicable to plant operating less than 1500 hours per year. We have therefore not assessed this operational aspect of either the gas turbine operating <300 hours in open cycle mode or the boilers operating for <500 hours on Hydrotreated Vegetable Oil (HVO).

We have included a process monitoring requirement in table S3.4 of the consolidated variation notice for all plant. This is required to demonstrate that efficiency levels are maintained following any significant overhauls of equipment in order to fulfil the requirement of BAT Conclusion 2.

4.4 Fuel characterisation

During determination, the Operator confirmed that the site will no longer be using gas oil. They confirmed that the gas oil tank has now been emptied and cleaned and restocked with new Hydrotreated Vegetable Oil (HVO).

BAT 9 requires the Operator to carry out fuel characterisation. We have therefore included an improvement condition in the consolidated variation notice (IC14) requiring the Operator to submit a plan outlining how this will be carried out for approval prior to the implementation date for the BAT Conclusions.

5 Decision checklist regarding relevant BAT Conclusions

BAT Conclusions for large combustion plant, were published by the European Commission on 17th August 2017. There are 75 BAT Conclusions. Only the BAT Conclusions relevant to the particular fuel type used on site have been replicated below.

This annex provides a record of decisions made in relation to each relevant BAT Conclusion applicable to the installation. This annex should be read in conjunction with the Consolidated Variation Notice.

The conditions in the permit through which the relevant BAT Conclusions are implemented include but are not limited to the following:

BAT Conclusion requirement topic	Permit condition(s)	Permit table(s)
Environmental Management System	1.1.1	S1.2
BAT AELs	3.1.1 and 3.5.1	S3.1a
Monitoring	2.3, 3.5 and 3.6	S1.2, S1.4, S1.5, S3.1a
Energy efficiency	1.2 and 2.3	S3.4
Noise	3.4 and 2.3	S1.2
Other operating techniques	2.3	S1.2

The overall status of compliance with the BAT conclusion is indicated in the table as:

- NA Not Applicable
- CC Currently Compliant
- FC Compliant in the future (within 4 years of publication of BAT conclusions)
- NC Not Compliant
- PC Partially Compliant

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
General			
1	<p>In order to improve the overall environmental performance, BAT is to implement and adhere to an environmental management system (EMS) that incorporates all of the following features:</p> <ul style="list-style-type: none"> i. commitment of the management, including senior management; ii. definition of an environmental policy that includes the continuous improvement of the installation by the management; iii. planning and establishing the necessary procedures, objectives and targets, in conjunction with financial planning and investment; iv. implementation of procedures <ul style="list-style-type: none"> (a) Structure and responsibility (b) Training (c) Communication (d) Employee involvement (e) Documentation (f) Efficient process control (g) Maintenance programmes (h) Emergency preparedness and response (i) Safeguarding compliance with environmental legislation v. checking performance and taking corrective action, paying particular attention to: <ul style="list-style-type: none"> (a) monitoring and measurement (see also the Reference Document on the General Principles of Monitoring) (b) corrective and preventive action (c) maintenance of records (d) independent (where practicable) internal and external auditing in order to determine whether or not the EMS conforms to planned arrangements and has been properly implemented and maintained; vi. review of the EMS and its continuing suitability, adequacy and effectiveness by senior management; vii. following the development of cleaner technologies; viii. consideration for the environmental impacts from the eventual decommissioning of the installation at the stage of designing a new plant, and throughout its operating life; viii. consideration for the environmental impacts from the eventual decommissioning of the installation at the stage of designing a new plant, and throughout its operating life; ix. application of sectoral benchmarking on a regular basis. <p>Etc - see BAT Conclusions</p>	FC	<p>Veolia is a quality assured company with its sites registered under the Quality Management System ISO 9001, OHSAS 18001 and ISO 14001. Veolia have confirmed that the management system meets all of the applicable requirements of BAT Conclusion 1.</p> <p>There was a change in ownership in 2019 when the permit was transferred to Veolia Energy & Utility Services UK Plc. The site is currently in the process of implementing the business management system and will be internally and externally audited once this process is completed. We therefore consider the site to be 'Future Compliant' with BAT Conclusion 1.</p> <p>We do not consider it necessary to set an improvement condition as we will track progress via compliance. It is expected that the management system will be implemented by 17 August 2021 and that the site will be compliant with BAT Conclusion 1.</p>

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement													
	<p>Applicability. The scope (e.g. level of detail) and nature of the EMS (e.g. standardised or non-standardised) will generally be related to the nature, scale and complexity of the installation, and the range of environmental impacts it may have.</p>															
2	<p>BAT is to determine the net electrical efficiency and/or the net total fuel utilisation and/or the net mechanical energy efficiency of the gasification, IGCC and/or combustion units by carrying out a performance test at full load (1), according to EN standards, after the commissioning of the unit and after each modification that could significantly affect the net electrical efficiency and/or the net total fuel utilisation and/or the net mechanical energy efficiency of the unit. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.</p>	CC	<p>A full load performance test was carried out in November 2017 by Siemens on behalf of ENGIE (previous Operator) following the upgrade of the gas turbine. The Operator provided a copy of this report (Site Performance Test 10th November, 2017 Basic Summary of Engine Performance, dated 24 November 2017).</p> <p>There is a monitored on site SCADA system. This produces a daily download in spreadsheet format, which is reviewed monthly.</p> <p>A process monitoring requirement has been set in table S3.4 which requires energy efficiency monitoring (net total fuel utilisation) after an overhaul.</p>													
3	<p>BAT is to monitor key process parameters relevant for emissions to air and water including those given below.</p> <table border="1" data-bbox="322 1193 1491 1369"> <thead> <tr> <th data-bbox="322 1193 689 1230">Stream</th> <th data-bbox="689 1193 1124 1230">Parameter(s)</th> <th data-bbox="1124 1193 1491 1230">Monitoring</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 1230 689 1337" rowspan="3">Flue-gas</td> <td data-bbox="689 1230 1124 1267">Flow</td> <td data-bbox="1124 1230 1491 1267">Periodic or continuous determination</td> </tr> <tr> <td data-bbox="689 1267 1124 1303">Oxygen content, temperature, and pressure</td> <td data-bbox="1124 1267 1491 1303">Periodic or continuous measurement</td> </tr> <tr> <td data-bbox="689 1303 1124 1337">Water vapour content (%)</td> <td data-bbox="1124 1303 1491 1337"></td> </tr> <tr> <td data-bbox="322 1337 689 1369">Waste water from flue-gas treatment</td> <td data-bbox="689 1337 1124 1369">Flow, pH, and temperature</td> <td data-bbox="1124 1337 1491 1369">Continuous measurement</td> </tr> </tbody> </table>	Stream	Parameter(s)	Monitoring	Flue-gas	Flow	Periodic or continuous determination	Oxygen content, temperature, and pressure	Periodic or continuous measurement	Water vapour content (%)		Waste water from flue-gas treatment	Flow, pH, and temperature	Continuous measurement	FC	<p>All parameters are monitored through the SCADA system, with a daily download in spreadsheet format giving 1/2 hourly data and totalised data over a 24hour period.</p> <p>The Operator has confirmed that the existing CEMS covers the Gas</p>
Stream	Parameter(s)	Monitoring														
Flue-gas	Flow	Periodic or continuous determination														
	Oxygen content, temperature, and pressure	Periodic or continuous measurement														
	Water vapour content (%)															
Waste water from flue-gas treatment	Flow, pH, and temperature	Continuous measurement														

BAT Concn. Numbe r	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
			<p>Turbine and Waste Heat Recovery Boiler (WHRB). The CEMS is a CODEL G-CEM4100 extractive flue gas analyser which is a MCERTS certified product.</p> <p>CEMS is currently used for process monitoring only, not compliance purposes. CO and NOx emissions as well as key process parameters including O2 content, temperature, pressure and water vapour content are monitored by the CEMS.</p> <p>The previous permit specified periodic monitoring. However, in line with the requirement of the BAT Conclusions, we consider that CEMS should be used for compliance when the LCP is running as a CCGT (Gas turbine with WHRB in supplementary mode). We have therefore specified continuous monitoring in Table S3.1a of the consolidated permit for this mode of operation.</p> <p>The Operator also confirmed that they run the Gas Turbine with its exhaust gases going through the WHRB, so that heat can be recovered, but without the WHRB burners firing. We consider that the monitoring requirements and limits applicable to this mode of</p>

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																														
			operation are the same as the Gas Turbine and WHRB in supplementary mode.																														
4	<p>BAT is to monitor emissions to air with at least the frequency given below and in accordance with EN standards. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.</p> <table border="1" data-bbox="320 595 1494 1383"> <thead> <tr> <th data-bbox="320 595 477 715">Substance/Parameter</th> <th data-bbox="477 595 790 715">Fuel/Process/Type of combustion plant</th> <th data-bbox="790 595 947 715">Combustion plant total rated thermal input</th> <th data-bbox="947 595 1126 715">Standard(s)⁽⁴⁾</th> <th data-bbox="1126 595 1350 715">Minimum monitoring frequency⁽⁵⁾</th> <th data-bbox="1350 595 1494 715">Monitoring associated with</th> </tr> </thead> <tbody> <tr> <td data-bbox="320 715 477 778">NH₃</td> <td data-bbox="477 715 790 778">— When SCR and/or SNCR is used</td> <td data-bbox="790 715 947 778">All sizes</td> <td data-bbox="947 715 1126 778">Generic EN standards</td> <td data-bbox="1126 715 1350 778">Continuous⁽⁶⁾⁽⁷⁾</td> <td data-bbox="1350 715 1494 778">BAT 7</td> </tr> <tr> <td data-bbox="320 778 477 1297">NO_x</td> <td data-bbox="477 778 790 1297"> <ul style="list-style-type: none"> — Coal and/or lignite including waste co-incineration — Solid biomass and/or peat including waste co-incineration — HFO- and/or gas-oil-fired boilers and engines — Gas-oil-fired gas turbines — Natural-gas-fired boilers, engines, and turbines — Iron and steel process gases — Process fuels from the chemical industry — IGCC plants </td> <td data-bbox="790 778 947 1297">All sizes</td> <td data-bbox="947 778 1126 1297">Generic EN standards</td> <td data-bbox="1126 778 1350 1297">Continuous⁽⁶⁾⁽⁸⁾</td> <td data-bbox="1350 778 1494 1297">BAT 20 BAT 24 BAT 28 BAT 32 BAT 37 BAT 41 BAT 42 BAT 43 BAT 47 BAT 48 BAT 56 BAT 64 BAT 65 BAT 73</td> </tr> <tr> <td data-bbox="320 1297 477 1383"></td> <td data-bbox="477 1297 790 1383">— Combustion plants on offshore platforms</td> <td data-bbox="790 1297 947 1383">All sizes</td> <td data-bbox="947 1297 1126 1383">EN 14792</td> <td data-bbox="1126 1297 1350 1383">Once every year⁽⁹⁾</td> <td data-bbox="1350 1297 1494 1383">BAT 53</td> </tr> <tr> <td data-bbox="320 1383 477 1390">N₂O</td> <td data-bbox="477 1383 790 1390">— Coal and/or lignite in circulating fluidised bed boilers</td> <td data-bbox="790 1383 947 1390">All sizes</td> <td data-bbox="947 1383 1126 1390">EN 21258</td> <td data-bbox="1126 1383 1350 1390">Once every year⁽¹⁰⁾</td> <td data-bbox="1350 1383 1494 1390">BAT 20 BAT 24</td> </tr> </tbody> </table>	Substance/Parameter	Fuel/Process/Type of combustion plant	Combustion plant total rated thermal input	Standard(s) ⁽⁴⁾	Minimum monitoring frequency ⁽⁵⁾	Monitoring associated with	NH ₃	— When SCR and/or SNCR is used	All sizes	Generic EN standards	Continuous ⁽⁶⁾ ⁽⁷⁾	BAT 7	NO _x	<ul style="list-style-type: none"> — Coal and/or lignite including waste co-incineration — Solid biomass and/or peat including waste co-incineration — HFO- and/or gas-oil-fired boilers and engines — Gas-oil-fired gas turbines — Natural-gas-fired boilers, engines, and turbines — Iron and steel process gases — Process fuels from the chemical industry — IGCC plants 	All sizes	Generic EN standards	Continuous ⁽⁶⁾ ⁽⁸⁾	BAT 20 BAT 24 BAT 28 BAT 32 BAT 37 BAT 41 BAT 42 BAT 43 BAT 47 BAT 48 BAT 56 BAT 64 BAT 65 BAT 73		— Combustion plants on offshore platforms	All sizes	EN 14792	Once every year ⁽⁹⁾	BAT 53	N ₂ O	— Coal and/or lignite in circulating fluidised bed boilers	All sizes	EN 21258	Once every year ⁽¹⁰⁾	BAT 20 BAT 24	FC	<p>All parameters are monitored through the SCADA system, with a daily download in spreadsheet format giving 1/2 hourly data and totalised data over a 24hour period.</p> <p>The previous permit specified periodic monitoring. However, in line with the requirement of the BAT Conclusions, we consider that CEMS should be used for compliance when the LCP is running as a CCGT (Gas turbine with WHRB in supplementary mode). We have therefore specified continuous monitoring in Table S3.1a of the consolidated permit for this mode of operation.</p> <p>The Operator also confirmed that they run the Gas Turbine with its exhaust gases going through the WHRB, so that heat can be recovered, but without the WHRB burners firing. We consider that the monitoring requirements and limits applicable to this mode of operation are the same as the Gas Turbine and WHRB in supplementary mode.</p>
Substance/Parameter	Fuel/Process/Type of combustion plant	Combustion plant total rated thermal input	Standard(s) ⁽⁴⁾	Minimum monitoring frequency ⁽⁵⁾	Monitoring associated with																												
NH ₃	— When SCR and/or SNCR is used	All sizes	Generic EN standards	Continuous ⁽⁶⁾ ⁽⁷⁾	BAT 7																												
NO _x	<ul style="list-style-type: none"> — Coal and/or lignite including waste co-incineration — Solid biomass and/or peat including waste co-incineration — HFO- and/or gas-oil-fired boilers and engines — Gas-oil-fired gas turbines — Natural-gas-fired boilers, engines, and turbines — Iron and steel process gases — Process fuels from the chemical industry — IGCC plants 	All sizes	Generic EN standards	Continuous ⁽⁶⁾ ⁽⁸⁾	BAT 20 BAT 24 BAT 28 BAT 32 BAT 37 BAT 41 BAT 42 BAT 43 BAT 47 BAT 48 BAT 56 BAT 64 BAT 65 BAT 73																												
	— Combustion plants on offshore platforms	All sizes	EN 14792	Once every year ⁽⁹⁾	BAT 53																												
N ₂ O	— Coal and/or lignite in circulating fluidised bed boilers	All sizes	EN 21258	Once every year ⁽¹⁰⁾	BAT 20 BAT 24																												

BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
		— Solid biomass and/or peat in circulating fluidised bed boilers					All other modes of operation are not subject to the requirements of continuous monitoring.	
CO	<ul style="list-style-type: none"> — Coal and/or lignite including waste co-incineration — Solid biomass and/or peat including waste co-incineration — HFO- and/or gas-oil-fired boilers and engines — Gas-oil-fired gas turbines — Natural-gas-fired boilers, engines, and turbines — Iron and steel process gases — Process fuels from the chemical industry — IGCC plants 	All sizes	Generic EN standards	Continuous ⁽⁶⁾ ⁽⁸⁾	BAT 20 BAT 24 BAT 28 BAT 33 BAT 38 BAT 44 BAT 49 BAT 56 BAT 64 BAT 65 BAT 73			
	— Combustion plants on offshore platforms	All sizes	EN 15058	Once every year ⁽⁹⁾	BAT 54			
SO ₂	<ul style="list-style-type: none"> — Coal and/or lignite incl waste co-incineration — Solid biomass and/or peat incl waste co-incineration — HFO- and/or gas-oil-fired boilers — HFO- and/or gas-oil-fired engines — Gas-oil-fired gas turbines — Iron and steel process gases — Process fuels from the chemical industry in boilers 	All sizes	Generic EN standards and EN 14791	Continuous ⁽⁶⁾ ⁽¹¹⁾ ⁽¹²⁾	BAT 21 BAT 25 BAT 29 BAT 34 BAT 39 BAT 50 BAT 57 BAT 66 BAT 67 BAT 74			

BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	—	IGCC plants						
SO ₃	—	When SCR is used	All sizes	No EN standard available	Once every year	—		
Gaseous chlorides, expressed as HCl	—	Coal and/or lignite Process fuels from the chemical industry in boilers	All sizes	EN 1911	Once every three months ⁽⁶⁾ ⁽¹³⁾ ⁽¹⁴⁾	BAT 21 BAT 57		
	—	Solid biomass and/or peat	All sizes	Generic EN standards	Continuous ⁽¹⁵⁾ ⁽¹⁶⁾	BAT 25		
	—	Waste co-incineration	All sizes	Generic EN standards	Continuous ⁽⁶⁾ ⁽¹⁶⁾	BAT 66 BAT 67		
HF	—	Coal and/or lignite Process fuels from the chemical industry in boilers	All sizes	No EN standard available	Once every three months ⁽⁶⁾ ⁽¹³⁾ ⁽¹⁴⁾	BAT 21 BAT 57		
	—	Solid biomass and/or peat	All sizes	No EN standard available	Once every year	BAT 25		
	—	Waste co-incineration	All sizes	Generic EN standards	Continuous ⁽⁶⁾ ⁽¹⁶⁾	BAT 66 BAT 67		
Dust	—	Coal and/or lignite Solid biomass and/or peat HFO- and/or gas-oil-fired boilers Iron and steel process gases Process fuels from the chemical industry in boilers IGCC plants HFO- and/or gas-oil-fired engines Gas-oil-fired gas turbines	All sizes	Generic EN standards and EN 13284-1 and EN 13284-2	Continuous ⁽⁶⁾ ⁽¹⁷⁾	BAT 22 BAT 26 BAT 30 BAT 35 BAT 39 BAT 51 BAT 58 BAT 75		

BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	—	Waste co-incineration	All sizes	Generic EN standards and EN 13284-2	Continuous	BAT 68 BAT 69		
	Metals and metalloids except mercury (As, Cd, Co, Cr, Cu, Mn, Ni, Pb, Sb, Se, Ti, V, Zn)	—	Coal and/or lignite	All sizes	EN 14385	Once every year ⁽¹⁸⁾		BAT 22 BAT 26 BAT 30
		—	Solid biomass and/or peat					
		—	Waste co-incineration	< 300 MW _{th}	EN 14385	Once every six months ⁽¹³⁾		BAT 68 BAT 69
		—		≥ 300 MW _{th}	EN 14385	Once every three months ⁽¹⁹⁾ ⁽¹³⁾		
	—	IGCC plants	≥ 100 MW _{th}	EN 14385	Once every year ⁽¹⁸⁾	BAT 75		
	Hg	—	Coal and/or lignite including waste co-incineration	< 300 MW _{th}	EN 13211	Once every three months ⁽¹³⁾ ⁽²⁰⁾		BAT 23
				≥ 300 MW _{th}	Generic EN standards and EN 14884	Continuous ⁽¹⁶⁾ ⁽²¹⁾		
		—	Solid biomass and/or peat	All sizes	EN 13211	Once every year ⁽²²⁾		BAT 27
		—	Waste co-incineration with solid biomass and/or peat	All sizes	EN 13211	Once every three months ⁽¹³⁾		BAT 70
		—	IGCC plants	≥ 100 MW _{th}	EN 13211	Once every year ⁽²³⁾		BAT 75
	TVOC	—	HFO- and/or gas-oil-fired engines	All sizes	EN 12619	Once every six months ⁽¹³⁾		BAT 33 BAT 59
		—	Process fuels from chemical industry in boilers					
	—	Waste co-incineration with coal, lignite, solid biomass and/or peat	All sizes	Generic EN standards	Continuous	BAT 71		
	Formaldehyde	—	Natural-gas in spark-ignited lean-burn gas and dual fuel engines	All sizes	No EN standard available	Once every year		BAT 45
	CH ₄	—	Natural-gas-fired engines	All sizes	EN ISO 25139	Once every year ⁽²⁴⁾		BAT 45

BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																																																	
	PCDD/F	<ul style="list-style-type: none"> — Process fuels from chemical industry in boilers — Waste co-incineration 	All sizes	EN 1948-1, EN 1948-2, EN 1948-3	Once every six months ⁽¹³⁾ ⁽²⁵⁾	BAT 59 BAT 71																																																			
5	<p>BAT is to monitor emissions to water from flue-gas treatment with at least the frequency given below and in accordance with EN standards. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.</p> <table border="1" data-bbox="331 614 1491 1361"> <thead> <tr> <th colspan="2" data-bbox="331 614 667 699">Substance/Parameter</th> <th data-bbox="667 614 1025 699">Standard(s)</th> <th data-bbox="1025 614 1267 699">Minimum monitoring frequency</th> <th data-bbox="1267 614 1491 699">Monitoring associated with</th> </tr> </thead> <tbody> <tr> <td colspan="2" data-bbox="331 699 667 730">Total organic carbon (TOC)⁽²⁶⁾</td> <td data-bbox="667 699 1025 730">EN 1484</td> <td data-bbox="1025 699 1267 1361" rowspan="10">Once every month</td> <td data-bbox="1267 699 1491 1361" rowspan="10">BAT 15</td> </tr> <tr> <td colspan="2" data-bbox="331 730 667 794">Chemical oxygen demand (COD)⁽²⁶⁾</td> <td data-bbox="667 730 1025 794">No EN standard available</td> </tr> <tr> <td colspan="2" data-bbox="331 794 667 826">Total suspended solids (TSS)</td> <td data-bbox="667 794 1025 826">EN 872</td> </tr> <tr> <td colspan="2" data-bbox="331 826 667 858">Fluoride (F⁻)</td> <td data-bbox="667 826 1025 858">EN ISO 10304-1</td> </tr> <tr> <td colspan="2" data-bbox="331 858 667 890">Sulphate (SO₄²⁻)</td> <td data-bbox="667 858 1025 890">EN ISO 10304-1</td> </tr> <tr> <td colspan="2" data-bbox="331 890 667 922">Sulphide, easily released (S²⁻)</td> <td data-bbox="667 890 1025 922">No EN standard available</td> </tr> <tr> <td colspan="2" data-bbox="331 922 667 954">Sulphite (SO₃²⁻)</td> <td data-bbox="667 922 1025 954">EN ISO 10304-3</td> </tr> <tr> <td data-bbox="331 954 595 1265" rowspan="7">Metals and metalloids</td> <td data-bbox="595 954 667 986">As</td> <td data-bbox="667 954 1025 986" rowspan="7">Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)</td> </tr> <tr> <td data-bbox="595 986 667 1018">Cd</td> </tr> <tr> <td data-bbox="595 1018 667 1050">Cr</td> </tr> <tr> <td data-bbox="595 1050 667 1082">Cu</td> </tr> <tr> <td data-bbox="595 1082 667 1114">Ni</td> </tr> <tr> <td data-bbox="595 1114 667 1145">Pb</td> </tr> <tr> <td data-bbox="595 1145 667 1177">Zn</td> </tr> <tr> <td data-bbox="595 1177 667 1265">Hg</td> <td data-bbox="667 1177 1025 1265">Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)</td> </tr> <tr> <td colspan="2" data-bbox="331 1265 667 1329">Chloride (Cl⁻)</td> <td data-bbox="667 1265 1025 1329">Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)</td> <td data-bbox="1025 1265 1267 1329"></td> <td data-bbox="1267 1265 1491 1329">—</td> </tr> <tr> <td colspan="2" data-bbox="331 1329 667 1361">Total nitrogen</td> <td data-bbox="667 1329 1025 1361">EN 12260</td> <td data-bbox="1025 1329 1267 1361"></td> <td data-bbox="1267 1329 1491 1361">—</td> </tr> </tbody> </table>						Substance/Parameter		Standard(s)	Minimum monitoring frequency	Monitoring associated with	Total organic carbon (TOC) ⁽²⁶⁾		EN 1484	Once every month	BAT 15	Chemical oxygen demand (COD) ⁽²⁶⁾		No EN standard available	Total suspended solids (TSS)		EN 872	Fluoride (F ⁻)		EN ISO 10304-1	Sulphate (SO ₄ ²⁻)		EN ISO 10304-1	Sulphide, easily released (S ²⁻)		No EN standard available	Sulphite (SO ₃ ²⁻)		EN ISO 10304-3	Metals and metalloids	As	Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)	Cd	Cr	Cu	Ni	Pb	Zn	Hg	Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)	Chloride (Cl ⁻)		Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)		—	Total nitrogen		EN 12260		—	NA	Not applicable; no flue gas treatment.
Substance/Parameter		Standard(s)	Minimum monitoring frequency	Monitoring associated with																																																					
Total organic carbon (TOC) ⁽²⁶⁾		EN 1484	Once every month	BAT 15																																																					
Chemical oxygen demand (COD) ⁽²⁶⁾		No EN standard available																																																							
Total suspended solids (TSS)		EN 872																																																							
Fluoride (F ⁻)		EN ISO 10304-1																																																							
Sulphate (SO ₄ ²⁻)		EN ISO 10304-1																																																							
Sulphide, easily released (S ²⁻)		No EN standard available																																																							
Sulphite (SO ₃ ²⁻)		EN ISO 10304-3																																																							
Metals and metalloids	As	Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)																																																							
	Cd																																																								
	Cr																																																								
	Cu																																																								
	Ni																																																								
	Pb																																																								
	Zn																																																								
Hg	Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)																																																								
Chloride (Cl ⁻)		Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)		—																																																					
Total nitrogen		EN 12260		—																																																					

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																						
6	<p>In order to improve the general environmental performance of combustion plants and to reduce emissions to air of CO and unburnt substances, BAT is to ensure optimised combustion and to use an appropriate combination of the techniques given below.</p> <table border="1" data-bbox="331 475 1487 1075"> <thead> <tr> <th data-bbox="331 475 367 507">Technique</th> <th data-bbox="367 475 994 507">Description</th> <th data-bbox="994 475 1487 507">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="331 507 367 592">a.</td> <td data-bbox="367 507 555 592">Fuel blending and mixing</td> <td data-bbox="555 507 994 592">Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type</td> <td data-bbox="994 507 1487 592" rowspan="2">Generally applicable</td> </tr> <tr> <td data-bbox="331 592 367 676">b.</td> <td data-bbox="367 592 555 676">Maintenance of the combustion system</td> <td data-bbox="555 592 994 676">Regular planned maintenance according to suppliers' recommendations</td> </tr> <tr> <td data-bbox="331 676 367 761">c.</td> <td data-bbox="367 676 555 761">Advanced control system</td> <td data-bbox="555 676 994 761">See description in Section 8.1</td> <td data-bbox="994 676 1487 761">The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> <tr> <td data-bbox="331 761 367 845">d.</td> <td data-bbox="367 761 555 845">Good design of the combustion equipment</td> <td data-bbox="555 761 994 845">Good design of furnace, combustion chambers, burners and associated devices</td> <td data-bbox="994 761 1487 845">Generally applicable to new combustion plants</td> </tr> <tr> <td data-bbox="331 845 367 1075">e.</td> <td data-bbox="367 845 555 1075">Fuel choice</td> <td data-bbox="555 845 994 1075">Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used</td> <td data-bbox="994 845 1487 1075">Applicable within the constraints associated with the availability of suitable types of fuel with a better environmental profile as a whole, which may be impacted by the energy policy of the Member State, or by the integrated site's fuel balance in the case of combustion of industrial process fuels. For existing combustion plants, the type of fuel chosen may be limited by the configuration and the design of the plant</td> </tr> </tbody> </table>	Technique	Description	Applicability	a.	Fuel blending and mixing	Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type	Generally applicable	b.	Maintenance of the combustion system	Regular planned maintenance according to suppliers' recommendations	c.	Advanced control system	See description in Section 8.1	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system	d.	Good design of the combustion equipment	Good design of furnace, combustion chambers, burners and associated devices	Generally applicable to new combustion plants	e.	Fuel choice	Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used	Applicable within the constraints associated with the availability of suitable types of fuel with a better environmental profile as a whole, which may be impacted by the energy policy of the Member State, or by the integrated site's fuel balance in the case of combustion of industrial process fuels. For existing combustion plants, the type of fuel chosen may be limited by the configuration and the design of the plant	CC	<p>Maintenance of the combustion system: Regular planned maintenance of combustion systems is carried out.</p> <p>Advanced control system: All combustion systems are automatically controlled.</p> <p>Good design of the combustion equipment: Gas turbine control system has been upgraded to DLE.</p> <p>For PB1, the Operator has confirmed that the low NOx burners have been installed and partially commissioned. The completion of the commissioning has been delayed due to low heat demand as well as the COVID-19 working restrictions. They confirm that commissioning should be completed by the compliance deadline.</p> <p>Fuel choice: Primary fuel is natural gas.</p>
Technique	Description	Applicability																							
a.	Fuel blending and mixing	Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type	Generally applicable																						
b.	Maintenance of the combustion system	Regular planned maintenance according to suppliers' recommendations																							
c.	Advanced control system	See description in Section 8.1	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system																						
d.	Good design of the combustion equipment	Good design of furnace, combustion chambers, burners and associated devices	Generally applicable to new combustion plants																						
e.	Fuel choice	Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used	Applicable within the constraints associated with the availability of suitable types of fuel with a better environmental profile as a whole, which may be impacted by the energy policy of the Member State, or by the integrated site's fuel balance in the case of combustion of industrial process fuels. For existing combustion plants, the type of fuel chosen may be limited by the configuration and the design of the plant																						

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement						
7	<p>In order to reduce emissions of ammonia to air from the use of selective catalytic reduction (SCR) and/or selective non-catalytic reduction (SNCR) for the abatement of NO_x emissions, BAT is to optimise the design and/or operation of SCR and/or SNCR (e.g. optimised reagent to NO_x ratio, homogeneous reagent distribution and optimum size of the reagent drops).</p> <p>BAT-associated emission levels</p> <p>The BAT-associated emission level (BAT-AEL) for emissions of NH₃ to air from the use of SCR and/or SNCR is < 3–10 mg/Nm³ as a yearly average or average over the sampling period. The lower end of the range can be achieved when using SCR and the upper end of the range can be achieved when using SNCR without wet abatement techniques. In the case of plants combusting biomass and operating at variable loads as well as in the case of engines combusting HFO and/or gas oil, the higher end of the BAT-AEL range is 15 mg/Nm³.</p>	NA	Not applicable; no SCR or SNCR.						
8	<p>In order to prevent or reduce emissions to air during normal operating conditions, BAT is to ensure, by appropriate design, operation and maintenance, that the emission abatement systems are used at optimal capacity and availability.</p>	NA	Not applicable; no abatement fitted						
9	<p>In order to improve the general environmental performance of combustion and/or gasification plants and to reduce emissions to air, BAT is to include the following elements in the quality assurance/quality control programmes for all the fuels used, as part of the environmental management system (see BAT 1):</p> <ul style="list-style-type: none"> (i) Initial full characterisation of the fuel used including at least the parameters listed below and in accordance with EN standards. ISO, national or other international standards may be used provided they ensure the provision of data of an equivalent scientific quality; (ii) Regular testing of the fuel quality to check that it is consistent with the initial characterisation and according to the plant design specifications. The frequency of testing and the parameters chosen from the table below are based on the variability of the fuel and an assessment of the relevance of pollutant releases (e.g. concentration in fuel, flue-gas treatment employed); (iii) Subsequent adjustment of the plant settings as and when needed and practicable (e.g. integration of the fuel characterisation and control in the advanced control system (see description in Section 8.1)). <p>Description</p> <p>Initial characterisation and regular testing of the fuel can be performed by the operator and/or the fuel supplier. If performed by the supplier, the full results are provided to the operator in the form of a product (fuel) supplier specification and/or guarantee.</p> <table border="1" data-bbox="322 1257 1496 1374"> <thead> <tr> <th data-bbox="322 1257 714 1294">Fuel(s)</th> <th data-bbox="714 1257 1496 1294">Substances/Parameters subject to characterisation</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 1294 714 1331">Biomass/peat</td> <td data-bbox="714 1294 1496 1331">— LHV</td> </tr> <tr> <td data-bbox="322 1331 714 1374"></td> <td data-bbox="714 1331 1496 1374">— moisture</td> </tr> </tbody> </table>	Fuel(s)	Substances/Parameters subject to characterisation	Biomass/peat	— LHV		— moisture	<p>CC</p> <p>FC</p>	<p>The primary fuel is natural gas. We consider that for plants which burn natural gas from the National Grid as a fuel that it is not necessary for the operator to replicate the testing carried out by the National Grid.</p> <p>During determination, the Operator confirmed that the site will no longer be using gas oil. They confirmed that the gas oil tank has now been emptied and cleaned and restocked with new Hydrotreated Vegetable Oil (HVO).</p> <p>An improvement condition has been included requiring the Operator to submit a plan outlining</p>
Fuel(s)	Substances/Parameters subject to characterisation								
Biomass/peat	— LHV								
	— moisture								

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																
	<table border="1"> <tr> <td data-bbox="322 384 712 507"></td> <td data-bbox="712 384 1491 507"> <ul style="list-style-type: none"> — Ash — C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn) </td> </tr> <tr> <td data-bbox="322 507 712 719">Coal/lignite</td> <td data-bbox="712 507 1491 719"> <ul style="list-style-type: none"> — LHV — Moisture — Volatiles, ash, fixed carbon, C, H, N, O, S — Br, Cl, F — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) </td> </tr> <tr> <td data-bbox="322 719 712 802">HFO</td> <td data-bbox="712 719 1491 802"> <ul style="list-style-type: none"> — Ash — C, S, N, Ni, V </td> </tr> <tr> <td data-bbox="322 802 712 885">Gas oil</td> <td data-bbox="712 802 1491 885"> <ul style="list-style-type: none"> — Ash — N, C, S </td> </tr> <tr> <td data-bbox="322 885 712 968">Natural gas</td> <td data-bbox="712 885 1491 968"> <ul style="list-style-type: none"> — LHV — CH₄, C₂H₆, C₃, C₄₊, CO₂, N₂, Wobbe index </td> </tr> <tr> <td data-bbox="322 968 712 1051">Process fuels from the chemical industry⁽²⁷⁾</td> <td data-bbox="712 968 1491 1051"> <ul style="list-style-type: none"> — Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) </td> </tr> <tr> <td data-bbox="322 1051 712 1125">Iron and steel process gases</td> <td data-bbox="712 1051 1491 1125"> <ul style="list-style-type: none"> — LHV, CH₄ (for COG), C_xH_y (for COG), CO₂, H₂, N₂, total sulphur, dust, Wobbe index </td> </tr> <tr> <td data-bbox="322 1125 712 1281">Waste⁽²⁸⁾</td> <td data-bbox="712 1125 1491 1281"> <ul style="list-style-type: none"> — LHV — Moisture — Volatiles, ash, Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) </td> </tr> </table>		<ul style="list-style-type: none"> — Ash — C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn) 	Coal/lignite	<ul style="list-style-type: none"> — LHV — Moisture — Volatiles, ash, fixed carbon, C, H, N, O, S — Br, Cl, F — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) 	HFO	<ul style="list-style-type: none"> — Ash — C, S, N, Ni, V 	Gas oil	<ul style="list-style-type: none"> — Ash — N, C, S 	Natural gas	<ul style="list-style-type: none"> — LHV — CH₄, C₂H₆, C₃, C₄₊, CO₂, N₂, Wobbe index 	Process fuels from the chemical industry ⁽²⁷⁾	<ul style="list-style-type: none"> — Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) 	Iron and steel process gases	<ul style="list-style-type: none"> — LHV, CH₄ (for COG), C_xH_y (for COG), CO₂, H₂, N₂, total sulphur, dust, Wobbe index 	Waste ⁽²⁸⁾	<ul style="list-style-type: none"> — LHV — Moisture — Volatiles, ash, Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) 		<p>how fuel characterisation will be carried out for HVO in order to meet the requirements of BAT9.</p> <p>HVO is only used for stand-by fuel. The fuel specification provided confirms it is <0.1% sulphur.</p>
	<ul style="list-style-type: none"> — Ash — C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn) 																		
Coal/lignite	<ul style="list-style-type: none"> — LHV — Moisture — Volatiles, ash, fixed carbon, C, H, N, O, S — Br, Cl, F — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) 																		
HFO	<ul style="list-style-type: none"> — Ash — C, S, N, Ni, V 																		
Gas oil	<ul style="list-style-type: none"> — Ash — N, C, S 																		
Natural gas	<ul style="list-style-type: none"> — LHV — CH₄, C₂H₆, C₃, C₄₊, CO₂, N₂, Wobbe index 																		
Process fuels from the chemical industry ⁽²⁷⁾	<ul style="list-style-type: none"> — Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) 																		
Iron and steel process gases	<ul style="list-style-type: none"> — LHV, CH₄ (for COG), C_xH_y (for COG), CO₂, H₂, N₂, total sulphur, dust, Wobbe index 																		
Waste ⁽²⁸⁾	<ul style="list-style-type: none"> — LHV — Moisture — Volatiles, ash, Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) 																		
10	In order to reduce emissions to air and/or to water during other than normal operating conditions (OTNOC), BAT is to set up and implement a management plan as part of the environmental management system (see BAT 1), commensurate with the relevance of potential pollutant releases, that includes the following elements:	CC	Standard operating procedures are held on site to provide																

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement								
	<ul style="list-style-type: none"> — appropriate design of the systems considered relevant in causing OTNOC that may have an impact on emissions to air, water and/or soil (e.g. low-load design concepts for reducing the minimum start-up and shutdown loads for stable generation in gas turbines), — set-up and implementation of a specific preventive maintenance plan for these relevant systems, — review and recording of emissions caused by OTNOC and associated circumstances and implementation of corrective actions if necessary, — periodic assessment of the overall emissions during OTNOC (e.g. frequency of events, duration, emissions quantification/estimation) and implementation of corrective actions if necessary. 		<p>instruction to operators in the event of OTNOC.</p> <p>The Operator confirms that systems considered relevant in causing OTNOC are covered by the Preventative Maintenance Plan.</p> <p>Periods of OTNOC are recorded and details of emissions can be extracted from the CEM's and SCADA systems.</p> <p>Occurrences of OTNOC are reviewed on a monthly basis. Periods of OTNOC are recorded and occurrences of OTNOC are reviewed regularly and corrective actions implemented if necessary.</p>								
11	<p>BAT is to appropriately monitor emissions to air and/or to water during OTNOC.</p> <p>Description</p> <p>The monitoring can be carried out by direct measurement of emissions or by monitoring of surrogate parameters if this proves to be of equal or better scientific quality than the direct measurement of emissions. Emissions during start-up and shutdown (SU/SD) may be assessed based on a detailed emission measurement carried out for a typical SU/SD procedure at least once every year, and using the results of this measurement to estimate the emissions for each and every SU/SD throughout the year.</p>	CC	<p>Periods of OTNOC are recorded and details of emissions can be extracted from the CEM's and SCADA systems.</p>								
12	<p>In order to increase the energy efficiency of combustion, gasification and/or IGCC units operated $\geq 1\,500$ h/yr, BAT is to use an appropriate combination of the techniques given below.</p> <table border="1" data-bbox="320 1251 1494 1347"> <thead> <tr> <th data-bbox="320 1251 365 1283"></th> <th data-bbox="365 1251 577 1283">Technique</th> <th data-bbox="577 1251 1057 1283">Description</th> <th data-bbox="1057 1251 1494 1283">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="320 1283 365 1347">a.</td> <td data-bbox="365 1283 577 1347">Combustion optimisation</td> <td data-bbox="577 1283 1057 1347">See description in Section 8.2.</td> <td data-bbox="1057 1283 1494 1347">Generally applicable</td> </tr> </tbody> </table>		Technique	Description	Applicability	a.	Combustion optimisation	See description in Section 8.2.	Generally applicable	CC	<p>The Operator has confirmed that the combustion units will use a combination of the techniques described in BAT 12 to increase energy efficiency. These include:</p>
	Technique	Description	Applicability								
a.	Combustion optimisation	See description in Section 8.2.	Generally applicable								

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
			Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues		<p>g) Advanced control systems: Computerised control of the main combustion parameters enables the combustion efficiency to be improved. Output on Tmax (temperature control) is controlled and the fuel /air ratio is adjusted to give optimum performance in terms of electrical output and emissions. PB1 has a Scanview Burner Management System installed which monitors and controls the fuel/air ratio in the boiler to adjust firing rates. The WHRB is controlled via a three term controller which monitors steam flow, feedwater flow and boiler pressure.</p> <p>h) Feed-water preheating using recovered heat: Feed-water coming out of the de-aerators is preheated as it passes through the economisers before going into the boiler tubes. The heat is recovered from the flue gas before it is discharged to the stack.</p> <p>i) Heat recovery by cogeneration (CHP): Heat from the gas turbine gases is recovered in the Waste Heat Boiler for producing</p>
b.	Optimisation of the working medium conditions	Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO _x emissions or the characteristics of energy demanded			
c.	Optimisation of the steam cycle	Operate with lower turbine exhaust pressure by utilisation of the lowest possible temperature of the condenser cooling water, within the design conditions			
d.	Minimisation of energy consumption	Minimising the internal energy consumption (e.g. greater efficiency of the feed-water pump)			
e.	Preheating of combustion air	Reuse of part of the heat recovered from the combustion flue-gas to preheat the air used in combustion	Generally applicable within the constraints related to the need to control NO _x emissions		
f.	Fuel preheating	Preheating of fuel using recovered heat	Generally applicable within the constraints associated with the boiler design and the need to control NO _x emissions		
g.	Advanced control system	See description in Section 8.2. Computerised control of the main combustion parameters enables the combustion efficiency to be improved	Generally applicable to new units. The applicability to old units may be constrained by the need to retrofit the combustion system and/or control command system		
h.	Feed-water preheating using recovered heat	Preheat water coming out of the steam condenser with recovered heat, before reusing it in the boiler	Only applicable to steam circuits and not to hot boilers. Applicability to existing units may be limited due to constraints associated with the plant configuration and the amount of recoverable heat		
i.	Heat recovery by cogeneration (CHP)	Recovery of heat (mainly from the steam system) for producing hot water/steam to be used in industrial processes/activities or in a public network for district heating. Additional heat recovery is possible from: — flue-gas	Applicable within the constraints associated with the local heat and power demand. The applicability may be limited in the case of gas compressors with an unpredictable operational heat profile		

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
			<ul style="list-style-type: none"> — grate cooling — circulating fluidised bed 		steam to be used in industrial production processes on the Syngenta site.
	j.	CHP readiness	See description in Section 8.2.	Only applicable to new units where there is a realistic potential for the future use of heat in the vicinity of the unit	
	k.	Flue-gas condenser	See description in Section 8.2.	Generally applicable to CHP units provided there is enough demand for low-temperature heat	
	l.	Heat accumulation	Heat accumulation storage in CHP mode	Only applicable to CHP plants. The applicability may be limited in the case of low heat load demand	
	m.	Wet stack	See description in Section 8.2.	Generally applicable to new and existing units fitted with wet FGD	
	n.	Cooling tower discharge	The release of emissions to air through a cooling tower and not via a dedicated stack	Only applicable to units fitted with wet FGD where reheating of the flue-gas is necessary before release, and where the unit cooling system is a cooling tower	
	o.	Fuel pre-drying	The reduction of fuel moisture content before combustion to improve combustion conditions	Applicable to the combustion of biomass and/or peat within the constraints associated with spontaneous combustion risks (e.g. the moisture content of peat is kept above 40 % throughout the delivery chain). The retrofit of existing plants may be restricted by the extra calorific value that can be obtained from the drying operation and by the limited retrofit possibilities offered by some boiler designs or plant configurations	
	p.	Minimisation of heat losses	Minimising residual heat losses, e.g. those that occur via the slag or those that can be reduced by insulating radiating sources	Only applicable to solid-fuel-fired combustion units and to gasification/IGCC units	
	q.	Advanced materials	Use of advanced materials proven to be capable of withstanding high operating temperatures and pressures and thus to achieve increased steam/combustion process efficiencies	Only applicable to new plants	

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	
	r.	Steam turbine upgrades	This includes techniques such as increasing the temperature and pressure of medium-pressure steam, addition of a low-pressure turbine, and modifications to the geometry of the turbine rotor blades	The applicability may be restricted by demand, steam conditions and/or limited plant lifetime		
	s.	Supercritical and ultra-supercritical steam conditions	Use of a steam circuit, including steam reheating systems, in which steam can reach pressures above 220,6 bar and temperatures above 374 °C in the case of supercritical conditions, and above 250 – 300 bar and temperatures above 580 – 600 °C in the case of ultra-supercritical conditions	Only applicable to new units of $\geq 600 \text{ MW}_{\text{th}}$ operated $> 4\,000 \text{ h/yr}$. Not applicable when the purpose of the unit is to produce low steam temperatures and/or pressures in process industries. Not applicable to gas turbines and engines generating steam in CHP mode. For units combusting biomass, the applicability may be constrained by high-temperature corrosion in the case of certain biomasses		
13	In order to reduce water usage and the volume of contaminated waste water discharged, BAT is to use one or both of the techniques given below.			CC	Water consumption is for boiler feedwater only. The waste water generated at the site primarily consists of general runoff, this is not suitable for reuse as boiler feedwater. Runoff is discharged to Fenay Beck. Process effluents collected by the waste water drainage system are dispatched to the on-site physico / chemical effluent treatment plant operated by Syngenta Limited.	
	Technique	Description		Applicability		
	a.	Water recycling	Residual aqueous streams, including run-off water, from the plant are reused for other purposes. The degree of recycling is limited by the quality requirements of the recipient water stream and the water balance of the plant	Not applicable to waste water from cooling systems when water treatment chemicals and/or high concentrations of salts from seawater are present		
	b.	Dry bottom ash handling	Dry, hot bottom ash falls from the furnace onto a mechanical conveyor system and is cooled down by ambient air. No water is used in the process.	Only applicable to plants combusting solid fuels. There may be technical restrictions that prevent retrofitting to existing combustion plants		
14	In order to prevent the contamination of uncontaminated waste water and to reduce emissions to water, BAT is to segregate waste water streams and to treat them separately, depending on the pollutant content.			CC	Two waste water streams are produced at the site: process effluents (including boiler blowdown water and wastewater from the demineralisation plant)	
	Description Waste water streams that are typically segregated and treated include surface run-off water, cooling water, and waste water from flue-gas treatment.					

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																		
	<p>Applicability The applicability may be restricted in the case of existing plants due to the configuration of the drainage systems.</p>		<p>and surface run-off water. To prevent contamination of uncontaminated waste water, these streams are discharged into separate dedicated drainage systems. Process effluents collected by the waste water drainage system are dispatched to the on-site physico / chemical effluent treatment plant operated by Syngenta Limited. Clean surface water runoffs collected by the surface water drainage system are discharged to the site surface water system.</p>																		
15	<p>In order to reduce emissions to water from flue-gas treatment, BAT is to use an appropriate combination of the techniques given below, and to use secondary techniques as close as possible to the source in order to avoid dilution.</p> <table border="1" data-bbox="322 1011 1491 1369"> <thead> <tr> <th data-bbox="322 1011 712 1070">Technique</th> <th data-bbox="712 1011 1025 1070">Typical pollutants prevented/abated</th> <th data-bbox="1025 1011 1491 1070">Applicability</th> </tr> </thead> <tbody> <tr> <td colspan="3" data-bbox="322 1070 1491 1107" style="text-align: center;">Primary techniques</td> </tr> <tr> <td data-bbox="322 1107 367 1193">a.</td> <td data-bbox="367 1107 712 1193">Optimised combustion (see BAT 6) and flue-gas treatment systems (e.g. SCR/SNCR, see BAT 7)</td> <td data-bbox="712 1107 1491 1193">Organic compounds, ammonia (NH₃) Generally applicable</td> </tr> <tr> <td colspan="3" data-bbox="322 1193 1491 1230" style="text-align: center;">Secondary techniques ⁽²⁹⁾</td> </tr> <tr> <td data-bbox="322 1230 367 1289">b.</td> <td data-bbox="367 1230 712 1289">Adsorption on activated carbon</td> <td data-bbox="712 1230 1491 1289">Organic compounds, mercury (Hg) Generally applicable</td> </tr> <tr> <td data-bbox="322 1289 367 1369">c.</td> <td data-bbox="367 1289 712 1369">Aerobic biological treatment</td> <td data-bbox="712 1289 1491 1369">Biodegradable organic compounds, ammonium (NH₄⁺) Generally applicable for the treatment of organic compounds. Aerobic biological treatment of ammonium (NH₄⁺) may not be applicable in the</td> </tr> </tbody> </table>	Technique	Typical pollutants prevented/abated	Applicability	Primary techniques			a.	Optimised combustion (see BAT 6) and flue-gas treatment systems (e.g. SCR/SNCR, see BAT 7)	Organic compounds, ammonia (NH ₃) Generally applicable	Secondary techniques ⁽²⁹⁾			b.	Adsorption on activated carbon	Organic compounds, mercury (Hg) Generally applicable	c.	Aerobic biological treatment	Biodegradable organic compounds, ammonium (NH ₄ ⁺) Generally applicable for the treatment of organic compounds. Aerobic biological treatment of ammonium (NH ₄ ⁺) may not be applicable in the	NA	Not applicable; no flue gas treatment.
Technique	Typical pollutants prevented/abated	Applicability																			
Primary techniques																					
a.	Optimised combustion (see BAT 6) and flue-gas treatment systems (e.g. SCR/SNCR, see BAT 7)	Organic compounds, ammonia (NH ₃) Generally applicable																			
Secondary techniques ⁽²⁹⁾																					
b.	Adsorption on activated carbon	Organic compounds, mercury (Hg) Generally applicable																			
c.	Aerobic biological treatment	Biodegradable organic compounds, ammonium (NH ₄ ⁺) Generally applicable for the treatment of organic compounds. Aerobic biological treatment of ammonium (NH ₄ ⁺) may not be applicable in the																			

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
			case of high chloride concentrations (i.e. around 10 g/l)		
	d.	Anoxic/anaerobic biological treatment	Mercury (Hg), nitrate (NO ₃ ⁻), nitrite (NO ₂ ⁻)	Generally applicable	
	e.	Coagulation and flocculation	Suspended solids	Generally applicable	
	f.	Crystallisation	Metals and metalloids, sulphate (SO ₄ ²⁻), fluoride (F ⁻)	Generally applicable	
	g.	Filtration (e.g. sand filtration, microfiltration, ultrafiltration)	Suspended solids, metals	Generally applicable	
	h.	Flotation	Suspended solids, free oil	Generally applicable	
	i.	Ion exchange	Metals	Generally applicable	
	j.	Neutralisation	Acids, alkalis	Generally applicable	
	k.	Oxidation	Sulphide (S ²⁻), sulphite (SO ₃ ²⁻)	Generally applicable	
	l.	Precipitation	Metals and metalloids, sulphate (SO ₄ ²⁻), fluoride (F ⁻)	Generally applicable	
	m.	Sedimentation	Suspended solids	Generally applicable	
	n.	Stripping	Ammonia (NH ₃)	Generally applicable	
	The BAT-AELs refer to direct discharges to a receiving water body at the point where the emission leaves the installation.				
	BAT-AELs for direct discharges to a receiving water body from flue-gas treatment				
	Substance/Parameter		BAT-AELs		
			Daily average		
	Total organic carbon (TOC)		20–50 mg/l ⁽³⁰⁾ ⁽³¹⁾ ⁽³²⁾		
	Chemical oxygen demand (COD)		60–150 mg/l ⁽³⁰⁾ ⁽³¹⁾ ⁽³²⁾		
	Total suspended solids (TSS)		10–30 mg/l		
	Fluoride (F ⁻)		10–25 mg/l ⁽³²⁾		
	Sulphate (SO ₄ ²⁻)		1,3–2,0 g/l ⁽³²⁾ ⁽³³⁾ ⁽³⁴⁾ ⁽³⁵⁾		
	Sulphide (S ²⁻), easily released		0,1–0,2 mg/l ⁽³²⁾		
	Sulphite (SO ₃ ²⁻)		1–20 mg/l ⁽³²⁾		
	Metals and metalloids	As	10–50 µg/l		

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement														
	<table border="1"> <tr><td>Cd</td><td>2–5 µg/l</td></tr> <tr><td>Cr</td><td>10–50 µg/l</td></tr> <tr><td>Cu</td><td>10–50 µg/l</td></tr> <tr><td>Hg</td><td>0,2–3 µg/l</td></tr> <tr><td>Ni</td><td>10–50 µg/l</td></tr> <tr><td>Pb</td><td>10–20 µg/l</td></tr> <tr><td>Zn</td><td>50–200 µg/l</td></tr> </table>	Cd	2–5 µg/l	Cr	10–50 µg/l	Cu	10–50 µg/l	Hg	0,2–3 µg/l	Ni	10–50 µg/l	Pb	10–20 µg/l	Zn	50–200 µg/l		
Cd	2–5 µg/l																
Cr	10–50 µg/l																
Cu	10–50 µg/l																
Hg	0,2–3 µg/l																
Ni	10–50 µg/l																
Pb	10–20 µg/l																
Zn	50–200 µg/l																
16	<p>In order to reduce the quantity of waste sent for disposal from the combustion and/or gasification process and abatement techniques, BAT is to organise operations so as to maximise, in order of priority and taking into account life-cycle thinking:</p> <p>(a) waste prevention, e.g. maximise the proportion of residues which arise as by-products;</p> <p>(b) waste preparation for reuse, e.g. according to the specific requested quality criteria;</p> <p>(c) waste recycling;</p> <p>(d) other waste recovery (e.g. energy recovery),</p> <p>by implementing an appropriate combination of techniques such as:</p> <table border="1"> <thead> <tr> <th data-bbox="322 919 573 951">Technique</th> <th data-bbox="573 919 1079 951">Description</th> <th data-bbox="1079 919 1491 951">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 951 573 1110">a. Generation of gypsum as a by-product</td> <td data-bbox="573 951 1079 1110">Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g. as raw material in the plasterboard industry). The quality of limestone used in the wet FGD influences the purity of the gypsum produced</td> <td data-bbox="1079 951 1491 1110">Generally applicable within the constraints associated with the required gypsum quality, the health requirements associated to each specific use, and by the market conditions</td> </tr> <tr> <td data-bbox="322 1110 573 1238">b. Recycling or recovery of residues in the construction sector</td> <td data-bbox="573 1110 1079 1238">Recycling or recovery of residues (e.g. from semi-dry desulphurisation processes, fly ash, bottom ash) as a construction material (e.g. in road building, to replace sand in concrete production, or in the cement industry)</td> <td data-bbox="1079 1110 1491 1238">Generally applicable within the constraints associated with the required material quality (e.g. physical properties, content of harmful substances) associated to each specific use, and by the market conditions</td> </tr> <tr> <td data-bbox="322 1238 573 1350">c. Energy recovery by using waste in the fuel mix</td> <td data-bbox="573 1238 1079 1350">The residual energy content of carbon-rich ash and sludges generated by the combustion of coal, lignite, heavy fuel oil, peat or biomass can be recovered for example by mixing with the fuel</td> <td data-bbox="1079 1238 1491 1350">Generally applicable where plants can accept waste in the fuel mix and are technically able to feed the fuels into the combustion chamber</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Generation of gypsum as a by-product	Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g. as raw material in the plasterboard industry). The quality of limestone used in the wet FGD influences the purity of the gypsum produced	Generally applicable within the constraints associated with the required gypsum quality, the health requirements associated to each specific use, and by the market conditions	b. Recycling or recovery of residues in the construction sector	Recycling or recovery of residues (e.g. from semi-dry desulphurisation processes, fly ash, bottom ash) as a construction material (e.g. in road building, to replace sand in concrete production, or in the cement industry)	Generally applicable within the constraints associated with the required material quality (e.g. physical properties, content of harmful substances) associated to each specific use, and by the market conditions	c. Energy recovery by using waste in the fuel mix	The residual energy content of carbon-rich ash and sludges generated by the combustion of coal, lignite, heavy fuel oil, peat or biomass can be recovered for example by mixing with the fuel	Generally applicable where plants can accept waste in the fuel mix and are technically able to feed the fuels into the combustion chamber	CC	<p>No waste is generated on site as by-products from the combustion process and there is no flue gas treatment plant.</p> <p>Any waste generated is limited to small quantities resulting from maintenance activities. Hazardous waste (principally empty chemical containers) are segregated from non-hazardous waste which are themselves segregated at source in separated skips depending on the type of waste. Waste is then managed under a service agreement and is dealt with in accordance with the waste hierarchy.</p>		
Technique	Description	Applicability															
a. Generation of gypsum as a by-product	Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g. as raw material in the plasterboard industry). The quality of limestone used in the wet FGD influences the purity of the gypsum produced	Generally applicable within the constraints associated with the required gypsum quality, the health requirements associated to each specific use, and by the market conditions															
b. Recycling or recovery of residues in the construction sector	Recycling or recovery of residues (e.g. from semi-dry desulphurisation processes, fly ash, bottom ash) as a construction material (e.g. in road building, to replace sand in concrete production, or in the cement industry)	Generally applicable within the constraints associated with the required material quality (e.g. physical properties, content of harmful substances) associated to each specific use, and by the market conditions															
c. Energy recovery by using waste in the fuel mix	The residual energy content of carbon-rich ash and sludges generated by the combustion of coal, lignite, heavy fuel oil, peat or biomass can be recovered for example by mixing with the fuel	Generally applicable where plants can accept waste in the fuel mix and are technically able to feed the fuels into the combustion chamber															

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																			
	d. Preparation of spent catalyst for reuse	Preparation of catalyst for reuse (e.g. up to four times for SCR catalysts) restores some or all of the original performance, extending the service life of the catalyst to several decades. Preparation of spent catalyst for reuse is integrated in a catalyst management scheme	The applicability may be limited by the mechanical condition of the catalyst and the required performance with respect to controlling NO _x and NH ₃ emissions																					
17	In order to reduce noise emissions, BAT is to use one or a combination of the techniques given below.			CC	<ul style="list-style-type: none"> - The plant is enclosed within a dedicated building. - GT is housed in an acoustic enclosure. - Plant is operated by experienced staff. 																			
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 15%;">Technique</th> <th style="width: 45%;">Description</th> <th style="width: 40%;">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="315 628 573 938">a. Operational measures</td> <td data-bbox="580 628 1081 938"> These include: <ul style="list-style-type: none"> — improved inspection and maintenance of equipment — closing of doors and windows of enclosed areas, if possible — equipment operated by experienced staff — avoidance of noisy activities at night, if possible — provisions for noise control during maintenance activities </td> <td data-bbox="1088 628 1496 938">Generally applicable</td> </tr> <tr> <td data-bbox="315 943 573 1002">b. Low-noise equipment</td> <td data-bbox="580 943 1081 1002">This potentially includes compressors, pumps and disks</td> <td data-bbox="1088 943 1496 1002">Generally applicable when the equipment is new or replaced</td> </tr> <tr> <td data-bbox="315 1007 573 1107">c. Noise attenuation</td> <td data-bbox="580 1007 1081 1107">Noise propagation can be reduced by inserting obstacles between the emitter and the receiver. Appropriate obstacles include protection walls, embankments and buildings</td> <td data-bbox="1088 1007 1496 1107">Generally applicable to new plants. In the case of existing plants, the insertion of obstacles may be restricted by lack of space</td> </tr> <tr> <td data-bbox="315 1112 573 1289">d. Noise-control equipment</td> <td data-bbox="580 1112 1081 1289"> This includes: <ul style="list-style-type: none"> — noise-reducers — equipment insulation — enclosure of noisy equipment — soundproofing of buildings </td> <td data-bbox="1088 1112 1496 1289">The applicability may be restricted by lack of space</td> </tr> <tr> <td data-bbox="315 1294 573 1374">e. Appropriate location of equipment and buildings</td> <td data-bbox="580 1294 1081 1374">Noise levels can be reduced by increasing the distance between the emitter and the receiver and by using buildings as noise screens</td> <td data-bbox="1088 1294 1496 1374">Generally applicable to new plant</td> </tr> </tbody> </table>			Technique			Description	Applicability	a. Operational measures	These include: <ul style="list-style-type: none"> — improved inspection and maintenance of equipment — closing of doors and windows of enclosed areas, if possible — equipment operated by experienced staff — avoidance of noisy activities at night, if possible — provisions for noise control during maintenance activities 	Generally applicable	b. Low-noise equipment	This potentially includes compressors, pumps and disks	Generally applicable when the equipment is new or replaced	c. Noise attenuation	Noise propagation can be reduced by inserting obstacles between the emitter and the receiver. Appropriate obstacles include protection walls, embankments and buildings	Generally applicable to new plants. In the case of existing plants, the insertion of obstacles may be restricted by lack of space	d. Noise-control equipment	This includes: <ul style="list-style-type: none"> — noise-reducers — equipment insulation — enclosure of noisy equipment — soundproofing of buildings 	The applicability may be restricted by lack of space	e. Appropriate location of equipment and buildings	Noise levels can be reduced by increasing the distance between the emitter and the receiver and by using buildings as noise screens	Generally applicable to new plant		
Technique	Description	Applicability																						
a. Operational measures	These include: <ul style="list-style-type: none"> — improved inspection and maintenance of equipment — closing of doors and windows of enclosed areas, if possible — equipment operated by experienced staff — avoidance of noisy activities at night, if possible — provisions for noise control during maintenance activities 	Generally applicable																						
b. Low-noise equipment	This potentially includes compressors, pumps and disks	Generally applicable when the equipment is new or replaced																						
c. Noise attenuation	Noise propagation can be reduced by inserting obstacles between the emitter and the receiver. Appropriate obstacles include protection walls, embankments and buildings	Generally applicable to new plants. In the case of existing plants, the insertion of obstacles may be restricted by lack of space																						
d. Noise-control equipment	This includes: <ul style="list-style-type: none"> — noise-reducers — equipment insulation — enclosure of noisy equipment — soundproofing of buildings 	The applicability may be restricted by lack of space																						
e. Appropriate location of equipment and buildings	Noise levels can be reduced by increasing the distance between the emitter and the receiver and by using buildings as noise screens	Generally applicable to new plant																						

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																																																															
Combustion of gaseous fuels																																																																		
40	<p>In order to increase the energy efficiency of natural gas combustion, BAT is to use an appropriate combination of the techniques given in BAT 12 and below.</p> <table border="1" data-bbox="322 485 1496 730"> <thead> <tr> <th data-bbox="322 485 353 523">Technique</th> <th data-bbox="353 485 501 523">Description</th> <th data-bbox="501 485 1496 523">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 523 353 730">a. Combined cycle</td> <td data-bbox="353 523 501 730">See description in Section 8.2</td> <td data-bbox="501 523 1496 730">Generally applicable to new gas turbines and engines except when operated < 1 500 h/yr. Applicable to existing gas turbines and engines within the constraints associated with the steam cycle design and the space availability. Not applicable to existing gas turbines and engines operated < 1 500 h/yr. Not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns. Not applicable to boilers</td> </tr> </tbody> </table> <p>BAT-associated energy efficiency levels (BAT-AEELs) for the combustion of natural gas</p> <table border="1" data-bbox="322 759 1496 1066"> <thead> <tr> <th data-bbox="322 759 595 912" rowspan="3">Type of combustion unit</th> <th colspan="5" data-bbox="595 759 1496 794">BAT-AEELs ⁽¹³⁶⁾ ⁽¹³⁷⁾</th> </tr> <tr> <th colspan="2" data-bbox="595 794 712 855">Net electrical efficiency (%)</th> <th data-bbox="712 794 913 855" rowspan="2">Net total fuel utilisation (%) ⁽¹³⁸⁾ ⁽¹³⁹⁾</th> <th colspan="2" data-bbox="913 794 1496 855">Net mechanical energy efficiency (%) ⁽¹³⁹⁾ ⁽¹⁴⁰⁾</th> </tr> <tr> <th data-bbox="595 855 712 912">New unit</th> <th data-bbox="712 855 913 912">Existing unit</th> <th data-bbox="913 855 1137 912">New unit</th> <th data-bbox="1137 855 1496 912">Existing unit</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 912 595 970">Gas engine</td> <td data-bbox="595 912 712 970">39,5–44 ⁽¹⁴¹⁾</td> <td data-bbox="712 912 913 970">35–44 ⁽¹⁴¹⁾</td> <td data-bbox="913 912 1137 970">56–85 ⁽¹⁴¹⁾</td> <td colspan="2" data-bbox="1137 912 1496 970">No BAT-AEEL.</td> </tr> <tr> <td data-bbox="322 970 595 1008">Gas-fired boiler</td> <td data-bbox="595 970 712 1008">39–42,5</td> <td data-bbox="712 970 913 1008">38–40</td> <td data-bbox="913 970 1137 1008">78–95</td> <td colspan="2" data-bbox="1137 970 1496 1008">No BAT-AEEL.</td> </tr> <tr> <td data-bbox="322 1008 595 1066">Open cycle gas turbine, ≥ 50 MW_{th}</td> <td data-bbox="595 1008 712 1066">36–41,5</td> <td data-bbox="712 1008 913 1066">33–41,5</td> <td data-bbox="913 1008 1137 1066">No BAT-AEEL</td> <td data-bbox="1137 1008 1290 1066">36,5–41</td> <td data-bbox="1290 1008 1496 1066">33,5–41</td> </tr> </tbody> </table> <p>Combined cycle gas turbine (CCGT)</p> <table border="1" data-bbox="322 1114 1496 1257"> <tbody> <tr> <td data-bbox="322 1114 595 1152">CCGT, 50–600 MW_{th}</td> <td data-bbox="595 1114 712 1152">53–58,5</td> <td data-bbox="712 1114 913 1152">46–54</td> <td data-bbox="913 1114 1137 1152">No BAT-AEEL</td> <td colspan="2" data-bbox="1137 1114 1496 1152">No BAT-AEEL</td> </tr> <tr> <td data-bbox="322 1152 595 1190">CCGT, ≥ 600 MW_{th}</td> <td data-bbox="595 1152 712 1190">57–60,5</td> <td data-bbox="712 1152 913 1190">50–60</td> <td data-bbox="913 1152 1137 1190">No BAT-AEEL</td> <td colspan="2" data-bbox="1137 1152 1496 1190">No BAT-AEEL</td> </tr> <tr> <td data-bbox="322 1190 595 1228">CHP CCGT, 50–600 MW_{th}</td> <td data-bbox="595 1190 712 1228">53–58,5</td> <td data-bbox="712 1190 913 1228">46–54</td> <td data-bbox="913 1190 1137 1228">65–95</td> <td colspan="2" data-bbox="1137 1190 1496 1228">No BAT-AEEL</td> </tr> <tr> <td data-bbox="322 1228 595 1257">CHP CCGT, ≥ 600 MW_{th}</td> <td data-bbox="595 1228 712 1257">57–60,5</td> <td data-bbox="712 1228 913 1257">50–60</td> <td data-bbox="913 1228 1137 1257">65–95</td> <td colspan="2" data-bbox="1137 1228 1496 1257">No BAT-AEEL</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Combined cycle	See description in Section 8.2	Generally applicable to new gas turbines and engines except when operated < 1 500 h/yr. Applicable to existing gas turbines and engines within the constraints associated with the steam cycle design and the space availability. Not applicable to existing gas turbines and engines operated < 1 500 h/yr. Not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns. Not applicable to boilers	Type of combustion unit	BAT-AEELs ⁽¹³⁶⁾ ⁽¹³⁷⁾					Net electrical efficiency (%)		Net total fuel utilisation (%) ⁽¹³⁸⁾ ⁽¹³⁹⁾	Net mechanical energy efficiency (%) ⁽¹³⁹⁾ ⁽¹⁴⁰⁾		New unit	Existing unit	New unit	Existing unit	Gas engine	39,5–44 ⁽¹⁴¹⁾	35–44 ⁽¹⁴¹⁾	56–85 ⁽¹⁴¹⁾	No BAT-AEEL.		Gas-fired boiler	39–42,5	38–40	78–95	No BAT-AEEL.		Open cycle gas turbine, ≥ 50 MW _{th}	36–41,5	33–41,5	No BAT-AEEL	36,5–41	33,5–41	CCGT, 50–600 MW _{th}	53–58,5	46–54	No BAT-AEEL	No BAT-AEEL		CCGT, ≥ 600 MW _{th}	57–60,5	50–60	No BAT-AEEL	No BAT-AEEL		CHP CCGT, 50–600 MW _{th}	53–58,5	46–54	65–95	No BAT-AEEL		CHP CCGT, ≥ 600 MW _{th}	57–60,5	50–60	65–95	No BAT-AEEL		CC	<p>BAT 12: g, h and i.</p> <p>We consider that the BAT-AEELs are not applicable. The configuration of the LCP does not correspond with Table 23 of the LCP BAT Conclusions. Also, Table 23 specifies that the BAT-AEELs are not applicable to plant operating less than 1500 hours per year. See 4.2 of the key issues section for further information.</p>
Technique	Description	Applicability																																																																
a. Combined cycle	See description in Section 8.2	Generally applicable to new gas turbines and engines except when operated < 1 500 h/yr. Applicable to existing gas turbines and engines within the constraints associated with the steam cycle design and the space availability. Not applicable to existing gas turbines and engines operated < 1 500 h/yr. Not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns. Not applicable to boilers																																																																
Type of combustion unit	BAT-AEELs ⁽¹³⁶⁾ ⁽¹³⁷⁾																																																																	
	Net electrical efficiency (%)		Net total fuel utilisation (%) ⁽¹³⁸⁾ ⁽¹³⁹⁾	Net mechanical energy efficiency (%) ⁽¹³⁹⁾ ⁽¹⁴⁰⁾																																																														
	New unit	Existing unit		New unit	Existing unit																																																													
Gas engine	39,5–44 ⁽¹⁴¹⁾	35–44 ⁽¹⁴¹⁾	56–85 ⁽¹⁴¹⁾	No BAT-AEEL.																																																														
Gas-fired boiler	39–42,5	38–40	78–95	No BAT-AEEL.																																																														
Open cycle gas turbine, ≥ 50 MW _{th}	36–41,5	33–41,5	No BAT-AEEL	36,5–41	33,5–41																																																													
CCGT, 50–600 MW _{th}	53–58,5	46–54	No BAT-AEEL	No BAT-AEEL																																																														
CCGT, ≥ 600 MW _{th}	57–60,5	50–60	No BAT-AEEL	No BAT-AEEL																																																														
CHP CCGT, 50–600 MW _{th}	53–58,5	46–54	65–95	No BAT-AEEL																																																														
CHP CCGT, ≥ 600 MW _{th}	57–60,5	50–60	65–95	No BAT-AEEL																																																														
41	<p>In order to prevent or reduce NO_x emissions to air from the combustion of natural gas in boilers, BAT is to use one or a combination of the techniques given below.</p> <table border="1" data-bbox="322 1327 1496 1362"> <thead> <tr> <th data-bbox="322 1327 577 1362">Technique</th> <th data-bbox="577 1327 1021 1362">Description</th> <th data-bbox="1021 1327 1496 1362">Applicability</th> </tr> </thead> <tbody> </tbody> </table>	Technique	Description	Applicability	CC	<p>The Operator confirms that both boilers use control systems through their local control panels,</p>																																																												
Technique	Description	Applicability																																																																

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	a. Air and/or fuel staging	See descriptions in Section 8.3. Air staging is often associated with low-NO _x burners	Generally applicable		(Technique d). The package boiler, PB1, has also been fitted with Low-NOX burners (Technique c).
b. Flue-gas recirculation	See description in Section 8.3				
c. Low-NO _x burners (LNB)					
d. Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system			
e. Reduction of the combustion air temperature	See description in Section 8.3	Generally applicable within the constraints associated with the process needs			
f. Selective non-catalytic reduction (SNCR)		Not applicable to combustion plants operated < 500 h/yr with highly variable boiler loads. The applicability may be limited in the case of combustion plants operated between 500 h/yr and 1 500 h/yr with highly variable boiler loads			
g. Selective catalytic reduction (SCR)		Not applicable to combustion plants operated < 500 h/yr. Not generally applicable to combustion plants of < 100 MW _{th} . There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr			
42	In order to prevent or reduce NO _x emissions to air from the combustion of natural gas in gas turbines, BAT is to use one or a combination of the techniques given below.			CC	Gas turbine has been upgraded to include dry low NOx burners. Computerised control of the main combustion parameters enables the combustion efficiency to be improved. The GT was also fitted with a new local control panel in 2017 as part of the engine
	Technique	Description	Applicability		
a.	Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system		
b.	Water/steam addition	See description in Section 8.3	The applicability may be limited due to water availability		

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	c.	Dry low-NO _x burners (DLN)		The applicability may be limited in the case of turbines where a retrofit package is not available or when water/steam addition systems are installed	<p>upgrade. The GT Siemens HMI controls the GT output on Tmax (temperature control) and adjusts the fuel /air ratio to give optimum performance in terms of electrical output and emissions.</p> <p>DLN effective criteria (applicable to all configurations when the gas turbine is running): GT full load is 6.7MWe GT DLN is applicable to GT load at 70-100% MCR.</p>
d.	Low-load design concept	Adaptation of the process control and related equipment to maintain good combustion efficiency when the demand in energy varies, e.g. by improving the inlet airflow control capability or by splitting the combustion process into decoupled combustion stages	The applicability may be limited by the gas turbine design		
e.	Low-NO _x burners (LNB)	See description in Section 8.3	Generally applicable to supplementary firing for heat recovery steam generators (HRSGs) in the case of combined-cycle gas turbine (CCGT) combustion plants		
f.	Selective catalytic reduction (SCR)		Not applicable in the case of combustion plants operated < 500 h/yr. Not generally applicable to existing combustion plants of < 100 MW _{th} . Retrofitting existing combustion plants may be constrained by the availability of sufficient space. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr		
43	In order to prevent or reduce NO _x emissions to air from the combustion of natural gas in engines, BAT is to use one or a combination of the techniques given below.			NA	Not applicable to gas turbines or boilers.
	Technique	Description	Applicability		
a.	Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system		
b.	Lean-burn concept	See description in Section 8.3. Generally used in combination with SCR	Only applicable to new gas-fired engines		
c.	Advanced lean-burn concept	See descriptions in Section 8.3	Only applicable to new spark plug ignited engines		

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																																												
	d. Selective catalytic reduction (SCR)		Retrofitting existing combustion plants may be constrained by the availability of sufficient space. Not applicable to combustion plants operated < 500 h/yr. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr																																														
44	<p>In order to prevent or reduce CO emissions to air from the combustion of natural gas, BAT is to ensure optimised combustion and/or to use oxidation catalysts.</p> <p>Description - See descriptions in Section 8.3.</p> <p>BAT-associated emission levels (BAT-AELs) for NO_x emissions to air from the combustion of natural gas in gas turbines</p>			CC	<p>The combustion process is optimised for all 3 combustion plants through their dedicated local control panel.</p> <p>The GT Siemens HMI controls the GT output on Tmax (temperature control) and adjusts the fuel /air ratio to give optimum performance in terms of electrical output and emissions.</p> <p>PB1 has a Scanview Burner Management System installed which monitors and controls the fuel/air ratio in the boiler to adjust firing rates.</p> <p>WHRB is controlled via a three term controller which optimises the combustion process by controlling the firing rate of the boiler. However, the WHRB is an older plant which was installed in 1996 and was not specifically designed to meet the current CO emission level, in particular the indicative yearly average</p>																																												
<table border="1"> <thead> <tr> <th data-bbox="324 726 786 847" rowspan="2">Type of combustion plant</th> <th data-bbox="792 726 1025 847" rowspan="2">Combustion plant total rated thermal input (MW_{th})</th> <th colspan="2" data-bbox="1032 726 1487 759">BAT-AELs (mg/Nm³) ⁽¹⁴²⁾ ⁽¹⁴³⁾</th> </tr> <tr> <th data-bbox="1032 764 1249 847">Yearly average ⁽¹⁴⁴⁾ ⁽¹⁴⁵⁾</th> <th data-bbox="1256 764 1487 847">Daily average or average over the sampling period</th> </tr> </thead> <tbody> <tr> <td colspan="4" data-bbox="324 852 1487 885" style="text-align: center;">Open-cycle gas turbines (OCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁷⁾</td> </tr> <tr> <td data-bbox="324 890 786 924">New OCGT</td> <td data-bbox="792 890 1025 924">≥ 50</td> <td data-bbox="1032 890 1249 924">15–35</td> <td data-bbox="1256 890 1487 924">25–50</td> </tr> <tr> <td data-bbox="324 928 786 1007">Existing OCGT (excluding turbines for mechanical drive applications) — All but plants operated < 500 h/yr</td> <td data-bbox="792 928 1025 1007">≥ 50</td> <td data-bbox="1032 928 1249 1007">15–50</td> <td data-bbox="1256 928 1487 1007">25–55 ⁽¹⁴⁸⁾</td> </tr> <tr> <td colspan="4" data-bbox="324 1011 1487 1045" style="text-align: center;">Combined-cycle gas turbines (CCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁹⁾</td> </tr> <tr> <td data-bbox="324 1050 786 1083">New CCGT</td> <td data-bbox="792 1050 1025 1083">≥ 50</td> <td data-bbox="1032 1050 1249 1083">10–30</td> <td data-bbox="1256 1050 1487 1083">15–40</td> </tr> <tr> <td data-bbox="324 1088 786 1147">Existing CCGT with a net total fuel utilisation of < 75 %</td> <td data-bbox="792 1088 1025 1147">≥ 600</td> <td data-bbox="1032 1088 1249 1147">10–40</td> <td data-bbox="1256 1088 1487 1147">18–50</td> </tr> <tr> <td data-bbox="324 1152 786 1211">Existing CCGT with a net total fuel utilisation of ≥ 75 %</td> <td data-bbox="792 1152 1025 1211">≥ 600</td> <td data-bbox="1032 1152 1249 1211">10–50</td> <td data-bbox="1256 1152 1487 1211">18–55 ⁽¹⁵⁰⁾</td> </tr> <tr> <td data-bbox="324 1216 786 1275">Existing CCGT with a net total fuel utilisation of < 75 %</td> <td data-bbox="792 1216 1025 1275">50–600</td> <td data-bbox="1032 1216 1249 1275">10–45</td> <td data-bbox="1256 1216 1487 1275">35–55</td> </tr> <tr> <td data-bbox="324 1279 786 1339">Existing CCGT with a net total fuel utilisation of ≥ 75 %</td> <td data-bbox="792 1279 1025 1339">50–600</td> <td data-bbox="1032 1279 1249 1339">25–50 ⁽¹⁵¹⁾</td> <td data-bbox="1256 1279 1487 1339">35–55 ⁽¹⁵²⁾</td> </tr> <tr> <td colspan="4" data-bbox="324 1343 1487 1375" style="text-align: center;">Open- and combined-cycle gas turbines</td> </tr> </tbody> </table>				Type of combustion plant	Combustion plant total rated thermal input (MW _{th})	BAT-AELs (mg/Nm ³) ⁽¹⁴²⁾ ⁽¹⁴³⁾		Yearly average ⁽¹⁴⁴⁾ ⁽¹⁴⁵⁾	Daily average or average over the sampling period	Open-cycle gas turbines (OCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁷⁾				New OCGT	≥ 50	15–35	25–50	Existing OCGT (excluding turbines for mechanical drive applications) — All but plants operated < 500 h/yr	≥ 50	15–50	25–55 ⁽¹⁴⁸⁾	Combined-cycle gas turbines (CCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁹⁾				New CCGT	≥ 50	10–30	15–40	Existing CCGT with a net total fuel utilisation of < 75 %	≥ 600	10–40	18–50	Existing CCGT with a net total fuel utilisation of ≥ 75 %	≥ 600	10–50	18–55 ⁽¹⁵⁰⁾	Existing CCGT with a net total fuel utilisation of < 75 %	50–600	10–45	35–55	Existing CCGT with a net total fuel utilisation of ≥ 75 %	50–600	25–50 ⁽¹⁵¹⁾	35–55 ⁽¹⁵²⁾	Open- and combined-cycle gas turbines			
Type of combustion plant	Combustion plant total rated thermal input (MW _{th})	BAT-AELs (mg/Nm ³) ⁽¹⁴²⁾ ⁽¹⁴³⁾																																															
		Yearly average ⁽¹⁴⁴⁾ ⁽¹⁴⁵⁾	Daily average or average over the sampling period																																														
Open-cycle gas turbines (OCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁷⁾																																																	
New OCGT	≥ 50	15–35	25–50																																														
Existing OCGT (excluding turbines for mechanical drive applications) — All but plants operated < 500 h/yr	≥ 50	15–50	25–55 ⁽¹⁴⁸⁾																																														
Combined-cycle gas turbines (CCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁹⁾																																																	
New CCGT	≥ 50	10–30	15–40																																														
Existing CCGT with a net total fuel utilisation of < 75 %	≥ 600	10–40	18–50																																														
Existing CCGT with a net total fuel utilisation of ≥ 75 %	≥ 600	10–50	18–55 ⁽¹⁵⁰⁾																																														
Existing CCGT with a net total fuel utilisation of < 75 %	50–600	10–45	35–55																																														
Existing CCGT with a net total fuel utilisation of ≥ 75 %	50–600	25–50 ⁽¹⁵¹⁾	35–55 ⁽¹⁵²⁾																																														
Open- and combined-cycle gas turbines																																																	

BAT Concn. Number	Summary of BAT Conclusion requirement				Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																							
	Gas turbine put into operation no later than 27 November 2003, or existing gas turbine for emergency use and operated < 500 h/yr	≥ 50	No BAT-AEL	60–140 ⁽¹⁵³⁾ ⁽¹⁵⁴⁾		<p>emission level. We have included an improvement condition (IC15) specifying that the Operator is required to propose an achievable emission limit for carbon monoxide expressed as an annual mean of validated hourly averages. If the proposed ELV deviates from the indicative BAT AEL for CO of 30mg/m³ then an associated BAT justification shall be submitted.</p> <p>See 4.1 of the key issues section for further information on the limits set within the permit.</p>																							
Existing gas turbine for mechanical drive applications — All but plants operated < 500 h/yr	≥ 50	15–50 ⁽¹⁵⁵⁾	25–55 ⁽¹⁵⁶⁾																										
<p>As an indication, the yearly average CO emission levels for each type of existing combustion plant operated ≥ 1 500 h/yr and for each type of new combustion plant will generally be as follows:</p>																													
<ul style="list-style-type: none"> — New OCGT of ≥ 50 MW_{th}: < 5–40 mg/Nm³. For plants with a net electrical efficiency (EE) greater than 39 %, a correction factor may be applied to the higher end of this range, corresponding to [higher end] × EE/39, where EE is the net electrical energy efficiency or net mechanical energy efficiency of the plant determined at ISO baseload conditions. — Existing OCGT of ≥ 50 MW_{th} (excluding turbines for mechanical drive applications): < 5–40 mg/Nm³. The higher end of this range will generally be 80 mg/Nm³ in the case of existing plants that cannot be fitted with dry techniques for NO_x reduction, or 50 mg/Nm³ for plants that operate at low load. — New CCGT of ≥ 50 MW_{th}: < 5–30 mg/Nm³. For plants with a net electrical efficiency (EE) greater than 55 %, a correction factor may be applied to the higher end of the range, corresponding to [higher end] × EE/55, where EE is the net electrical energy efficiency of the plant determined at ISO baseload conditions. — Existing CCGT of ≥ 50 MW_{th}: < 5–30 mg/Nm³. The higher end of this range will generally be 50 mg/Nm³ for plants that operate at low load. — Existing gas turbines of ≥ 50 MW_{th} for mechanical drive applications: < 5–40 mg/Nm³. The higher end of the range will generally be 50 mg/Nm³ when plants operate at low load. <p>In the case of a gas turbine equipped with DLN burners, these indicative levels correspond to when the DLN operation is effective.</p> <p>BAT-associated emission levels (BAT-AELs) for NO_x emissions to air from the combustion of natural gas in boilers and engines</p> <table border="1" data-bbox="315 1102 1494 1326"> <thead> <tr> <th rowspan="3">Type of combustion plant</th> <th colspan="4">BAT-AELs (mg/Nm³)</th> </tr> <tr> <th colspan="2">Yearly average ⁽¹⁵⁷⁾</th> <th colspan="2">Daily average or average over the sampling period</th> </tr> <tr> <th>New plant</th> <th>Existing plant ⁽¹⁵⁸⁾</th> <th>New plant</th> <th>Existing plant ⁽¹⁵⁹⁾</th> </tr> </thead> <tbody> <tr> <td>Boiler</td> <td>10–60</td> <td>50–100</td> <td>30–85</td> <td>85–110</td> </tr> <tr> <td>Engine ⁽¹⁶⁰⁾</td> <td>20–75</td> <td>20–100</td> <td>55–85</td> <td>55–110 ⁽¹⁶¹⁾</td> </tr> </tbody> </table> <p>As an indication, the yearly average CO emission levels will generally be:</p>							Type of combustion plant	BAT-AELs (mg/Nm ³)				Yearly average ⁽¹⁵⁷⁾		Daily average or average over the sampling period		New plant	Existing plant ⁽¹⁵⁸⁾	New plant	Existing plant ⁽¹⁵⁹⁾	Boiler	10–60	50–100	30–85	85–110	Engine ⁽¹⁶⁰⁾	20–75	20–100	55–85	55–110 ⁽¹⁶¹⁾
Type of combustion plant	BAT-AELs (mg/Nm ³)																												
	Yearly average ⁽¹⁵⁷⁾		Daily average or average over the sampling period																										
	New plant	Existing plant ⁽¹⁵⁸⁾	New plant	Existing plant ⁽¹⁵⁹⁾																									
Boiler	10–60	50–100	30–85	85–110																									
Engine ⁽¹⁶⁰⁾	20–75	20–100	55–85	55–110 ⁽¹⁶¹⁾																									

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	<ul style="list-style-type: none"> — < 5–40 mg/Nm³ for existing boilers operated ≥ 1 500 h/yr, — < 5–15 mg/Nm³ for new boilers, — 30–100 mg/Nm³ for existing engines operated ≥ 1 500 h/yr and for new engines. 		

6. Emissions to Water

The consolidated permit incorporates the current discharge to controlled waters, described in the permit as minor release points as identified in H/A1/152879 sheet 6 emissions to Fenay Beck.

There are no BAT AELs specified in the BAT Conclusions for this type of plant. There are also no additional treatment options identified as BAT for the installation. We have therefore not carried out any additional assessment of the emissions to water as part of this review.

8 Additional IED Chapter II requirements:

There are no additional IED Chapter II requirements addressed through the permit review.

9 Review and assessment of changes that are not part of the BAT Conclusions derived permit review.

This document should be read in conjunction with the application, supporting information and notice.

Aspect considered	Decision
Receipt of application	
Confidential information	A claim for commercial or industrial confidentiality has not been made.
Identifying confidential information	We have not identified information provided as part of the application that we consider to be confidential.
The site	
Biodiversity, heritage, landscape and nature conservation	The application is not within the relevant distance criteria of a site of heritage, landscape or nature conservation, and/or protected species or habitat.
Operating techniques	
General operating techniques	<p>We have reviewed the techniques used by the operator where they are relevant to the BAT Conclusions and compared these with the relevant guidance notes.</p> <p>The permit conditions ensure compliance with the relevant BREF, BAT Conclusions. The ELVs deliver compliance with the BAT-AELs.</p>
Permit conditions	
Updating permit conditions during consolidation	We have updated permit conditions to those in the current generic permit template as part of permit consolidation. The conditions will provide at least the same level of protection as those in the previous permit and in some cases will provide a higher level of protection to those in the previous permit.
Changes to the permit conditions due to an Environment Agency initiated variation	We have varied the permit as stated in the variation notice.
Improvement programme	<p>Based on the information on the application, we consider that we need to impose an improvement programme.</p> <p>We have imposed an improvement condition (IC14) to ensure that the operator will have a plan in place to ensure that the fuel is characterised in line with BAT 9.</p>

Aspect considered	Decision
	<p>We have included an improvement condition (IC15) specifying that the Operator is required to propose an achievable emission limit for carbon monoxide expressed as an annual mean of validated hourly averages</p> <p>We have also removed the completed improvement conditions from the permit.</p>
Emission limits	<p>We have decided that emission limits should be set for the parameters listed in the permit.</p> <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p> <p>It is considered that the ELVs/equivalent parameters or technical measures described above will ensure that significant pollution of the environment is prevented and a high level of protection for the environment is secured.</p>
Monitoring	<p>We have decided that monitoring should be carried out for the parameters listed in the permit, using the methods detailed and to the frequencies specified.</p> <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p> <p>Table S3.4 Process monitoring requirements was amended to include the requirement to monitor energy efficiency after overhauls on site in line with BAT2.</p>
Reporting	<p>We have specified reporting in the permit for the following parameters:</p> <ul style="list-style-type: none"> • Nitrogen dioxide • Carbon monoxide • Sulphur dioxide • Dust <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p>
Operator competence	
Management system	There is no known reason to consider that the operator will not have the management system to enable it to comply with the permit conditions.
Growth Duty	
Section 108 Deregulation Act 2015 – Growth duty	<p>We have considered our duty to have regard to the desirability of promoting economic growth set out in section 108(1) of the Deregulation Act 2015 and the guidance issued under section 110 of that Act in deciding whether to grant this permit.</p> <p>Paragraph 1.3 of the guidance says:</p>

Aspect considered	Decision
	<p>“The primary role of regulators, in delivering regulation, is to achieve the regulatory outcomes for which they are responsible. For a number of regulators, these regulatory outcomes include an explicit reference to development or growth. The growth duty establishes economic growth as a factor that all specified regulators should have regard to, alongside the delivery of the protections set out in the relevant legislation.”</p> <p>We have addressed the legislative requirements and environmental standards to be set for this operation in the body of the decision document above. The guidance is clear at paragraph 1.5 that the growth duty does not legitimise non-compliance and its purpose is not to achieve or pursue economic growth at the expense of necessary protections.</p> <p>We consider the requirements and standards we have set in this permit are reasonable and necessary to avoid a risk of an unacceptable level of pollution. This also promotes growth amongst legitimate operators because the standards applied to the operator are consistent across businesses in this sector and have been set to achieve the required legislative standards.</p>