

## **Construction noise and vibration Monthly Report – November 2021**

**Warwick District Council**

<b>Non-Technical Summary</b>	<b>1</b>
<b>Abbreviations and Descriptions</b>	<b>3</b>
<b>1 Introduction</b>	<b>4</b>
1.2 Measurement Locations	6
<b>2 Summary of Results</b>	<b>8</b>
2.1 Summary of Measured Noise and Vibration Levels	8
2.2 Exceedances of the LOAEL and SOAEL	11
2.3 Exceedances of Trigger Level	15
2.4 Complaints	15
<b>Appendix A Site Locations</b>	<b>16</b>
<b>Appendix B Monitoring Locations</b>	<b>23</b>
<b>Appendix C Data</b>	<b>29</b>
<b>List of tables</b>	
Table 1: Table of Abbreviations	3
Table 2: Monitoring Locations	6
Table 3: Summary of Measured dB $L_{Aeq}$ Data over the Monitoring Period	9
Table 4: Summary of Exceedances of LOAEL and SOAEL	12
Table 5: Summary of Exceedances of Trigger Levels	15
Table 6: Summary of Complaints	15

# Non-Technical Summary

This Noise and Vibration Monitoring Report fulfils HS2 Limited's commitment detailed in the Environmental Minimum Requirements (EMRs), Annex 1, Code of Construction Practice, to present the results of noise and vibration monitoring carried out within Warwick District Council (WDC) area during the month of November 2021.

Within this period monitoring was undertaken at the following worksites:

- Noise monitoring were undertaken at the Burton Green Tunnel worksite (ref.: BGT), where work activities included excavation works.
- Noise monitoring was undertaken at Bockenden Cutting (ref.: BC), where work activities included drainage installations.
- Noise monitoring was undertaken at the A429 Kenilworth Road Overbridge (ref.: A429KRO), where work activities included stockpile management, silt and site traffic management.
- Noise monitoring was undertaken at the A46 Compound (ref.: A46C), where work activities included bellmouth construction, installation of transition slabs, construction for lay-down area and excavation of haul road.
- Noise monitoring was undertaken at the Stoneleigh Park (ref.: SP), where work activities included hoarding installation.
- Noise monitoring was undertaken at the Cubbington Road (ref.: CR), where work activities included drainage installation and vegetation clearance.
- Noise monitoring was undertaken at Fosseway Diversion (ref.: FD), where work activities included roadworks and utility works.
- Noise monitoring was undertaken at Offchurch Cutting (ref.: OC), where work activities included:
  - In the Valley Field area: Pond and fencing construction, temporary drainage construction, filling of embankment earthworks, boundary fencing installation and construction of road tie-in.
  - in the Offchurch Cutting central area: Road construction works, draining of reservoir, earthworks at reservoir, cutting of temporary ramp and ground investigation which included boreholes and trial pits.
  - In the Welsh Road area: Earthworks, conveyor belt construction and road widening.

Further works, where monitoring did not take place, were also undertaken at:

- Burton Green, as part of water utility works.
- Burton Green, as part of power utility works.

There were two exceedances of the HS2 threshold levels for significant noise impacts, which are defined in Information Paper E23 (<https://www.gov.uk/government/publications/hs2-information-papers-environment>), during the reporting period.

There were no exceedances of trigger levels as defined in Section 61 consents during the reporting period at any monitoring position.

Two complaint was received during the monitoring period. A description of the complaint, the results of investigations and any actions taken are detailed in Table 7 of this report.

# Abbreviations and Descriptions

The abbreviations, descriptions and project terminology used within this report can be found in Table 1.

Table 1: Table of Abbreviations

Acronym/Term	Definition
$L_{Aeq,T}$	See equivalent continuous sound pressure level
Ambient sound	A description of the all-encompassing sound at a given location and time which will include sound from many sources near and far. Ambient sound can be quantified in terms of the equivalent continuous sound pressure level, $L_{pAeq,T}$
Decibel(s), or dB	Between the quietest audible sound and the loudest tolerable sound there is a million to one ratio in sound pressure (measured in Pascal (Pa)). Because of this wide range, a level scale called the decibel (dB) scale, based on a logarithmic ratio, is used in sound measurement. Audibility of sound covers a range of approximately 0-140dB.
Decibel(s) A-weighted, or dB(A)	The human ear system does not respond uniformly to sound across the detectable frequency range and consequently instrumentation used to measure sound is weighted to represent the performance of the ear. This is known as the 'A weighting' and is written as 'dB(A)'.
Equivalent continuous sound pressure level, or $L_{Aeq,T}$	An index used internationally for the assessment of environmental sound impacts. It is defined as the notional unchanging level that would, over a given period of time (T), deliver the same sound energy as the actual time-varying sound over the same period. Hence fluctuating sound levels can be described in terms of an equivalent single figure value, typically expressed as a decibel level.
Exclusion of data	Measurement of noise levels can be affected by weather conditions such as prolonged periods of rain, winds speeds higher than 5m/s and snow/ice ground cover. Noise levels measured during these periods are considered not representative of normal noise conditions at the site and, for the purposes of this report, are excluded from the assessment of exceedances and calculation of typical noise levels and are also greyed out in charts. Identifiable incongruous noise and vibration events not attributable to HS2 construction noise are also excluded.
Façade	A facade noise level is the noise level 1m in front of a large reflecting surface. The effect of reflection, is to produce a slightly higher (typically +2.5 to +3 dB) sound level than it would be if the reflecting surface was not there.
Free-field	A free-field noise level is the noise level measured at a location where no reflective surfaces, other than the ground, lies within 3.5 metres of the microphone position.
LOAEL	Lowest Observed Adverse Effect Level - the level above which adverse effects on health and quality of life can be detected.
Peak particle velocity, or PPV	Instantaneous maximum velocity reached by a vibrating element as it oscillates about its rest position. The PPV is a simple indicator of perceptibility and risk of damage to structures due to vibration. It is usually measured in mm/s.
SOAEL	Significant Observed Adverse Effect Level - the level above which significant adverse effects on health and quality of life occur.
Sound pressure level	The parameter by which sound levels are measured in air. It is measured in decibels. The threshold of hearing has been set at 0dB, while the threshold of pain is approximately 120dB. Normal speech is approximately 60dB at a distance of 1 metre and a change of 3dB in a time varying sound signal is commonly regarded as being just detectable. A change of 10dB is subjectively twice, or half, as loud.
Vibration dose value, or VDV	An index used to evaluate human exposure to vibration in buildings. While the PPV provides information regarding the magnitude of single vibration events, the VDV provides a measure of the total vibration experienced over a specified period of time (typically 16h daytime and 8h night-time). It takes into account the magnitude, the number and the duration of vibration events and can be used to quantify exposure to continuous, impulsive, occasional and intermittent vibration. The vibration dose value is measured in $m/s^{1.75}$ .

# 1 Introduction

1.1.1 HS2 is required to undertake noise (and vibration) monitoring as necessary to comply with the requirements of the High Speed Rail (London-West Midlands) Environmental Minimum Requirements, including specifically Annex 1: Code of Construction Practice, in addition to any monitoring requirements arising from conditions imposed through consents under Section 61 of the Control of Pollution Act, 1974 or through Undertakings & Assurances given to third parties. Such monitoring may be undertaken for the following purposes:

- monitoring the impact of construction works;
- to investigate complaints, incidents and exceedance of trigger levels; or
- monitoring the effectiveness of noise and vibration control measures.

1.1.2 Monitoring data and interpretive reports are to be provided to each relevant local authority on a monthly basis and shall include a summary of the construction activities occurring, the data recorded over the monitoring period, any complaints received, any periods in exceedance of agreed trigger levels, the results of any investigations and any actions taken or mitigation measures implemented. This report provides noise data, and interpretation thereof, for monitoring carried out by HS2 within the Warwick District Council (WDC) area for the period 1<sup>st</sup> to 30<sup>th</sup> November 2021.

1.1.3 Construction sites in the local authority area where monitoring was undertaken during this period include:

- Burton Green Tunnel worksite (ref.: BGT, see plan 1 in Appendix A), where work activities included:
  - excavation works.
- Bockenden Cutting (ref.: BC, see plan 1 in Appendix A), where work activities included:
  - drainage installations.
- A429 Kenilworth Road Overbridge (ref.: A429KRO, see plan 2 in Appendix A), where work activities included:
  - stockpile management works; and
  - silt and site traffic management.
- A46 Compound, (ref.: A429KRO, see plan 3 in Appendix A), where work activities included:
  - construction of road tie-in;

- installation of transition slabs;
- construction for lay-down area; and
- excavation of haul road.
- Stoneleigh Park, (ref.: A429KRO, see plan 3 in Appendix A), where work activities included:
  - hoarding installation.
- Cubbington Road (ref.: CR, see plan 4 in Appendix B), where work activities included:
  - temporary drainage installation; and
  - vegetation clearance.
- Fosseway Diversion (ref.: FD, see plan 5 in Appendix A), where work activities included:
  - works on the Southern Roundabout;
  - tie-in of Welsh Road with Roundabout; and
  - utility works along Welsh Road .
- Offchurch Cutting worksite (ref.: OC, see plan 5 in Appendix A), where work activities included:
  - In the Valley Field area:
    - pond and fencing construction;
    - temporary drainage construction;
    - filling of embankment earthworks;
    - boundary fencing installation; and
    - construction of road tie-in.
  - In the Offchurch Cutting centra area :
    - road construction works;
    - draining of reservoir;
    - earthworks at reservoir and cutting of temporary ramp; and
    - ground investigation which included boreholes and trial pits.
  - In the Welsh Road area:
    - earthworks for formation of landscape embankment;

- conveyor belt construction; and
- road widening on Welsh Road.

1.1.4 Further works, where monitoring did not take place, were also undertaken at:

- Burton Green, as part of water utility works.
- Burton Green, as part of power utility works.

1.1.5 The applicable standards, guidance, and monitoring methodology is outlined in the construction noise and vibration monitoring methodology report which can be found at the following location

<https://www.gov.uk/government/collections/monitoring-the-environmental-effects-of-hs2>. Noise and vibration monitoring reports for previous months can also be found at this location.

## 1.2 Measurement Locations

1.2.1 Fourteen (14) noise monitoring installations were active in November in the WDC area. Table 2 summarises the position of the noise monitoring installations within the WDC area in November 2021.

1.2.2 A new noise monitor (ref.: OC-N3) at worksite Offchurch Cutting (ref.: OC) was installed in the WDC area on 18<sup>th</sup> of November 2021.

1.2.3 A noise monitor (ref.:BGT-N1) at worksite Burton Green Tunnel (ref.: BGT) was relocated to be 15 metres west of previous location on 4<sup>th</sup> of November 2021.

1.2.4 Maps showing the position of the noise and vibration monitoring installations are presented in Appendix B.

Table 2: Monitoring Locations

Worksite Reference	Measurement Reference	Address
Burton Green Tunnel (BGT)	BGT-N1	301 Cromwell Lane, Burton Green, Warwick, Warwickshire
	BGT-N2	Broadwell Woods Caravan Park, Red Lane, Burton Green, Warwick, Warwickshire
Bockenden Cutting (BC)	BC-N1	Thistle Estate, Red Lane, Burton Green, Warwick, Warwickshire
A429 Kenilworth Road Overbridge (A429KRO)	A429KRO-N1	Millburn Grange, Coventry Road, Kenilworth
	A429KRO-N2	Brookview, Milburn Grange, Coventry Road, Kenilworth
	A429KRO-N3	16 Kenilworth Road, Kenilworth



<b>Worksite Reference</b>	<b>Measurement Reference</b>	<b>Address</b>
A46 Compound (A46C)	A46C-N1	Kingswood Farmhouse, Dalehouse Lane, Kenilwort
Stoneleigh Park (SP)	SP-N2	Stoneleigh Park, Kenilworth
Cubbington (CR)	CR-N1	Wychwood, Cubbington Road, Leamington Spa
Fosseway Diversion (FD)	FD-N1	Burnt Heath Cottages Long Itchington Rd, Offchurch, Leamington Spa
	FD-N2	Spring Hill Cottages Fosseway, Offchurch, Leamington Spa
Offchurch Cutting (OC)	OC-N1	Welsh Road, Offchurch, Leamington
	OC-N2	Valley Fields, Offchurch, Leamington Spa
	OC-N3	Brickyard Cottage, Welsh Road, Offchurch, Warwick

## 2 Summary of Results

### 2.1 Summary of Measured Noise and Vibration Levels

2.1.1 Table 3 presents a summary of the measured noise levels at each monitoring location over the reporting period. The  $L_{Aeq,T}$  is presented for each of the relevant time periods averaged over the calendar month, along with the highest single period  $L_{Aeq,T}$  that was found to occur within the month.

Table 3: Summary of Measured dB L<sub>Aeq</sub> Data over the Monitoring Period

Worksite Reference	Measurement Reference	Site Address	Free-field or Façade Measurement	Weekday Average L <sub>Aeq,T</sub> (highest day L <sub>Aeq,T</sub> )					Saturday Average L <sub>Aeq,T</sub> (highest day L <sub>Aeq,T</sub> )					Sunday / Public Holiday Average L <sub>Aeq,T</sub> (highest day L <sub>Aeq,T</sub> )	
				0700 - 0800	0800 - 1800	1800 - 1900	1900 - 2200	2200 - 0700	0700 - 0800	0800 - 1300	1300 - 1400	1400 - 2200	2200 - 0700	0700 - 2200	2200 - 0700
BGT	BGT-N1	301 Cromwell Lane, Burton Green, Warwick, Warwickshire	Free-field	44.9 (47.3)	53.5 (65.7)	42.5 (46.1)	41.5 (56.4)	36.6 (50.1)	41.6 (42.1)	51.8 (56.8)	54.6 (62.7)	51.1 (61.1)	42.5 (53.0)	45.0 (62.1)	37.6 (47.5)
	BGT-N2	Broadwell Woods Caravan Park, Red Lane, Burton Green, Warwick, Warwickshire	Free-field	44.6 (48.3)	53.1 (58.0)	42.8 (48.4)	41.3 (60.8)	37.8 (58.1)	41.7 (48.4)	48.8 (52.6)	47.2 (54.6)	45.0 (55.9)	37.5 (45.9)	43.8 (59.2)	35.5 (47.2)
BC	BC-N1	Thistle Estate, Red Lane, Burton Green, Warwick, Warwickshire	Free-field	43.6 (49.2)	47.2 (54.5)	38.9 (43.6)	39.6 (49.4)	37.9 (57.5)	42.7 (52.1)	45.1 (54.6)	46.1 (56.1)	49.8 (60.7)	41.4 (48.3)	41.9 (53.1)	35.8 (43.2)
A429KRO	A429KRO-N1	Millburn Grange, Coventry Road, Kenilworth	Free-field	51.5 (55.7)	54.6 (57.3)	52.5 (58.3)	52.1 (59.0)	49.6 (58.3)	50.3 (50.5)	51.4 (52.5)	52.0 (52.1)	53.7 (65.1)	41.9 (51.9)	52.3 (57.2)	47.7 (56.5)
	A429KRO-N2	Brookview, Milburn Grange, Coventry Road, Kenilworth	Free-field	51.3 (54.1)	53.7 (57.4)	50.7 (60.0)	49.5 (60.1)	45.9 (52.8)	47.6 (48.9)	50.3 (50.8)	49.9 (50.8)	50.3 (57.1)	43.8 (49.2)	50.2 (54.7)	44.8 (53.2)
	A429KRO-N3	16 Kenilworth Road, Kenilworth	Free-field	57.5 (58.7)	57.9 (60.0)	56.9 (60.6)	54.6 (60.4)	48.4 (55.5)	51.7 (51.9)	56.0 (56.2)	55.8 (55.9)	55.0 (57.0)	48.3 (53.2)	55.3 (60.5)	47.3 (53.5)
A46C	A46C-N1	Kingswood Farmhouse, Dalehouse Lane, Kenilworth	Free-field	59.9 (65.5)	58.5 (62.8)	58.7 (61.9)	56.8 (60.8)	54.3 (63.2)	55.0 (57.6)	56.7 (59.6)	55.0 (57.5)	55.7 (59.7)	47.1 (52.3)	53.3 (56.6)	52.2 (63.2)

OFFICIAL

Worksite Reference	Measurement Reference	Site Address	Free-field or Façade Measurement	Weekday Average $L_{Aeq,T}$ (highest day $L_{Aeq,T}$ )					Saturday Average $L_{Aeq,T}$ (highest day $L_{Aeq,T}$ )					Sunday / Public Holiday Average $L_{Aeq,T}$ (highest day $L_{Aeq,T}$ )	
				0700 - 0800	0800 - 1800	1800 - 1900	1900 - 2200	2200 - 0700	0700 - 0800	0800 - 1300	1300 - 1400	1400 - 2200	2200 - 0700	0700 - 2200	2200 - 0700
SP	SP-N2	Stoneleigh Park, Kenilworth	Free-field	54.3 (59.5)	55.9 (59.5)	50.5 (56.3)	46.0 (55.3)	44.9 (56.1)	46.0 (52.0)	52.3 (55.1)	51.7 (53.0)	49.8 (56.8)	39.9 (45.2)	51.1 (58.0)	44.7 (56.3)
CR	CR-N1	Wychwood, Cubbington Road, Lillington, Leamington Spa	Free field	55.3 (56.9)	56.2 (64.4)	53.9 (55.1)	51.0 (55.3)	44.1 (50.3)	50.2 (50.2)	54.2 (55.1)	54.5 (54.5)	52.2 (54.6)	40.4 (47.7)	49.8 (55.5)	42.2 (48.6)
				(51.9)	(70.3)	(50.0)	(52.7)	(48.5)	(43.8)	(45.2)	(44.1)	(55.8)	(45.0)	(48.0)	(45.7)
FD	FD-N1	Burnt Heath Cottages Long Itchington Rd, Offchurch, Leamington Spa	Free-field	58.5 (61.2)	62.8 (74.0)	56.8 (58.4)	53.6 (58.2)	50.5 (62.7)	54.9 (59.4)	58.9 (61.0)	60.2 (62.6)	57.9 (62.8)	48.3 (54.2)	55.4 (60.7)	48.4 (57.2)
	FD-N2	Spring Hill Cottages Fosseway, Offchurch, Leamington Spa	Free-field	61.0 (71.2)	67.0 (72.1)	64.3 (70.8)	59.2 (76.7)	59.1 (77.1)	60.8 (66.5)	65.3 (68.6)	65.8 (68.7)	63.4 (69.9)	63.1 (82.8)	61.4 (70.0)	52.3 (67.7)
OC	OC-N1	Welsh Road, Offchurch, Leamington	Free-field	46.1	48.2	42.4	40.1	38.0	42.9	45.0	43.8	43.8	35.3	43.7	36.5
	OC-N2	Valley Fields, Hunningham Road, Offchurch, Leamington Spa	Free field	48.2	51.3	43.5	43.3	40.2	43.8	43.9	44.1	47.2	39.7	43.2	41.1
	OC-N3	Brickyard Cottage, Welsh Road, Offchurch, Warwick	Free-field	48.0 (56.1)	53.5 (58.3)	52.1 (55.4)	44.4 (55.5)	42.0 (48.8)	45.4 (45.4)	52.2 (52.2)	52.5 (52.5)	53.1 (57.5)	48.0 (50.2)	46.6 (49.7)	39.1 (44.9)

2.1.2 Appendix C presents graphs of the noise monitoring data over the month for each of the measurement locations. Noise data presented consists of the hourly  $L_{Aeq}$  values and, where relevant, the  $L_{Aeq,T}$  values (where the time period T has been taken to be the averaging period as specified in Table 1 of HS2 Information Paper E23). The full data set for the monitoring equipment can be found at the following location: <https://data.gov.uk/dataset/24542ae7-dd44-444f-b259-871c4cc43b5e/environmental-monitoring-data>.

## 2.2 Exceedances of the LOAEL and SOAEL

2.2.1 The lowest observed adverse effect level (LOAEL) is defined in the Planning Practice Guidance – Noise (PPG) as the level above which "noise starts to cause small changes in behaviour and/or attitude, e.g. turning up volume of television; speaking more loudly; where there is no alternative ventilation, having to close windows for some of the time because of the noise. Potential for some reported sleep disturbance. Affects the acoustic character of the area such that there is a perceived change in the quality of life".

2.2.2 The significant observed adverse effect level (SOAEL) is defined in the 'Planning Practice Guidance – Noise' as the level above which "noise causes a material change in behaviour and/or attitude, e.g. avoiding certain activities during periods of intrusion; where there is no alternative ventilation, having to keep windows closed most of the time because of the noise. Potential for sleep disturbance resulting in difficulty in getting to sleep, premature awakening and difficulty in getting back to sleep. Quality of life diminished due to change in acoustic character of the area."

2.2.3 HS2 Phase One Information Paper E23: Control of Construction Noise and Vibration sets out the LOAELs and SOAELs for construction noise.

2.2.4 Where reported construction noise levels exceed the LOAEL and SOAEL, relevant periods will be identified. Summary statistics to evaluate ongoing qualification for noise insulation and temporary rehousing are also presented where relevant.

2.2.5 Table 4 presents a summary of recorded exceedances of the LOAEL and SOAEL at each measurement location over the reporting period, including the number of exceedances during each time period.

Table 4: Summary of Exceedances of LOAEL and SOAEL

Worksite Reference	Measurement Reference	Site Address	Day (Weekday, Saturday, Sunday, Night)	Time period	Number of exceedances of LOAEL	Number of exceedances of SOAEL
BGT	BGT-N1*	301 Cromwell Lane, Burton Green, Warwick, Warwickshire	Weekday	0800 - 1800	2	No exceedances
	BGT-N2*	Broadwell Woods Caravan Park, Red Lane, Burton Green, Warwick, Warwickshire	All days	All periods	No exceedances	No exceedances
BC	BC-N1*	Thistle Estate, Red Lane, Burton Green, Warwick, Warwickshire	All days	All periods	No exceedances	No exceedances
A429KRO	A429KRO -N1*	Millburn Grange, Coventry Road, Kenilworth	All days	All periods	No exceedances	No exceedances
	A429KRO -N2*	Brookview, Milburn Grange, Coventry Road, Kenilworth	All days	All periods	No exceedances	No exceedances
	A429KRO -N3*	16 Kenilworth Road, Kenilworth	All days	All periods	No exceedances	No exceedances
A46C	A46C-N1	Kingswood Farmhouse, Dalehouse Lane, Kenilworth	All days	All periods	No exceedances	No exceedances
SP	SP-N2	Stoneleigh Park, Kenilworth	All days	All periods	No exceedances	No exceedances
CR	CR-N1	Wychwood, Cubbington Road, Lillington, Leamington Spa	Weekday	0800-1800	1	No exceedances

Worksite Reference	Measurement Reference	Site Address	Day (Weekday, Saturday, Sunday, Night)	Time period	Number of exceedances of LOAEL	Number of exceedances of SOAEL
FD	FD-N1	Burnt Heath Cottages Long Itchington Rd, Offchurch, Leamington Spa	Weekday	0800-1800	10	1
	FD-N2	Spring Hill Cottages Fosse Way, Offchurch, Leamington Spa	Weekday Saturday	0800-1800 0800-1300	19 4	1 No exceedances
OC	OC-N1*	Welsh Road, Offchurch, Leamington,	All days	All periods	No exceedances	No exceedances
	OC-N2*	Valley Fields, Hunningham Road, Offchurch, Leamington Spa	Weekday	0800-1800	1	No exceedances
	OC-N3	Brickyard Cottage, Welsh Road, Offchurch, Warwick	All days	All periods	No exceedances	No exceedances

\* A distance correction has been applied while calculating exceedances of the LOAEL and SOAEL.

2.2.6 Thirty-seven (37) LOAEL exceedances were recorded at the BGT-N1, FD-N1, FD-N2 and OC-N2 worksites during weekday and Saturdays core hour periods during November 2021.

2.2.7 For the purpose of assessing eligibility for noise insulation or temporary rehousing, multiple exceedances of the SOAEL in a 24-hour period would be counted as a single exceedance during that day. Over the reporting period, the overall number of SOAEL exceedances at each measurement location is shown in Table 6 and may be lower than the total sum of individual exceedances reported in Table 5 for each location.

Table 5: Summary of Total Exceedances of SOAEL

Worksite Reference	Measurement Reference	Monitor Address	Total of SOAEL exceedances in the month
FD	FD-N1	Burnt Heath Cottages Long Itchington Rd, Offchurch, Leamington Spa	1
	FD-N2	Spring Hill Cottages Fosse Way, Offchurch, Leamington Spa	2

2.2.8 Two exceedances of the SOAEL at two monitoring locations were recorded due to HS2 construction works during November 2021. The exceedances occurred at:

- Monitoring location FD-N1 during one weekday period due to drainage works happening in close proximity to the monitor;
- Monitoring location FD-N2 during one weekday period and one weekend period due to drainage works happening in close proximity to the monitor.



## 2.3 Exceedances of Trigger Level

2.3.1 Table 6 provides a summary of exceedances of the Section 61 trigger noise levels determined to be due to HS2 related construction noise measured during the reporting period, along with the findings of any investigation.

Table 6: Summary of Exceedances of Trigger Levels

Complaint Reference Number (if applicable)	Worksite Reference	Date and Time Period	Identified Source	Results of Investigation (including noise monitoring results)	Actions Taken
-	-	-	-	-	-


## 2.4 Complaints

2.4.1 Table 7 provides a summary of complaint information related to noise and vibration received during the reporting period, along with the findings of any investigation.

Table 7: Summary of Complaints


Complaint Reference Number	Worksite Reference	Description of Complaint	Results of Investigation	Actions Taken
HS2-21-42955-C	BGT	Complaint regarding noise disturbance, vibration affecting property and dust pollution due to construction works at BGT.	Attempt to get more information from stakeholder regarding the disturbance through voicemail and email was not responded to.	Complaint was closed due to lack of information from the stakeholder. Additional information from stakeholder still invited.
HS2-21-42971-C	BC/BGT	Complaint regarding construction works starting progressively earlier as the days passed.	Beeping noises and flashing lights are needed for safety reasons on site.	Confirmed the results of the investigation and construction core hours with the stakeholder. Explained the likely time and duration of these activities to the stakeholder.


# Appendix A Site Locations





**Legend**


Active Worksites


















# Appendix B Monitoring Locations












# Appendix C Data


## Noise


The following graphs show the hourly measured ambient noise level  $L_{Aeq,1h}$  and, where relevant, the averaged noise level  $L_{Aeq,T}$  values, where the time period T is as specified in Table 1 of HS2 Information Paper E23. Periods with adversely weather affected noise levels are greyed out and have been excluded from the calculation of the  $L_{Aeq,T}$  values in Table 3 of the main report.

### Worksite: BGT - Monitoring Ref: BGT-N1




Note: Missing data between 15:00 and 16:00 on Thursday 4<sup>th</sup> of November was due to equipment being paused for relocation.






Note: Missing data between 05:00 on Saturday 20<sup>th</sup> of November and 12:00 on Sunday 21<sup>st</sup> of November was due to loss of solar power to the equipment.






Note: Missing data throughout the week were due to loss of solar power to the equipment.




Note: Missing data throughout the week were due to loss of solar power to the equipment. To ensure there is no loss of power again batteries have been installed and are replaced frequently.





## Worksite: BGT - Monitoring Ref: BGT-N2






**Worksite: BC - Monitoring Ref: BC-N1**







Note: Missing data throughout the week were due to loss of solar power to the equipment. To ensure there is no loss of power again batteries have been installed and are replaced frequently and solar maintenance is being conducted.



Note: Missing data throughout the week were due to loss of solar power to the equipment.








Note: Missing data between 00:00 and 08:00 on Sunday 28<sup>th</sup> of November was due to loss of solar power to the equipment.




Note: Missing data between 23:00 on Monday 29<sup>th</sup> of November and the end of the month was due to loss of solar power to the equipment.




# Worksite: A429KRO - Monitoring Ref: A429KRO-N1






**Worksite: A429KRO – Monitoring Ref: A429KRO-N2**







Note: Missing data between 05:00 and 10:00 on Sunday 28<sup>th</sup> of November was due to loss of solar power to the equipment.






Note: Missing data between 04:00 on Monday 29<sup>th</sup> of November and 11:00 on Tuesday 30<sup>th</sup> of November was due to loss of solar power to the equipment.




### Worksite: A429KRO - Monitoring Ref: A429KRO-N3













## Worksite: A46C – Monitoring Ref: A46C-N1






**Worksite: SP – Monitoring Ref: SP-N2**










Note: Very high noise level at 20:00 on Tuesday 22<sup>nd</sup> November 2021 was due to an error within the measuring equipment.








**Worksite: CR – Monitoring Ref: CR-N1**






# Worksite: FD – Monitoring Ref: FD-N1









## Worksite: FD - Monitoring Ref: FD-N2
















**Worksite: OC – Monitoring Ref: OC-N1**











**Worksite: OC – Monitoring Ref: OC-N2**





## Worksite: OC – Monitoring Ref: OC-N3



Note: The noise monitor was installed on 18<sup>th</sup> of November 2021.

