

Permitting Decisions- Variation (substantial)

We have decided to grant the variation for Saltfleetby Wellsites operated by Angus Energy Weald Basin No.3 Limited.

The variation number is EPR/BJ3107XB/V002.

The variation is required to install the following equipment at Saltfleetby well-site SFB:

- Gas processing (refining) plant; and
- Power generation equipment comprising four gas engines each at 2.17 MWth, identified as new medium combustion plant (MCP), to provide power to the gas processing plant. A fifth future booster engine of similar size has also been included.

Saltfleetby A and B (SFA and SFB) onshore production well-sites were established in 1999, producing natural gas, water and condensate. A pipeline transported hydrocarbons to the nearby Theddlethorpe Gas Terminal (TGT) for processing. Gas production at the installation was suspended in 2017 due to the closure of TGT.

Operations will be brought back into production status once the additional gas processing plant is installed and commissioned and the new gas export pipeline extension is installed to allow pumping of gas direct to the National Grid Transmission System (NTS).

The gas processing (refining) plant is defined by the following definitions in Part 2, Schedule 1 of the Environmental Permitting Regulations (EPR) 2016:

Section 1.2 Part A(1)(a) - Refining gas where this is likely to involve the use of 1,000 or more tonnes of gas in any 12-month period.

Section 1.2 Part A(1)(e)(i) - The loading, unloading, handling or storage of, or the physical, chemical or thermal treatment of crude oil.

We consider in reaching that decision we have taken into account all relevant considerations and legal requirements and that the permit will ensure that the appropriate level of environmental protection is provided.

Purpose of this document

This decision document provides a record of the decision-making process. It

- highlights key issues in the determination
- summarises the decision making process in the decision considerations section to show how the main relevant factors have been taken into account
- explains why we have also made an Environment Agency initiated variation
- shows how we have considered the consultation responses

Unless the decision document specifies otherwise, we have accepted the applicant's proposals.

Read the permitting decisions in conjunction with the environmental permit and the variation notice.

Key issues of the decision

Noise impact assessment

Noise impact assessment, November 2021

The application contained a noise impact assessment (NIA) which identified local noise-sensitive receptors, potential sources of noise at the proposed plant and noise attenuation measures. Measurements were taken of the prevailing ambient noise levels to produce a baseline noise survey and an assessment was carried out in accordance with BS 4142:2014 to compare the predicted plant rating noise levels with the established background levels.

The Saltfleetby B site is in a rural area, with just a few residential properties and scattered farms in the vicinity. The nearest receptor is Newfoundland on Saddleback Road which is 400 m from the well-site.

The main sources of sound from the operational equipment are anticipated to be:

- Dewpoint control with condensate tower & glycol regeneration;
- Power generation package (x2); and
- Compression package (x3). A third future booster engine has also been included.

Specific sources are anticipated to operate continuously, 24-hours per day 7-days per week, and as such no provision was made for any day/night variation in levels.

The operator has proposed noise mitigation measures to reduce the noise impacts at sensitive receptors. This includes acoustic barriers adjacent to the power generation packages and acoustic enclosures for other plant. The barriers have been included in the model predictions.

The operator concluded that the sound from operation of the specified equipment at the site carries a low risk of adverse or significant impacts on receptors in the surrounding area at all times.

Based upon the information in the application we are not satisfied that the appropriate measures will be in place to prevent or where that is not practicable to minimise noise and vibration and to prevent pollution from noise and vibration outside the site.

The assessment does not include tanker movements, which means that specific sound levels are underestimated at a number of nearby residential receptors. The operator confirmed that tanker movements were not included as these are restricted to removal of condensate or produced water which at a worst case would be a single movement in any one day during daylight hours which should not materially affect the conclusion of the assessment. We agree with this approach.

The assessment has overestimated the level of attenuation provided by the acoustic barriers.

Worst case scenarios have not been taken into account, which require separate assessments for the weekdays and weekends.

We conclude that there is a risk of significant adverse impacts at West Lane in the early morning during the week and the weekend.

Updated noise impact assessment, December 2021

An updated NIA was provided, dated December 2021 (received 17 December 2021). Mitigation is proposed in the form of acoustic barriers up to five metres high (para 6.1.1 of the assessment). Two of which will surround equipment which includes the generators and the gas conditioning plant, partially enclosing the equipment. The third barrier will be on the northeast site boundary. This is shown on drawing number 3793=AEL-PI-LAY-001, revision P3.

We confirmed that the acoustic barriers in the model are five metres above ground level at their location.

The noisiest items of equipment (power generation packages) are to be installed in the central part of the site, with the dewpoint control and compression equipment located in the south-east of the site, both surrounded by noise barriers. The ground flare is located in the north-east of the site surrounded by the perimeter noise barrier.

The assessment concludes that sound from the operation of the specified equipment at this site carries some risk of adverse impacts during the night at three locations along Saddleback Road, but a low risk of significant adverse impacts on receptors in the surrounding area at all times.

In order to avoid an adverse or significant adverse impact from the specific sources during the most sensitive periods (i.e. night-time), the planned mitigation will therefore be designed to achieve at least the predicted acoustic performance, to result in absolute external sound levels at identified receptors of 35 dB or lower.

The site will initially operate with only two compressor packages and only diesel power generators (which are substantially quieter than the fuel gas generators to be introduced later). This is likely to result in notably lower sound levels at the commencement of operations. Sound levels rising to the levels predicted in the NIA in the future will be a perceptually smaller change than their introduction from the existing sound climate.

There is also the opportunity to validate and verify predictions, and to implement additional noise control measures where appropriate, during the initial phase of the site operations where adverse impacts are less likely to occur.

We agree with the conclusions drawn, however these are dependant upon the site layout and proposed equipment sound power levels.

Updated sound power levels, February 2022

Our conclusions above were dependant upon the site layout and proposed equipment sound power levels.

We asked the operator to provide evidence to support the sound power levels stated in table 7 of their updated NIA. They also confirmed that the table 7 sound sources are based on actual proposed plant i.e. they are not indicative.

We concluded that there is a high level of uncertainty surrounding the source sound levels and performance of acoustic enclosures on site.

Updated noise impact assessment, February 2022

An updated NIA was provided, dated February 2022 (received 22 February 2022).

This assessment provides evidence for the sound power levels, performance of the acoustic enclosures and takes account of the changes to the site layout. This assessment supersedes previous assessments.

Mitigation is proposed in the form of three acoustic barriers up to five metres high. One partially enclosing the power generation packages, the second partially enclosing the compression packages and Joule Thomson skid, with the third along portions of the northeast boundaries where required. This was confirmed in para 6.1.1 of the assessment and illustrated as figure 2 (see below).

The assessment concludes that sound from the operation of the specified equipment at this site carries some risk of adverse impacts during the night at three locations along Saddleback Road, but a low risk of significant adverse impacts on receptors in the surrounding area at all times.

In order to avoid an adverse or significant adverse impact from the specific sources during the most sensitive periods (i.e. night-time), the planned mitigation will therefore be designed to achieve at least the predicted acoustic performance, to result in absolute external sound levels at identified receptors of 35 dB or lower.

We confirmed that the acoustic barriers in the model are five metres above ground level at their location. The height and location should be included in the noise management plan (NMP), see below.

Evidence has been provided to support the level of attenuation which will be provided by mufflers and enclosures. The minimum specification of these mitigation measures should be stated within the NMP, see below.

We concluded that the further evidence provided has substantially reduced the level of uncertainty surrounding the sound power levels of the sources on site. However, the compressor sound power level has not been used appropriately within the modelling and we find that there is a risk of significant adverse impacts at nearby residential properties. It is also not clear if any mitigation measures will be applied directly to the compressors.

Updated noise impact assessment, March 2022

An updated NIA was provided, dated 04 March 2022 (received 08 March 2022). This assessment supersedes previous assessments.

This assessment corrects the sound power levels from the compressors and includes the use of an acoustic enclosure surrounding the compressors and associated equipment.

It is proposed to enclose the G3512 compressor packages in a well-sealed enclosure designed and installed by a noise control specialist. Predicted external levels of 71 dB(A) at 1m and 64 dB(A) at 10m from the enclosure façade are identified as the design targets required to be met in order to result in the predicted levels outlined in the NIA. Acoustic performance of this level is considered likely to be feasible but cannot be assessed in full prior to detailed design. Design criteria have been calculated based on modelling predictions.

In addition to the compressor acoustic enclosure, there will be three acoustic barriers up to five metres high:

- Partially enclosing power generation packages;
- Partially enclosing the Joule-Thomson skid;
- Along portions of the north-east boundaries of the site where required.

The NIA confirms that mitigation will be designed and selected to achieve at least the predicted acoustic performance in-situ. Monitoring will be carried out upon installation of equipment to validate and verify these predictions. If it is not achieved then the operator confirms that larger, longer, or more absorptive barrier solutions can be adopted in order to meet the required acoustic performance.

The assessment concludes that sound from the operation of the specified equipment at this site carries some risk of adverse impacts during the night at three locations along Saddleback Road, but a low risk of significant adverse impacts on receptors in the surrounding area at all times.

In order to avoid an adverse or significant adverse impact from the specific sources during the most sensitive periods (i.e. night-time), the planned mitigation will therefore be designed to achieve at least the predicted acoustic performance, to result in absolute external sound levels at identified receptors of 35 dB or lower.

We agree with the conclusions drawn, that there is a risk of adverse impacts during the night at three locations along Saddleback Road. This is based on the design targets for the larger compressor enclosure being met and other mitigation measures are as specified in the NIA.

We confirm that the operator has proposed a large enclosure surrounding the G3512 compressor plant at the south end of the site. This has a design limit of 71 dB at 1 m from the enclosure. The pre-operational condition for a NMP includes this requirement.

Further NIAs have been included as two improvement conditions, to confirm the effectiveness of mitigation measures on site which includes a review of the acoustic design targets and sound reduction indices. These are required for the initial phase and full-scale operations.

Therefore, in line with the Noise Policy Statement for England (NPSE), the site should implement Best Available Techniques (BAT), which means that the level of noise is predicted to be low enough to enable permit determination.


Mitigation measures can only be assessed by monitoring, after operations have begun. We have included improvement conditions requiring NIAs, see above. These will include a comparison between the initial and full-scale operations assessment and the model predictions. The comparison at the initial phase will be an indication of whether noise levels at full-scale are likely to cause pollution beyond the site boundary.

We have also included a pre-operational condition for a NMP to be in place prior to commissioning of the new plant. This condition requires the NMP to include the three five metre high acoustic barriers and acoustic enclosures as noise predictions are based on these (see above). It also includes the required minimum sound reduction indices of the enclosures (for the engines) and muffler (for the exhausts) and the design target for the large enclosure housing the G3512 compressor equipment. The performance of this enclosure will be checked through on site measurements required by the NIA improvement conditions.

The NMP should follow our template guidance at:

<https://defra.sharepoint.com/:w:/s/Community821/EXYMgXx618lBhj5u-e7jo48BWkVs9LodY1gANwZ3oQ4kRg?e=8GeALU&CID=5F79586A-002A-42E6-9F38-C29A713166FF&wdLOR=c518D68D3-8BB7-4D20-B79D-F4C365EAE050>

The modelled barriers in the NIA (all at five metres) are shown as green lines in the drawing below:



Permitting Decisions- Variation (substantial)



Angus En Figure 2: Proposed Site Layout (Production Phase) of the Saltfleetby B Well site
 Issued 22/03/2022 Page 8 of 81

Permitting Decisions- Variation (substantial)

BAT Conclusions – refining of mineral oil and gas

We have reviewed the proposal for the gas refining activity against the best available techniques (BAT) Conclusions for the refining of mineral oil and gas industry sector published on 28 October 2014.

This section explains how we have reviewed and considered the techniques proposed by the operator for the operation and control of the gas refining activity. This review has been undertaken with reference to the decision made by the European Commission establishing BAT Conclusions for the refining of mineral oil and gas as detailed in document reference IEDC-7-1.

It is our record of our decision-making process and shows how we have taken into account all relevant factors in reaching our position. It also provides a justification for the inclusion of any specific conditions in the permit that are in addition to those included in our generic permit template.

We issued a Notice for further information on 12 August 2021 requiring the operator to provide information to demonstrate how the proposed gas refining operation will meet the standards described in the BAT Conclusions document.

The Notice also required that where the standards will not be met, the operator should provide the following information:

- Why the BAT standard is not applicable to those processes, or
- Justifies why an alternative technique will achieve the same level of environmental protection equivalent to the standard described in the BAT Conclusions.

Where the operator proposed that they were not intending to meet a BAT standard that also included a BAT Associated Emission Level (BAT AEL) described in the BAT Conclusions document, the Notice requested that the operator make a formal request for derogation from compliance with that AEL (as provisioned by Article 15(4) of the Industrial Emissions Directive (IED)). In this circumstance, the Notice identified that any such request for derogation must be supported and justified by sufficient technical and commercial information that would enable us to determine acceptability of the derogation request.

A response to the Notice was received from the operator on 17 September 2021. There was no request for a derogation.

We considered it was in the correct form and contained sufficient information for us to begin our review of the proposed gas refining activity, but not that it necessarily contained all the information we would need to complete that review.

We requested additional information as follows:

Information requested	Response received
Request for clarification on BAT Conclusions 4, 6, 37, 49 and 51 sent 29 September 2021	13 October 2021
Request for clarification on BAT Conclusion 49 sent 26 October 2021	08 November 2021
-	Bridging document received 01 December 2021 including amended BAT Conclusion 49
-	17 January 2022, BAT Conclusion 49 clarification.

In relation to BAT Conclusion 6 we agree with the operator in respect to their capability as recorded in the response to the Notice, and have set a pre-operational condition requiring the submission of a diffuse volatile organic compounds (VOC) monitoring plan. Their operational techniques will be updated so that the requirements of the BAT Conclusion are delivered.

Decision checklist regarding BAT Conclusions

BAT Conclusions for the refining of mineral oil and gas, were published by the European Commission on 09 October 2014. There are 58 BAT Conclusions.

This section provides a record of decisions made in relation to each relevant BAT Conclusion applicable to the proposed gas refining activity. This section should be read in conjunction with the Consolidated Variation Notice.

The overall status of compliance with the BAT Conclusion is indicated in the table as:

- NA Not applicable
- CC Currently compliant
- FC Compliant in the future
- NC Not compliant
- PC Partially compliant

BAT Conclusion Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition(s)
	<p>(f) Efficient process control (g) Maintenance programmes (h) Emergency preparedness and response (i) Safeguarding compliance with environmental legislation</p> <p>v. checking performance and taking corrective action, paying particular attention to:</p> <p>(a) monitoring and measurement (see also the Reference Document on the General Principles of Monitoring)</p> <p>(b) corrective and preventive action</p> <p>(c) maintenance of records</p> <p>(d) independent (where practicable) internal and external auditing in order to determine whether or not the EMS conforms to planned arrangements and has been properly implemented and maintained;</p> <p>vi. review of the EMS and its continuing suitability, adequacy and effectiveness by senior management;</p> <p>vii. following the development of cleaner technologies;</p> <p>viii. consideration for the environmental impacts from the eventual decommissioning of the installation at the stage of designing a new plant, and throughout its operating life;</p> <p>viii. consideration for the environmental impacts from the eventual decommissioning of the installation at the stage of designing a new plant, and throughout its operating life;</p> <p>ix. application of sectoral benchmarking on a regular basis.</p>		<p>(a) Structure and responsibility (b) Training, development and Employee involvement (c) Communication arrangements including complaints management (d) Document management including records maintenance (e) Operational and process control (f) Maintenance management (g) Emergency and accident management (h) Audits and management review (i) Non-compliance and corrective action</p> <p>The EMS structure essentially incorporates a plan, do, check and act cycle which meets the requirements of criteria (i) to (ix) inclusive of this BAT Conclusion.</p> <p>Details of the specific operational controls and monitoring are provided in the Technical Plan received 17 September 2021. We have set a pre-operational condition for this plan to be resubmitted as it did not include the appropriate level of detail.</p> <p>The operator is FC with the requirements of this BAT Conclusion.</p>	

BAT Conclusion Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition(s)										
	<p>Applicability. The scope (e.g. level of detail) and nature of the EMS (e.g. standardised or non-standardised) will generally be related to the nature, scale and complexity of the installation, and the range of environmental impacts it may have.</p>													
2	<p>In order to use energy efficiently, BAT is to use an appropriate combination of the techniques given below.</p> <table border="1" data-bbox="367 647 1151 1326"> <thead> <tr> <th data-bbox="367 647 600 711">Technique</th> <th data-bbox="600 647 1151 711">Description</th> </tr> </thead> <tbody> <tr> <td colspan="2" data-bbox="367 711 1151 743">i. Design techniques</td> </tr> <tr> <td data-bbox="367 743 600 895">a. Pinch analysis</td> <td data-bbox="600 743 1151 895">Methodology based on a systematic calculation of thermodynamic targets for minimising energy consumption of processes. Used as a tool for the evaluation of total systems designs</td> </tr> <tr> <td data-bbox="367 895 600 1078">b. Heat integration</td> <td data-bbox="600 895 1151 1078">Heat integration of process systems ensures that a substantial proportion of the heat required in various processes is provided by exchanging heat between streams to be heated and streams to be cooled</td> </tr> <tr> <td data-bbox="367 1078 600 1326">c. Heat and power recovery</td> <td data-bbox="600 1078 1151 1326"> Use of energy recovery devices e.g. <ul style="list-style-type: none"> • waste heat boilers • expanders/power recovery in the FCC unit • use of waste heat in district heating </td> </tr> </tbody> </table>	Technique	Description	i. Design techniques		a. Pinch analysis	Methodology based on a systematic calculation of thermodynamic targets for minimising energy consumption of processes. Used as a tool for the evaluation of total systems designs	b. Heat integration	Heat integration of process systems ensures that a substantial proportion of the heat required in various processes is provided by exchanging heat between streams to be heated and streams to be cooled	c. Heat and power recovery	Use of energy recovery devices e.g. <ul style="list-style-type: none"> • waste heat boilers • expanders/power recovery in the FCC unit • use of waste heat in district heating 	CC	<p>The operator confirmed that:</p> <p>The approach to energy management and efficiency is provided in the Resource Management Plan. The main considerations include:</p> <ul style="list-style-type: none"> • Design and selection of energy efficient equipment; • Automated combustion control; and • Process optimisation. <p>The current site operations are powered by electricity from the national grid. A small diesel generator will also be present on-site which is only activated as a back-up in the event of a power failure from the national grid.</p> <p>In relation to the new processing operations, power generators will be installed in the southeast corner of the site. The generators will combust site produced natural gas products in order to produce electricity which will be used to meet on-site electricity demands. There will be no surplus electricity generation.</p> <p>In addition to the above, once production has resumed and stabilised, the operator will review the viability of</p>	1.2
Technique	Description													
i. Design techniques														
a. Pinch analysis	Methodology based on a systematic calculation of thermodynamic targets for minimising energy consumption of processes. Used as a tool for the evaluation of total systems designs													
b. Heat integration	Heat integration of process systems ensures that a substantial proportion of the heat required in various processes is provided by exchanging heat between streams to be heated and streams to be cooled													
c. Heat and power recovery	Use of energy recovery devices e.g. <ul style="list-style-type: none"> • waste heat boilers • expanders/power recovery in the FCC unit • use of waste heat in district heating 													

BAT Conclusion Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition(s)												
3	<p>In order to prevent or, where that is not practicable, to reduce dust emissions from the storage and handling of dusty materials, BAT is to use one or a combination of the techniques given below:</p> <ul style="list-style-type: none"> i. store bulk powder materials in enclosed silos equipped with a dust abatement system (e.g. fabric filter); ii. store fine materials in enclosed containers or sealed bags; iii. keep stockpiles of coarse dusty material wetted, stabilise the surface with crusting agents, or store under cover in stockpiles; iv. use road cleaning vehicles 	NA	<p>The installation does not store or handle any materials which could generate dust.</p> <p>This BAT Conclusion is not applicable to the relevant activities carried out at this installation.</p>	NA												
4	<p>BAT is to monitor emissions to air by using the monitoring techniques with at least the minimum frequency given below and in accordance with EN standards. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.</p> <table border="1" data-bbox="367 810 1128 1214"> <thead> <tr> <th data-bbox="367 810 562 906">Description</th> <th data-bbox="562 810 750 906">Unit</th> <th data-bbox="750 810 940 906">Minimum frequency</th> <th data-bbox="940 810 1128 906">Monitoring technique</th> </tr> </thead> <tbody> <tr> <td data-bbox="367 906 562 1002">SO_x, NO_x and dust emissions</td> <td data-bbox="562 906 750 1002">Catalytic cracking</td> <td data-bbox="750 906 940 1002">continuous</td> <td data-bbox="940 906 1128 1002">Direct measurement</td> </tr> <tr> <td data-bbox="367 1002 562 1214"></td> <td data-bbox="562 1002 750 1214">Combustion units ≥ 100MW⁽³⁾ and calcining units</td> <td data-bbox="750 1002 940 1214">continuous</td> <td data-bbox="940 1002 1128 1214">Direct measurement⁽⁴⁾</td> </tr> </tbody> </table>	Description	Unit	Minimum frequency	Monitoring technique	SO _x , NO _x and dust emissions	Catalytic cracking	continuous	Direct measurement		Combustion units ≥ 100MW ⁽³⁾ and calcining units	continuous	Direct measurement ⁽⁴⁾	NA	<p>The operator confirmed that:</p> <p>Site combustion units have a combined rated thermal input of <20 MW.</p> <p>The power generation units will be operated on a blend of export specification (commercial grade) natural gas and off-specification gas. The ratio will be confirmed during commissioning trials but is anticipated to be a blend of 60% commercial grade/40% off-specification grade. Off-specification gas will be that which does not meet the NTS specification criteria for export.</p> <p>With respect to the compressor engines, it is proposed that the in the early phases of operation that these units will be operated using 100% export specification (commercial grade) natural gas. It is intended that at a later phase once the plant is commissioned and production operations are established that the compressors will also be operated in the long term on a blend of commercial grade and off specification gas.</p>	NA
Description	Unit	Minimum frequency	Monitoring technique													
SO _x , NO _x and dust emissions	Catalytic cracking	continuous	Direct measurement													
	Combustion units ≥ 100MW ⁽³⁾ and calcining units	continuous	Direct measurement ⁽⁴⁾													

BAT Conclusion Number	Summary of BAT Conclusion requirement				Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition(s)
		Combustion units of 50 to 100 MW ⁽³⁾	continuous	Direct measurement or indirect monitoring		<p>Article 2 (3) (o) of the medium combustion plant directive (MCPD) confirms that the directive does not apply to combustion plants firing refinery fuels alone or with other fuels for the production of energy within mineral oil and gas refineries.</p> <p>On the basis of the above, we have not set any monitoring requirements (or limits) for the combustion units/medium combustion plants (MCPs).</p>	
	Combustion units < 50 MW ⁽³⁾	once a year and after significant fuel changes	Direct measurement or indirect monitoring				
	Sulphur recovery units (SRU)	continuous for SO2 only	Direct measurement or indirect monitoring ⁽⁶⁾				
NH ₃ emissions	All units equipped with SCR or SNCR	continuous	Direct measurement				
CO emissions	Catalytic Cracking and combustion units >= 100MW ⁽³⁾	continuous	Direct measurement				
	Other combustion units	once every 6 months ⁽⁵⁾	Direct measurement				

BAT Conclusion Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition(s)						
	<p>(7) Antimony (Sb) is monitored only in catalytic cracking units when Sb injection is used in the process (e.g. for metals passivation)</p> <p>(8) With the exception of combustion units firing only gaseous fuel</p>									
5	<p>BAT is to monitor the relevant process parameters linked to pollutant emissions, at catalytic cracking and combustion units by using appropriate techniques and with at least the frequency given below.</p> <table border="1"> <thead> <tr> <th>Description</th> <th>Minimum frequency</th> </tr> </thead> <tbody> <tr> <td>Monitoring of parameters linked to pollution emissions, e.g. O₂ content in flue-gas, N and S content in fuel or feed ⁽¹⁾</td> <td>Continuous for O₂ content. For N and S content, periodic at a frequency based on significant fuel/feed changes.</td> </tr> <tr> <td colspan="2">⁽¹⁾ N and S monitoring in fuel or feed may not be necessary when continuous emission measurement of NO_x and SO₂ are carried out at the stack.</td> </tr> </tbody> </table>	Description	Minimum frequency	Monitoring of parameters linked to pollution emissions, e.g. O ₂ content in flue-gas, N and S content in fuel or feed ⁽¹⁾	Continuous for O ₂ content. For N and S content, periodic at a frequency based on significant fuel/feed changes.	⁽¹⁾ N and S monitoring in fuel or feed may not be necessary when continuous emission measurement of NO _x and SO ₂ are carried out at the stack.		CC	<p>There are no catalytic cracking units installed at the installation.</p> <p>The operator confirmed that they will undertake periodic emissions monitoring at the combustion plants, therefore continuous monitoring of O₂ is not believed to be required.</p> <p>Section 4 of the Technical plan confirms that gas composition has been relatively stable throughout the 20-year life of the field. The typical gas composition was provided in table 4.1, with nitrogen at 3.43 Mole %. No sulphur has been detected in the gas.</p> <p>We have not set any monitoring requirements, refer to our assessment of BAT Conclusion 4 above.</p> <p>The operator is CC with the requirements of this BAT Conclusion.</p>	3.5.1
Description	Minimum frequency									
Monitoring of parameters linked to pollution emissions, e.g. O ₂ content in flue-gas, N and S content in fuel or feed ⁽¹⁾	Continuous for O ₂ content. For N and S content, periodic at a frequency based on significant fuel/feed changes.									
⁽¹⁾ N and S monitoring in fuel or feed may not be necessary when continuous emission measurement of NO _x and SO ₂ are carried out at the stack.										
6	<p>BAT is to monitor diffuse VOC emissions to air from the entire site by using all of the following techniques:</p> <p>i. sniffing methods associated with correlation curves for key equipment;</p> <p>ii. optical gas imaging techniques;</p>	FC	<p>The operator confirmed that:</p> <p>The site will maintain a register of all relevant valves and vents. This will be subject to a programme of planned preventative maintenance and monitoring in accordance with a leak detection and repair (LDAR) inspection and monitoring programme.</p> <p>An outline LDAR plan is provided with the Schedule 5 response received 17 September 2021. The detailed</p>	3.2						

BAT Conclusion Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition(s)
	<p>iii. calculations of chronic emissions based on emissions factors periodically (e.g. once every two years) validated by measurements.</p> <p>The screening and quantification of site emissions by periodic campaigns with optical absorption-based-techniques, such as differential absorption light detection and ranging (DIAL) or solar occultation flux (SOF) is a useful complementary technique.</p> <p>Description. See section 1.20.6, Annex 1.</p>		<p>list of valves and vents will be produced once detailed design and HAZOP processes are complete and the final LDAR plan will be available prior to the facility coming into operation. The LDAR monitoring approach will utilise a combination of:</p> <ul style="list-style-type: none"> • Snoop tests; • Steady state monitoring; • Fixed gas monitoring on identified key items of plant; and • Sniff monitoring using handheld infrared or FID monitors at defined frequencies. <p>They also confirmed that, an annual diffuse VOC emission survey will be conducted using an optical gas imaging camera to identify leaks on an annual basis. The annual survey frequency is assessed as acceptable based on the modern installation and commissioning standards required for the facility. An emission survey by the optical gas imaging camera will take place within two months after the successful commissioning of the process facility and first gas flow to validate the assessment.</p> <p>Any leaks detected by the optical gas imaging camera will be further assessed using an infra-red survey technique to assess and locate leaks. Any leak detected at a concentration in excess of 1,000 ppmv CH₄ (or equivalent) will be recorded (so-called 'qualifying leaks') and will form part of an annual emission estimate and logged for repair. Any leak detected at a concentration below 1,000 ppmv CH₄ or equivalent (that is, 'non-qualifying leaks') will also be</p>	

BAT Conclusion Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition(s)
			<p>recorded, and logged for repair at an appropriate maintenance point, but will not feature in the site's annual emission estimate in line with the approach outlined in EN15446:2008 and BAT requirement to calculate chronic emissions.</p> <p>We have set a pre-operational condition requiring the submission of a diffuse VOC monitoring plan.</p> <p>Permit condition 4.2.2 requires annual reporting of the results of the monitoring and assessment undertaken.</p> <p>The operator is FC with the requirements of this BAT Conclusion.</p>	
7	<p>In order to prevent or reduce emissions to air, BAT is to operate the acid gas removal units, sulphur recovery units and all other waste gas treatment systems with a high availability and at optimal capacity.</p> <p>Special procedures can be defined for other than normal operating conditions, in particular:</p> <ul style="list-style-type: none"> i. During start-up and shut-down operations. ii. during other circumstances that could affect the proper functioning of the systems (e.g. regular and extraordinary maintenance work and cleaning operations of the units and/or of the waste gas treatment system); iii. in case of insufficient waste gas flow or temperature which prevents the use of the waste gas treatment system at full capacity. 	NA	<p>The Operator confirmed that there is no acid gas removal, sulphur recovery units or other waste gas treatment units operated on the installation.</p> <p>We agree this BAT Conclusion is not applicable to the relevant activities carried out at this installation.</p>	NA

BAT Conclusion Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition(s)				
8	<p>In order to prevent and reduce ammonia (NH₃) emissions to air when applying selective catalytic reduction (SCR) or selective non-catalytic reduction (SNCR) techniques, BAT is to maintain suitable operating conditions of the SCR or SNCR waste gas treatment systems, with the aim of limiting emissions of unreacted NH₃.</p> <p>Table 2 BAT- associated emission levels for ammonia (NH₃) emissions to air for a combustion process unit where SCR or SNCR techniques are used.</p> <table border="1" data-bbox="367 628 1128 783"> <thead> <tr> <th data-bbox="367 628 712 719">Parameter</th> <th data-bbox="712 628 1128 719">BAT-AEL (monthly average mg/m³)</th> </tr> </thead> <tbody> <tr> <td data-bbox="367 719 712 783">Ammonia expressed as NH₃</td> <td data-bbox="712 719 1128 783"><5 - 15mg/Nm³ ⁽¹⁾ ⁽²⁾</td> </tr> </tbody> </table> <p>(¹) the higher end of the range is associated with higher inlet NO_x concentrations, higher NO_x reduction rates and the ageing of the catalyst</p> <p>(²) The lower end of the range is associated with the use of the SCR technique.</p>	Parameter	BAT-AEL (monthly average mg/m ³)	Ammonia expressed as NH ₃	<5 - 15mg/Nm ³ ⁽¹⁾ ⁽²⁾	NA	<p>Not currently applicable in the UK</p> <p>There is no SNCR or SCR employed at the installation.</p>	NA
Parameter	BAT-AEL (monthly average mg/m ³)							
Ammonia expressed as NH ₃	<5 - 15mg/Nm ³ ⁽¹⁾ ⁽²⁾							
9	<p>In order to prevent and reduce emissions to air when using a sour water steam stripping unit, BAT is to route the acid off-gases from this unit to an SRU or any equivalent gas treatment system.</p> <p>It is not BAT to directly incinerate the untreated sour water stripping gases.</p>	NA	<p>Sour water stripping units are not operated on the installation.</p> <p>We agree this BAT Conclusion is not applicable to the relevant activities carried out at this installation.</p>	NA				

BAT Conclusion Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition(s)																								
10	<p>BAT is to monitor emissions to water by using the monitoring techniques with at least the frequency given in Table 3 (as below) and in accordance with EN standards. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.</p> <p>Table 3 BAT – associated emission levels for direct waste water discharges from the refining of mineral oil and gas monitoring frequencies associated with BAT (1)</p> <table border="1" data-bbox="367 660 1146 1283"> <thead> <tr> <th>Parameter</th> <th>Unit</th> <th>BAT – AEL (yearly average)</th> <th>Monitoring (2) frequency and analytical method (standard)</th> </tr> </thead> <tbody> <tr> <td>Hydrocarbon oil index (HOI)</td> <td>mg/l</td> <td>0.1 – 2.5</td> <td>Daily EN 9377-2</td> </tr> <tr> <td>Total suspended solids (TSS)</td> <td>mg/l</td> <td>5 - 25</td> <td>Daily</td> </tr> <tr> <td>Chemical oxygen demand (COD) (4)</td> <td>mg/l</td> <td>30 - 125</td> <td>Daily</td> </tr> <tr> <td>BOD 5</td> <td>mg/l</td> <td>No BAT - AEL</td> <td>Weekly</td> </tr> <tr> <td>Total nitrogen (5) expressed as N</td> <td>mg/l</td> <td>1 – 25 (6)</td> <td>Daily</td> </tr> </tbody> </table>	Parameter	Unit	BAT – AEL (yearly average)	Monitoring (2) frequency and analytical method (standard)	Hydrocarbon oil index (HOI)	mg/l	0.1 – 2.5	Daily EN 9377-2	Total suspended solids (TSS)	mg/l	5 - 25	Daily	Chemical oxygen demand (COD) (4)	mg/l	30 - 125	Daily	BOD 5	mg/l	No BAT - AEL	Weekly	Total nitrogen (5) expressed as N	mg/l	1 – 25 (6)	Daily	NA	<p>The operator confirmed that:</p> <p>The site does not routinely generate or discharge wastewater.</p> <p>There are no direct waste water discharges from the installation. This BAT Conclusion is not applicable to the relevant activities carried out at this installation.</p> <p>Whilst this BAT Conclusion is not relevant to the surface water discharges, the operator confirmed that:</p> <p>Surface water is collected in the site perimeter drains which are kept isolated. If water accumulates in the drains, then samples are taken and quality is checked.</p> <p>Discharge to surface water is permitted only if the criteria in the Surface Water Management Plan are met. Waters pass through an oil interceptor prior to discharge. Where water quality data is not met or there is a concern regarding the accumulated surface waters then the water will be removed by tanker and taken to an off-site treatment facility for disposal.</p> <p>The permit has been updated to include the surface water drainage system as follows:</p> <p>The surface water drainage system has been added to table S1.1 as a directly associated activity.</p> <p>Table S3.2 has been added to include uncontaminated surface water discharges W1 to W3 (see below).</p>	NA
Parameter	Unit	BAT – AEL (yearly average)	Monitoring (2) frequency and analytical method (standard)																									
Hydrocarbon oil index (HOI)	mg/l	0.1 – 2.5	Daily EN 9377-2																									
Total suspended solids (TSS)	mg/l	5 - 25	Daily																									
Chemical oxygen demand (COD) (4)	mg/l	30 - 125	Daily																									
BOD 5	mg/l	No BAT - AEL	Weekly																									
Total nitrogen (5) expressed as N	mg/l	1 – 25 (6)	Daily																									

BAT Conclusion Number	Summary of BAT Conclusion requirement				Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition(s)
	Lead, expressed as Pb	mg/l	0.005 – 0.030	Quarterly		A pre-operational condition has been added requiring an updated surface water management plan and a surface water monitoring plan. The submission for this condition was provided prior to the variation being issued and identified an additional release point W3 associated with SFA. We have included this in table S3.2.	
Cadmium expressed as Cd	mg/l	0.002 – 0.008	Quarterly				
Nickel, expressed as Ni	mg/l	0.005 – 0.100	Quarterly				
Mercury, expressed as Hg	mg/l	0.0001 – 0.001	Quarterly				
Vanadium	mg/l	No BAT - AEL	Quarterly				
Phenol index	mg/l	No BAT - AEL	Monthly EN 14402				
Benzene, toluene, ethyl benzene, xylene (BTEX)	mg/l	Benzene 0.001 – 0.050 No BAT – AEL for T, E, X	Monthly				
<p>(1) Not all parameters and sampling frequencies are applicable to effluent from gas refining sites</p> <p>(2) Refers to a flow-proportional composite sample taken over period of 24 hours, or provided that sufficient flow stability is demonstrated, a time-proportional sample</p> <p>(3) Moving from the current method to EN 9377-2 may require an adaptation period</p> <p>(4) Where on-site correlation is available, COD may be replaced by TOC. The correlation between COD and TOC should be</p>							

BAT Conclusion Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition(s)
	<p>elaborated on a case-by-case basis. TOC monitoring would be the preferred option because it does not rely on the use of very toxic compounds</p> <p>(5) Where total-nitrogen is the sum of the total Kjeldahl nitrogen (TKN), nitrates and nitrites</p> <p>(6) When nitrification/denitrification is used, levels below 15 mg/l can be achieved</p>			

11	<p>In order to reduce water consumption and the volume of contaminated water, BAT is to use all of the techniques given below.</p> <table border="1"> <thead> <tr> <th data-bbox="367 320 562 379">Technique</th> <th data-bbox="562 320 902 379">Description</th> <th data-bbox="902 320 1142 379">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="367 379 562 627">i. water stream integration</td> <td data-bbox="562 379 902 627">Reduction of process water produced at the unit level prior to discharge by the internal reuse of water streams from e.g. cooling, condensates, especially for use in crude desalting</td> <td data-bbox="902 379 1142 627">Generally applicable for new units. For existing units, applicability may require a complete rebuilding of the unit or the installation</td> </tr> <tr> <td data-bbox="367 627 562 930">ii. water and drainage system for segregation of contaminated water streams</td> <td data-bbox="562 627 902 930">Design of an industrial site to optimise water management, where each stream is treated as appropriate, by e.g. routing generated sour water (from distillation, cracking, coking units, etc.) to appropriate pre-treatment, such as a stripping unit</td> <td data-bbox="902 627 1142 930">Generally applicable for new units. For existing units, applicability may require a complete rebuilding of the unit or the installation</td> </tr> <tr> <td data-bbox="367 930 562 1201">iii. segregation of non-contaminated water streams (e.g. once-through cooling, rain water)</td> <td data-bbox="562 930 902 1201">Design of a site in order to avoid sending non-contaminated water to general waste water treatment and to have a separate release after possible reuse for this type of stream</td> <td data-bbox="902 930 1142 1201">Generally applicable for new units. For existing units, applicability may require a complete rebuilding of the unit or the installation</td> </tr> <tr> <td data-bbox="367 1201 562 1321">iv. prevention of spillages and leaks</td> <td data-bbox="562 1201 902 1321">Practices that include the utilisation of special procedures and/or temporary equipment to maintain</td> <td data-bbox="902 1201 1142 1321">Generally applicable</td> </tr> </tbody> </table>	Technique	Description	Applicability	i. water stream integration	Reduction of process water produced at the unit level prior to discharge by the internal reuse of water streams from e.g. cooling, condensates, especially for use in crude desalting	Generally applicable for new units. For existing units, applicability may require a complete rebuilding of the unit or the installation	ii. water and drainage system for segregation of contaminated water streams	Design of an industrial site to optimise water management, where each stream is treated as appropriate, by e.g. routing generated sour water (from distillation, cracking, coking units, etc.) to appropriate pre-treatment, such as a stripping unit	Generally applicable for new units. For existing units, applicability may require a complete rebuilding of the unit or the installation	iii. segregation of non-contaminated water streams (e.g. once-through cooling, rain water)	Design of a site in order to avoid sending non-contaminated water to general waste water treatment and to have a separate release after possible reuse for this type of stream	Generally applicable for new units. For existing units, applicability may require a complete rebuilding of the unit or the installation	iv. prevention of spillages and leaks	Practices that include the utilisation of special procedures and/or temporary equipment to maintain	Generally applicable	CC	<p>The operator confirmed that:</p> <p>Details of water management techniques are provided in the Resource Management Report and indicative BAT is demonstrated by:</p> <ul style="list-style-type: none"> • Minimising water use, checks will be made on water consumption as part of the site EMS. Management arrangements and leaks will be reported and repaired as soon as practicable. • Process water is generated as a by-product of the three phase separation process which removes produced water from the gas stream. This material is removed by tanker from site for off-site treatment, recycling and disposal. • Surface water run-off from the site will be directed to the site perimeter drain which is lined with an impermeable plastic geo-membrane and flows towards a sump. The drain will be subject to daily inspection and when necessary, collected material will be removed by tanker from site to an appropriately permitted site for treatment, recovery or disposal. <p>The operator is CC with the requirements of this BAT Conclusion.</p>	1.3.1
Technique	Description	Applicability																	
i. water stream integration	Reduction of process water produced at the unit level prior to discharge by the internal reuse of water streams from e.g. cooling, condensates, especially for use in crude desalting	Generally applicable for new units. For existing units, applicability may require a complete rebuilding of the unit or the installation																	
ii. water and drainage system for segregation of contaminated water streams	Design of an industrial site to optimise water management, where each stream is treated as appropriate, by e.g. routing generated sour water (from distillation, cracking, coking units, etc.) to appropriate pre-treatment, such as a stripping unit	Generally applicable for new units. For existing units, applicability may require a complete rebuilding of the unit or the installation																	
iii. segregation of non-contaminated water streams (e.g. once-through cooling, rain water)	Design of a site in order to avoid sending non-contaminated water to general waste water treatment and to have a separate release after possible reuse for this type of stream	Generally applicable for new units. For existing units, applicability may require a complete rebuilding of the unit or the installation																	
iv. prevention of spillages and leaks	Practices that include the utilisation of special procedures and/or temporary equipment to maintain	Generally applicable																	

BAT Conclusion Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition(s)												
		performances when necessary to manage special circumstances such as spills, loss of containment, etc																
12	<p>In order to reduce the emission load of pollutants in the waste water discharge to the receiving water body, BAT is to remove insoluble and soluble polluting substances by using all of the techniques given below.</p> <table border="1" data-bbox="367 644 1151 1295"> <thead> <tr> <th data-bbox="367 644 618 708">Technique</th> <th data-bbox="618 644 976 708">Description</th> <th data-bbox="976 644 1151 708">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="367 708 618 868">i. Removal of insoluble substances by recovering oil</td> <td data-bbox="618 708 976 868">See Section 1.21.2, Annex 1.</td> <td data-bbox="976 708 1151 868">Generally applicable</td> </tr> <tr> <td data-bbox="367 868 618 1075">ii. Removal of insoluble substances by recovering suspended solids and dispersed oil</td> <td data-bbox="618 868 976 1075">See Section 1.21.2, Annex 1.</td> <td data-bbox="976 868 1151 1075">Generally applicable</td> </tr> <tr> <td data-bbox="367 1075 618 1295">iii. Removal of insoluble substances including biological treatment and clarification.</td> <td data-bbox="618 1075 976 1295">See Section 1.21.2, Annex 1.</td> <td data-bbox="976 1075 1151 1295">Generally applicable</td> </tr> </tbody> </table>			Technique	Description	Applicability	i. Removal of insoluble substances by recovering oil	See Section 1.21.2, Annex 1.	Generally applicable	ii. Removal of insoluble substances by recovering suspended solids and dispersed oil	See Section 1.21.2, Annex 1.	Generally applicable	iii. Removal of insoluble substances including biological treatment and clarification.	See Section 1.21.2, Annex 1.	Generally applicable	NA	<p>The operator confirmed that:</p> <p>No discharge of process waste-water takes place at the site. Produced water will be removed from site by road tanker to an appropriately licenced off-site treatment facility. Refer to BAT Conclusion 10 above.</p> <p>We agree this BAT Conclusion is not applicable to the relevant activities carried out at this installation.</p>	NA
Technique	Description	Applicability																
i. Removal of insoluble substances by recovering oil	See Section 1.21.2, Annex 1.	Generally applicable																
ii. Removal of insoluble substances by recovering suspended solids and dispersed oil	See Section 1.21.2, Annex 1.	Generally applicable																
iii. Removal of insoluble substances including biological treatment and clarification.	See Section 1.21.2, Annex 1.	Generally applicable																

BAT Conclusion Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition(s)
	BAT – associated emission levels – see Table 3			
13	When further removal of organic substances or nitrogen is needed, BAT is to use an additional treatment step as described in Section 1.21.2 (see Annex 1).	NA	The operator confirmed that this BAT Conclusion is not applicable with reference to BAT Conclusion 12 above. We agree this BAT Conclusion is not applicable to the relevant activities carried out at this installation.	NA

14	<p>In order to prevent or, where that is not practicable, to reduce waste generation, BAT is to adopt and implement a waste management plan that, in order of priority, ensures that waste is prepared for reuse, recycling, recovery or disposal.</p>	FC	<p>The operator confirmed that:</p> <p>Details of waste avoidance, recovery and disposal is provided in the Waste Management Plan in section 5 of the application. Indicative BAT is demonstrated through:</p> <ul style="list-style-type: none"> • Potentially hazardous waste materials produced at the site during side-track or maintenance activities will be collected in dedicated storage drums/containers to prevent cross contamination. Such materials will be collected by an appropriately licenced waste carrier for transfer off-site to a licenced facility for treatment, recovery or disposal. Such materials are generally associated with maintenance activities and will comprise waste lubricants, oils and oil-contaminated materials. It is unlikely that halogenated organic or similar wastes with environmental sensitivity will be produced at the site. • At times where improvement (e.g. work-over), remediation or restoration activities generate a wider range of waste materials, site storage arrangements will be reviewed and appropriate storage containers, enclosed skips and drums will be arranged suitable for the materials generated at that stage. Materials will be removed to appropriately licenced facilities for treatment, recovery or disposal if they can't be re-used on site. • The site is underlain with a geo-membrane and higher risk areas are covered with an impermeable surface to prevent penetration of spillages into the underlying ground. Spillages will be removed promptly in accordance with defined site procedures and 	1.4.1
----	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	----	-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	-------

BAT Conclusion Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition(s)									
15	<p>In order to reduce the amount of sludge to be treated or disposed of, BAT is to use one or a combination of the techniques given below.</p> <table border="1" data-bbox="367 448 1151 1086"> <thead> <tr> <th data-bbox="367 448 600 512">Technique</th> <th data-bbox="600 448 920 512">Description</th> <th data-bbox="920 448 1151 512">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="367 512 600 810">i Sludge pretreatment</td> <td data-bbox="600 512 920 810">Prior to final treatment (e.g. in a fluidised bed incinerator), the sludges are dewatered and/or de-oiled (by e.g. centrifugal decanters or steam dryers) to reduce their volume and to recover oil from slop equipment.</td> <td data-bbox="920 512 1151 810">Generally applicable</td> </tr> <tr> <td data-bbox="367 810 600 1086">ii Reuse of sludge in process units</td> <td data-bbox="600 810 920 1086">Certain types of sludge (e.g. oily sludge) can be processed in units (e.g. coking) as part of the feed due to their oil content.</td> <td data-bbox="920 810 1151 1086">Applicability is restricted to sludges that can fulfil the requirements to be processed in units with appropriate treatment</td> </tr> </tbody> </table>	Technique	Description	Applicability	i Sludge pretreatment	Prior to final treatment (e.g. in a fluidised bed incinerator), the sludges are dewatered and/or de-oiled (by e.g. centrifugal decanters or steam dryers) to reduce their volume and to recover oil from slop equipment.	Generally applicable	ii Reuse of sludge in process units	Certain types of sludge (e.g. oily sludge) can be processed in units (e.g. coking) as part of the feed due to their oil content.	Applicability is restricted to sludges that can fulfil the requirements to be processed in units with appropriate treatment	NA	<p>The operator confirmed that:</p> <p>The site will only produce small amounts of sludge generated during maintenance cleaning of the condensate and produced water tanks. This material would be removed by tanker for off-site recycling/recovery.</p> <p>We conclude that no sludge is routinely produced. Sludge is only produced during non-routine tank cleaning operations which are carried out periodically.</p> <p>This BAT Conclusion is not applicable to the relevant activities carried out at this installation.</p>	NA
Technique	Description	Applicability											
i Sludge pretreatment	Prior to final treatment (e.g. in a fluidised bed incinerator), the sludges are dewatered and/or de-oiled (by e.g. centrifugal decanters or steam dryers) to reduce their volume and to recover oil from slop equipment.	Generally applicable											
ii Reuse of sludge in process units	Certain types of sludge (e.g. oily sludge) can be processed in units (e.g. coking) as part of the feed due to their oil content.	Applicability is restricted to sludges that can fulfil the requirements to be processed in units with appropriate treatment											

BAT Conclusion Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition(s)						
16	<p>In order to reduce the generation of spent solid catalyst waste, BAT is to use one or a combination of the techniques given below.</p> <table border="1" data-bbox="367 418 1151 970"> <thead> <tr> <th data-bbox="367 418 712 481">Technique</th> <th data-bbox="712 418 1151 481">Description</th> </tr> </thead> <tbody> <tr> <td data-bbox="367 481 712 756">i. Spent solid catalyst management</td> <td data-bbox="712 481 1151 756">Scheduled and safe handling of the materials used as catalyst (e.g. by contractors) in order to recover or reuse them in off-site facilities. These operations depend on the type of catalyst and process</td> </tr> <tr> <td data-bbox="367 756 712 970">ii. Removal of catalyst from slurry decant oil</td> <td data-bbox="712 756 1151 970">Decanted oil sludge from process units (e.g. FCC unit) can contain significant concentrations of catalyst fines. These fines can be separated prior to the reuse of decant oil as a feedstock.</td> </tr> </tbody> </table>	Technique	Description	i. Spent solid catalyst management	Scheduled and safe handling of the materials used as catalyst (e.g. by contractors) in order to recover or reuse them in off-site facilities. These operations depend on the type of catalyst and process	ii. Removal of catalyst from slurry decant oil	Decanted oil sludge from process units (e.g. FCC unit) can contain significant concentrations of catalyst fines. These fines can be separated prior to the reuse of decant oil as a feedstock.	NA	<p>Solid catalytic treatment is not undertaken as part of the relevant activities carried out in the installation.</p> <p>This BAT Conclusion is not applicable to the relevant activities carried out at this installation.</p>	NA
Technique	Description									
i. Spent solid catalyst management	Scheduled and safe handling of the materials used as catalyst (e.g. by contractors) in order to recover or reuse them in off-site facilities. These operations depend on the type of catalyst and process									
ii. Removal of catalyst from slurry decant oil	Decanted oil sludge from process units (e.g. FCC unit) can contain significant concentrations of catalyst fines. These fines can be separated prior to the reuse of decant oil as a feedstock.									

BAT Conclusion Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition(s)									
17	<p>In order to prevent or reduce noise, BAT is to use one or a combination of the techniques given below:</p> <ul style="list-style-type: none"> i. Make an environmental noise assessment and formulate a noise management plan as appropriate to the local environment; ii. Enclose noisy equipment/operation in a separate structure/unit; iii. Use embankments to screen the source of noise; iv. Use noise protection walls; 	FC	<p>Refer to Key issues section (noise impact assessment (NIA)) of this document.</p> <p>We have included improvement conditions for the NIA to be validated at initial phase and full-scale operations. A pre-operational condition also requires a noise management plan (NMP) to be in place prior to commissioning of the gas refining activities.</p> <p>The operator is FC with the requirements of this BAT Conclusion.</p>	3.4.1									
18	<p>In order to prevent or reduce diffuse VOC emissions, BAT is to apply the techniques given below.</p> <table border="1" data-bbox="365 922 1144 1326"> <thead> <tr> <th data-bbox="365 922 584 986">Technique</th> <th data-bbox="584 922 981 986">Description</th> <th data-bbox="981 922 1144 986">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="365 986 584 1265">I. Techniques related to plant design.</td> <td data-bbox="584 986 981 1265"> <ul style="list-style-type: none"> i. Limiting the number of potential emission sources ii. Maximising inherent process containment features iii. Selecting high integrity equipment iv. Facilitating monitoring and maintenance activities by ensuring access to potentially leaking components </td> <td data-bbox="981 986 1144 1265">Applicability may be limited for existing units</td> </tr> <tr> <td data-bbox="365 1265 584 1326">II. Techniques related to</td> <td data-bbox="584 1265 981 1326">i. Well defined procedures for construction and assembly</td> <td data-bbox="981 1265 1144 1326">Applicability may be</td> </tr> </tbody> </table>	Technique	Description	Applicability	I. Techniques related to plant design.	<ul style="list-style-type: none"> i. Limiting the number of potential emission sources ii. Maximising inherent process containment features iii. Selecting high integrity equipment iv. Facilitating monitoring and maintenance activities by ensuring access to potentially leaking components 	Applicability may be limited for existing units	II. Techniques related to	i. Well defined procedures for construction and assembly	Applicability may be	CC	<p>The operator confirmed that the proposed process utilises:</p> <ul style="list-style-type: none"> a. Pressure containment pipework and vessels that will be rated to 600 pound flange rating (1440 psi) which exceeds the maximum pressures that could be experienced due to the wells. b. Pipework which is designed and constructed to national industry standards. Pipework is carefully chosen to provide maximum protection from all forms of damage or impact and all intersections are fitted with shut-off valves which can be used to isolate parts of the system in the event of a leak or fire. All pipelines 	3.2.1
Technique	Description	Applicability											
I. Techniques related to plant design.	<ul style="list-style-type: none"> i. Limiting the number of potential emission sources ii. Maximising inherent process containment features iii. Selecting high integrity equipment iv. Facilitating monitoring and maintenance activities by ensuring access to potentially leaking components 	Applicability may be limited for existing units											
II. Techniques related to	i. Well defined procedures for construction and assembly	Applicability may be											

BAT Conclusion Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition(s)
	plant installation and commissioning	ii. Robust commissioning and hand-over procedures to ensure that the plant is installed in line with the design requirements.	limited for existing units		<p>will be inspected in accordance with a 24 monthly statutory inspection regime.</p> <p>c. Pressure vessels will be designed to recognised industrial standards. All pressure vessels will be inspected in accordance with statutory inspection requirements.</p> <p>The new plant will be installed and commissioned by the technical supplier in accordance with a commissioning plan. This will include training of site operators in respect of the ongoing operation, monitoring and maintenance of the plant. Handover of the plant from the Technical Supplier will not occur until the staff training is completed and the commissioning plan criteria have been met.</p> <p>The site will maintain a register of all relevant valves and vents. This will be subject to a programme of planned preventative maintenance and monitoring in accordance with a LDAR inspection and monitoring programme. (See response to BAT Conclusion 6 above).</p> <p>We have set an improvement condition requiring a report on the commissioning of the facility.</p> <p>The operator is CC with the requirements of this BAT Conclusion.</p>	
	III. Techniques related to plant operation	Use of a risk-based leak detection and repair (LDAR) programme in order to identify leaking components, and to repair these leaks. See table 1.20.6 under BAT 6	Generally applicable			
19 and 20	Hydrofluoric acid alkylation process			NA		NA

BAT Conclusion Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition(s)						
21	Sulphuric acid alkylation process	NA	These processes are not part of the relevant activities carried out in the installation.	NA						
22	Base oil production process	NA	These BAT Conclusions are not applicable to the relevant activities carried out at this installation.	NA						
23	Bitumen production process	NA		NA						
BAT conclusions 24 to 27 for the fluid catalytic cracking process		NA		Catalytic cracking processes are not part of the relevant activities carried out in the installation. These BAT Conclusions are not applicable to the relevant activities carried out at this installation.	NA					
28	Catalytic reforming process	NA	These processes are not part of the relevant activities carried out in the installation.	NA						
BAT Conclusions 29 to 32 for coking processes		NA	These BAT Conclusions are not applicable to the relevant activities carried out at this installation.	NA						
33	Desalting process	NA		NA						
Combustion units										
34	<p>BAT 34. In order to prevent or reduce NO_x emissions to air from the combustion units, BAT is to use one or a combination of the techniques given below.</p> <p>I. Primary or process-related techniques, such as:</p> <table border="1"> <thead> <tr> <th>Technique</th> <th>Description</th> <th>Applicability</th> </tr> </thead> <tbody> <tr> <td> </td> <td> </td> <td> </td> </tr> </tbody> </table>	Technique	Description	Applicability				CC	<p>The operator confirmed that:</p> <p>The site will utilise:</p> <ul style="list-style-type: none"> • 3 gas compressor units • 2 gas fuelled generator units • 2 diesel back-up generators. 	2.3.1
Technique	Description	Applicability								

BAT Conclusion Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition(s)						
	<p>i. Selection or treatment of fuel</p> <table border="1" data-bbox="367 389 1142 1241"> <tr> <td data-bbox="367 389 629 724">(a) Use of gas to replace liquid fuel</td> <td data-bbox="629 389 862 724"> <p>Gas generally contains less nitrogen than liquid and its combustion leads to a lower level of NO_x emissions.</p> <p>See section 1.20.3, Annex 1.</p> </td> <td data-bbox="862 389 1142 724"> <p>The applicability may be limited by the constraints associated with the availability of low sulphur gas fuels, which may be impacted by the energy policy of the Member State</p> </td> </tr> <tr> <td data-bbox="367 724 629 1241">(b) Use of low nitrogen refinery fuel oil (RFO) e.g. by RFO selection or by hydrotreatment of RFO</td> <td data-bbox="629 724 862 1241"> <p>Refinery fuel oil selection favours low nitrogen liquid fuels among the possible sources to be used at the unit.</p> <p>Hydrotreatment aims at reducing the sulphur, nitrogen and metal contents of the fuel.</p> <p>See section 1.20.3, Annex 1.</p> </td> <td data-bbox="862 724 1142 1241"> <p>Applicability is limited by the availability of low nitrogen liquid fuels, hydrogen production and hydrogen sulphide (H₂S) treatment capacity (e.g. amine and Claus units)</p> </td> </tr> </table> <p>ii. Combustion modifications</p>	(a) Use of gas to replace liquid fuel	<p>Gas generally contains less nitrogen than liquid and its combustion leads to a lower level of NO_x emissions.</p> <p>See section 1.20.3, Annex 1.</p>	<p>The applicability may be limited by the constraints associated with the availability of low sulphur gas fuels, which may be impacted by the energy policy of the Member State</p>	(b) Use of low nitrogen refinery fuel oil (RFO) e.g. by RFO selection or by hydrotreatment of RFO	<p>Refinery fuel oil selection favours low nitrogen liquid fuels among the possible sources to be used at the unit.</p> <p>Hydrotreatment aims at reducing the sulphur, nitrogen and metal contents of the fuel.</p> <p>See section 1.20.3, Annex 1.</p>	<p>Applicability is limited by the availability of low nitrogen liquid fuels, hydrogen production and hydrogen sulphide (H₂S) treatment capacity (e.g. amine and Claus units)</p>		<p>The combined thermal input of the main engines are 8.68 MWth (4 x 2.17) at 100% capacity or 6.76 MWth at 75% capacity.</p> <p>The back-up generators will be used for start-up and shut-down, each with a thermal input of approximately 1 MWth.</p> <p>With respect to NO_x control, the following techniques will be employed:</p> <ul style="list-style-type: none"> • The combustion units will utilise produced gas as fuel source as an alternative to liquid fuel. • Low emission compressor units have been selected. • Optimisation of combustion control will be managed via an electronic engine management system that provides continuous computer controlled adjustments of parameters such as engine timing, air flow and cooling water temperatures. <p>NO_x emission levels on combustion units will be < 95 mg/Nm³ at reference conditions and as such no secondary/end-of pipe solutions are required.</p> <p>The 95 mg/Nm³ NO_x emission is less than the BAT AEL limit of 100 mg/Nm³ for new plant set out in table 10 of this BAT Conclusion.</p> <p>We have not set any limits as there are no monitoring requirements, refer to our assessment of BAT Conclusion 4 above.</p>	
(a) Use of gas to replace liquid fuel	<p>Gas generally contains less nitrogen than liquid and its combustion leads to a lower level of NO_x emissions.</p> <p>See section 1.20.3, Annex 1.</p>	<p>The applicability may be limited by the constraints associated with the availability of low sulphur gas fuels, which may be impacted by the energy policy of the Member State</p>								
(b) Use of low nitrogen refinery fuel oil (RFO) e.g. by RFO selection or by hydrotreatment of RFO	<p>Refinery fuel oil selection favours low nitrogen liquid fuels among the possible sources to be used at the unit.</p> <p>Hydrotreatment aims at reducing the sulphur, nitrogen and metal contents of the fuel.</p> <p>See section 1.20.3, Annex 1.</p>	<p>Applicability is limited by the availability of low nitrogen liquid fuels, hydrogen production and hydrogen sulphide (H₂S) treatment capacity (e.g. amine and Claus units)</p>								

BAT Conclusion Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition(s)
	(a) Staged combustion: • air staging • fuel staging	See section 1.20.2, Annex 1.	Fuel staging for mixed or liquid firing may require a specific burner design		The operator is CC with the requirements of this BAT Conclusion.	
	(b) Optimisation of combustion	See section 1.20.2, Annex 1.	Generally applicable			
	(c) Flue-gas recirculation	See section 1.20.2, Annex 1.	Applicable through the use of specific burners with internal recirculation of the flue-gas. The applicability may be restricted to retrofitting external flue-gas recirculation to units with a forced/induced draught mode of operation			
	(d) Diluent injection	See section 1.20.2, Annex 1.	Applicable for gas turbines where appropriate inert diluents are available			
	(e) Use of low-NO _x burners (LNB)	See section 1.20.2, Annex 1.	Generally applicable for new units taking into account, the fuel-			

BAT Conclusion Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition(s)
			<p>specific limitation (e.g. for heavy oil).</p> <p>For existing units, applicability may be restricted by the complexity caused by site-specific conditions e.g. furnaces design, surrounding devices.</p> <p>In very specific cases, substantial modifications may be required.</p> <p>The applicability may be restricted for furnaces in the delayed coking process, due to possible coke generation in the furnaces.</p> <p>In gas turbines, the applicability is restricted to low hydrogen content fuels (generally < 10 %)</p>			
	II. Secondary or end-of-pipe techniques, such as:					
	Technique	Description	Applicability			

BAT Conclusion Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition(s)
	i. Selective catalytic reduction (SCR)	See section 1.20.2, Annex 1.	<p>Generally applicable for new units.</p> <p>For existing units, the applicability may be constrained due to the requirements for significant space and optimal reactant injection</p>			
	ii. Selective non-catalytic reduction (SNCR)	See section 1.20.2, Annex 1.	<p>Generally applicable for new units.</p> <p>For existing units, the applicability may be constrained by the requirement for the temperature window and the residence time to be reached by reactant injection</p>			
	iii. Low temperature oxidation	See section 1.20.2, Annex 1.	The applicability may be limited by the need for additional scrubbing capacity and by the fact that ozone generation and the associated risk management need to be properly addressed.			

BAT Conclusion Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition(s)						
			<p>The applicability may be limited by the need for additional waste water treatment and related cross-media effects (e.g. nitrate emissions) and by an insufficient supply of liquid oxygen (for ozone generation).</p> <p>For existing units, the applicability of the technique may be limited by space availability</p>									
	iv. SNO _x combined technique	See section 1.20.4, Annex 1.	Applicable only for high flue-gas (e.g. > 800 000 Nm ³ /h) flow and when combined NO _x and SO _x abatement is needed									
	BAT- associated emission levels: See Table 9, Table 10 and Table 11											
	<p>Table 9 BAT-associated emission levels for NO_x emissions to air from a gas turbine</p>											
	<table border="1"> <thead> <tr> <th data-bbox="362 1152 571 1270">Parameter</th> <th data-bbox="580 1152 887 1270">Type of equipment</th> <th data-bbox="887 1152 1151 1270">BAT-AEL ⁽¹⁾ (monthly average) mg/Nm³ at 15% O₂</th> </tr> </thead> <tbody> <tr> <td> </td> <td> </td> <td> </td> </tr> </tbody> </table>	Parameter	Type of equipment	BAT-AEL ⁽¹⁾ (monthly average) mg/Nm ³ at 15% O ₂								
Parameter	Type of equipment	BAT-AEL ⁽¹⁾ (monthly average) mg/Nm ³ at 15% O ₂										

BAT Conclusion Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition(s)							
	NOx, expressed as NO ₂	Gas turbine (including combined cycle gas turbine – CCGT) and integrated gasification combined cycle turbine (IGCC))	40 - 120 (existing gas turbine) 20 - 50 (new turbine) ⁽²⁾										
<p>(1) BAT-AEL refers to combined emissions from the gas turbine and the supplementary firing recovery boiler, where present</p> <p>(2) For fuel with high H₂ content (i.e. above 10%), the upper end of the range is 75 mg/Nm³</p>													
<p>Table 10 BAT- associated emission levels for NOX emissions to air from a gas-fired combustion unit, with the exception of gas turbines</p>													
<table border="1"> <thead> <tr> <th data-bbox="369 858 533 970">Parameter:</th> <th data-bbox="539 858 869 970">Type of combustion</th> <th data-bbox="875 858 1149 970">BAT-AEL (monthly average) mg/Nm³</th> </tr> </thead> <tbody> <tr> <td data-bbox="369 975 533 1123" rowspan="2">NOx, expressed as NO₂</td> <td data-bbox="539 975 869 1123" rowspan="2">Gas firing</td> <td data-bbox="875 975 1149 1066">30 - 150 for existing unit ⁽¹⁾</td> </tr> <tr> <td data-bbox="875 1070 1149 1123">30 - 100 for new unit</td> </tr> </tbody> </table>							Parameter:	Type of combustion	BAT-AEL (monthly average) mg/Nm ³	NOx, expressed as NO ₂	Gas firing	30 - 150 for existing unit ⁽¹⁾	30 - 100 for new unit
Parameter:	Type of combustion	BAT-AEL (monthly average) mg/Nm ³											
NOx, expressed as NO ₂	Gas firing	30 - 150 for existing unit ⁽¹⁾											
		30 - 100 for new unit											
<p>(1) For an existing unit using high air pre-heat (i.e. > 200 C) or with H₂ content in the fuel gas higher than 50% the upper end of the BAT-AEL range is 200 mg/Nm³</p>													

BAT Conclusion Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition(s)									
	<p>Table 11 BAT –associated emission levels for NO_x emissions to air from a multi-fuel fired combustion unit with the exception of gas turbines</p> <table border="1" data-bbox="367 448 1151 663"> <thead> <tr> <th data-bbox="367 448 629 571">Parameter:</th> <th data-bbox="629 448 891 571">Type of combustion</th> <th data-bbox="891 448 1151 571">BAT-AEL (monthly average) mg/Nm³</th> </tr> </thead> <tbody> <tr> <td data-bbox="367 571 629 663">NO_x expressed as NO₂</td> <td data-bbox="629 571 891 663">Multi-fuel fired combustion unit</td> <td data-bbox="891 571 1151 663">30 -3—for existing unit ⁽¹⁾ ⁽²⁾</td> </tr> </tbody> </table> <p data-bbox="367 663 1151 807">(1) For existing units < 100 MW firing fuel oil with a nitrogen content higher than 0.5% (w/w) or with liquid firing > 50% or using air preheating values up to 450 mg/Nm³ may occur (2) The lower end of the range can be achieved by using the SCR technique</p> <p data-bbox="367 868 1151 938">The associated monitoring is in BAT 4.</p>	Parameter:	Type of combustion	BAT-AEL (monthly average) mg/Nm ³	NO _x expressed as NO ₂	Multi-fuel fired combustion unit	30 -3—for existing unit ⁽¹⁾ ⁽²⁾						
Parameter:	Type of combustion	BAT-AEL (monthly average) mg/Nm ³											
NO _x expressed as NO ₂	Multi-fuel fired combustion unit	30 -3—for existing unit ⁽¹⁾ ⁽²⁾											
35	<p>In order to prevent or reduce dust and metal emissions to air from the combustion units, BAT is to use one or a combination of the techniques given below.</p> <p data-bbox="412 1070 1151 1098">I. Primary or process-related techniques, such as:</p> <table border="1" data-bbox="367 1098 1151 1319"> <thead> <tr> <th data-bbox="367 1098 629 1161">Technique</th> <th data-bbox="629 1098 891 1161">Description</th> <th data-bbox="891 1098 1151 1161">Applicability</th> </tr> </thead> <tbody> <tr> <td colspan="3" data-bbox="367 1161 1151 1225">Selection or treatment of fuel</td> </tr> <tr> <td data-bbox="367 1225 629 1319">(a) Use of gas to replace liquid fuel</td> <td data-bbox="629 1225 891 1319">Gas instead of liquid combustion leads to</td> <td data-bbox="891 1225 1151 1319">The applicability may be limited by the constraints</td> </tr> </tbody> </table>	Technique	Description	Applicability	Selection or treatment of fuel			(a) Use of gas to replace liquid fuel	Gas instead of liquid combustion leads to	The applicability may be limited by the constraints	CC	<p data-bbox="1272 948 1872 975">The operator confirmed that:</p> <p data-bbox="1272 1011 1872 1070">With respect to dust and metal control, the following techniques will be employed:</p> <ul data-bbox="1323 1107 1872 1319" style="list-style-type: none"> <li data-bbox="1323 1107 1872 1193">• The combustion units will utilise produced gas as the fuel source, as an alternative to liquid fuel. <li data-bbox="1323 1198 1872 1257">• Low emission compressor units have been selected. <li data-bbox="1323 1262 1872 1319">• Optimisation of combustion control will be managed via an electronic engine 	2.3.1
Technique	Description	Applicability											
Selection or treatment of fuel													
(a) Use of gas to replace liquid fuel	Gas instead of liquid combustion leads to	The applicability may be limited by the constraints											

BAT Conclusion Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition(s)
		<p>lower level of dust emissions</p> <p>See section 1.20.3, Annex 1.</p>	<p>associated with the availability of low sulphur fuels such as natural gas which may be impacted by the energy policy of the Member State</p>		<p>management system that provides continuous computer controlled adjustments of parameters such as engine timing, air flow and cooling water temperatures.</p> <p>No secondary/end-of pipe solutions are required.</p> <p>It is unlikely that dust or metals would be present in emissions from the combustion of produced gas. Emissions of dust and metals from the combustion of diesel will be minimal as only small quantities will be required for start-up and shut-down.</p> <p>We have not set any limits as there are no monitoring requirements, refer to our assessment of BAT Conclusion 4 above.</p> <p>The operator is CC with the requirements of this BAT Conclusion.</p>	
	<p>(b) Use of low sulphur refinery fuel oil (RFO) e.g. by RFO selection or by hydro-treatment of RFO</p>	<p>Refinery fuel oil selection favours low sulphur liquid fuels among the possible sources to be used at the unit.</p> <p>Hydrotreatment aims at reducing the sulphur, nitrogen and metal contents of the fuel</p> <p>See section 1.20.3, Annex 1.</p>	<p>The applicability may be limited by the availability of low sulphur liquid fuels, hydrogen production and the hydrogen sulphide (H₂S) treatment capacity (e.g. amine and Claus units)</p>			
	<p>Combustion modifications</p>					
	<p>(a) Optimisation of combustion</p>	<p>See section 1.20.2, Annex 1.</p>	<p>Generally applicable to all types of combustion</p>			

BAT Conclusion Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition(s)
	(b) Atomisation of liquid fuel	Use of high pressure to reduce the droplet size of liquid fuel. Recent optimal burner designs generally include steam atomisation	Generally applicable to liquid fuel firing			
	II Secondary or end-of-pipe techniques, such as:					
	Technique	Description	Applicability			
	i. Electrostatic precipitator (ESP)	See section 1.20.1, Annex 1.	For existing units, the applicability may be limited by space availability			
	ii. Third stage blowback filter	See section 1.20.1, Annex 1.	Generally applicable			

BAT Conclusion Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition(s)							
	iii. Wet scrubbing	See section 1.20.1, Annex 1.	The applicability may be limited in arid areas and in the case where by-products from treatment (including e.g. waste water with a high level of salt) cannot be reused or appropriately disposed of. For existing units, the applicability of the technique may be limited by space availability										
	iv. Centrifugal washers	See section 1.20.1, Annex 1.	Generally applicable										
<p>Table 12 BAT – associated emission levels of dust emissions to air from a multi-fuel fired combustion unit with the exception of gas turbines</p>													
<table border="1"> <thead> <tr> <th data-bbox="365 1054 629 1150">Parameter</th> <th data-bbox="629 1054 889 1150">Type of combustion</th> <th data-bbox="889 1054 1151 1150">BAT-AEL (monthly average) mg/Nm³</th> </tr> </thead> <tbody> <tr> <td data-bbox="365 1150 629 1334" rowspan="2">Dust</td> <td data-bbox="629 1150 889 1334" rowspan="2">Multi-fuel firing</td> <td data-bbox="889 1150 1151 1241">5 – 50 for existing unit ⁽¹⁾ ⁽²⁾</td> </tr> <tr> <td data-bbox="889 1241 1151 1334">5 – 25 for new unit < 50 MW</td> </tr> </tbody> </table>							Parameter	Type of combustion	BAT-AEL (monthly average) mg/Nm ³	Dust	Multi-fuel firing	5 – 50 for existing unit ⁽¹⁾ ⁽²⁾	5 – 25 for new unit < 50 MW
Parameter	Type of combustion	BAT-AEL (monthly average) mg/Nm ³											
Dust	Multi-fuel firing	5 – 50 for existing unit ⁽¹⁾ ⁽²⁾											
		5 – 25 for new unit < 50 MW											

BAT Conclusion Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition(s)									
	<p>(1) The lower end of the range is achievable for units with the use of end-of-pipe techniques</p> <p>(2) The upper end of the range refers to the use of a high percentage of oil burning and where only primary techniques are applicable</p> <p>The associated monitoring is in BAT 4.</p>												
36	<p>In order to prevent or reduce SO_x emissions to air from the combustion units, BAT is to use one or a combination of the techniques given below.</p> <p>I. Primary or process-related techniques</p> <table border="1" data-bbox="367 695 1151 1339"> <thead> <tr> <th data-bbox="367 695 629 759">Technique</th> <th data-bbox="629 695 891 759">Description</th> <th data-bbox="891 695 1151 759">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="367 759 629 1091">i. Use of gas to replace liquid fuel</td> <td data-bbox="629 759 891 1091">See section 1.20.3, Annex 1.</td> <td data-bbox="891 759 1151 1091">The applicability may be limited by the constraints associated with the availability of low sulphur fuels such as natural gas, which may be impacted by the energy policy of the Member State</td> </tr> <tr> <td data-bbox="367 1091 629 1339">ii. Treatment of refinery fuel gas (RFG)</td> <td data-bbox="629 1091 891 1339">Residual H₂S concentration in RFG depends on the treatment process parameter, e.g. the amine-scrubbing pressure.</td> <td data-bbox="891 1091 1151 1339">For low calorific gas containing carbonyl sulphide (COS) e.g. from coking units, a converter may be required prior to H₂S removal</td> </tr> </tbody> </table>	Technique	Description	Applicability	i. Use of gas to replace liquid fuel	See section 1.20.3, Annex 1.	The applicability may be limited by the constraints associated with the availability of low sulphur fuels such as natural gas, which may be impacted by the energy policy of the Member State	ii. Treatment of refinery fuel gas (RFG)	Residual H ₂ S concentration in RFG depends on the treatment process parameter, e.g. the amine-scrubbing pressure.	For low calorific gas containing carbonyl sulphide (COS) e.g. from coking units, a converter may be required prior to H ₂ S removal	CC	<p>The operator confirmed that:</p> <p>With respect to SO_x control, the following techniques will be employed:</p> <ul style="list-style-type: none"> • The combustion units will utilise produced gas as the fuel source, as an alternative to liquid fuel. • Low emission compressor units have been selected. • Optimisation of combustion control will be managed via an electronic engine management system that provides continuous computer controlled adjustments of parameters such as engine timing, air flow and cooling water temperatures. <p>No secondary/end-of pipe solutions are required.</p> <p>It is unlikely that SO_x would be present in emissions from the combustion of produced gas. Section 4 of the Technical plan confirms that gas composition has been relatively stable throughout the 20 year life of the field. The typical gas composition was provided in table 4.1,</p>	2.3.1
Technique	Description	Applicability											
i. Use of gas to replace liquid fuel	See section 1.20.3, Annex 1.	The applicability may be limited by the constraints associated with the availability of low sulphur fuels such as natural gas, which may be impacted by the energy policy of the Member State											
ii. Treatment of refinery fuel gas (RFG)	Residual H ₂ S concentration in RFG depends on the treatment process parameter, e.g. the amine-scrubbing pressure.	For low calorific gas containing carbonyl sulphide (COS) e.g. from coking units, a converter may be required prior to H ₂ S removal											

BAT Conclusion Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition(s)
		See Section 1.20.3, Annex 1.			<p>with nitrogen. No sulphur has been detected in the gas.</p> <p>Emissions of SO_x from the combustion of diesel will be minimal as only small quantities will be required for start-up and shut-down.</p> <p>We have not set any limits as there are no monitoring requirements, refer to our assessment of BAT Conclusion 4 above.</p> <p>The operator is CC with the requirements of this BAT Conclusion.</p>	
	iii. Use of low sulphur refinery fuel oil (RFO) e.g. by RFO selection or by hydrotreatment of RFO	<p>Refinery fuel oil selection favours low sulphur liquid fuels among the possible sources to be used at the unit.</p> <p>Hydrotreatment aims at reducing the sulphur, nitrogen and metal contents of the fuel.</p> <p>See Section 1.20.3, Annex 1.</p>	<p>The applicability is limited by the availability of low sulphur liquid fuels, hydrogen production and the hydrogen sulphide (H₂S) treatment capacity (e.g. amine and Claus units)</p>			
	II. Secondary or end-of-pipe techniques					
	Technique	Description	Applicability			
	i. Non-regenerative scrubbing	<p>Wet scrubbing or seawater scrubbing.</p> <p>See Section 1.20.3, Annex 1.</p>	<p>The applicability may be limited in arid areas and in the case where the by-products from treatment (including e.g. waste water with high level of salts) cannot be reused or</p>			

BAT Conclusion Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition(s)										
	<table border="1" data-bbox="367 325 1151 603"> <tr> <td data-bbox="367 325 629 603"></td> <td data-bbox="629 325 1151 603"> <p>appropriately disposed of.</p> <p>For existing units, the applicability of the technique may be limited by space availability</p> </td> </tr> </table> <p data-bbox="367 603 1151 724">Table 13 BAT – associated emission levels for SO₂ emissions to air from combustion unit firing refinery fuel gas (RFG), with the exception of gas turbines</p> <table border="1" data-bbox="367 724 1151 884"> <thead> <tr> <th data-bbox="367 724 759 820">Parameter</th> <th data-bbox="759 724 1151 820">BAT-AEL (monthly average) mg/Nm³</th> </tr> </thead> <tbody> <tr> <td data-bbox="367 820 759 884">SO₂</td> <td data-bbox="759 820 1151 884">5 – 35 ⁽¹⁾</td> </tr> </tbody> </table> <p data-bbox="367 884 1151 1034">(1) In the specific configuration of RFG treatment with a low scrubber operative pressure and with refinery fuel gas with an H/C molar ratio above 5, the upper end of the BAT-AEL range can be as high as 45 mg/Nm³</p> <p data-bbox="367 1034 1151 1098">The associated monitoring is in BAT 4.</p> <p data-bbox="367 1098 1151 1219">Table 14 BAT- associated emission levels for SO₂ emissions to air from multi-fuel fired combustion units, with the exception of gas turbines and stationary engines</p> <table border="1" data-bbox="367 1219 1151 1318"> <thead> <tr> <th data-bbox="367 1219 759 1318">Parameter</th> <th data-bbox="759 1219 1151 1318">BAT-AEL (monthly average) mg/Nm³</th> </tr> </thead> <tbody> <tr> <td data-bbox="367 1219 759 1318"></td> <td data-bbox="759 1219 1151 1318"></td> </tr> </tbody> </table>		<p>appropriately disposed of.</p> <p>For existing units, the applicability of the technique may be limited by space availability</p>	Parameter	BAT-AEL (monthly average) mg/Nm ³	SO ₂	5 – 35 ⁽¹⁾	Parameter	BAT-AEL (monthly average) mg/Nm ³					
	<p>appropriately disposed of.</p> <p>For existing units, the applicability of the technique may be limited by space availability</p>													
Parameter	BAT-AEL (monthly average) mg/Nm ³													
SO ₂	5 – 35 ⁽¹⁾													
Parameter	BAT-AEL (monthly average) mg/Nm ³													

BAT Conclusion Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition(s)				
	<table border="1" data-bbox="367 325 1151 389"> <tr> <td data-bbox="367 325 757 389">SO₂</td> <td data-bbox="757 325 1151 389">35 - 600</td> </tr> </table> <p data-bbox="367 389 1151 459">The associated monitoring is in BAT 4.</p>	SO ₂	35 - 600					
SO ₂	35 - 600							
37	<p data-bbox="367 469 1151 533">In order to reduce carbon monoxide (CO) emissions to air from the combustion units, BAT is to use a combustion operation control.</p> <p data-bbox="367 564 1151 596">Description: See section 1.20.5, Annex 1.</p> <p data-bbox="367 628 1151 692">Table 15 BAT – associated emission levels for carbon monoxide emissions to air from combustion unit</p> <table border="1" data-bbox="367 715 1151 906"> <thead> <tr> <th data-bbox="367 715 757 810">Parameter</th> <th data-bbox="757 715 1151 810">BAT- AEL (monthly average) mg/Nm³</th> </tr> </thead> <tbody> <tr> <td data-bbox="367 810 757 906">Carbon monoxide expressed as CO</td> <td data-bbox="757 810 1151 906">≤ 100</td> </tr> </tbody> </table> <p data-bbox="367 906 1151 938">Associated monitoring is in BAT 4.</p>	Parameter	BAT- AEL (monthly average) mg/Nm ³	Carbon monoxide expressed as CO	≤ 100	CC	<p data-bbox="1276 469 1877 501">The operator confirmed that:</p> <p data-bbox="1276 533 1877 708">With respect to CO control, combustion will be optimised and managed via an electronic engine management system that provides continuous computer controlled adjustments of parameters such as engine timing, air flow and cooling water temperatures.</p> <p data-bbox="1276 740 1877 852">The power generation units will be operated on a blend of export specification (commercial grade) natural gas and off-specification gas (refer to BAT Conclusion 4 above).</p> <p data-bbox="1276 884 1877 916">CO emission levels are expected to be < 100 mg/Nm³.</p> <p data-bbox="1276 948 1877 1027">We have not set any limits as there are no monitoring requirements, refer to our assessment of BAT Conclusion 4 above.</p> <p data-bbox="1276 1059 1877 1123">The operator is CC with the requirements of this BAT Conclusion.</p>	2.3.1
Parameter	BAT- AEL (monthly average) mg/Nm ³							
Carbon monoxide expressed as CO	≤ 100							

BAT Conclusion Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition(s)
38	In order to reduce emissions to air from the etherification process, BAT is to ensure the appropriate treatment of process off-gases by routing them to the refinery fuel gas system.	NA	Etherification processes are not carried out at the installation. This BAT Conclusion is not applicable to the relevant activities carried out at this installation.	NA
39	In order to prevent upset of the biotreatment, BAT is to use a storage tank and an appropriate unit production plan management to control the toxic components dissolved content (e.g. methanol, formic acid, ethers) of the waste water stream prior to final treatment.	NA	This process is not carried out at the installation. This BAT Conclusion is not applicable to the relevant activities carried out at this installation.	NA
40	In order to reduce emissions to air of chlorinated compounds, BAT is to optimise the use of chlorinated organic compounds used to maintain catalyst activity when such a process is in place or to use non-chlorinated catalytic systems.	NA	This process is not carried out at the installation. This BAT Conclusion is not applicable to the relevant activities carried out at this installation.	NA
41	In order to reduce sulphur dioxide emissions to air from the natural gas plant, BAT is to apply BAT 54.	CC	Refer to BAT Conclusion 36. The operator is CC with the requirements of this BAT Conclusion.	2.3.1
42	In order to reduce nitrogen oxides (NO_x) emissions to air from the natural gas plant, BAT is to apply BAT 34	CC	Refer to BAT Conclusion 34. The operator is CC with the requirements of this BAT Conclusion.	2.3.1

BAT Conclusion Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition(s)
43	<p>In order to prevent emissions of mercury when present in raw natural gas, BAT is to remove the mercury and recover the mercury-containing sludge for waste disposal.</p>	NA	<p>The operator confirmed that:</p> <p>As per the typical gas composition shown in table 4.1 of the Technical Plan, mercury is not expected to be present in the produced gas. Section 4 of the Technical plan confirms that gas composition has been relatively stable throughout the 20 year life of the field.</p> <p>This BAT Conclusion is not applicable to the relevant activities carried out at this installation.</p>	NA
44	<p>In order to prevent or reduce waste water flow generation from the distillation process, BAT is to use liquid ring vacuum pumps or surface condensers.</p> <p>Applicability. May not be applicable in some retrofit cases. For new units, vacuum pumps, either in or not in combination with the steam ejectors, may be needed to achieve a high volume (10 mm Hg). Also, a spare should be available in case the vacuum pump fails.</p>	NA	<p>The operator confirmed that no distillation processes take place.</p> <p>This BAT Conclusion is not applicable to the relevant activities carried out at this installation.</p>	NA
45	<p>In order to prevent or reduce water pollution from the distillation process, BAT is to route sour water to the stripping unit.</p>	NA	See BAT Conclusion 44.	NA

BAT Conclusion Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition(s)
46	<p>In order to prevent or reduce emissions to air from distillation units, BAT is to ensure the appropriate treatment of process off-gases, especially incondensable off-gases, by acid gas removal prior to further use.</p> <p>Applicability. Generally applicable for crude and vacuum distillation units. May not be applicable for standalone lubricant and bitumen refineries, with emissions of less than 1 t/d of sulphur compounds. In specific refinery configurations, applicability may be restricted, due to the need for e.g. large piping, compressors or additional amine treating capacity.</p>	NA	See BAT Conclusion 44.	NA
47	<p>In order to reduce emissions to air from the products treatment process, BAT is to ensure the appropriate disposal of off-gases, especially odorous spent air from sweetening units, by routing them to destruction, e.g. by incineration.</p> <p>Applicability. Generally applicable to products treatment processes where the gas streams can be safely processed to the destruction units. May not be applicable to sweetening units, due to safety reasons.</p>	NA	<p>The operator confirmed that there are no sweetening units.</p> <p>This BAT Conclusion is not applicable to the relevant activities carried out at this installation.</p>	NA
48	<p>In order to reduce waste and waste water generation when a products treatment process using caustic is in place, BAT is to use cascading caustic solution and a global management of spent caustic, including recycling after appropriate treatment, e.g. by stripping.</p>	NA	<p>The operator confirmed that there are no products treatment processes using caustic.</p> <p>This BAT Conclusion is not applicable to the relevant activities carried out at this installation.</p>	NA

49	<p>In order to reduce VOC emissions to air from the storage of volatile liquid hydrocarbon compounds, BAT is to use floating roof storage tanks equipped with high efficiency seals or a fixed roof tank connected to a vapour recovery system.</p> <p>Description. High efficiency seals are specific devices for limiting losses of vapour e.g. improved primary seals, additional multiple (secondary or tertiary) seals (according to quantity emitted).</p> <p>Applicability. The applicability of high efficiency seals may be restricted for retrofitting tertiary seals in existing tanks.</p>	CC	<p>The operator confirmed that:</p> <p>The condensate and produced water are stored in dedicated fixed roof tanks as shown on drawings 3793-AEL-PR-PFD-001 and 3793-AEL-PR-PFD-002. There are four tanks in total, two each for condensate and produced water. One tank is intended to be in operation with the second on standby for offloading.</p> <p>The tanks are of standard design, fabricated for the project. They are not fitted with a mechanical vapour recovery system as the production process virtually eliminates all vapours from the liquids. The storage tanks are connected to the flare so that any gas that enters the tanks can be captured and safely combusted.</p> <p>Under normal operations the production process eliminates almost all vapours. In certain process upset conditions (i.e. equipment failure) gas could conceivably enter the tanks and the connection to the flare eliminates the overpressure risk. Also for safety reasons as the flare has a permanently lit pilot system and the tanks are periodically drained to trucks for offsite shipment, a permanent gas blanket is maintained on the tanks.</p> <p>Due to the very low quantity of gas, options to recover gas from the tanks are limited. Options that were considered are:</p> <ul style="list-style-type: none"> A) Full vapour recovery system; and B) Recover to the flare and use as a pilot fuel. <p>Option A – A full vapour recovery system would need to recirculate the gas into a main stream elsewhere in</p>	2.3.1
----	-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	----	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	-------

		<p>the plant, which would necessitate the recovered stream being compressed to a higher pressure. This would require a major modification to the current system with an extensive increase in mechanical equipment, power consumption and additional piping hardware. Given the extremely low quantity of residual gas in the liquid leaving the production process the vapour recovery system is considered a sub-optimal solution as it creates an unnecessary increase in energy consumption and waste.</p> <p>Option B – Routing gas to a flare is described as incineration of hazardous waste in the permit. In this instance the gas is being used as a portion of the pilot fuel. The flare has a requirement for continuous pressure to avoid flame-back into the low- and high-pressure flare headers as well as a requirement for the permanent pilot light for swift ignition in emergencies.</p> <p>The precise data for each use in Nm³/h and kg/h was provided. The volume of gas displaced from the water and condensate is very small, and in fact is barely sufficient to cover even the pilot light requirement of 1.88 kg/h (1.7 Nm³/h).</p> <p>In summary:</p> <p>The main process is designed to minimise gas vapours at the storage tanks by extracting the highest practical amount of gas from the liquids before they are transferred to storage. The stabilised condensate in the storage tanks does not generate any gas vapours at atmospheric pressure.</p> <p>All gas extracted from the liquids is intended to be utilised on site as fuel gas for power generation, pilot lights or gas purge blankets. There is a permanently</p>	
--	--	-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	--

BAT Conclusion Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition(s)
			<p>manifolded system to route and measure extracted gas to the different utilities.</p> <p>Gas vented at tanks is very low quantities predominately consisting of a gas blanket maintained as an anti-explosion protection</p> <p>Gas vented at tanks will be utilised and combusted in the flare to ensure a positive pressure is maintained on this low-pressure flare header as recommended by the manufacturer for safe operation.</p> <p>The use of site extracted gas (i.e. from the process) as the fuel gas for site utilities eliminates the need for import of propane or similar gas and avoids traffic movements associated with such import.</p> <p>Not installing a vapour recovery system avoids higher operating energy requirements and additional waste production.</p> <p>The operator is CC with the requirements of this BAT Conclusion.</p>	

BAT Conclusion Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition(s)									
50	<p>In order to reduce VOC emissions to air from the storage of volatile liquid hydrocarbon compounds, BAT is to use one or a combination of the techniques given below.</p> <table border="1" data-bbox="367 448 1151 1177"> <thead> <tr> <th data-bbox="367 448 629 512">Technique</th> <th data-bbox="629 448 891 512">Description</th> <th data-bbox="891 448 1151 512">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="367 512 629 695">i. Manual crude oil tank cleaning</td> <td data-bbox="629 512 891 695">Oil tank cleaning is performed by workers entering the tank and removing sludge manually</td> <td data-bbox="891 512 1151 695">Generally applicable</td> </tr> <tr> <td data-bbox="367 695 629 1177">ii. Use of a closed-loop system</td> <td data-bbox="629 695 891 1177">For internal inspections, tanks are periodically emptied, cleaned and rendered gas-free. This cleaning includes dissolving the tank bottom. Closed-loop systems that can be combined with end-of-pipe mobile abatement techniques prevent or reduce VOC emissions</td> <td data-bbox="891 695 1151 1177">The applicability may be limited by e.g. the type of residues, tank roof construction or tank materials</td> </tr> </tbody> </table>	Technique	Description	Applicability	i. Manual crude oil tank cleaning	Oil tank cleaning is performed by workers entering the tank and removing sludge manually	Generally applicable	ii. Use of a closed-loop system	For internal inspections, tanks are periodically emptied, cleaned and rendered gas-free. This cleaning includes dissolving the tank bottom. Closed-loop systems that can be combined with end-of-pipe mobile abatement techniques prevent or reduce VOC emissions	The applicability may be limited by e.g. the type of residues, tank roof construction or tank materials	CC	<p>The operator confirmed that:</p> <p>The site will employ a closed loop system whereby the tanks will be periodically emptied, cleaned and left gas-free prior to internal inspection.</p> <p>The operator is CC with the requirements of this BAT Conclusion.</p>	2.3.1
Technique	Description	Applicability											
i. Manual crude oil tank cleaning	Oil tank cleaning is performed by workers entering the tank and removing sludge manually	Generally applicable											
ii. Use of a closed-loop system	For internal inspections, tanks are periodically emptied, cleaned and rendered gas-free. This cleaning includes dissolving the tank bottom. Closed-loop systems that can be combined with end-of-pipe mobile abatement techniques prevent or reduce VOC emissions	The applicability may be limited by e.g. the type of residues, tank roof construction or tank materials											

BAT Conclusion Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition(s)									
51	<p>In order to prevent or reduce emissions to soil and groundwater from the storage of liquid hydrocarbon compounds, BAT is to use one or a combination of the techniques given below.</p> <table border="1"> <thead> <tr> <th>Technique</th> <th>Description</th> <th>Applicability</th> </tr> </thead> <tbody> <tr> <td>i. Maintenance programme including corrosion monitoring, prevention and control</td> <td>A management system including leak detection and operational controls to prevent overfilling, inventory control and risk-based inspection procedures on tanks at intervals to prove their integrity, and maintenance to improve tank containment. It also includes a system response to spill consequences to act before spills can reach the groundwater. To be especially reinforced during maintenance periods</td> <td>Generally applicable</td> </tr> <tr> <td>ii. Double bottomed tanks</td> <td>A second impervious bottom that provides a measure of protection against</td> <td>Generally applicable for new tanks and</td> </tr> </tbody> </table>	Technique	Description	Applicability	i. Maintenance programme including corrosion monitoring, prevention and control	A management system including leak detection and operational controls to prevent overfilling, inventory control and risk-based inspection procedures on tanks at intervals to prove their integrity, and maintenance to improve tank containment. It also includes a system response to spill consequences to act before spills can reach the groundwater. To be especially reinforced during maintenance periods	Generally applicable	ii. Double bottomed tanks	A second impervious bottom that provides a measure of protection against	Generally applicable for new tanks and	CC	<p>The operator confirmed that:</p> <ul style="list-style-type: none"> i. Maintenance programme including corrosion monitoring, prevention and control: <ul style="list-style-type: none"> • Level detection including alarms and overflow protection on the storage tanks; • Tanks which are protected against over and under pressurisation; • Welded and/or flanged connections on the tanks and associated pipework to reduce the likelihood of leaks; • Shut off valves and chokes on each tank to control the flow of fluid into/out of the tank; • Supervised tanker loading operations with pre-use checks on hoses and hose fittings to avoid detachment during loading operations; • A condensate tank which is equipped with a system that will detect water build-up in the tank and will facilitate draining of the water without significant release of the condensate; • Integrity testing prior to initial operation of each tank to ensure no leaks; • Routine tank and containment bund inspections to confirm no leaks are present and that operational controls remain effective; • Each tank and associated pipework, valves and monitoring/alarms systems will be subject to a preventative maintenance schedule in accordance with manufacturers recommendations – this will include integrity checks using an appropriate technique at the recommended frequency; 	1.1 2.3.1 3.2.3
Technique	Description	Applicability											
i. Maintenance programme including corrosion monitoring, prevention and control	A management system including leak detection and operational controls to prevent overfilling, inventory control and risk-based inspection procedures on tanks at intervals to prove their integrity, and maintenance to improve tank containment. It also includes a system response to spill consequences to act before spills can reach the groundwater. To be especially reinforced during maintenance periods	Generally applicable											
ii. Double bottomed tanks	A second impervious bottom that provides a measure of protection against	Generally applicable for new tanks and											

BAT Conclusion Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition(s)
		releases from the first material	after an overhaul of existing tanks (1)		<ul style="list-style-type: none"> • Operating a site surface drainage system which is kept isolated during normal operations and ensures any spillages external to containment bunds are retained on-site and removed by tanker for off-site disposal; and • Development, testing and implementation of an emergency spills procedure including maintaining appropriate spills control equipment/stocks. <p>ii Double bottomed tanks:</p> <p>The tanks proposed for condensate and produced water storage are not double bottomed tanks – the proposed tanks will be situated on raised pedestals within a concrete lined containment bunded area which means that any leak would be visible to operators.</p> <p>We do not consider double bottomed tanks represent BAT in the UK.</p> <p>iii An impervious membrane liner is beneath the facility.</p> <p>iv Sufficient tank farm bund containment with inspection and maintenance. Containment bund areas will be concrete lined and capable of containing 110% capacity of the volume of the largest single tank or contain 25% of the of the total volume where more than one tank is contained in a containment area.</p> <p>BAT is to use one or a combination of techniques.</p>	
	iii. Impervious membrane liners	A continuous leak barrier under the entire bottom surface of the tank	Generally applicable for new tanks and after an overhaul of existing tanks (1)			
	iv. Sufficient tank farm bund containment	A tank farm bund is designed to contain large spills potentially caused by a shell rupture or overfilling (for both environmental and safety reasons). Size and associated building rules are generally defined by local regulations	Generally applicable			
	(1) Techniques ii and iii may be generally applicable where tanks are dedicated to products that require heat for liquid handling (e.g. bitumen) and where no leak is likely because of solidification					

BAT Conclusion Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition(s)
			The operator is CC with the requirements of this BAT Conclusion.	

BAT Conclusion Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition(s)										
52	<p>In order to prevent or reduce VOC emissions to air from loading and unloading operations of volatile liquid hydrocarbon compounds, BAT is to use one or a combination of the techniques given below to achieve a recovery rate of at least 95 %.</p> <table border="1" data-bbox="367 475 1151 944"> <thead> <tr> <th data-bbox="367 475 629 539">Technique</th> <th data-bbox="629 475 891 539">Description</th> <th data-bbox="891 475 1151 539">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="367 539 629 944"> Vapour recovery by: i. Condensation ii. Absorption iii. Adsorption iv. Membrane separation v. Hybrid systems </td> <td data-bbox="629 539 891 944">See section 1.20.6, Annex 1.</td> <td data-bbox="891 539 1151 944"> Generally applicable to loading/unloading operations where annual throughput is > 5 000 m³/yr. Not applicable to loading/unloading operations for sea-going vessels with an annual throughput < 1 million m³/yr ⁽¹⁾ </td> </tr> </tbody> </table> <p data-bbox="367 944 1151 1029">(1) A vapour destruction unit (e.g. by incineration) may be substituted for a vapour recovery unit, if vapour recovery is unsafe or technically impossible because of the volume of return vapour</p> <p data-bbox="367 1029 1151 1117">Table 16 BAT- associated emission levels for non-methane VOC and benzene emissions to air from loading and unloading operations of volatile liquid hydrocarbon compounds</p> <table border="1" data-bbox="367 1117 1151 1284"> <thead> <tr> <th data-bbox="367 1117 752 1216">Parameter</th> <th data-bbox="752 1117 1151 1216">BAT-AEL (hourly average) (1)</th> </tr> </thead> <tbody> <tr> <td data-bbox="367 1216 752 1284">NMVOC</td> <td data-bbox="752 1216 1151 1284">0.15 - 10g/Nm³ ⁽²⁾ ⁽³⁾</td> </tr> </tbody> </table>	Technique	Description	Applicability	Vapour recovery by: i. Condensation ii. Absorption iii. Adsorption iv. Membrane separation v. Hybrid systems	See section 1.20.6, Annex 1.	Generally applicable to loading/unloading operations where annual throughput is > 5 000 m ³ /yr. Not applicable to loading/unloading operations for sea-going vessels with an annual throughput < 1 million m ³ /yr ⁽¹⁾	Parameter	BAT-AEL (hourly average) (1)	NMVOC	0.15 - 10g/Nm ³ ⁽²⁾ ⁽³⁾	CC	<p>The operator confirmed that:</p> <p>It is not expected or anticipated that venting of natural gas from the produced water will occur as dissolved methane will be separated from the produced water. Therefore this BAT conclusion is not applicable to produced water loading and unloading operations.</p> <p>In respect of condensate production, based on a peak production of 28,000 bbl per annum, export should not exceed 5,000 m³/yr. The condensate tank will be fitted with dry break coupling connection and arrangements for back venting during loading of road tankers back to the bulk storage tank for containment. This will allow a vapour recovery rate of at least 95%.</p> <p>A limit on throughput of 5,000 m³/year has been included in table S1.1 of the permit.</p> <p>The operator is CC with the requirements of this BAT Conclusion.</p>	<p>1.1</p> <p>2.3.1</p> <p>3.2</p>
Technique	Description	Applicability												
Vapour recovery by: i. Condensation ii. Absorption iii. Adsorption iv. Membrane separation v. Hybrid systems	See section 1.20.6, Annex 1.	Generally applicable to loading/unloading operations where annual throughput is > 5 000 m ³ /yr. Not applicable to loading/unloading operations for sea-going vessels with an annual throughput < 1 million m ³ /yr ⁽¹⁾												
Parameter	BAT-AEL (hourly average) (1)													
NMVOC	0.15 - 10g/Nm ³ ⁽²⁾ ⁽³⁾													

BAT Conclusion Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition(s)									
	<table border="1"> <tr> <td>Benzene ⁽³⁾</td> <td><1 mg/Nm³</td> </tr> <tr> <td colspan="2"> (1) Hourly values in continuous operation expressed and measured according to Directive 94/63/EA (2) Lower value achievable with two-stage hybrid systems. Upper value achievable with single-stage adsorption or membrane system (3) Benzene monitoring may not be necessary where emissions of NMVOC are at the lower end of the range. </td> </tr> </table>	Benzene ⁽³⁾	<1 mg/Nm ³	(1) Hourly values in continuous operation expressed and measured according to Directive 94/63/EA (2) Lower value achievable with two-stage hybrid systems. Upper value achievable with single-stage adsorption or membrane system (3) Benzene monitoring may not be necessary where emissions of NMVOC are at the lower end of the range.									
Benzene ⁽³⁾	<1 mg/Nm ³												
(1) Hourly values in continuous operation expressed and measured according to Directive 94/63/EA (2) Lower value achievable with two-stage hybrid systems. Upper value achievable with single-stage adsorption or membrane system (3) Benzene monitoring may not be necessary where emissions of NMVOC are at the lower end of the range.													
53	In order to reduce emissions to water from visbreaking and other thermal processes, BAT is to ensure the appropriate treatment of waste water streams by applying the techniques of BAT 11.	NA	<p>Visbreaking or other thermal processes are not carried out at the installation.</p> <p>This BAT Conclusion is not applicable to the relevant activities carried out at this installation.</p>	NA									
54	In order to reduce sulphur emissions to air from off-gases containing hydrogen sulphides (H₂S), BAT is to use all of the techniques given below.	NA	<p>There are only trace quantities of H₂S present in the incoming gas streams and no acid gas removal, SRU or TGTU processing steps are required. Section 4 of the Technical plan confirms that gas composition has been relatively stable throughout the 20 year life of the field, with the typical gas composition provided in table 4.1. The H₂S composition is zero in this table.</p> <p>We agree this BAT Conclusion is not applicable to the relevant activities carried out at this installation.</p>	NA									
	<table border="1"> <thead> <tr> <th>Technique</th> <th>Description</th> <th>Applicability</th> </tr> </thead> <tbody> <tr> <td>i. Acid gas removal e.g. by amine treating</td> <td>See section 1.20.3, Annex 1.</td> <td>Generally applicable</td> </tr> <tr> <td>ii. Sulphur recovery unit (SRU), e.g. by Claus process</td> <td>See section 1.20.3, Annex 1.</td> <td>Generally applicable</td> </tr> </tbody> </table>	Technique	Description	Applicability	i. Acid gas removal e.g. by amine treating	See section 1.20.3, Annex 1.	Generally applicable	ii. Sulphur recovery unit (SRU), e.g. by Claus process	See section 1.20.3, Annex 1.	Generally applicable			
Technique	Description	Applicability											
i. Acid gas removal e.g. by amine treating	See section 1.20.3, Annex 1.	Generally applicable											
ii. Sulphur recovery unit (SRU), e.g. by Claus process	See section 1.20.3, Annex 1.	Generally applicable											

BAT Conclusion Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition(s)			
	iii. Tail gas treatment unit (TGTU)	See section 1.20.3, Annex 1.	For retrofitting existing SRU, the applicability may be limited by the SRU size and configuration of the units and the type of sulphur recovery process already in place						
(1) My not be applicable for stand-alone lubricant or bitumen refineries with a release of sulphur compounds of less than 1 t/d			<p>Table 17 BAT-associated environmental performance levels for a waste gas sulphur (H₂S) recovery system</p> <table border="1"> <thead> <tr> <th data-bbox="371 691 730 810"></th> <th data-bbox="730 691 1144 810">BAT-associated environmental performance level (monthly average)</th> </tr> </thead> <tbody> <tr> <td data-bbox="371 810 730 965">Acid gas removal</td> <td data-bbox="730 810 1144 965">Achieve hydrogen sulphides (H₂S) removal in the treated RFG in order to meet gas firing BAT-AEL for BAT 36</td> </tr> <tr> <td data-bbox="371 965 730 1093">Sulphur recovery efficiency (¹)</td> <td data-bbox="730 965 1144 1093">New unit: 99.5 – > 99.9 % Existing unit: ≥ 98.5 %</td> </tr> </tbody> </table> <p>(1) Sulphur recovery efficiency is calculated over the whole treatment chain (including SRU and TGTU) as the fraction of sulphur in the feed that is recovered in the sulphur stream routed to the collection pots. When the applied technique does not include a recovery of sulphur (e.g. seawater scrubber) it refers to the sulphur removal efficiency, as the % of sulphur removed by the whole treatment chain</p>		BAT-associated environmental performance level (monthly average)	Acid gas removal	Achieve hydrogen sulphides (H ₂ S) removal in the treated RFG in order to meet gas firing BAT-AEL for BAT 36	Sulphur recovery efficiency (¹)	New unit: 99.5 – > 99.9 % Existing unit: ≥ 98.5 %
	BAT-associated environmental performance level (monthly average)								
Acid gas removal	Achieve hydrogen sulphides (H ₂ S) removal in the treated RFG in order to meet gas firing BAT-AEL for BAT 36								
Sulphur recovery efficiency (¹)	New unit: 99.5 – > 99.9 % Existing unit: ≥ 98.5 %								
Acid gas removal	Achieve hydrogen sulphides (H ₂ S) removal in the treated RFG in order to meet gas firing BAT-AEL for BAT 36								
Sulphur recovery efficiency (¹)	New unit: 99.5 – > 99.9 % Existing unit: ≥ 98.5 %								

BAT Conclusion Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition(s)
	The associated monitoring is described in BAT 4.			

BAT Conclusion Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition(s)															
			The operator is CC with the requirements of this BAT Conclusion.																
56	<p>In order to reduce emissions to air from flares when flaring is unavoidable, BAT is to use the techniques given below.</p> <table border="1" data-bbox="367 523 1151 1117"> <thead> <tr> <th data-bbox="367 523 629 587">Technique</th> <th data-bbox="629 523 891 587">Description</th> <th data-bbox="891 523 1151 587">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="367 587 629 836">i. Correct plant design</td> <td data-bbox="629 587 891 836">See section 1.20.7, Annex 1.</td> <td data-bbox="891 587 1151 836">Applicable to new units. Flare gas recovery system may be retrofitted in existing units</td> </tr> <tr> <td data-bbox="367 836 629 932">ii. Plant management</td> <td data-bbox="629 836 891 932">See section 1.20.7, Annex 1.</td> <td data-bbox="891 836 1151 932">Generally applicable</td> </tr> <tr> <td data-bbox="367 932 629 1027">iii. Correct flaring devices design</td> <td data-bbox="629 932 891 1027">See section 1.20.7, Annex 1.</td> <td data-bbox="891 932 1151 1027">Applicable to new units</td> </tr> <tr> <td data-bbox="367 1027 629 1117">iv. Monitoring and reporting</td> <td data-bbox="629 1027 891 1117">See section 1.20.7, Annex 1.</td> <td data-bbox="891 1027 1151 1117">Generally applicable</td> </tr> </tbody> </table>	Technique	Description	Applicability	i. Correct plant design	See section 1.20.7, Annex 1.	Applicable to new units. Flare gas recovery system may be retrofitted in existing units	ii. Plant management	See section 1.20.7, Annex 1.	Generally applicable	iii. Correct flaring devices design	See section 1.20.7, Annex 1.	Applicable to new units	iv. Monitoring and reporting	See section 1.20.7, Annex 1.	Generally applicable	CC	<p>The operator confirmed that:</p> <p>The details of techniques employed for selection and use of the flare are detailed in section 4.3 of the Technical Plan and the Flare BAT Assessment Report. Information provided includes techniques to be employed covering:</p> <ul style="list-style-type: none"> • Plant and flare design requirements • Plant management arrangements • Process monitoring arrangements <p>In an email received 09 December 2021, the operator confirmed that there are no plans to monitor combustion temperature in the existing ground flare system.</p> <p>Flame monitoring equipment does not come as standard in the flare package as all performance criteria have been calculated to confirm adequate combustion efficiency by the manufacturer.</p> <p>The inlet manifolding allows for automatic selection of different configuration of burner heads subject to changes in inlet pressure. It is this option that ensures combustion efficiency across a wide range of flow-rates.</p>	2.3.1
Technique	Description	Applicability																	
i. Correct plant design	See section 1.20.7, Annex 1.	Applicable to new units. Flare gas recovery system may be retrofitted in existing units																	
ii. Plant management	See section 1.20.7, Annex 1.	Generally applicable																	
iii. Correct flaring devices design	See section 1.20.7, Annex 1.	Applicable to new units																	
iv. Monitoring and reporting	See section 1.20.7, Annex 1.	Generally applicable																	

BAT Conclusion Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition(s)
			<p>The manufacturers engineering document confirms flare performance across the full spectrum of anticipated rates and calculates combustion efficiency at over 99% across them.</p> <p>The operator has committed to providing a method for calculating emissions from the flare. We have secured this with a pre-operational condition in the permit.</p> <p>During normal operations at the facility there is no gas routed to flare. All on-specification gas is routed to pipeline for sales.</p> <p>The operator is CC with the requirements of this BAT Conclusion.</p>	
	<p>BAT Conclusions for integrated emission management</p> <p>BAT Conclusions 57 and 58</p>	NA	These BAT Conclusions are not applicable to the relevant activities carried out at this installation.	NA

Permitting Decisions- Variation (substantial)

Decision considerations

Standard rules criteria check

The application meets the criteria for the standard rules SR2018 No 7 applied for; however in this case the medium combustion plant directive (MCPD) does not apply. Refer to Operating techniques for combustion plant below.

Confidential information

A claim for commercial or industrial confidentiality has not been made.

Identifying confidential information

We have not identified information provided as part of the application that we consider to be confidential.

Consultation

The consultation requirements were identified in accordance with the Environmental Permitting (England and Wales) Regulations (2016) and our public participation statement.

The application was publicised on the GOV.UK website.

We consulted the following organisations:

- Food Standards Agency (FSA)
- East Lindsey District Council (Planning & Environmental Health)
- Lincolnshire County Council (LCC) (Planning & Environmental Health)
- National Grid
- Health & Safety Executive (HSE)
- Public Health England (PHE) / Director of Public Health (became the UK Health Security Agency (UKHSA) 01 October 2021)
- Mineral Planning Authority (MPA)
- Oil & Gas Authority (OGA)

The comments and our responses are summarised in the [consultation responses](#) section.

The regulated facility


We considered the extent and nature of the facilities at the site in accordance with RGN2 'Understanding the meaning of regulated facility', Appendix 2 of RGN2 'Defining the scope of the installation' and Appendix 1 of RGN 2 'Interpretation of Schedule 1'.

We have added the gas processing facilities which are defined by the following definitions in Part 2, Schedule 1 of the Environmental Permitting (England and Wales) Regulations (EPR) 2016:

Section 1.2 Part A(1)(a)	Refining gas where this is likely to involve the use of 1,000 or more tonnes of gas in any 12-month period.
Section 1.2 Part A(1)(e)(i)	The loading, unloading, handling or storage of, or the physical, chemical or thermal treatment of crude oil.

The extent of the facility is defined in the site plan and in the permit. The activities are defined in table S1.1 of the permit.

Process flow



The site

The operator has provided plans which we consider to be satisfactory.

These show the extent of the site of the facility.

The plan is included in the permit.

Site condition report

The operator has provided a description of the condition of the site, which we consider is satisfactory. The decision was taken in accordance with our guidance on site condition reports and baseline reporting under the Industrial Emissions Directive.

Waste management plan

The operator has provided an updated waste management plan (WMP) which we consider is not satisfactory.

It would appear that the operator wishes to include the bulk of the detail within the WR11 submission rather than the WMP. We do not support this approach as it removes control from the permit as it cannot be incorporated into the operating techniques table. It is also a misuse of the WR11 notification process as this is generally about protection of groundwater rather than waste management.

We would expect to see a WMP which includes a full waste management matrix for all activities. This would include details of the types of waste, projected volumes, classifications, disposal routes and final destinations of any waste materials that may be produced. The summaries that have been included within sections 4.2, 4.3 and 4.4 lack detail and also include incorrect waste codes.

We would also expect the WMP to include a list of fluids and chemicals that are likely to be used during drilling activities. There is currently very little detail other than some safety data sheets in the appendices.

The storage arrangements set out within section 4.5 are questionable and provide no reassurance that the waste will be handled in a manner that prevents pollution. There's little information with regards to containment bunds other than stating that existing infrastructure will be used. We require assurance that they are fit for purpose by reference to their intended compliance with CIRIA C736.

Surface water discharges have been referenced as having a tertiary lining system. We require assurance that the existing liner is fit for purpose and that the containment is in line with current guidance.

Standard rules permit 2015 No1 may be used as a guide to the minimum amount of detail that we would expect to see in a WMP.

We have set a pre-operational condition to address the deficiencies.

Nature conservation, landscape, heritage and protected species and habitat designations

We have checked the location of the application to assess if it is within the screening distances we consider relevant for impacts on nature conservation, landscape, heritage and protected species and habitat designations. The application is within our screening distances for these designations.

We have already assessed the application (EPR/DB3504XY/A001) and its' potential to affect sites of nature conservation, landscape, heritage and protected species and habitat designations identified in the nature conservation screening report as part of the permitting process, refer to emergency flare assessment below.

We consider that the application will not affect any site of nature conservation, landscape and heritage, and/or protected species or habitats identified.

We have not consulted Natural England.

The decision was taken in accordance with our guidance.

Environmental risk

We have reviewed the operator's assessment of the environmental risk from the facility.

Noise impacts

Refer to Key issues section (NIA) of this document.

Odour impacts

The applicant identified the odour sources as follows:

- tanks and pipework;
- material and waste storage;
- fugitive releases in close proximity to the well-heads during side-track or work-over activities if required.

The impact assessment identified a number of control measures that are in place to minimise odour.

No cold venting is proposed from the new activities as the various process vents are routed to the flare and the condensate storage tank is designed to operate under slight vacuum (refer to the response provided for BAT Conclusion 49 above).

The impact assessment report was however, developed to cover both the existing equipment currently allowed under the existing permit which is not proposed to change as a result of this application as well as the new proposed plant and associated operations to ensure it covered all potential impact from the site. The specific item in the impact assessment (E5) relates to cold venting during an emergency, which is specific to the existing permitted equipment which includes a cold vent on the test separator. This vent would only operate if the high high pressure trip on the separator was triggered, which is very unlikely to occur. This would only occur where the high pressure trip fails to trigger plant isolation resulting in over pressurisation of the vessel.

We are satisfied with the measures in place; however there is provision in the permit for the submission of an odour management plan should it be required.

Emergency flare impact assessment

The assessment was based on a maximum annual operation of 876 hours. The flare unit will be used as a safety device for short, infrequent periods of time.

The proposed replacement flare is significantly smaller than the flare previously assessed. The total capacity of the original flare was 7,667 Nm³/hour, with that of the proposed flare being 5,000 Nm³/hour. The larger flare was evaluated at the time of the permit application (EPR/DB3504XY/A001) and the permit was issued 03 October 2016. We concluded that it did not have the potential to cause a significant impact on human health and ecological receptors. As this proposal is a betterment in terms of design and releases, we have not carried out any further assessment.

We have included measures in the permit to ensure that if operation of the flare were to exceed 876 hours/year then an assessment of the impact would be required. This requirement is set out in table S4.3 (Performance parameters). The previous limit in table S3.4 (Process monitoring) has also been amended from 7,667 Nm³/hour to 5,000 Nm³/hour and moved into table S3.1.

The operator's risk assessment is satisfactory.

Climate change

The operator confirmed that the site is located within a 3a Flood Zone, which is an area having a high probability of flooding (1 in 100 year or greater probability of river flooding or a 1 in 200 or greater annual probability of sea flooding in any year).

Based on the flooding risk, we have included the standard climate change permit condition and adapted it to refer to a climate change adaptation improvement condition that we have included. Whilst these requirements are generally just applicable to new bespoke permits, this variation is to add new gas processing facilities, which is more akin to a new application rather than a variation to the existing facilities. This is substantiated by the application fee which is based on the charge for a new application.

Operating techniques

Refer to Key issues section in this document: BAT Conclusions – refining of mineral oil and gas.

We have reviewed the techniques used by the operator and compared these with the relevant guidance notes and we consider them to represent appropriate techniques for the facility.

The operating techniques that the applicant must use are specified in table S1.2 in the environmental permit.

Operating techniques for combustion plant

The operator applied for the standard rules permit SR2018 No 7, for new, low risk, stationary Medium Combustion Plant between 1 to less than 20 MWth (in operation on or after 20/12/2018). This is to authorise five x 2.17 MWth MCPs fired on a gas mixture comprising 60% commercial grade and 40% off-specification grade. The off-specification grade is defined as refinery fuel gas (RFG).

Article 2 (3) (o) of the medium combustion plant directive (MCPD) confirms that the directive does not apply to combustion plants firing refinery fuels alone or with other fuels for the production of energy within mineral oil and gas refineries.

On this basis we have not set any limits or monitoring requirements for the MCPs.

Noise management

We consider that the activities carried out at the site have the potential to cause noise that might cause pollution outside the site. Refer to Key issues section (NIA) of this document.

We have set a pre-operational condition requiring the submission of a NMP prior to commissioning of the gas refining activities.

The approved plan will be incorporated into the operating techniques, table S1.2.

Updating permit conditions during consolidation

We have updated permit conditions to those in the current generic permit template as part of permit consolidation. The conditions will provide the same level of protection as those in the previous permit.

Changes to the permit conditions due to an Environment Agency initiated variation

We have varied the permit as stated in the variation notice.

We have removed improvement conditions IC1 to IC4 as they have been superseded and so are no longer relevant.

Raw materials/fuels

We have specified a sulphur content not exceeding 0.1% w/w for the diesel used for the back-up generators.

Pre-operational conditions

Pre-operational conditions are required for the new gas refining activities.

Based on the information in the application, we consider that we need to include the following pre-operational conditions.

Commissioning plan required.

Noise management plan - refer to the appropriate sections of this document.

Waste management plan - refer to the appropriate sections of this document.

Technical plan - refer to the appropriate sections of this document.

Surface water management and surface water monitoring plans - refer to the appropriate sections of this document.

BAT Conclusion 6 requiring a diffuse VOC monitoring plan - refer to the appropriate sections of this document.

CIRIA compliant bund required for the condensate separator.

Improvement programme

Based on the information on the application, we consider that we need to include an improvement programme.

We have included an improvement programme to ensure that the appropriate controls are in place for:

Commissioning of the gas refining activity.

Climate change adaptation - refer to the appropriate section of this document.

Noise - refer to the appropriate sections of this document.

Emission limits

No emission limits have been set, refer to 'Operating techniques for Combustion plant' section of this document.

Monitoring

Monitoring has changed as a result of this variation.

The monitoring requirements for the emergency flare in table S3.1 have been removed as they no longer apply to the new flare.

Process monitoring requirements for the emergency flare have been moved into table S3.1.

Reporting

We have amended reporting in the permit to include gas production and operation of the emergency gas flare.

Management system

We are not aware of any reason to consider that the operator will not have the management system to enable them to comply with the permit conditions.

The decision was taken in accordance with the guidance on operator competence and how to develop a management system for environmental permits.

Previous performance

We have assessed operator competence. There is no known reason to consider the applicant will not comply with the permit conditions.

We have checked our systems to ensure that all relevant convictions have been declared.

No relevant convictions were found. The operator satisfies the criteria in our guidance on operator competence.

Growth duty

We have considered our duty to have regard to the desirability of promoting economic growth set out in section 108(1) of the Deregulation Act 2015 and the guidance issued under section 110 of that Act in deciding whether to grant this permit variation.

Paragraph 1.3 of the guidance says:

“The primary role of regulators, in delivering regulation, is to achieve the regulatory outcomes for which they are responsible. For a number of regulators, these regulatory outcomes include an explicit reference to development or growth. The growth duty establishes economic growth as a factor that all specified regulators should have regard to, alongside the delivery of the protections set out in the relevant legislation.”

We have addressed the legislative requirements and environmental standards to be set for this operation in the body of the decision document above. The guidance is clear at paragraph 1.5 that the growth duty does not legitimise non-compliance and its purpose is not to achieve or pursue economic growth at the expense of necessary protections.

We consider the requirements and standards we have set in this permit are reasonable and necessary to avoid a risk of an unacceptable level of pollution. This also promotes growth amongst legitimate operators because the standards applied to the operator are consistent across businesses in this sector and have been set to achieve the required legislative standards.

Consultation Responses

The following summarises the responses to consultation with other organisations, our notice on GOV.UK for the public, and the way in which we have considered these in the determination process.

Responses from organisations listed in the consultation section

Response received from East Lindsey District Council, Assistant Director of Planning, reference N/158/01992/21/IC.

Advised that we also consult with Lincolnshire County Council (LCC) and the Environmental Protection Team at East Lindsey District Council.

We have already consulted with the Environmental Protection Team at East Lindsey District Council.

We consulted with LCC ^{Note 1} 28 September 2021.

Note 1: We were also a statutory consultee on the planning application for this gas refining plant, including power generation equipment, being determined by LCC. In order to implement the changes, the operator requires both planning permission and a variation to the environmental permit. The pollution control and planning regimes are intended to be complementary. We are only able to take into account those issues, which fall within the scope of the EPR. In our role of statutory consultee to LCC, we made comments about the noise impacts.

Response received from UK Health Security Agency (UKHSA) (previously PHE), Principal Environmental Public Health Scientist, dated 04 October 2021.

No issues raised.

Representations from individual members of the public

Response received from individual members of the public	
Planning permission	
<p>The planning application submitted to Lincolnshire County Council (LCC) referred to a sidetrack, which included a well test and clean-up. It was suggested that this would take two weeks, with an interval of two-three weeks between completion of drilling and the start of well testing.</p> <p>It was presumed that the planning consent was granted on the basis that this well test would be done.</p> <p>The company asserted in its investor Q&A session 29 September 2021 (printed on its website under "Media") that they were no longer planning to conduct a well test/clean-up.</p> <p>Clarification as to whether there are any safety or other issues involved in this decision, and if so, whether the operator has informed the Environment Agency and the other relevant regulatory authorities.</p>	<p>The Environment Agency are concerned with the management of extractive wastes from borehole drilling operations for the purpose of exploration, well workovers and decommissioning. The management of waste generated from the drilling of a side-track well from an existing borehole is included within these activities.</p> <p>Waste generated during well clean-up or testing activities must be handled safely and in line with the requirements of the sites environmental permit (ref: EPR/JB3107XB).</p> <p>Other aspects of a wells operation such as safety are the responsibility of other regulatory bodies such as the Health & Safety Executive (HSE) and do not directly fall within the Environment Agency's remit.</p>
<p>That the proposed variation to the permit reflects the planning permissions and permitted development previously obtained.</p>	<p>The variation application is consistent with the planning application.</p>
<p>That the application to vary an existing permit relates to a prior approval application approved 11 June 2020 reference N/158/00504/20 (LCC PL/0052/20) to construct a gas processing plant and planning application approved 7 August 2020 reference N/180/00971/20 (LCC PL/0060/20) to install and operate a gas pipe-line connecting Saltfleetby to the National Grid at Theddlethorpe. No significant variation to the approved variation has been identified</p>	<p>We have consulted with LCC and the MPA, refer to consultation section of this document.</p>

and as a consequence LCC and the Mineral Planning Authority (MPA) do not wish to comment further.	
<u>Operator competence</u> Concerned about staff competence and safety.	Refer to 'Management system' section of this document.
<u>Noise</u> Concerned about noise.	Refer to Noise impacts in the 'Environmental Risks' section of this document.
<u>Consultation</u> Concerned that they were not informed.	Our consultation requirements were identified in accordance with the Environmental Permitting (England and Wales) Regulations (2016) and our public participation statement. The application was publicised on the GOV.UK website.
<u>Water quality</u> Concerned about the impact on local bore-hole water.	No discharge of process waste water takes place at the site. Produced water will be removed from site by road tanker to an appropriately licenced off-site treatment facility.
<u>Operation</u> That they were informed that the process would take a few weeks; however this variation is for the long-term.	Our assessment of the operation is addressed throughout this document.
<u>Light pollution</u> Concerned about light pollution.	Pollution from light is primarily a concern for considering visual impacts and as such covered by the planning process. It was not considered to be a significant issue in the planning decision.
<u>Traffic</u> Concerned about traffic.	Refer to Noise impacts in the 'Environmental Risks' section of this document.

That the application is fully supported due to the UK dependency on imported gas during a substantial period of prices rises and providing local employment.

-