

# HS2

September 2022

## **Construction Noise and Vibration Monthly Report – July 2022**

**North Warwickshire Borough Council**

<b>Non-Technical Summary</b>	<b>1</b>
<b>Abbreviations and Descriptions</b>	<b>3</b>
<b>1 Introduction</b>	<b>4</b>
1.2 Measurement Locations	8
<b>2 Summary of Results</b>	<b>10</b>
2.1 Summary of Measured Noise and Vibration Levels	10
2.2 Exceedances of the LOAEL and SOAEL	13
2.3 Exceedances of Trigger Level	16
2.4 Complaints	16
<b>Appendix A Site Locations</b>	<b>18</b>
<b>Appendix B Monitoring Locations</b>	<b>27</b>
<b>Appendix C Data</b>	<b>39</b>

### List of tables

Table 1: Table of Abbreviations	3
Table 2: Monitoring Locations	8
Table 3: Summary of Measured dB $L_{Aeq}$ Data over the Monitoring Period	11
Table 4: Summary of Measured PPV Data over the Monitoring Period	13
Table 5: Summary of Exceedances of LOAEL and SOAEL	14
Table 6: Summary of Exceedances of Trigger Levels	16
Table 7: Summary of Complaints	17

# Non-Technical Summary

This Noise and Vibration Monitoring Report fulfils HS2 Limited's commitment detailed in the Environmental Minimum Requirements (EMRs), Annex 1, Code of Construction Practice, to present the results of noise and vibration monitoring carried out within North Warwickshire Borough Council (NWBC) area during the month of July 2022.

Within this period monitoring was undertaken at the following worksites:

- Noise monitoring was undertaken at the Kingsbury Main Compound worksite (ref.: KMC), where work activities included fence installation, stockpiling, road marking, services installations, road sweeping, installation of fuel pipes, material moving, asphalt laying, deliveries, and concrete works.
- Noise monitoring was undertaken at the Birmingham & Fazeley Canal Viaduct worksite (ref.: BFCV), where work activities included topsoil stripping and ground works.
- Noise and vibration monitoring were undertaken at the Marston Box/Marston Lane worksite (ref.: MB), where work activities included steel fixing, base slab preparation, stockpile removal, embankment removal, excavation and piling.
- Noise monitoring was undertaken at the Faraday Avenue Embankment and Underbridge worksite (ref.: FAEU), where work activities included stockpiling and trial hole excavation.
- Noise monitoring was not undertaken at the Water Orton South Compound worksite (ref.: WOSC), where work activities included installation of lighting tower foundations, steel works and deliveries.
- Noise monitoring was undertaken at the Attleboro Lane Overbridge worksite (ref.: ALO), where work activities included compound and pond construction, topsoil stripping, waste clearance, vegetation clearance and platform remediation works.
- Noise monitoring was undertaken at the Gilson Drive worksite (ref.: GLD), where work activities included haul road construction, de-vegetation, deliveries and fencing.
- Noise monitoring was undertaken at the Birmingham Road worksite (ref.: BRD), where work activities included de-vegetation and demolition.
- Noise monitoring was undertaken at the Coleshill Heath Road worksite (ref.: CHR), where work activities included ground removal for working platforms, excavation, stockpiling and lime stabilisation.

- Noise monitoring was undertaken at the Packington Embankment worksite (ref.: PE), where work activities included piling works, embankment works, concrete removal, surface stripping, material laying, existing access road concrete removal and materials relocation.
- Noise monitoring was undertaken at the Bickenhill Cutting worksite (ref.: BIC), where work activities included site clean-up.
- Noise monitoring was undertaken at The Island Project worksite (ref.: TIP), where no works took place during the month of July.

Further works, where monitoring did not take place, were undertaken at Gilson, Green Lane, where sewer line diversion was underway.

There were two (2) exceedances of the HS2 threshold levels for significant noise impacts, which are defined in Information Paper E23 (<https://www.gov.uk/government/publications/hs2-information-papers-environment>) during the reporting period.

There were no exceedances of trigger levels, as defined in Section 61 consents during the reporting period.

Two (2) complaints were received within the North Warwickshire area during the monitoring period.

# Abbreviations and Descriptions

The abbreviations, descriptions and project terminology used within this report can be found in Table 1.

Table 1: Table of Abbreviations

Acronym/Term	Definition
$L_{Aeq,T}$	See equivalent continuous sound pressure level
Ambient sound	A description of the all-encompassing sound at a given location and time which will include sound from many sources near and far. Ambient sound can be quantified in terms of the equivalent continuous sound pressure level, $L_{pAeq,T}$
Decibel(s), or dB	Between the quietest audible sound and the loudest tolerable sound there is a million to one ratio in sound pressure (measured in Pascal (Pa)). Because of this wide range, a level scale called the decibel (dB) scale, based on a logarithmic ratio, is used in sound measurement. Audibility of sound covers a range of approximately 0-140dB.
Decibel(s) A-weighted, or dB(A)	The human ear system does not respond uniformly to sound across the detectable frequency range and consequently instrumentation used to measure sound is weighted to represent the performance of the ear. This is known as the 'A weighting' and is written as 'dB(A)'.
Equivalent continuous sound pressure level, or $L_{Aeq,T}$	An index used internationally for the assessment of environmental sound impacts. It is defined as the notional unchanging level that would, over a given period of time (T), deliver the same sound energy as the actual time-varying sound over the same period. Hence fluctuating sound levels can be described in terms of an equivalent single figure value, typically expressed as a decibel level.
Exclusion of data	Measurement of noise levels can be affected by weather conditions such as prolonged periods of rain, winds speeds higher than 5m/s and snow/ice ground cover. Noise levels measured during these periods are considered not representative of normal noise conditions at the site and, for the purposes of this report, are excluded from the assessment of exceedances and calculation of typical noise levels and are also greyed out in charts. Identifiable incongruous noise and vibration events not attributable to HS2 construction noise are also excluded.
Façade	A facade noise level is the noise level 1m in front of a large reflecting surface. The effect of reflection, is to produce a slightly higher (typically +3 dB) sound level than it would be if the reflecting surface was not there.
Free-field	A free-field noise level is the noise level measured at a location where no reflective surfaces, other than the ground, lies within 3.5 metres of the microphone position.
LOAEL	Lowest Observed Adverse Effect Level - the level above which adverse effects on health and quality of life can be detected.
Peak particle velocity, or PPV	Instantaneous maximum velocity reached by a vibrating element as it oscillates about its rest position. The PPV is a simple indicator of perceptibility and risk of damage to structures due to vibration. It is usually measured in mm/s.
SOAEL	Significant Observed Adverse Effect Level - the level above which significant adverse effects on health and quality of life occur.
Sound pressure level	The parameter by which sound levels are measured in air. It is measured in decibels. The threshold of hearing has been set at 0dB, while the threshold of pain is approximately 120dB. Normal speech is approximately 60dB at a distance of 1 metre and a change of 3dB in a time varying sound signal is commonly regarded as being just detectable. A change of 10dB is subjectively twice, or half, as loud.
Vibration dose value, or VDV	An index used to evaluate human exposure to vibration in buildings. While the PPV provides information regarding the magnitude of single vibration events, the VDV provides a measure of the total vibration experienced over a specified period of time (typically 16h daytime and 8h night-time). It takes into account the magnitude, the number and the duration of vibration events and can be used to quantify exposure to continuous, impulsive, occasional and intermittent vibration. The vibration dose value is measured in $m/s^{1.75}$ .

# 1 Introduction

1.1.1 HS2 is required to undertake noise (and vibration) monitoring as necessary to comply with the requirements of the High Speed Rail (London-West Midlands) Environmental Minimum Requirements, including specifically Annex 1: Code of Construction Practice, in addition to any monitoring requirements arising from conditions imposed through consents under Section 61 of the Control of Pollution Act, 1974 or through Undertakings & Assurances given to third parties. Such monitoring may be undertaken for the following purposes:

- monitoring the impact of construction works;
- to investigate complaints, incidents and exceedance of trigger levels; or
- monitoring the effectiveness of noise and vibration control measures.

1.1.2 Monitoring data and interpretive reports are to be provided to each relevant local authority on a monthly basis and shall include a summary of the construction activities occurring, the data recorded over the monitoring period, any complaints received, any periods in exceedance of agreed trigger levels, the results of any investigations and any actions taken or mitigation measures implemented. This report provides noise data, and interpretation thereof, for monitoring carried out by HS2 within the North Warwickshire Borough Council (NWBC) area for the period 1<sup>st</sup> to 31<sup>st</sup> July 2022.

1.1.3 Construction sites in the local authority area where monitoring was undertaken during this period include:

Kingsbury Main Compound worksite, ref.: KMC (see Plan 1 in Appendix A), where work activities included:

- Stockpile movement;
- Fencing installation;
- Installation of road markings;
- Services installation;
- Road sweeping;
- Asphalt laying;
- Fuel pipe installation;
- Delivery of stone; and
- Concrete works (foundations and bases).

- Birmingham & Fazeley Canal Viaduct worksite, ref.: BFCV (see Plan 1 in Appendix A), where works included:
  - Topsoil stripping; and
  - Ground works.
- Marston Box/Marston Lane worksite, ref.: MB (see Plan 1 in Appendix A), where work activities included:
  - Steel fixing of guide rafts and pre-fabrication cages;
  - Subsoil stockpile removal;
  - Piling; and
  - Embankment removal;
- Faraday Avenue Embankment and Underbridge worksite, ref.: FAEU (see Plan 2 in Appendix A), work activities included:
  - Stockpiling; and
  - Trial hole excavation.
- Water Orton South Compound worksite, ref.: WOSC (see Plan 3 in Appendix A), work activities included:
  - Concrete works;
  - Assembly of steel cages, foundations, formworks assembly; and
  - Material deliveries.
- Attleboro Lane Overbridge worksite, ref.: ALO (see Plan 3 in Appendix A), work activities included:
  - Compound and pond construction;
  - Topsoil stripping;
  - Waste clearance works;
  - Vegetation clearance; and
  - Platform remediation works.
- Gilson Drive worksite, ref.: GLD (see Plan 3 in Appendix A), works activities included:
  - Haul road construction;
  - De-vegetation;

- Deliveries; and
- Fencing
- Birmingham Road worksite, ref.: BRD (see Plan 4 in Appendix A), work activities included:
  - De-vegetation; and
  - Demolition.
- Coleshill Heath Road worksite, ref.: CHR (see Plan 5 in Appendix A), works activities included:
  - Ground removal for working platforms;
  - Excavations;
  - Stockpiling; and
  - Lime stabilisation.
- Packington Embankment worksite, ref.: PE (see Plan 6 in Appendix A), works activities included:
  - Piling works;
  - Embankment works;
  - Concrete removal;
  - Surface stripping;
  - Material laying;
  - Existing access road concrete removal; and
  - Ramp materials relocation.
- Bickenhill Cutting worksite, ref.: BIC (see Plan 6 in Appendix A), works activities included:
  - Site clean-up.
- The Island Project worksite: ref.: TIP (see Plan 7 in Appendix A), where no works took place during the month of July.

1.1.4 Further works, where noise and vibration monitoring did not take place, were also undertaken at Gilson Road as part of sewer diversion works.

1.1.5 The applicable standards, guidance, and monitoring methodology is outlined in the construction noise and vibration monitoring methodology report which can be found at the following location <https://www.gov.uk/government/collections/monitoring->



[the-environmental-effects-of-hs2](#). Noise and vibration monitoring reports for previous months can also be found at this location.

## 1.2 Measurement Locations

- 1.2.1 Thirteen (13) noise monitoring installations and six (6) vibration monitoring installations were active in July in the NWBC area. Table 2 summarises the position of noise and vibration monitoring installations within the NWBC area in July 2022.
- 1.2.2 Noise monitor, ref.: TIP-N1, was installed at The Island Project worksite ref.: TIP on 13<sup>th</sup> July 2022.
- 1.2.3 Noise monitor, ref,; CHR-N1, was installed at Coleshill Heath Road worksite ref.: CHR on 20<sup>th</sup> July 2022.
- 1.2.4 An additional noise monitor, ref,; GLD-V1, was installed at Gilson Drive worksite ref.: GLD on 5<sup>th</sup> July 2022.
- 1.2.5 Maps showing the position of noise and vibration monitoring installations are presented in Appendix B.

Table 2: Monitoring Locations

Worksite Reference	Measurement Reference	Address
Kingsbury Main Compound (KMC)	KMC-N1	Kingsbury Road, Curdworth CP, Marston, Warwick, West Midlands
	KMC-N2	Kingsbury Road, Curdworth CP, Marston, Warwick, West Midlands
Birmingham Fazeley Canal Viaduct (BFCV)	BFCV-N1	Lock Cottage, Marston Lane, Curdworth CP, North Warwickshire
	BFCV-V1	Lock Cottage, Marston Lane, Curdworth CP, North Warwickshire
Marston Box (MB)	MB-N1	Kingsbury Road, Curdworth, Sutton Coldfield, West Midlands
	MB-V1	Kingsbury Road, Curdworth, Sutton Coldfield, West Midlands
Faraday Avenue Embankment and Underbridge (FAEU)	FAEU-N1	Orchard Cottage, Newlands Lane, Curdworth, Warwickshire
	FAEU-V1	Orchard Cottage, Newlands Lane, Curdworth, Warwickshire
Water Orton South Compound (WOSC)	WOSC-N1	53 Watton Lane, Water Orton CP, Warwickshire
Attleboro Lane Overbridge (ALO)	ALO-N1	47 Attleboro Lane, Water Orton, Birmingham
	ALO-V1	47 Attleboro Lane, Water Orton, Birmingham
Gilson Drive (GLD)	GLD-N1	Gilson Dr, Coleshill, Birmingham
	GLD-V1	Gilson Dr, Coleshill, Birmingham
Birmingham Road (BRD)	BRD-N2	New Cottages, Birmingham Road, Coleshill, Birmingham
	BRD-V1	New Cottages, Birmingham Road, Coleshill, Birmingham
Coleshill Heath Road (CHR)	CHR-N1	Coleshill Heath Road, Coleshill Heath, Solihull

Worksite Reference	Measurement Reference	Address
Pakington Embankment (PE)	PE-N1	Common Farm, Chester Road, Coleshill, Birmingham
Bickenhill Cutting (BIC)	BIC-N1	Park Farm Barns, Chester Rd, Marston Green, Coventry
The Island Project (TIP)	TIP-N1	Diddington Hall Diddington Lane, Meriden

## 2 Summary of Results

### 2.1 Summary of Measured Noise and Vibration Levels

2.1.1 Table 3 presents a summary of the measured noise levels at each monitoring location over the reporting period. The  $L_{Aeq,T}$  is presented for each of the relevant time periods averaged over the calendar month, along with the highest single period  $L_{Aeq,T}$  that was found to occur within the month.

Table 3: Summary of Measured dB L<sub>Aeq</sub> Data over the Monitoring Period

Worksite Reference	Measurement Reference	Site Address	Free-Field or Façade Measurement	Weekday Average L <sub>Aeq,T</sub> (Highest Day L <sub>Aeq,T</sub> )					Saturday Average L <sub>Aeq,T</sub> (Highest Day L <sub>Aeq,T</sub> )					Sunday / Public Holiday Average L <sub>Aeq,T</sub> (Highest Day L <sub>Aeq,T</sub> )	
				0700 - 0800	0800 - 1800	1800 - 1900	1900 - 2200	2200 - 0700	0700 - 0800	0800 - 1300	1300 - 1400	1400 - 2200	2200 - 0700	0700 - 2200	2200 - 0700
KMC	KMC-N1	Kingsbury Road, Curdworth CP, Marston	Free-field	58.0 (60.7)	58.8 (61.5)	55.7 (66.6)	53.9 (58.1)	53.0 (58.9)	55.0 (55.6)	56.1 (61.3)	54.2 (55.7)	53.9 (57.6)	51.7 (54.7)	53.8 (58.1)	53.6 (57.8)
	KMC-N2	Kingsbury Road, Curdworth CP, Marston	Free-field	55.0 (57.0)	57.6 (63.8)	53.7 (56.6)	52.9 (55.4)	52.3 (57.0)	53.3 (55.1)	53.6 (56.7)	52.5 (54.4)	52.6 (55.4)	51.5 (53.8)	52.9 (56.1)	53.0 (56.6)
BFCV	BFCV-N1	Lock Cottage, Marston Lane, Curdworth CP	Free-field	64.3 (67.5)	63.3 (65.9)	65.1 (69.3)	63.4 (67.8)	63.2 (69.8)	62.6 (64.4)	69.2 (81.5)	71.8 (89.9)	66.7 (82.1)	60.5 (65.3)	66.0 (78.1)	64.0 (68.3)
MB	MB-N1	Kingsbury Road, Curdworth, Sutton Coldfield	Free-field	56.7 (60.0)	56.3 (59.0)	56.2 (62.3)	55.6 (62.3)	52.5 (58.6)	55.1 (56.4)	55.1 (57.0)	52.8 (54.3)	54.4 (58.1)	51.0 (56.0)	54.9 (62.0)	53.5 (57.7)
FAEU	FAEU-N1	Orchard Cottage, Newlands Lane, Curdworth	Free-field	57.9 (70.7)	65.0 (71.3)	56.1 (61.3)	54.7 (60.4)	54.4 (61.6)	56.2 (58.3)	56.2 (58.9)	55.4 (57.9)	55.9 (60.8)	53.5 (58.6)	56.4 (62.6)	55.1 (60.6)
WOSC	WOSC-N1	53 Watton Lane, Water Orton CP	Free-field	64.9 (65.7)	68.8 (71.5)	64.2 (65.9)	62.4 (63.9)	59.7 (64.7)	60.2 (60.6)	62.5 (62.7)	62.8 (63.1)	62.1 (65.4)	56.3 (58.6)	62.8 (65.3)	58.4 (62.8)
ALO	ALO-N1	47 Attleboro Lane, Water Orton	Free-field	54.4 (60.4)	60.9 (66.6)	53.3 (57.8)	52.8 (57.4)	51.7 (58.6)	53.3 (56.7)	54.0 (57.8)	52.7 (58.4)	54.1 (60.8)	52.4 (57.3)	54.6 (61.5)	53.2 (59.2)

Worksite Reference	Measurement Reference	Site Address	Free-Field or Façade Measurement	Weekday Average $L_{Aeq,T}$ (Highest Day $L_{Aeq,T}$ )					Saturday Average $L_{Aeq,T}$ (Highest Day $L_{Aeq,T}$ )					Sunday / Public Holiday Average $L_{Aeq,T}$ (Highest Day $L_{Aeq,T}$ )	
				0700 - 0800	0800 - 1800	1800 - 1900	1900 - 2200	2200 - 0700	0700 - 0800	0800 - 1300	1300 - 1400	1400 - 2200	2200 - 0700	0700 - 2200	2200 - 0700
GLD	GLD-N1	10 Gilson Dr, Coleshill, Birmingham	Free-field	57.2 (60.7)	57.6 (62.9)	55.4 (61.7)	54.1 (58.7)	53.9 (61.2)	53.7 (58.4)	55.3 (57.1)	54.0 (56.0)	53.7 (58.0)	53.2 (60.5)	55.7 (69.0)	55.9 (69.2)
BRD	BRD-N2	1, New Cottages, Birmingham Road, Coleshill	Free field	61.4 (63.6)	61.1 (76.5)	57.8 (63.0)	59.6 (64.3)	57.5 (64.0)	57.8 (59.9)	59.9 (61.6)	60.0 (60.7)	59.4 (62.1)	56.0 (59.1)	59.5 (62.4)	57.7 (62.2)
CHR	CHR-N1	Coleshill Heath Road, Coleshill Heath, Solihull	Free-field	63.1 (64.4)	64.7 (65.9)	61.6 (62.7)	60.2 (61.6)	57.6 (63.8)	58.9 (59.4)	59.8 (60.0)	60.5 (60.9)	59.9 (60.7)	55.2 (58.1)	60.0 (61.3)	56.6 (61.4)
PE	PE-N1	Common Farm, Chester Road, Coleshill	Free-field	56.9 (60.0)	59.5 (62.0)	54.9 (58.8)	55.0 (58.1)	52.8 (60.0)	54.3 (56.2)	56.8 (60.7)	55.6 (59.8)	55.3 (58.7)	53.1 (59.0)	55.2 (60.2)	54.7 (59.4)
BIC	BIC-N1	Park Farm Barns, Chester Rd, Marston Green	Free-field	55.0 (59.8)	55.5 (61.0)	53.4 (68.1)	52.1 (59.9)	51.6 (64.9)	51.8 (54.9)	52.5 (54.8)	52.2 (55.0)	53.9 (62.7)	51.9 (64.3)	52.7 (63.4)	52.8 (59.3)
TIP	TIP-N1	Diddington Hall Diddington Lane, Meriden	Façade	51.4 (56.2)	50.0 (53.3)	48.2 (50.7)	47.7 (52.8)	46.6 (61.2)	46.1 (48.6)	53.1 (57.5)	50.4 (55.4)	48.1 (55.6)	45.2 (50.5)	48.6 (54.8)	46.5 (53.6)

2.1.2 Table 4 presents a summary of the measured vibration levels at the monitoring location over the reporting period. The highest PPV measured during the monitoring along any axis is presented in the table.

Table 4: Summary of Measured PPV Data over the Monitoring Period

Worksite Reference	Measurement Reference	Monitor Address	Highest PPV measured in any axis, mm/s
BFCV - Birmingham Fazeley Canal	BFCV-V1	Lock Cottage, Marston Lane, Curdworth CP, North Warwickshire, B76 0DG	0.71 (X-axis)
MB - Marston Box	MB-V1	Kingsbury Road, Curdworth, Sutton Coldfield, West Midland, B76 0DF	0.85 (X-axis)
ALO - Attleboro Lane Overbridge	ALO-V1	47 Attleboro Lane, Water Orton, Birmingham, B46 1SB	0.81 (X-axis)
BRD - Birmingham Road	BRD-V1	1, New Cottages, Birmingham Road, Coleshill, Birmingham B46 1DP	7.45 (X-axis)
FAEU - Orchard Cottage	FAEU-V1	Orchard Cottage, Newlands Lane, Curdworth, Warwickshire, B76 0BE	3.51 (Z-axis)
GLD - Gilson Drive	GLD-V1	10 Gilson Dr, Coleshill, Birmingham B46 1DN	1.37 (X-axis)

2.1.3 Appendix C presents graphs of the noise and vibration monitoring data over the month for each of the measurement locations. Noise data presented consists of the hourly  $L_{Aeq}$  values and, where relevant, the  $L_{Aeq,T}$  values (where the time period T has been taken to be the averaging period as specified in Table 1 of HS2 Information Paper E23). Vibration data presented consist of hourly PPV values. The full data set for the monitoring equipment can be found at the following location:

<https://data.gov.uk/dataset/24542ae7-dd44-444f-b259-871c4cc43b5e/environmental-monitoring-data>.

## 2.2 Exceedances of the LOAEL and SOAEL

2.2.1 The lowest observed adverse effect level (LOAEL) is defined in the Planning Practice Guidance – Noise (PPG) as the level above which "noise starts to cause small changes in behaviour and/or attitude, e.g. turning up volume of television; speaking more loudly; where there is no alternative ventilation, having to close windows for some of the time because of the noise. Potential for some reported sleep disturbance. Affects the acoustic character of the area such that there is a perceived change in the quality of life".

2.2.2 The significant observed adverse effect level (SOAEL) is defined in the 'Planning Practice Guidance – Noise' as the level above which "noise causes a material change in behaviour and/or attitude, e.g. avoiding certain activities during periods of

intrusion; where there is no alternative ventilation, having to keep windows closed most of the time because of the noise. Potential for sleep disturbance resulting in difficulty in getting to sleep, premature awakening and difficulty in getting back to sleep. Quality of life diminished due to change in acoustic character of the area."

2.2.3 HS2 Phase One Information Paper E23: Control of Construction Noise and Vibration sets out the LOAELs and SOAELs for construction noise.

2.2.4 Where reported construction noise levels exceed the LOAEL and SOAEL, relevant periods will be identified. Summary statistics to evaluate ongoing qualification for noise insulation and temporary rehousing are also presented where relevant.

2.2.5 Table 5 presents a summary of recorded exceedances of the LOAEL and SOAEL at each measurement location over the reporting period, including the number of exceedances during each time period.

Table 5: Summary of Exceedances of LOAEL and SOAEL

Worksite Reference	Measurement Reference	Site Address	Day (Weekday, Saturday, Sunday, Night)	Time period	Number of exceedances of LOAEL	Number of exceedances of SOAEL
KMC	KMC-N1*	Wheatley House, Kingsbury Road, Sutton Coldfield	All days	All periods	No exceedances	No exceedances
	KMC-N2	Wheatley House, Kingsbury Road, Sutton Coldfield	Weekdays	0800-1800	1	No exceedances
BFCV	BFCV-N1	Lock Cottage, Marston Lane, Curdworth	Weekend	0800 – 1300	1	1
MB	MB-N1*	Kingsbury Road, Curdworth	All days	All periods	No exceedances	No exceedances
FAEU	FAEU-N1	Orchard Cottage, Newlands Lane, Curdworth	Weekdays	0800-1800	14	No exceedances



Worksite Reference	Measurement Reference	Site Address	Day (Weekday, Saturday, Sunday, Night)	Time period	Number of exceedances of LOAEL	Number of exceedances of SOAEL
WOSC	WOSC-N1	53 Watton Lane, Water Orton CP, Warwickshire	Weekdays	0800-1800	1	No exceedances
ALO	ALO-N1	47 Attleboro Lane, Water Orton, Birmingham	All days	All periods	6	No exceedances
BRD	BRD-N2	New Cottages, Birmingham Road, Coleshill, Birmingham B46 1DP	Weekdays	08:00-18:00	1	1
PE	PE-N1	Common Farm, Chester Road, Coleshill	All days	All periods	1	No exceedances
BIC	BIC-N1	Park Farm Barns, Chester Rd, Marston Green	All days	All periods	No exceedances	No exceedances
TIP	TIP-N1	Diddington Hall Diddington Lane, Meriden	All days	All periods	No exceedances	No exceedances
CHR	CHR-N1	Coleshill Heath Road, Coleshill Heath, Solihull	Weekdays	08:00-18:00	8	No exceedances
GLD	GLD-N1	Gilson Dr, Coleshill, Birmingham	Weekdays	08:00-18:00	1	No exceedances

\* A distance correction has been applied when calculating exceedances of the LOAEL and SOAEL.

2.2.6 Thirty- Four (34) exceedances of the LOAEL were recorded at KMC, BFCV, WOSC, ALO, BRD, PE, CHR, FAEU and GLD worksites during core working hours.

OFFICIAL

2.2.7 For the purpose of assessing eligibility for noise insulation or temporary rehousing, multiple exceedances of the SOAEL in a 24-hour period would be counted as a single exceedance during that day. Over the reporting period, the overall number of SOAEL exceedances at each measurement location is shown in Table 6 and may be lower than the total sum of individual exceedances reported in Table 4 for each location.

Table 6 - Summary of Total Exceedances of SOAEL

Worksite Reference	Measurement Reference	Monitor Address	Total of SOAEL exceedances in the month
BRD	BRD-N2	New Cottages, Birmingham Road, Coleshill	1
BFCV	BFCV-N1	Lock Cottage, Marston Lane, Curdworth	1

2.2.8 Two (2) exceedances of SOAEL were recorded at monitoring location ref.: BRD-N2 and monitoring location ref.: BFCV-N1 due to HS2 construction works during July 2022.

## 2.3 Exceedances of Trigger Level

2.3.1 Table 7 provides a summary of exceedances of the Section 61 trigger noise levels determined to be due to HS2 related construction noise measured during the reporting period, along with the findings of any investigation.

Table 7: Summary of Exceedances of Trigger Levels

Complaint Reference Number (if applicable)	Worksite Reference	Date and Time Period	Identified Source	Results of Investigation (including noise monitoring results)	Actions Taken
-	-	-	-	-	-


## 2.4 Complaints

2.4.1 Table 8 provides a summary of complaint information related to noise and vibration received during the reporting period, along with the findings of any investigation.


Table 8: Summary of Complaints


Complaint Reference Number	Worksite Reference	Description of Complaint	Results of Investigation	Actions Taken
HS2-22-43791-C	WOSC	High levels of vibrations were felt in house.	Local monitoring has taken place, it has shown the measured vibration levels showed no exceedance of the SOAEL or consented levels.	The community engagement team has responded back to the complainant and a meeting has been offered to stakeholder.
HS2-22-43842-C	ALO	High levels of vibrations were felt in house.	Levels have been monitored and no exceedances found.	The community engagement team has responded back to the complainant and a meeting has been offered to stakeholder.


# Appendix A Site Locations





























# Appendix B Monitoring Locations














































# Appendix C Data

## Noise




The following graphs show the hourly measured ambient noise level  $L_{Aeq,1h}$  and, where relevant, the averaged noise level  $L_{Aeq,T}$  values, where the time period T is as specified in Table 1 of HS2 Information Paper E23. Periods with adversely weather affected noise levels are greyed out and have been excluded from the calculation of the  $L_{Aeq,T}$  values in Table 3 of the main report.:

### Worksite: FAEU – Monitoring Ref: FAEU-N1








## Worksite: KMC – Monitoring Ref: KMC-N1







OFFICIAL





## Worksite: KMC - Monitoring Ref: KMC-N2













**Worksite: MB - Monitoring Ref: MB-N1**








## Worksite: BFCV – Monitoring Ref: BFCV-N1








### Worksite: WOSC – Monitoring Ref: WOSC-N1




Note: Missing data from 00:00 on 1<sup>st</sup> until 12:00 on 22<sup>nd</sup> of July was due to vegetation infestation of the monitoring station.


OFFICIAL



**Worksite: ALO – Monitoring Ref: ALO-N1**






Note: Missing data from 21:00 on Friday 1<sup>st</sup> July until 09:00 on Monday 4<sup>th</sup> July was due to a firmware error within the monitoring station.




Note: Missing data from 21:00 on Friday 1<sup>st</sup> July until 09:00 on Monday 4<sup>th</sup> July was due to a firmware error within the monitoring station.



**OFFICIAL**





## Worksite: BRD - Monitoring Ref: BRD-N2







Note: Missing data Friday 26<sup>th</sup> at 1700 due to an intermittent power issue.








**Worksite: PE - Monitoring Ref: PE-N1**











**Worksite: BIC - Monitoring Ref: BIC-N1**










## Worksite: TIP - Monitoring Ref: TIP-N1




Note: Noise monitor installed at 16:00 on Wednesday 13<sup>th</sup> July.




## Worksite: CHR - Monitoring Ref: CHR-N1






Note: Noise monitor installed at 1400 Wednesday 20<sup>th</sup> July.




## Worksite: GLD - Monitoring Ref: GLD-N1



OFFICIAL












## Vibration

The following graphs show the hourly measured peak particle velocity PPV recorded during the monitoring period. The graphs show the highest PPV of the three orthogonal axes x, y and z. Where high values of PPV were caused by local interference with the vibration monitor, which are not representative of HS2 construction works, these values have been greyed out in the following charts and have been excluded to calculate values in Table 4 of the main report.

### Worksite: MB - Monitoring Ref: MB-V1







Note: Missing data 0900 Thursday 28<sup>th</sup> July was due to an intermittent issue with the meter.

OFFICIAL


## Worksite: ALO – Monitoring Ref: ALO-V1




Note: Excluded levels during core working hours are due to works in close proximity to the monitor resulting in levels unrepresentative of the nearest receptor approximately 60m away. An alternative monitoring location is currently being sought. Missing data 0400 2nd July - 0100 3rd July was due to a power supply issue.




Note: Excluded levels during core working hours are due to works in close proximity to the monitor resulting in levels unrepresentative of the nearest receptor approximately 60m away. An alternative monitoring location is currently being sought.



Note: Excluded levels during core working hours are due to works in close proximity to the monitor resulting in levels unrepresentative of the nearest receptor approximately 60m away. An alternative monitoring location is currently being sought.






Note: Excluded levels during core working hours are due to works in close proximity to the monitor resulting in levels unrepresentative of the nearest receptor approximately 60m away. An alternative monitoring location is currently being sought.





Note: Excluded levels during core working hours are due to works in close proximity to the monitor resulting in levels unrepresentative of the nearest receptor approximately 60m away. An alternative monitoring location is currently being sought.

OFFICIAL

## Worksite: BRD - Monitoring Ref: BRD-V1













Note: High vibration levels 26th July were due to a local disturbance.


### Worksite: BFCV – Monitoring Ref: BFCV-V1










**Worksite: FAEU – Monitoring Ref: FAEU-V1**






Note: High vibration levels 11<sup>th</sup> July and 13<sup>th</sup> July were due to a local disturbance.



Note: High vibration levels 18<sup>th</sup> July and 23<sup>rd</sup> July were due to a local disturbance.



**Worksite: GLD – Monitoring Ref: GLD-V1**

