

# Permit with introductory note

## The Environmental Permitting (England & Wales) Regulations 2016

---

Amazon Data Services UK Limited  
Slough Data Centre Back-up Generation Facility  
110 Buckingham Avenue  
Trading Estate  
Slough  
Berkshire  
SL1 4PF

### **Permit number**

EPR/PP3309MK

# Slough Data Centre Back-up Generation Facility

## Permit number EPR/PP3309MK

### Introductory note

#### **This introductory note does not form a part of the permit**

The main features of the permit are as follows.

The site is part of a new electronic data storage centre which includes back-up generation capacity, a Schedule 1 S1.1 Part A(1) (a) activity under the Environmental Permitting Regulations (the burning of any fuel in an appliance with a rated thermal input of 50 or more megawatts (MW)). The site is located on Buckingham Avenue in Slough. The National Grid Reference for the site is SU 95697 81097. The nearest residential receptors are approximately 400 m to the north east and 500m to the east.

The combustion plant only operates under limited routine maintenance or in an emergency scenario if the National Grid power supply fails. The combustion activity comprises 20 gas oil fuelled standby generators (SBGs), 18 of the SBGs each have a thermal input of 8.13 MWth, the remaining two SBGs will have a thermal input of 2.5 MWth. The aggregated total combustion capacity on site is 151.34 MWth. Each generator has an exhaust, which is 23m above ground level. The Operator is intending to install 19 SBGs but an additional SBG may be installed in the future in order to future proof the site. The application and the air emissions assessment are based on the installation of all 20 SBGs. Of the 20 SBGs 2 will be inhouse generators which will provide emergency power to non-IT infrastructure at the data centre in the event of disruption in the grid power supply.

Electrical power is provided to the data centre from the National Grid. In the event of a failure of the electrical supply, the operator will utilise the generators to maintain power to the datacentre. The generators will be used solely for the purpose of providing a back-up power supply, with no electricity being exported from the installation. The datacentre will be developed in three phases; the first phase is for the installation of 9 SBGs, phase two (approximately 60 weeks after phase 1) is for the installation of 5 SBGs and the final phase, phase 3 is for the installation of the final 5/6 SBGs.

The generators are subject to a routine maintenance testing schedule at 45% load, with fortnightly testing for 30 minutes and quarterly testing for 1 hour. Every six months the generators will also be tested at 100% load for 1.5 hours. During this routine testing, each generator will be tested separately to minimise air quality impact. In addition there will also be an annual emergency test of all generators operating simultaneously and continuously for 4 hours. The testing scenarios total 24 hours operation per generator per year.

Each of the SBGs runs on gas oil fuel, each generator has a 'belly tank' with a capacity of 40,000 litres, the two-house generators each have a belly tank with a capacity of 14,000 litres. In addition, the site has two receiver tanks each with a capacity of 1,200 litres. The receiver tanks will be used to top up the belly tanks. The maximum volume of 750,400 litres of gas oil can be stored at the installation. The belly tanks are bunded to provide 110% containment, fitted with high-and low-level alarms, leak detection and tank level gauges.

The main emissions from the installation are to air in the form of nitrogen oxides, sulphur dioxide, particulate matter and carbon monoxide. The site is covered in hardstanding, uncontaminated surface water from the generator compounds is discharged via the surface water drainage system. The runoff will pass through a full retention oil interceptor prior to discharge to the onsite soakaway.

The status log of the permit sets out the permitting history, including any changes to the permit reference number.

<b>Status log of the permit</b>		
<b>Description</b>	<b>Date</b>	<b>Comments</b>
Application EPR/PP3309MK/A001	Duly made 25/02/2022	Application for a combustion facility consisting of 20 diesel engines providing emergency power to an electronic datacentre.
Further Information received, response to Schedule 5 Notice	28/09/2022	Updates to air quality modelling assessment, confirmation of engine standards and an updated site plan
Permit determined EPR/PP3309MK (Billing ref. PP3309MK)	19/01/2023	Permit issued to Amazon Data Services UK Limited.

End of introductory note

# Permit

## The Environmental Permitting (England and Wales) Regulations 2016

### Permit number

EPR/PP3309MK

The Environment Agency hereby authorises, under regulation 13 of the Environmental Permitting (England and Wales) Regulations 2016

**Amazon Data Services UK Limited** (“the operator”),

whose registered office is

**1 Principal Place  
Worship Street  
London  
EC2A 2FA**

company registration number 09959151

to operate an installation at

**Slough Data Centre Back-up Generation Facility  
110 Buckingham Avenue  
Trading Estate  
Slough  
Berkshire  
SL1 4PF**

to the extent authorised by and subject to the conditions of this permit.

Name	Date
<b>M Bischer</b>	<b>19/01/2023</b>

Authorised on behalf of the Environment Agency

# Conditions

## 1 Management

### 1.1 General management

1.1.1 The operator shall manage and operate the activities:

- (a) in accordance with a written management system that identifies and minimises risks of pollution, including those arising from operations, maintenance, accidents, incidents, non-conformances, closure and those drawn to the attention of the operator as a result of complaints; and
- (b) using sufficient competent persons and resources.

1.1.2 Records demonstrating compliance with condition 1.1.1 shall be maintained.

1.1.3 Any person having duties that are or may be affected by the matters set out in this permit shall have convenient access to a copy of it kept at or near the place where those duties are carried out.

### 1.2 Energy efficiency

1.2.1 The operator shall:

- (a) take appropriate measures to ensure that energy is used efficiently in the activities;
- (b) review and record at least every four years whether there are suitable opportunities to improve the energy efficiency of the activities; and
- (c) take any further appropriate measures identified by a review.

### 1.3 Efficient use of raw materials

1.3.1 The operator shall:

- (a) take appropriate measures to ensure that raw materials and water are used efficiently in the activities;
- (b) maintain records of raw materials and water used in the activities;
- (c) review and record at least every four years whether there are suitable alternative materials that could reduce environmental impact or opportunities to improve the efficiency of raw material and water use; and
- (d) take any further appropriate measures identified by a review.

### 1.4 Avoidance, recovery and disposal of wastes produced by the activities

1.4.1 The operator shall take appropriate measures to ensure that:

- (a) the waste hierarchy referred to in Article 4 of the Waste Framework Directive is applied to the generation of waste by the activities; and
- (b) any waste generated by the activities is treated in accordance with the waste hierarchy referred to in Article 4 of the Waste Framework Directive; and
- (c) where disposal is necessary, this is undertaken in a manner which minimises its impact on the environment.

- 1.4.2 The operator shall review and record at least every four years whether changes to those measures should be made and take any further appropriate measures identified by a review.

## **2 Operations**

### **2.1 Permitted activities**

- 2.1.1 The operator is only authorised to carry out the activities specified in schedule 1 table S1.1 (the “activities”).

### **2.2 The site**

- 2.2.1 The activities shall not extend beyond the site, being the land shown edged in green on the site plan at schedule 7 to this permit.

### **2.3 Operating techniques**

- 2.3.1 The activities shall, subject to the conditions of this permit, be operated using the techniques and in the manner described in the documentation specified in schedule 1, table S1.2, unless otherwise agreed in writing by the Environment Agency.
- 2.3.2 If notified by the Environment Agency that the activities are giving rise to pollution, the operator shall submit to the Environment Agency for approval within the period specified, a revision of any plan or other documentation (“plan”) specified in schedule 1, table S1.2 or otherwise required under this permit which identifies and minimises the risks of pollution relevant to that plan, and shall implement the approved revised plan in place of the original from the date of approval, unless otherwise agreed in writing by the Environment Agency.
- 2.3.3 For the following activities referenced in schedule 1, table S1.1: AR1. The activities shall not operate for more than 500 hours in emergency use per annum.
- 2.3.4 Any raw materials or fuels listed in schedule 2 table S2.1 shall conform to the specifications set out in that table.
- 2.3.5 The operator shall ensure that where waste produced by the activities is sent to a relevant waste operation, that operation is provided with the following information, prior to the receipt of the waste:
- (a) the nature of the process producing the waste;
  - (b) the composition of the waste;
  - (c) the handling requirements of the waste;
  - (d) the hazardous property associated with the waste, if applicable; and
  - (e) the waste code of the waste.
- 2.3.6 The operator shall ensure that where waste produced by the activities is sent to a landfill site, it meets the waste acceptance criteria for that landfill.

### **2.4 Improvement programme**

- 2.4.1 The operator shall complete the improvements specified in schedule 1 table S1.3 by the date specified in that table unless otherwise agreed in writing by the Environment Agency.
- 2.4.2 Except in the case of an improvement which consists only of a submission to the Environment Agency, the operator shall notify the Environment Agency within 14 days of completion of each improvement.

## **2.5 Pre-operational conditions**

- 2.5.1 The activities shall not be brought into operation until the measures specified in schedule 1 table S1.4 have been completed.

## **3 Emissions and monitoring**

### **3.1 Emissions to water, air or land**

- 3.1.1 There shall be no point source emissions to water, air or land except from the sources and emission points listed in schedule 3 tables S3.1 and S3.2.
- 3.1.2 Periodic monitoring shall be carried out at least once every 5 years for groundwater and 10 years for soil, unless such monitoring is based on a systematic appraisal of the risk of contamination.

### **3.2 Emissions of substances not controlled by emission limits**

- 3.2.1 Emissions of substances not controlled by emission limits (excluding odour) shall not cause pollution. The operator shall not be taken to have breached this condition if appropriate measures, including, but not limited to, those specified in any approved emissions management plan, have been taken to prevent or where that is not practicable, to minimise, those emissions.
- 3.2.2 The operator shall:
- (a) if notified by the Environment Agency that the activities are giving rise to pollution, submit to the Environment Agency for approval within the period specified, an emissions management plan which identifies and minimises the risks of pollution from emissions of substances not controlled by emission limits;
  - (b) implement the approved emissions management plan, from the date of approval, unless otherwise agreed in writing by the Environment Agency.
- 3.2.3 All liquids in containers, whose emission to water or land could cause pollution, shall be provided with secondary containment, unless the operator has used other appropriate measures to prevent or where that is not practicable, to minimise, leakage and spillage from the primary container.

### **3.3 Odour**

- 3.3.1 Emissions from the activities shall be free from odour at levels likely to cause pollution outside the site, as perceived by an authorised officer of the Environment Agency, unless the operator has used appropriate measures, including, but not limited to, those specified in any approved odour management plan, to prevent or where that is not practicable to minimise the odour.
- 3.3.2 The operator shall:
- (a) if notified by the Environment Agency that the activities are giving rise to pollution outside the site due to odour, submit to the Environment Agency for approval within the period specified, an odour management plan which identifies and minimises the risks of pollution from odour;
  - (b) implement the approved odour management plan, from the date of approval, unless otherwise agreed in writing by the Environment Agency.

### **3.4 Noise and vibration**

- 3.4.1 Emissions from the activities shall be free from noise and vibration at levels likely to cause pollution outside the site, as perceived by an authorised officer of the Environment Agency, unless the operator has used appropriate measures, including, but not limited to, those specified in any

approved noise and vibration management plan to prevent or where that is not practicable to minimise the noise and vibration.

3.4.2 The operator shall:

- (a) if notified by the Environment Agency that the activities are giving rise to pollution outside the site due to noise and vibration, submit to the Environment Agency for approval within the period specified, a noise and vibration management plan which identifies and minimises the risks of pollution from noise and vibration;
- (b) implement the approved noise and vibration management plan, from the date of approval, unless otherwise agreed in writing by the Environment Agency.

## **3.5 Monitoring**

3.5.1 The operator shall, unless otherwise agreed in writing by the Environment Agency, undertake the monitoring specified in the following tables in schedule 3 to this permit:

- (a) point source emissions specified in tables S3.1 and S3.2.

3.5.2 The operator shall maintain records of all monitoring required by this permit including records of the taking and analysis of samples, instrument measurements (periodic and continuous), calibrations, examinations, tests and surveys and any assessment or evaluation made on the basis of such data.

3.5.3 Permanent means of access shall be provided to enable sampling/monitoring to be carried out in relation to the emission points specified in schedule 3 table S3.1 unless otherwise agreed in writing by the Environment Agency.

## **4 Information**

### **4.1 Records**

4.1.1 All records required to be made by this permit shall:

- (a) be legible;
- (b) be made as soon as reasonably practicable;
- (c) if amended, be amended in such a way that the original and any subsequent amendments remain legible, or are capable of retrieval; and
- (d) be retained, unless otherwise agreed in writing by the Environment Agency, for at least 6 years from the date when the records were made, or in the case of the following records until permit surrender:
  - (i) off-site environmental effects; and
  - (ii) matters which affect the condition of the land and groundwater.

4.1.2 The operator shall keep on site all records, plans and the management system required to be maintained by this permit, unless otherwise agreed in writing by the Environment Agency.

### **4.2 Reporting**

4.2.1 The operator shall send all reports and notifications required by the permit to the Environment Agency using the contact details supplied in writing by the Environment Agency.

4.2.2 A report or reports on the performance of the activities over the previous year shall be submitted to the Environment Agency by 31 January (or other date agreed in writing by the Environment Agency) each year. The report(s) shall include as a minimum:



- (a) a review of the results of the monitoring and assessment carried out in accordance with the permit including an interpretive review of that data;
  - (b) the performance parameters set out in schedule 4 table S4.2 using the forms specified in table S4.3 of that schedule;
  - (c) where conditions 2.3.3 applies, the hours of operation in any year.
- 4.2.3 Within 28 days of the end of the reporting period the operator shall, unless otherwise agreed in writing by the Environment Agency, submit reports of the monitoring and assessment carried out in accordance with the conditions of this permit, as follows:
- (a) in respect of the parameters and emission points specified in schedule 4 table S4.1;
  - (b) for the reporting periods specified in schedule 4 table S4.1 and using the forms specified in schedule 4 table S4.3; and
  - (c) giving the information from such results and assessments as may be required by the forms specified in those tables.
- 4.2.4 The operator shall, unless notice under this condition has been served within the preceding four years, submit to the Environment Agency, within six months of receipt of a written notice, a report assessing whether there are other appropriate measures that could be taken to prevent, or where that is not practicable, to minimise pollution.

## 4.3 Notifications

- 4.3.1 In the event:
- (a) that the operation of the activities gives rise to an incident or accident which significantly affects or may significantly affect the environment, the operator must immediately—
    - (i) inform the Environment Agency,
    - (ii) take the measures necessary to limit the environmental consequences of such an incident or accident, and
    - (iii) take the measures necessary to prevent further possible incidents or accidents;
  - (b) of a breach of any permit condition the operator must immediately—
    - (i) inform the Environment Agency, and
    - (ii) take the measures necessary to ensure that compliance is restored within the shortest possible time;
  - (c) of a breach of permit condition which poses an immediate danger to human health or threatens to cause an immediate significant adverse effect on the environment, the operator must immediately suspend the operation of the activities or the relevant part of it until compliance with the permit conditions has been restored.
- 4.3.2 Any information provided under condition 4.3.1 shall be confirmed by sending the information listed in schedule 5 to this permit within the time period specified in that schedule.
- 4.3.3 Where the Environment Agency has requested in writing that it shall be notified when the operator is to undertake monitoring and/or spot sampling, the operator shall inform the Environment Agency when the relevant monitoring and/or spot sampling is to take place. The operator shall provide this information to the Environment Agency at least 14 days before the date the monitoring is to be undertaken.
- 4.3.4 The Environment Agency shall be notified within 14 days of the occurrence of the following matters, except where such disclosure is prohibited by Stock Exchange rules:
- Where the operator is a registered company:
- (a) any change in the operator's trading name, registered name or registered office address; and

- (b) any steps taken with a view to the operator going into administration, entering into a company voluntary arrangement or being wound up.

Where the operator is a corporate body other than a registered company:

- (a) any change in the operator's name or address; and
- (b) any steps taken with a view to the dissolution of the operator.

In any other case:

- (a) the death of any of the named operators (where the operator consists of more than one named individual);
- (b) any change in the operator's name(s) or address(es); and
- (c) any steps taken with a view to the operator, or any one of them, going into bankruptcy, entering into a composition or arrangement with creditors, or, in the case of them being in a partnership, dissolving the partnership.

4.3.5 Where the operator proposes to make a change in the nature or functioning, or an extension of the activities, which may have consequences for the environment and the change is not otherwise the subject of an application for approval under the Regulations or this permit:

- (a) the Environment Agency shall be notified at least 14 days before making the change; and
- (b) the notification shall contain a description of the proposed change in operation.

4.3.6 The Environment Agency shall be given at least 14 days notice before implementation of any part of the site closure plan.

4.3.7 Where the operator has entered into a climate change agreement with the Government, the Environment Agency shall be notified within one month of:

- (a) a decision by the Secretary of State not to re-certify the agreement;
- (b) a decision by either the operator or the Secretary of State to terminate the agreement; and
- (c) any subsequent decision by the Secretary of State to re-certify such an agreement.

## **4.4 Interpretation**

4.4.1 In this permit the expressions listed in schedule 6 shall have the meaning given in that schedule.

4.4.2 In this permit references to reports and notifications mean written reports and notifications, except where reference is made to notification being made "immediately", in which case it may be provided by telephone.

# Schedule 1 – Operations

<b>Table S1.1 activities</b>			
<b>Activity reference</b>	<b>Activity listed in Schedule 1 of the EP Regulations</b>	<b>Description of specified activity</b>	<b>Limits of specified activity</b>
AR1	S1.1 A (1) (a) Burning any fuel in an appliance with a rated thermal input of 50 or more megawatts	<p>Operation of 20 emergency standby generators with a total thermal input of approximately 151.34 MWth.</p> <p>The generators will burn gas oil solely for the purpose of providing electricity to the installation in the event of a failure of supply from the National Grid and during maintenance testing.</p> <p>18 x 8.13 MWth engines 2 x 2.5 MWth engine (New Medium Combustion Plant)</p>	<p>From receipt of raw materials and generation of electricity to despatch of waste.</p> <p>Electricity produced at the installation cannot be exported to the National Grid.</p> <p>The emergency operational hours of the installation shall not exceed the specifications set out in condition 2.3.3.</p>
<b>Directly Associated Activity</b>			
AR2	Storage of raw materials		From receipt of raw materials to use within the facility.
AR3	Surface water drainage		Input to site drainage system until discharge to site soakaway via interceptors (emission point W1).

<b>Table S1.2 Operating techniques</b>		
<b>Description</b>	<b>Parts</b>	<b>Date Received</b>
Application	Application forms B2 and B3 and all referenced supporting information, including generators testing schedule (as detailed in Section 6.1 of Amazon Data Services UK Limited, Lon2 Data Centre, Slough Best Available Techniques and Operating Techniques).	Duly Made 24/02/2022
Response to further information request dated 17/08/2022	Response to question 1: restriction of operating envelope of the 4-hour emergency test (MSM2) to the hours between 8am and 6pm.	28/09/2022

<b>Table S1.3 Improvement programme requirements</b>		
<b>Reference</b>	<b>Requirement</b>	<b>Date</b>
IC1	<p><b>Air Quality Management Plan</b></p> <p>The Operator shall produce an Air Quality Management Plan in conjunction with the Local Authority outlining response measures to be taken in the event of a grid failure. This should include but not be limited to the following considerations:</p> <ul style="list-style-type: none"> <li>• The response should be tailored to reflect the predicted potential impact indicated by the air dispersion modelling at individual receptors;</li> <li>• Specific timescales for response measures;</li> <li>• How local conditions during a grid failure might influence the response required, for example meteorological conditions or time of day;</li> <li>• Contingency for how the response will be carried out in the event scenario i.e. loss of power;</li> <li>• Selection of appropriate times for full-scale testing of the generators;</li> <li>• Timescales for continued review of the management plan.</li> </ul> <p>The agreed Air Quality Management Plan shall be submitted to the Environment Agency for approval.</p>	19 July 2024 or as agreed in writing with the Environment Agency
IC2	<p><b>Monitoring of emissions</b></p> <p>The operator shall submit a monitoring plan for approval by the Environment Agency detailing their proposal for the implementation of the flue gas monitoring requirements specified in Table S3.1, in line with web guide 'Monitoring stack emissions: low risk MCPs and specified generators' Published 16 February 2021 (formerly known as TGN M5). The plan shall include, but not be limited to:</p> <ul style="list-style-type: none"> <li>- When the generators are not fitted with sampling ports, a proposal to install them within the shortest practical timeline;</li> <li>- Details of any relevant safety, cost and operational constraints affecting the monitoring regime, in support of any proposed deviation from the testing regime specified in table S3.1.</li> </ul>	19 April 2023 or as agreed in writing with the Environment Agency

<b>Table S1.4 Pre-operational measures</b>	
<b>Reference</b>	<b>Operation</b>
PO1	<p><b>Commissioning plan</b></p> <p>At least 1 month before operation the operator shall submit a commissioning plan to the Environment Agency for approval. The plan will provide timescales for the commissioning of the gas-oil generators and shall demonstrate that the commissioning of the gas-oil generators is covered within the site's permitted regular testing regime, thereby minimising durations and impacts. When the commissioning is not covered within the site's permitted regular testing regime, the operator shall submit an environmental risk assessment for approval by the Environment Agency, demonstrating that the environmental risks during the commissioning are minimised and remain not significant. The commissioning of the engines shall not begin prior to receiving written approval to the plan and associated environmental risk assessment by the Environment Agency.</p> <p>The plan shall be implemented in accordance with the Environment Agency's written approval.</p>

## Schedule 2 – Waste types, raw materials and fuels

<b>Table S2.1 Raw materials and fuels</b>	
<b>Raw materials and fuel description</b>	<b>Specification</b>
Sulphur content in gas oil fuel	0.001% max

## Schedule 3 – Emissions and monitoring

Table S3.1 Point source emissions to air – emission limits and monitoring requirements						
Emission point ref. & location	Source	Parameter	Limit (including unit)	Reference period	Monitoring frequency	Monitoring standard or method
A1 to A20 Emission points from generators as shown on site plan in schedule 7	Gas oil fuelled generator exhausts 18 x 8.13 MWth 2 x 2.5 MWth	Oxides of Nitrogen (NO and NO <sub>2</sub> expressed as NO <sub>2</sub> )	No limit set	In line with web guide 'Monitoring stack emissions: low risk MCPs and specified generators' Published 16 February 2021 (formerly known as TGN M5)	Every 1500 hours of operation or once every five years (whichever comes first). [Note 1]	In line with web guide 'Monitoring stack emissions: low risk MCPs and specified generators' Published 16 February 2021 (formerly known as TGN M5)
		Carbon monoxide	No limit set	In line with web guide 'Monitoring stack emissions: low risk MCPs and specified generators' Published 16 February 2021 (formerly known as TGN M5)	Every 1500 hours of operation or once every five years (whichever comes first). [Note 1]	In line with web guide 'Monitoring stack emissions: low risk MCPs and specified generators' Published 16 February 2021 (formerly known as TGN M5)
		Sulphur dioxide	No limit set	-	No requirement	-
		Particulate Matter	No limit set	-	No requirement	-
Pressure relief valves	20 x gas oil generators  2 x gas oil receiver tanks	No parameter set	No limit set	-	No requirement	-
Note 1: Unless otherwise agreed in writing with the Environment Agency as a result of approval of Improvement Condition IC2.						

**Table S3.2 Point Source emissions to water (other than sewer) and land – emission limits and monitoring requirements**

Emission point ref. & location	Source	Parameter	Limit (incl. Unit)	Reference period	Monitoring frequency	Monitoring standard or method
W1 Emission point SW1 as shown on site plan in schedule 7	Uncontaminated surface water via interceptor	-	-	-	-	-

## Schedule 4 – Reporting

<b>Table S4.1 Reporting of monitoring data</b>			
<b>Parameter</b>	<b>Emission or monitoring point/reference</b>	<b>Reporting period</b>	<b>Period begins</b>
Emissions to air Parameters as required by condition 3.5.1.	A1 to A20	Every 1500 hours of operation or once every five years (whichever comes first).	Within 4 months of the issue date of the permit or the date when the engine is first put into operation, whichever is later. [Note 1]
Note 1: Unless otherwise agreed in writing with the Environment Agency as a result of approval of Improvement Condition IC2.			

<b>Table S4.2 Performance parameters</b>		
<b>Parameter</b>	<b>Frequency of assessment</b>	<b>Units</b>
Gas oil usage	Annually	Tonnes
Generator operation for maintenance	Report to be submitted annually	<ul style="list-style-type: none"> <li>- Total hours for the site (hours),</li> <li>- Total hours per generator (hours),</li> <li>- Total number of runs per generator (quantity)</li> <li>- Number of minutes per run (minutes)</li> </ul>
Generator operation during emergency scenario	Within 24 hours if operation commences	<ul style="list-style-type: none"> <li>- Date and time of grid failure,</li> <li>- Number of generators operating immediately after the failure,</li> <li>- Number of generators operating two hours after failure,</li> <li>- Anticipated duration of the mains supply failure (hours)</li> </ul>
Generator operation during emergency scenario	Annually	<ul style="list-style-type: none"> <li>- Total number of runs (quantity)</li> <li>- Duration of runs (hours)</li> </ul>



<b>Table S4.3 Reporting forms</b>		
<b>Media/parameter</b>	<b>Reporting format</b>	<b>Date of form</b>
Air	Emissions to Air Reporting Form or other form as agreed in writing by the Environment Agency	Version 1, 08/03/2021
Other performance indicators	Form 'performance 1' or other form as agreed in writing by the Environment Agency	28/11/2022
Generator operation during emergency scenario	Form 'emergency scenario' or other form as agreed in writing by the Environment Agency	28/11/2022

# Schedule 5 – Notification

These pages outline the information that the operator must provide.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the EP Regulations.

## Part A

Permit Number	
Name of operator	
Location of Facility	
Time and date of the detection	

<b>(a) Notification requirements for any malfunction, breakdown or failure of equipment or techniques, accident, or emission of a substance not controlled by an emission limit which has caused, is causing or may cause significant pollution</b>	
<b>To be notified within 24 hours of detection</b>	
Date and time of the event	
Reference or description of the location of the event	
Description of where any release into the environment took place	
Substances(s) potentially released	
Best estimate of the quantity or rate of release of substances	
Measures taken, or intended to be taken, to stop any emission	
Description of the failure or accident.	

<b>(b) Notification requirements for the breach of a limit</b>	
<b>To be notified within 24 hours of detection unless otherwise specified below</b>	
Emission point reference/ source	
Parameter(s)	
Limit	
Measured value and uncertainty	
Date and time of monitoring	

<b>(b) Notification requirements for the breach of a limit</b>	
<b>To be notified within 24 hours of detection unless otherwise specified below</b>	
Measures taken, or intended to be taken, to stop the emission	

<b>Time periods for notification following detection of a breach of a limit</b>	
<b>Parameter</b>	<b>Notification period</b>

<b>(c) Notification requirements for the breach of permit conditions not related to limits</b>	
<b>To be notified within 24 hours of detection</b>	
Condition breached	
Date, time and duration of breach	
Details of the permit breach i.e. what happened including impacts observed.	
Measures taken, or intended to be taken, to restore permit compliance.	

<b>(d) Notification requirements for the detection of any significant adverse environmental effect</b>	
<b>To be notified within 24 hours of detection</b>	
Description of where the effect on the environment was detected	
Substances(s) detected	
Concentrations of substances detected	
Date of monitoring/sampling	

## Part B – to be submitted as soon as practicable

Any more accurate information on the matters for notification under Part A.	
Measures taken, or intended to be taken, to prevent a recurrence of the incident	

Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	
The dates of any unauthorised emissions from the facility in the preceding 24 months.	

Name*	
Post	
Signature	
Date	

\* authorised to sign on behalf of the operator

## Schedule 6 – Interpretation

“accident” means an accident that may result in pollution.

“application” means the application for this permit, together with any additional information supplied by the operator as part of the application and any response to a notice served under Schedule 5 to the EP Regulations.

“authorised officer” means any person authorised by the Environment Agency under section 108(1) of The Environment Act 1995 to exercise, in accordance with the terms of any such authorisation, any power specified in section 108(4) of that Act.

“Energy efficiency” means the annual net plant energy efficiency, the value for which is calculated from the operational data collected over the year.

“EP Regulations” means The Environmental Permitting (England and Wales) Regulations SI 2016 No.1154 and words and expressions used in this permit which are also used in the Regulations have the same meanings as in those Regulations.

“emissions of substances not controlled by emission limits” means emissions of substances to air, water or land from the activities, either from the emission points specified in schedule 3 or from other localised or diffuse sources, which are not controlled by an emission or background concentration limit.

“groundwater” means all water, which is below the surface of the ground in the saturation zone and in direct contact with the ground or subsoil.

“Industrial Emissions Directive” means DIRECTIVE 2010/75/EU OF THE EUROPEAN PARLIAMENT AND OF THE COUNCIL of 24 November 2010 on industrial emissions, as read in accordance with Schedule 1A to the Environmental Permitting (England and Wales) Regulations 2016.

“Medium Combustion Plant” or “MCP” means a combustion plant with a rated thermal input equal to or greater than 1 MW but less than 50 MW.

“Medium Combustion Plant Directive” or “MCPD” means Directive 2015/2193/EU of the European Parliament and of the Council on the limitation of emissions of certain pollutants into the air from medium combustion plants, as read in accordance with Schedule 1A to the Environmental Permitting (England and Wales) Regulations 2016.


“Waste Framework Directive” or “WFD” means Waste Framework Directive 2008/98/EC of the European Parliament and of the Council on waste, as read in accordance with Schedule 1A to the Environmental Permitting (England and Wales) Regulations 2016.

Unless otherwise stated, any references in this permit to concentrations of substances in emissions into air means:

- in relation to emissions from combustion processes, the concentration in dry air at a temperature of 273K, at a pressure of 101.3 kPa and with an oxygen content of 3% dry for liquid and gaseous fuels other than gas engines or gas turbines, 6% dry for solid fuels; and/or
- in relation to emissions from gas engines or gas turbines, the concentration in dry air at a temperature of 273K, at a pressure of 101.3 kPa and with an oxygen content of 15% dry for liquid and gaseous fuels.

“year” means calendar year ending 31 December.

# Schedule 7 – Site plan



END OF PERMIT

Permit number  
EPR/PP3309MK