



Marine
Management
Organisation

**MARINE AND COASTAL ACCESS ACT 2009
SECTION 72**

DEEMED MARINE LICENCE - NOTICE OF VARIATION

THE DOGGER BANK CREYKE BECK OFFSHORE WIND FARM ORDER 2015 (AS AMENDED), SCHEDULE 10

VARIATION NUMBER:

6

AUTHORISED DEVELOPMENT:

Dogger Bank A&B Offshore Wind Farms Order 2015

UNDERTAKER:

Dogger Bank A&B Offshore Windfarms
1 Waterloo Street
Glasgow
United Kingdom
G2 6AY

DATE:

25/01/2023

COMPANY REGISTRATION NUMBER:

Project 2 Projco Limited 07914510

PREVIOUS VARIATIONS:

5

The Marine Management Organisation (“MMO”) received a request on 23 December 2022 from Dogger Bank A&B Offshore Wind Farm Projects (“the applicant”) for a variation to the deemed marine licence (“DML”) contained within Schedule 10 of the Dogger Bank Creyke Beck Offshore Wind Farm Order 2015 (“the Order”)

NOTICE IS HEREBY GIVEN that the MMO varies the DML in relation to the provision of the DML specified in the first column of the table in the Annex to this notice, by replacing the words set out in the second column of that table with the words set out in the third column of that table, in accordance with section 72(3)(d) of the Marine and Coastal Access Act 2009.

This variation has immediate effect from the date of this notice.

In accordance with regulation 3 of The Marine Licensing (Notices Appeals) Regulations 2011, you may appeal the notice of variation to the First-tier Tribunal. If you wish to appeal then in accordance with Rule 22(1)(b) of the Tribunal Procedure (First-tier Tribunal)(General Regulatory Chamber) Rules 2009 (SI 2009/1976) you have 28 days from the date of the sending of this notice to send or deliver a notice of appeal to the First- tier Tribunal.

Signed:



Name and Position: Luke Harto, Marine Licensing Case Officer

Date: 25 January 2023

Annex 1: Amendments to Schedule 10 contained within the Dogger Bank Creyke Beck Offshore Wind Farm Order 2015

Provision	Previous text	Replacement text
Schedule 10 Part B Condition 14 Construction Monitoring	where driven or part-driven pile foundations (for each specific foundation type) are proposed to be used, include measurements of noise generated by the installation of 1 pile from each of the first 4 structures with piled foundations, following which the MMO must determine whether further noise monitoring is required. The results of the initial noise measurements must be provided to the MMO within 6 weeks of the installation of the first	where driven or part-driven pile foundations (for each specific foundation type) are proposed to be used, include measurements of noise generated by the installation of 1 pile from each of the first 4 structures with piled foundations, following which the MMO must determine whether further noise monitoring is required. The results of the initial noise measurements must be provided to the MMO within 9 weeks of the installation of the first