

Product Recall

CPT 15 & 22 Temperature and Pressure Relief Valves		
Aspect	Details	
Images	EN 1490 (C) Reliance CPT15 WWRAS 10 NW 10 Dar 90-95°C	
Alert Number	2304-0079	
Product Type	Pressure equipment / vessels	
Product Identifiers	Product Codes PTEM540005 1/2 x 15mm 10 bar P&T 95mm probe c/w PTFE PTEM540010 1/2 x 15mm 7 bar P&T 95mm probe c/w PTFE PTEM540020 1/2 x 15mm 6 bar P&T 95mm probe c/w PTFE PTEM540025 15mm x 15mm 7 bar P&T 95mm probe no PTFE PTEM540100 1/2 x 15mm 7 bar P&T 195mm probe no PTFE PTEM540105 15mm x 15mm 7 bar P&T 195mm probe no PTFE PTEM540110 1/2 x 15mm 10 bar P&T 195mm probe no PTFE PTEM585200 3/4" x 22mm 4.5 bar P&T 95mm probe c/w PTFE PTEM585210 3/4" x 22mm 7 bar P&T 95mm probe c/w PTFE PTEM585250 3/4" x 22mm 10 bar P&T 95mm probe c/w PTFE PTEM585250 3/4" x 22mm 7 bar P&T 95mm probe c/w	
Product Description	Pressure and temperature relief valve	
Country of Origin	Germany	
Counterfeit	No	
Risk Type	Burns	
Risk Description	The valve's present a risk of burns as the valve cartridge is not sufficiently tight in the brass body. When manually operated, the valve cartridge may unscrew and allow hot water to escape.	
Corrective Measures	The product has been recalled from end users. For more information, please see: https://www.reliancevalves.com/gb/en/resources/news/product-safety-notice-cpt-15-22	
Online Marketplace	N/A	

The OPSS Product Safety Alerts, Reports and Recalls Site can be accessed at the following link: https://www.gov.uk/guidance/product-recalls-and-alerts



Product Recall

Notifier	Office for Product Safety and Standards
----------	---