

#### **Environment Agency**

# Review of an Environmental Permit for an Installation subject to Chapter II of the Industrial Emissions Directive under the Environmental Permitting (England & Wales) Regulations 2016

# Decision document recording our decision-making process following review of a permit

The Permit number is: EPR/WP3738DE The Operator is: GB Bio Limited

The Installation is: Tansterne Biomass Power Plant

This Variation Notice number is: EPR/WP3738DE/V003

#### What this document is about

Article 21(3) of the Industrial Emissions Directive (IED) requires the Environment Agency to review conditions in permits that it has issued and to ensure that the permit delivers compliance with relevant standards, within four years of the publication of updated decisions on best available techniques (BAT) conclusions.

We have reviewed the permit for this installation against the revised BAT Conclusions for waste incineration published on 3<sup>rd</sup> December 2019. This is our decision document, which explains the reasoning for the consolidated variation notice that we are issuing. This review has been undertaken with reference to the decision made by the European Commission establishing best available techniques (BAT) conclusions ('BAT conclusions') for incineration as detailed in document reference C(2019) 7987. It is our record of our decision-making process and shows how we have taken into account all relevant factors in reaching our position. It also provides a justification for the inclusion of any specific conditions in the permit that are in addition to those included in our generic permit template.

It explains how we will ensure that the installation complies with the BAT conclusions by 3<sup>rd</sup> December 2023. It is our record of our decision-making process and shows how we have taken into account all relevant factors in reaching our position. It also provides a justification for the inclusion of any specific conditions in the permit that are in addition to those included in our generic permit template.

Permit Review DD Issued 23/11/23 EPR/WP3738DE/V003 Page 1 of 28

As well as ensuring that the Installation complies with the BAT conclusions the consolidated variation notice takes into account and brings together in a single document all previous variations that relate to the original permit issued. It also modernises the entire permit to reflect the conditions contained in our current generic permit template.

The introduction of new template conditions makes the Permit consistent with our current general approach and philosophy and with other permits issued to installations in this sector. Although the wording of some conditions has changed, while others have been removed because of the new regulatory approach, it does not reduce the level of environmental protection achieved by the permit in any way. In this document we therefore address mainly our determination of substantive issues relating to the new BAT Conclusions.

Throughout this document we will use a number of expressions. These are as referred to in the glossary.

We try to explain our decision as accurately, comprehensively and plainly as possible. We would welcome any feedback as to how we might improve our decision documents in future. The use of technical terms and acronyms are inevitable in a document of this nature: we provide a glossary of acronyms near the front of the document, for ease of reference.

Permit Review DD Issued 23/11/23 EPR/WP3738DE/V003 Page 2 of 28

### How this document is structured

#### **Contents**

1	Glossary of acronyms used in this document	4
2	Our decision	5
3	How we reached our decision	5
3.2	Requesting information to demonstrate compliance with BAT Conclusion Plant	5 Ition 6
5	The key issues	3
5.1 5.2 5.3 5.4 6	Ensuring the Installation complies with the BAT conclusions	8 9 9
<b>6.1</b> <b>6.2</b> Ann	Waste types	C
Dec	cision checklist regarding relevant BAT Conclusions1	1
	Review and assessment of derogation requests made by the operator in tion to BAT Conclusions which include an associated emission level (AEL) ue	,
8	Summary checklist	7

# 1 Glossary of acronyms used in this document

(Please note that this glossary is standard for our decision documents and therefore not all these acronyms are necessarily used in this document.)

APC	Air Pollution Control
BAT	Best Available Technique(s)
BAT-AEEL	BAT Associated Energy Efficiency Level
BAT-AEPL	BAT Associated environmental performance level
BAT-AEL	BAT Associated Emission Level
BATc	BAT conclusion
BREF	Best available techniques reference document
CEM	Continuous emissions monitor
CHP	Combined heat and power
CV	Calorific value
DAA	Directly associated activity – Additional activities necessary to be carried out to allow the principal activity to be carried out
ELV	Emission limit value derived under BAT or an emission limit value set out in IED
EMS	Environmental Management System
EPR	Environmental Permitting (England and Wales) Regulations 2016 (SI 2016 No. 1154)
EWC	European waste catalogue
FSA	Food Standards Agency
IC	Improvement Condition
IED	Industrial Emissions Directive (2010/75/EU)
NOx	Oxides of nitrogen (NO plus NO <sub>2</sub> expressed as NO <sub>2</sub> )
PHE	Public Health England
SAC	Special Area of Conservation
SGN	Sector guidance note
TGN	Technical guidance note
TOC	Total Organic Carbon
WFD	Water Framework Directive (2000/60/EC)

Permit Review DD Issued 23/11/23 EPR/WP3738DE/V003 Page 4 of 28

#### 2 Our decision

We have decided to issue the consolidated variation notice to the operator. This will allow it to continue to operate the Installation, subject to the conditions in the consolidated variation notice.

We consider that, in reaching that decision, we have taken into account all relevant considerations and legal requirements and that the varied permit will ensure that a high level of protection is provided for the environment and human health.

The consolidated variation notice contains many conditions taken from our standard Environmental Permit template including the relevant Annexes. We developed these conditions in consultation with industry, having regard to the legal requirements of the Environmental Permitting Regulations and other relevant legislation. This document does not therefore include an explanation for these standard conditions. Where they are included in the Notice, we consider that those conditions are appropriate.

#### 3 How we reached our decision

# 3.1 Requesting information to demonstrate compliance with BAT Conclusions for incineration Plant

We issued a Notice under Regulation 61(1) of the Environmental Permitting (England and Wales) Regulations 2016 (a Regulation 61 Notice) on 31/08/22 requiring the Operator to provide information to demonstrate how the operation of their installation currently meets, or will subsequently meet, the revised standards described in the incineration BAT Conclusions document. The Notice also required that where the revised standards are not currently met, the operator should provide information that:

- Describes the techniques that will be implemented before 3<sup>rd</sup> December 2023, which will then ensure that operations meet the revised standard, or
- Justifies why standards will not be met by 3<sup>rd</sup> December 2023, and confirmation of the date when the operation of those processes will cease within the installation or an explanation of why the revised BAT standard is not applicable to those processes, or
- Justifies why an alternative technique will achieve the same level of environmental protection equivalent to the revised standard described in the BAT Conclusions.

Where the Operator proposed that they were not intending to meet a BAT standard that also included a BAT Associated Emission Level (BAT AEL) described in the BAT Conclusions Document, the Regulation 61 Notice requested that the Operator make a formal request for derogation from compliance with that AEL (as provisioned by Article 15(4) of IED). In this circumstance, the Notice identified that any such request for derogation must

Permit Review DD Issued 23/11/23 EPR/WP3738DE/V003 Page 5 of 28

be supported and justified by sufficient technical and commercial information that would enable us to determine acceptability of the derogation request.

The Regulation 61 Notice response from the Operator was received on 13/12/22.

We have not received any information in relation to the Regulation 61 Notice response that appears to be confidential in relation to any party.

3.2 Review of our own information in respect to the capability of the installation to meet revised standards included in the BAT Conclusions document

Based on our records and previous regulatory activities with the facility we have no reason to consider that the operator will not be able to comply with the conditions that we include in the permit.

Permit Review DD Issued 23/11/23 EPR/WP3738DE/V003 Page 6 of 28

#### 4 The legal framework

The consolidated variation notice will be issued under Regulation 20 of the EPR. The Environmental Permitting regime is a legal vehicle which delivers most of the relevant legal requirements for activities falling within its scope. In particular, the regulated facility is:

- an installation as described by the IED;
- subject to aspects of other relevant legislation which also have to be addressed.

We consider that the consolidated variation notice will ensure that the operation of the Installation complies with all relevant legal requirements and that a high level of protection will be delivered for the environment and human health.

We explain how we have addressed specific statutory requirements more fully in the rest of this document.

Permit Review DD Issued 23/11/23 EPR/WP3738DE/V003 Page 7 of 28

#### 5 The key issues

The key issues arising during this permit review are:

- Ensuring the Installation complies with the BAT conclusions.
- Setting emission limits (including BAT AELs) for emissions to air,
- The energy efficiency levels associated with the Best Available Techniques (BAT-AEELs)

#### 5.1 Ensuring the Installation complies with the BAT conclusions

We have reviewed the operator's response to the regulation 61 notice and we are satisfied that the Installation will meet the requirements of the BAT conclusions by 3<sup>rd</sup> December 2023. Further detail on our assessment is in annex 1 of this decision document.

Based on our records and previous regulatory activities with the Installation we have no reason to consider that the operator will not be able to comply with the conditions that we have included in the permit.

#### 5.2 Emissions to air and the emission limits applied to the plant

The consolidated permit includes new emission limits for emissions to air. These limits ensure that the installation will comply with the relevant BAT-AELs, as specified in the BAT conclusions, and the relevant limits from IED Annex VI.

A number of general principles were applied during the permit review, including those set out in the UK Waste Incineration BAT Conclusions Interpretation Document . These included:

- The upper value of the BAT-AELs ranges specified were used unless use of the tighter limit was justified.
- The principle of no backsliding where if existing limits in the permit were already tighter than the upper end of the BAT-AEL ranges, the existing permit limits were retained.
- Where a limit was specified in both IED Annex VI and the BAT Conclusions for a particular reference period, the tighter limit was applied and in the majority of cases this was from the BAT Conclusions.

We have set the emissions limit values at the top end of the BAT-AEL range in line with section 4.35 of Defra's Industrial emissions Directive EPR Guidance on Part A installations which states: Where the BAT AELs are expressed as a range, the ELV should be set on the basis of the top of the relevant BAT-AEL range – that is to say, at the highest associated emission level - unless the

Permit Review DD Issued 23/11/23 EPR/WP3738DE/V003 Page 8 of 28

installation is demonstrably capable of compliance with a substantially lower ELV, based on the BAT proposed by the operator, or exceptional environmental considerations compel a tighter ELV.

We are satisfied that environmental considerations do not require tighter ELVs to be set, and the operator has not proposed any lower ELVs, and so we have set the ELVs at the top end of the BAT-AEL ranges.

We have set IC9 which requires the operator to assess options to reduce NO<sub>X</sub> emissions below the top of the BAT AEL range.

#### 5.3 Energy efficiency

The BAT conclusions specify an energy efficiency level associated with the best available techniques (BAT-AEEL). The BAT AEEL is based on gross electrical efficiency, gross energy efficiency or boiler efficiency depending on the type of plant.

The relevant BAT AEEL for this installation is gross electrical efficiency.

The Applicant stated that gross electrical efficiency is 32.3%. This within the range specified in the BAT conclusions. The operator stated this would be reconfirmed when the plant is re-commissioned. Permit table S3.3 requires this to be carried out

#### 5.4 Monitoring

The monitoring requirements for mercury and dioxins/furans are dependent on whether the waste has low a low and stable mercury content and whether emissions of dioxins are stable respectively. Improvement conditions IC10 and IC11 require the operator to submit information to enable us to require the correct monitoring.

#### 6 Issues not directly relating to the BAT conclusions

#### 6.1 Waste types

Hazardous waste wood from demolition activities and other sources is sometimes chipped and blended with non-hazardous waste wood, and the resulting mixture sent to Chapter-IV compliant co-incinerators.

Permit Review DD Issued 23/11/23 EPR/WP3738DE/V003 Page 9 of 28

Although this mixed waste stream is pre-mixed hazardous, <u>RPS 250</u> currently means it can be moved as non-hazardous under a waste transfer note, and so co-incinerators have not been required to have hazardous waste codes in their permits.

RPS 250 expires in September 23. We have therefore included hazardous waste codes and other relevant conditions as part of this permit review. These changes will not lead to any change to the emissions from the plant as they will simply formalise what it is already allowed to do under RPS 250, and there will be no actual changes to the types of waste types received by the plant. However, changing a non-hazardous permitted plant to a hazardous permitted plant is a substantial change under IED, and we therefore consulted on the change from 28th June 2023 until 26th July 2023. Key issues from the responses received and how we considered them are set out below.

Brief summary of issues raised:	Summary of action taken / how this has
	been covered
Gasification should be used rather than incineration.	The addition of hazardous waste codes to the permit does not change our assessment that the technology used at the installation is BAT
Concern over emissions to air	The addition of the hazardous waste code will not change emissions to air and does not change our view that emissions will not be significant.

#### 6.2 Emissions to water or sewer

There are emission to water from

Boiler blowdown, reverse osmosis plant discharge, condensed steam and from a package sewage treatment plant. The emissions were assessed in the variation issued on 9/12/21. We have retained the improvement condition relating to this discharge.

Permit Review DD Issued 23/11/23 EPR/WP3738DE/V003 Page 10 of 28

#### Annex 1

# **Decision checklist regarding relevant BAT Conclusions**

This annex provides a record of decisions made in relation to each relevant BAT Conclusion applicable to the installation.

Permit Review DD Issued 23/11/23 EPR/WP3738DE/V003 Page 11 of 28

The overall status of compliance with the BAT conclusion is indicated in the table below as

NA - Not Applicable

CC - Currently Compliant FC - Compliant in the future (by 3<sup>rd</sup> December 2023)

NC - Not Compliant

BAT No.	Topic	Brief Description	Operator response	Complies with BAT? (NA, CC, FC, NC)
1	EMS	Improve overall performance via use of a compliant EMS.	The EMS meets the requirements of BAT 1 with the exception of waste acceptance/pre-acceptance procedures, OTNOC management plan, noise and vibration management plan, accident management plan and the EMS will be updated by 03/12/23 to ensure that it meets BAT 1	FC
2	Energy efficiency	Determine gross electrical efficiency, gross energy efficiency or boiler efficiency (depending on plant type).	Energy efficiency has been calculated using the design heat flow mass balance. Given that the site has not been operational since 2019 this will need to be recalculated after first fire in March 2023 but it is expected that the BAT requirement will be achieved.	FC

Permit Review DD Issued 23/11/23 EPR/WP3738DE/V003 Page 12 of 28

BAT No.	Topic	Brief Description	Operator response	Complies with BAT? (NA, CC, FC, NC)
3	Process Monitoring	Monitor key process parameters for emissions to air and water specified in the corresponding table.	Process monitoring is carried out in line with BAT 3 requirements for the following relevant parameters flow, temperature, pressure, moisture and oxygen content.	CC
4	Air emissions monitoring	Monitor emissions to air with at least the frequency in the corresponding table and in accordance with the EN standards.	Monitoring is carried out in line with BAT 4 requirements except for parameters tested periodically which include cadmium and thallium, heavy metals, hydrogen fluoride, dioxins and furans and PCBs which will be in place by 03/12/23	FC
	PBDD/F	Monitor emissions to air of brominated dioxins and furans periodically if waste streams are known to contain brominated flame retardants are burned	PBDD/F monitoring is not required as no waste containing brominated flame retardants are/will be burned	NA
	PCDD/F	Monitor emissions to air of dioxins and furans using a continuous sampler unless emissions are sufficiently stable.	Attempts will be made to demonstrate via the PCCD/F Monitoring Protocol that emissions to air of PCDD/F are sufficiently stable and that a continuous sampler (long-term monitoring) is not required by 03/12/23; if these are unsuccessful, continuous sampling will be installed as soon as reasonably practical.	FC

Permit Review DD Issued 23/11/23 EPR/WP3738DE/V003 Page 13 of 28

BAT No.	Topic	Brief Description	Operator response	Complies with BAT? (NA, CC, FC, NC)
	Mercury	Monitor emissions to air of mercury using continuous monitoring if required.	Attempts will be made to demonstrate via the Mercury Monitoring Protocol that emissions to air of mercury are low and stable and that a continuous sampler is not required by 03/12/23; if these are unsuccessful, continuous monitoring will be installed as soon as reasonably practical.	FC
5	OTNOC monitoring	Appropriately monitor emissions during OTNOC.  Monitor PCCD/F and dioxin-like PCB mass emissions during a planned start-up and shut-down following the successful commissioning of the plant; already-operational plants must carry out this monitoring every 3 years; emissions profiles of continuously monitored pollutants must also be established following successful commissioning and for existing plants; consider further monitoring for plants that use abatement-system bypasses during start-up and/or shut-down.	Plant has been successfully commissioned, or is likely to be before 03/12/23. Emissions profiles of continuously monitored pollutants have been established during start-up and shut-down or will be established by 03/12/23. Monitoring of PCCD/F and dioxin-like PCB mass emissions during a planned start-up and shut-down will be carried within 3 years of 03/12/23.	FC

Permit Review DD Issued 23/11/23 EPR/WP3738DE/V003 Page 14 of 28

BAT No.	Topic	Brief Description	Operator response	Complies with BAT? (NA, CC, FC, NC)
6	Water emissions	Monitor emissions from FGC and/or bottom ash treatment.  Monitor to frequencies and standards in corresponding table.	Not applicable as no emissions to water from FGC or bottom ash treatment.	NA
6	monitoring	Reduced monitoring frequency permitted if emissions can be shown to be sufficiently stable.	Not applicable as no emissions to water from FGC or bottom ash treatment.	NA
7	Ash monitoring	Monitor LOI or TOI content of bottom ash to the frequencies and standards in corresponding table .	Monitoring carried out for TOC	CC
8	POP monitoring	For hazardous waste containing POPs, monitor POP content of waste streams (applicable to dedicated hazardous waste incinerators only). After commissioning and then after significant change that could affect POP content.	Not applicable - plant is not a dedicated hazardous waste incinerator	NA

Permit Review DD Issued 23/11/23 EPR/WP3738DE/V003 Page 15 of 28

BAT No.	Topic	Brief Description	Operator response	Complies with BAT? (NA, CC, FC, NC)
9	Waste input controls	Pre-acceptance / acceptance procedures. Use all techniques (a) to (c) in corresponding table, and where relevant (d), (e) and (f).	Techniques set out in BAT 9 (a)-(c) will be place by 03/12/23. Techniques (d)-(f) are not relevant.	FC
10	Bottom ash treatment	Quality output management system part of EMS where bottom ash treatment is carried out.	Not applicable - bottom ash treatment is not carried out.	NA
11	Waste delivery, storage and handling	Monitor waste deliveries in line with corresponding table, depending on the risk posed by the waste type.	Measures in line with BAT 11 are in place	CC

Permit Review DD Issued 23/11/23 EPR/WP3738DE/V003 Page 16 of 28

BAT No.	Topic	Brief Description	Operator response	Complies with BAT? (NA, CC, FC, NC)
		Radioactivity detection	Not required - no increased risk identified	NA
12		Storage and handling. Use both techniques listed in corresponding table.	Measures in line with BAT 12 are in place	CC
13		Storage and handling of clinical waste. Combination of techniques listed in corresponding table.	Not applicable as clinical waste not received at the installation	NA
14	Overall environment performance	Reduce unburnt substances in slags / bottom ash and reduce emissions. Use a combination of techniques listed in corresponding table	The following measures listed in the table of BAT 14 are used: b, c	CC

Permit Review DD Issued 23/11/23 EPR/WP3738DE/V003 Page 17 of 28

BAT No.	Topic	Brief Description	Operator response	Complies with BAT? (NA, CC, FC, NC)
		BAT-AEPL for TOC or LOI	The installation meets the BAT-AEPL for TOC or LOI as shown by historic monitoring data	CC
15		Control plant settings to reduce emissions to air. Use techniques such as an advanced control system.	An advanced control system is in place to achieve the requirements of BAT 15.	CC
16		Procedures to limit shutdown and start-up. Set up and implement procedures such as continuous rather than batch operation	Start-up and shut-down is minimised by pre-set fuel specification to guarantee as consistent a material as possible for incineration as well as a continuous process outside of planned maintenance periods.	CC
17	Emission to air and water	Design of FGC system and waste water treatment plant. Appropriate design, operated in design range, maintained to ensure optimal availability.	Flue gas system is designed appropriately and is operated within those design parameters	CC

Permit Review DD Issued 23/11/23 EPR/WP3738DE/V003 Page 18 of 28

BAT No.	Topic	Brief Description	Operator response	Complies with BAT? (NA, CC, FC, NC)
18	OTNOC	Reduce frequency of OTNOC by setting up and implementing an OTNOC management plan.	An OTNOC management plan which meets the requirements of BAT 18 will be implemented by 03/12/23.	FC
19		Increase efficiency by using a heat recovery boiler.	A heat recovery boiler is used to generate electricity.	CC
	Energy efficiency	Increase efficiency by using a combination of techniques listed in corresponding table.	The following measures listed in the table of BAT 20 are used: c, d, h, i	CC
20		BAT-AEEL is within the BAT – AEEL range	The gross electrical efficiency is 32.3 %. To be demonstrated after first fire in March 2023 through a performance test.	СС

Permit Review DD Issued 23/11/23 EPR/WP3738DE/V003 Page 19 of 28

BAT No.	Topic	Brief Description	Operator response	Complies with BAT? (NA, CC, FC, NC)
21		Prevent or reduce diffuse emissions (including odour) using the listed techniques.	Measures in line with BAT 21 are in place	CC
22	Diffuse emissions to air	Prevent diffuse emissions of VOCs from gaseous and liquid wastes by direct feed to furnace.	Not applicable - gaseous or liquid waste are not accepted	NA
23		Prevent or reduce diffuse emissions to air from treatment of slags and bottom ashes by including listed measures in the EMS.	Not applicable - bottom ash treatment is not carried out.	NA
24		Prevent or reduce diffuse emissions to air from treatment of slags and bottom ashes. Use one or a combination of techniques in corresponding table	Not applicable - bottom ash treatment is not carried out.	NA

Permit Review DD Issued 23/11/23 EPR/WP3738DE/V003 Page 20 of 28

BAT No.	Topic	Brief Description	Operator response	Complies with BAT? (NA, CC, FC, NC)
		Reduce emissions of metals and metalloids from incineration of waste. Use one or a combination of techniques in corresponding table.	The following measures listed in the table of BAT 25 are used: a, c	CC
25	Channelled	BAT-AELs for dust and metals	The plant will be able to achieve an emission limit value set at the top end of the BAT-AEL range by 03/12/23.	FC
-	emissions to air	Reduce emissions of dust from treatment of slags and bottom ashes. Use a bag filter if treating air from treatment of IBA under sub-atmospheric conditions.	Not applicable - bottom ash treatment is not carried out.	NA
26		BAT-AEL for dust from IBA treatment. Applies if using a bag filter to treat air from treatment of IBA under sub-atmospheric conditions	Not applicable - bottom ash treatment is not carried out.	NA

Permit Review DD Issued 23/11/23 EPR/WP3738DE/V003 Page 21 of 28

BAT No.	Topic	Brief Description	Operator response	Complies with BAT? (NA, CC, FC, NC)
27		Reduce emissions of HCI, HF and SO <sub>2</sub> using one or a combination of techniques in corresponding table.	The following measures listed in the table of BAT 27 are used: c	CC
		Reduce peak emissions of HCl, HF and SO <sub>2</sub> and amount of residue produced, using technique (a) or both techniques in corresponding table.	The following measures listed in the table of BAT 28 are used: a, b	CC
28		BAT-AELs for HCl, HF and SO2	The plant will be able to achieve an emission limit value set at the top end of the BAT-AEL range by 03/12/23.	FC
29		Reduce emissions of NOx while limiting emissions of CO, N <sub>2</sub> O and NH <sub>3</sub> using appropriate combination of techniques in corresponding table.	The following measures listed in the table of BAT 29 are used: a, b, c, f	CC

Permit Review DD Issued 23/11/23 EPR/WP3738DE/V003 Page 22 of 28

BAT No.	Topic	Brief Description	Operator response	Complies with BAT? (NA, CC, FC, NC)
		BAT-AELs for NOx, CO and NH₃	The plant will be able to achieve an emission limit value set at the top end of the BAT-AEL range by 03/12/23.	FC
30		Reduce emissions of organic compounds including PCDD/F and PCBs using techniques (a), (b), (c), (d) and one or a combination of techniques (e) to (i) in corresponding table	The following measures listed in the table of BAT 30 are used: a, b, c, d, e	CC
		BAT-AELs for PCDD/F	The plant will be able to achieve an emission limit value set at the top end of the BAT-AEL range by 03/12/23.	FC
31		Reduce mercury emissions using one or a combination of techniques in the corresponding table.	The following measures listed in the table of BAT 31 are used: b, c	CC

Permit Review DD Issued 23/11/23 EPR/WP3738DE/V003 Page 23 of 28

BAT No.	Topic	Brief Description	Operator response	Complies with BAT? (NA, CC, FC, NC)
		BAT-AEL for mercury	The plant will be able to achieve an emission limit value set at the top end of the BAT-AEL range by 03/12/23.	FC
32	Emissions to water	Reduce contamination of uncontaminated water, reduce emissions to water and increase resource efficiency. Segregate waste water streams and treat them separately.	The measures listed under BAT 32 are used.	CC
33	Water usage	Reduce water usage, prevent waste water generation using one or a combination of techniques in the corresponding table	The following measures listed in the table of BAT 33 are used: a, c, d	CC
34	Emissions to water	Reduce emissions to water from FGC and/or from storage and treatment of slags and bottom ashes using one or a combination of techniques in the corresponding table and use secondary techniques as close to source as possible.	Not applicable - no direct or indirect emissions to water from FGC or bottom ash treatment	NA

Permit Review DD Issued 23/11/23 EPR/WP3738DE/V003 Page 24 of 28

BAT No.	Topic	Brief Description	Operator response	Complies with BAT? (NA, CC, FC, NC)
		BAT-AELs	Not applicable - no direct or indirect emissions to water from FGC or bottom ash treatment	NA
35	Resource	Resource efficiency. Handle and treat bottom ashes separately from FGC residues.	Bottom ashes are handled and treated separately from FGC residues.	CC
36	efficiency	Resource efficiency for treatment of slags and bottom ashes. Use appropriate combination of techniques in corresponding table depending on hazardous properties of the slags and bottom ashes.	Not applicable - bottom ash treatment is not carried out.	NA
37	Noise	Reduce noise emissions using one or a combination of techniques in the corresponding table.	The following measures listed in the table of BAT 37 will be implemented by 03/12/23: a, b, d, e	CC

Permit Review DD Issued 23/11/23 EPR/WP3738DE/V003 Page 25 of 28

7 Review and assessment of derogation requests made by the operator in relation to BAT Conclusions which include an associated emission level (AEL) value

The IED enables a competent authority to allow derogations from BAT AELs stated in BAT Conclusions under specific circumstances as detailed under Article 15(4):

By way of derogation from paragraph 3, and without prejudice to Article 18, the competent authority may, in specific cases, set less strict emission limit values. Such a derogation may apply only where an assessment shows that the achievement of emission levels associated with the best available techniques as described in BAT conclusions would lead to disproportionately higher costs compared to the environmental benefits due to:

- (a) the geographical location or the local environmental conditions of the installation concerned; or
- (b) the technical characteristics of the installation concerned.

As part of their Regulation 61 Note response, the operator has not requested a derogation from compliance with any AEL values.

Permit Review DD Issued 23/11/23 EPR/WP3738DE/V003 Page 26 of 28

# 8 Summary checklist

Aspect considered	Decision		
Receipt of application			
Confidential information	A claim for commercial or industrial confidentiality has not been made.		
Identifying confidential information	We have not identified information provided as part of the application that we consider to be confidential.		
	The decision was taken in accordance with our guidance on confidentiality.		
Operating techniques			
General operating techniques	We have reviewed the techniques used by the operator where they are relevant to the BAT Conclusions and compared these with the relevant guidance notes.		
	The permit conditions ensure compliance with the relevant BREF, BAT Conclusions. The ELVs deliver compliance with the BAT-AELs.		
Permit conditions			
Updating permit conditions during consolidation	We have updated permit conditions to those in the current generic permit template as part of permit consolidation. The conditions will provide at least the same level of protection as those in the previous permit and in some cases will provide a higher level of protection to those in the previous permit.		
Changes to the permit conditions due to an Environment Agency initiated variation	We have varied the permit as stated in the variation notice.		
Improvement programme	Based on the information on the application, we consider that we need to impose an improvement programme.		
Emission limits	We have decided that emission limits should be set for the parameters listed in the permit.		
	These are described in the relevant BAT Conclusions in Section 5 of this document.		
	It is considered that the ELVs/equivalent parameters or technical measures described above will ensure that significant pollution of the environment is prevented and a high level of protection for the environment is secured.		

Permit Review DD Issued 23/11/23 EPR/WP3738DE/V003 Page 27 of 28

Aspect considered	Decision	
Monitoring	We have decided that monitoring should be carried out for the parameters listed in the permit, using the methods detailed and to the frequencies specified.	
	These are described in the relevant BAT Conclusions in Section 5 of this document.	
Operator competence		
Management system	There is no known reason to consider that the operator will not have the management system to enable it to comply with the permit conditions.	
Growth Duty		
Section 108 Deregulation Act 2015 – Growth duty	We have considered our duty to have regard to the desirability of promoting economic growth set out in section 108(1) of the Deregulation Act 2015 and the guidance issued under section 110 of that Act in deciding whether to grant this permit.	
	Paragraph 1.3 of the guidance says:	
	"The primary role of regulators, in delivering regulation, is to achieve the regulatory outcomes for which they are responsible. For a number of regulators, these regulatory outcomes include an explicit reference to development or growth. The growth duty establishes economic growth as a factor that all specified regulators should have regard to, alongside the delivery of the protections set out in the relevant legislation."	
	We have addressed the legislative requirements and environmental standards to be set for this operation in the body of the decision document above. The guidance is clear at paragraph 1.5 that the growth duty does not legitimise non-compliance and its purpose is not to achieve or pursue economic growth at the expense of necessary protections.	
	We consider the requirements and standards we have set in this permit are reasonable and necessary to avoid a risk of an unacceptable level of pollution. This also promotes growth amongst legitimate operators because the standards applied to the operator are consistent across businesses in this sector and have been set to achieve the required legislative standards.	

Permit Review DD Issued 23/11/23 EPR/WP3738DE/V003 Page 28 of 28