

From: Planning <planning@uttlesford.gov.uk>
Sent: 02 January 2024 14:29
To: Section 62A Applications <section62a@planninginspectorate.gov.uk>
Subject: FW: [External] LSBUD Ref: 31975252 Your Ref: S62A/2023/0031 Planning Application Holding Objection

From: plantprotection@cadentgas.com <plantprotection@cadentgas.com>
Sent: 02 January 2024 14:25
To: Planning <planning@uttlesford.gov.uk>
Subject: [External] LSBUD Ref: 31975252 Your Ref: S62A/2023/0031 Planning Application Holding Objection

Your attachments have been security checked by Mimecast Attachment Protection. Files where no threat or malware was detected are attached.

Date: 02/01/2024
LinesearchbeforeUdig ref: 31975252
Your ref: S62A/2023/0031

Dear Sir/Madam,

Your planning application – Holding objection

We have received a notification from the LinesearchbeforeUdig (LSBUD) platform regarding a planning application which is in the vicinity of our gas asset/s. We are placing a holding objection on the proposal whilst our engineering team reviews the available information. We will be in touch once we have reviewed the proposals in more detail. In the meantime, we may contact you for more information to help us make the decision.

What you need to do

Please review our attached plans, which detail the Cadent gas asset/s in the area. If your application affects one of our high pressure pipelines, it is a statutory requirement that you input the details into the HSE's Planning Advice Web App. For further details visit www.hse.gov.uk/landuseplanning/planning-advice-web-app.htm

Your responsibilities and obligations

Cadent may have a Deed of Easement on the pipeline, which provides us with a right of access for a number of functions and prevents change to existing ground levels and storage of materials. It also prevents the erection of permanent/temporary buildings, or structures. If necessary Cadent will take action to legally enforce the terms of the easement.

This letter does not constitute any formal agreement or consent for any proposed development work either generally or related to Cadent's easements or other rights, or any planning or building regulations applications.

Cadent Gas Ltd or their agents, servants or contractors do not accept any liability for any losses arising under or in connection with this information. This limit on liability applies to all and any claims in contract, tort (including negligence), misrepresentation (excluding fraudulent misrepresentation), breach of statutory duty or otherwise. This limit on liability does not exclude or restrict liability where prohibited by the law nor does it supersede the express terms of any related agreements.

If you need any further information or have any questions about the outcome, please contact us at box.eaplantprotectionops@cadentgas.com

Kind Regards,
East of England Plant Protection Team
T: 0800 688 588
box.eaplantprotectionops@cadentgas.com
cadentgas.com

We work together | **We take responsibility** | **We drive performance** | **We shape the future**
Keeping people warm, *while protecting the planet*