



Incentives & Policies Relevant to Renewable GQCHP

Mahmoud Abu-Ebid
CHPQA Programme Director

29th November 2022



Fiscal Measures for GQCHP

- CCL Exemption (on fuel input and electricity output where directly supplied)
- Carbon Price Support (CPS) exemption
- Business Rates Exemption (embedded schemes)
- Hydrocarbon Oil Duty Relief
- ~~Enhanced Capital Allowance (ECA) – scheme now closed~~
- 1ROC/MWh of electricity from EfW CHP, 2 ROCs/MWh from dedicated biomass CHP (April 2009)
- Specific RHI tariff for biomass fuelled GQCHP
- CHP specific CfDs applicable to biomass and waste fuelled CHP, replaced RO for all new projects from 1/4/2017.



Talk Coverage

Renewable CHP Incentives

- Renewables Obligation-Uplift to GQCHP (RO) **Closed for new schemes from 2015**
- Contracts for Difference (CfD) – **Round 4 opened on 13th December 2021**
- Renewable Heat Incentive (RHI) – **Closed for new schemes from April 2021**



Renewables Obligation (RO)



The Renewable Obligation (RO) and Banding

- First introduced in 2009 and gave:
- Closed to New Schemes in 2017
- But accredited schemes under the RO will need to continue with CHPQA certification to end of the policy period in 2037.



Banding Regime 2016/17

Generation Type	CHP Qualifying Power Output [ROCs/MWh]	Non-CHP Power Output [ROCs/MWh]
Co-firing of regular bioliquid with CHP	1.0	0.5
Low-range co-firing of relevant energy crops with CHP	1.5	1.0
Dedicated biomass with CHP*	1.8	1.4
High-range co-firing with CHP	1.4	0.9
Mid-range co-firing with CHP	1.1	0.6
Low-range co-firing with CHP	1.0	0.5
Station/unit conversion with CHP [†]	1.5	1.0
Energy from Waste with CHP	1.0	0.0



ROC Eligibility

For GQCHP, the power output eligible for the award of ROCs is determined using:

$$\text{Eligible Power Output} = \text{Net Power Output} \times \text{Biomass Content (\%)} \times \left(\frac{\text{QPO}}{\text{TPO}} \right)$$

From CHPQA
Certificate



ROC eligible CHP Schemes

CHP Schemes Requested GN44 Certificate

No. Schemes	CHTPC (kWe)	CHPQPO (MWh)	CHPTFI (MWh)	CHPQHO (MWh)
61	793,709	3,518,000	21,477,337	3,864,663


ROC benefit > £79 million (based on 0.5 ROC uplift)



ROC Eligibility – QI Definitions

Advanced Conversion Technologies (ACTs)

- Gasification
 - Pyrolysis
 - Anaerobic Digestion
- For biogas fired schemes, the fuel input boundary should normally be drawn at the gas inlet to RE
 - Should use the Biogas QI formula
 - **This means can't qualify for Biomass CHP uplift tariff.**





Contract for Difference (CfD)



Contracts for Difference (CfD)

- Regulations for CfDs came into force in Great Britain on 1/8/2014
- CfDs replace the RO for all new projects from 1/4/2017
- Generators are paid the difference between the 'strike price' and the 'reference price' (average market price for electricity in GB market). **If 'reference' exceeds 'strike' price, generator must pay difference.**
- CfDs are awarded via allocation rounds, which government can tailor to specific technologies
 - First allocation round was in October 2014: **two EfW CHP stations were awarded CfDs**
 - Second allocation round was announced in April 2017. Technologies include:
 - Advanced Conversion technologies (with or without CHP)
 - Anaerobic Digestion (with or without CHP) – **1 Scheme Awarded**
 - Dedicated Biomass with CHP – **2 Schemes Awarded**
 - Third allocation round was in Sep 2019 – **CHP not included**
 - Fourth allocation round planned for 2021 – **Opened on 13th December 2021 (includes Biomass CHP)**



Contracts for Difference (CfD)

Round 4, one successful CHP application:

- EfW CHP, total capacity 30 MWe

Technology	Capacity (MWe)	Strike Price (£/MWh)	2021/22 Administrative Strike Price (£/MWh)
EfW CHP	30	45.99	125

- Round 4 (opened on 13th December 2021) includes for ACT, AD and dedicated biomass CHP, the draft administrative prices are:
- Only 1 CHP scheme



CHP-specific CfD Eligibility

- Dedicated Biomass and Energy from Waste generators are only supported if they are **'with CHP'**.
- Provision for other technologies to be 'with CHP' (ACT, AD and geothermal)
- Support is paid only on the proportion of metered electrical output assessed by CHPQA to be **QPO**.
- Uses the CHP Qualifying Multiplier, **$CHPQM = QPO/TPO$** .
- Provide evidence of intended "useful heat" load in F3 submission.
- For 'with CHP' technologies, the generator must maintain annual CHPQA certification (full or partial) including **GN44 certification** for the duration of the CfD.



GN44 Changes

ISSUE 6

- For CHP schemes under 25MWe to have a minimum:
 - Primary energy saving of 10%, and
 - Heat efficiency of 10% Gross Calorific Value (GCV)
- For CHP schemes equal to and over 25MW to have a minimum:
 - Primary energy saving of 10%,
 - Heat efficiency of 10% GCV, and
 - Overall efficiency of at least 35% GCV

ISSUE 7

- Applicable to CfD only
- For CHP schemes of all sizes to have a minimum:
 - Primary energy saving of 10%,
 - Heat efficiency of 10% Gross Calorific Value (GCV), and
 - Overall efficiency of 70% NCV for all sizes.



GN44 Issue 7 – Added Provisions

- Investor Safeguard (para GN44.11)
- Safeguard Provision (para GN44.20)
- Heat Network Flexibility (para GN44.21)



Investor Safeguard

- Contract for Difference for Dedicated Biomass with CHP Schemes only
- Protection against risk of loss of heat customers for **up to 5 years**
- **Can be 5 discrete** years not necessarily consecutive
- RP may elect to have CHP Qualifying Multiplier (QM) based on most recent F3 Certificate
- Requires written request to CHPQA to invoke

No Schemes have had to utilise this provision



Safeguard Provision for QI value

- RO and CfD Schemes
- for new Schemes meet relevant policy criteria (heat efficiency, PES and Overall efficiency) but don't achieve $QI=100$
- CHPQA will recalculate the X coefficient specifically against the design of the Scheme on a case-by-case basis
- Based on finding the operating point at which a Scheme just meets all of the relevant policy criteria and an X value is found that gives a $QI=100$
- Revised X value is now used at all operating conditions for Scheme lifetime

Under the ROC policy about 5 Schemes utilising this provision



Heat Network Flexibility Safeguards

- For renewable Schemes supplying heating/cooling networks
- Adopts a QI threshold of 95 for an initial period of operation of 5 years
- Schemes must demonstrate a heat load development business plan
- That shows build-out will achieve QI=100 in sixth year; or
- QI will increase by at least 5 points by the sixth year
- Business Plan must accompany an F3 submission
- 5 year period starts from first firing and following 5 full calendar years
- Schemes then return to QI=100

Under the ROC policy 2 Schemes using this provision



Dual CHPQA Certification



CHP QA

Department for
Business, Energy
& Industrial Strategy

**Quality Certification for
an existing CHP Scheme**

CHPQA Certificate No: P04231498

Scheme: CHPQA SITE Z
GEMINI BUILDING
HARWELL
OXFORD
OX11 0QR

DRAFT

CHPQA Scheme Reference No: 8760 Z

This is to Certify that the Self-Assessment of the above CHP Scheme undertaken by TEST USER of Scheme performance during the calendar year: 2016 has been Validated under the Combined Heat and Power Quality Assurance programme and that:

1. The Total Power Capacity of this Scheme is: and the Qualifying Power Capacity is:	50,000 MWe 50,000 MWe
2. The threshold Power Efficiency criterion for this Scheme is: and the Power Efficiency of this Scheme is:	20 % 25.85 %
3. The Qualifying Heat Output from this Scheme is: and the Heat Efficiency of this Scheme is:	135,461 MWh 35.46 %
4. The threshold Quality Index criterion for under Annual Operation is: and the Quality Index of this Scheme is:	100 97.75
5. The Total Fuel Input to this Scheme is: and the Qualifying Fuel Input is:	382,033 MWh 382,033 MWh
6. The Percentage of Fuel Input Referable to Electricity Generation is:	56.22 %
7. The Percentage of Conventional Fuel is:	1.51 %
8. The Total Power Output from this Scheme is: and the Qualifying Power Output is:	98,764 MWh 89,049 MWh
9. The fuel supply reference(s) (e.g. TRANSCOMGR gas meter reference nos. and/or other unique ID descriptors) for this Scheme are:	

The CHPQA programme is carried out on behalf of the Department for Business, Energy & Industrial Strategy, the Scottish and Welsh Governments, and the Northern Ireland Department for the Economy.

For the purposes of the Climate Change Levy (General) (Amendment) Regulations 2003 only, the QPO limit shall be equal to the actual output of the station multiplied by the following ratio: the Qualifying Power Output referred to at item 8 above over the Total Power Output referred to at item 8 above.

CHP QA

Department for
Business, Energy
& Industrial Strategy

**Quality Certification for an existing
CHP Scheme for CfD eligibility**

CHPQA Certificate No: F04231498/CID

Scheme: CHPQA SITE Z
GEMINI BUILDING
HARWELL
OXFORD
OX11 0QR

DRAFT

CHPQA Scheme Reference No: 8760 Z

This is to Certify that the Self-Assessment of the above CHP Scheme undertaken by TEST USER of Scheme performance during the calendar year: 2016 has been Validated under the Combined Heat and Power Quality Assurance programme and that:

Information for CfD Eligibility

1. The Total Power Capacity of this Scheme is:	50,000 MWe
2. The Power Efficiency of this Scheme is:	25.85 %
3. The Qualifying Heat Output from this Scheme is: and the Heat Efficiency of this Scheme is:	135,461 MWh 35.46 %
4. The threshold Quality Index criterion for this Scheme under Annual Operation is: and the Quality Index of this Scheme is:	100.00 114.83
5. The Total Fuel Input to this Scheme is:	382,033 MWh
6. The Total Power Output from this Scheme is: and the Qualifying Power Output is:	98,764 MWh 98,764 MWh
7. The CHP Qualifying Multiplier for this Scheme is:	1.00
8. The Technology Type for this Scheme is:	Pass-out condensing steam turbine
9. The Main Fuel Type for this Scheme is:	Wood Fuel
10. The Percentage of Renewable Fuel is:	98.69 %

The CHPQA programme is carried out on behalf of the Department for Business, Energy & Industrial Strategy, the Scottish and Welsh Governments, and the Northern Ireland Department for the Economy.

For the purposes of the Climate Change Levy (General) (Amendment) Regulations 2003 only, the QPO limit shall be equal to the actual output of the station multiplied by the following ratio: the Qualifying Power Output referred to at item 6 above over the Total Power Output referred to at item 6 above.

6. The Total Power Output from this Scheme is:
and the Qualifying Power Output is:

98,764 MWh
98,764 MWh



Renewable Heat Incentive (RHI)



CHP in RHI

- The specific tariff for solid biomass GQCHP of **4.57p/kWh (from 1 April 2016)**
- Schemes need to be certified by CHPQA in order to benefit from CHP tariff
- **EfW plants are only eligible for the biomass boiler tariff** for the biomass percentage contained in the waste
- No special CHP RHI tariffs for EfW or other fuels
- RHI eligible heat from CHP is not the same as QHO
- CHP scheme boundaries for CHPQA certification are not always the same as for RHI eligible installation
- Only heat produced via the **engine/turbine** can qualify for the CHP tariff
- This needs to be metered separately



Tariff rates for RHI accreditation after 1 April 2018

Tariff name	Eligible sizes	Tariff, p/kWh	
Small commercial biomass	< 200 kWth	Tier 1	3.15
		Tier 2	2.21
Medium commercial biomass	200 kWth to ≤ 1MWth	Tier 1	3.15
		Tier 2	2.21
Large commercial biomass	>1MWth	Tier 1	3.15
		Tier 2	2.21
Solid biomass CHP systems	All capacities	n/a	4.57

- **No tiers for Solid biomass CHP**
- For boilers Tier 1 rate applied for 3,066 hours (35% load factor).
- Remainder of heat generated in the 12 months paid at Tier 2 rate.



RHI eligible CHP Schemes


RHI CHP Schemes

No. Schemes	CHPTPC (kWe)	CHPTPO (MWh)	CHPQPO (MWh)	CHPTFI (MWh)	CHPQHO (MWh)
73	65,713	363,595	118,550	2,038,944	592,310

RHI benefit > £1.2 million (based on RHI tariff difference of £2.03/MWh)




ST Example CHP



Pass Out Condensing Steam Turbine
with CHP heat



ST Example with non-CHP Heat




Pass Out Condensing Steam Turbine
with non-CHP heat in bypass




CHP Heat

Organic Rankine
Cycle Turbine as
CHP mode





non-CHP Heat



Organic Rankine Cycle
Turbine in a non-CHP
mode



What to do after receiving CHPQA certificate?

- **There is no reconciliation in ROCs or RHI**

- **For ROCs**
 - You need to inform Ofgem if your Scheme's QPO/TPO ratio has changed
 - Ofgem also gets this ratio from the CHPQA Administrator
 - This will be used for the rest of the year and following year operation.

- **For RHI:**
 - Again this is managed by Ofgem,
 - You need to inform them if your Scheme's power efficiency dropped below the threshold (10%, 15% or 20%).



FEEDBACK

Feedback Questionnaire Relating to CHPQA Seminars and Workshops 2022

We would appreciate a few minutes of your time to complete this questionnaire. Please tick the boxes that relate to your views (☑). By completing the form, you are giving consent for this information to be used by BEIS and CHPQA to understand and seek to improve this event.

1. You/Your Company

Name Job Title

Organisation

Date(s) of event(s) attended

2. What were your main objectives in attending this event?

To find out about CHPQA as you are considering applying

To find out about developments in CHPQA for your next submission

To find out how to obtain the financial incentives available through CHPQA certification

Other (please state):

3. Were your objectives met?

Yes No

If not, please explain why

4. The Presentations - How useful were they?

	Very Useful	Useful	Somewhat Useful	Not at all Useful
Module 1:				
CHPQA - Principles and procedures	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CHPQA Electronic submissions - What's involved	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CHPQA Metering Requirements, Uncertainty	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Module 2:				
Review of incentives/policies – Conventional CHP	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Review of incentives/policies – Renewable CHP	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Feedback on Gas CHP policy review and call for evidence - BEIS	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Do you have any additional comments?

5. Are you registered with the CHPQA programme?

Yes No

If not, please explain your interest in CHPQA

6. Are there any other topics you would like covered in future events?

.....



Final message

To obtain any of the fiscal benefits available for GQCHP the Scheme must be certified by CHPQA and must have a valid Certificate

Submission any time from 1 Jan 2023

Thank You