

## Product application checklist

Please complete in BLOCK CAPITALS

### Heat Pumps: Air to water

Manufacturer/supplier name: .....

Applicant's name: .....

Telephone number: .....

#### Product information

Product name: .....

Model number: .....

Please complete each section of this form based on your product's characteristics. Incomplete or incorrect data could affect the processing of your product application.

Each product application should be made on a separate form unless a product's design characteristics are common to all the products. In this instance a single application can be made for multiple products.

<b>1. Product Testing and Certification</b>	<b>No</b>	<b>Yes</b>
---	-----------	------------

Where type testing has been applied to demonstrate product performance please ensure that the information supplied is sufficient to demonstrate the performance of all the products for which applications are being made.

**1.1 Is the product CE Marked?**

**1.2 Has the product been tested in accordance with the test procedures and standard rating conditions in the following standards?**

- a) BS EN 14825:2016 for cooling mode
- b) Commission Regulation (EU) No 813/2013, Annex III

**1.3 How was the product(s) performance tested? (Please select one).**

- a) Tested in the manufacturer's in-house laboratory, in accordance with a registered Quality Management System (i.e. 'self-tested') AND a representative sample of the test data has been verified or cross-checked by an independent body.
- b) Tested in a laboratory either in house or on-site, witnessed by an independent body (i.e. 'witnessed testing').
- c) Tested by an independent laboratory (i.e. 'independent testing').
- d) Representative models used.

*Please refer to Section 2 of ECA Guidance Note 5 "ECA Testing Programme: Energy Technology List (ETL) Product Testing Framework" for details of the requirements that must be satisfied for each of these product testing options.*

<b>1. Product testing and certification (continued)</b>	<b>No</b>	<b>Yes</b>
---	-----------	------------

**1.4 Where the product was tested in the manufacturer’s in-house laboratory:**

a)What is the registration number of the Quality Management System?

---

b)What is the name of the independent body that has verified or cross-checked a sample of the test data?

---

**1.5 Where product testing has been witnessed by an independent body, what was the name of the witness?**

*(Please include contact details).*

---



---

**1.6 Where products have been tested by an independent laboratory:**

a) What is the name of the independent laboratory?

---

b) What is the laboratory’s registration number (where accredited)?

---

**1.7 Is the application for:** *(Please select one).*

- a) A single unique product – in this case go to 2.1
- b) A range of products, which are variants of the same basic design
- c) One or more additional models to a range of products already on the ETPL

**Products will only be considered to be variants of the same basic design, if they:**

- Use the same refrigerant as the representative model.
- Have the same compressor type (i.e. manufacturer, method of compression (e.g. reciprocating or scroll) and type of enclosure (e.g. hermetic or semi-hermetic) as the representative model.
- Fit within the same product category and are designed for the same application (i.e. are all low temperature air to water heat pumps designed for space heating only).

**1.8 If representative testing has been used, what are the “representative models”?**

**ETL Product ID number**

**Product name and model number**

---



---



---



---



---



---



---

*The representative models must be selected by dividing the range of products into groups of models with similar design characteristics, and testing a model in each group. The performance of each model in the group must be predicted using a validated mathematical model. As a minimum, at least one model must be tested in each group of products.*

*A report documenting performed model calculations, showing all significant calculation steps, shall be submitted with the application..*

2. Product type		No	Yes															
2.1	<p><b>What type of heat pump is your product?</b> (Please select one).</p> <p>a) Low temperature air to water heat pump (specifically designed for low temperature application and unable to deliver heating water with an outlet temperature of 52°C at an inlet dry (wet) bulb temperature of -7°C (-8°C) in the reference conditions for average climate.)</p> <p>b) Medium and high temperature heat pumps.</p> <p>c) Large irreversible heat pumps.</p>																	
2.2	<p><b>What application is your product designed for?</b></p> <p>a) Space heating only?</p> <p>b) Primarily space heating but capable of providing domestic hot water?</p> <p><i>Note an air to water heat pump which provides heating only must be a “space heater” as defined by Commission Regulation (EU) No 813/2013 and one which provides space heating and domestic hot water must be a “combination heater” as defined by Commission Regulation (EU) No 813/2013.</i></p>																	
3. Product features		No	Yes															
3.1	<b>Does the product incorporate an electrically driven refrigeration system?</b>																	
3.2	<b>Does the product consist of a single factory assembled (packaged) unit?</b> <i>If yes proceed to 3.4.</i>																	
3.3	<p><b>Does the product consist of an ‘outdoor’ unit and an indoor unit that are:</b></p> <p>a) Factory built sub-assemblies</p> <p>b) Supplied as a matched pair of units</p> <p>c) Designed to be connected together during installation?</p>																	
3.4	<b>Is the product designed for, and include fittings for, permanent installation?</b>																	
4. Product performance		No	Yes															
4.1	<p><b>Is the Seasonal Space Heating Energy Efficiency (<math>\eta_{s,h}</math>) of your product equal to or greater than the thresholds for the product category (as set out in Table 1 below) in heating mode?</b></p> <p><i>Performance data must be determined and the <math>\eta_{s,h}</math> calculated, following the requirements of Commission Regulation (EU) No 813/2013 Annex III, by dividing the SCOP by the factor 2.5 (to allow for generation efficiency), corrected by contributions accounting for temperature controls.</i></p>																	
4.2	<b>Is the product designed to provide cooling?</b> <i>If no proceed to section 5.</i>																	
4.3	<p><b>Is the Energy Efficiency Ratio of your product greater than the performance thresholds for the product category (as set out in Table 1 below), across the range of connected capacities and including 100% (full) load in cooling mode?</b></p> <p><i>Products should be tested in accordance with BS EN 14825:2016 at the conditions given in Table 4, part load condition A, cooling floor application.</i></p> <p><b>Table 1</b> Performance thresholds for air to water heat pumps</p> <table border="1"> <thead> <tr> <th>Product Category</th> <th>Heating mode (<math>\eta_{s,h}</math>)</th> <th>Cooling mode (SEER)</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>Low temperature heat pumps</td> <td><math>\geq 155\%</math></td> <td><math>\geq 4.50</math></td> </tr> <tr> <td>2</td> <td>Medium and high temperature heat pumps</td> <td><math>\geq 130\%</math></td> <td><math>\geq 4.50</math></td> </tr> <tr> <td>3</td> <td>Large irreversible heat pumps</td> <td><math>\geq 125\%</math></td> <td>N/a</td> </tr> </tbody> </table> <p><i>“<math>\geq</math>” means “greater than or equal to”</i></p> <p><i>For the avoidance of doubt test data should be presented to three significant figures. As an example a low temperature heat pump with a heating mode <math>\eta_{s,h}</math> of 149.4% or a cooling mode SEER of 4.494 would be deemed a fail.</i></p>	Product Category	Heating mode ( $\eta_{s,h}$ )	Cooling mode (SEER)	1	Low temperature heat pumps	$\geq 155\%$	$\geq 4.50$	2	Medium and high temperature heat pumps	$\geq 130\%$	$\geq 4.50$	3	Large irreversible heat pumps	$\geq 125\%$	N/a		
Product Category	Heating mode ( $\eta_{s,h}$ )	Cooling mode (SEER)																
1	Low temperature heat pumps	$\geq 155\%$	$\geq 4.50$															
2	Medium and high temperature heat pumps	$\geq 130\%$	$\geq 4.50$															
3	Large irreversible heat pumps	$\geq 125\%$	N/a															

## 5. Summary of documents to be included

No	Yes
----	-----

Please send **ONE** copy of each of the following documents:

**If the relevant information in support of the questions above is contained within a larger document, please indicate the location of the relevant information. Note that all documentation submitted must directly refer to the model numbers for which you are making this application. Documentation should be added to your online application at [https://etl.beis.gov.uk/engetl/fox/live/ETL\\_PUBLIC\\_PRODUCT\\_SEARCH](https://etl.beis.gov.uk/engetl/fox/live/ETL_PUBLIC_PRODUCT_SEARCH).**

- a. A technical sales brochure or leaflet for the product clearly summarising:
- The key features of the product (ideally including photographs of the product's exterior).
  - The product's operation (i.e. in-built functionality) and intended applications (i.e. usage).
  - Any product selection options (including optional extras, alternative configurations etc.).

*This documentation should contain sufficient detail to enable the assessor to confirm that the proposed entry on the Energy Technology Product List (ETPL) is correct, and uniquely represents a single product of fixed design (as defined by the rules of the ECA Scheme). If the model names contain any 'wildcards' in respect of cosmetic variations please check with ECA Questions that this is permitted before submitting your application.*

- b. A technical specification for the product, including:
- Details of the model numbers covered (including individual features of each model).
  - The product's design ratings (electrical, mechanical, thermal, flow rates, energy use etc.).
  - A description of how to install the product including connection/wiring diagrams. Where the product must be assembled, configured and/or commissioned on site before use, please include instructions.

*This documentation should contain sufficient detail to enable the assessor to confirm that each product entry on the Energy Technology Product List (ETPL) has the design features specified in the eligibility criteria for that category of product. Please indicate on the checklist where information on specific design features is located in the documentation.*

- c. Evidence that the product meets the performance criteria, including:
- The technical product fiche for the product as specified in Commission Regulation (EU) No 813/2013 Annex II, section 5, Table 2 (measured/calculated in accordance with Annex III). This should be in the tabular format shown in Table 2.
  - The detailed calculation used to determine the SCOP and SSHEE – for example a copy of the completed MCS 026 SCOP and SSHEE calculator for the product if it is an MCS certified product.
  - A heating mode test report and a cooling mode test report as specified in Table 1.2 of the ECA criteria for Air to water heat pumps. The testing should be carried out in accordance with the procedures in BS EN 14825:2016 for cooling and Commission Regulation (EU) No 813/2013 for heating mode.
  - Details of the test procedures/standards used to determine product performance.
  - A declaration certifying the accuracy of the test reports and confirming that:
    - The test facilities used comply with the minimum specifications outlined in the test standard, and the required test conditions were applied during testing.
    - All measurement equipment used in testing was calibrated by an accredited laboratory, or its calibration is otherwise traceable back to national standards.
    - Appropriate quality assurance procedures have been used to verify or cross-check the accuracy and repeatability of the test procedures and test results.
  - Where representative testing has been used, please include details of selection method used and evidence that the products covered by the representative model(s) are variants of the same basic design.

*Please note that summary test reports will only be accepted where the accuracy of the test reports has been certified by a recognised independent body, or where one detailed test report has been submitted per product range.*

*Please refer to ECA Guidance Note 5 "ECA Testing Programme: Energy Technology List (ETL) Product Testing Framework Issue 3 (July 2014)" for further guidance on the submission of test results, and minimum information requirements.*

- d. A Declaration of Conformity with EU Directives on product safety, including:
- CE Marking Directives.
- e. Evidence that a quality assurance system/procedures is/are in place to control the specification, design, manufacturing and testing of the products.
- f. Signed application checklist.

*Please note that all product documentation provided must be written in, or translated into, English.*

## 6. Declaration

I confirm that the information given above is correct to the best of my knowledge and that I have read and agree to the terms and conditions governing the management of the Enhanced Capital Allowance Energy Technology List (ETL).  
A copy of the terms and conditions can be found at <https://www.gov.uk/guidance/energy-technology-list>.

Signature: ..... Date: .....

### For more information:

**Web:**  
<https://www.gov.uk/guidance/energy-technology-list>

**Phone:**  
0300 3300657

**Email:**  
[ECAQuestions@carbontrust.co.uk](mailto:ECAQuestions@carbontrust.co.uk)

**Post:**  
ETL Coordinator,  
ICF,  
6th floor,  
Watling House,  
33 Cannon Street,  
London, EC4M 5SB

Whilst reasonable steps have been taken to ensure that the information contained within this publication is correct, the Carbon Trust, its agents, contractors and sub-contractors, and the Government give no warranty and make no representation as to its accuracy and accept no liability for any errors or omissions.

Any trademarks, service marks or logos used in this publication are the property of the Carbon Trust and Government. Nothing in this publication shall be construed as granting any licence or right to use or reproduce any of the trademarks, service marks, logos, copyright or any proprietary information in any way without the Carbon Trust's prior written permission. The Carbon Trust enforces infringements of its intellectual property rights to the full extent permitted by law.

The Carbon Trust is a company limited by guarantee and registered in England and Wales under Company Number 04190230 with its Registered Office at: 4th Floor, Dorset House, 27-45 Stamford Street, London SE1 9NT. The Enhanced Capital Allowance Scheme for energy saving equipment is run by the Carbon Trust on behalf of Government.

Published in the UK: March 2019.

ECA774 v11