

# **Review of an Environmental Permit for an Installation subject to Chapter II of the Industrial Emissions Directive under the Environmental Permitting (England & Wales) Regulations 2016 (as amended)**

## **Decision document recording our decision-making process following review of a permit**

The Permit number is:                   EPR/BP2191IS  
The Operator is:                       Princes Limited  
The Installation is:                   Weaverthorpe Soft Drinks  
This Variation Notice number is:   EPR/BP2191IS/V006

## **What this document is about**

Article 21(3) of the Industrial Emissions Directive (IED) requires the Environment Agency to review conditions in permits that it has issued and to ensure that the permit delivers compliance with relevant standards, within four years of the publication by the European Commission of updated decisions on best available techniques (BAT) Conclusions.

We have reviewed the permit for this installation against the BAT Conclusions for the Food, Drink and Milk Industries published on 4<sup>th</sup> December 2019 in the Official Journal of the European Union. In this decision document, we set out the reasoning for the consolidated variation notice that we have issued.

It explains how we have reviewed and considered the techniques used by the Operator in the operation and control of the plant and activities of the installation. It is our record of our decision-making process and shows how we have taken into account all relevant factors in reaching our position.

As well as considering the review of the operating techniques used by the Operator for the operation of the plant and activities of the installation, the consolidated variation notice takes into account and brings together in a single document all previous variations that relate to the original permit issue. Where this has not already been done, it also modernises the entire permit to reflect the conditions contained in our current generic permit template.

The introduction of new template conditions makes the Permit consistent with our current general approach and with other permits issued to Installations in this sector. Although the wording of some conditions has changed, while others have been deleted because of the new regulatory approach, it does not reduce the level of environmental protection achieved by the Permit in any way. In this document, we therefore address only our determination of substantive issues relating to the new BAT Conclusions.

We try to explain our decision as accurately, comprehensively and plainly as possible. Achieving all three objectives is not always easy, and we would welcome any feedback as to how we might improve our decision documents in future.

## **How this document is structured**

1. Our decision
2. How we reached our decision
3. The legal framework
4. Annex 1 – Review of operating techniques within the Installation against BAT Conclusions.
5. Annex 2 – Review and assessment of changes that are not part of the BAT Conclusions derived permit review
6. Annex 3 – Improvement Conditions

# 1 Our decision

We have decided to issue the Variation Notice to the Operator. This will allow the Operator to continue to operate the Installation, subject to the conditions in the Consolidated Variation Notice that updates the whole permit.

We consider that, in reaching our decision, we have taken into account all relevant considerations and legal requirements and that the varied permit will ensure that a high level of protection is provided for the environment and human health.

The Consolidated Variation Notice contains many conditions taken from our standard Environmental Permit template including the relevant annexes. We developed these conditions in consultation with industry, having regard to the legal requirements of the Environmental Permitting Regulations and other relevant legislation. This document does not therefore include an explanation for these standard conditions. Where they are included in the Notice, we have considered the techniques identified by the operator for the operation of their installation, and have accepted that the details are sufficient and satisfactory to make those standard conditions appropriate. This document does, however, provide an explanation of our use of “tailor-made” or installation-specific conditions, or where our Permit template provides two or more options.

## 2 How we reached our decision

### 2.1 Requesting information to demonstrate compliance with BAT Conclusion techniques

We issued a Notice under Regulation 61(1) of the Environmental Permitting (England and Wales) Regulations 2016 (a Regulation 61 Notice) on 09/11/2021 requiring the Operator to provide information to demonstrate where the operation of their installation currently meets, or how it will subsequently meet, the revised standards described in the relevant BAT Conclusions document.

The Notice required that where the revised standards are not currently met, the operator should provide information that:

- describes the techniques that will be implemented before 4 December 2023, which will then ensure that operations meet the revised standards, or
- justifies why standards will not be met by 4 December 2023, and confirmation of the date when the operation of those processes will cease within the Installation or an explanation of why the revised BAT standards are not applicable to those processes, or
- justifies why an alternative technique will achieve the same level of environmental protection equivalent to the revised BAT standards described in the BAT Conclusions.

Where the Operator proposed that they were not intending to meet a BAT standard that also included a BAT Associated Emission Level (BAT-AEL) described in the BAT Conclusions Document, the Regulation 61 Notice required that the Operator make a formal request for derogation from compliance with that BAT-AEL (as provisioned by Article 15(4) of IED). In this circumstance, the Notice identified that any such request for derogation must be supported and justified by sufficient technical and commercial information that would enable us to determine acceptability of the derogation request.

The Regulation 61 Notice response from the Operator was received on 17/05/2022.

We considered it was in the correct form and contained sufficient information for us to begin our determination of the permit review but not that it necessarily contained all the information we would need to complete that determination.

The Operator made no claim for commercial confidentiality. We have not received any information in relation to the Regulation 61 Notice response that appears to be confidential in relation to any party.

## 2.2 Review of our own information in respect to the capability of the Installation to meet revised standards included in the BAT Conclusions document

Based on our records and previous experience in the regulation of the installation we consider that the Operator will be able to comply with the techniques and standards described in the BAT Conclusions other than for those techniques and requirements described in BAT Conclusion 9. The operator does not currently comply with the requirements of BATc 6(a). In relation to this/these BAT Conclusion(s), we do not fully agree with the Operator in respect of their current stated capability as recorded in their response to the Regulation 61 Notice. We have therefore included Improvement Conditions IC10 and IC11 in the Consolidated Variation Notice to ensure that the requirements of the BAT Conclusions are delivered within 3 months of the variation being issued.

## 2.3 Requests for further information during determination

Although we were able to consider the Regulation 61 Notice response generally satisfactory at receipt, we did in fact need more information in order to complete our permit review assessment, and issued a further information request on 24/11/2023 concerning BATcs 1, 2, 5, 6(a), 7, 8, 9, 11, 12, 33, EPL for energy consumption, MCPs capacity and number, RHS Baseline, Containment measures, carbon dioxide (CO<sub>2</sub>) recovery measures, cooling towers, updated site plan, range of products, non-technical description of the main activity. A copy of the further information request was placed on our public register.

In addition to the response(s) to our further information request(s), we received additional information during the determination from the Operator concerning BATcs 7(a), 33, and containment measures on received on 21/12/2023. We made a copy of this information available to the public in the same way as the response to our information request.

# **3 The legal framework**

The Consolidated Variation Notice will be issued under Regulations 18 and 20 of the EPR. The Environmental Permitting regime is a legal vehicle which delivers most of the relevant legal requirements for activities falling within its scope. In particular, the regulated facility is:

- an *installation* as described by the IED;
- subject to aspects of other relevant legislation which also have to be addressed.

We consider that, in issuing the Consolidated Variation Notice, it will ensure that the operation of the Installation complies with all relevant legal requirements and that a high level of protection will be delivered for the environment and human health.

We explain how we have addressed specific statutory requirements more fully in the rest of this document.

## Annex 1: decision checklist regarding relevant BAT Conclusions

BAT Conclusions for the Food, Drink and Milk Industries, were published by the European Commission on 4 December 2019.

There are 37 BAT Conclusions.

BAT 1 – 15 are General BAT Conclusions (Narrative BAT) applicable to all relevant Food, Drink and Milk Installations in scope.

BAT 16 – 37 are sector-specific BAT Conclusions, including Best Available Techniques Associated Emissions Levels (BAT-AELs) and Associated Environmental Performance Levels (BAT-AEPLs):

BAT 16 & 17	BAT Conclusions for Animal Feed
BAT 18 – 20	BAT Conclusions for Brewing
BAT 21 – 23	BAT Conclusions for Dairies
BAT 24	BAT Conclusions for Ethanol Production
BAT 25 & 26	BAT Conclusions for Fish and Shellfish Processing
BAT 27	BAT Conclusions for Fruit and Vegetable Processing
BAT 28	BAT Conclusions for Grain Milling
BAT 29	BAT Conclusions for Meat Processing
BAT 30 – 32	BAT Conclusions for Oilseed Processing and Vegetable Oil Refining
BAT 33	BAT Conclusions for Soft Drinks and Nectar/Fruit Juice Processed from Fruit and Vegetables
BAT 34	BAT Conclusions for Starch Production
BAT 35 – 37	BAT Conclusions for Sugar Manufacturing

This annex provides a record of decisions made in relation to each relevant BAT Conclusion applicable to the installation. This annex should be read in conjunction with the Consolidated Variation Notice.

The overall status of compliance with the BAT conclusion is indicated in the table as:

**NA – Not Applicable**

**CC – Currently Compliant**

**FC – Compliant in the future (within 4 years of publication of BAT Conclusions)**

**NC – Not Compliant**

BATC No.	Summary of BAT Conclusion requirement for Food, Drink and Milk Industries	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
<b>GENERAL BAT CONCLUSIONS (BAT 1-15)</b>			
1	<p><b>Environmental Management System - Improve overall environmental performance.</b></p> <p>Implement an EMS that incorporates all the features as described within BATc 1.</p>	<b>CC</b>	<p>The operator has provided information to support compliance with BATc 1. We have assessed the information provided and we are satisfied that the operator has demonstrated compliance with BATc 1.</p> <p>Because the operator has an EMS externally accredited to the ISO14001 standard, we do not consider the non-compliance statement in relation to BATc 1 (xvi), (xx), and (iv – energy management plan) to be of significant importance as the Operator declared they will be compliant by 04/12/2023.</p>
2	<p><b>EMS Inventory of inputs &amp; outputs. Increase resource efficiency and reduce emissions.</b></p> <p>Establish, maintain and regularly review (including when a significant change occurs) an inventory of water, energy and raw materials consumption as well as of waste water and waste gas streams, as part of the environmental management system (see BAT 1), that incorporates all of the features as detailed within the BATCs.</p>	<b>CC</b>	<p>The operator has provided information to support compliance with BATc 2. We have assessed the information provided and we are satisfied that the operator has demonstrated compliance with BATc 2.</p> <p>The Operator declared the following:</p> <ul style="list-style-type: none"> <li>• Use of a simplified process flow sheet and awareness of techniques used to minimise wastewater and waste gas generation</li> <li>• Use of detailed water consumption data to identify efficiency opportunities</li> <li>• Monitoring of wastewater characteristics prior to discharge to sewer</li> <li>• Knowledge of the site's energy consumption, raw materials utilisations, and characterisation of waste streams and composition with a view to minimise resource use</li> <li>• Continuous monitoring and review of resources use and waste generated.</li> </ul>

BATC No.	Summary of BAT Conclusion requirement for Food, Drink and Milk Industries	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
			The Operator declared that subpoints (I) and (II) are to be reviewed and consolidated by April 2024. Because the EMS is ISO accredited, we will not be including an improvement condition at this time.
3	<b>Monitoring key process parameters at key locations for emissions to water.</b> For relevant emissions to water as identified by the inventory of waste water streams (see BAT 2), BAT is to monitor key process parameters (e.g. continuous monitoring of waste water flow, pH and temperature) at key locations (e.g. at the inlet and/or outlet of the pre-treatment, at the inlet to the final treatment, at the point where the emission leaves the installation).	CC	<p>The operator has provided information to support compliance with BATc 3. We have assessed the information provided and we are satisfied that the operator has demonstrated compliance with BATc 3.</p> <p>The Operator declared that pH is monitored at the inlet to the effluent treatment plant (ETP), and that flow, chemical oxygen demand (COD), and suspended solids prior to discharge.</p>
4	<b>Monitoring emissions to water to the required frequencies and standards.</b> BAT is to monitor emissions to water with at least the frequency given [refer to BAT 4 table in BATc] and in accordance with EN standards. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.	NA	<p>We are satisfied that BATc 4 is not applicable to this site.</p> <p>This BATc is concerned with discharges of process effluent to a receiving water body and this site has no such discharges. All process effluent, following treatment in the onsite ETP, is discharge to sewer under consent from Yorkshire Water therefore, BATc 4 is not applicable.</p> <p>Only uncontaminated surface water run-off is discharged to Holroyd Beck, and this waste stream is not subject to the requirements of BATc 4.</p>
5	<b>Monitoring channelled emissions to air to the required frequencies and standards.</b> BAT is to monitor channelled emissions to air with at least the frequency given and in accordance with EN standards.	NA	<p>We are satisfied that BATc 5 is not applicable to this site.</p> <p>The Operator declared that this installation does not produces dust emissions nor is generating such emissions. This site is</p>

BATC No.	Summary of BAT Conclusion requirement for Food, Drink and Milk Industries	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
			producing drinks therefore, this BATc is not applicable.
6	<b>Energy Efficiency</b> In order to increase energy efficiency, BAT is to use an energy efficiency plan (BAT 6a) and an appropriate combination of the common techniques listed in technique 6b within the table in the BATc.	<b>FC</b>	<p>The operator has provided information to support compliance with BATc 6. We have assessed the information provided and we are not satisfied that the operator has demonstrated compliance with BATc 6.</p> <p>The Operator declared the following techniques are used:</p> <ul style="list-style-type: none"> <li>• LED lighting</li> <li>• Automated process control systems and monitoring systems</li> <li>• Burner regulation and control through preventive planned maintenance (PPM)</li> <li>• Reducing heat losses by insulation</li> </ul> <p><b>However, the Operator does not currently have an unified energy management plan, as requested by BATc 6(a). The Operator demonstrated a good understanding of energetic efficiency path with plans already in place to improve performance such as replacing motors with VSDs energy efficient ones, or implementing a heat recovery project.</b></p> <p>We have included IC10 for the Operator to develop a stand-alone energy management plant and include this in EMS.</p>
7	<b>Water and wastewater minimisation</b> In order to reduce water consumption and the volume of waste water discharged, BAT is to use BAT 7a and one or a combination of the techniques b to k given below. (a) water recycling and/or reuse (b) Optimisation of water flow	<b>CC</b>	<p>The operator has provided information to support compliance with BATc 7. We have assessed the information provided and we are satisfied that the operator has demonstrated compliance with BATc 7.</p>



BATC No.	Summary of BAT Conclusion requirement for Food, Drink and Milk Industries	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	(c) Optimisation of water nozzles and hoses (d) Segregation of water streams Techniques related to cleaning operations: (e) Dry cleaning (f) Pigging system for pipes (g) High-pressure cleaning (h) Optimisation of chemical dosing and water use in cleaning-in-place (CIP) (i) Low-pressure foam and/or gel cleaning (j) Optimised design and construction of equipment and process areas (k) Cleaning of equipment as soon as possible		The Operator declared that optimisation of chemical dosing and water use in cleaning-in-place (CIP) and cleaning equipment as soon as possible techniques are used to minimise the use of water and creation of wastewater. Water is reused in the CIP up to four times before it is discharged to sewer.
8	<b>Prevent or reduce the use of harmful substances</b> In order to prevent or reduce the use of harmful substances, e.g. in cleaning and disinfection, BAT is to use one or a combination of the techniques given below. (a) Proper selection of cleaning chemicals and/or disinfectants (b) Reuse of cleaning chemicals in cleaning-in-place (CIP) (c) Dry cleaning (d) Optimised design and construction of equipment and process areas	CC	The operator has provided information to support compliance with BATc 8. We have assessed the information provided and we are satisfied that the operator has demonstrated compliance with BATc 8.  The Operator declared they reuse chemicals in CIP up to 4 times. In addition, the suitability of the chemicals used on site is agreed in consultation with a 3 <sup>rd</sup> party supplier.
9	<b>Refrigerants</b> In order to prevent emissions of ozone-depleting substances and of substances with a high global warming potential from cooling and freezing, BAT is to use refrigerants without ozone depletion potential and with a low global warming potential.	FC	The operator has provided information to support compliance with BATc 9. We have assessed the information provided and we are satisfied that the operator has demonstrated compliance with BATc 9.  <b>The Operator provided a copy of the FGAS register in support of the compliance statement. Studying this document, we have concluded that a number of assets associated with production processes do utilise gases with a high GWP score, such as R404A, R410A, R134A, and R407C.</b>  <b>We could not establish the Operator's intentions in respect to these refrigerants,</b>

BATC No.	Summary of BAT Conclusion requirement for Food, Drink and Milk Industries	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
			<p>nor a refrigerants replacement plan has been submitted as part of the Reg.61 and RFI responses.</p> <p>We are asking the Operator to consider the replacement of this gases with ones of lower GWP.</p> <p>Improvement condition IC11 has been included in the permit to achieve compliance (see Annex 3).</p>
10	<p><b>Resource efficiency</b></p> <p>In order to increase resource efficiency, BAT is to use one or a combination of the techniques given below:</p> <ul style="list-style-type: none"> <li>(a) Anaerobic digestion</li> <li>(b) Use of residues</li> <li>(c) Separation of residues</li> <li>(d) Recovery and reuse of residues from the pasteuriser</li> <li>(e) Phosphorus recovery as struvite</li> <li>(f) Use of waste water for land spreading</li> </ul>	<b>CC</b>	<p>The operator has provided information to support compliance with BATc 10. We have assessed the information provided and we are satisfied that the operator has demonstrated compliance with BATc 10.</p> <p>The Operator declared that they are using separation of residue as a resource efficiency technique. In addition, the site uses a 'reduce waste at source' approach to keep waste at or under 3% of produce volume.</p>
11	<p><b>Waste water buffer storage</b></p> <p>In order to prevent uncontrolled emissions to water, BAT is to provide an appropriate buffer storage capacity for waste water.</p>	<b>CC</b>	<p>The operator has provided information to support compliance with BATc 11. We have assessed the information provided and we are satisfied that the operator has demonstrated compliance with BATc 11.</p> <p>The Operator declared that it has sufficient buffer capacity comprising of two interceptor tanks on waste water drainage lines, wet and dry well systems on the ETP to prevent overflow into waste water system and buffer divert tank for high value waste.</p> <p>In addition, there is a contract with an external provider for temporary penstocks, if required.</p>
12	<b>Emissions to water – treatment</b>	<b>CC</b>	<p>The operator has provided information to support compliance with BATc 12. We have</p>

BATC No.	Summary of BAT Conclusion requirement for Food, Drink and Milk Industries	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement										
	<p>In order to reduce emissions to water, BAT is to use an appropriate combination of the techniques given below.</p> <p>Preliminary, primary and general treatment</p> <p>(a) Equalisation</p> <p>(b) Neutralisation</p> <p>(c) Physical separate (eg screens, sieves, primary settlement tanks etc)</p> <p>Aerobic and/or anaerobic treatment (secondary treatment)</p> <p>(d) Aerobic and/or anaerobic treatment (eg activated sludge, aerobic lagoon etc)</p> <p>(e) Nitrification and/or denitrification</p> <p>(f) Partial nitrification - anaerobic ammonium oxidation</p> <p>Phosphorus recovery and/or removal</p> <p>(g) Phosphorus recovery as struvite</p> <p>(h) Precipitation</p> <p>(i) Enhanced biological phosphorus removal</p> <p>Final solids removal</p> <p>(j) Coagulation and flocculation</p> <p>(k) Sedimentation</p> <p>(l) Filtration (eg sand filtration, microfiltration, ultrafiltration)</p> <p>(m) Flotation</p>		<p>assessed the information provided and we are satisfied that the operator has demonstrated compliance with BATc 12.</p> <p>The Operator declared the use of the following techniques:</p> <ul style="list-style-type: none"><li>• Physical separation</li><li>• Neutralisation and equalisation</li><li>• Chemical dosing</li></ul>										
12	<p><b>Emissions to water – treatment</b></p> <p><b>BAT-associated emission levels (BAT-AELs) for direct emissions to a receiving water body</b></p> <table><tr><th>Parameter</th><th>BAT-AEL <sup>(15)</sup> <sup>(16)</sup> (daily average)</th></tr><tr><td>Chemical oxygen demand (COD) <sup>(17)</sup> <sup>(18)</sup></td><td>25-100 mg/l <sup>(19)</sup></td></tr><tr><td>Total suspended solids (TSS)</td><td>4-50 mg/l <sup>(20)</sup></td></tr><tr><td>Total nitrogen (TN)</td><td>2-20 mg/l <sup>(21)</sup> <sup>(22)</sup></td></tr><tr><td>Total phosphorus (TP)</td><td>0,2-2 mg/l <sup>(23)</sup></td></tr></table>	Parameter	BAT-AEL <sup>(15)</sup> <sup>(16)</sup> (daily average)	Chemical oxygen demand (COD) <sup>(17)</sup> <sup>(18)</sup>	25-100 mg/l <sup>(19)</sup>	Total suspended solids (TSS)	4-50 mg/l <sup>(20)</sup>	Total nitrogen (TN)	2-20 mg/l <sup>(21)</sup> <sup>(22)</sup>	Total phosphorus (TP)	0,2-2 mg/l <sup>(23)</sup>	NA	<p>We are satisfied that BAT-AELs are not applicable to this installation.</p> <p>These BAT-AELs are applicable to discharges to water of process effluent and this site discharges to sewer only therefore, the BAT-AELs are not applicable.</p>
Parameter	BAT-AEL <sup>(15)</sup> <sup>(16)</sup> (daily average)												
Chemical oxygen demand (COD) <sup>(17)</sup> <sup>(18)</sup>	25-100 mg/l <sup>(19)</sup>												
Total suspended solids (TSS)	4-50 mg/l <sup>(20)</sup>												
Total nitrogen (TN)	2-20 mg/l <sup>(21)</sup> <sup>(22)</sup>												
Total phosphorus (TP)	0,2-2 mg/l <sup>(23)</sup>												

BATC No.	Summary of BAT Conclusion requirement for Food, Drink and Milk Industries	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	<p>(16) The BAT-AELs may not apply to the production of citric acid or yeast</p> <p>(17) No BAT-AEL applies for biochemical oxygen demand (BOD). As an indication, the yearly average BOD5 level in the effluent from a biological waste water treatment plant will generally be <math>\leq 20</math> mg/l.</p> <p>(18) The BAT-AEL for COD may be replaced by a BAT-AEL for TOC. The correlation between COD and TOC is determined on a case-by-case basis. The BAT-AEL for TOC is the preferred option because TOC monitoring does not rely on the use of very toxic compounds.</p> <p>(20) The lower end of the range is typically achieved when using filtration (e.g. sand filtration, microfiltration, membrane bioreactor), while the upper end of the range is typically achieved when using sedimentation only.</p> <p>(21) The upper end of the range is 30 mg/l as a daily average only if the abatement efficiency is <math>\geq 80</math> % as a yearly average or as an average over the production period.</p> <p>(22) The BAT-AEL may not apply when the temperature of the waste water is low (e.g. below 12 °C) for prolonged periods.</p>		
13	<p><b>Noise management plan</b></p> <p>In order to prevent or, where that is not practicable, to reduce noise emissions, BAT is to set up, implement and regularly review a noise management plan, as part of the environmental management system (see BAT 1), that includes all of the following elements:</p> <ul style="list-style-type: none"> <li>- a protocol containing actions and timelines;</li> <li>- a protocol for conducting noise emissions monitoring;</li> <li>- a protocol for response to identified noise events, eg complaints;</li> <li>- a noise reduction programme designed to identify the source(s), to measure/estimate noise and vibration exposure, to characterise the contributions of the sources and to implement prevention and/or reduction measures.</li> </ul>	NA	<p>We are satisfied that BATc 13 is not applicable to this Installation.</p> <p>A noise management plan is only required where noise nuisance at sensitive receptors is expected or has been substantiated. There have been no substantiated noise nuisances from the site therefore an NMP is not a requirement for this site.</p>
14	<p><b>Noise management</b></p> <p>In order to prevent or, where that is not practicable, to reduce noise emissions, BAT is to use one or a combination of the techniques given below.</p> <ul style="list-style-type: none"> <li>(a) Appropriate location of equipment and buildings</li> <li>(b) Operational measures</li> <li>(c) Low-noise equipment</li> <li>(d) Noise control equipment</li> <li>(e) Noise abatement</li> </ul>	CC	<p>The operator has provided information to support compliance with BATc 14. We have assessed the information provided and we are satisfied that the operator has demonstrated compliance with BATc 14.</p> <p>The Operator declared that is using the following noise management techniques:</p> <ul style="list-style-type: none"> <li>• Operational measures consisting of PPM and the use of trees planted in key areas</li> <li>• Noise control equipment in the form of noise bafflers such as fencing.</li> </ul>
15	<p><b>Odour Management</b></p> <p>In order to prevent or, where that is not practicable, to reduce odour emissions, BAT is to set up, implement and regularly review an odour management plan, as</p>	NA	<p>We are satisfied that BATc 15 is not applicable to this Installation.</p>

BATC No.	Summary of BAT Conclusion requirement for Food, Drink and Milk Industries	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement															
	<p>part of the environmental management system (see BAT 1), that includes all of the following elements:</p> <ul style="list-style-type: none"><li>- a protocol containing actions and timelines;</li><li>- a protocol for conducting odour monitoring.</li><li>- a protocol for response to identified odour incidents eg complaints;</li><li>- an odour prevention and reduction programme designed to identify the source(s); to measure/estimate odour exposure: to characterise the contributions of the sources; and to implement prevention and/or reduction measures.</li></ul>		An odour management plan is only required where odour nuisance at sensitive receptors is expected or has been substantiated. There have been no substantiated odour nuisance from the site recently, therefore this BATc is not applicable.															
SOFT DRINKS AND NECTAR/ JUICE MADE FROM PROCESSED FRUIT AND VEGETABLES BAT CONCLUSIONS (BAT 33)																		
33	<p><b>Energy efficiency – Soft drinks and nectar/ juice made from processed fruit and vegetables</b></p> <p>In order to increase energy efficiency, BAT is to use an appropriate combination of the techniques specified in BAT 6 and of the techniques given below.</p> <table><tr><th colspan="2">Technique</th><th>Description</th><th>Applicability</th></tr><tr><td>(a)</td><td>Single pasteuriser for nectar/juice production</td><td>Use of one pasteuriser for both the juice and the pulp instead of using two separate pasteurisers.</td><td>May not be applicable due to the pulp particle size.</td></tr><tr><td>(b)</td><td>Hydraulic sugar transportation</td><td>Sugar is transported to the production process with water. As some of the sugar is already dissolved during the transportation, less energy is needed in the process for dissolving sugar.</td><td rowspan="2">Generally applicable.</td></tr><tr><td>(c)</td><td>Energy-efficient homogeniser for nectar/juice production</td><td>See BAT 21b.</td></tr></table>	Technique		Description	Applicability	(a)	Single pasteuriser for nectar/juice production	Use of one pasteuriser for both the juice and the pulp instead of using two separate pasteurisers.	May not be applicable due to the pulp particle size.	(b)	Hydraulic sugar transportation	Sugar is transported to the production process with water. As some of the sugar is already dissolved during the transportation, less energy is needed in the process for dissolving sugar.	Generally applicable.	(c)	Energy-efficient homogeniser for nectar/juice production	See BAT 21b.	CC	<p>The operator has provided information to support compliance with BATc 33. We have assessed the information provided and we are satisfied that the operator has demonstrated compliance with BATc.</p> <p>The Operator declared that they do not have any pulp product in their processes so only one pasteuriser used on the lines that require them.</p> <p>Sugar is dissolved on site using a contisolve plant located adjacent to the sugar silo; once dissolved, the sugar is kept circulating through the holding tank prior to be called to the IPC to be added to recipes.</p> <p>Homogenisers are in use on the site where required.</p>
Technique		Description	Applicability															
(a)	Single pasteuriser for nectar/juice production	Use of one pasteuriser for both the juice and the pulp instead of using two separate pasteurisers.	May not be applicable due to the pulp particle size.															
(b)	Hydraulic sugar transportation	Sugar is transported to the production process with water. As some of the sugar is already dissolved during the transportation, less energy is needed in the process for dissolving sugar.	Generally applicable.															
(c)	Energy-efficient homogeniser for nectar/juice production	See BAT 21b.																
Soft Drinks and Nectar/ Juice made from processed fruit and vegetables sector Environmental Performance Levels																		

BATC No.	Summary of BAT Conclusion requirement for Food, Drink and Milk Industries	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement				
EPL	<b>Environmental Performance Level – Energy consumption for the Soft Drinks and Nectar/ Juice made from processed fruit and vegetables sector</b> <table><tr><td>Unit</td><td>Specific energy consumption (yearly average)</td></tr><tr><td>MWh/hl of products</td><td>0.01 – 0.035</td></tr></table>	Unit	Specific energy consumption (yearly average)	MWh/hl of products	0.01 – 0.035	CC	<p>The operator has provided information to support compliance with BAT-EPL. We have assessed the information provided and we are satisfied that the operator has demonstrated compliance with BAT-EPL.</p> <p>The Operator declare an annual average energy consumption of 0.01MWh/hl which is within the range of 0.01 – 0.035 MWh/hl of products.</p>
	Unit	Specific energy consumption (yearly average)					
	MWh/hl of products	0.01 – 0.035					
EPL	<b>Environmental Performance Level – Specific waste water discharge for the Soft Drinks and Nectar/ Juice made from processed fruit and vegetables sector</b> <table><tr><td>Unit</td><td>Specific waste water discharge (yearly average)</td></tr><tr><td>m³/hl of products</td><td>0.08 – 0.20</td></tr></table>	Unit	Specific waste water discharge (yearly average)	m³/hl of products	0.08 – 0.20	CC	<p>The operator has provided information to support compliance with BAT-EPL. We have assessed the information provided and we are satisfied that the operator has demonstrated compliance with BAT-EPL.</p> <p>The Operator declared an annual average wastewater discharge volume of 0.018 m³/hl, which is with the range of 0.08 – 0.02 m³/hl of products.</p>
	Unit	Specific waste water discharge (yearly average)					
	m³/hl of products	0.08 – 0.20					

## **Annex 2: Review and assessment of changes that are not part of the BAT Conclusions derived permit review**

### **Updating permit during permit review consolidation**

- Activity name
- Introductory note updated
- Site plan
- Table S1.1 overhaul
  - Activity Reference (AR) renumbering
  - Updated listed activities
  - Addition of production capacity
  - Directly associated activities (DAAs) standardisation

We have updated permit conditions to those in the current generic permit template as a part of permit consolidation. The conditions will provide the same level of protection as those in the previous permit.

### **Capacity Threshold**

The Environment Agency is looking to draw a “line in the sand” for permitted production capacity; a common understanding between the Operator and regulator for the emissions associated with a (maximum) level of production, whereby the maximum emissions have been demonstrated as causing no significant environmental impact.

We have included a permitted production level (capacity) within table S1.1 of the permit for the section 6.8 listed activity and we need to be confident that the level of emissions associated with this production level have been demonstrated to be acceptable.

The Operator has completed a H1 assessment of emissions for typical figures of production at the time of permitting.

The existing H1 assessment of emissions to water remains valid for the capacity threshold now placed within table S1.1 of the permit.

### **Emissions to Air**

We asked the operator to list all emission points to air from the installation in the Regulation 61 notice. And to provide a site plan indicating the locations of all air emission points.

The operator has provided an up to date air emission plan.

### **Implementing the requirements of the Medium Combustion Plant Directive**

#### **Existing Medium Combustion Plant (1MW-50MW)**

We asked the Operator to provide information on all combustion plant on site in the Regulation 61 Notice as follows:

- Number of combustion plant (CHP engines, back-up generators, boilers);
- Size of combustion plant – rated thermal input (MWth)
- Date each combustion plant came into operation

The Operator provided the information in the table(s) below:

#### Boilers

1. Rated thermal input (MW) of the medium combustion plant.	11.2 MWth
2. Type of the medium combustion plant (diesel engine, gas turbine, dual fuel engine, other engine or other medium combustion plant).	Boiler 1 – 5.6 MWth Boiler 2 – 5.6 MWth
3. Type and share of fuels used according to the fuel categories laid down in Annex II.	Natural gas 100%
4. Date of the start of the operation of the medium combustion plant or, where the exact date of the start of the operation is unknown, proof of the fact that the operation started before 20 December 2018.	Boiler 1 – March 2010 Boiler 2 – June 2012

We have reviewed the information provided and we consider that the declared combustion plant qualify as “existing” medium combustion plant.

For existing medium combustion plant with a rated thermal input greater than 5 MW, Boilers 1 and 2, the emission limit values set out in tables 2 and 3 of Part 1 of Annex II MCPD shall apply from 1 January 2025.

These two boilers have replaced in 2010 and 2012 respectively the originally permitted ones of 12.6 MWth combined input.

We have included the appropriate emission limit values for existing medium combustion plant as part of this permit review. See Table S3.1 in the permit. We have also included a new condition 3.1.4 within the permit which specifies the monitoring requirements for the combustion plant in accordance with the MCPD.

#### **Emissions to Water and implementing the requirements of the Water Framework Directive**

We asked the Operator to provide information on all emissions to water at the installation in the Regulation 61 Notice as follows;

- Identify any effluents which discharge directly to surface or groundwater;
- Provide an assessment of volume and quality, including results of any monitoring data available;
- and for any discharges to water / soakaway whether a recent assessment of the feasibility of connection to sewer has been carried out.

The operator has previously provided assessments for all emissions to water at the installation. The operator declares there has been no change to activities and subsequent effluents generated at the installation since this risk assessment was taken. Consequently, we agree that the original risk assessments remain valid at this time.



### **Soil & groundwater risk assessment (baseline report)**

The IED requires that the operator of any IED installation using, producing or releasing “relevant hazardous substances” (RHS) shall, having regarded the possibility that they might cause pollution of soil and groundwater, submit a “baseline report” with its permit application. The baseline report is an important reference document in the assessment of contamination that might arise during the operational lifetime of the regulated facility and at cessation of activities. It must enable a quantified comparison to be made between the baseline and the state of the site at surrender.

At the definitive cessation of activities, the Operator has to satisfy us that the necessary measures have been taken so that the site ceases to pose a risk to soil or groundwater, taking into account both the baseline conditions and the site’s current or approved future use. To do this, the Operator has to submit a surrender application to us, which we will not grant unless and until we are satisfied that these requirements have been met.

The Operator declared that it does not have a site condition report and a baseline investigation has been planned for 2024 to assess the groundwater and soil conditions.

We have included an Improvement condition in the permit (IC12) which requires the Operator to submit an updated site condition report which includes baseline soil and groundwater data. See Improvement condition(s) in Annex 3 of this decision document.

### **Climate Change Adaptation**

The operator has considered if the site is at risk of impacts from adverse weather (flooding, unavailability of land for land spreading, prolonged dry weather / drought) .

The operator has identified the installation as likely to be or has been affected by dry weather/ drought, which we consider to be a severe weather event.

We do not consider the operator to have submitted a suitable climate change adaptation plan for the installation. We have included an improvement condition into the permit (IC13) to request a climate change adaptation plan is submitted by the operator for approval from the Environment Agency.

### **Containment**

We asked the Operator via the Regulation 61 Notice to provide details of the each above ground tanks which contain potentially polluting liquids at the site, including tanks associated with the effluent treatment process where applicable.

The Operator provided details of all tanks;

- Tank reference/name
- Contents
- Capacity (litres)
- Location
- Construction material(s) of each tank
- The bunding specification including

- Whether the tank is bunded
- If the bund is shared with other tanks
- The capacity of the bund
- The bund capacity as % of tank capacity
- Construction material of the bund
- Whether the bund has a drain point
- Whether any pipes penetrate the bund wall
- Details of overfill prevention
- Drainage arrangements outside of bunded areas
- Tank filling/emptying mitigation measures (drips/splashes)
- Leak detection measures
- Details of when last bund integrity test was carried out
- Maintenance measures in place for tank and bund (inspections)
- How the bund is emptied
- Details of tertiary containment

and whether the onsite tanks currently meet the relevant standard in the Ciria “Containment systems for the prevention of pollution (C736)” report.

We reviewed the information provided by the operator. We are satisfied that the existing tanks and containment measures on site meet the standards set out in CIRIA C736.

### **Carbon Dioxide Recovery**

We asked the Operator as part of the Regulation 61 Notice to confirm whether carbon dioxide (CO<sub>2</sub>) is recovered from the fermentation stage of the process. Where this recovery is not currently in place, we asked them to provide a summary of any feasibility study carried out.

CO<sub>2</sub> recovery is a recognised technique to be considered in the determination of BAT as described in Chapter 4.4.4.3 of the FDM BREF. The stated environmental benefits include reduced carbon emissions from the permitted installation.

The economics of on-site recovery at the time of the BREF review was a relevant factor in determining whether CO<sub>2</sub> recovery was included as a specific BAT Conclusion. It was noted at the time that industrial gas suppliers were able to provide CO<sub>2</sub> obtained as a co-product from other sectors, such as during ammonia production, at low cost and as readily available resource.

This situation has now changed in the UK over the last two years, primarily due to energy prices. Ammonia is no longer produced in the UK and the CO<sub>2</sub> supply chain is fragile and dependent on imports. Defra and Department for Business and Trade are keen on diversification of CO<sub>2</sub> supply to increase supply resilience.

There is no potential for carbon dioxide recovery as this site is not a brewery but a soft drinks manufacturer where CO<sub>2</sub> is imported to site. Because these products are not brewed or fermented, there is no CO<sub>2</sub> generation.

## Annex 3: Improvement Conditions

Based on the information in the Operator's Regulation 61 Notice response and our own records of the capability and performance of the installation at this site, we consider that we need to set improvement conditions so that the outcome of the techniques detailed in the BAT Conclusions are achieved by the installation. These improvement conditions are set out below - justifications for them is provided at the relevant section of the decision document (Annex 1 or Annex 2).

Previous improvement conditions marked as complete in the previous permit.

<b>Superseded Improvement Conditions – Removed from permit as marked as “complete”</b>	
<b>Reference</b>	<b>Improvement Condition</b>
IC1	The Operator shall review the secondary containment measures provided for the potentially polluting substances that are stored or held on site. The review shall include but not be restricted to the Sodium Hydroxide, Hydrochloric acid, Sugar and Fruit concentrate tanks; and ensure that all storage tanks, drums and containers within the installation meet indicative BAT as per Agency guidelines Food and Drink Sector Guidance Note S6.10 Oct.2003 (section 2.2.5). The Operator shall provide the Agency with a written copy of the review and shall implement identified improvements to a timescale agreed with the Agency.
IC2	The Operator shall provide the Agency with a report on the substitution of R22 Refrigerant with less hazardous alternatives. The Operator shall provide the Agency with a written report that includes a timescale for the implementation of any improvements that have been identified.
IC3	The Operator shall submit a written report of the findings to the agency of the water minimisation audit which the Operator stated (page 61 of the application) they will complete within one year of the permit.
IC4	The Operator shall review the Accident Management Plan submitted as part of the IPPC application in line with Agency Sector Guidance Note IPPC S6.10, Issue 1, August 2003. A copy of the revised Accident Management plan shall be submitted to the Agency, together with proposals for associated improvements to a timescale agreed in writing with the Agency.
IC5	The Operator shall review the operation of the effluent treatment plants on site (Main and Zeus) in line with Agency guide lines Food and Drink Sector Guidance Note S6.10 Oct.2003 (2.2.2) including but not restricted to pH control. The Operator shall provide the Agency with a written report that includes a timescale for the implementation of any improvements that have been identified.
IC6	The Operator shall carry out a survey to assess the adequacy of the construction and condition of the trade effluent and surface water drainage system with the purpose of preventing fugitive releases leading to contamination of surface water, groundwater and land, having regard for Agency Sector Guidance Note IPPC S6.10, Issue 1, August 2003. A written report summarising the findings shall be submitted to the

	Agency, which shall include proposals for improvements with a timescale for implementation which shall be adhered to unless otherwise agreed in writing by the Agency.
IC7	The operator shall make provision for the protection of surface water from fugitive emissions having regard for Agency Sector Guidance Note IPPC S6.10, Issue 1, August 2003. This shall include but not be restricted to the fitting of a conductivity meter with centralised alarm and Penstock valve. A report shall be submitted to the Agency which shall include a timescale for implementation which shall be adhered to unless otherwise agreed in writing by the Agency.
IC8	The Operator shall develop and implement a formal procedure for the inspection and subsequent maintenance of all surface and trade effluent drainage systems, with the purpose of preventing fugitive releases to the environment, having regard for Agency Sector Guidance Note IPPC S6.10, Issue 1, August 2003. A copy of the procedure shall be submitted the Agency, together with a timescale for implementation and proposals for the frequency of future inspections.
IC9	Retained and renumbered IC14
PO1	Removed as not applicable anymore.

The following improvement conditions have added to the permit as a result of the variation.

<b>Improvement programme requirements</b>		
<b>Reference</b>	<b>Reason for inclusion</b>	<b>Justification of deadline</b>
IC10	The operator shall confirm achievement of the 'Narrative' BAT conclusions as identified in the Food, Drink and Milk Bref published on 4 December 2019 where BAT is currently not demonstrated or achieved with respect to BATc 6. Refer to BAT Conclusions for a full description of the BAT requirement.	3 months from permit issue
IC11	The operator shall use refrigerants without ozone depletion potential and with a low global warming potential (GWP) in accordance with BAT 9 from the Food, Drink and Milk Industries BATCs. To demonstrate compliance against BAT 9, the operator shall produce a plan for the onsite refrigerant system(s) at the installation. The plan is to be assessed by the Environment Agency and shall be incorporated within the existing environmental management system. The plan should include, but not be limited to, the following: <ul style="list-style-type: none"> <li>Where practicable, retro filling systems containing high GWP refrigerants e.g. R-404A with lower GWP alternatives as soon as possible.</li> </ul>	3 months from permit issue

	<ul style="list-style-type: none"> <li>An action log with timescales, for replacement of end-of-life equipment using refrigerants with the lowest practicable GWP.</li> </ul>	
IC12	<p>The Operator shall produce a Site Condition Report (SCR) in line with our H5 Guidance. The report shall contain the information necessary to determine the state of soil and groundwater, and ensure this is maintained throughout the life of the permit by using the results to better inform the SPMP. The report shall be submitted to the Environment Agency for review.</p>	12 months from permit issue
IC13	<p>The operator shall produce a climate change adaptation plan, which will form part of the EMS. The plan shall include, but not be limited to:</p> <ul style="list-style-type: none"> <li>Details of how the installation has or could be affected by severe weather;</li> <li>The scale of the impact of severe weather on the operations within the installation;</li> <li>An action plan and timetable for any improvements to be made to minimise the impact of severe weather at the installation.</li> </ul> <p>The Operator shall implement any necessary improvements to a timetable agreed in writing with the Environment Agency.</p>	12 months from permit issue or other date as agreed in writing with the Environment Agency
IC14	<p>The Operator shall review the site Environment Management System (EMS) in accordance with condition 1.3.1 of the permit, and provide a summary report to the Environment Agency of any changes made.</p> <p>The review shall consider:-</p> <ul style="list-style-type: none"> <li>Changes made on-site following construction and commissioning of the Ingredients Processing Centre (IPC).</li> <li>All relevant guidance including 'How you'll be regulated: environmental permits', and 'The Environmental Permitting (England and Wales) Regulations 2016'.</li> </ul>	3 months from permit issue