



Department for
Energy Security
& Net Zero

Richard Chambers
Southern Electric Power Distribution PLC
Faraday Road
Dorcan
Swindon
SN3 5EY

Energy Infrastructure Planning

3-8 Whitehall Place
London
SW1A 2JP

Email:

S37consents@energysecurity.gov.uk

Website: www.gov.uk/desnz

Our ref: 1925u
Your ref: EUL148

17 June 2024

Dear Mr Chambers,

**SCREENING DECISION BY THE SECRETARY OF STATE UNDER THE
ELECTRICITY WORKS (ENVIRONMENTAL IMPACT ASSESSMENT)
(ENGLAND AND WALES) REGULATIONS 2017 (“THE 2017
REGULATIONS”)**

NAME OF SCHEME: Sherrington Dairy

Decision:

The Secretary of State concludes that the proposed works are not EIA development under the 2017 Regulations and do not require a statutory EIA as they are unlikely to have significant effects on the environment due to their nature, location and size. A copy of this letter has been sent to the LPA for information.

Screening decision for a proposed development (“the proposed development”) to:

- Upgrade approximately 1,065 metres of existing 11kV overhead from 2-phase to 3-phase.
- Upgrade an existing pole-mounted transformer to 110kVA.



Department for Energy Security & Net Zero

Secretary of State considerations:

The Secretary of State has considered the factors set out in Schedule 3 of the 2017 Regulations, together with the information within the supplied documentation (“the Application”) by Southern Electric Power Distribution PLC (“the Applicant”) in relation to the impacts on the environment of the proposed development and the views of Wiltshire Council (“the LPA”). In reaching her decision the Secretary of State notes the following factors:

1. The proposed development does not fall within Schedule 1 (mandatory EIA).
2. The proposed development falls under Schedule 2 of the 2017 Regulations as the electricity line is to be installed above ground in a sensitive area.
3. The proposed development falls within the Cranborne Chase & West Wiltshire Downs National Landscape (formerly Area of Outstanding National Beauty) and a Site of Special Scientific Interest (SSSI) Impact Risk Zone (IRZ) associated with the River Avon SSSI/Special Area of Conservation (~30 metres away).
4. The Applicant consulted with the LPA who had no objection to the proposed development (reference: PL/2024/00958) and concluded that EIA is not required as there will be no demonstrable impact to the National Landscape as visual qualities of the equipment would remain the same as present upon completion of the proposed development.
5. The Applicant consulted with Natural England who confirmed in communications on 6 June 2024 (Natural England reference: 465010) that they had no comment to make on the proposed development.
6. The proposed development is a minor modification to an existing piece of infrastructure and is likely to have minimal visual impact on the National Landscape in which it is situated.

Yours sincerely,

John McKenna
Head of Network Planning team
Energy Infrastructure Planning Delivery Team