

## **Construction Noise and Vibration Monthly Report – September 2024**

**North Warwickshire Borough Council**

<b>Non-Technical Summary</b>	<b>1</b>
<b>Abbreviations and Descriptions</b>	<b>3</b>
<b>1 Introduction</b>	<b>4</b>
1.2 Measurement Locations	6
<b>2 Summary of Results</b>	<b>8</b>
2.1 Summary of Measured Noise and Vibration Levels	8
2.2 Exceedances of the LOAEL and SOAEL	12
2.3 Exceedances of Trigger Level	15
2.4 Complaints	15
<b>Appendix A Site Locations</b>	<b>16</b>
<b>Appendix B Monitoring Locations</b>	<b>22</b>
<b>Appendix C Data</b>	<b>28</b>

### List of tables

Table 1: Table of Abbreviations	3
Table 2: Monitoring Locations	6
Table 3: Summary of Measured dB $L_{Aeq}$ Data over the Monitoring Period	9
Table 4: Summary of Measured PPV Data over the Monitoring Period	12
Table 5: Summary of Exceedances of LOAEL and SOAEL	13
Table 6: Summary of Total Exceedances of SOAEL	15
Table 7: Summary of Exceedances of Trigger Levels	15
Table 8: Summary of Complaints	15

# Non-Technical Summary

This Noise and Vibration Monitoring Report fulfils HS2 Limited's commitment detailed in the Environmental Minimum Requirements (EMRs), Annex 1, Code of Construction Practice, to present the results of noise and vibration monitoring carried out within North Warwickshire Borough Council (NWBC) area during the month of September 2024.

Within this period noise and vibration monitoring were undertaken at the following worksites:

- Church Lane Embankment worksite (ref.: CLE), where concrete works, blinding, pond construction, fencing, topsoil stripping, material deliveries and sheet pile installation were underway.
- Kingsbury Main Compound worksite (ref.: KMC), where no works were underway.
- Birmingham & Fazeley Canal Viaduct worksite (ref.: BFCV), where timber frame installation, deck works, and parapet installation were underway.
- Marston Box worksite (ref.: MB), where timber frame installation, stripping of shutters, steel cutting, and lifting works were underway.
- Faraday Avenue Embankment and Underbridge worksite (ref.: FAEU), where surfacing works, site maintenance, concrete works, terminal installation, excavation and cable pulling were underway.
- Chattle Hill Box Structure worksite (ref.: CHBS), where steel fixing and diaphragm wall installation were underway.
- Attleboro Lane Overbridge worksite (ref.: ALO), where utility works and drainage were underway.
- Marsh Lane Embankment (ref.: MLE), where no works were underway.
- Gilson Embankment worksite (ref.: GE), where road realignment works, stockpiling, retaining wall works and temporary road installation were underway.
- Gilson Drive worksite (ref.: GLD), where temporary road works, platform installation and material deliveries were underway.
- Birmingham Road worksite (ref.: BRD), where embankment filling was underway.

The HS2 threshold levels for significant noise impacts, which are defined in Information Paper E23 (<https://www.gov.uk/government/publications/hs2-information-papers-environment>) were exceeded on one (1) occasion during the reporting period.

There were no exceedances of trigger levels, as defined in Section 61 consents during the reporting period.

No complaints were received during the monitoring period.

# Abbreviations and Descriptions

The abbreviations, descriptions and project terminology used within this report can be found in Table 1.

Table 1: Table of Abbreviations

Acronym/Term	Definition
$L_{Aeq,T}$	See equivalent continuous sound pressure level
Ambient sound	A description of the all-encompassing sound at a given location and time which will include sound from many sources near and far. Ambient sound can be quantified in terms of the equivalent continuous sound pressure level, $L_{pAeq,T}$
Decibel(s), or dB	Between the quietest audible sound and the loudest tolerable sound there is a million to one ratio in sound pressure (measured in Pascal (Pa)). Because of this wide range, a level scale called the decibel (dB) scale, based on a logarithmic ratio, is used in sound measurement. Audibility of sound covers a range of approximately 0-140dB.
Decibel(s) A-weighted, or dB(A)	The human ear system does not respond uniformly to sound across the detectable frequency range and consequently instrumentation used to measure sound is weighted to represent the performance of the ear. This is known as the 'A weighting' and is written as 'dB(A)'.
Equivalent continuous sound pressure level, or $L_{Aeq,T}$	An index used internationally for the assessment of environmental sound impacts. It is defined as the notional unchanging level that would, over a given period of time (T), deliver the same sound energy as the actual time-varying sound over the same period. Hence fluctuating sound levels can be described in terms of an equivalent single figure value, typically expressed as a decibel level.
Exclusion of data	Measurement of noise levels can be affected by weather conditions such as prolonged periods of rain, winds speeds higher than 5m/s and snow/ice ground cover. Noise levels measured during these periods are considered not representative of normal noise conditions at the site and, for the purposes of this report, are excluded from the assessment of exceedances and calculation of typical noise levels and are also greyed out in charts. Identifiable incongruous noise and vibration events not attributable to HS2 construction noise are also excluded.
Façade	A facade noise level is the noise level 1m in front of a large reflecting surface. The effect of reflection, is to produce a slightly higher (typically +3 dB) sound level than it would be if the reflecting surface was not there.
Free-field	A free-field noise level is the noise level measured at a location where no reflective surfaces, other than the ground, lies within 3.5 metres of the microphone position.
LOAEL	Lowest Observed Adverse Effect Level - the level above which adverse effects on health and quality of life can be detected.
Peak particle velocity, or PPV	Instantaneous maximum velocity reached by a vibrating element as it oscillates about its rest position. The PPV is a simple indicator of perceptibility and risk of damage to structures due to vibration. It is usually measured in mm/s.
SOAEL	Significant Observed Adverse Effect Level - the level above which significant adverse effects on health and quality of life occur.
Sound pressure level	The parameter by which sound levels are measured in air. It is measured in decibels. The threshold of hearing has been set at 0dB, while the threshold of pain is approximately 120dB. Normal speech is approximately 60dB at a distance of 1 metre and a change of 3dB in a time varying sound signal is commonly regarded as being just detectable. A change of 10dB is subjectively twice, or half, as loud.
Vibration dose value, or VDV	An index used to evaluate human exposure to vibration in buildings. While the PPV provides information regarding the magnitude of single vibration events, the VDV provides a measure of the total vibration experienced over a specified period of time (typically 16h daytime and 8h night-time). It takes into account the magnitude, the number and the duration of vibration events and can be used to quantify exposure to continuous, impulsive, occasional and intermittent vibration. The vibration dose value is measured in $m/s^{1.75}$ .

# 1 Introduction

1.1.1 HS2 is required to undertake noise (and vibration) monitoring as necessary to comply with the requirements of the High Speed Rail (London-West Midlands) Environmental Minimum Requirements, including specifically Annex 1: Code of Construction Practice, in addition to any monitoring requirements arising from conditions imposed through consents under Section 61 of the Control of Pollution Act, 1974 or through Undertakings & Assurances given to third parties. Such monitoring may be undertaken for the following purposes:

- monitoring the impact of construction works;
- to investigate complaints, incidents and exceedance of trigger levels; or
- monitoring the effectiveness of noise and vibration control measures.

1.1.2 Monitoring data and interpretive reports are to be provided to each relevant local authority on a monthly basis and shall include a summary of the construction activities occurring, the data recorded over the monitoring period, any complaints received, any periods in exceedance of agreed trigger levels, the results of any investigations and any actions taken or mitigation measures implemented. This report provides noise data, and interpretation thereof, for monitoring carried out by HS2 within the North Warwickshire Borough Council (NWBC) area for the period 1<sup>st</sup> to 30<sup>th</sup> of September 2024.

1.1.3 Construction sites in the local authority area where monitoring was undertaken during this period include:

- Church Lane Embankment worksite, ref.: CLE (see Plan 1 in Appendix A), where work activities included:
  - Concrete works, including platform and slabs.
  - Blinding.
  - Pond construction.
  - Fencing including fixing gate.
  - Topsoil stripping.
  - Material deliveries.
  - Sheet pile installation.
- Kingsbury Main Compound worksite, ref.: KMC (see Plan 2 in Appendix A), where no works were underway.

- Birmingham & Fazeley Canal Viaduct worksite, ref.: BFCV (see Plan 2 in Appendix A), where work activities included:
  - Timber frame installation.
  - Deck works.
  - Parapet installation.
- Marston Box/Marston Lane worksite (ref.: MB), where work activities included:
  - Timber frame installation.
  - Stripping of shutters.
  - Steel cutting.
  - Lifting including parapet installation.
- Faraday Avenue Embankment and Underbridge worksite, ref.: FAEU (see Plan 3 in Appendix A), where work activities included:
  - Surfacing works, including laying tarmac and rolling.
  - Site maintenance.
  - Concrete works.
  - Terminal installation.
  - Excavation.
  - Cable pulling.
- Chattle Hill Box Structure worksite, ref.: CHBS (see Plan 4 in Appendix A), where work activities included:
  - Steel fixing of deck.
  - Diaphragm wall installation.
- Attleboro Lane Overbridge worksite, ref.: ALO (see Plan 4 in Appendix A), where work activities included:
  - Utility works.
  - Drainage
- Marsh Lane Embankment worksite, ref: MLE (See Plan 4 in Appendix A), where no works were underway.
- Gilson Embankment worksite, ref.: GE (see Plan 4 in Appendix A)
  - Road realignment works.

- Stockpiling.
- Retaining wall platform works.
- Temporary road installation.
- Gilson Drive worksite, ref.: GLD (see Plan 4 in Appendix A), works activities included:
  - Temporary road works.
  - Platform installation.
  - Material deliveries.
- Birmingham Road worksite, ref.: BRD (see Plan 4 in Appendix A), work activities included:
  - Embankment filling.

1.1.4 The applicable standards, guidance, and monitoring methodology is outlined in the construction noise and vibration monitoring methodology report which can be found at the following location <https://www.gov.uk/government/collections/monitoring-the-environmental-effects-of-hs2>. Noise and vibration monitoring reports for previous months can also be found at this location.

## 1.2 Measurement Locations

1.2.1 Sixteen (16) noise monitoring installations and nine (9) vibration monitoring installations were active in September in the NWBC area. Table 2 summarises the location of noise and vibration monitoring installations within the NWBC area in September 2024.

1.2.2 Maps showing the position of noise and vibration monitoring installations are presented in Appendix B.

Table 2: Monitoring Locations

Worksite Reference	Measurement Reference	Address
Church Lane Embankment (CLE)	CLE-N1	Highfields Cottage, Middleton, North Warwickshire
Kingsbury Main Compound (KMC)	KMC-N1	Wheatley House, Kingsbury Road, Curdworth CP, Marston, Warwick
Birmingham Fazeley Canal Viaduct (BFCV)	BFCV-N2	North of Lock Cottage, Marston Lane, Curdworth CP, North Warwickshire
	BFCV-V4	North of Lock Cottage, Marston Lane, Curdworth CP, North Warwickshire



Worksite Reference	Measurement Reference	Address
Marston Box (MB)	MB-N1	Elford House, Kingsbury Road, Curdworth, Sutton Coldfield
	MB-V1	Elford House, Kingsbury Road, Curdworth, Sutton Coldfield
Faraday Avenue Embankment and Underbridge (FAEU)	FAEU-N1	South of Orchard Cottage, Newlands Lane, Curdworth, Warwickshire
	FAEU-V1	South of Orchard Cottage, Newlands Lane, Curdworth, Warwickshire
Chattle Hill Box Structure (CHBS)	CHBS-N1	6 Gorsey Way, Coleshill, Warwickshire, Birmingham
Marsh Lane Embankment (MLE)	MLE-N1	Rostrevor, Vicarage Lane, Water Orton CP, North Warwickshire
Attleboro Lane Overbridge (ALO)	ALO-N1	West of 47 Attleboro Lane, Water Orton, Birmingham
	ALO-N2	(south of) 57 Attleboro Lane, Water Orton, Birmingham, B46 1SD
	ALO-V1	West of 47 Attleboro Lane, Water Orton, Birmingham
	ALO-V5	(south of) 57 Attleboro Lane, Water Orton, Birmingham, B46 1SD
	AFE-N1	Attleboro Farm, Attleboro Lane, Water Orton, Birmingham, B46 1SD
	AFE-V1	Attleboro Farm, Attleboro Lane, Water Orton, Birmingham, B46 1SD
Gilson Embankment (GE)	GE-N1	The Cottage, Gilson Road, Coleshill, Warwickshire
	GE-N2	Lovelock Cottage, Gilson Road, Warwickshire
	GE-V1	The Cottage, Gilson Road, Coleshill, Warwickshire
Gilson Drive (GLD)	GLD-N1	10 Gilson Dr, Coleshill, Birmingham
	GLD-V1	10 Gilson Dr, Coleshill, Birmingham
	CM-N1	Coleshill Manor Office Campus, Birmingham
Birmingham Road (BRD)	BRD-N2	1 New Cottages, Birmingham Road, Coleshill, Birmingham
	BRD-N3	1 New Cottages, Birmingham Road, Coleshill, Birmingham
	BRD-V1	1 New Cottages, Birmingham Road, Coleshill, Birmingham

## 2 Summary of Results

### 2.1 Summary of Measured Noise and Vibration Levels

2.1.1 Table 3 presents a summary of the measured noise levels at each monitoring location over the reporting period. The  $L_{Aeq,T}$  is presented for each of the relevant time periods averaged over the calendar month, along with the highest single period  $L_{Aeq,T}$  that was found to occur within the month.

Table 3: Summary of Measured dB L<sub>Aeq</sub> Data over the Monitoring Period

Worksite Reference	Measurement Reference	Site Address	Free-Field or Façade Measurement	Weekday Average L <sub>Aeq,T</sub> (Highest Day L <sub>Aeq,T</sub> )					Saturday Average L <sub>Aeq,T</sub> (Highest Day L <sub>Aeq,T</sub> )					Sunday / Public Holiday Average L <sub>Aeq,T</sub> (Highest Day L <sub>Aeq,T</sub> )	
				0700 - 0800	0800 - 1800	1800 - 1900	1900 - 2200	2200 - 0700	0700 - 0800	0800 - 1300	1300 - 1400	1400 - 2200	2200 - 0700	0700 - 2200	2200 - 0700
CLE	CLE-N1	Highfields Cottage, Middleton	Free-field	47.1 (50.4)	47.0 (51.1)	44.7 (52.0)	43.4 (51.7)	40.8 (49.7)	44.4 (46.5)	46.8 (54.8)	44.1 (45.8)	45.6 (60.7)	40.3 (55.2)	45.8 (53.4)	44.6 (52.2)
KMC	KMC-N1	Kingsbury Road, Curdworth	Free-field	57.6 (67.6)	62.6 (69.6)	55.6 (66.5)	54.1 (66.5)	54.1 (71.8)	62.0 (74.7)	53.9 (60.7)	52.9 (56.7)	51.7 (55.4)	49.4 (66.6)	53.3 (67.0)	51.0 (60.5)
BFCV	BFCV-N2	(North of) Lock Cottage, Marston Lane, Curdworth	Free-field	68.5 (70.5)	68.9 (70.7)	67.6 (70.0)	66.9 (69.3)	64.7 (70.1)	65.8 (66.8)	67.1 (69.2)	67.3 (69.1)	66.6 (68.7)	62.8 (66.0)	67.8 (71.0)	65.2 (70.5)
MB	MB-N1	Elford House, Kingsbury Road, Curdworth	Free-field	57.5 (60.7)	57.1 (60.8)	57.4 (61.5)	56.3 (60.2)	54.1 (60.4)	55.8 (57.5)	54.8 (56.3)	54.6 (57.7)	54.1 (58.2)	50.1 (55.6)	54.5 (57.6)	53.4 (61.0)
FAEU	FAEU-N1	(South of) Orchard Cottage, Newlands Lane, Curdworth	Free-field	56.0 (59.6)	57.2 (67.7)	55.2 (60.3)	53.8 (59.4)	52.2 (59.5)	54.8 (56.9)	54.2 (56.0)	53.2 (55.9)	52.1 (57.4)	48.8 (55.0)	52.9 (61.3)	52.4 (59.7)
CHBS	CHBS-N1	6 Gorsey Way, Coleshill	Free-field	65.2 (67.9)	64.9 (69.0)	63.2 (65.6)	60.9 (67.1)	59.1 (65.4)	61.4 (62.0)	63.2 (64.4)	63.5 (63.8)	62.1 (65.6)	56.9 (60.0)	62.4 (65.4)	60.2 (64.7)

Worksite Reference	Measurement Reference	Site Address	Free-Field or Façade Measurement	Weekday Average $L_{Aeq,T}$ (Highest Day $L_{Aeq,T}$ )					Saturday Average $L_{Aeq,T}$ (Highest Day $L_{Aeq,T}$ )					Sunday / Public Holiday Average $L_{Aeq,T}$ (Highest Day $L_{Aeq,T}$ )	
				0700 - 0800	0800 - 1800	1800 - 1900	1900 - 2200	2200 - 0700	0700 - 0800	0800 - 1300	1300 - 1400	1400 - 2200	2200 - 0700	0700 - 2200	2200 - 0700
				MLE	MLE-N1	Rostrevor, Vicarage Lane, Water Orton CP	Free field	54.7 (59.2)	54.5 (57.8)	53.0 (57.2)	52.7 (56.6)	51.0 (59.0)	52.9 (57.0)	52.8 (56.8)	51.9 (54.4)
ALO	ALO-N1	West of 47 Attleboro Lane, Water Orton	Free field	55.8 (61.4)	58.0 (65.4)	53.6 (60.4)	53.8 (59.8)	52.3 (61.7)	55.8 (68.4)	55.3 (60.6)	53.1 (57.1)	54.6 (64.6)	49.0 (58.1)	54.1 (60.8)	51.9 (59.1)
	ALO-N2	(South of) 57 Attleboro Lane, Water Orton	Free field	56.8 (62.2)	63.4 (75.4)	54.5 (61.1)	54.7 (61.3)	53.1 (62.2)	54.6 (59.5)	57.4 (62.5)	53.7 (58.3)	55.7 (65.9)	49.3 (57.6)	54.7 (61.8)	52.5 (60.2)
	AFE-N1	Attleboro Farm, Attleboro Lane	Free field	61.7 (65.7)	63.2 (66.6)	60.3 (67.4)	59.8 (66.6)	58.5 (66.9)	58.7 (63.0)	60.1 (64.3)	58.3 (62.8)	60.1 (66.0)	55.8 (61.0)	59.4 (65.0)	58.7 (66.7)
GE	GE-N1	The Cottage, Gilson Road, Coleshill	Free-field	60.9 (63.7)	64.2 (70.0)	58.6 (62.5)	57.9 (67.7)	55.8 (63.0)	56.8 (59.9)	58.3 (61.8)	57.8 (61.4)	57.1 (63.4)	52.2 (57.3)	56.3 (59.2)	55.0 (61.6)
	GE-N2	Lovelock Cottage, Gilson Road	Free-field	60.9 (63.6)	63.4 (66.3)	60.9 (63.8)	59.4 (62.3)	57.0 (62.1)	56.6 (59.4)	56.6 (59.3)	57.2 (60.2)	57.8 (60.7)	53.0 (56.7)	57.0 (60.5)	54.8 (59.2)

Worksite Reference	Measurement Reference	Site Address	Free-Field or Façade Measurement	Weekday Average $L_{Aeq,T}$ (Highest Day $L_{Aeq,T}$ )					Saturday Average $L_{Aeq,T}$ (Highest Day $L_{Aeq,T}$ )					Sunday / Public Holiday Average $L_{Aeq,T}$ (Highest Day $L_{Aeq,T}$ )	
				0700 - 0800	0800 - 1800	1800 - 1900	1900 - 2200	2200 - 0700	0700 - 0800	0800 - 1300	1300 - 1400	1400 - 2200	2200 - 0700	0700 - 2200	2200 - 0700
GLD	GLD-N1	10 Gilson Dr, Coleshill	Free-field	56.6 (60.6)	57.9 (60.6)	56.1 (58.5)	54.0 (58.3)	52.1 (61.8)	54.5 (59.0)	54.7 (55.4)	54.5 (56.6)	53.0 (62.1)	49.1 (53.4)	54.2 (60.0)	52.3 (61.1)
	CM-N1	Coleshill Manor Office Campus	Free-field	57.1 (60.5)	58.0 (65.5)	55.5 (59.1)	54.8 (57.7)	53.2 (58.7)	54.5 (55.5)	54.4 (56.7)	53.7 (56.4)	53.3 (59.6)	50.5 (55.1)	55.0 (58.9)	53.6 (60.3)
BRD	BRD-N2	1 New Cottages, Birmingham Road, Coleshill	Free-field	62.5 (64.9)	63.7 (65.6)	59.9 (61.8)	58.5 (62.9)	56.8 (62.5)	58.8 (60.1)	62.2 (64.3)	59.9 (62.4)	58.3 (66.1)	53.8 (57.5)	59.1 (63.3)	57.2 (64.8)
	BRD-N3		Free-field	65.2 (70.6)	67.3 (70.8)	60.4 (66.1)	58.1 (61.2)	56.2 (61.3)	58.7 (60.3)	65.9 (69.5)	62.0 (69.6)	59.3 (67.0)	54.1 (56.7)	58.2 (63.1)	56.3 (62.9)

2.1.2 Table 4 presents a summary of the measured vibration levels at the monitoring location over the reporting period. The highest PPV measured during the monitoring along any axis is presented in the table.

Table 4: Summary of Measured PPV Data over the Monitoring Period

Worksite Reference	Measurement Reference	Monitor Address	Highest PPV measured in any axis, mm/s
BFCV	BFCV-V4	(North of) Lock Cottage, Marston Lane, Curdworth CP, North Warwickshire	0.78 (X-axis)
MB	MB-V1	Kingsbury Road, Curdworth, Sutton Coldfield, West Midland	0.40 (X-axis)
FAEU	FAEU-N1	(south of) Orchard Cottage, Newlands Lane, Curdworth, Warwickshire	1.10 (Z-axis)
ALO	ALO-V1	West of 47 Attleboro Lane, Water Orton, Birmingham	1.63 (X-axis)
	ALO-V5	(south of) 57 Attleboro Lane, Water Orton, Birmingham, B46 1SD	12.70 (Z-axis)*
	AFE-V1	Attleboro Farm, Attleboro Lane, Water Orton, Birmingham, B46 1SD	1.19 (Z-axis)
GE	GE-V1	The Cottage, Gilson Road, Coleshill, Warwickshire	1.82 (Z-axis)
GLD	GLD-V1	10 Gilson Dr, Coleshill, Birmingham	0.66 (Z-axis)
BRD	BRD-V1	1, New Cottages, Birmingham Road, Coleshill, Birmingham	4.40 (X-axis)

\*High vibration level due to vacuum excavation taking place in close proximity to the monitoring station.

2.1.3 Appendix C presents graphs of the noise and vibration monitoring data over the month for each of the measurement locations. Noise data presented consists of the hourly  $L_{Aeq}$  values and, where relevant, the  $L_{Aeq,T}$  values (where the time period T has been taken to be the averaging period as specified in Table 1 of HS2 Information Paper E23). Vibration data presented consist of hourly PPV values. The full data set for the monitoring equipment can be found at the following location: <https://data.gov.uk/dataset/24542ae7-dd44-444f-b259-871c4cc43b5e/environmental-monitoring-data>.

## 2.2 Exceedances of the LOAEL and SOAEL

2.2.1 The lowest observed adverse effect level (LOAEL) is defined in the Planning Practice Guidance – Noise (PPG) as the level above which "noise starts to cause small changes in behaviour and/or attitude, e.g. turning up volume of television; speaking more loudly; where there is no alternative ventilation, having to close windows for some of

the time because of the noise. Potential for some reported sleep disturbance. Affects the acoustic character of the area such that there is a perceived change in the quality of life".

- 2.2.2 The significant observed adverse effect level (SOAEL) is defined in the 'Planning Practice Guidance – Noise' as the level above which "noise causes a material change in behaviour and/or attitude, e.g. avoiding certain activities during periods of intrusion; where there is no alternative ventilation, having to keep windows closed most of the time because of the noise. Potential for sleep disturbance resulting in difficulty in getting to sleep, premature awakening and difficulty in getting back to sleep. Quality of life diminished due to change in acoustic character of the area."
- 2.2.3 HS2 Phase One Information Paper E23: Control of Construction Noise and Vibration sets out the LOAELs and SOAELs for construction noise.
- 2.2.4 Where reported construction noise levels exceed the LOAEL and SOAEL, relevant periods will be identified. Summary statistics to evaluate ongoing qualification for noise insulation and temporary rehousing are also presented where relevant.
- 2.2.5 Table 5 presents a summary of recorded exceedances of the LOAEL and SOAEL at each measurement location over the reporting period, including the number of exceedances during each time period.

Table 5: Summary of Exceedances of LOAEL and SOAEL

Worksite Reference	Measurement Reference	Site Address	Day (Weekday, Saturday, Sunday, Night)	Time period	Number of exceedances of LOAEL	Number of exceedances of SOAEL
CLE	CLE-N1*	Highfields Cottage, Middleton	All days	All periods	No exceedances	No exceedances
KMC	KMC-N1*	Kingsbury Road, Sutton Coldfield	All days	All periods	No exceedances	No exceedances
BFCV	BFCV-N2	North of Lock Cottage, Marston Lane, Curdworth	All days	All periods	No exceedances	No exceedances
MB	MB-N1*	Elford House, Kingsbury Road, Curdworth	All days	All periods	No exceedances	No exceedances
FAEU	FAEU-N1*	South of Orchard Cottage, Newlands Lane, Curdworth	All days	All periods	No exceedances	No exceedances

Worksite Reference	Measurement Reference	Site Address	Day (Weekday, Saturday, Sunday, Night)	Time period	Number of exceedances of LOAEL	Number of exceedances of SOAEL
CHBS	CHBS-N1*	6 Gorsey Way, Coleshill	Weekday	0800-1800	1	No exceedances
MLE	MLE-N1	Rostrevor, Vicarage Lane, Water Orton CP	All days	All periods	No exceedances	No exceedances
ALO	ALO-N1	West of 47 Attleboro Lane, Water Orton	Weekday	0800-1800	1	No exceedances
	ALO-N2	(south of) 57 Attleboro Lane, Water Orton, Birmingham, B46 1SD	Weekday	0800-1800	7	1
	AFE-N1	Attleboro Farm, Attleboro Lane, Water Orton, Birmingham, B46 1SD	Weekday Weekday	All periods	No exceedances	No exceedances
GE	GE-N1	The Cottage, Gilson Road, Coleshill	Weekday	0800-1800	1	No exceedances
	GE-N2	Lovelock Cottage, Gilson Road	All days	All periods	No exceedances	No exceedances
GLD	GLD-N1	10 Gilson Dr, Coleshill	All days	All periods	No exceedances	No exceedances
	CM-N1	Coleshill Manor Office Campus, Birmingham	Weekday	0800-1800	1	No exceedances
BRD	BRD-N2	1 New Cottages, Birmingham Road, Coleshill	All days	All periods	No exceedances	No exceedances
	BRD-N3*	1 New Cottages, Birmingham Road, Coleshill	Weekday Weekday	0700-0800 0800-1800	1 2	No exceedances

\*A distance correction has been applied when calculating exceedances of the LOAEL and SOAEL.

2.2.6 Exceedances of the LOAEL were recorded at six (6) noise monitors. The LOAEL exceedances were recorded during weekday daytime periods.



2.2.7 For the purpose of reporting the number of days where the SOAEL is exceeded, multiple exceedances of the SOAEL in a 24-hour period would be counted as a single exceedance during that day. Over the reporting period, the overall number of SOAEL exceedances at each measurement location is shown in Table 6 and may be lower than the total sum of individual exceedances reported in Table 5 for each location.

Table 6: Summary of Total Exceedances of SOAEL

Worksite Reference	Measurement Reference	Monitor Address	Total of SOAEL exceedances in the month
ALO	ALO-N2	(south of) 57 Attleboro Lane, Water Orton, Birmingham, B46 1SD	1

2.2.8 One (1) SOAEL exceedance was recorded due to HS2 construction works during September 2024. The exceedance occurred at ALO-N2 during the weekday daytime period.

## 2.3 Exceedances of Trigger Level

2.3.1 Table 7 provides a summary of exceedances of the Section 61 trigger noise levels determined to be due to HS2 related construction noise measured during the reporting period, along with the findings of any investigation.

Table 7: Summary of Exceedances of Trigger Levels

Complaint Reference Number (if applicable)	Worksite Reference	Date and Time Period	Identified Source	Results of Investigation (including noise monitoring results)	Actions Taken
-	-	-	-	-	-

## 2.4 Complaints

2.4.1 Table 8 provides a summary of complaint information related to noise and vibration received during the reporting period, along with the findings of any investigation.


Table 8: Summary of Complaints

Complaint Reference Number	Worksite Reference	Description of Complaint	Results of Investigation	Actions Taken
-	-	-	-	-


# Appendix A Site Locations


# HS2


## Worksite Identification Plan - Overview















# Appendix B Monitoring Locations



















# Appendix C Data


## Noise

The following graphs show the hourly measured ambient noise level  $L_{Aeq,1h}$  and, where relevant, the averaged noise level  $L_{Aeq,T}$  values, where the time period T is as specified in Table 1 of HS2 Information Paper E23. Periods with adversely weather affected noise levels are greyed out and have been excluded from the calculation of the  $L_{Aeq,T}$  values in Table 3 of the main report.:



### Worksite: CLE – Monitoring Ref: CLE-N1










**Worksite: KMC – Monitoring Ref: KMC-N1**













Note: Missing data between 11:00 on Monday 23<sup>rd</sup> and 09:00 on Thursday 26<sup>th</sup> September was due to a remote reset error causing the monitor to remain offline until manually reset.


OFFICIAL





**Worksite: BFCV - Monitoring Ref: BFCV-N2**













**Worksite: MB – Monitoring Ref: MB-N1**













**Worksite: FAEU – Monitoring Ref: FAEU-N1**











**Worksite: CHBS – Monitoring Ref: CHBS-N1**

















**Worksite: MLE – Monitoring Ref: MLE-N1**













### Worksite: ALO – Monitoring Ref: ALO-N1













### Worksite: ALO - Monitoring Ref: ALO-N2











**Worksite: ALO - Monitoring Ref: AFE-N1**
















**Worksite: GE – Monitoring Ref: GE-N1**










### Worksite: GE – Monitoring Ref: GE-N2








Note: Missing data from the beginning of the month until 11:00 on Friday 20<sup>th</sup> September was due to the monitor being replaced.




**Worksite: GLD - Monitoring Ref: GLD-N1**












### Worksite: GLD - Monitoring Ref: CM-N1
















**Worksite: BRD - Monitoring Ref: BRD-N2**












**Worksite: BRD - Monitoring Ref: BRD-N3**













## Vibration

The following graphs show the hourly measured peak particle velocity PPV recorded during the monitoring period. The graphs show the highest PPV of the three orthogonal axes x, y and z. Where high values of PPV were caused by local interference with the vibration monitor, which are not representative of HS2 construction works, these values have been greyed out in the following charts and have been excluded to calculate values in Table 4 of the main report.



### Worksite: BFCV - Monitoring Ref: BFCV-V4











**Worksite: MB - Monitoring Ref: MB-V1**

















### Worksite: FAEU – Monitoring Ref: FAEU-V1













**Worksite: ALO – Monitoring Ref: ALO-V1**













### Worksite: ALO - Monitoring Ref: ALO-V5











**Worksite: ALO – Monitoring Ref: AFE-V1**

















**Worksite: GE – Monitoring Ref: GE-V1**











### Worksite: GLD – Monitoring Ref: GLD-V1







### Worksite: BRD – Monitoring Ref: BRD-V1

