

Determination of an Application for an Environmental Permit under the Environmental Permitting (England & Wales) Regulations 2016

Decision document recording our decision-making process

The Permit Number is: EPR/RP3628SJ/A001
The Applicant / Operator is: TEGCO Immingham limited
The Installation is located at: Netherlands Way, Grimsby,
DN41 8DF

What this document is about

This is a decision document, which accompanies a permit.

It explains how we have considered the Applicant's Application, and why we have included the specific conditions in the permit we are issuing to the Applicant. It is our record of our decision-making process, to show how we have taken into account all relevant factors in reaching our position. Unless the document explains otherwise, we have accepted the Applicant's proposals.

We try to explain our decision as accurately, comprehensively and plainly as possible. Achieving all three objectives is not always easy, and we would welcome any feedback as to how we might improve our decision documents in future. A lot of technical terms and acronyms are inevitable in a document of this nature: we provide a glossary of acronyms near the front of the document, for ease of reference.

Preliminary information and use of terms

We gave the application the reference number EPR/RP3628SJ/A001. We refer to the application as "the **Application**" in this document in order to be consistent.

The number we have given to the permit is EPR/RP3628SJ. We refer to the permit as "the **Permit**" in this document.

The Application was duly made on 04/06/24.

The applicant is TEGCO Immingham Ltd. We refer to TEGCO Immingham Ltd as "the **Applicant**" in this document. Where we are talking about what would happen after the Permit is granted, we call TEGCO Immingham Ltd "the **Operator**".

TEGCO Immingham Limited's facility is located at Netherlands Way, Grimsby, DN41 8DF. We refer to this as "the **Installation**" in this document.

How this document is structured

Contents

| | |
|---|----|
| Glossary of acronyms used in this document | 4 |
| Links to guidance documents | 7 |
| UKHSA: Municipal waste incinerators emissions: impact on health..... | 7 |
| 1 Our decision..... | 8 |
| 2 How we reached our decision..... | 8 |
| 3 The legal framework | 10 |
| 4 The Installation | 10 |
| 4.1 Description of the Installation and related issues..... | 10 |
| 4.2 The site and its protection..... | 13 |
| 4.3 Operation of the Installation – general issues..... | 14 |
| 5 Minimising the Installation’s environmental impact | 21 |
| 5.1 Assessment Methodology..... | 22 |
| 5.2 Assessment of Impact on Air Quality | 24 |
| 5.3 Human health risk assessment..... | 33 |
| 5.4 Impact on protected conservation areas (SPAs, SACs, Ramsar sites and SSSIs and local nature sites) | 41 |
| 5.5 Impact of abnormal operations | 44 |
| 6 Application of Best Available Techniques | 47 |
| 6.1 Scope of Consideration | 47 |
| 6.2 BAT and emissions control | 55 |
| 6.3 BAT and global warming potential | 65 |
| 6.4 BAT and POPs | 67 |
| 6.5 Other Emissions to the Environment | 69 |
| 6.6 Setting ELVs and other Permit conditions | 72 |
| 6.7 Monitoring..... | 73 |
| 6.8 Reporting..... | 74 |
| 7 Other legal requirements | 75 |
| 7.1 The EPR 2016 and related Directives | 75 |
| 7.2 National primary legislation..... | 77 |
| 7.3 National secondary legislation | 82 |
| 7.4 Other relevant legal requirements | 83 |
| Annexes..... | 85 |
| Annex 1A: Application of chapter IV of the Industrial Emissions Directive | 85 |
| Annex 1B: Compliance with Bat Conclusions..... | 90 |
| Annex 2: Pre-Operational Conditions | 94 |
| Annex 3: Improvement Conditions..... | 95 |
| Annex 4: Consultation Reponses | 96 |

Glossary of acronyms used in this document

(Please note that this glossary is standard for our decision documents and therefore not all these acronyms are necessarily used in this document.)

| | |
|---------|--|
| AAD | Ambient Air Directive (2008/50/EC) |
| APC | Air Pollution Control |
| AQS | Air Quality Strategy |
| BAT | Best Available Technique(s) |
| BAT-AEL | BAT Associated Emission Level |
| BREF | Best Available Techniques (BAT) Reference Documents for Waste Incineration |
| BAT C | BAT conclusions |
| CEM | Continuous emissions monitor |
| CFD | Computerised fluid dynamics |
| CHP | Combined heat and power |
| COMEAP | Committee on the Medical Effects of Air Pollutants |
| CROW | Countryside and rights of way Act 2000 |
| CV | Calorific value |
| CW | Clinical waste |
| DAA | Directly associated activity – Additional activities necessary to be carried out to allow the principal activity to be carried out |
| DD | Decision document |
| EAL | Environmental assessment level |
| EIAD | Environmental Impact Assessment Directive (85/337/EEC) |
| ELV | Emission limit value |
| EMAS | EU Eco Management and Audit Scheme |
| EMS | Environmental Management System |
| EPR | Environmental Permitting (England and Wales) Regulations 2016 (SI 2016 No. 1154) as amended |
| EQS | Environmental Quality Standard |
| ES | Environmental standard |
| EWC | European waste catalogue |
| FGC | Flue gas cleaning |
| FPP | Fire prevention plan |
| FSA | Food Standards Agency |
| GWP | Global Warming Potential |

| | |
|--------|---|
| HHRAP | Human Health Risk Assessment Protocol |
| HPA | Health Protection Agency (now UKHSA – UK Health Security Agency) |
| HRA | Human Rights Act 1998 |
| HW | Hazardous waste |
| HWI | Hazardous waste incinerator |
| IBA | Incinerator Bottom Ash |
| IED | Industrial Emissions Directive (2010/75/EU) |
| IPPCD | Integrated Pollution Prevention and Control Directive (2008/1/EC) – now superseded by IED |
| I-TEF | Toxic Equivalent Factors set out in Annex VI Part 2 of IED |
| I-TEQ | Toxic Equivalent Quotient calculated using I-TEF |
| LCV | Lower calorific value – also termed net calorific value |
| LfD | Landfill Directive (1999/31/EC) |
| LADPH | Local Authority Director(s) of Public Health |
| LOI | Loss on Ignition |
| MBT | Mechanical biological treatment |
| MSW | Municipal Solid Waste |
| MWI | Municipal waste incinerator |
| NOx | Oxides of nitrogen (NO plus NO ₂ expressed as NO ₂) |
| OTNOC | Other than normal operating conditions |
| PAH | Polycyclic aromatic hydrocarbons |
| PC | Process Contribution |
| PCB | Polychlorinated biphenyls |
| PEC | Predicted Environmental Concentration |
| PHE | Public Health England (now UKHSA – UK Health Security Agency) |
| POP(s) | Persistent organic pollutant(s) |
| PPS | Public participation statement |
| PR | Public register |
| PXDD | Poly-halogenated di-benzo-p-dioxins |
| PXB | Poly-halogenated biphenyls |
| PXDF | Poly-halogenated di-benzo furans |
| RDF | Refuse derived fuel |

| | |
|---------|---|
| RGN | Regulatory Guidance Note |
| SAC | Special Area of Conservation |
| SCR | Selective catalytic reduction |
| SHPI(s) | Site(s) of High Public Interest |
| SNCR | Selective non-catalytic reduction |
| SPA(s) | Special Protection Area(s) |
| SS | Sewage sludge |
| SSSI(s) | Site(s) of Special Scientific Interest |
| SWMA | Specified waste management activity |
| TDI | Tolerable daily intake |
| TEF | Toxic Equivalent Factors |
| TGN | Technical guidance note |
| TOC | Total Organic Carbon |
| UHV | Upper heating value –also termed gross calorific value |
| UN_ECE | United Nations Environmental Commission for Europe |
| US EPA | United States Environmental Protection Agency |
| WFD | Waste Framework Directive (2008/98/EC) |
| WHO | World Health Organisation |
| WID | Waste Incineration Directive (2000/76/EC) – now superseded by IED |

Links to guidance documents

The table below provides links to the key guidance documents referred to in this document. The links were correct at the time of producing this document.

| Name of guidance document | Link |
|---|----------------------------------|
| RGN 6: Determinations involving sites of high public interest | RGN 6 |
| CHP Ready Guidance for Combustion and Energy from Waste Power Plants | CHP ready |
| Risk assessments for your environmental permit | Risk assessments |
| Guidance to Applicants on Impact Assessment for Group 3 Metals Stack Releases – version 4". | Metals guide |
| The Incineration of Waste (EPR 5.01) | EPR 5.01 |
| Waste incineration BREF and BAT conclusions | BREF and BAT C |
| UKHSA: Municipal waste incinerators emissions: impact on health | UKHSA reports |

1 Our decision

We have decided to grant the Permit to the Applicant. This will allow it to operate the Installation, subject to the conditions in the Permit.

We consider that, in reaching that decision, we have taken into account all relevant considerations and legal requirements and that the permit will ensure that a high level of protection is provided for the environment and human health.

This Application is to operate an installation which is subject principally to the Industrial Emissions Directive (IED).

The Permit contains many conditions taken from our standard Environmental Permit template including the relevant Annexes. We developed these conditions in consultation with industry, having regard to the legal requirements of the Environmental Permitting Regulations (EPR) and other relevant legislation. This document does not therefore include an explanation for these standard conditions. Where they are included in the permit, we have considered the Application and accepted that the details provided are sufficient and satisfactory to make use of the standard condition acceptable and appropriate. This document does, however, provide an explanation of our use of “tailor-made” or installation-specific conditions, or where our Permit template provides two or more options, an explanation of the reason(s) for choosing the option that has been specified.

2 How we reached our decision

2.1 Receipt of Application

The Application was duly made on 04/06/2024. This means we considered it was in the correct form and contained sufficient information for us to begin our determination but not that it necessarily contained all the information we would need to complete that determination: see section 2.3 below.

The Applicant made no claim for commercial confidentiality. We have not received any information in relation to the Application that appears to be confidential in relation to any party.

2.2 Consultation on the Application

We carried out consultation on the Application in accordance with the EPR, our statutory Public Participation Statement (PPS) and our own internal guidance RGN 6 for Determinations involving Sites of High Public Interest. RGN 6 was withdrawn as external guidance, but it is still relevant as Environment Agency internal guidance.

We consider that this process satisfies, and frequently goes beyond the requirements of the Aarhus Convention on Access to Information, Public Participation in Decision-Making and Access to Justice in Environmental Matters, which are directly incorporated into the IED, which applies to the Installation and the Application. We have also taken into account our obligations under the Local Democracy, Economic Development and Construction Act 2009 (particularly Section 23). This requires us, where we consider it appropriate, to take such steps as we consider appropriate to secure the involvement of representatives of interested persons in the exercise of our functions, by providing them with information, consulting them or involving them in any other way. In this case, we consider that our consultation already satisfies the requirements of the 2009 Act.

We advertised the Application by a notice placed on our website, which contained all the information required by the IED, including telling people where and when they could see a copy of the Application. We also placed an advertisement in the Grimsby Telegraph that contained the same information.

We made a copy of the Application and all other documents relevant to our determination available to view on our Public Register. Anyone wishing to see these documents could do so and arrange for copies to be made.

We sent copies of the Application to the following bodies, which includes those with whom we have “Working Together Agreements”:

- Local Authority – Environmental Protection Department
- Local Authority – Planning
- Fire & Rescue
- Director of PH/UKHSA
- Health and Safety Executive
- Food Standards Agency
- Sewerage Authorities
- National Grid
- Civil Aviation Authority
- National air traffic services (NATS)
- Humberside International Airport Limited

These are bodies whose expertise, democratic accountability and/or local knowledge make it appropriate for us to seek their views directly. Note under our Working Together Agreement with Natural England, we only inform Natural England of the results of our assessment of the impact of the installation on designated Habitats sites.

Further details along with a summary of consultation comments and our response to the representations we received can be found in Annex 4. We have taken all relevant representations into consideration in reaching our determination.

2.3 Requests for Further Information

Although we were able to consider the Application duly made, we did in fact need more information in order to determine it, and issued requests for more on 14/06/24 and 17/10/24. A copy of the requests and responses were placed on our public register.

3 The legal framework

The Permit is granted under Regulation 13 of the EPR. The Environmental Permitting regime is a legal vehicle which delivers most of the relevant legal requirements for activities falling within its scope. In particular, the regulated facility is:

- an *installation* and a *waste incineration plant* as described by the IED;
- an *operation* covered by the WFD, and
- subject to aspects of other relevant legislation which also have to be addressed.

We address some of the major legal requirements directly where relevant in the body of this document. Other requirements are covered in section 7 towards the end of this document.

We consider that in granting the Permit, it will ensure that the operation of the Installation complies with all relevant legal requirements and that a high level of protection will be delivered for the environment and human health.

We explain how we have addressed specific statutory requirements more fully in the rest of this document.

4 The Installation

4.1 Description of the Installation and related issues

4.1.1 The permitted activities

The Installation is subject to the EPR because it carries out an activity listed in Part 1 of Schedule 1 to the EPR:

- Section 5.1 Part A(1)(b) – incineration of non-hazardous waste in a waste incineration plant with a capacity of 3 tonnes or more per hour.

The IED definition of “waste incineration plants” and “waste co-incineration plants” says that it includes:

| | | |
|--|---------------|---|
| | Page 10 of 96 | Application Number EPR/RP3638SJ/A001 |
|--|---------------|---|

“all incineration lines or co-incineration lines, waste reception, storage, on-site pre-treatment facilities, waste, fuel and air supply systems, boilers, facilities for the treatment of waste gases, on-site facilities for treatment or storage of residues and waste water, stacks, devices for controlling incineration or co-incineration operations, recording and monitoring incineration or co-incineration conditions.”

Many activities which would normally be categorised as “directly associated activities” (DAA) for EPR purposes, such as air pollution control plant, and the ash storage bunker, are therefore included in the listed activity description.

An installation may also comprise “directly associated activities”, which at this Installation includes the generation of electricity using a steam turbine and a back up electricity generator for emergencies. These activities comprise one installation, because the incineration plant and the steam turbine are successive steps in an integrated activity.

Together, these listed activities and directly associated activities comprise the Installation.

4.1.2 The Site

The Installation is located at Netherlands Way, Stallingborough, Grimsby on part of the former Immingham rail freight terminal. Stallingborough North Beck Drain is to the west and north, there are commercial/light industrial units to the south with brownfield land to the east. The nearest housing is ~ 1.3km to the west. Humber Estuary SAC, SPA, SSSI and Ramsar is ~ 1.1 km away.

The Applicant submitted a plan which we consider is satisfactory, showing the site of the Installation and its extent. A plan is included in Schedule 7 to the Permit, and the Operator is required to carry on the permitted activities within the site boundary.

Further information on the site is addressed below at 4.3.

4.1.3 What the Installation does

For the purposes of IED (in particular Chapter IV) and EPR, the installation is a waste incineration plant because:

Notwithstanding the fact that energy will be recovered from the process; the process is never the less ‘incineration’ because it is considered that its main purpose is the thermal treatment of waste.

The key features of the Installation can be summarised in the table below.

| | | |
|--|---------------|---|
| | Page 11 of 96 | Application Number EPR/RP3638SJ/A001 |
|--|---------------|---|

| | | |
|----------------------------|--|---|
| Waste throughput | 320,000 tonnes per year | 20 tonnes per hour for each line |
| Waste processed | RDF | |
| Number of lines | 2 | |
| Furnace technology | Grate | |
| Auxiliary Fuel | Natural Gas | |
| Acid gas abatement | Dry using hydrated lime | |
| NOx abatement | SNCR using urea | |
| Reagent consumption | Auxiliary Fuel (natural gas) | 5,792 MWh/year |
| | Urea | 3,360 t/year of 40% solution |
| | Hydrated lime | 7,200 t/year |
| | Activated carbon | 180 t/year |
| | Process water | 36,000 t/year in CHP mode or 144,000 t/year if in electricity only mode |
| Flue gas recirculation | Yes | |
| Dioxin abatement | Activated carbon | |
| Stack | Grid Reference : 520623,414344 Height: 65 m | |
| CHP mode (usual operation) | Electricity generated | 17.8 MWe |
| | Electricity exported | 11.7 MWe |
| | Steam exported | 51 MWth 60 t/hour 322 °C 22 bar |
| Electricity only mode | Electricity generated | 30.0 MWe |
| | Electricity exported | 24.0 MWe |
| | Steam conditions | 421 °C 56 bar |

4.1.4 Key Issues in the Determination

The key issues arising during determination of the Application were emissions to air and assessment of BAT and we therefore describe how we determined these issues in greater detail in the body of this document.

4.2 **The site and its protection**

4.2.1 Site setting, layout and history

The Installation is located at Netherlands Way, Stallingborough, Grimsby on part of the former Immingham rail freight terminal.

The site comprises made ground to a depth of up to 2.1m, comprised of sandy gravel with stone, brick, concrete, and ash present. Underlying superficial deposits are comprised of silty clays with horizons of sand gravel and peat present in some boreholes. The bedrock was encountered just over 19m below ground level comprising a weathered chalk.

The chalk bedrock is defined as a principle aquifer and it is known to support groundwater abstractions, the closest of which is to the north of the site. The site is not in a drinking water protection area but is located in a zone 3 source protection zone.

The closest surface water course is the North Beck Drain, which lies to the north and west of the site boundary. It is likely that this is in hydraulic continuity with groundwater under the site. The North Beck Drain flows towards the Humber Estuary, which lies approximately 1.2 km to the east of the site.

A site investigation was undertaken in 2020, comprising 10 cable percussive boreholes, 4 windowless sample boreholes and 12 trial pits. During the investigation standpipes were placed in 8 of the boreholes to provide gas and groundwater samples. The investigation found that contamination levels were low and no specific remediation was required.

4.2.2 Proposed site design: potentially polluting substances and prevention measures

All waste and other materials will be stored inside the buildings or in sealed silos. Bunding will be provided for all tanks and containers to provide secondary containment for all liquids. Storage areas will have concrete surfacing allowing any spillage to be contained and cleaned up, preventing emissions to groundwater.

Under Article 22(2) of the IED the Applicant is required to provide a baseline report containing at least the information set out in paragraphs (a) and (b) of the Article before starting operation.

The Applicant has submitted a site condition report which includes a report on the baseline conditions as required by Article 22. We have reviewed that report

and consider that it adequately describes the condition of the soil and groundwater prior to the start of operations.

The baseline report is an important reference document in the assessment of contamination that might arise during the operational lifetime of the installation and at cessation of activities at the installation

4.2.3 Closure and decommissioning

Having considered the information submitted in the Application, we are satisfied that the appropriate measures will be in place for the closure and decommissioning of the Installation. Pre-operational condition PO1 requires the Operator to have an Environmental Management System in place before the Installation is operational, and this will include a site closure plan.

At the definitive cessation of activities, the Operator has to satisfy us that the necessary measures have been taken so that the site ceases to pose a risk to soil or groundwater, taking into accounts both the baseline conditions and the site's current or approved future use. To do this, the Operator will apply to us for surrender of the permit, which we will not grant unless and until we are satisfied that these requirements have been met.

4.3 **Operation of the Installation – general issues**

4.3.1 Administrative issues

The Applicant is the sole Operator of the Installation.

We are satisfied that the Applicant is the person who will have control over the operation of the Installation after the granting of the Permit; and that the Applicant will be able to operate the Installation so as to comply with the conditions included in the Permit.

4.3.2 Management

The Applicant has stated in the Application that they will implement an Environmental Management System (EMS) that will be certified under ISO14001. A pre-operational condition (PO1) is included requiring the Operator to provide a summary of the EMS prior to commissioning of the plant and to make available for inspection all EMS documentation. The Environment Agency recognises that certification of the EMS cannot take place until the Installation is operational. An improvement condition (IC1) is included requiring the Operator to report progress towards gaining accreditation of its EMS.

We are satisfied that appropriate management systems and management structures will be in place for this Installation, and that sufficient resources are available to the Operator to ensure compliance with all the Permit conditions.

4.3.3 Site security

Having considered the information submitted in the Application, we are satisfied that appropriate infrastructure and procedures will be in place to ensure that the site remains secure.

4.3.4 Accident management

The Applicant has not submitted an Accident Management Plan. However, having considered the other information submitted in the Application, we are satisfied that appropriate measures will be in place to ensure that accidents that may cause pollution are prevented but that, if they should occur, their consequences are minimised. An Accident Management Plan will form part of the Environmental Management System and must be in place prior to commissioning as required by a pre-operational condition (PO1).

The Applicant submitted a Fire Prevention Plan. We reviewed the plan and are satisfied that it is appropriate.

4.3.5 Off-site conditions

We do not consider that any off-site conditions are necessary.

4.3.6 Operating techniques

We have specified that the Applicant must operate the Installation in accordance with the following documents contained in the Application:

| Description | Parts Included | Justification |
|---------------------------------------|--|---|
| The Application | Operating techniques described in the following documents <ul style="list-style-type: none"> • Non technical description • BAT review • Discharges to water • Dust emissions management plan • Noise and vibration management plan • Odour management plan • Energy efficiency • Fire prevention plan • IED requirements • Non technical description • Appendix 3.1 Raw materials • Appendix 3.2 by-products and wastes produced | Key operating measures are set out in these documents |
| Additional information dated 28/10/24 | E-mail relating to Fire Prevention Plan | Description of how quarantine area will be used |
| Page 15 of 96 | | Application Number EPR/RP3638SJ/A001 |

| | | |
|--|--|--|
| | | |
|--|--|--|

The details set out above describe the techniques that will be used for the operation of the Installation that have been assessed by us as BAT; they form part of the Permit through Permit condition 2.3.1 and Table S1.2 in the Permit Schedules.

Article 45(1) of the IED requires that the Permit must include a list of all types of waste which may be treated using at least the types of waste set out in the European Waste List established by Decision 2005/532/EC, EC, if possible, and containing information on the quantity of each type of waste, where appropriate. The Application contains a list of those wastes coded by the European Waste Catalogue (EWC) number, which the Applicant will accept in the waste streams entering the plant and which the plant is capable of burning in an environmentally acceptable way. We have specified the permitted waste types, descriptions and where appropriate quantities which can be accepted at the installation in Table S2.2.

We are satisfied that the Applicant can accept the wastes contained in Table S2.2 of the Permit because:

- (i) these wastes are categorised as municipal waste in the European Waste Catalogue or are non-hazardous wastes similar in character to municipal waste;
- (ii) the wastes are all categorised as non-hazardous in the European Waste Catalogue and are capable of being safely burnt at the Installation.
- (iii) these wastes are likely to be within the design calorific value (CV) range for the plant;
- (iv) these wastes are unlikely to contain harmful components that cannot be safely processed at the Installation.

The incineration plant will take refuse derived fuel that will have gone through some level of sorting.

The amount of recyclable material in the waste feed is largely outside the remit of this permit determination with recycling initiatives being a matter for the local authority. However permit conditions 2.3.5 and 2.3.6 limit the burning of separately collected fractions in line with regulation 12 of the Waste (England and Wales) Regulations 2011.

We have limited the capacity of the Installation to 350,400 tonnes per year. This is based on the installation operating 8,760 hours per year at plant capacity of 20 tonnes per hour for each of the two lines. The nominal capacity based on 8,000 hours per year is 320,000 tonnes per year, however the risk assessments were based on continual operation so we have set the permit limit at the maximum capacity.

The Installation will be designed, constructed and operated using BAT for the incineration of the permitted wastes. We are satisfied that the operating and

abatement techniques are BAT for incinerating these types of waste. Our assessment of BAT is set out later in this document.

4.3.7 Energy efficiency

(i) Consideration of energy efficiency

We have considered the issue of energy efficiency in the following ways:

1. The use of energy within, and generated by, the Installation which are normal aspects of all EPR permit determinations. This issue is dealt with in this section.
2. The extent to which the Installation meets the requirements of Article 50(5) of the IED, which requires “*the heat generated during the incineration and co-incineration process is recovered as far as practicable through the generation of heat, steam or power*”. This issue is covered in this section.
3. The combustion efficiency and energy utilisation of different design options for the Installation are relevant considerations in the determination of BAT for the Installation, including the Global Warming Potential of the different options. This aspect is covered in the BAT assessment in section 6 of this Decision Document.
4. The extent to which the Installation meets the requirement of Article 14(5) of the Energy Efficiency Directive which requires new thermal electricity generation installations with a total thermal input exceeding 20 MW to carry out a cost-benefit assessment to “*assess the cost and benefits of providing for the operation of the installation as a high-efficiency cogeneration installation*”.
Cogeneration means the simultaneous generation in one process of thermal energy and electrical or mechanical energy and is also known as combined heat and power (CHP)
High-efficiency co-generation is cogeneration which achieves at least 10% savings in primary energy usage compared to the separate generation of heat and power – see Annex II of the Energy Efficiency Directive for detail on how to calculate this.

(ii) Use of energy within the Installation

Having considered the information submitted in the Application, we are satisfied that appropriate measures will be in place to ensure that energy is used efficiently within the Installation.

The Application details a number of measures that will be implemented at the Installation in order to increase its energy efficiency:

- high efficiency motors
- high standards of cladding
- insulation
- energy efficiency plan

The Application shows that electricity consumption, a measure of energy consumed per unit of waste processed, will be 150 kWh/tonne based on nominal capacity of 320,000 tonnes per year.

The BREF says that electricity consumption is typically between 60 kWh/t and 190 kWh/t depending on the LCV of the waste. The specific energy consumption in the Application is in line with the BREF.

(iii) Generation of energy within the Installation - Compliance with Article 50(5) of the IED

Article 50(5) of the IED requires that *“the heat generated during the incineration and co-incineration process is recovered as far as practicable”*.

Our combined heat and power (CHP) Ready Guidance - February 2013 considers that BAT for energy efficiency for Energy from Waste (EfW) plant is the use of CHP in circumstances where there are technically and economically viable opportunities for the supply of heat from the outset.

The term CHP in this context represents a plant which also provides a supply of heat from the electrical power generation process to either a district heating network or to an industrial / commercial building or process. However, it is recognised that opportunities for the supply of heat do not always exist from the outset (i.e. when a plant is first consented, constructed and commissioned).

In cases where there are no immediate opportunities for the supply of heat from the outset, we consider that BAT is to build the plant to be CHP Ready (CHP-R) to a degree which is dictated by the likely future opportunities which are technically viable and which may, in time, also become economically viable.

The BREF says that 0.4 – 0.8 MWh of electricity can be generated per tonne of waste. Our technical guidance note, EPR S5.01, states that where electricity only is generated, 5-9 MW of electricity should be recoverable per 100,000 tonnes/annum of waste.

The plant's usual operating mode will be to provide heat in the form of steam to an industrial customer and export some electricity to the grid. The electrical output of the plant will be 17.8 MWe with 51 MWth supplied as steam

If steam export is not available the plant can operate in electricity only mode. In this situation it would generate 30 MWe which is 9.4 MW per 100,000 tonnes/yr of waste burned. The Installation is therefore at the top of the indicative BAT range.

The Applicant provided calculations of the gross electrical efficiency and gross energy efficiency and compared it to the BAT AEELs specified in BAT conclusions BAT 20.

In electricity only mode the gross electrical efficiency is 30.49 % which is within the BAT AEEL range.

Gross energy efficiency was calculated at 75.95% which is within the BAT AEEL range. Gross energy efficiency is applicable because the plant will generate heat and electricity using a back pressure turbine, although it can also operate in condensing mode.

In accordance with BAT 2 table S3.3 of the Permit requires the gross energy efficiency and gross electrical efficiency to be measured by carrying out a performance test at full load.

Guidance note EPR 5.01 and Chapter IV of the IED both require that, as well as maximising the primary use of heat to generate electricity; waste heat should be recovered as far as practicable. This installation is designed to be CHP and supply heat to a local user.

We consider that the Installation will recover heat as far as practicable, and therefore that the requirements of Article 50(5) are met.

(iv) Choice of Steam Turbine

A condensing turbine will be used with high steam conditions, 421 °C 56 bar. This is in accordance with BAT 20.

(v) Choice of Cooling System

An air cooled condenser will be used to maximise reliability and minimise cooling water requirements. We agree that this is BAT.

(vi) Compliance with Article 14(5) of the Energy Efficiency Directive

The applicant proposes to operate the Installation as a high-efficiency cogeneration installation.

(vii) Permit conditions concerning energy efficiency

Permit condition 2.3.1 and table S1.2 require the operator to operate as a high-efficiency co-generation installation in the manner described within the Application.

The Operator is required to report energy usage and energy generated under condition 4.2 and Schedule 5 of the Permit. The following parameters are required to be reported: total electrical energy generated; electrical energy exported; total energy usage and energy exported as heat (if any). Together with the total MSW burned per year, this will enable the us to monitor energy recovery efficiency at the Installation and take action if at any stage the energy recovery efficiency is less than proposed.

There are no site-specific considerations that require the imposition of standards beyond indicative BAT, and so we accept that the Applicant's proposals represent BAT for this Installation.

4.3.8 Efficient use of raw materials

Having considered the information submitted in the Application, we are satisfied that the appropriate measures will be in place to ensure that the Operator will make efficient use of raw materials and water.

The Operator is required to report with respect to raw material usage under condition 4.2. and Schedule 5, including consumption of hydrated lime, activated carbon and urea. This will enable the Environment Agency to assess whether there have been any changes in the efficiency of the air pollution control plant, and the operation of the SNCR to abate NO_x. These are the most significant raw materials that will be used at the Installation, other than the waste feed itself (addressed elsewhere). The efficiency of the use of auxiliary fuel will be tracked separately as part of the energy reporting requirement under condition 4.2.1. Optimising reagent dosage for air abatement systems and minimising the use of auxiliary fuels is further considered in the section on BAT.

4.3.9 Avoidance, recovery or disposal with minimal environmental impact of wastes produced by the permitted activities

This requirement addresses wastes produced at the Installation and does not apply to the waste being treated there. The principal waste streams the Installation will produce are incinerator bottom ash (IBA) and air pollution control (APC) residues.

The first objective is to avoid producing waste at all. Waste production will be avoided by achieving a high degree of burnout of the ash in the furnace, which results in a material that is both reduced in volume and in chemical reactivity. Condition 3.1.5 and associated Table S3.4 specify limits for total organic carbon (TOC) of 3% in bottom ash. Compliance with this limit will demonstrate that

good combustion control and waste burnout is being achieved in the furnaces and waste generation is being avoided where practicable.

IBA will normally be classified as non-hazardous waste. However, IBA is classified on the European List of Wastes as a “mirror entry”, which means IBA is a hazardous waste if it possesses a hazardous property relating to the content of dangerous substances. Monitoring of IBA at the Installation will be carried out in accordance with the requirements of Article 53(3) of IED. Classification of IBA for its subsequent use or disposal is controlled by other legislation and so is not duplicated within the Permit.

APC residues from flue gas treatment are hazardous waste and therefore must be sent for disposal to a landfill site permitted to accept hazardous waste, or to an appropriately permitted facility for hazardous waste treatment. The amount of APC residues is minimised through optimising the performance of the air emissions abatement plant.

In order to ensure that the IBA residues are adequately characterised, pre-operational condition PO2 requires the Operator to provide a written plan for approval detailing the IBA sampling protocols. Table S3.4 requires the Operator to carry out an ongoing programme of monitoring.

The Application proposes that bottom ash will be transported to a suitable treatment facility, from where it could be re-used in the construction industry as an aggregate.

Having considered the information submitted in the Application, we are satisfied that the waste hierarchy referred to in Article 4 of the Waste Framework Directive (WFD) will be applied to the generation of waste and that any waste generated will be treated in accordance with that Article.

We are satisfied that waste from the Installation that cannot be recovered will be disposed of using a method that minimises any impact on the environment. Standard condition 1.4.1 will ensure that this position is maintained.

5 Minimising the Installation’s environmental impact

Regulated activities can present different types of risk to the environment, these include odour, noise and vibration; accidents, fugitive emissions to air and water; as well as point source releases to air, discharges to ground or groundwater, global warming potential (GWP) and generation of waste and other environmental impacts. Consideration may also have to be given to the effect of emissions being subsequently deposited onto land (where there are ecological receptors). All these factors are discussed in this and other sections of this document.

For an installation of this kind, the principal emissions are those to air, although we also consider those to land and water.

The next sections of this document explain how we have approached the critical issue of assessing the likely impact of the emissions to air from the Installation on human health and the environment and what measures we are requiring to ensure a high level of protection.

5.1 Assessment Methodology

5.1.1 Application of Environment Agency guidance 'risk assessments for your environmental permit'

A methodology for risk assessment of point source emissions to air, which we use to assess the risk of applications we receive for permits, is set out in our guidance 'Air emissions risk assessment for your environmental permit' and has the following steps:

- Describe emissions and receptors
- Calculate process contributions
- Screen out insignificant emissions that do not warrant further investigation
- Decide if detailed air modelling is needed
- Assess emissions against relevant standards
- Summarise the effects of emissions

The methodology uses a concept of "process contribution (PC)", which is the estimated concentration of emitted substances after dispersion into the receiving environmental media at the point where the magnitude of the concentration is greatest. The methodology provides a simple method of calculating PC primarily for screening purposes and for estimating process contributions where environmental consequences are relatively low. It is based on using dispersion factors. These factors assume worst case dispersion conditions with no allowance made for thermal or momentum plume rise and so the process contributions calculated are likely to be an overestimate of the actual maximum concentrations. More accurate calculation of process contributions can be achieved by mathematical dispersion models, which take into account relevant parameters of the release and surrounding conditions, including local meteorology – these techniques are expensive but normally lead to a lower prediction of PC.

5.1.2 Use of Air Dispersion Modelling

For incineration applications, we normally require the Applicant to submit a full air dispersion model as part of their application. Air dispersion modelling enables the process contribution to be predicted at any environmental receptor that might be impacted by the plant.

Once short-term and long-term PCs have been calculated in this way, they are compared with Environmental Standards (ES) for air emissions. ES are

described in our web guide 'Air emissions risk assessment for your environmental permit'.

Our web guide sets out the relevant ES as:

- Air Quality Standards Regulations 2010 Limit Values
- Air Quality Standards Regulations 2010 Target Values
- UK Air Quality Strategy Objectives
- Environmental Assessment Levels

Where a Limit Value exists, the relevant standard is the Limit Value. Where a Limit Value does not exist, target values, UK Air Quality Strategy (AQS) Objectives or Environmental Assessment Levels (EALs) are used. Our web guide sets out EALs which have been derived to provide a similar level of protection to human health and the environment as the limit values, target values and AQS objectives. In a very small number of cases, e.g. for emissions of lead, the AQS objective is more stringent than the Limit Value. In such cases, we use the AQS objective for our assessment.

Target values, AQS objectives and EALs do not have the same legal status as Limit Values, and there is no explicit requirement to impose stricter conditions than BAT in order to comply with them. However, they are a standard for harm and any significant contribution to a breach is likely to be unacceptable.

PCs are screened out as **Insignificant** if:

- the **long-term** PC is less than **1%** of the relevant ES; and
- the **short-term** PC is less than **10%** of the relevant ES.

The **long term** 1% PC insignificance threshold is based on the judgements that:

- It is unlikely that an emission at this level will make a significant contribution to air quality;
- The threshold provides a substantial safety margin to protect human health and the environment.

The **short term** 10% PC insignificance threshold is based on the judgements that:

- spatial and temporal conditions mean that short term process contributions are transient and limited in comparison with long term process contributions;
- the threshold provides a substantial safety margin to protect human health and the environment.

Where an emission is screened out in this way, we would normally consider the Applicant's proposals for the prevention and control of the emission to be BAT. That is because if the impact of the emission is already insignificant, it follows that any further reduction in this emission will also be insignificant.

However, where an emission cannot be screened out as insignificant, it does not mean it will necessarily be significant.

For those pollutants which do not screen out as insignificant, we determine whether exceedences of the relevant ES are likely. This is done through detailed audit and review of the Applicant's air dispersion modelling taking background concentrations and modelling uncertainties into account. Where an exceedance of an AAD limit value is identified, we may require the applicant to go beyond what would normally be considered BAT for the Installation or we may refuse the application if the applicant is unable to provide suitable proposals. Whether or not exceedences are considered likely, the application is subject to the requirement to operate in accordance with BAT.

This is not the end of the risk assessment, because we also take into account local factors (for example, particularly sensitive receptors nearby such as a SSSIs, SACs or SPAs). These additional factors may also lead us to include more stringent conditions than BAT.

If, as a result of reviewing the risk assessment and taking account of any additional techniques that could be applied to limit emissions, we consider that emissions **would cause significant pollution**, we would refuse the Application.

5.2 Assessment of Impact on Air Quality

The Applicant's assessment of the impact of air quality is set out in the Application. The assessment comprises:

- Dispersion modelling of emissions to air from the operation of the incinerator.
- A study of the impact of emissions on nearby protected conservation areas

This section of the decision document deals primarily with the dispersion modelling of emissions to air from the incinerator chimney and its impact on local air quality. The impact on conservation sites is considered in section 5.4.

The Applicant has assessed the Installation's potential emissions to air against the relevant air quality standards, and the potential impact upon local conservation and habitat sites and human health. These assessments predict the potential effects on local air quality from the Installation's stack emissions using the air dispersion model software ADMS 5.2 dispersion model, which is a commonly used computer model for regulatory dispersion modelling. The model used 5 years of meteorological data collected from the weather station at Humberside Airport (11 km from the Installation) between 2015 and 2019. The effect of the terrain surrounding the site upon plume dispersion was considered in the dispersion modelling.

The air impact assessments, and the dispersion modelling upon which they were based, employed the following assumptions.

- First, they assumed that the ELVs in the Permit would be the maximum permitted by Article 15(3), Article 46(2) and Annex VI of the IED. These substances are:
 - Oxides of nitrogen (NO_x), expressed as NO₂
 - Total dust
 - Carbon monoxide (CO)
 - Sulphur dioxide (SO₂)
 - Hydrogen chloride (HCl)
 - Hydrogen fluoride (HF)
 - Metals (cadmium, thallium, mercury, antimony, arsenic, lead, chromium, cobalt, copper, manganese, nickel and vanadium), Cr(VI) was assumed to be 20% of total chromium.
 - Polychlorinated dibenzo-para-dioxins and polychlorinated dibenzo furans (referred to as dioxins and furans)
 - Gaseous and vaporous organic substances, expressed as Total Organic Carbon (TOC)
 - Ammonia (NH₃)
- Second, they assumed that the Installation operates continuously at the relevant long-term or short-term ELVs, i.e. the maximum permitted emission rate (metals are considered further in section 5.2.3 of this decision document).
- Third, the model also considered emissions of pollutants not covered by Annex VI of IED, specifically, polycyclic aromatic hydrocarbons (PAH) and polychlorinated biphenyls (PCBs). Emission rates used in the modelling were based on DEFRA report WR0608. They are considered further in section 5.2.2.

We are in agreement with this approach. The assumptions underpinning the model have been checked and are a reasonable worst-case .

The Applicant established the background (or existing) air quality against which to measure the potential impact of the incinerator.

As well as predicting the maximum ground level concentration of the pollutants within the modelling domain, the Applicant has modelled several discrete receptor locations to represent human and ecological exposure.

The Applicant's use of the dispersion models, selection of input data, use of background data and the assumptions made, have been reviewed by our modelling specialists to establish the robustness of the Applicant's air impact assessment. The output from the model has then been used to inform further assessment of human health impacts and impact on protected conservation areas. Our audit takes account of modelling uncertainties. We make reasonable worst case assumptions and use the uncertainties (minimum 140%) in analysing the likelihood of exceeding any particular standard.

Our review of the Applicant's assessment leads us to agree with the Applicant's conclusions. We have also audited the air quality and human health impact assessment and similarly agree that the conclusions drawn in the reports were acceptable.

The Applicant's modelling predictions are summarised in the following sections.

5.2.1 Assessment of Air Dispersion Modelling Outputs

The Applicant's modelling predictions are summarised in the tables below.

The Applicant's modelling predicted peak ground level exposure to pollutants in ambient air and at discreet receptors. The tables below show their predicted ground level concentrations at the most impacted receptor.

As part of our checks, we carry out sensitivity analysis of the data provided and conduct our own check modelling to ensure that the applicant's modelling predictions are reliable.

Whilst we have used the Applicant's modelling predictions in the table below, we have made our own simple verification calculation of the percentage PC and predicted environmental concentration (PEC). These are the numbers shown in the tables below and so may be very slightly different to those shown in the Application. Any such minor discrepancies do not materially impact on our conclusions.

| Pollutant | ES | | Back-ground $\mu\text{g}/\text{m}^3$ | Process Contribution (PC) | | Predicted Environmental Concentration (PEC) | |
|-------------------|--------------------------|-----------------------------------|---|---------------------------|----------|---|----------|
| | $\mu\text{g}/\text{m}^3$ | Reference period | | $\mu\text{g}/\text{m}^3$ | % of EAL | $\mu\text{g}/\text{m}^3$ | % of EAL |
| NO ₂ | 40 | Annual Mean | 13.5 | 0.22 | 0.55 | 13.7 | 34.3 |
| | 200 | 99.79th %ile of 1-hour means | 27 | 2.9 | 1.5 | 29.9 | 15.0 |
| PM ₁₀ | 40 | Annual Mean | 15.7 | 0.016 | 0.04 | 15.7 | 39.3 |
| | 50 | 90.41st %ile of 24-hour means | 18.5 | 0.065 | 0.13 | 18.565 | 37.1 |
| PM _{2.5} | 20 | Annual Mean | 8.6 | 0.016 | 0.08 | 8.62 | 43.1 |
| SO ₂ | 266 | 99.9th %ile of 15-min means | 38.9 | 2.7 | 1.0 | 41.6 | 15.6 |
| | 350 | 99.73rd %ile of 1-hour means | 29 | 2.5 | 0.71 | 31.5 | 9.0 |
| | 125 | 99.18th %ile of 24-hour means | 17.1 | 1.1 | 0.9 | 18.2 | 14.6 |
| HCl | 750 | 1-hour average | 0.62 | 0.64 | 0.08 | 1.3 | 0.17 |
| HF | 16 | Monthly average | 0.5 | 0.018 | 0.11 | 0.518 | 3.24 |
| | 160 | 1-hour average | 1 | 0.11 | 0.069 | 1.11 | 0.7 |
| CO | 10000 | Maximum daily running 8-hour mean | 169 | 3.4 | 0.03 | 172 | 1.7 |
| | 30000 | 1-hour average | 242 | 5.3 | 0.02 | 247 | 0.8 |
| TOC | 2.25 | Annual Mean | 0.11 | 0.031 | 1.38 | 0.14 | 6.27 |

| Pollutant | ES | | Back-ground | Process Contribution (PC) | | Predicted Environmental Concentration (PEC) | |
|-----------------|--------------------------|---------------------------|-------------|---------------------------|--------------------------|---|--------------------------|
| | $\mu\text{g}/\text{m}^3$ | Reference period | | $\mu\text{g}/\text{m}^3$ | $\mu\text{g}/\text{m}^3$ | % of EAL | $\mu\text{g}/\text{m}^3$ |
| | 30 | Daily average | 0.46 | 0.48 | 1.60 | 0.94 | 3.13 |
| | 2.25 | 24 Hour Mean (Short Term) | 0.46 | 0.48 | 21.33 | 0.94 | 41.78 |
| PAH | 0.00025 | Annual Mean | 0.00085 | 2.80×10^{-07} | 0.11 | 0.00085 | 340.1 |
| NH ₃ | 180 | Annual Mean | 2.1 | 0.031 | 0.02 | 2.13 | 1.18 |
| | 2500 | 1-hour average | 4.2 | 1.1 | 0.04 | 5.3 | 0.2 |
| PCBs | 0.2 | Annual Mean | 0.00024 | 1.00×10^{-07} | 1×10^{-4} | 0.00024 | 0.12 |
| | 6 | 1-hour average | 0.000048 | 1.00×10^{-06} | 2×10^{-5} | 0.00005 | 0.00 |

PAH as benzo[a]pyrene

| Pollutant | ES | | Back-ground | Process Contribution | | Predicted Environmental Concentration | |
|-----------|------------------------|---------------------------|-------------|------------------------|------------------------|---------------------------------------|------------------------|
| | ng/m^3 | Reference period | | ng/m^3 | ng/m^3 | % of EAL | ng/m^3 |
| Cd | 5 | Annual mean | 0.81 | 0.53 | 10.6 | 1.34 | 26.8 |
| | 30 | 24 hour mean (short term) | 1.6 | 0.96 | 3.2 | 2.56 | 8.5 |
| Hg | 600 | 1-hour mean (short term) | - | 4.98 | 0.83 | 4.98 | 0.83 |
| | 60 | 24 hour mean (long term) | - | 0.75 | 1.25 | 0.75 | 1.25 |
| Sb | 5000 | Annual mean | - | 10 | 0.20 | 10.00 | 0.20 |
| | 150000 | 1-hour average | - | 750 | 0.50 | 750.00 | 0.500 |
| Pb | 250 | Annual mean | 21.1 | 8 | 3.20 | 29.10 | 11.64 |
| Cu | 50 | 24 hour mean (long term) | 4.2 | 10 | 20.00 | 14.20 | 28.400 |
| Mn | 150 | Annual mean | 81.9 | 7.95 | 5.30 | 89.85 | 59.90 |
| | 1500000 | 1-hour average | 164 | 1500 | 0.100 | 1664.00 | 0.11 |
| V | 5000 | Annual mean | 9.3 | 10 | 0.20 | 19.30 | 0.39 |
| | 1000 | 24-hr average | 18.6 | 58 | 5.80 | 76.60 | 7.66 |
| As | 6 | Annual mean | 0.73 | 7.92 | 132.00 | 8.65 | 144.2 |

| Pollutant | ES | | Back-ground | Process Contribution | | Predicted Environmental Concentration | |
|--------------|-------------------|--------------------------|-------------|----------------------|-------------------|---------------------------------------|-------------------|
| | ng/m ³ | Reference period | | ng/m ³ | ng/m ³ | % of EAL | ng/m ³ |
| Cr (II)(III) | 2000 | 24 hour mean (long term) | 3.5 | 10 | 0.50 | 13.50 | 0.675 |
| Cr (VI) | 0.25 | Annual mean | 7.80 | 1.99 | 795.00 | 9.79 | 3915.0 |
| Ni | 20 | Annual mean | 1.5 | 7.94 | 39.70 | 9.44 | 47.2 |
| | 700 | 1-hour mean | 3 | 5.88 | 0.84 | 8.88 | 1.3 |

New Environmental Assessment Levels (EAL) were implemented for a few pollutants including some metals on 20 November 2023 (after the Application was received).

We checked the applicants modelling against these new EALs and carried out our own screening checks. We are satisfied that the new EALS do no change the conclusions of our audit and the tables above include the new EALs.

(i) Screening out emissions which are insignificant

From the tables above the following emissions can be screened out as insignificant in that the PC is < 1% of the long term ES and <10% of the short term ES. These are:

- NO₂, particulates, SO₂, HCl, HF, CO, PAH, NH₃, PCB, Hg, Sb, V, Cr(II)(III).

Therefore we consider the Applicant's proposals for preventing and minimising the emissions of these substances to be BAT for the Installation subject to the detailed audit referred to below.

(ii) Emissions unlikely to give rise to significant pollution

Also from the tables above the following emissions (which were not screened out as insignificant) have been assessed as being unlikely to give rise to significant pollution in that the PEC is less than 100% (taking expected modelling uncertainties into account) of both the long term and short term ES.

- TOC, Cd, Pb, Cu, Mn, Ni.

For these emissions, we have carefully scrutinised the Applicant's proposals to ensure that they are applying BAT to prevent and minimise emissions of these substances. This is reported in section 6 of this document.

(iii) Emissions requiring further assessment

From the tables above the following emissions are considered to have the potential to give rise to significant pollution in that the Predicted Environmental Concentration exceeds 100% of the long term or short term ES.

- As, Cr(VI).

These metals are considered further in section 5.2.4 below.

5.2.2 Consideration of key pollutants

(i) Nitrogen dioxide (NO₂)

The impact on air quality from NO₂ emissions has been assessed against the ES of 40 µg/m³ as a long term annual average and 200 µg/m³ as a short term hourly average.

The model assumes a 70% NO_x to NO₂ conversion for the long term and 35% for the short term assessment in line with Environment Agency guidance on the use of air dispersion modelling.

The above tables show that the maximum long term PC is less than 1% of the ES and the maximum short term PC is less than 10% of the ES and so can be screened out as insignificant. Therefore, we consider the Applicant's proposals for preventing and minimising the emissions of these substances to be BAT for the Installation.

(ii) Particulate matter PM₁₀ and PM_{2.5}

The impact on air quality from particulate emissions has been assessed against the ES for PM₁₀ (particles of 10 microns and smaller) and PM_{2.5} (particles of 2.5 microns and smaller). For PM₁₀, the ES are a long term annual average of 40 µg/m³ and a short term daily average of 50 µg/m³. For PM_{2.5} the ES of 20 µg/m³ as a long-term annual average was used, having changed from 25 µg/m³ in 2020.

The Applicant's predicted impact of the Installation against these ES is shown in the tables above. The assessment assumes that **all** particulate emissions are present as PM₁₀ for the PM₁₀ assessment and that **all** particulate emissions are present as PM_{2.5} for the PM_{2.5} assessment.

The above assessment is considered to represent a worst case assessment in that:

- It assumes that the plant emits particulates continuously at the IED Annex VI limit for total dust, whereas actual emissions from similar plant are normally lower.
- It assumes all particulates emitted are below either 10 microns (PM₁₀) or 2.5 microns (PM_{2.5}), when some are expected to be larger.

We have reviewed the Applicant's particulate matter impact assessment and are satisfied in the robustness of the Applicant's conclusions.

| | | |
|--|---------------|---|
| | Page 29 of 96 | Application Number EPR/RP3638SJ/A001 |
|--|---------------|---|

The above table shows that the predicted PC for emissions of PM₁₀ is below 1% of the long term ES and below 10% of the short term ES and so can be screened out as insignificant. Therefore, we consider the Applicant's proposals for preventing and minimising the emissions of particulates to be BAT for the Installation.

The above table also shows that the predicted PC for emissions of PM_{2.5} is also below 1% of the ES. Therefore, the Environment Agency concludes that particulate emissions from the installation, including emissions of PM₁₀ or PM_{2.5}, will not give rise to significant pollution.

There is currently no emission limit prescribed nor any continuous emissions monitor for particulate matter specifically in the PM₁₀ or PM_{2.5} fraction. Whilst we are confident that current monitoring techniques will capture the fine particle fraction (PM_{2.5}) for inclusion in the measurement of total particulate matter, an improvement condition (IC2) has been included that will require a full analysis of particle size distribution in the flue gas, and hence determine the ratio of fine to coarse particles. In the light of current knowledge and available data however we are satisfied that the health of the public would not be put at risk by such emissions, as explained in section 5.3.3.

(iii) Acid gases, sulphur dioxide (SO₂), hydrogen chloride (HCl) and hydrogen fluoride (HF)

From the tables above, emissions of HCl and HF can be screened out as insignificant in that the process contribution is <10% of the short term ES. The ES for HCl is 750 µg/m³, this is an hourly short term average, there is no long term ES for HCl. HF has 2 assessment criteria – a 1-hr ES of 160 µg/m³ and a monthly ES of 16 µg/m³ – the process contribution is <1% of the monthly ES and so the emission screens out as insignificant if the monthly ES is interpreted as representing a long term ES.

There is no long term EAL for SO₂ for the protection of human health. Protection of ecological receptors from SO₂ for which there is a long term ES is considered in section 5.4. There are three short term ES, hourly of 350 µg/m³, 15 – minute of 266 µg/m³ and daily of 125 µg/m³.

From the above table, emissions of SO₂ can be screened out as insignificant in that the short term process contribution is <10% of each of the three short term ES values. Therefore, we consider the Applicant's proposals for preventing and minimising the emissions of these substances to be BAT for the Installation.

(iv) Emissions to air of carbon monoxide (CO), Volatile Organic Compounds (VOCs), Polycyclic Aromatic Hydrocarbons (PAHs), Polychlorinated Biphenyls (PCBs), Dioxins and ammonia (NH₃)

The above tables show that for CO the maximum short term PC is less than 10% of the ES and so can be screened out as insignificant. Therefore, we consider the Applicant's proposals for preventing and minimising the emissions of this substance to be BAT for the Installation.

The above tables show that for VOC emissions, the maximum long term PC is greater than 1% of the ES and therefore cannot be screened out as insignificant. However, the emission is not expected to result in the ES being exceeded.

The Applicant has used the ES for 1,3 butadiene for their assessment of the impact of VOC. This is based on 1,3 butadiene having the lowest ES of organic species likely to be present in VOC (other than PAH, PCBs, dioxins and furans).

The above tables show that for PAH and PCB emissions, the maximum long term PC is less than 1% of the ES and the maximum short term PC is less than 10% of the ES for PCBs and so can be screened out as insignificant. Therefore, we consider the Applicant's proposals for preventing and minimising the emissions of these substances to be BAT for the Installation.

The Applicant has also used the ES for benzo[a]pyrene (BaP) for their assessment of the impact of PAH. We agree that the use of the BaP ES is sufficiently precautionary.

There is no ES for dioxins and furans as the principal exposure route for these substances is by ingestion and the risk to human health is through the accumulation of these substances in the body over an extended period of time. This issue is considered in more detail in section 5.3

From the tables above all the other emissions can be screened out as insignificant in that the PC is < 1% of the long term ES and <10% of the short term ES.

The ammonia emission is based on a release concentration of 10 mg/m³. We are satisfied that this level of emission is consistent with the operation of a well controlled SNCR NO_x abatement system.

Whilst all emissions cannot be screened out as insignificant, the Applicant's modelling shows that the installation is unlikely to result in a breach of the ES. The Applicant is required to prevent, minimise and control PAH and VOC emissions using BAT, this is considered further in Section 6. We are satisfied that PAH and VOC emissions will not result in significant pollution.

(V) Summary

For the above emissions to air, for those emissions that have not screened out as insignificant, we have carefully scrutinised the Applicant's proposals to ensure that they are applying the BAT to prevent and minimise emissions of these substances. This is reported in section 6 of this document. Therefore, we consider the Applicant's proposals for preventing and minimising emissions to be BAT for the Installation. Dioxins and furans are considered further in section 5.3.2.

5.2.3 Assessment of Emission of Metals

The Applicant has assessed the impact of metal emissions to air, as previously described.

There are three sets of BAT AELs for metal emissions:

- An emission limit value of 0.02 mg/m³ for mercury and its compounds (formerly WID group 1 metals).
- An aggregate emission limit value of 0.02 mg/m³ for cadmium and thallium and their compounds (formerly WID group 2 metals).
- An aggregate emission limit of 0.3 mg/m³ for antimony, arsenic, lead, chromium, cobalt, copper, manganese, nickel and vanadium and their compounds (formerly WID group 3 metals).

In addition, the UK is a Party to the Heavy Metals Protocol within the framework of the UN-ECE Convention on long-range trans-boundary air pollution. Compliance with the IED Annex VI emission limits for metals along with the Application of BAT also ensures that these requirements are met.

In section 5.2.1 above, the following emissions of metals were screened out as insignificant:

- Hg, Sb, V, Cr(II)(III).

Also in section 5.2.1, the following emissions of metals whilst not screened out as insignificant were assessed as being unlikely to give rise to significant pollution:

- Cd, Pb, Cu, Mn, Ni.

This left emissions of As and Cr(VI) requiring further assessment. For all other metals, the Applicant has concluded that exceedences of the EAL for all metals are not likely to occur.

Where the BREF sets an aggregate limit, the Applicant's assessment assumes that each metal is emitted individually at the relevant aggregate emission limit value. This is a something which can never actually occur in practice as it would inevitably result in a breach of the said limit, and so represents a very much worst case scenario.

For metals As and Cr(VI) the Applicant Used representative emissions data from other municipal waste incinerators using our guidance note Please refer

to “Guidance to Applicants on Impact Assessment for Group 3 Metals Stack Releases – version 4”. Measurement of Chromium (VI) at the levels anticipated at the stack emission points is expected to be difficult, with the likely levels being below the level of detection by the most advanced methods.

Data for Cr (VI) was based on total Cr emissions measurements and the proportion of total Cr to Cr (VI) in APC residues.

Based on the above, the following emissions of metals were screened out as insignificant:

- As, Cr(VI).

We have set improvement condition IC6 for the assumptions used above for As and Cr(VI) to be confirmed with monitoring data.

The installation has been assessed as meeting BAT for control of metal emissions to air. See section 6 of this document.

5.2.4 Consideration of Local Factors

(i) Impact on Air Quality Management Areas (AQMAs)

No AQMAs have been declared within an area likely to be affected by emissions from the Installation.

(ii) Combined impacts

The Applicant considered whether other permitted but not yet operational sites could affect the background levels, specifically they carried out a cumulative impact with North Beck Energy Centre which.

We have audited this and agree that cumulative impacts from the proposed installation with nearby proposed developments will not cause a breach of any ES set for the protection of human health, nor any critical load or level set for the protection of ecological designations.

5.3 **Human health risk assessment**

5.3.1 Our role in preventing harm to human health

The Environment Agency has a statutory role to protect the environment and human health from all processes and activities it regulates. We assessed the effects on human health for this application in the following ways:

i) Applying Statutory Controls

The plant will be regulated under EPR. The EPR include the requirements of relevant EU Directives, notably, the IED, the WFD, and ADD.

The main conditions in an EfW permit are based on the requirements of the IED. Specific conditions have been introduced to specifically ensure compliance with the requirements of Chapter IV of the IED. The aim of the IED is to prevent or, where that is not practicable, to reduce emissions to air, water and land and prevent the generation of waste, in order to achieve a high level of protection of the environment taken as a whole. IED achieves this aim by setting operational conditions, technical requirements and emission limit values to meet the requirements set out in Articles 11 and 18 of the IED. These requirements may in some circumstances dictate tighter emission limits and controls than those set out in the BAT conclusions (BAT-C) or Chapter IV of IED on waste incineration and co-incineration plants. The assessment of BAT for this installation is detailed in section 6 of this document.

ii) Environmental Impact Assessment

Industrial activities can give rise to odour, noise and vibration, accidents, fugitive emissions to air and water, releases to air (including the impact on Photochemical Ozone Creation Potential (POCP)), discharges to ground or groundwater, GWP and the generation of waste. For an installation of this kind, the principal environmental effects are through emissions to air, although we also consider all of the other impacts listed. Section 5.1 and 5.2 above explain how we have approached the critical issue of assessing the likely impact of the emissions to air from the Installation on human health and the environment and any measures we are requiring to ensure a high level of protection.

iii) Expert Scientific Opinion

There is a significant amount of literature on whether there are links between operation of incineration plants and effects on health. We have not referenced them here, but we have included information on one of the most recent studies that was commissioned by the UK Health Security Agency (UKHSA), previously Public Health England (PHE). The overall weight of the evidence is that there is not a significant impact on human health.

UKHSA review research undertaken to examine suggested links between emissions from municipal waste incinerators and effects on health. UKHSA's risk assessment is that modern, well run and regulated municipal waste incinerators are not a significant risk to public health. While it is not possible to rule out adverse health effects from these incinerators completely, any potential effect for people living close by is likely to be very small.

UKHSA keep literature on health effects under review and would inform us if there were any changes to the above position. Similarly, we would consult UKHSA if new evidence was provided to us.

In 2012 the UK Small Area Health Statistics Unit (SAHSU) at Imperial College was commissioned by PHE to carry out a study to extend the evidence base and to provide further information to the public about any potential reproductive and infant health risks from municipal waste incineration (MWIs).

A number of papers have been published by SAHSU since 2012 which show no effect on birth outcomes. One paper in the study looked at exposure to emissions from MWIs in the UK and concluded that exposure was low. Subsequent papers found no increased risk of a range of birth outcomes (including stillbirth and infant mortality) in relation to exposure to PM₁₀ emissions and proximity to MWIs, and no association with MWIs opening on changes in risks of infant mortality or sex ratio.

The final part of the study, published on 21/06/19, found no evidence of increased risk of congenital anomalies from exposure to MWI chimney emissions, but a small potential increase in risk of congenital anomalies for children born within ten kilometres of MWIs. The paper does not demonstrate a causal effect, and it acknowledges that the observed results may well be

down to not fully adjusting the study for factors such as other sources of pollution around MWIs or deprivation.

UKHSA have stated that 'While the conclusions of the study state that a causal effect cannot be excluded, the study does not demonstrate a causal association and makes clear that the results may well reflect incomplete control for confounding i.e. insufficiently accounting for other factors that can cause congenital anomalies, including other sources of local pollution. This possible explanation is supported by the fact no increased risk of congenital anomalies was observed as a result of exposure to emissions from an incinerator.'

Following this study, UKHSA have further stated that their position remains that modern, well run and regulated municipal waste incinerators are not a significant risk to public health.

We agree with the view stated by the UKHSA. We ensure that permits contain conditions which require the installation to be well-run and regulate the installation to ensure compliance with such permit conditions.

iv) Health Risk Models

Comparing the results of air dispersion modelling as part of the Environmental Impact assessment against European and national air quality standards effectively makes a health risk assessment for those pollutants for which a standard has been derived. These air quality standards have been developed primarily to protect human health via known intake mechanisms, such as inhalation and ingestion. Some pollutants, such as dioxins, furans and dioxin like PCBs, have human health impacts at lower ingestion levels than lend themselves to setting an air quality standard to control against. For these pollutants, a different human health risk model is required which better reflects the level of dioxin intake.

Models are available to predict the dioxin, furan and dioxin like PCBs intake for comparison with the Tolerable Daily Intake (TDI) recommended by the Committee on Toxicity of Chemicals in Food, Consumer Products and the Environment, known as COT. These include the HHRAP model.

HHRAP has been developed by the US EPA to calculate the human body intake of a range of carcinogenic pollutants and to determine the mathematical quantitative risk in probabilistic terms. In the UK, in common with other European countries, we consider a threshold dose below which the likelihood of an adverse effect is regarded as being very low or effectively zero.

The TDI is the amount of a substance that can be ingested daily over a lifetime without appreciable health risk. It is expressed in relation to bodyweight to allow for different body size, such as for adults and children of different ages. In the UK, the COT has set a TDI for dioxins, furans and dioxin like PCBs of 2

picograms WHO-TEQ/kg-body weight/day (a picogram is a millionth of a millionth (10^{-12}) of a gram).

In addition to an assessment of risk from dioxins, furans and dioxin like PCBs, the HHRAP model enables a risk assessment from human intake of a range of heavy metals. In principle, the respective ES for these metals are protective of human health. It is not therefore necessary to model the human body intake.

The Committee on the Medical Effects of Air Pollution (COMEAP) developed a methodology based on the results of time series epidemiological studies which allows calculation of the public health impact of exposure to the classical air pollutants (NO_2 , SO_2 and particulates) in terms of the numbers of “deaths brought forward” and the “number of hospital admissions for respiratory disease brought forward or additional”. Defra reviewed this methodology and concluded that the use of the COMEAP methodology is not generally recommended for modelling the human health impacts of individual installations.

Our recommended approach is therefore the use of the methodology set out in our guidance for comparison for most pollutants (including metals) and dioxin intake modelling using the HHRAP model as described above for dioxins, furans and dioxin like PCBs. Where an alternative approach is adopted for dioxins, we check the predictions ourselves.

v) Consultations

As part of our normal procedures for the determination of a permit application, we consult with Local Authorities, Local Authority Directors of Public Health, FSA and PHE. We also consult the local communities who may raise health related issues. All issues raised by these consultations are considered in determining the Application as described in Annex 4 of this document.

5.3.2 Assessment of Intake of Dioxins, Furans and Dioxin like PCBs

For dioxins, furans and dioxin like PCBs, the principal exposure route is through ingestion, usually through the food chain, and the main risk to health is through accumulation in the body over the lifetime of the receptor.

The human health risk assessment calculates the dose of dioxins and furans that would be received by local receptors if their food and water were sourced from the locality where the deposition of dioxins, furans and dioxin like PCBs is predicted to be the highest. This is then assessed against the Tolerable Daily Intake (TDI) levels established by the COT of 2 picograms WHO-TEQ / kg body weight/ day.

The results of the Applicant’s assessment of dioxin intake are detailed in the table below (worst case results for each category are shown). The results showed that the predicted daily intake of dioxins, furans and dioxin like PCBs at all receptors, resulting from emissions from the proposed facility, were significantly below the recommended TDI levels.

| Receptor | adult | child |
|--------------|---------|---------|
| Agricultural | 0.12 | 0.18 |
| Residential | 0.00029 | 0.00082 |

Calculated maximum daily intake of dioxins over a lifetime by local receptors resulting from the operation of the proposed facility (WHO-TEQ/ kg-BW/day)

In 2010, the FSA studied the levels of chlorinated, brominated and mixed (chlorinated-brominated) dioxins and dioxin-like PCBs in fish, shellfish, meat and eggs consumed in the UK. It asked COT to consider the results and to advise on whether the measured levels of these PXDDs, PXDFs and PXBs indicated a health concern ('X' means a halogen). COT issued a statement in December 2010 and concluded that "The major contribution to the total dioxin toxic activity in the foods measured came from chlorinated compounds. Brominated compounds made a much smaller contribution, and mixed halogenated compounds contributed even less (1% or less of TDI). Measured levels of PXDDs, PXDFs and dioxin-like PXBs do not indicate a health concern". COT recognised the lack of quantified TEFs for these compounds but said that "even if the TEFs for PXDDs, PXDFs and dioxin-like PXBs were up to four fold higher than assumed, their contribution to the total TEQ in the diet would still be small. Thus, further research on PXDDs, PXDFs and dioxin-like PXBs is not considered a priority."

In the light of this statement, we assess the impact of chlorinated compounds as representing the impact of all chlorinated, brominated and mixed dioxins / furans and dioxin like PCBs.

5.3.3 Particulates smaller than 2.5 microns

The Operator will be required to monitor particulate emissions using the method set out in Table S3.1 of Schedule 3 of the Permit. This method requires that the filter efficiency must be at least 99.5 % on a test aerosol with a mean particle diameter of 0.3 µm, at the maximum flow rate anticipated. The filter efficiency for larger particles will be at least as high as this. This means that particulate monitoring data effectively captures everything above 0.3 µm and much of what is smaller. It is not expected that particles smaller than 0.3 µm will contribute significantly to the mass release rate / concentration of particulates because of their very small mass, even if present. This means that emissions monitoring data can be relied upon to measure the true mass emission rate of particulates.

Nano-particles are considered to refer to those particulates less than 0.1 µm in diameter (PM_{0.1}). Questions are often raised about the effect of nano-particles on human health, in particular on children's health, because of their high surface to volume ratio, making them more reactive, and their very small size, giving them the potential to penetrate cell walls of living organisms. The small size also means there will be a larger number of small particles for a given mass concentration. However, the UKHSA statement (referenced below) says that due to the small effects of incinerators on local concentration of particles, it is highly unlikely that there will be detectable effects of any particular incinerator on local infant mortality.

The UKHSA addresses the issue of the health effects of particulates in their September 2009 statement 'The Impact on Health of Emissions to Air from Municipal Incinerators'. It refers to the coefficients linking PM₁₀ and PM_{2.5} with effects on health derived by COMEAP and goes on to say that if these coefficients are applied to small increases in concentrations produced, locally, by incinerators; the estimated effects on health are likely to be small. UKHSA note that the coefficients that allow the use of number concentrations in impact calculations have not yet been defined because the national experts have not judged that the evidence is sufficient to do so. This is an area being kept under review by COMEAP.

In December 2010, COMEAP published a report on The Mortality Effects of Long-Term Exposure to Particulate Air Pollution in the United Kingdom. It says that "a policy which aims to reduce the annual average concentration of PM_{2.5} by 1 µg/m³ would result in an increase in life expectancy of 20 days for people born in 2008." However, "The Committee stresses the need for careful interpretation of these metrics to avoid incorrect inferences being drawn – they are valid representations of population aggregate or average effects, but they can be misleading when interpreted as reflecting the experience of individuals."

UKHSA also point out that in 2007 incinerators contributed 0.02% to ambient ground level PM₁₀ levels compared with 18% for road traffic and 22% for industry in general. UKHSA noted that in a sample collected in a day at a typical urban area the proportion of PM_{0.1} is around 5-10% of PM₁₀. It goes on to say that PM₁₀ includes and exceeds PM_{2.5} which in turn includes and exceeds PM_{0.1}. The National Atmospheric Emissions Inventory (NAEI) figures show that in 2016 municipal waste incineration contributed 0.03% to ambient ground level PM₁₀ levels and 0.05% to ambient ground level PM_{2.5} levels. The 2016 data also shows that road traffic contributed to 5.35% of PM₁₀ and 4.96% of PM_{2.5} and that domestic wood burning contributed 22.4% to PM₁₀ and 34.3% of PM_{2.5} levels.

This is consistent with the assessment of this Application which shows emissions of PM₁₀ to air to be insignificant.

A 2016 a paper by Jones and Harrison concluded that 'ultrafine particles (<100nm) in flue gases from incinerators are broadly similar to those in urban air and that after dispersion with ambient air ultrafine particle concentrations are typically indistinguishable from those that would occur in the absence of the incinerator.

We take the view, based on the foregoing evidence, that techniques which control the release of particulates to levels which will not cause harm to human health will also control the release of fine particulate matter to a level which will not cause harm to human health.

5.3.4 Assessment of Health Effects from the Installation

Our assessment of health impacts is summarised below

- i. We have applied the relevant requirements of the Environmental legislation in imposing the permit conditions. We are satisfied that compliance with these conditions will ensure protection of the environment and human health.
- ii. In carrying out air dispersion modelling as part of the environmental impact assessment and comparing the PC and PEC with the ES, the Applicant has effectively made a health risk assessment for many pollutants. The ES have been developed primarily to protect human health. The Applicant's assessment indicated that the Installation emissions screen out as insignificant and where the impact of emissions of have not been screened out as insignificant, the assessment still shows that the PEC are well within the ES.
- iii. We have assessed the health effects from the operation of this installation in relation to the above (sections 5.3.1 to 5.3.3).
- iv. We have reviewed the methodology employed by the Applicant to carry out the health impact assessment.

Overall, taking into account the conservative nature of the impact assessment (i.e. that it is based upon an individual exposed for a life-time to the effects of the highest predicted relevant airborne concentrations and consuming mostly locally grown food), it was concluded that the operation of the proposed facility will not pose a significant risk to human health.

- v. We agree with the conclusion reached by UKHSA that modern, well run and regulated municipal waste incinerators are not a significant risk to public health. While it is not possible to rule out adverse health effects from these incinerators completely, any potential effect for people living close by is likely to be very small.
- vi. UKHSA and the Local Authority Director of Public Health were consulted on the Application. The UKHSA concluded that they had no significant concerns regarding the risk to the health of humans from the installation. The Local Authority Director of Public Health did not provide a response. The Food Standards Agency was also consulted during the permit determination process, they did not provide a response to our consultation. Details of the responses provided by to the consultation on this Application can be found in Annex 4.

We are therefore satisfied that the Applicant's conclusions presented above are reliable and we conclude that the potential emissions of pollutants including dioxins, furans and metals from the proposed facility are unlikely to have a significant impact on human health.

5.4 Impact on protected conservation areas (SPAs, SACs, Ramsar sites and SSSIs and local nature sites)

5.4.1 Sites Considered

The following Special Areas of Conservation (SAC), Special Protection Areas (SPA) and Ramsar sites are located within 10 km of the Installation:

- Humber Estuary SAC, SPA and Ramsar

The following Sites of Special Scientific Interest (SSSI) are located within 2 km of the Installation:

- Humber Estuary SSSI

The following local nature sites (ancient woodlands, local wildlife sites and national and local nature reserves) are located within 2 km of the Installation:

- Laporte Road Brownfield Site
- Stallingborough Fish Ponds

5.4.2 Habitats Assessment

The Applicant's habitats assessment was reviewed by our technical specialists for air dispersion modelling and assessment and specialists for, habitats and conservation who agreed with the assessment's conclusions, that there would be no likely significant effect on the interest features of the protected site.

Humber Estuary SAC, SPA and Ramsar

The Applicants figures are shown in the table below.

| Pollutant | ES / EAL ($\mu\text{g}/\text{m}^3$) | Back-ground ($\mu\text{g}/\text{m}^3$) | Process Contribution (PC) ($\mu\text{g}/\text{m}^3$) | PC as % of ES | Predicted Environmental Concentration (PEC) ($\mu\text{g}/\text{m}^3$) | PEC as % ES |
|---------------------------------|--|---|---|------------------------|---|-------------------|
| Direct Impacts ¹ | | | | | | |
| NO _x Annual | 30 | 21.30 | 0.91 | 3.03 | 22.21 | 74.03 |
| NO _x Daily Mean | 75 | - | 4.50 | 6.00 | - | - |
| SO ₂ | 20 | 3.49 | 0.27 | 1.35 | 3.76 | 18.80 |
| Ammonia | 3 | 1.96 | 0.091 | 3.03 | 2.05 | 68.37 |
| HF Weekly Mean | 0.5 | - | 0.027 | 5.40 | - | - |
| HF Daily Mean | 5 | - | 0.076 | 1.52 | - | - |
| Deposition Impacts ¹ | | | | | | |

| Pollutant | ES / EAL ($\mu\text{g}/\text{m}^3$) | Back-ground ($\mu\text{g}/\text{m}^3$) | Process Contribution (PC) ($\mu\text{g}/\text{m}^3$) | PC as % of ES | Predicted Environmental Concentration (PEC) ($\mu\text{g}/\text{m}^3$) | PEC as % ES |
|---------------------------------------|---|---|---|------------------------|---|-------------------|
| N Deposition (kg N/ha/yr) | 20 (critical load used in applicant's assessment) | 19.64 | 0.60 | 3.00 | 20.24 | 101.20 |
| Acidification (N+S) (Keq/ha/yr) | Not sensitive to acidification | | | | | |

(1) Direct impact units are $\mu\text{g}/\text{m}^3$ and deposition impact units are kg N/ha/yr or Keq/ha/yr.

The PECs for NO_x, HF, SO₂ and NH₃ are below the critical levels and therefore we concluded no likely significant effect.

Whilst acid deposition has been included in the Applicant's assessment the notified features and/or habitats present at the receptor locations are not considered sensitive to impacts from it and therefore acidification is not considered there would be any effect at all.

The Applicant modelled nutrient nitrogen deposition for all relevant sensitive habitats present in the designated site. The process contribution exceeded 1% with the background level above the critical load, so an appropriate assessment was required.

The Applicant's background of 19 kgN/ha/yr is likely this figure was taken from APIS prior to a recent update of the website. A check of APIS for this assessment shows that at the estimated highest point of impact within the Humber Estuary designated sites the background load is given as 14.9kg N/ha/yr. However, this is for moorland (short vegetation) and it is likely that actual deposition is less than this, based on APIS guidance:

"Direct deposition onto habitats with little or no surface vegetation, such as freshwaters or shingle, will be less than onto e.g. bogs, heath etc. in the same location, but modelled deposition rates are not currently available for these habitats. Using the EMEP4UK model, direct deposition of total nitrogen onto freshwaters has been estimated at 63 % of the deposition rate onto moorland. This proportion of the local nitrogen deposition onto moorland could be used as an estimate of direct deposition onto freshwater within the same grid cell, but measurements are scarce and the proportion remains uncertain."

The only habitat present in that location is mudflats, which are also subject to tidal inundation, it is expected that deposition impacts would be minimal.

However, to quantify the likely worse case scenario, the PEC using the updated background load of 14.9kg N/ha/yr is calculated to be 15.5kg N/ha/yr, which equates to 77.5% of the critical load (CL), low enough that it can be concluded there would be no likely adverse impact.

5.4.3 SSSI Assessment

| | | |
|--|---------------|---|
| | Page 42 of 96 | Application Number EPR/RP3638SJ/A001 |
|--|---------------|---|

The Applicant's assessment of SSSIs was reviewed by our technical specialists for air dispersion modelling and assessment and specialists for habitats and conservation, who agreed with the assessment's conclusions, that the proposal does not damage the special features of the SSSI.

The Applicants figures are shown in the table below.

| Pollutant | ES / EAL ($\mu\text{g}/\text{m}^3$) | Back-ground ($\mu\text{g}/\text{m}^3$) | Process Contribution (PC) ($\mu\text{g}/\text{m}^3$) | PC as % of ES | Predicted Environmental Concentration (PEC) ($\mu\text{g}/\text{m}^3$) | PEC as % ES |
|---------------------------------|--|---|---|---------------------|---|-------------------|
| Direct Impacts ¹ | | | | | | |
| NO _x Annual | 30 | 21.30 | 0.91 | 3.03 | 22.21 | 74.03 |
| NO _x Daily Mean | 75 | - | 4.50 | 6.00 | - | - |
| SO ₂ | 20 | 3.49 | 0.27 | 1.35 | 3.76 | 18.80 |
| Ammonia | 3 | 1.96 | 0.091 | 3.03 | 2.05 | 68.37 |
| HF Weekly Mean | 0.5 | - | 0.027 | 5.40 | - | - |
| HF Daily Mean | 5 | - | 0.076 | 1.52 | - | - |
| Deposition Impacts ¹ | | | | | | |
| N Deposition (kg N/ha/yr) | Not sensitive nitrogen deposition | | | | | |
| Acidification (Keq/ha/yr) | Not sensitive to acidification | | | | | |

(1) Direct impact units are $\mu\text{g}/\text{m}^3$ and deposition impact units are kg N/ha/yr or Keq/ha/yr.

The PECs for NO_x, HF, SO₂ and NH₃ are below the critical levels and therefore we concluded not likely to damage.

For nitrogen deposition we used the same critical load as for the habitat site in the section above. Based on this our conclusion is not likely to damage with the PEC being 77.5% of the critical load.

5.4.4 Assessment of local nature sites

Conservation sites are protected in law by legislation which provides the highest level of protection for SACs and SPAs, and also for protection of protection for SSSIs. Finally, the Environment Act 1995 provides more generalised protection for flora and fauna rather than for specifically named conservation designations. It is under the Environment Act 1995 that we assess other sites (such as ancient woodlands, local wildlife sites and national and local nature reserves) which prevents us from permitting something that will result in significant pollution; and which offers levels of protection proportionate with other European and national legislation. However, it should not be assumed that because levels of protection are less stringent for these

other sites, that they are not of considerable importance. Local sites link and support EU and national nature conservation sites together and hence help to maintain the UK's biodiversity resilience.

For SACs SPAs, Ramsars and SSSIs we consider the PC and the background levels in making an assessment of impact. In assessing the local nature sites under the Environment Act 1995 we look at the impact from the Installation alone to determine whether it would cause significant pollution. This is a proportionate approach, in line with the levels of protection offered by the conservation legislation to protect these other sites (which are generally more numerous than Natura 2000 or SSSIs) whilst ensuring that we do not restrict development.

Critical levels and loads are set to protect the most vulnerable habitat types. Thresholds change in accordance with the levels of protection afforded by the legislation. Therefore, the thresholds for SAC SPA and SSSI features are more stringent than those for local nature sites.

Therefore, we would generally conclude that the Installation is not causing significant pollution at these other sites if the PC is less than the relevant critical level or critical load, provided that the Applicant is using BAT to control emissions.

The applicant assessed impacts at 3 sites:

- North Moss Lane Meadow SNCI
- Immingham Dock Reedbeds SNCI
- Laporte Road Brownfield Site LWS

The applicants modelling show that process contributions are well below the critical levels and loads.

We also identified Stallingborough Fish Ponds LWS

The site is close to North Moss Lane Meadow SNCI and based on modelling results at that site we are satisfied that process contributions are well below the critical levels and loads at this site as well.

We are satisfied that the Installation will not cause significant pollution at any of the other conservation sites. The Applicant is required to prevent, minimise and control emissions using BAT, this is considered further in Section 6.

5.5 Impact of abnormal operations

Article 50(4)(c) of the IED requires that waste incineration and co-incineration plants shall operate an automatic system to prevent waste feed whenever any of the continuous emission monitors show that an ELV is exceeded due to disturbances or failures of the purification devices. Notwithstanding this, Article 46(6) allows for the continued incineration and co-incineration of waste under such conditions provided that this period does not (in any circumstances)

exceed 4 hours uninterrupted continuous operation or the cumulative period of operation does not exceed 60 hours in a calendar year. This is a recognition that the emissions during transient states (e.g. start-up and shut-down) are higher than during steady-state operation, and the overall environmental impact of continued operation with a limited exceedance of an ELV may be less than that of a partial shut-down and re-start.

For incineration plant, IED sets backstop limits for particulates, CO and TOC which must continue to be met during abnormal operation. The CO and TOC limits are the same as for normal operation, and are intended to ensure that good combustion conditions are maintained. The backstop limit for particulates is 150 mg/m³ (as a half hourly average) which is five times the limit in normal operation.

Article 45(1)(f) requires that the permit shall specify the maximum permissible period of any technically unavoidable stoppages, disturbances, or failures of the purification devices or the measurement devices, during which the concentrations in the discharges into the air may exceed the prescribed emission limit values. In this case we have decided to set the time limit at 4 hours, which is the maximum period prescribed by Article 46(6) of the IED.

These abnormal operations are limited to no more than a period of 4 hours continuous operation and no more than 60 hours aggregated operation in any calendar year. This is less than 1% of total operating hours and so abnormal operating conditions are not expected to have any significant long term environmental impact unless the background conditions were already close to, or exceeding, an ES. For the most part therefore consideration of abnormal operations is limited to consideration of its impact on short term ESs.

In making an assessment of abnormal operations the following worst case scenario has been assumed:

- Dioxin emissions of 100 x normal
- Mercury emissions are 100 times those of normal operation
- NO_x emissions of 500 mg/m³
- Particulate emissions of 150 mg/m³
- Metal emissions other than mercury are 30 times those of normal operation
- SO₂ emissions of 258 mg/m³
- HCl emissions of 398 mg/m³
- PCBs 100 x normal

This is a worst case scenario in that these abnormal conditions include a number of different equipment failures not all of which will necessarily result in an adverse impact on the environment (e.g. a failure of a monitoring instrument does not necessarily mean that the incinerator or abatement plant is malfunctioning). This analysis assumes that any failure of any equipment results in all the negative impacts set out above occurring simultaneously.

The result on the Applicant's short-term environmental impact is summarised in the table below.

| Pollutant | ES | | Back-ground | Process Contribution (PC) | | Predicted Environmental Concentration (PEC) | |
|------------------|-------------------------|-------------------------------|-------------------------|---------------------------|-------------------------|---|-------------------|
| | µg/m ³ | | | µg/m ³ | µg/m ³ | % of EAL | µg/m ³ |
| NO ₂ | 200 | 99.79th %ile of 1-hour means | 27 | 45.4 | 22.7 | 72.4 | 36.2 |
| PM ₁₀ | 50 | 90.41st %ile of 24-hour means | 18.5 | 5.6 | 11.20 | 24.1 | 48.2 |
| SO ₂ | 266 | 99.9th %ile of 15-min means | 38.9 | 89.7 | 33.7 | 128.6 | 48.3 |
| | 350 | 99.73rd %ile of 1-hour means | 29 | 45.4 | 12.97 | 74.4 | 21.3 |
| | 125 | 99.18th %ile of 24-hour means | 17.1 | 13.2 | 10.56 | 30.3 | 24.2 |
| HCl | 750 | 1-hr average | 0.62 | 103.3 | 13.77 | 103.9 | 13.86 |
| HF | 160 | 1-hr average | 1 | 0.9 | 0.5625 | 1.90 | 1.2 |
| | ng/m³ | | ng/m³ | | ng/m³ | | |
| Hg | 600 | 1-hr average | - | 519 | 86.50 | 519.00 | 86.50 |
| Sb | 150000 | 1-hr average | - | 2334 | 1.56 | 2334 | 1.556 |
| Mn | 1500000 | 1-hr average | 164 | 2334 | 0.16 | 2498 | 0.1665 |
| PCBs | 6000 | 1-hr average | 0.000048 | 0.000093 | 0.0000016 | 0.000141 | 0.0000024 |

From the table above emissions have been assessed as being unlikely to give rise to significant pollution in that the predicted environmental concentration is less than 100% of short term ES. The Applicant's assessment was based on Hg emissions being 100 x normal emissions. However our view is that this is very much a worst case with the BREF indicating a 95% removal efficiency with activated carbon meaning that failure of that system could increase emissions

by a factor of 20. The Applicant did not have any data on background mercury levels.

We are therefore satisfied that it is not necessary to further constrain the conditions and duration of the periods of abnormal operation beyond those permitted under Chapter IV of the IED.

We have not assessed the impact of abnormal operations against long term ESs for the reasons set out above. Except that if dioxin emissions were at 10 ng/m³ for the maximum period of abnormal operation, this would result in an increase of approximately 70% in the TDI reported in section 5.3.3. In these circumstances the TDI would be 0.31 pg(WHO-TEQ/ kg-BW/day), which is 15.5 % of the COT TDI. Our checks showed that it would be <10% of the TDI and that emissions of dioxins will still not pose a risk to human health.

6 Application of Best Available Techniques

6.1 Scope of Consideration

In this section, we explain how we have determined whether the Applicant's proposals are BAT for this Installation.

- The first issue we address is the fundamental choice of incineration technology. There are a number of alternatives, and the Applicant has explained why it has chosen one particular kind for this Installation.
- We then consider in particular control measures for the emissions which were not screened out as insignificant in the previous section on minimising the installation's environmental impact.
- We also have to consider the combustion efficiency and energy utilisation of different design options for the Installation, which are relevant considerations in the determination of BAT for the Installation, including the GWP of the different options.
- Finally, the prevention and minimisation of Persistent Organic Pollutants (POPs) must be considered, as we explain below.

Chapter IV of the IED specifies a set of maximum ELV. Although these limits are designed to be stringent, and to provide a high level of environmental protection, they do not necessarily reflect what can be achieved by new plant. Article 14(3) of the IED says that BAT-C shall be the reference for setting the permit conditions,. The BAT-C were published on 03/12/2019 and set BAT AELs for various substances mainly as daily average values which are in many cases lower than the chapter IV limits.

Operational controls complement the ELV and should generally result in emissions below the maximum allowed; whilst the limits themselves provide headroom to allow for unavoidable process fluctuations. Actual emissions are therefore almost certain to be below emission limits in practice, because any Operator that sought to operate its installation continually at the maximum permitted limits would almost inevitably breach those limits regularly, simply by virtue of normal fluctuations in plant performance, resulting in enforcement action (including potentially prosecution, suspension or revocation) being taken. Assessments based on BAT AELs or Chapter IV limits are therefore “worst-case” scenarios.

We are satisfied that emissions at the permitted limits would ensure a high level of protection for human health and the environment in any event.

6.1.1 Consideration of Furnace Type

The prime function of the furnace is to achieve maximum combustion of the waste. Chapter IV of the IED requires that the plant (furnace in this context) should be designed to deliver its requirements. The main requirements of Chapter IV in relation to the choice of a furnace are compliance with air emission limits for CO and TOC and achieving a low TOC/LOI level in the bottom ash.

The BREF states that Municipal Waste can be incinerated in traveling grates, rotary kilns and fluidised bed technology. Fluidised bed technology requires MSW to be of a certain particle size range, which usually requires some degree of pre-treatment even when the waste is collected separately.

The BREF describes other process such as gasification and pyrolysis. The BREF notes that some of the processes have encountered technical and economic problems when scaled up to commercial, industrial sizes. Some are used on a commercial basis in Japan and are being tested in demonstration plants in Europe but still only have a small share of overall capacity.

Section 4.3 of the BREF provides a comparison of combustion and thermal treatment technologies, used in Europe and factors affecting their applicability and operational suitability for various waste types. There is also some information on the comparative costs. The table below has been extracted from the BREF tables. This table is also in line with the Guidance Note “The Incineration of Waste (EPR 5.01)). However, it should not be taken as an exhaustive list nor that all technologies listed have found equal application across Europe.

Overall, any of the furnace technologies identified in the BREF would be considered as BAT provided the Applicant has justified it in terms of:

- nature/physical state of the waste and its variability
- proposed plant throughput which may affect the number of incineration lines
- preference and experience of chosen technology including plant availability
- nature and quantity/quality of residues produced.

- emissions to air – usually NOx as the furnace choice could have an effect on the amount of unabated NOx produced
- energy consumption – whole plant, waste preparation, effect on GWP
- Need, if any, for further processing of residues to comply with TOC
- Costs

Summary comparison of thermal treatment technologies (reproduced from the Waste Incineration BREF)

| Technique | Key waste characteristics and suitability | Throughput per line | Advantages | Disadvantages / Limitations of use | Bottom Ash Quality | Cost |
|------------------------------|--|---|---|---|--------------------|--|
| Moving grate (air-cooled) | <ul style="list-style-type: none"> • Low to medium heat values (LCV 5 – 16.5 GJ/t) • Municipal and other heterogeneous solid wastes • Can accept a proportion of sewage sludge and/or medical waste with municipal waste • Applied at most modern • MSW installations | <ul style="list-style-type: none"> • 1 to 50 t/h with most projects 5 to 30 t/h. • Most industrial applications not below 2.5 or 3 t/h. | <ul style="list-style-type: none"> • Widely proven at large scales. • Robust • Low maintenance cost • Long operational history • Can take heterogeneous wastes without special preparation | <ul style="list-style-type: none"> • Generally not suited to powders, liquids or materials that melt through the grate | TOC 0.5% to 3% | High capacity reduces specific cost per tonne of waste |
| Moving grate (liquid Cooled) | Same as air-cooled grates except: LCV 10 – 20 GJ/t | Same as air-cooled grates | As air-cooled grates but: <ul style="list-style-type: none"> • higher heat value waste is treatable • Better combustion control possible. | As air-cooled grates but: <ul style="list-style-type: none"> • risk of grate damage/leaks • higher complexity | TOC 0.5% to 3% | Slightly higher capital cost than air-cooled |

| Technique | Key waste characteristics and suitability | Throughput per line | Advantages | Disadvantages / Limitations of use | Bottom Ash Quality | Cost |
|-------------------------|---|---------------------|---|---|--------------------|--|
| Rotary Kiln | <p>Can accept liquids and pastes as well as gases</p> <p>Solid feeds more limited than grate (due to refractory damage)</p> <p>often applied to hazardous Wastes</p> | <16 t/h | <ul style="list-style-type: none"> • Very well proven • Broad range of wastes • Good burn out even of HW | Throughputs lower than grates | TOC <3 % | Higher specific cost due to reduced capacity |
| Fluid bed - bubbling | <ul style="list-style-type: none"> • Wide range of CV (5-25 MJ/kg) • Only finely divided consistent wastes. • Limited use for raw MSW • Often applied to sludges co fired with RDF, shredded MSW, sludges, poultry manure | Up to 25 t/h | <ul style="list-style-type: none"> • Good mixing • Fly ashes of good leaching quality | <ul style="list-style-type: none"> • Careful operation required to avoid clogging bed. • Higher fly ash quantities. | TOC <1% | <p>FGT cost may be lower.</p> <p>Costs of waste preparation</p> |
| Fluid bed - circulating | <ul style="list-style-type: none"> • Wide range of CV (6-25 MJ/kg) • Only finely divided consistent wastes. • Limited use for raw MSW • Often applied to sludges co-fired with RDF, coal, wood waste | Up to 70 t/h | <ul style="list-style-type: none"> • Good mixing • High steam parameters up to 500°C • Greater fuel flexibility than BFB • Fly ashes of good leaching quality | <ul style="list-style-type: none"> • Cyclone required to conserve bed material • Higher fly ash quantities | TOC <1% | <ul style="list-style-type: none"> • FGT cost may be lower. • Costs of waste preparation |

| Technique | Key waste characteristics and suitability | Throughput per line | Advantages | Disadvantages / Limitations of use | Bottom Ash Quality | Cost |
|-------------------------------|---|----------------------------|--|---|---|---|
| Spreader - stoker combustor | <ul style="list-style-type: none"> • RDF and other particle feeds • Poultry manure • Wood wastes | No information | <ul style="list-style-type: none"> • Simple grate construction • Less sensitive to particle size than FB | Only for well defined mono-streams | No information | No information |
| Gasification - fixed bed | <ul style="list-style-type: none"> • Mixed plastic wastes • Other similar consistent streams • Gasification less widely used/proven than incineration | Up to 20 t/h | <ul style="list-style-type: none"> • Low leaching residue • Good burnout if oxygen blown • Syngas available • Reduced oxidation of recyclable metals | <ul style="list-style-type: none"> • Limited waste feed • Not full combustion • High skill level • Tar in raw gas • Less widely proven | <ul style="list-style-type: none"> • Low leaching bottom ash • Good burnout with oxygen | High operating/ maintenance costs |
| Gasification - entrained flow | <ul style="list-style-type: none"> • Mixed plastic wastes • Other similar consistent streams • Not suited to untreated MSW • Gasification less widely used/proven than incineration | Up to 10 t/h | <ul style="list-style-type: none"> • Low leaching slag • Reduced oxidation of recyclable metals | <ul style="list-style-type: none"> • Limited waste feed • Not full combustion • High skill level • Less widely proven | low leaching slag | <ul style="list-style-type: none"> • High operation/ maintenance costs • High pre-treatment costs |
| Gasification - fluidised bed | <ul style="list-style-type: none"> • Mixed plastic wastes • Shredded MSW • Shredder residues • Sludges • Metal rich wastes • Other similar consistent streams • Gasification less widely used/proven than incineration | 5 – 20 t/h | <ul style="list-style-type: none"> • Can use low reactor temperatures e.g. for Al recovery • Separation of main non combustibles • Can be combined with ash melting • Reduced oxidation of recyclable metals | <ul style="list-style-type: none"> • Limited waste size (<30cm) • Tar in raw gas • Higher UHV raw gas • Less widely proven | If combined with ash melting chamber ash is vitrified | Lower than other gasifiers |

| Technique | Key waste characteristics and suitability | Throughput per line | Advantages | Disadvantages / Limitations of use | Bottom Ash Quality | Cost |
|------------------|---|--|--|---|---|---|
| Pyrolysis | <ul style="list-style-type: none"> • Pre-treated MSW • High metal inert streams • Shredder residues/plastics • Pyrolysis is less widely used/proven than incineration | <p>~ 5 t/h (short drum) 5 – 10 t/h (medium drum)</p> | <ul style="list-style-type: none"> • No oxidation of metals • No combustion energy for metals/inert • In reactor acid neutralisation possible • Syngas available | <ul style="list-style-type: none"> • Limited wastes • Process control and engineering critical • High skill level • Not widely proven • Need market for syngas | <ul style="list-style-type: none"> • Dependent on process temperature • Residue produced requires further processing and sometimes combustion | High pre-treatment, operation and capital costs |

The Applicant has proposed to use a furnace technology comprising a moving grate type furnace, specifically a reciprocating plate grate. The Applicant's justification is that moving grate is:

- Very widely proven on large scales
- Robust – low maintenance cost
- Long operational history.
- Can take heterogeneous wastes without special preparation

Moving grate is identified in the tables above as being considered BAT in the BREF for this type of waste feed.

The Applicant proposes to use natural gas as support fuel for start-up, shut down and for the auxiliary burners. The choice of support fuel is based on high pressure gas main nearby, avoiding need to deliver and store liquid fuel at the site with a small footprint.

Boiler Design

In accordance with BAT 30 of the BAT-C and our guidance, EPR 5.01, the Applicant has confirmed that the boiler design will include the following features to minimise the potential for reformation of dioxins within the de-novo synthesis range:

- Rapid cooling through the “de novo” temperature range (400°C – 250°C)
- Minimise dust impingement/deposition on internal boiler surfaces
- Minimisation of boiler surfaces operating within the de novo synthesis temperature range
- 3 on-line boiler cleaning systems
- Boiler tubes designed to allow easy removal for off-line cleaning

Summary

Any of the options listed in the BREF and summarised in the table above can be BAT. The Applicant has chosen a furnace technique that is listed in the BREF and we are satisfied that the Applicant has provided sufficient justification to show that their technique is BAT. This is not to say that the other techniques could not also be BAT, but that the Applicant has shown that their chosen technique is at least comparable with the other BAT options. We believe that, based on the information gathered by the BREF process, the chosen technology will achieve the requirements of Chapter IV of the IED for the air emission of TOC/CO and the TOC/LOI on bottom ash. We are also satisfied that the proposed boiler design will be BAT.

6.2 BAT and emissions control

The prime function of flue gas treatment is to reduce the concentration of pollutants in the exhaust gas as far as practicable. The techniques which are described as BAT individually are targeted to remove specific pollutants, but the BREF notes that there is benefit from considering the Flue Gas Cleaning System (FGC) system as a whole unit. Individual units often interact, providing a primary abatement for some pollutants and an additional effect on others.

The BREF lists the general factors requiring consideration when selecting FGC systems as:

- type of waste, its composition and variation
- type of combustion process, and its size
- flue-gas flow and temperature
- flue-gas content, including magnitude and rate of composition fluctuations
- target emission limit values
- restrictions on discharge of aqueous effluents
- plume visibility requirements
- land and space availability
- availability and cost of outlets for residues accumulated/recovered
- compatibility with any existing process components (existing plants)
- availability and cost of water and other reagents
- energy supply possibilities (e.g. supply of heat from condensing scrubbers)
- reduction of emissions by primary methods
- noise
- arrangement of different flue-gas cleaning devices if possible with decreasing flue-gas temperatures from boiler to stack

Taking these factors into account the BREF points to a range of technologies being BAT subject to circumstances of the Installation.

6.2.1 Particulate Matter

| Particulate matter | | | | |
|----------------------------------|--|---|--|---|
| Technique | Advantages | Disadvantages | Optimisation | Defined as BAT in BREF or TGN for: |
| Bag / Fabric filters (BF) | Reliable abatement of particulate matter to below 5mg/m ³ | Max temp 250°C Higher energy use than ESP Sensitive to condensation and corrosion | Multiple compartments Bag burst detectors | Most plants |
| Wet scrubbing | May reduce acid gases simultaneously. | Not normally BAT. | Require reheat to prevent visible | Where scrubbing required for |

| | | Liquid effluent produced | plume and dew point problems. | other pollutants |
|--|--|---|-------------------------------|---|
| Ceramic filters | High temperature applications Smaller plant. | May "blind" more than fabric filters | | Small plant. High temperature gas cleaning required. |
| Electrostatic precipitators (ESP) | Low pressure gradient. Use with BF may reduce the energy consumption of the induced draft fan. | Not normally BAT by itself Risk of dioxin formation if used in 200-400°C range | | When used with other particulate abatement plant |

The Applicant proposes to use fabric filters for the abatement of particulate matter. Fabric filters provide reliable abatement of particulate matter to below 5 mg/m³ and are BAT for most installations. The Applicant proposes to use multiple compartment filters with burst bag detection to minimise the risk of increased particulate emissions in the event of bag rupture.

Emissions of particulate matter have been previously screened out as insignificant, and so we agree that the Applicant's proposed technique is BAT for the installation.

6.2.2 Oxides of Nitrogen

| Oxides of Nitrogen : Primary Measures | | | | |
|---|---|---|---------------------------------|---|
| Technique | Advantages | Disadvantages | Optimisation | Defined as BAT in BREF or TGN for: |
| Low NOx burners | Reduces NOx at source | | Start-up, supplementary firing. | Where auxiliary burners required. |
| Starved air systems | Reduce CO simultaneously. | | | Pyrolysis, Gasification systems. |
| Optimise primary and secondary air injection | | | | All plant. |
| Flue Gas Recirculation (FGR) | Reduces the consumption of reagents used for secondary NOx control. May increase overall energy recovery | Some applications experience corrosion problems. Can result in elevated CO and other products of incomplete combustion | | Justify if not used |

| Oxides of Nitrogen : Secondary Measures (BAT is to apply Primary Measures first) | | | | |
|---|--|---|---------------------|---|
| Technique | Advantages | Disadvantages | Optimisation | Defined as BAT in BREF or TGN for: |
| Selective catalytic reduction (SCR) | NOx emissions 40-150mg/ m ³ Reduces CO, VOC, dioxins | Expensive. Re-heat required – reduces plant efficiency | | All plant |
| SCR by catalytic filter bags | 50-120 mg/m ³ | | | Applicable to new and existing plants with or without existing SNCR. Can be used with NH ₃ as slip catalyst with SNCR |

| | | | | |
|---|---|---|--------------------------|---|
| Selective non-catalytic reduction (SNCR) | NO _x emissions 80 -180 mg/m ³ Lower energy consumption than SCR Lower costs than SCR | Relies on an optimum temperature around 900 °C, and sufficient retention time for reduction May lead to Ammonia slip | Port injection locations | All plant unless lower NO _x release required for local environmental protection. |
| Reagent Type: Ammonia | Likely to be BAT | More difficult to handle Lower nitrous oxide formation Narrower temperature window | | All plant |
| Reagent Type: Urea | Likely to be BAT | Higher N ₂ O emissions than ammonia, optimisation particularly important | | All plant |

The Applicant proposes to implement the following primary measures:

- Natural gas auxiliary burners
- Optimise primary and secondary air injection – this technique is BAT for all plant.
- Flue gas recirculation – this technique reduces the consumption of reagents for secondary NO_x control and can increase overall energy recovery.

There are three recognised techniques for secondary measures to reduce NO_x. These are Selective Catalytic Reduction (SCR), SCR by catalytic filter bags and Selective Non-Catalytic Reduction (SNCR) with or without catalytic filter bags. For each technique, there is a choice of urea or ammonia reagent.

SCR can reduce NO_x levels to below 50 mg/m³ and can be applied to all plant, it is generally more expensive than SNCR and requires reheating of the waste gas stream which reduces energy efficiency, periodic replacement of the catalysts also produces a hazardous waste. The use of SCR by catalytic filter bags can reduce emissions to 50 -120 mg/m³ with low investment costs. SNCR can typically reduce NO_x levels to between 80 and 180 mg/m³, it relies on an optimum temperature of around 900 °C and sufficient retention time for reduction. SNCR is more likely to have higher levels of ammonia slip. The technique can be applied to all plant unless lower NO_x releases are required for local environmental protection. Urea or ammonia can be used as the reagent with either technique, urea is somewhat easier to handle than ammonia and

has a wider operating temperature window, but tends to result in higher emissions of N₂O. Both reagents are BAT, and the use of one over the other is not normally significant in environmental terms.

The Applicant proposes to use SNCR with urea as the reagent.

Emissions of NO_x have been previously been screened out as insignificant, and so the Environment Agency agrees that the Applicant's proposed technique is BAT for the installation.

In addition the Applicant considered that the additional cost of SCR over SNCR is not justified by the reduction in environmental impact. Thus SCR is not BAT in this case, and SNCR is BAT for the Installation. The Applicant has justified the use of urea on the basis of reduced storage risks and wider operational temperature range. We agree with this assessment.

The amount of urea used for NO_x abatement will need to be optimised to maximise NO_x reduction and minimise NH₃ slip. Improvement condition IC5 requires the Operator to report to the Environment Agency on optimising the performance of the NO_x abatement system. The BAT AEL for ammonia has been set and the Operator is also required to monitor and report on N₂O emissions.

6.2.3 Acid Gases, SO_x, HCl and HF

| Acid gases and halogens : Primary Measures | | | | |
|---|--|---|---------------------------------|---|
| Technique | Advantages | Disadvantages | Optimisation | Defined as BAT in BREF or TGN for: |
| Low sulphur fuel, (< 0.1%S gasoil or natural gas) | Reduces SO _x at source | | Start-up, supplementary firing. | Where auxiliary fuel required. |
| Management of waste streams | Disperses sources of acid gases (e.g. PVC) through feed. | Requires closer control of waste management | | All plant with heterogeneous waste feed |

| Acid gases and halogens : Secondary Measures (BAT is to apply Primary Measures first) | | | | |
|--|---------------------|-----------------------------|---------------------|---|
| Technique | Advantages | Disadvantages | Optimisation | Defined as BAT in BREF or TGN for: |
| Wet | High reaction rates | Large effluent disposal and | | Used for wide range of |

| | | | | |
|--|--|--|--|---|
| | <p>Low solid residues production</p> <p>Reagent delivery may be optimised by concentration and flow rate</p> | <p>water consumption if not fully treated for recycle</p> <p>Effluent treatment plant required</p> <p>May result in wet plume</p> <p>Energy required for effluent treatment and plume reheat</p> | | <p>waste types</p> <p>Can be used as polishing step after other techniques where emissions are high or variable</p> |
| Dry | <p>Low water use</p> <p>Higher reagent consumption to achieve emissions of other FGC techniques but may be reduced by recycling in plant</p> <p>Lower energy use</p> <p>Higher reliability</p> <p>Lowest visible plume potential</p> | <p>Higher solid residue production</p> <p>Reagent consumption controlled only by input rate</p> | | All plant |
| Semi-dry (also described as semi-wet in the Bref) | <p>Medium reaction rates</p> <p>Reagent delivery may be varied by</p> | <p>Higher solid waste residues than wet but lower than dry system</p> | | All plant |

| | | | | |
|---------------------------------------|--|--|--------------------|--|
| | concentration and input rate | | | |
| Direct injection into boiler | Reduced acid loading to subsequent cleaning stages. Reduced peak emissions and reduced reagent usage | | | Generally applicable to grate and rotary kiln plants. |
| Direction desulphurisation | Reduced boiler corrosion | Does not improve overall performance. Can affect bottom ash quality. Corrosion problems in flue gas cleaning system. | | Partial abatement upstream of other techniques in fluidised beds |
| Reagent Type: Sodium Hydroxide | Highest removal rates Low solid waste production | Corrosive material ETP sludge for disposal | | HWIs |
| Reagent Type: Lime | Very good removal rates Low leaching solid residue Temperature of reaction well suited to use with bag filters | Corrosive material May give greater residue volume if no in-plant recycle | Wide range of uses | MWIs, CWIs |

| | | | | |
|---|---|--|---------------------------|------|
| Reagent Type: Sodium Bicarbonate | Good removal rates Easiest to handle Dry recycle systems proven | Efficient temperature range may be at upper end for use with bag filters Leachable solid residues Bicarbonate more expensive | Not proven at large plant | CWIs |
|---|---|--|---------------------------|------|

The Applicant proposes to implement the following primary measures:

- Use of low sulphur fuels for start up and auxiliary burners – gas should be used if available, where fuel oil is used, this will be low sulphur (i.e. <0.1%), this will reduce SO_x at source. The Applicant has justified its choice of natural gas and we agree with that assessment.
- Plant will burn RDF which is relatively homogeneous with further blending in the waste bunker, avoiding peak acid gas loads.

There are five recognised techniques for secondary measures to reduce acid gases, all of which can be BAT. These are wet, dry, semi-dry, boiler sorbent injection and direct desulphurisation. Wet scrubbing produces an effluent for treatment and disposal in compliance with Article 46(3) of IED. It will also require reheat of the exhaust to avoid a visible plume. Wet scrubbing is unlikely to be BAT except where there are high acid gas and metal components in the exhaust gas as may be the case for some hazardous waste incinerators. In this case, the Applicant does not propose using wet scrubbing, and we agree that wet scrubbing is not appropriate in this case. Direct desulphurisation is only applicable for fluidised bed furnaces.

Both dry and semi-dry methods rely on the dosing of powdered materials into the exhaust gas stream. Semi-dry systems (i.e. hydrated reagent) offer reduced material consumption through faster reaction rates, but reagent recycling in dry systems can offset this.

In both dry and semi-dry systems, the injected powdered reagent reacts with the acid gases and is removed from the gas stream by the bag filter system. The powdered materials are either lime or sodium bicarbonate. Both are effective at reducing acid gases, and dosing rates can be controlled from continuously monitoring acid gas emissions. The decision on which reagent to use is normally economic. Lime produces a lower leaching solid residue in the APC residues than sodium bicarbonate and the reaction temperature is well suited to bag filters, it tends to be lower cost, but it is a corrosive material and can generate a greater volume of solid waste residues than sodium

bicarbonate. Both reagents are BAT, and the use of one over the other is not significant in environmental terms in this case.

Direct boiler injection is not proposed. The Applicant's justification is that its primary use is upstream of other abatement when acid gas concentrations are high which will not be the case when incinerating RDF.

In this case, the Applicant proposes to use a dry system with hydrated lime. We are satisfied that this is BAT

6.2.4 Carbon monoxide and volatile organic compounds (VOCs)

The prevention and minimisation of emissions of carbon monoxide and volatile organic compounds is through the optimisation of combustion controls, where all measures will increase the oxidation of these species.

| Carbon monoxide and volatile organic compounds (VOCs) | | | | |
|--|--|----------------------|---|---|
| Technique | Advantages | Disadvantages | Optimisation | Defined as BAT in BREF or TGN for: |
| Optimise combustion control | All measures will increase oxidation of these species. | | Covered in section on furnace selection | All plants |

6.2.5 Dioxins and furans (and other POPs)

| Dioxins and furans | | | | |
|---|--|--|--|---|
| Technique | Advantages | Disadvantages | Optimisation | Defined as BAT in BREF or TGN for: |
| Optimise combustion control | All measures will increase oxidation of these species. | | Covered in section on furnace selection | All plants |
| Avoid <i>de novo</i> synthesis | | | Covered in boiler design | All plant |
| Effective Particulate matter removal | | | Covered in section on particulate matter | All plant |
| Activated Carbon injection | Can be combined with acid gas absorber or fed separately. Metallic | Combined feed rate usually controlled by acid gas content. | | All plant. Separate feed normally BAT unless feed is |

| | | | | |
|------------------------------|-----------------------------|---|--|---|
| | mercury is also absorbed. | | | constant and acid gas control also controls dioxin release. |
| Catalytic filter bags | High destruction efficiency | Does not remove mercury. Higher cost than non-catalytic filter bags | | |

The prevention and minimisation of emissions of dioxins and furans is achieved through:

- optimisation of combustion control including the maintenance of permit conditions on combustion temperature and residence time, which has been considered in 6.1.1 above;
- avoidance of de novo synthesis, which has been covered in the consideration of boiler design;
- the effective removal of particulate matter, which has been considered in 6.2.1 above;
- injection of activated carbon. This can be combined with the acid gas reagent or dosed separately. Where the feed is combined, the combined feed rate will be controlled by the acid gas concentration in the exhaust. Therefore, separate feed of activated carbon would normally be considered BAT unless the feed was relatively constant. Effective control of acid gas emissions also assists in the control of dioxin releases.

In this case the Applicant proposes separate feed and we are satisfied their proposals are BAT.

6.2.6 Metals

| Metals | | | | |
|--|---|--|--|---|
| Technique | Advantages | Disadvantages | Optimisation | Defined as BAT in BREF or TGN for: |
| Effective Particulate matter removal | | | Covered in section on particulate matter | All plant |
| Activated Carbon injection for mercury recovery | Can be combined with acid gas absorber or fed separately. | Combined feed rate usually controlled by acid gas content. | | All plant. Separate feed normally BAT unless feed is constant and acid gas |
| | | Page 64 of 96 | Application Number EPR/RP3638SJ/A001 | |

| | | | | |
|---------------------------------------|--|---|--|--|
| | Can be impregnated with bromine or sulphur to enhance reactivity, for use during peak emissions. | | | control also controls dioxin release. |
| Fixed or moving bed adsorption | Mainly for mercury and other metals, as well as organic compounds | | | Limited applicability due to pressure drop |
| Boiler bromine injection | Injection during mercury peaks. Oxidation of mercury leading to improved removal in downstream removal method. | Consumption of aqueous bromine. Can lead to formation of polybrominated dioxins. Can damage bag filter. Effects can be limited to dealing with peak emissions | | Not suitable for pyrolysis or gasification. Can deal with mercury peaks. |

The prevention and minimisation of metal emissions is achieved through the effective removal of particulate matter, and this has been considered in 6.2.1 above.

Unlike other metals however, mercury if present will be in the vapour phase. BAT for mercury removal is one or a combination of the techniques listed above. The Applicant has proposed dosing of activated carbon into the exhaust gas stream. This can be combined with the acid gas reagent or dosed separately. Where the feed is combined, the combined feed rate will be controlled by the acid gas concentration in the exhaust. Therefore, separate feed of activated carbon would normally be considered BAT unless the feed was relatively constant.

In this case the Applicant proposes separate feed and we are satisfied their proposals are BAT.

6.3 BAT and global warming potential

This section summarises the assessment of greenhouse gas impacts which has been made in the determination of this Application. Emissions of carbon dioxide (CO₂) and other greenhouse gases differ from those of other pollutants in that,

except at gross levels, they have no localised environmental impact. Their impact is at a global level and in terms of climate change. Nonetheless, CO₂ is clearly a pollutant for IED purposes.

The principal greenhouse gas emitted is CO₂, but the plant also emits small amounts of N₂O arising from the operation of secondary NO_x abatement. N₂O has a global warming potential 310 times that of CO₂. The Applicant will therefore be required to optimise the performance of the secondary NO_x abatement system to ensure its GWP impact is minimised.

The major source of greenhouse gas emissions from the installation is however CO₂ from the combustion of waste. There will also be CO₂ emissions from the burning of support fuels at start up, shut down and should it be necessary to maintain combustion temperatures. BAT for greenhouse gas emissions is to maximise energy recovery and efficiency.

The electricity that is generated by the Installation will displace emissions of CO₂ elsewhere in the UK, as virgin fossil fuels will not be burnt to create the same electricity.

The Installation is not subject to the Greenhouse Gas Emissions Trading Scheme Regulations 2012 therefore it is a requirement of the IED to investigate how emissions of greenhouse gases emitted from the installation might be prevented or minimised.

Factors influencing GWP and CO₂ emissions from the Installation are:

On the debit side

- CO₂ emissions from the burning of the waste;
- CO₂ emissions from burning auxiliary or supplementary fuels;
- CO₂ emissions associated with electrical energy used;
- N₂O from the de-NO_x process.

On the credit side

- CO₂ saved from the export of electricity to the public supply by displacement of burning of virgin fuels;

The GWP of the plant will be dominated by the emissions of carbon dioxide that will be released as a result of waste combustion. This will be constant for all options considered in the BAT assessment. Any differences in the GWP of the options in the BAT appraisal will therefore arise from small differences in energy recovery and in the amount of N₂O emitted.

The Applicant considered energy efficiency and BAT for the de-NO_x process in its BAT assessment. SNCR is proposed which will mean higher energy recovery than if SCR was used due to SCR needing the flue gas to be reheated.

Note: avoidance of methane which would be formed if the waste was landfilled has not been included in this assessment. If it were included due to its avoidance it would be included on the credit side.

We are satisfied that the Application shows that the BAT options chose by the Applicant will maximise energy recovery and are therefore BAT in terms of GWP.

We agree with this assessment and that the chosen option is BAT for the installation.

6.4 BAT and POPs

International action on Persistent Organic pollutants (POPs) is required under the UN's Stockholm Convention, which entered into force in 2004. The EU implemented the Convention through the POPs Regulation (2019/1021), which is directly applicable in UK law. We are required by national POPs Regulations (SI 2007 No 3106) to give effect to Article 6(3) of the EC POPs Regulation when determining applications for environmental permits.

However, it needs to be borne in mind that this application is for a particular type of installation, namely a waste incinerator. The Stockholm Convention distinguishes between intentionally-produced and unintentionally-produced POPs. Intentionally-produced POPs are those used deliberately (mainly in the past) in agriculture (primarily as pesticides) and industry. Those intentionally-produced POPs are not relevant where waste incineration is concerned, as in fact high-temperature incineration is one of the prescribed methods for destroying POPs.

The unintentionally-produced POPs addressed by the Convention are:

- dioxins and furans;
- HCB (hexachlorobenzene)
- PCBs (polychlorobiphenyls) and
- PeCB (pentachlorobenzene)

The UK's national implementation plan for the Stockholm Convention, published in 2007, makes explicit that the relevant controls for unintentionally-produced POPs, such as might be produced by waste incineration, are delivered through the requirements of the IED. That would include an examination of BAT, including potential alternative techniques, with a view to preventing or minimising harmful emissions. These have been applied as explained in this document, which explicitly addresses alternative techniques and BAT for the minimisation of emissions of dioxins.

Our legal obligation, under regulation 4(b) of the POPs Regulations, is, when considering an application for an environmental permit, to comply with article 6(3) of the POPs Regulation:

“Member States shall, when considering proposals to construct new facilities or to significantly modify existing facilities using processes that release chemicals listed in Annex III, give priority consideration to alternative processes, techniques or practices that have similar usefulness but which avoid the formation and release of substances listed in Annex III, without prejudice to Directive 2010/75/EU of the European Parliament and of the Council”

The 1998 Protocol to the Convention recommended that unintentionally produced POPs should be controlled by imposing emission limits (e.g 0.1 ng/m³ for MWIs) and using BAT for incineration. UN Economic Commission for Europe (Executive Body for the Convention) (ECE-EB) produced BAT guidance for the parties to the Convention in 2009. This document considers various control techniques and concludes that primary measures involving management of feed material by reducing halogenated substances are not technically effective. This is not surprising because halogenated wastes still need to be disposed of and because POPs can be generated from relatively low concentrations of halogens. In summary, the successful control techniques for waste incinerators listed in the ECE-EB BAT are:

- maintaining furnace temperature of 850°C and a combustion gas residence time of at least 2 seconds
- rapid cooling of flue gases to avoid the *de novo* reformation temperature range of 250-450°C
- use of bag filters and the injection of activated carbon or coke to adsorb residual POPs components.

Using the methods listed above, the UN-ECE BAT document concludes that incinerators can achieve an emission concentration of 0.1 ng TEQ/m³.

We believe that the Permit ensures that the formation and release of POPs will be prevented or minimised. As we explain above, high-temperature incineration is one of the prescribed methods for destroying POPs. Permit conditions are based on the use of BAT and Chapter IV of the IED and incorporate all the above requirements of the UN-ECE BAT guidance and deliver the requirements of the Stockholm Convention in relation to unintentionally produced POPs.

The release of **dioxins and furans** to air is required by the IED to be assessed against the International Toxic Equivalence (I-TEQ) limit of 0.1 ng/m³. Further development of the understanding of the harm caused by dioxins has resulted in the World Health Organisation (WHO) producing updated factors to calculate the WHO-TEQ value. Certain **PCBs** have structures which make them behave like dioxins (dioxin-like PCBs), and these also have toxic equivalence factors defined by the WHO to make them capable of being considered together with dioxins. The UK's independent health advisory committee, the Committee on Toxicity of Chemicals in Food, Consumer Products and the Environment (COT) has adopted WHO-TEQ values for both dioxins and dioxin-like PCBs in their review of Tolerable Daily Intake (TDI) criteria. The Permit requires that, in addition to the requirements of the IED, the WHO-TEQ values for both dioxins and dioxin-like PCBs should be monitored for reporting purposes, to enable

evaluation of exposure to dioxins and dioxin-like PCBs to be made using the revised TDI recommended by the COT. The release of dioxin-like PCBs and PAHs is expected to be low where measures have been taken to control dioxin releases. The Permit also requires monitoring of a range of PAHs and dioxin-like PCBs at the same frequency as dioxins are monitored. We have included a requirement to monitor and report against these WHO-TEQ values for dioxins and dioxin-like PCBs and the range of PAHs as listed in the Permit. We are confident that the measures taken to control the release of dioxins will also control the releases of dioxin-like PCBs and PAHs. Section 5.2.1 of this document details the assessment of emissions to air, which includes dioxins and concludes that there will be no adverse effect on human health from either normal or abnormal operation.

Hexachlorobenzene (HCB) is released into the atmosphere as an accidental product from the combustion of coal, waste incineration and certain metal processes. It has also been used as a fungicide, especially for seed treatment although this use has been banned in the UK since 1975. Natural fires and volcanoes may serve as natural sources. Releases of (HCB) are addressed by the European Environment Agency (EEA), which advises that:

"due to comparatively low levels in emissions from most (combustion) processes special measures for HCB control are usually not proposed. HCB emissions can be controlled generally like other chlorinated organic compounds in emissions, for instance dioxins/furans and PCBs: regulation of time of combustion, combustion temperature, temperature in cleaning devices, sorbents application for waste gases cleaning etc." [reference http://www.eea.europa.eu/publications/EMEPCORINAIR4/sources_of_HCB.pdf]

Pentachlorobenzene (PeCB) is another of the POPs list to be considered under incineration. PeCB has been used as a fungicide or flame retardant, there is no data available however on production, recent or past, outside the UN-ECE region. PeCBs can be emitted from the same sources as for PCDD/F: waste incineration, thermal metallurgic processes and combustion plants providing energy. As discussed above, the control techniques described in the UN-ECE BAT guidance and included in the permit, are effective in controlling the emissions of all relevant POPs including PeCB.

We have assessed the control techniques proposed for dioxins by the Applicant and have concluded that they are appropriate for dioxin control. We are confident that these controls are in line with the UN-ECE BAT guidance and will minimise the release of HCB, PCB and PeCB.

We are therefore satisfied that the substantive requirements of the Convention and the POPs Regulation have been addressed and complied with.

6.5 Other Emissions to the Environment

6.5.1 Emissions to water

There will be an emission to North Beck drain of:

- Uncontaminated rainwater run-off
- Wash water from air cooled condenser tube cleaning
- Treated water from offices

Water from offices does not form part of the Installation.

The external surfaces of the ACC condenser tubes are periodically sprayed with demineralised water to remove any atmospheric dust and other debris that has been deposited by the cooling air flowing through the radiators. The excess water discharges directly to the surface water system.

Uncontaminated surface water will consist of drainage from the following areas:

- Roofs and gravelled/clean process areas
- Roadways with trapped gully drains and detention lagoons.
- Yard areas outside waste receipt building and raw material receipt areas via an interceptor and detention lagoon. Raw material areas will be isolated during loading/unloading activities.

Based upon the information in the Application we are satisfied that appropriate measures will be in place to prevent and /or minimise emissions to water.

6.5.2 Emissions to sewer

There are no emissions to sewer from the Installation.

6.5.3 Fugitive emissions

The IED specifies that plants must be able to demonstrate that the plant is designed in such a way as to prevent the unauthorised and accidental release of polluting substances into soil, surface water and groundwater. In addition storage requirements for waste and for contaminated water under Article 46(5) of the IED must be arranged.

RDF will be delivered and stored prior to incineration in the reception building which will be maintained under negative pressure.

Bottom ash will be stored in a bunker and will be damp to prevent dust emissions. It will be removed from site using covered vehicles, storage and unloading will be in an enclosed building.

APC residues and fly ash will be stored in a silos fitted with a filter to prevent fugitive emissions. It will be discharged to a tanker for removal from site, the tanker will vent back to the silo.

All waste and other materials will be stored inside the buildings or in sealed silos. Bunding will be provided for all tanks and containers to provide secondary containment for all liquids. Storage areas will have concrete surfacing allowing any spillage to be contained and cleaned up, preventing emissions to groundwater.

Based upon the information in the Application we are satisfied that appropriate measures will be in place to prevent and /or minimise fugitive emissions.

6.5.4 Odour

Based upon the information in the Application we are satisfied that the appropriate measures will be in place to prevent or where that is not practicable to minimise odour and to prevent pollution from odour.

Waste accepted at the installation will be delivered in containers and bulk storage of waste will only occur in the installation's waste bunker. An automatic closing and opening door will be used to close the entrance to the tipping hall outside of the waste delivery periods and combustion air will be drawn from above the waste storage bunker in order to prevent odours and airborne particulates from leaving the facility building.

RDF inventory and deliveries will be rundown prior to complete shutdown to ensure no waste storage. RDF deliveries will be stopped/diverted during shutdown. The use of 2 lines means that a single line can be shutdown for maintenance and the other continue to operate maintaining the sub atmospheric pressure in the hall. In the event of unexpected complete shutdown, RDF will be returned to suppliers or alternative licenced treatment facilities. Applicant stated that alternative extraction during shut-down would not be required but could be fitted in the event that issue did occur.

6.5.5 Noise and vibration

The Applicant proposed the following key measures to minimise noise emissions and impacts:

- ID fans will be installed within enclosures.
- Large fans will be installed on anti vibration mounting
- The air cooled condenser will have sound baffles on all 4 sides.
- Materials handling systems located inside buildings
- The vast majority of vehicle movements are along the roadway on the northern side of the site meaning that the process buildings will act as barriers
- No HGV movements to/from the installation during night hours.
- Process alarms located within the control room ensuring prompt response from operational staff and preventing them being heard off-site. Any additional alarm installed locally to process equipment will also be silenced when the alarm in the control room is silenced. These alarms are also located within the process buildings or on the northern side of the installation.

Based upon the information in the Application we are satisfied that the appropriate measures will be in place to prevent or where that is not practicable to minimise noise and vibration and to prevent pollution from noise and vibration outside the site.

The Application contained a noise impact assessment which identified local noise-sensitive receptors, potential sources of noise at the proposed plant and noise attenuation measures. Measurements were taken of the prevailing ambient noise levels to produce a baseline noise survey and an assessment was carried out in accordance with BS 4142:2014 to compare the predicted plant rating noise levels with the established background levels.

We audited the noise assessment. We found low noise impacts, but this was dependent upon an extensive acoustic mitigation scheme, including buildings constructed of components with a high sound reduction index. The Applicant stated that detailed design has not yet been carried out. As a result a number of sources and transmission paths have not been assessed due to the uncertainty around the detailed site layout and plant selection at this stage. Although we agree that the risk is low, we have set a pre-operational condition (PO9) to request an updated Noise Impact Assessment (NIA) and Noise Management Plan (NMP) following completion of detailed design stage to verify that acceptable noise impacts can be achieved in line with confirmed proposals for plant layout, plant selection and the acoustic mitigation scheme.

6.6 Setting ELVs and other Permit conditions

6.6.1 Translating BAT into Permit conditions

Article 14(3) of the IED states that BAT-C shall be the reference for permit conditions. Article 15(3) further requires that under normal operating conditions; emissions do not exceed the emission levels associated with the BAT as laid down in the decisions on BAT-C.

BAT-C for waste incineration or co-incineration were published on 03/12/2019

The use of BAT AELs and IED Chapter IV emission limits for air dispersion modelling sets the worst case scenario. If this shows emissions are insignificant then we have accepted that the Applicant's proposals are BAT, and that there is no justification to reduce ELVs below the BAT AELs and Chapter IV limits.

Below we consider whether, for those emissions not screened out as insignificant, different conditions are required as a result of consideration of local or other factors, so that no significant pollution is caused (Article 11(c)) or to comply with environmental quality standards (EQS) (Article 18).

(i) Local factors

We have considered the location in assessing BAT. However no measures beyond BAT were required. We are satisfied that the measures described above as BAT will ensure a high level of protection for the environment as a whole at this location.

(ii) National and European ESs

We are satisfied that the Installation will not result in an exceedance of any National or European ES.

(iii) Global Warming

CO₂ is an inevitable product of the combustion of waste. The amount of CO₂ emitted will be essentially determined by the quantity and characteristics of waste being incinerated, which are already subject to conditions in the Permit. It is therefore inappropriate to set an ELV for CO₂, which could do no more than recognise what is going to be emitted. The gas is not therefore targeted as a key pollutant under Annex II of the IED, which lists the main polluting substances that are to be considered when setting ELVs in permits.

We have therefore considered setting equivalent parameters or technical measures for CO₂. However, provided energy is recovered efficiently (see section 4.3.7 above), there are no additional equivalent technical measures (beyond those relating to the quantity and characteristics of the waste) that can be imposed that do not run counter to the primary purpose of the plant, which is the destruction of waste. Controls in the form of restrictions on the volume and type of waste that can be accepted at the Installation and Permit conditions relating to energy efficiency effectively apply equivalent technical measures to limit CO₂ emissions.

(iv) Commissioning

We have set pre-operational condition PO3 for the operator to submit a commissioning plan to the Environment Agency for approval.

6.7 Monitoring

6.7.1 Monitoring during normal operations

We have decided that monitoring should be carried out for the parameters listed in Schedule 3 using the methods and to the frequencies specified in those tables. These monitoring requirements have been imposed in order to demonstrate compliance with ELVs and to enable correction of measured concentration of substances to the appropriate reference conditions; to gather information about the performance of the SNCR system; to establish data on the release of dioxin-like PCBs and PAHs from the incineration process and to deliver the requirements of Chapter IV of the IED for monitoring of residues and temperature in the combustion chamber.

For emissions to air, the methods for continuous and periodic monitoring are in accordance with our guidance for monitoring of stack emissions to air.

Based on the information in the Application and the requirements set in the conditions of the Permit we are satisfied that the Operator's techniques, personnel and equipment will have either MCERTS certification or MCERTS accreditation as appropriate.

6.7.2 Monitoring under abnormal operations arising from the failure of the installed CEMs

The Operator has stated that they will provide back-up CEMS working in parallel to the operating CEMS. The back-up CEMS measure the same parameters as the operating CEMS. In the unlikely event that the back-up CEMS also fail Condition 2.3.9 of the permit requires that the abnormal operating conditions apply.

6.7.3 Continuous emissions monitoring for dioxins and heavy metals

The BAT-C specify either manual extractive monitoring or long term monitoring for dioxins. For mercury either continuous or long term monitoring is specified, manual extractive monitoring is specified for other metals.

For dioxins long term monitoring does not apply if emissions are stable, and for mercury long term monitoring can be used instead of continuous if the mercury content of the waste is low and stable.

Based on the waste types and control measures proposed in the Application we expect that emissions of dioxins will be stable and that the mercury content of the waste will be low and stable. We have therefore set manual extractive monitoring in the Permit. However, the Permit requires the stable and low criteria to be demonstrated through Improvement conditions IC09 and 10 and we can require long term monitoring for dioxins and continuous monitoring for mercury if required.

6.8 Reporting

We have specified the reporting requirements in Schedule 5 of the Permit either to meet the reporting requirements set out in the IED, or to ensure data is reported to enable timely review by us to ensure compliance with the Permit conditions and to monitor the efficiency of material use and energy recovery at the installation.

7 Other legal requirements

In this section we explain how we have addressed other relevant legal requirements, to the extent that we have not addressed them elsewhere in this document.

7.1 The EPR 2016 and related Directives

The EPR delivers the requirements of a number of European and national laws.

7.1.1 Schedules 1 and 7 to the EPR 2016 – IED Directive

We address the requirements of the IED in the body of this document above and the specific requirements of Chapter IV in Annex 1 of this document.

There is one requirement not addressed above, which is that contained in Article 5(3) IED. Article 5(3) requires that “In the case of a new installation or a substantial change where Article 4 of Directive 85/337/EC (now Directive 2011/92/EU) (the EIA Directive) applies, any relevant information obtained or conclusion arrived at pursuant to articles 5, 6 and 7 of that Directive shall be examined and used for the purposes of granting the permit.”

- Article 5 of EIA Directive relates to the obligation on developers to supply the information set out in Annex IV of the Directive when making an application for development consent.
- Article 6(1) requires Member States to ensure that the authorities likely to be concerned by a development by reason of their specific environmental responsibilities are consulted on the Environmental Statement and the request for development consent.
- Article 6(2)-6(6) makes provision for public consultation on applications for development consent.
- Article 7 relates to projects with transboundary effects and consequential obligations to consult with affected Member States.

The grant or refusal of development consent is a matter for the relevant local planning authority. The Environment Agency’s obligation is therefore to examine and use any relevant information obtained or conclusion arrived at by the local planning authorities pursuant to those EIA Directive articles.

In determining the Application we have considered the following documents: -

- The Environmental Statement submitted with the planning application (which also formed part of the Environmental Permit Application).
- The decision of North East Lincolnshire Council to grant planning permission on 20/12/2018.
- The report and decision notice of the local planning authority accompanying the grant of planning permission.
- The response of the Environment Agency to the local planning authority in its role as consultee to the planning process.

From consideration of all the documents above, the Environment Agency considers that no additional or different conditions are necessary.

The Environment Agency has also carried out its own consultation on the Environmental Permitting Application which includes the Environmental Statement submitted to the local planning authority. The results of our consultation are described elsewhere in this decision document.

7.1.2 Schedule 9 to the EPR 2016 – Waste Framework Directive

As the Installation involves the treatment of waste, it is carrying out a *waste operation* for the purposes of the EPR 2016, and the requirements of Schedule 9 therefore apply. This means that we must exercise our functions so as to ensure implementation of certain articles of the WFD.

We must exercise our relevant functions for the purposes of ensuring that the waste hierarchy referred to in Article 4 of the Waste Framework Directive is applied to the generation of waste and that any waste generated is treated in accordance with Article 4 of the Waste Framework Directive. (See also section 4.3.9)

The conditions of the permit ensure that waste generation from the facility is minimised. Where the production of waste cannot be prevented it will be recovered wherever possible or otherwise disposed of in a manner that minimises its impact on the environment. This is in accordance with Article 4.

We must also exercise our relevant functions for the purposes of implementing Article 13 of the Waste Framework Directive; ensuring that the requirements in the second paragraph of Article 23(1) of the Waste Framework Directive are met; and ensuring compliance with Articles 18(2)(b), 18(2)(c), 23(3), 23(4) and 35(1) of the Waste Framework Directive.

Article 13 relates to the protection of human health and the environment. These objectives are addressed elsewhere in this document.

Article 23(1) requires the permit to specify:

- (a) the types and quantities of waste that may be treated;
- (b) for each type of operation permitted, the technical and any other requirements relevant to the site concerned;
- (c) the safety and precautionary measures to be taken;
- (d) the method to be used for each type of operation;
- (e) such monitoring and control operations as may be necessary;
- (f) such closure and after-care provisions as may be necessary.

These are all covered by permit conditions.

The permit does not allow the mixing of hazardous waste so Article 18(2) is not relevant.

We consider that the intended method of waste treatment is acceptable from the point of view of environmental protection so Article 23(3) does not apply.

Energy efficiency is dealt with elsewhere in this document but we consider the conditions of the permit ensure that the recovery of energy take place with a high level of energy efficiency in accordance with Article 23(4).

Article 35(1) relates to record keeping and its requirements are delivered through permit conditions.

7.1.3 Schedule 22 to the EPR 2016 – Water Framework and Groundwater Directives

To the extent that it might lead to a discharge of pollutants to groundwater (a “groundwater activity” under the EPR 2016), the Permit is subject to the requirements of Schedule 22, which delivers the requirements of EU Directives relating to pollution of groundwater. The Permit will require the taking of all necessary measures to prevent the input of any hazardous substances to groundwater, and to limit the input of non-hazardous pollutants into groundwater so as to ensure such pollutants do not cause pollution, and satisfies the requirements of Schedule 22.

No releases to groundwater from the Installation are permitted. The Permit also requires material storage areas to be designed and maintained to a high standard to prevent accidental releases.

7.1.4 Directive 2003/35/EC – The Public Participation Directive

Regulation 60 of the EPR 2016 requires the Environment Agency to prepare and publish a statement of its policies for complying with its public participation duties. We have published our public participation statement.

This Application has been consulted upon in line with this statement, as well as with our guidance RGS6 on Sites of High Public Interest, which addresses specifically extended consultation arrangements for determinations where public interest is particularly high. This satisfies the requirements of the Public Participation Directive.

Our decision in this case has been reached following a programme of public consultation. The way in which this has been done is set out in Section 2. A summary of the responses received to our consultations and our consideration of them is set out in Annex 2.

7.2 National primary legislation

7.2.1 Environment Act 1995

(i) Section 4 (Pursuit of Sustainable Development)

We are required to contribute towards achieving sustainable development, as considered appropriate by Ministers and set out in guidance issued to us. The Secretary of State for Environment, Food and Rural Affairs has issued *The Environment Agency's Objectives and Contribution to Sustainable Development: Statutory Guidance (December 2002)*. This document:

"provides guidance to the Agency on such matters as the formulation of approaches that the Agency should take to its work, decisions about priorities for the Agency and the allocation of resources. It is not directly applicable to individual regulatory decisions of the Agency".

In respect of regulation of industrial pollution through the EPR, the Guidance refers in particular to the objective of setting permit conditions *"in a consistent and proportionate fashion based on Best Available Techniques and taking into account all relevant matters..."*. The Environment Agency considers that it has pursued the objectives set out in the Government's guidance, where relevant, and that there are no additional conditions that should be included in this Permit to take account of the Section 4 duty.

(ii) Section 5 (Preventing or Minimising Effects of Pollution of the Environment)

We are satisfied that our pollution control powers have been exercised for the purpose of preventing or minimising, remedying or mitigating the effects of pollution.

(iii) Section 6(1) (Conservation Duties with Regard to Water)

We have a duty to the extent we consider it desirable generally to promote the conservation and enhancement of the natural beauty and amenity of inland and coastal waters and the land associated with such waters, and the conservation of flora and fauna which are dependent on an aquatic environment.

We consider that no additional or different conditions are appropriate for this Permit.

(iv) Section 6(6) (Fisheries)

We have a duty to maintain, improve and develop fisheries of salmon, trout, eels, lampreys, smelt and freshwater fish.

We consider that no additional or different conditions are appropriate for this Permit.

(v) Section 7 (General Environmental Duties)

| | | |
|--|---------------|---|
| | Page 78 of 96 | Application Number EPR/RP3638SJ/A001 |
|--|---------------|---|

This places a duty on us, when considering any proposal relating to our functions, to have regard amongst other things to any effect which the proposals would have on sites of archaeological, architectural, or historic interest; the economic and social well-being of local communities in rural areas; and to take into account any effect which the proposals would have on the beauty or amenity of any rural or urban area or on any such flora, fauna, features, buildings, sites or objects.

We considered whether we should impose any additional or different requirements in terms of our duty to have regard to the various conservation objectives set out in Section 7, but concluded that we should not.

(vi) Section 39 (Costs and Benefits)

We have a duty to take into account the likely costs and benefits of our decisions on the applications ('costs' being defined as including costs to the environment as well as any person). This duty, however, does not affect our obligation to discharge any duties imposed upon us in other legislative provisions.

In so far as relevant we consider that the costs that the permit may impose on the applicant are reasonable and proportionate in terms of the benefits it provides.

(viii) Section 81 (National Air Quality Strategy)

We have had regard to the National Air Quality Strategy and consider that our decision complies with the Strategy, and that no additional or different conditions are appropriate for this Permit.

We have also had regard to the clean air strategy 2019 and consider that our decision complies with the Strategy, and that no additional or different conditions are appropriate for this Permit.

We have had regard to the National Air Pollution Control Programme (set under the National Emissions Ceiling Regulations 2018) and consider that our decision complies with the Strategy, and that no additional or different conditions are appropriate for this Permit.

7.2.2 Section 108 Deregulation Act 2015 – Growth duty

We considered our duty to have regard to the desirability of promoting economic growth set out in section 108(1) of the Deregulation Act 2015 and

the guidance issued under section 110 of that Act in deciding whether to grant this permit.

Paragraph 1.3 of the statutory guidance issued by the Department of Business, Energy and Industrial Strategy in March 2017 says:

“The primary role of regulators, in delivering regulation, is to achieve the regulatory outcomes for which they are responsible. For a number of regulators, these regulatory outcomes include an explicit reference to development or growth. The growth duty establishes economic growth as a factor that all specified regulators should have regard to, alongside the delivery of the protections set out in the relevant legislation.”

We have addressed the legislative requirements and environmental standards to be set for this operation in the body of the decision document above. The guidance is clear at paragraph 1.5 that the growth duty does not legitimise non-compliance and its purpose is not to achieve or pursue economic growth at the expense of necessary protections.

We consider the requirements and standards we have set in this permit are reasonable and necessary to avoid a risk of an unacceptable level of pollution. This promotes growth amongst legitimate operators because the standards applied to the operator are consistent across businesses in this sector and have been set to achieve the required legislative standards. It also ensures that any pollution that may arise from the regulated facility does not adversely affect local businesses.

7.2.3 Legislative and Regulatory Reform Act 2006

In accordance with section 21 of this Act, when making this decision we have had regard to the need to be transparent, accountable, proportionate and consistent, and the need to target action where it is needed.

In accordance with section 22 of the Act we have had regard to the Regulators’ Code; in particular the need to base our decision on environmental risk, and to support the applicant to comply and grow, so that burdens have only been imposed where they are necessary and proportionate.

7.2.4 Human Rights Act 1998

We have considered potential interference with rights addressed by the European Convention on Human Rights in reaching our decision and consider that our decision is compatible with our duties under the Human Rights Act 1998. In particular, we have considered the right to life (Article 2), the right to a fair trial (Article 6), the right to respect for private and family life (Article 8) and the right to protection of property (Article 1, First Protocol). We do not believe that Convention rights are engaged in relation to this determination.

7.2.5 Countryside and Rights of Way Act 2000 (CROW 2000)

Section 85 of this Act imposes a duty on Environment Agency to have regard to the purpose of conserving and enhancing the natural beauty of the area of outstanding natural beauty (AONB). There is no AONB which could be affected by the Installation.

7.2.6 Wildlife and Countryside Act 1981

Under section 28G of the Wildlife and Countryside Act 1981 the Environment Agency has a duty to take reasonable steps to further the conservation and enhancement of the flora, fauna or geological or physiographical features by reason of which a site is of special scientific interest. Under section 28I the Environment Agency has a duty to consult Natural England in relation to any permit that is likely to damage SSSIs.

We assessed the Application and concluded that the Installation will not damage the special features of any SSSI. This was recorded on a CROW Appendix 4 form,

The Wildlife and Countryside Act (CRoW) assessment is summarised in greater detail in section 5.4 of this document. A copy of the full Appendix 4 Assessment can be found on the public register.

7.2.7 Natural Environment and Rural Communities Act 2006

Section 40 of the Natural Environment and Rural Communities Act 2006 has been amended with effect from 1 January 2023 to require consideration as to what action we can properly take, consistently with the proper exercise of our functions, to further the general biodiversity objective, which is to further the conservation and enhancement of biodiversity and having considered, determined such policies and specific objectives as we consider appropriate for taking action to further the general biodiversity objective, and take such action as we consider appropriate, in the light of those policies and objectives, to further that objective.

Section 40(2A) states that in complying with the duty in section 40(1) and (1A) we must have particular regard to any relevant local nature recovery strategy and species protection strategy or protected sites strategy

We have, also, considered the general biodiversity objective when carrying out our permit application determination and, consider that no different or additional conditions are required in the permit.

7.2.8 Countryside Act 1968

Section 11 imposes a duty on the Environment Agency to exercise its functions relating to any land, having regard to the desirability of conserving the natural

beauty and amenity of the countryside including wildlife. We have done so and consider that no different or additional conditions in the Permit are required.

7.2.9 National Parks and Access to the Countryside Act 1949

Section 11A and section 5(1) imposes a duty on the Environment Agency when exercising its functions in relation to land in a National Park, to have regard to the purposes of conserving and enhancing the natural beauty, wildlife and cultural heritage of the areas, and of promoting opportunities for the understanding and enjoyment of National Parks by the public.

We have done so and consider that no different or additional conditions in the Permit are required/ There is no National Park which could be affected by the Installation.

7.2.10 Environment Act 2021

Section 110(10) requires that we must have regard to a protected sites strategy, which Natural England has prepared and published in relation to improving the conservation and management of a protected site, and managing the impact of plans, projects or other activities (wherever undertaken) on the conservation and management of the protected site, where relevant to exercise of our duties under Conservation of Habitats and Species Regulations 2017, sections 28G to 28I Wildlife and Countryside Act 1981 or Marine and Coastal Access Act 2009.

We have had regard to this in our assessments.

7.3 National secondary legislation

7.3.1 Conservation of Habitats and Species Regulations 2017

We consulted Natural England on the appropriate assessment, and they agreed with our conclusion, that the operation of the Installation would not have adverse effects on the interest features of European sites.

The Habitats Regulations Assessment is summarised in greater detail in section 5.4 of this document. A copy of the Habitats Regulations Assessment can be found on the public register.

We have also considered our general duties under Regulation 9(3) to have regard to the requirements of the Habitats Directive in the exercise of our powers and under Regulation 10 in relation to wild bird habitat to take such steps in the exercise of their functions as they consider appropriate so far as lies within our powers to secure preservation, maintenance and re-establishment of a sufficient diversity and area of habitat for wild birds.

We considered whether we should impose any additional or different requirements in the permit in terms of these duties but concluded that we should not.

7.3.2 Water Environment (Water Framework Directive) Regulations 2017

Consideration has been given to whether any additional requirements should be imposed in terms of the Environment Agency's duty under regulation 3 to secure compliance with the requirements of the Water Framework Directive, Groundwater Directive and the EQS Directive through, amongst other things, environmental permits, and its obligation in regulation 33 to have regard to the river basin management plan (RBMP) approved under regulation 31 and any supplementary plans prepared under regulation 32. However, it is felt that existing conditions are sufficient in this regard and no other appropriate requirements have been identified.

We are satisfied that granting this application with the conditions proposed would not cause the current status of the water body to deteriorate.

7.3.3 The Persistent Organic Pollutants Regulations 2007

We have explained our approach to these Regulations, which give effect to the Stockholm Convention on POPs and the EU's POPs Regulation, above.

7.3.4 Bathing Water Regulations 2013

We have considered our duty, under regulation 5 of these Regulations, to exercise our relevant functions to ensure compliance with the Bathing Water Directive, and in particular to take realistic and proportionate measures with a view to increasing the number of bathing waters classified as "good" or "excellent".

We consider that no additional or different conditions are appropriate for this Permit.

7.3.5 Marine Strategy Regulations 2010

In relation to Regulation 9 of the Marine Strategy Regulations 2010 we have had regard to the marine strategy (in so far as it has been developed and published to date) and consider that there is nothing in it which would lead us to any different conclusions from those we have already reached through our other marine assessments.

7.4 Other relevant legal requirements

7.4.1 Duty to Involve

| | | |
|--|---------------|---|
| | Page 83 of 96 | Application Number EPR/RP3638SJ/A001 |
|--|---------------|---|

Section 23 of the Local Democracy, Economic Development and Construction Act 2009 require us where we consider it appropriate to take such steps as we consider appropriate to secure the involvement of interested persons in the exercise of our functions by providing them with information, consulting them or involving them in any other way. Section 24 requires us to have regard to any Secretary of State guidance as to how we should do that.

The way in which the Environment Agency has consulted with the public and other interested parties is set out in section 2 of this document. The way in which we have taken account of the representations we have received is set out in Annex 4. Our public consultation duties are also set out in the EP Regulations, and our statutory Public Participation Statement, which implement the requirements of the Public Participation Directive. In addition to meeting our consultation responsibilities, we have also taken account of our guidance in Environment Agency Guidance Note RGS6.

Annexes

Annex 1A: Application of chapter IV of the Industrial Emissions Directive

| IED Article | Requirement | Delivered by |
|--------------------|---|---|
| 45(1)(a) | The permit shall include a list of all types of waste which may be treated using at least the types of waste set out in the European Waste List established by Decision 2000/532/EC, if possible, and containing information on the quantity of each type of waste, where appropriate. | Condition 2.3.4(a) and Table S2.2 in Schedule 2 of the Permit. |
| 45(1)(b) | The permit shall include the total waste incinerating or co-incinerating capacity of the plant. | Condition 2.3.4(a) and Table S2.2 in Schedule 2 of the Permit. |
| 45(1)(c) | The permit shall include the limit values for emissions into air and water. | Conditions 3.1.1 and 3.1.2 and Tables S3.1, S3.1(a) in Schedule 3 of the Permit. |
| 45(1)(d) | The permit shall include the requirements for pH, temperature and flow of waste water discharges. | Not Applicable |
| 45(1)(e) | The permit shall include the sampling and measurement procedures and frequencies to be used to comply with the conditions set for emissions monitoring. | Conditions 3.6.1 to 3.6.4 and Tables S3.1, S3.1(a), S3.3 in Schedule 3 of the Permit. |
| 45(1)(f) | The permit shall include the maximum permissible period of unavoidable stoppages, disturbances or failures of the purification devices or the measurement devices, during which the emissions into the air and the discharges of waste water may exceed the prescribed emission limit values. | Conditions 2.3.12 and 2.3.13. |
| 45(2)(a) | The permit shall include a list of the quantities of the different categories of hazardous waste which may be treated. | Not Applicable |

| IED Article | Requirement | Delivered by |
|--------------------|---|---|
| 45(2)(b) | The permit shall include the minimum and maximum mass flows of those hazardous waste, their lowest and maximum calorific values and the maximum contents of polychlorinated biphenyls, pentachlorophenol, chlorine, fluorine, sulphur, heavy metals and other polluting substances. | Not Applicable |
| 46(1) | Waste gases shall be discharged in a controlled way by means of a stack the height of which is calculated in such a way as to safeguard human health and the environment. | Condition 2.3.1(a) and Table S1.2 of Schedule 1 of the Permit. |
| 46(2) | Emission into air shall not exceed the emission limit values set out in part 3 of Annex VI. | Conditions 3.1.1 and 3.1.2 and Tables S3.1, S3.1a. |
| 46(3) | Relates to conditions for water discharges from the cleaning of exhaust gases. | There are no such discharges as condition 3.1.1 prohibits this. |
| 46(4) | Relates to conditions for water discharges from the cleaning of exhaust gases. | There are no such discharges as condition 3.1.1 prohibits this. |
| 46(5) | Prevention of unauthorised and accidental release of any polluting substances into soil, surface water or groundwater. Adequate storage capacity for contaminated rainwater run-off from the site or for contaminated water from spillage or fire-fighting. | The application explains the measures to be in place for achieving the directive requirements. The permit requires that these measures are used. Various permit conditions address this and when taken as a whole they ensure compliance with this requirement. |
| 46(6) | Limits the maximum period of operation when an ELV is exceeded to 4 hours uninterrupted duration in any one instance, and with a maximum cumulative limit of 60 hours per year. | Conditions 2.3.12 and 2.3.13 |

| IED Article | Requirement | Delivered by |
|-------------|---|--|
| | Limits on dust (150 mg/m ³), CO and TOC not to be exceeded during this period. | |
| 47 | In the event of breakdown, reduce or close down operations as soon as practicable. Limits on dust (150 mg/m ³), CO and TOC not to be exceeded during this period. | Condition 2.3.11 |
| 48(1) | Monitoring of emissions is carried out in accordance with Parts 6 and 7 of Annex VI. | Conditions 3.6.1 to 3.6.4, 3.2.1, 3.2.2, tables S3.1, S3.1(a). Reference conditions are defined in Schedule 6 of the Permit. |
| 48(2) | Installation and functioning of the automated measurement systems shall be subject to control and to annual surveillance tests as set out in point 1 of Part 6 of Annex VI. | Conditions 3.6.1, 3.6.3, table S3.1, S3.1(a), and S3.4 |
| 48(3) | The competent authority shall determine the location of sampling or measurement points to be used for monitoring of emissions. | Conditions 3.6.1. Pre-operational condition PO7 |
| 48(4) | All monitoring results shall be recorded, processed and presented in such a way as to enable the competent authority to verify compliance with the operating conditions and emission limit values which are included in the permit. | Conditions 4.1.1 and 4.1.2, and Tables S4.1 and S4.4 |
| 49 | The emission limit values for air and water shall be regarded as being complied with if the conditions described in Part 8 of Annex VI are fulfilled. | Conditions 3.1.1, 3.1.2, 3.2.1, 3.2.2 and tables S3.1, S3.1(a) |
| 50(1) | Slag and bottom ash to have Total Organic Carbon (TOC) < 3% or loss on ignition (LOI) < 5%. | Conditions 3.6.1 and Table S3.4 |
| 50(2) | Flue gas to be raised to a temperature of 850°C for two seconds, as measured at representative point of the combustion chamber. | Condition 2.3.9, Pre-operational condition PO5 and Improvement condition IC4 and Table S3.3 |
| | Page 87 of 96 | Application Number EPR/RP3638SJ/A001 |

| IED Article | Requirement | Delivered by |
|--------------------|--|--|
| 50(3) | At least one auxiliary burner which must not be fed with fuels which can cause higher emissions than those resulting from the burning of gas oil liquefied gas or natural gas. | Condition 2.3.14 |
| 50(4)(a) | Automatic shut-down to prevent waste feed if at start up until the specified temperature has been reached. | Condition 2.3.9 |
| 50(4)(b) | Automatic shut-down to prevent waste feed if the combustion temperature is not maintained. | Condition 2.3.9 |
| 50(4)(c) | Automatic shut-down to prevent waste feed if the CEMs show that ELVs are exceeded due to disturbances or failure of waste cleaning devices. | Condition 2.3.9 and 2.3.13 |
| 50(5) | Any heat generated from the process shall be recovered as far as practicable. | The plant will generate electricity and supply heat. Permit condition 1.2.1 |
| 50(6) | Relates to the feeding of infectious clinical waste into the furnace. | No infectious clinical waste will be burnt |
| 50(7) | Management of the Installation to be in the hands of a natural person who is competent to manage it. | Conditions 1.1.1 to 1.1.3 and 2.3.1 of the Permit. |
| 51(1) | Different conditions than those laid down in Article 50(1), (2) and (3) and, as regards the temperature Article 50(4) may be authorised, provided the other requirements of this chapter are met. | No such conditions Have been allowed |
| 51(2) | Changes in operating conditions do not cause more residues or residues with a higher content of organic polluting substances compared to those residues which could be expected under the conditions laid down in Articles 50(1), (2) and (3). | No such conditions Have been allowed |
| 51(3) | Changes in operating conditions shall include emission limit values for CO and TOC set out in Part 3 of Annex VI. | No such conditions Have been allowed |
| | | |
| Page 88 of 96 | | Application Number EPR/RP3638SJ/A001 |

| IED Article | Requirement | Delivered by |
|--------------------|---|---|
| 52(1) | Take all necessary precautions concerning delivery and reception of Wastes, to prevent or minimise pollution. | Conditions 2.3.1, 2.3.2, 2.3.4, 2.3.5, 2.3.6 |
| 52(2) | Determine the mass of each category of wastes, if possible according to the EWC, prior to accepting the waste. | Condition 2.3.4(a) and Table S2.2 in Schedule 3 of the Permit. |
| 52(3) | Prior to accepting hazardous waste, the operator shall collect available information about the waste for the purpose of compliance with the permit requirements specified in Article 45(2). | Not Applicable |
| 52(4) | Prior to accepting hazardous waste, the operator shall carry out the procedures set out in Article 52(4). | Not Applicable |
| 52(5) | Granting of exemptions from Article 52(2), (3) and (4). | Not Applicable |
| 53(1) | Residues to be minimised in their amount and harmfulness, and recycled where appropriate. | Conditions 1.4.1, 1.4.2 and 3.6.1 with Table S3.4 |
| 53(2) | Prevent dispersal of dry residues and dust during transport and storage. | conditions 1.4.1 2.3.1, 2.3.2 and 3.3.1. |
| 53(3) | Test residues for their physical and chemical characteristics and polluting potential including heavy metal content (soluble fraction). | Condition 3.6.1 and Table S3.4 and pre-operational condition PO2. |
| 55(1) | Application, decision and permit to be publicly available. | All documents are accessible from the Environment Agency Public Register. |
| 55(2) | An annual report on plant operation and monitoring for all plants burning more than 2 tonne/hour waste. | Condition 4.2.2 and 4.2.3. |

Annex 1B: Compliance with Bat Conclusions

| BAT conclusion | Criteria | Delivered by |
|-----------------------|---|---|
| 1 | Implement environmental management system | Condition 1.1 and Pre-operational condition PO1 |
| 2 | Determine gross electrical efficiency | Section 4.3.7 of this decision document. Permit table S3.3 |
| 3 | Monitor key process parameters | Condition 3.6.1 and table S3.3 |
| 4 | Monitoring emissions to air | Condition 3.6.1 and table S3.1 |
| 5 | Monitoring emissions to air during OTNOC | Condition 1.1.1 and pre-operational condition PO1 |
| 6 | Monitoring emissions to water from flue gas treatment and/or bottom ash treatment | There are no such emissions from the installation |
| 7 | Monitor unburnt substances in slags and bottom ashes | Conditions 3.1.3 and 3.6.1, and table S3.4 |
| 8 | Analysis of hazardous waste | Not applicable |
| 9 | Waste stream management techniques | The Application explains the measures that will be used. Permit condition 2.3.1, table S1.2 and pre-operational condition PO4 |
| 10 | Quality management system for bottom ash treatment plant | Not applicable |
| 11 | Monitor waste deliveries as part of waste acceptance procedures | The Application explains the measures that will be used. Permit condition 2.3.1, table S1.2 and pre-operational condition PO4 |
| 12 | Reception, handling and storage of waste | Measures are described in the Application and FPP. Permit conditions 2.3.1, table S1.2 and 3.8.1 |
| 13 | Storage and handling of clinical waste | Not applicable |
| 14 | Improve overall performance of plant including BAT-AELs for TOC or LOI | Techniques described in the Application. Permit condition 2.3.1, table S1.2, 3.1.3, 3.6.1 and table S3.4 |

| BAT conclusion | Criteria | Delivered by |
|-----------------------|--|--|
| 15 | Procedures to adjust plant settings to control performance | Measures described in the Application condition 2.3.1 and table S1.2 |
| 16 | Procedures to minimise start-up and shut down | Measures described in the Application |
| 17 | Appropriate design, operation and maintenance of FGC system | FGC measures described in Application. Operation and maintenance procedures will form part of the EMS |
| 18 | OTNOC management plan | Permit condition 1.1.1 and pre-operational condition PO1 |
| 19 | Use of heat recovery boiler | Described in the Application. Permit condition 2.3.1, table S1.2 |
| 20 | Measures to increase energy efficiency and BAT AEEL | Measures described in the Application. Permit condition 2.3.1, table S1.2 Section 4.3.7 of this decision document. |
| 21 | Measures to prevent or reduce diffuse emissions including odour | Measures described in the Application. Permit conditions 2.3.1, table S1.2, 3.4.1, 3.3.1, 3.3.2. Sections 4.2.2, 6.5.3 and 6.5.4 of this decision document. |
| 22 | Handling of gaseous and liquid wastes | Not applicable |
| 23 | Management system to prevent or reduce dust emissions from treatment of slags and ashes | Not applicable |
| 24 | Techniques to prevent or reduce diffuse emissions to air from treatment of slags and ashes | Not applicable |
| 25 | Minimisation of dust and metal emissions and compliance with BAT AEL | Section 5.2 of this decision document. Permit conditions 2.3.1, table S1.2, , 3.3.1, 3.3.2. 3.1.1 and 3.1.2 and table S3.1 |

| BAT conclusion | Criteria | Delivered by |
|-----------------------|---|--|
| 26 | Techniques and BAT AEL for dust emissions from enclosed slags and ashes treatment | Not applicable |
| 27 | Techniques to reduce emissions of HCl, HF and SO ₂ | Measures described in the Application. Permit condition 2.3.1 and table S1.2 Permit condition 2.3.1 and table S1.2 Section 5.2 of this decision document. |
| 28 | Techniques to reduce peak emissions of HCl, HF and SO ₂ , optimise reagent use and BAT AELs | Measures described in the Application. Permit conditions 2.3.1, table S1.2, 3.1.1 and 3.1.2 and table S3.1 |
| 29 | Techniques to reduce emissions of NO ₂ , N ₂ O, CO and NH ₃ and BAT AELs | Measures described in the Application. Section 5.2 of this decision document. Permit conditions 2.3.1, table S1.2, 3.1.1 and 3.1.2 and table S3.1 |
| 30 | Reduce emissions or organic compounds including dioxins/furans and PCBs. BAT AELs | Measures described in the Application. Section 5.2 of this decision document. Permit conditions 2.3.1, table S1.2, 3.1.1 and 3.1.2 and table S3.1 |
| 31 | Reduce emissions of mercury. BAT AEL | Measures described in the Application. Section 5.2 of this decision document. Permit conditions 2.3.1, table S1.2, , , 3.1.1 and 3.1.2 and table S3.1 |
| 32 | Segregate waste water streams to prevent contamination | Measures described in the Application Sections 4.2.2, 6.5.1 and 6.5.3 of this decision document. Permit conditions 2.3.1, 3.1.1, 3.1.2 and tables S1.2, S3.2 |

| BAT conclusion | Criteria | Delivered by |
|-----------------------|---|--|
| 33 | Techniques to reduce water usage and prevent or reduce waste water | Measures described in the Application. Sections 4.2.2 and 4.3.8 of this decision document Permit conditions 1.3.1, 2.3.1, table S1.2 |
| 34 | Reduce emissions to water from FGC and/or from treatment or storage of bottom ashes. BAT AELs | Not applicable |
| 35 | Handle and treat bottom ashes separately from FGC residues | Permit condition 2.3.15 |
| 36 | Techniques for treatment of slags and bottom ashes | No treatment carried out on site |
| 37 | Techniques to prevent or reduce noise emissions. | Measures are described in the Application. Section 6.5.5 of this decision document. Permit conditions 2.3.1, table S1.2, 3.5.1, 3.5.2 |

Annex 2: Pre-Operational Conditions

Based on the information on the Application, we consider that we do need to impose pre-operational conditions. These conditions are found in the Permit and referred to, where applicable, in the text of the decision document. We are using these conditions to require the Operator to confirm that the details and measures proposed in the Application have been adopted or implemented prior to the operation of the Installation.

Annex 3: Improvement Conditions

Based in the information in the Application we consider that we need to set improvement conditions. These conditions are found in the Permit and justifications for these is provided at the relevant section of the decision document. We are using these conditions to require the Operator to provide the Environment Agency with details that need to be established or confirmed during and/or after commissioning.

Annex 4: Consultation Responses

A) Advertising and Consultation on the Application

The Application has been advertised and consulted upon in accordance with the Environment Agency's Public Participation Statement. The way in which this has been carried out along with the results of our consultation and how we have taken consultation responses into account in reaching our decision is summarised in this Annex. Copies of consultation responses have been placed on the Environment Agency public register.

The Application was advertised on the Environment Agency website from 28/06/2024 to 09/08/2024 and in the Grimsby Telegraph. The Application was made available to view on the Environment Agency's Public Register.

The following statutory and non-statutory bodies were consulted:

- Local Authority – Environmental Protection Department
- Local Authority – Planning
- Fire & Rescue
- Director of PH/UKHSA
- Health and Safety Executive
- Food Standards Agency
- Sewerage Authorities
- National Grid
- Civil Aviation Authority
- National air traffic services (NATS)
- Humberside International Airport Limited

1) Consultation Responses from Statutory and Non-Statutory Bodies

| Response Received from the UKHSA | |
|---|--|
| Brief summary of issues raised: | Summary of action taken / how this has been covered |
| No issues raised | No action required |

2) Consultation Responses from Members of the Public and Community Organisations

No responses were received.