

Product Safety Report

| PAGED DI LIDI ED DI | | |
|---------------------------|--|--|
| PAGED BirchPly FR Plywood | | |
| Aspect | Details | |
| Images | PAGED FirePLY hardwood p FR Pure Class B-s1 d0 EN 133 E1, EN 636-25, CE1 EN 13986+A122 35 DoP 0763-CPR-6036 | |
| Alert Number | 2305-0038 | |
| Product Type | Construction Product – Plywood | |
| Product Identifiers | Date range of affected product: Product placed on the UK market on or after 15 December 2021 Board Size: 1220mm x 2440mm, thickness: 12mm to 24mm Board Markings: DoP 0763-CPR-6036 Declaration of Performance: 1. DoP-HW FR-02, dated 15.12.2021 (CE) 2. DoP-HW FR-02, dated 01.11.2022 (CE) 3. DoC-HW FR-02, dated 01.12.2022 (UKCA) Euroclass Declaration: B-s1 d0 | |
| Product Description | Birch Hardwood FR Plywood intended for construction sheeting. | |
| Country of Origin | Poland | |
| Counterfeit | No | |
| Risk Level | Not provided | |
| Risk Type | Non-performance | |
| Risk Description | Testing in accordance with EN 13501-1:2018 has found that the product may not consistently achieve Euroclass B for reaction to fire performance, despite being marketed as Euroclass B. The product may therefore not perform with the declared reaction to fire performance required or be suitable for its original desired application. This product does not meet the requirements of EU Construction Products Regulation 305/2011 as they apply in the UK. | |
| Corrective Measures | The manufacturer has withdrawn the product from the UK market and UK importers and distributors are to warn those they have supplied of the risk the product poses. The potential impact of lower performance of a product in relation to reaction to fire and building safety will vary on a project-by-project basis and will depend on factors unique to each building. Building owners should seek advice from their building safety officer, an independent inspector, fire safety | |

The OPSS Product Safety Alerts, Reports and Recalls Site can be accessed at the following link: https://www.gov.uk/guidance/product-recalls-and-alerts



Product Safety Report

| | officer or a relevant building control authority, as appropriate, and consider reviewing the building's fire strategy if necessary. |
|-----------------------|---|
| Online Marketplace | N/A |
| Notifier | Office for Product Safety and Standards |