








Specialist Door Solutions Hospital Fire Doors	
Aspect	Details
PSD Number	2501-0043
Product Type	Construction Products – Fire Doors
Product Identifiers	Brand: Specialist Door Solutions Ltd Models: FD30/FD30s, FD60/FD60s Lamdoor, Dfendoor, Shieldoor Component configuration: Flush-fit Clearglaze, Flush-fit Priviglaze, Flush-fit Priviglaze+. Warning Lights, Concealed Closers in Double-Swing Doorsets
Product Description	Fire doors installed in hospitals. Images of affected products are included in Annex A.
Country of Origin	United Kingdom
Counterfeit	No
Risk Level	Low
Risk Type	Fire
Risk Description	<p>The manufacturer has identified that specific configurations of Vision Panels and / or Concealed Closers in certain door leaves may not be fully in accordance with the certified design or installation standards. This could mean that the inclusion of a vision panel or concealed closer results in a slight reduction in the fire door's ability to contain fire and smoke, potentially compromising safety in the event of a fire. The issue may reduce the time for which the doors are certified for resisting fire. There is no issue with the core of any doorset.</p> <p>The product does not meet the requirements of the General Product Safety Regulations 2005.</p>
Corrective Measures	<p>The manufacturer has issued a recall for certain fire doors installed in hospitals due to concerns about the installation of specific vision panel configurations and certification queries affecting certain concealed closers. The remainder of the door set is unaffected.</p> <p>Affected projects have been notified of the issue directly, including information on interim safety measures that should be undertaken while doorsets are modified or replaced.</p> <p>Specialist Door Solutions' recall team can be contacted on 01684 770 012 or SDShelp@leviathanconsulting.co.uk for project managers with questions or requiring urgent assistance.</p>
Online Marketplace	N/A
Notifier	Local Authority Trading Standards



Annex A – Images of Affected Products

Panel type	Description	Image	
<p>Priviglaze</p>	<p>A double glazed unit finishing <u>flush with both faces of the door</u>, incorporating an integral blind.</p> <p>Units recessed into the aperture and fitted with PVC beads are NOT affected.</p>		
<p>Priviglaze +</p>	<p>A double glazed unit finishing <u>flush with both faces of the door</u>, incorporating an integral blind & LED Warning light.</p> <p>Units recessed into the aperture and fitted with PVC beads are NOT affected.</p>		
<p>Flush-fit Clearglaze</p>	<p>A double glazed unit finishing <u>flush with both faces of the door</u>.</p> <p>Units recessed into the aperture and fitted with PVC beads are NOT affected.</p>		
<p>Warning lights fitted in Dfendoor/Shieldoor</p>	<p>An integrated warning light panel <u>flush with both faces of the door, fitted into Lead-lined and Non-lead lined doorsets.</u></p>		
<p>Concealed closers in double-swing doors with EMHO</p>	<p>A closer installed in the head of the frame and head of the door. With EMHO function.</p>	