

## Appendix B – BRUKL Documents

## Project name

Club House - Be Green

As designed

Date: Tue Jun 18 14:21:01 2024

## Administrative information

## Building Details

Address: TBC

## Certifier details

Name: Name

Telephone number: Phone

Address: Street Address, City, Postcode

## Certification tool

Calculation engine: Apache

Calculation engine version: 7.0.24

Interface to calculation engine: IES Virtual Environment

Interface to calculation engine version: 7.0.24

BRUKL compliance module version: v6.1.e.1

Foundation area [m<sup>2</sup>]: 316.38The CO<sub>2</sub> emission and primary energy rates of the building must not exceed the targets

Target CO <sub>2</sub> emission rate (TER), kgCO <sub>2</sub> /m <sup>2</sup> annum	4.03
Building CO <sub>2</sub> emission rate (BER), kgCO <sub>2</sub> /m <sup>2</sup> annum	2.3
Target primary energy rate (TPER), kWh <sub>PE</sub> /m <sup>2</sup> annum	42.82
Building primary energy rate (BPER), kWh <sub>PE</sub> /m <sup>2</sup> annum	22.21
Do the building's emission and primary energy rates exceed the targets?	BER ≤ TER   BPER ≤ TPER

## The performance of the building fabric and fixed building services should achieve reasonable overall standards of energy efficiency

Fabric element	U <sub>a-Limit</sub>	U <sub>a-Calc</sub>	U <sub>i-Calc</sub>	First surface with maximum value
Walls*	0.26	0.18	0.18	0000001F:Surf[8]
Floors	0.18	0.12	0.12	0000001F:Surf[0]
Pitched roofs	0.16	-	-	No pitched roofs in building
Flat roofs	0.18	0.12	0.12	0000001F:Surf[1]
Windows** and roof windows	1.6	1.6	1.6	0000001F:Surf[2]
Rooflights***	2.2	-	-	No roof lights in building
Personnel doors^	1.6	1.6	1.6	00000020:Surf[6]
Vehicle access & similar large doors	1.3	-	-	No vehicle access doors in building
High usage entrance doors	3	-	-	No high usage entrance doors in building

U<sub>a-Limit</sub> = Limiting area-weighted average U-values [W/(m<sup>2</sup>K)]U<sub>i-Calc</sub> = Calculated maximum individual element U-values [W/(m<sup>2</sup>K)]U<sub>a-Calc</sub> = Calculated area-weighted average U-values [W/(m<sup>2</sup>K)]

\* Automatic U-value check by the tool does not apply to curtain walls whose limiting standard is similar to that for windows.

\*\* Display windows and similar glazing are excluded from the U-value check. \*\*\* Values for rooflights refer to the horizontal position.

^ For fire doors, limiting U-value is 1.8 W/m<sup>2</sup>K

NB: Neither roof ventilators (inc. smoke vents) nor swimming pool basins are modelled or checked against the limiting standards by the tool.

Air permeability	Limiting standard	This building
m <sup>3</sup> /(h.m <sup>2</sup> ) at 50 Pa	8	3

## Building services

For details on the standard values listed below, system-specific guidance, and additional regulatory requirements, refer to the Approved Documents.

Whole building lighting automatic monitoring & targeting with alarms for out-of-range values	NO
Whole building electric power factor achieved by power factor correction	<0.9

### 1- 001 | ASHP CHAV-R450YA-HPB

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
This system	3.24	-	0	-	0.85
Standard value	2.5*	N/A	N/A	N/A	N/A
Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system					YES
* Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps.					

### 2- 002 | Direct Electric

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
This system	1	-	0	-	0.85
Standard value	N/A	N/A	N/A	N/A	N/A
Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system					NO

"No HWS in project, or hot water is provided by HVAC system"

### Zone-level mechanical ventilation, exhaust, and terminal units

ID	System type in the Approved Documents
A	Local supply or extract ventilation units
B	Zonal supply system where the fan is remote from the zone
C	Zonal extract system where the fan is remote from the zone
D	Zonal balanced supply and extract ventilation system
E	Local balanced supply and extract ventilation units
F	Other local ventilation units
G	Fan assisted terminal variable air volume units
H	Fan coil units
I	Kitchen extract with the fan remote from the zone and a grease filter
NB: Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components.	

Zone name	SFP [W/(l/s)]										HR efficiency	
ID of system type	A	B	C	D	E	F	G	H	I		Zone	Standard
Standard value	0.3	1.1	0.5	2.3	2	0.5	0.5	0.4	1			
00 - Changing Room/Showers	-	-	-	0.8	-	-	-	-	-	-	-	N/A
00 - Changing Room/Showers	-	-	-	0.8	-	-	-	-	-	-	-	N/A
00 - Changing Room/Showers	-	-	-	0.8	-	-	-	-	-	-	-	N/A
00 - Changing Room/Showers	-	-	-	0.8	-	-	-	-	-	-	-	N/A
00 - Bathroom	-	-	-	0.8	-	-	-	-	-	-	-	N/A
00 - Bathroom	-	-	-	0.8	-	-	-	-	-	-	-	N/A
00 - Club Room	-	-	-	0.8	-	-	-	-	-	-	-	N/A
00 - Changing Room/Showers	-	-	-	0.8	-	-	-	-	-	-	-	N/A
00 - Changing Room/Showers	-	-	-	0.8	-	-	-	-	-	-	-	N/A
00 - WC	-	-	-	0.8	-	-	-	-	-	-	-	N/A
00 - WC	-	-	-	0.8	-	-	-	-	-	-	-	N/A

Zone name	SFP [W/(l/s)]										HR efficiency	
ID of system type	A	B	C	D	E	F	G	H	I			
Standard value	0.3	1.1	0.5	2.3	2	0.5	0.5	0.4	1	Zone	Standard	
00 - Changing Room/Showers	-	-	-	0.8	-	-	-	-	-	-	N/A	
00 - WC	-	-	-	0.8	-	-	-	-	-	-	N/A	
00 - WC	-	-	-	0.8	-	-	-	-	-	-	N/A	
00 - Changing Room/Showers	-	-	-	0.8	-	-	-	-	-	-	N/A	
00 - Bar	-	-	-	0.8	-	-	-	-	-	-	N/A	
00 - Kitchen	-	-	-	0.8	-	-	-	-	-	-	N/A	
00 - WC	-	-	-	0.8	-	-	-	-	-	-	N/A	
00 - Office	-	-	-	0.8	-	-	-	-	-	-	N/A	
00 - WC	-	-	-	0.8	-	-	-	-	-	-	N/A	
00 - WC	-	-	-	0.8	-	-	-	-	-	-	N/A	
00 - WC	-	-	-	0.8	-	-	-	-	-	-	N/A	

General lighting and display lighting		General luminaire	Display light source	
Zone name		Efficacy [lm/W]	Efficacy [lm/W]	Power density [W/m²]
Standard value		95	80	0.3
00 - Changing Room/Showers		100	-	-
00 - Changing Room/Showers		100	-	-
00 - Changing Room/Showers		100	-	-
00 - Changing Room/Showers		100	-	-
00 - Bathroom		100	-	-
00 - Bathroom		100	-	-
00 - CAC 1		100	-	-
00 - Club Room		100	-	-
00 - CAC 2		100	-	-
00 - Changing Room/Showers		100	-	-
00 - Changing Room/Showers		100	-	-
00 - WC		100	-	-
00 - WC		100	-	-
00 - Changing Room/Showers		100	-	-
00 - WC		100	-	-
00 - WC		100	-	-
00 - Changing Room/Showers		100	-	-
00 - Store		100	-	-
00 - Store		100	-	-
00 - Store		100	-	-
00 - Bar		100	-	-
00 - Clean cupboard		100	-	-
00 - Kitchen		100	-	-
00 - WC		100	-	-
00 - Office		100	-	-
00 - Lobby		100	-	-
00 - Plant		100	-	-
00 - WC		100	-	-

General lighting and display lighting		General luminaire	Display light source	
Zone name		Efficacy [lm/W]	Efficacy [lm/W]	Power density [W/m <sup>2</sup> ]
	Standard value	95	80	0.3
00 - Lobby		100	-	-
00 - Cellar		100	-	-
00 - WC		100	-	-
00 - WC		100	-	-

**The spaces in the building should have appropriate passive control measures to limit solar gains in summer**

Zone	Solar gain limit exceeded? (%)	Internal blinds used?
00 - Club Room	NO (-36.6%)	NO
00 - Bar	N/A	N/A
00 - Office	NO (-85.5%)	NO

### Regulation 25A: Consideration of high efficiency alternative energy systems

Were alternative energy systems considered and analysed as part of the design process?	YES
Is evidence of such assessment available as a separate submission?	YES
Are any such measures included in the proposed design?	YES

# Technical Data Sheet (Actual vs. Notional Building)

## Building Global Parameters

	Actual	Notional
Floor area [m <sup>2</sup> ]	431.3	431.3
External area [m <sup>2</sup> ]	1207	1181.7
Weather	LON	LON
Infiltration [m <sup>3</sup> /hm <sup>2</sup> @ 50Pa]	3	3
Average conductance [W/K]	230.3	0
Average U-value [W/m <sup>2</sup> K]	0.19	0
Alpha value* [%]	24.73	10

\* Percentage of the building's average heat transfer coefficient which is due to thermal bridging

## Building Use

### % Area Building Type

Retail/Financial and Professional Services  
 Restaurants and Cafes/Drinking Establishments/Takeaways  
 Offices and Workshop Businesses  
 General Industrial and Special Industrial Groups  
 Storage or Distribution  
 Hotels  
 Residential Institutions: Hospitals and Care Homes  
 Residential Institutions: Residential Schools  
 Residential Institutions: Universities and Colleges  
 Secure Residential Institutions  
 Residential Spaces  
 Non-residential Institutions: Community/Day Centre  
 Non-residential Institutions: Libraries, Museums, and Galleries

100

### Non-residential Institutions: Education

Non-residential Institutions: Primary Health Care Building  
 Non-residential Institutions: Crown and County Courts  
 General Assembly and Leisure, Night Clubs, and Theatres  
 Others: Passenger Terminals  
 Others: Emergency Services  
 Others: Miscellaneous 24hr Activities  
 Others: Car Parks 24 hrs  
 Others: Stand Alone Utility Block

## Energy Consumption by End Use [kWh/m<sup>2</sup>]

	Actual	Notional
Heating	11.24	10.42
Cooling	0	0
Auxiliary	5.36	3.96
Lighting	6.21	6.23
Hot water	9.7	8.06
Equipment*	32.09	32.09
<b>TOTAL **</b>	<b>32.5</b>	<b>28.67</b>

\* Energy used by equipment does not count towards the total for consumption or calculating emissions.

\*\* Total is net of any electrical energy displaced by CHP generators, if applicable.

## Energy Production by Technology [kWh/m<sup>2</sup>]

	Actual	Notional
Photovoltaic systems	18.85	0.02
Wind turbines	0	0
CHP generators	0	0
Solar thermal systems	0	0
<i>Displaced electricity</i>	<i>18.85</i>	<i>0.02</i>

## Energy & CO<sub>2</sub> Emissions Summary

	Actual	Notional
Heating + cooling demand [MJ/m <sup>2</sup> ]	122.75	104.04
Primary energy [kWh <sub>PE</sub> /m <sup>2</sup> ]	22.21	42.82
Total emissions [kg/m <sup>2</sup> ]	2.3	4.03

HVAC Systems Performance										
System Type	Heat dem MJ/m2	Cool dem MJ/m2	Heat con kWh/m2	Cool con kWh/m2	Aux con kWh/m2	Heat SSEFF	Cool SSEER	Heat gen SEFF	Cool gen SEER	
[ST] Central heating using water: floor heating, [HS] ASHP, [HFT] Electricity, [CFT] Electricity										
Actual	180.9	0	16.5	0	5.2	3.04	0	3.24	0	
Notional	153.1	0	15.3	0	2.5	2.78	0	----	----	
[ST] Other local room heater - unfanned, [HS] Direct or storage electric heater, [HFT] Electricity, [CFT] Electricity										
Actual	2.1	0	0.7	0	4.5	0.8	0	1	0	
Notional	4.4	0	0.9	0	1.8	1.41	0	----	----	
[ST] No Heating or Cooling										
Actual	0	0	0	0	0	0	0	0	0	
Notional	0	0	0	0	0	0	0	----	----	

### Key to terms

Heat dem [MJ/m2]	= Heating energy demand
Cool dem [MJ/m2]	= Cooling energy demand
Heat con [kWh/m2]	= Heating energy consumption
Cool con [kWh/m2]	= Cooling energy consumption
Aux con [kWh/m2]	= Auxiliary energy consumption
Heat SSEFF	= Heating system seasonal efficiency (for notional building, value depends on activity glazing class)
Cool SSEER	= Cooling system seasonal energy efficiency ratio
Heat gen SSEFF	= Heating generator seasonal efficiency
Cool gen SSEER	= Cooling generator seasonal energy efficiency ratio
ST	= System type
HS	= Heat source
HFT	= Heating fuel type
CFT	= Cooling fuel type



Contact details:

Whitecode Consulting Ltd  
26-27 The Hill  
Northfleet Gravesend  
Kent  
DA11 9EU

t: 01322 289977

f: 01322 289988

e: [design@whitecode.co.uk](mailto:design@whitecode.co.uk)