

Permit with introductory note

The Environmental Permitting (England & Wales) Regulations 2016

Crawley Data Centre Campus
Unit 1 and 2
Manor Royal
Crawley
RH10 9BD

Permit number

EPR/EP3022ST

Crawley Data Centre Campus

Permit number EPR/EP3022ST

Introductory note

This introductory note does not form a part of the notice.

The main features of the permit are as follows.

The permit authorises the operation of stand-by electricity generating plant at a data centre located in Crawley at national grid reference TQ 28670 51462. The data centre will under normal operating conditions be powered by grid supplied electricity.

The installation falls under the following Environmental Permitting Regulations (EPR) Schedule 1 listed activity description:

Section 1.1 Part A(1)(a) - Burning any fuel in an appliance with a rated thermal input of 50 or more megawatts.

The installation comprises 17 stand-by backup generators across 2 units to provide electrical power to the data centre in the event of a failure of power supply from the national grid. The standby generators are medium combustion plant (MCP) gas oil fuelled generators with an aggregated thermal input of 72.6MW_{th}. Unit 1 houses 10 stand-by generators which are Existing MCP. Unit 2 house 7 stand-by generators which are New MCP.

The plant is limited to operating less than 500 hours/year, including the testing regime. It is essential that the standby system is routinely tested to ensure the engines function correctly in the event of them being required to operate in an emergency.

The engines are tested monthly, quarterly, 6 monthly (Unit 2 engines only) and annually.

Unit 1 has eight 3.93MW_{th} generators which are fuelled from four above ground integrally bunded 13,500L gas oil bulk tanks, exhaust gases from each generator will be discharged through individual 16m stacks. There are also two 1.23MW_{th} generators fuelled from an integrally bunded 3050L tank, exhaust gases from each generator will be discharged through individual 14.5m stacks.

Unit 2 has seven 5.49MW_{th} generators each fed by a 2000L day tank, which are themselves fed by two above ground integrally bunded 38,000L gas oil bulk tanks. Exhaust gases from each generator will be discharged through individual 6.8m stacks.

There are no process effluent discharges from the installation. Uncontaminated surface water run-off from hard-standing will drain via oil-water interceptors before discharging to a combined sewer.

There are a number of local wildlife sites, local nature reserves and ancient woodland within 2km of the installation. The closest residential properties are located approximately 50m from the data centre boundary.

There is an Environmental Management System (EMS) in place based on the ISO 14001 standard.

The status log of a permit sets out the permitting history, including any changes to the permit reference number.

Status log of the permit		
Description	Date	Comments
Application EPR/EP3022ST/A001	Duly made 04/12/2024	Application to operate 17 standby gas oil fuelled generators in the event of National Grid failure and for testing and maintenance activities.
Schedule 5 Notice issued	24/03/2025	Response received 14/04/2025
Permit determined EPR/ EP3022ST	02/06/2025	Permit issued to Digital Realty Limited.

End of introductory note

Permit

The Environmental Permitting (England and Wales) Regulations 2016

Permit number

EPR/EP3022ST

The Environment Agency hereby authorises, under regulation 13 of the Environmental Permitting (England and Wales) Regulations 2016

Digital Realty (UK) Limited (“the operator”),

whose registered office is

**5th Floor
60 London Wall
London
United Kingdom
EC2M 5TQ**

company registration number **05813740**

to operate an installation at

**Crawley Data Centre Campus
Unit 1 and 2
Manor Royal
Crawley
RH10 9BD**

to the extent authorised by and subject to the conditions of this permit.

Name	Date
Daniel Timney	02/06/2025

Authorised on behalf of the Environment Agency

Conditions

1 Management

1.1 General management

1.1.1 The operator shall manage and operate the activities:

- (a) in accordance with a written management system that identifies and minimises risks of pollution, including those arising from operations, maintenance, accidents, incidents, non-conformances, closure and those drawn to the attention of the operator as a result of complaints; and
- (b) using sufficient competent persons and resources.

1.1.2 Records demonstrating compliance with condition 1.1.1 shall be maintained.

1.1.3 Any person having duties that are or may be affected by the matters set out in this permit shall have convenient access to a copy of it kept at or near the place where those duties are carried out.

1.2 Energy efficiency

1.2.1 The operator shall:

- (a) take appropriate measures to ensure that energy is used efficiently in the activities;
- (b) take appropriate measures to ensure the efficiency of energy generation at the permitted installation is maximised;
- (c) review and record at least every four years whether there are suitable opportunities to improve the energy efficiency of the activities; and
- (d) take any further appropriate measures identified by a review.

1.3 Efficient use of raw materials

1.3.1 The operator shall:

- (a) take appropriate measures to ensure that raw materials and water are used efficiently in the activities;
- (b) maintain records of raw materials and water used in the activities;
- (c) review and record at least every four years whether there are suitable alternative materials that could reduce environmental impact or opportunities to improve the efficiency of raw material and water use; and
- (d) take any further appropriate measures identified by a review.

1.4 Avoidance, recovery and disposal of wastes produced by the activities

1.4.1 The operator shall take appropriate measures to ensure that:

- (a) the waste hierarchy referred to in Article 4 of the Waste Framework Directive is applied to the generation of waste by the activities;
- (b) any waste generated by the activities is treated in accordance with the waste hierarchy referred to in Article 4 of the Waste Framework Directive; and
- (c) where disposal is necessary, this is undertaken in a manner which minimises its impact on the environment.

- 1.4.2 The operator shall review and record at least every four years whether changes to those measures should be made and take any further appropriate measures identified by a review.

2 Operations

2.1 Permitted activities

- 2.1.1 The operator is only authorised to carry out the activities specified in schedule 1 table S1.1 (the “activities”).

2.2 The site

- 2.2.1 The activities shall not extend beyond the site, being the land shown edged in green on the site plan at schedule 7 to this permit.

2.3 Operating techniques

- 2.3.1 The activities shall, subject to the conditions of this permit, be operated using the techniques and in the manner described in the documentation specified in schedule 1, table S1.2, unless otherwise agreed in writing by the Environment Agency.
- 2.3.2 If notified by the Environment Agency that the activities are giving rise to pollution, the operator shall submit to the Environment Agency for approval within the period specified, a revision of any plan or other documentation (“plan”) specified in schedule 1, table S1.2 or otherwise required under this permit which identifies and minimises the risks of pollution relevant to that plan, and shall implement the approved revised plan in place of the original from the date of approval, unless otherwise agreed in writing by the Environment Agency.
- 2.3.3 Any raw materials or fuels listed in schedule 2 table S2.1 shall conform to the specifications set out in that table.
- 2.3.4 The operator shall ensure that where waste produced by the activities is sent to a relevant waste operation, that operation is provided with the following information, prior to the receipt of the waste:
- (a) the nature of the process producing the waste;
 - (b) the composition of the waste;
 - (c) the handling requirements of the waste;
 - (d) the hazardous property associated with the waste, if applicable; and
 - (e) the waste code of the waste.
- 2.3.5 The operator shall ensure that where waste produced by the activities is sent to a landfill site, it meets the waste acceptance criteria for that landfill.
- 2.3.6 For the following activities referenced in schedule 1, table S1.1: AR1. The activities shall not operate for more than 500 hours in emergency use per annum.
- 2.3.7 For the following activities referenced in Schedule 1 table S1.1: AR1.
- (a) the operator must keep periods of start-up and shut down of the combustion plant as short as possible.
 - (b) there shall be no persistent emission of ‘dark smoke’ as defined in section 3(1) of the Clean Air Act 1993.

2.4 Improvement programme

- 2.4.1 The operator shall complete the improvements specified in schedule 1 table S1.3 by the date specified in that table unless otherwise agreed in writing by the Environment Agency.
- 2.4.2 Except in the case of an improvement which consists only of a submission to the Environment Agency, the operator shall notify the Environment Agency within 14 days of completion of each improvement.

3 Emissions and monitoring

3.1 Emissions to water, air or land

- 3.1.1 There shall be no point source emissions to water, air or land except from the sources and emission points listed in schedule 3 tables S3.1 and S3.2.
- 3.1.2 The limits given in schedule 3 shall not be exceeded.
- 3.1.3 Periodic monitoring shall be carried out at least once every 5 years for groundwater and 10 years for soil, unless such monitoring is based on a systematic appraisal of the risk of contamination.

3.2 Emissions of substances not controlled by emission limits

- 3.2.1 Emissions of substances not controlled by emission limits (excluding odour) shall not cause pollution. The operator shall not be taken to have breached this condition if appropriate measures, including, but not limited to, those specified in any approved emissions management plan, have been taken to prevent or where that is not practicable, to minimise, those emissions.
- 3.2.2 The operator shall:
 - (a) if notified by the Environment Agency that the activities are giving rise to pollution, submit to the Environment Agency for approval within the period specified, an emissions management plan which identifies and minimises the risks of pollution from emissions of substances not controlled by emission limits;
 - (b) implement the approved emissions management plan, from the date of approval, unless otherwise agreed in writing by the Environment Agency.
- 3.2.3 All liquids in containers, whose emission to water or land could cause pollution, shall be provided with secondary containment, unless the operator has used other appropriate measures to prevent or where that is not practicable, to minimise, leakage and spillage from the primary container.

3.3 Odour

- 3.3.1 Emissions from the activities shall be free from odour at levels likely to cause pollution outside the site, as perceived by an authorised officer of the Environment Agency, unless the operator has used appropriate measures, including, but not limited to, those specified in any approved odour management plan, to prevent or where that is not practicable to minimise the odour.
- 3.3.2 The operator shall:
 - (a) if notified by the Environment Agency that the activities are giving rise to pollution outside the site due to odour, submit to the Environment Agency for approval within the period specified, an odour management plan which identifies and minimises the risks of pollution from odour;
 - (b) implement the approved odour management plan, from the date of approval, unless otherwise agreed in writing by the Environment Agency.

3.4 Noise and vibration

- 3.4.1 Emissions from the activities shall be free from noise and vibration at levels likely to cause pollution outside the site, as perceived by an authorised officer of the Environment Agency, unless the operator has used appropriate measures, including, but not limited to, those specified in any approved noise and vibration management plan to prevent or where that is not practicable to minimise the noise and vibration.
- 3.4.2 The operator shall:
- (a) if notified by the Environment Agency that the activities are giving rise to pollution outside the site due to noise and vibration, submit to the Environment Agency for approval within the period specified, a noise and vibration management plan which identifies and minimises the risks of pollution from noise and vibration;
 - (b) implement the approved noise and vibration management plan, from the date of approval, unless otherwise agreed in writing by the Environment Agency.

3.5 Monitoring

- 3.5.1 The operator shall, unless otherwise agreed in writing by the Environment Agency, undertake the monitoring specified in the following tables in schedule 3 to this permit:
- (a) point source emissions specified in tables S3.1 and S3.2.
- 3.5.2 The operator shall maintain records of all monitoring required by this permit including records of the taking and analysis of samples, instrument measurements (periodic and continuous), calibrations, examinations, tests and surveys and any assessment or evaluation made on the basis of such data.
- 3.5.3 Monitoring equipment, techniques, personnel and organisations employed for the emissions monitoring programme and the environmental or other monitoring specified in condition 3.5.1 shall have either MCERTS certification or MCERTS accreditation (as appropriate), where available, unless otherwise agreed in writing by the Environment Agency.
- 3.5.4 Permanent means of access shall be provided to enable sampling/monitoring to be carried out in relation to the emission points specified in schedule 3 tables S3.1 and S3.2 unless otherwise agreed in writing by the Environment Agency.
- 3.5.5 The first monitoring measurements shall be carried out:
- (a) within four months of the issue date of the permit or the date when the MCP is first put into operation, whichever is later; and
 - (b) at any time for existing MCPs, but no later than the relevant compliance date.
- 3.5.6 Monitoring of MCP shall not take place during periods of start-up or shut down.

4 Information

4.1 Records

- 4.1.1 All records required to be made by this permit shall:
- (a) be legible;
 - (b) be made as soon as reasonably practicable;
 - (c) if amended, be amended in such a way that the original and any subsequent amendments remain legible, or are capable of retrieval; and

(d) be retained, unless otherwise agreed in writing by the Environment Agency, for at least 6 years from the date when the records were made, or in the case of the following records until permit surrender:

- (i) off-site environmental effects; and
- (ii) matters which affect the condition of the land and groundwater.

4.1.2 The operator shall keep on site all records, plans and the management system required to be maintained by this permit, unless otherwise agreed in writing by the Environment Agency.

4.1.3 The operator shall maintain a record of the type and quantity of fuel used and the total annual operating hours for each MCP.

4.2 Reporting

4.2.1 The operator shall send all reports and notifications required by the permit to the Environment Agency using the contact details supplied in writing by the Environment Agency.

4.2.2 A report or reports on the performance of the activities over the previous year shall be submitted to the Environment Agency by 31 January (or other date agreed in writing by the Environment Agency) each year. The report(s) shall include as a minimum:

- a) a review of the results of the monitoring and assessment carried out in accordance with the permit including an interpretive review of that data;
- b) the performance parameters set out in schedule 4 table S4.2 using the forms specified in table S4.3 of that schedule;
- c) where conditions 2.3.6 applies, the hours of operation in any year.

4.2.3 Within 28 days of the end of the reporting period the operator shall, unless otherwise agreed in writing by the Environment Agency, submit reports of the monitoring and assessment carried out in accordance with the conditions of this permit, as follows:

- (a) in respect of the parameters and emission points specified in schedule 4 table S4.1;
- (b) for the reporting periods specified in schedule 4 table S4.1 and using the forms specified in schedule 4 table S4.4; and
- (c) giving the information from such results and assessments as may be required by the forms specified in those tables.

4.2.4 The operator shall, unless notice under this condition has been served within the preceding four years, submit to the Environment Agency, within six months of receipt of a written notice, a report assessing whether there are other appropriate measures that could be taken to prevent, or where that is not practicable, to minimise pollution.

4.3 Notifications

4.3.1 In the event:

- (a) that the operation of the activities gives rise to an incident or accident which significantly affects or may significantly affect the environment, the operator must immediately—
 - (i) inform the Environment Agency,
 - (ii) take the measures necessary to limit the environmental consequences of such an incident or accident, and
 - (iii) take the measures necessary to prevent further possible incidents or accidents;
- (b) of a breach of any permit condition the operator must immediately—
 - (i) inform the Environment Agency, and

- (ii) take the measures necessary to ensure that compliance is restored within the shortest possible time;
 - (c) of a breach of permit condition which poses an immediate danger to human health or threatens to cause an immediate significant adverse effect on the environment, the operator must immediately suspend the operation of the activities or the relevant part of it until compliance with the permit conditions has been restored.
- 4.3.2 Any information provided under condition 4.3.1 shall be confirmed by sending the information listed in schedule 5 to this permit within the time period specified in that schedule.
- 4.3.3 Where the Environment Agency has requested in writing that it shall be notified when the operator is to undertake monitoring and/or spot sampling, the operator shall inform the Environment Agency when the relevant monitoring and/or spot sampling is to take place. The operator shall provide this information to the Environment Agency at least 14 days before the date the monitoring is to be undertaken.
- 4.3.4 The Environment Agency shall be notified within 14 days of the occurrence of the following matters, except where such disclosure is prohibited by Stock Exchange rules:

Where the operator is a registered company:

 - (a) any change in the operator's trading name, registered name or registered office address; and
 - (b) any steps taken with a view to the operator going into administration, entering into a company voluntary arrangement or being wound up.

Where the operator is a corporate body other than a registered company:

 - (c) any change in the operator's name or address; and
 - (d) any steps taken with a view to the dissolution of the operator.

In any other case:

 - (e) the death of any of the named operators (where the operator consists of more than one named individual);
 - (f) any change in the operator's name(s) or address(es); and
 - (g) any steps taken with a view to the operator, or any one of them, going into bankruptcy, entering into a composition or arrangement with creditors, or, in the case of them being in a partnership, dissolving the partnership.
- 4.3.5 Where the operator proposes to make a change in the nature or functioning, or an extension of the activities, which may have consequences for the environment and the change is not otherwise the subject of an application for approval under the Regulations or this permit:
 - (a) the Environment Agency shall be notified at least 14 days before making the change; and
 - (b) the notification shall contain a description of the proposed change in operation.
- 4.3.6 The Environment Agency shall be given at least 14 days' notice before implementation of any part of the site closure plan.
- 4.3.7 Where the operator has entered into a climate change agreement with the Government, the Environment Agency shall be notified within one month of:
 - (a) a decision by the Secretary of State not to re-certify the agreement;
 - (b) a decision by either the operator or the Secretary of State to terminate the agreement; and
 - (c) any subsequent decision by the Secretary of State to re-certify such an agreement.

4.4 Interpretation

- 4.4.1 In this permit the expressions listed in schedule 6 shall have the meaning given in that schedule.

- 4.4.2 In this permit references to reports and notifications mean written reports and notifications, except where reference is made to notification being made “immediately”, in which case it may be provided by telephone.

Schedule 1 – Operations

Table S1.1 activities			
Activity reference	Activity listed in Schedule 1 of the EP Regulations	Description of specified activity	Limits of specified activity
AR1	Section 1.1 Part A(1)(a): Burning any fuel in an appliance with a rated thermal input of 50 megawatts or more.	<p>Operation of 17 emergency stand-by generators with a total thermal input of approximately 72.6 MWth.</p> <p>The generators burn gas oil solely for the purpose of providing electricity to the data centre in the event of a failure of supply from the National Grid and during maintenance testing.</p> <p>Unit 1 Generators: 8 x 3.93MWth (Existing MCP) 2 x 1.23MWth (Existing MCP)</p> <p>Unit 2 Generators: 7 x 5.49MWth (New MCP)</p>	<p>From receipt of raw materials and generation of electricity to despatch of waste.</p> <p>Electricity produced at the installation cannot be exported to the National Grid.</p> <p>Testing of the generators shall only take place during daytime periods.</p> <p>The emergency operational hours of the installation shall not exceed the specifications set out in condition 2.3.6 of this permit.</p>
	Directly Associated Activity		
AR2	Storage of raw materials	From receipt of raw materials to use within the facility.	
AR3	Uncontaminated surface water drainage	From input to site drainage system until discharge to combined sewer and surface water drainage system (emission points S1 and S2).	

Table S1.2 Operating techniques		
Description	Parts	Date Received
Application EPR/EP3022ST/A001	Responses to section 3 of the Application form – Operating techniques and supporting information.	04/12/2024
	Non-Technical Summary; BAT Assessment; Environmental Risk Assessment; Figures and drawings; Site Condition Report and Appendices; LGW15&16 Pollution Prevention Response Plans.	31/10/2024
	Air Dispersion modelling Report V1 (Nov 2024)	07/11/2024
	Response to questions 1-7 in Request for Additional information dated 21/11/2024	03/12/2024 & 04/12/2024
Application EPR/EP3022ST/A001 Generators maintenance testing schedule	Generators maintenance testing schedule detailed in application document 'Air Dispersion Modelling Report V1' dated Nov 2024 – section 6.1 and Table 6.1.	07/11/2024

Table S1.2 Operating techniques		
Description	Parts	Date Received
Response to Schedule 5 Notice Request for Information Issued 24/03/2025	Response to questions 1 to 6.	15/04/2025

Table S1.3 Improvement programme requirements		
Reference	Requirement	Date
IC1	<p>Air Quality Management Plan (AQMP)</p> <p>The operator shall produce an AQMP in conjunction with the Local Authority outlining response measures to be taken in the event of a grid failure. This must include, but not be limited to, the following considerations:</p> <ul style="list-style-type: none"> • The response should be tailored to reflect the predicted potential impact indicated by the air dispersion modelling at individual receptors; • Preventative and reactive actions to be implemented to limit the duration of an outage event to less than 50 hours as far as possible; • Specific timescales for response measures; • How local conditions during a grid failure might influence the response required, for example meteorological conditions or time of day; • Contingency for how the response will be carried out in the event scenario i.e. loss of power; • Timescales for continued review of the management plan. <p>The agreed Air Quality Management Plan shall be submitted to the Environment Agency for approval.</p>	05/12/2025
IC2	<p>NOx Reduction Plan</p> <p>The operator shall submit a plan to reduce nitrogen dioxide (NOx) emissions from the standby generators in Unit 2. The plan shall include proposals for reducing NOx emissions from the generators to a level that complies with the minimum build standards set in the Environment Agency's 'Emergency backup diesel engines on installations: best available techniques (BAT) guidance' published 21 August 2023 (Emergency backup diesel engines on installations: best available techniques (BAT) - GOV.UK).</p> <p>The Plan shall include the shortest practical timescale for the implementation of the proposals.</p> <p>The plan and timescale for implementation shall be submitted to the Environment Agency in writing for approval.</p>	05/09/2025

Table S1.3 Improvement programme requirements		
Reference	Requirement	Date
IC3	<p>Monitoring plan - flue gas monitoring requirements</p> <p>The operator shall submit a monitoring plan for approval by the Environment Agency detailing their proposal for the implementation of the flue gas monitoring requirements specified in table S3.1, in line with web guide 'Monitoring stack emissions: low risk MCPs and specified generators' Published 20 March 2024 (formerly known as TGN M5). The plan shall include, but not necessarily be limited to:</p> <ul style="list-style-type: none"> • When the generators are not fitted with sampling ports, a proposal to install them within the shortest practical timeline; • Details of any relevant safety, cost and operational constraints affecting the monitoring regime, in support of any proposed deviation from the testing regime specified in permit table S3.1. 	<p>05/09/2025</p> <p>or as agreed in writing with the Environment Agency</p>

Schedule 2 – Raw materials and fuels

Table S2.1 Raw materials and fuels	
Raw materials and fuel description	Specification
Gas oil or equivalent substitute to be agreed in writing with the Environment Agency	Sulphur content 0.001% (w/w) max

Schedule 3 – Emissions and monitoring

Table S3.1 Point source emissions to air – emission limits and monitoring requirements						
Emission point ref. & location	Source	Parameter	Limit (including unit)	Reference period	Monitoring frequency ^{Note 2}	Monitoring standard or method ^{Note 4}
A1 – A7 from generators as shown in Schedule 7	Gas oil generator exhausts in Unit 2 (New MCP)	Oxides of nitrogen (NO and NO ₂ expressed as NO ₂)	No limit set	In line with web guide 'Monitoring stack emissions: low risk MCPs and specified generators' Published 20 March 2024 (formerly known as TGN M5)	Every 1500 hours of operation or once every five years (whichever comes first). <small>Note 1</small>	In line with web guide 'Monitoring stack emissions: low risk MCPs and specified generators' Published 20 March 2024 (formerly known as TGN M5)
		Carbon monoxide	No limit set	In line with web guide 'Monitoring stack emissions: low risk MCPs and specified generators' Published 20 March 2024 (formerly known as TGN M5)	Every 1500 hours of operation or once every five years (whichever comes first). <small>Note 1</small>	In line with web guide 'Monitoring stack emissions: low risk MCPs and specified generators' Published 20 March 2024 (formerly known as TGN M5)
		Sulphur dioxide	No limit set	-	-	-
		Particulates	No limit set	-	-	-

Table S3.1 Point source emissions to air – emission limits and monitoring requirements						
Emission point ref. & location	Source	Parameter	Limit (including unit)	Reference period	Monitoring frequency ^{Note 2}	Monitoring standard or method ^{Note 4}
A8 – A17 from generators as shown in Schedule 7	Gas Oil generator exhausts in Unit 1 (Existing MCP)	Oxides of nitrogen (NO and NO ₂ expressed as NO ₂)	No limit set	In line with web guide 'Monitoring stack emissions: low risk MCPs and specified generators' Published 20 March 2024 (formerly known as TGN M5)	Every 1500 hours of operation or once every five years (whichever comes first) from date of acceptance of first monitoring measurements under condition 3.5.5 <small>Note 1 & Note 3</small>	In line with web guide 'Monitoring stack emissions: low risk MCPs and specified generators' Published 20 March 2024 (formerly known as TGN M5)
		Carbon monoxide	No limit set	In line with web guide 'Monitoring stack emissions: low risk MCPs and specified generators' Published 20 March 2024 (formerly known as TGN M5)	Every 1500 hours of operation or once every five years (whichever comes first) from date of acceptance of first monitoring measurements under condition 3.5.5 <small>Note 1 & Note 3</small>	In line with web guide 'Monitoring stack emissions: low risk MCPs and specified generators' Published 20 March 2024 (formerly known as TGN M5)
		Sulphur dioxide	No limit set	-	-	-
		Particulates	No limit set	-	-	-
Vents associated with bulk diesel storage tanks	Vents from storage tanks	No parameters set	No limit set	-	-	-
<p>Note 1: Unless otherwise agreed in writing with the Environment Agency as a result of approval of Improvement Condition IC3 of this permit.</p> <p>Note 2: In accordance with condition 3.5.5 of this permit.</p> <p>Note 3: Monitoring applies from 01/01/2030, which is the relevant MCPD compliance date for existing MCP sized between 1-5MWth</p> <p>Note 4: Monitoring requirements are defined at a temperature of 273.15 K, a pressure of 101.3 kPa and after correction for the water vapour content of the waste gases at a standardised O₂ content of 6% for solid fuels, 15% for engines and gas turbines and 3% all other MCPs</p>						

Table S3.2 Point Source emissions to sewer – emission limits and monitoring requirements						
Emission point ref. & location	Source	Parameter	Limit (incl. unit)	Reference period	Monitoring frequency	Monitoring standard or method
S1 on site plan in schedule 7 emission to combined sewer from foul water drainage system	Uncontaminated surface water runoff via oil-water separator	Oil and grease	None visible	Spot sample	Weekly	-
S2 on site plan in schedule 7 emission to combined sewer from surface water drainage system						

Schedule 4 – Reporting

Parameters, for which reports shall be made, in accordance with conditions of this permit, are listed below.

Table S4.1 Reporting of monitoring data			
Parameter	Emission or monitoring point/reference	Reporting period	Period begins
Emissions to air Parameters as required by condition 3.5.1.	A1 to A7	Every 1500 hours of operation or every five years (whichever comes first).	Within four months of the issue date of the permit or the date when the engine is first put into operation, whichever is later. Note 1
Emissions to air Parameters as required by condition 3.5.1.	A8 to A17	Every 1500 hours of operation once or every five years (whichever comes first)	From date of acceptance of first monitoring measurements under condition 3.5.5 Note 1 & Note 2
<p>Note 1: Unless otherwise agreed in writing with the Environment Agency as a result of approval of Improvement Condition IC3.</p> <p>Note 2: Monitoring applies from 01/01/2030, which is the relevant MCPD compliance date for existing MCP sized between 1-5MWth</p>			

Table S4.2 Performance parameters		
Parameter	Frequency of assessment	Units
Gas oil (or equivalent substitute agreed in writing with the Environment Agency) usage	Annually	Tonnes
Generator operation for testing and maintenance	Report to be submitted annually	<ul style="list-style-type: none"> - Total hours for the site (hours), - Total hours per generator (hours), Total number of runs per generator (quantity and dates) - - Number of minutes per run (minutes)
Generator operation during emergency scenario	Within 24 hours if operation commences	<ul style="list-style-type: none"> - Date and time of grid failure, - Number of generators operating immediately after the failure, - Number of generators operating two hours after failure, - Anticipated duration of the mains supply failure (hours)
Generator operation during emergency scenario	Annually	Total number of runs (quantity), duration of runs (hours)

Table S4.3 Reporting forms		
Media/parameter	Reporting format	Date of form
Air	Emissions to Air Reporting Form or other form as agreed in writing by the Environment Agency	Version 1, 08/03/2021
Other performance indicators	Form 'performance 1' or other form as agreed in writing by the Environment Agency	As agreed with the Environment Agency
Generator operation during emergency scenario	Form 'emergency scenario' or other form as agreed in writing by the Environment Agency	As agreed with the Environment Agency

Schedule 5 – Notification

These pages outline the information that the operator must provide.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the EP Regulations.

Part A

Permit Number	
Name of operator	
Location of Facility	
Time and date of the detection	

(a) Notification requirements for any malfunction, breakdown or failure of equipment or techniques, accident, or emission of a substance not controlled by an emission limit which has caused, is causing or may cause significant pollution	
To be notified within 24 hours of detection	
Date and time of the event	
Reference or description of the location of the event	
Description of where any release into the environment took place	
Substances(s) potentially released	
Best estimate of the quantity or rate of release of substances	
Measures taken, or intended to be taken, to stop any emission	
Description of the failure or accident.	

(b) Notification requirements for the breach of a limit	
To be notified within 24 hours of detection unless otherwise specified below	
Emission point reference/ source	
Parameter(s)	
Limit	
Measured value and uncertainty	
Date and time of monitoring	

(b) Notification requirements for the breach of a limit	
To be notified within 24 hours of detection unless otherwise specified below	
Measures taken, or intended to be taken, to stop the emission	

Time periods for notification following detection of a breach of a limit	
Parameter	Notification period

(c) Notification requirements for the breach of permit conditions not related to limits	
To be notified within 24 hours of detection	
Condition breached	
Date, time and duration of breach	
Details of the permit breach i.e. what happened including impacts observed.	
Measures taken, or intended to be taken, to restore permit compliance.	

(d) Notification requirements for the detection of any significant adverse environmental effect	
To be notified within 24 hours of detection	
Description of where the effect on the environment was detected	
Substances(s) detected	
Concentrations of substances detected	
Date of monitoring/sampling	

Part B – to be submitted as soon as practicable

Any more accurate information on the matters for notification under Part A.	
Measures taken, or intended to be taken, to prevent a recurrence of the incident	

Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	
The dates of any unauthorised emissions from the facility in the preceding 24 months.	

Name*	
Post	
Signature	
Date	

* authorised to sign on behalf of the operator

Schedule 6 – Interpretation

“accident” means an accident that may result in pollution.

“application” means the application for this permit, together with any additional information supplied by the operator as part of the application and any response to a notice served under Schedule 5 to the EP Regulations.

“authorised officer” means any person authorised by the Environment Agency under section 108(1) of The Environment Act 1995 to exercise, in accordance with the terms of any such authorisation, any power specified in section 108(4) of that Act.

“emissions to land” includes emissions to groundwater.

“EP Regulations” means The Environmental Permitting (England and Wales) Regulations SI 2016 No.1154 and words and expressions used in this permit which are also used in the Regulations have the same meanings as in those Regulations.

“emissions of substances not controlled by emission limits” means emissions of substances to air, water or land from the activities, either from the emission points specified in schedule 3 or from other localised or diffuse sources, which are not controlled by an emission limit.

“existing MCP” means an MCP first put into operation before 20/12/2018.

“gas oil” includes diesel and is defined in Article 3(19) of the MCPD.

“groundwater” means all water, which is below the surface of the ground in the saturation zone and in direct contact with the ground or subsoil.

“Industrial Emissions Directive” means DIRECTIVE 2010/75/EU OF THE EUROPEAN PARLIAMENT AND OF THE COUNCIL of 24 November 2010 on industrial emissions, as read in accordance with Schedule 1A to the Environmental Permitting (England and Wales) Regulations 2016.

“MCERTS” means the Environment Agency’s Monitoring Certification Scheme.

“Medium Combustion Plant” or “MCP” means a combustion plant with a rated thermal input equal to or greater than 1 MW but less than 50 MW.

“Medium Combustion Plant Directive” or “MCPD” means Directive 2015/2193/EU of the European Parliament and of the Council on the limitation of emissions of certain pollutants into the air from medium combustion plants, as read in accordance with Schedule 1A to the Environmental Permitting (England and Wales) Regulations 2016.

“Net rated thermal input” means the rate at which fuel can be burned at the maximum continuous rating of the appliance multiplied by the net calorific value of the fuel and expressed as megawatts thermal.

“new MCP” means an MCP first put into operation on or after 20/12/2018.

“operating hours” means the time, expressed in hours, during which a combustion plant is operating and discharging emissions into the air, excluding start-up and shut-down periods.

“shut-down” is any period where the plant is being returned to a non-operational state.

“start-up” is any period, where the plant has been non-operational, until fuel has been fed to the plant to initiate steady-state conditions.

“year” means calendar year ending 31 December.

Where a minimum limit is set for any emission parameter, for example pH, reference to exceeding the limit shall mean that the parameter shall not be less than that limit.

Unless otherwise stated, any references in this permit to concentrations of substances in emissions into air means:

- in relation to emissions from combustion processes, the concentration in dry air at a temperature of 273K, at a pressure of 101.3 kPa and with an oxygen content of 3% dry for liquid and gaseous fuels, 6% dry for solid fuels; and/or
- in relation to emissions from non-combustion sources, the concentration at a temperature of 273K and at a pressure of 101.3 kPa, with no correction for water vapour content.

Schedule 7 – Site plan



END OF PERMIT