

Product Recall

Deltronic Security AB Environmental Alarm	
Aspect	Details
Images	Roreium Cabar toronth from Maior societt from 37 focus Roging West Company (M. Company (M. Ed. Mosengrang gata 4 Maior Societt from 37 focus Maior Mai
PSD Number	2511-0104
Product Type	Home Safety/Fire Prevention - Gas/Heat/Smoke Detectors
Product Identifiers	Brand: Deltronic Security AB Model: i10 Label: 4170008319 Affected products: Smoke i10 Art – 8276, Heat i10 Art – 8277, CO i10 Art – 8278 Batch Numbers: Lots 156-158 (inclusive)
Product Description	Smart, remotely monitored smoke detector, heat detector and carbon monoxide alarms. Affected units were manufactured between April 2022 and 4 July 2022.
Country of Origin	Sweden
Counterfeit	No
Risk Level	Serious
Risk Type	Health
Risk Description	The products present a risk of serious harm. Certain units may not provide the necessary alert to the remote monitoring center where fire, smoke or carbon monoxide is detected, when the product's battery is failing. The product does not meet the requirements of the Radio Equipment Regulations 2017.
Corrective Measures	The product has been recalled from end users. To obtain a replacement unit or to ask any questions please contact the Careium Support Team: support.care.uk@careium.com or refer to the following guidance: https://www.careium.co.uk/blog/product-recall-notice-i10-envirnomental-detectors/ .
Online Marketplace	N/A
Notifier	Local Authority Trading Standards