



# **Heat Network Technical Assurance Scheme**

New Build Heat Networks

Assessment Procedures

Consumer Heat System

Phase 2: Design

**HNTAS-NB-AP-CH-P2**

## Version History

| Revision | Notes       | Date     |
|----------|-------------|----------|
| V0.4     | Draft issue | 05/12/25 |

## Disclaimer

The following HNTAS Code document is published in draft format. This document is intended to give the sector early sight of HNTAS requirements in their current stage of development for the purpose of facilitating sector understanding of the scheme.

Draft Code documents, including Technical Specifications and Assessment Procedures, have been reviewed and consulted on through a series of technical workshops with participation from a range of experts from across the heat network industry. The content of this document is still in development and subject to change. Requirements should not be considered as fixed at this stage.

Changes which may be made to this document in future include those to:

- reflect learnings from the New Build and Existing network pilot programmes;
- align with aspects of HNTAS which are subject to public policy consultation;
- align with new requirements in TS1 and MMS;
- align the terminology of this document with that used in other HNTAS documentation;
- rectify errors in this draft version; and
- improve clarity of contents.

The Key Failures set out in the draft Code documents have been identified as a specific area for review, to ensure that:

- all Key Failures enable a binary assessment;
- Key Failures are only included for genuine issues presenting major risks to KPIs, and that moderate or lower risks are considered via non-conformity processes; and
- Key Failures do not duplicate Technical Requirements unless there is a clear justification to do so.

DESNZ will be welcoming feedback on the information in this document via a change management process. This process will run in parallel to the HNTAS policy consultation and DESNZ invites stakeholders to engage with both, once they are open. You can sign up to receive updates on future detailed draft technical documents as they are published by contacting: [heatnetworks@energysecurity.gov.uk](mailto:heatnetworks@energysecurity.gov.uk).

Please be advised that this document references other HNTAS draft Code documents which have not yet been published. References to other documents will also be subject to change following the publication of updated standards. The final version of this document will be released before the launch of HNTAS.

## Note on Phase 4: Operation (initial) and Phase 5: Operation (ongoing)

The New Build Technical Specification and Assessment Procedures Overview (Phase 0) documents indicate that there are separate New Build Code Documents for Phase 4: Operation (initial) and Phase 5: Operation (ongoing).

These documents have since been consolidated to reduce the number of Code Documents, so the Phase 4: Operation documents cover requirements for New Build networks during both initial and ongoing operation.

This change does not impact the assessment of New Build networks in operation, which still occurs:

- after 1 year of operation; and
- after 2 years of operation.


© Crown copyright 2025

This publication is licensed under the terms of the Open Government Licence v3.0 except where otherwise stated.

To view this licence, visit <https://www.nationalarchives.gov.uk/doc/open-government-licence/version/3/> or write to the Information Policy Team, The National Archives, Kew, London TW9 4DU, or email: [psi@nationalarchives.gov.uk](mailto:psi@nationalarchives.gov.uk).

Where we have identified any third-party copyright information you will need to obtain permission from the copyright holders concerned.

## Contents

|   |           |
|---|-----------|
| <b>Foreword</b> .....   | <b>5</b>  |
| <b>Scope</b> .....  | <b>8</b>  |
| <b>References</b> .....   | <b>10</b> |
| Normative references .....  | 10        |
| Informative references.....   | 10        |
| <b>Terms and Definitions</b> .....  | <b>11</b> |
| <b>2. Assessment Procedures for Stage 2: Developed Design and Stage 3: Technical Design</b> ..... | <b>12</b> |
| 2.1. Assessment of Technical Requirements.....  | 12        |
| 2.2. Assessment of Performance Monitoring Requirements .....                                      | 15        |

## Foreword

These Assessment Procedures form part of the UK Government's Heat Network Technical Assurance Scheme (HNTAS, The Scheme) delivered by the Department for Energy Security and Net Zero, in partnership with the Scottish Government and Ofgem. The Department for Energy Security and Net Zero appointed FairHeat as technical author for this document.

The Scheme has been designed and developed in consultation with a range of experts across the heat network industry in the form of Technical Sub-Working Groups, culminating in a series of Technical Specifications and Assessment Procedures to facilitate the validation and verification of performance outcomes of Elements within a Heat Network.

This document contains the Assessment Procedures for a Consumer Heat System Element within a New Build Heat Network in Phase 2: Design.

This document sits within a series of Assessment Procedures for a Consumer Heat System, which features within a wider Code documentation structure, as outlined in Table 1.

These Assessment Procedures have been issued in draft format and will be updated prior to scheme launch.

For further information on the use of this document within the Heat Network Technical Assurance Scheme, please refer to the Heat Network Technical Assurance Scheme – New Build Heat Networks – Scheme Rules – Assessment Regime (HNTAS-NB-SR-XX-AS) document.

## Authors

Lucy Sherburn (FairHeat)

Jake Adamson (FairHeat)

Gareth Jones (FairHeat)

## Technical Sub-Working Group Members

Nathan Barrington (Southern Housing)

Richard Bolton (WSP)

Silas Flytkjaer (SAV and BSI HIU Committee)

Ivan Grahm (Orchard Plumbing)

Steve Harper (Independent)

Valeria Khnykina (FVB and BESA HIU Committee)

Pete Mills (Bosch, MEHNA and BSI HIU Committee)

Matt Oliver (Notting Hill Genesis)

Oliver Pitchers (Metropolitan)

Ian Robinson (Baxi, BESA HIU and BSI HIU Committee)

Ian Spencer (Vital Energi)

Dave Turner (Camden Council)

Andy Yuill (Vattenfall)

Freddie Valletta (FairHeat and BESA HIU Committee)

David Welch (Orbit Group)

## Code Document Structure

### Assessment Procedures

| Document Type         | Element                       |    | Part/Phase        |                      |                   |                       |                    |
|-----------------------|-------------------------------|----|-------------------|----------------------|-------------------|-----------------------|--------------------|
|                       |                               |    | Overview          | Phase 1: Feasibility | Phase 2: Design   | Phase 3: Construction | Phase 4: Operation |
|                       |                               |    | P0                | P1                   | P2                | P3                    | P4                 |
| Assessment Procedures | Energy Centre                 | EC | HNTAS-NB-AP-EC-P0 | HNTAS-NB-AP-EC-P1    | HNTAS-NB-AP-EC-P2 | HNTAS-NB-AP-EC-P3     | HNTAS-NB-AP-EC-P4  |
|                       | District Distribution Network | DD | HNTAS-NB-AP-DD-P0 | HNTAS-NB-AP-DD-P1    | HNTAS-NB-AP-DD-P2 | HNTAS-NB-AP-DD-P3     | HNTAS-NB-AP-DD-P4  |
|                       | Substation                    | SS | HNTAS-NB-AP-SS-P0 | HNTAS-NB-AP-SS-P1    | HNTAS-NB-AP-SS-P2 | HNTAS-NB-AP-SS-P3     | HNTAS-NB-AP-SS-P4  |
|                       | Communal Distribution Network | CD | HNTAS-NB-AP-CD-P0 | HNTAS-NB-AP-CD-P1    | HNTAS-NB-AP-CD-P2 | HNTAS-NB-AP-CD-P3     | HNTAS-NB-AP-CD-P4  |
|                       | Consumer Connection           | CC | HNTAS-NB-AP-CC-P0 | HNTAS-NB-AP-CC-P1    | HNTAS-NB-AP-CC-P2 | HNTAS-NB-AP-CC-P3     | HNTAS-NB-AP-CC-P4  |
|                       | Consumer Heat System          | CH | HNTAS-NB-AP-CH-P0 | HNTAS-NB-AP-CH-P1    | HNTAS-NB-AP-CH-P2 | HNTAS-NB-AP-CH-P3     | N/A                |

Table 1: New Build Network Assessment Procedures structure

## Scope

This document specifies the Assessment Procedures applicable for a Consumer Heat System within a New Build Heat Network in Phase 2: Design.

A Consumer Heat System is defined as the heating and/or cooling, and hot water systems on the consumer side of a Consumer Connection or Substation.

A detailed definition of the Consumer Heat System is contained within the Heat Network Technical Assurance Scheme – New Build Heat Networks – Technical Specification – Consumer Heat System – Overview (HNTAS-NB-TS-CH-P0) document.

Detailed definitions of the Levels of Assessment specified in this document are provided in Heat Network Technical Assurance Scheme – New Build Heat Networks – Assessment Procedures – Consumer Heat System – Overview (HNTAS-NB-AP-CH-P0).

DRAFT



## New Build Heat Networks

There are two stages within Phase 2: Design, which are Stage 2: Developed Design and Stage 3: Technical Design. This is outlined in Figure 1.




Figure 1: HNTAS New Build regime phases and stages

## References

### Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

- Heat Network Technical Assurance Scheme – New Build Heat Networks – Scheme Rules – Assessment Regime (HNTAS-NB-SR-XX-AS)
- Heat Network Technical Assurance Scheme – New Build Heat Networks – Assessment Procedures – Consumer Heat System – Overview (HNTAS-NB-AP-CH-P0)

### Informative references

The following informative references apply to this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

- ISO 17029: Conformity Assessment – General principles and requirements for validation and verification (ISO, 2019)

## Terms and Definitions

For the purposes of this document, the terms and definitions given in the Heat Network Technical Assurance Scheme – Terms and Definitions (HNTAS-XX-TD) document apply.

DRAFT

## 2. Assessment Procedures for Stage 2: Developed Design and Stage 3: Technical Design

### 2.1. Assessment of Technical Requirements

For each HNTAS Technical Requirement, the Assessor shall follow the Assessment Procedures and minimum Level of Assessment specified in Table 2.

| Technical Requirement | Minimum Level of Assessment | Assessment Procedure   |
|-----------------------|-----------------------------|--|
| 2.1.1.                | 3                           | Confirm that the assumptions made and methodology used to calculate peak heat demand and annual heat consumption are in accordance with the applicable technical standard(s).  |
| 2.1.2.                | 3                           | Confirm that the temperatures for the domestic hot water system and individual outlets have been specified and are in accordance with the applicable technical standard(s).  |
| 2.1.3.                | 4                           | Confirm that the inputs, assumptions, and methodology used to calculate the domestic hot water delivery times and the DHW system design are in accordance with the applicable technical standard(s).<br><br>Undertake independent DHW delivery time calculations to confirm the accuracy of a sample of domestic hot water delivery time calculations. |
| 2.1.4.                | 3                           | Review the Consumer Heat System operating temperature assessment to confirm that the assumptions made and methodology used to determine operating temperatures are in accordance with the criteria and the applicable technical standard(s).   |
| 2.1.5.                | 4                           | Review heat emitter sizing to confirm that the inputs and assumptions used are correct, and an appropriate methodology has been used.<br><br>Undertake sample independent calculations to confirm the accuracy of sampled outputs.   |
| 2.1.6.                | 3                           | Review radiator and valves design and specification to ensure they are in accordance with the HNTAS requirement and applicable technical standard(s).  |
| 2.1.7.                | 4                           | Review the space heating distribution pipework pressure drop to confirm that the inputs and assumptions used are correct, and an appropriate methodology has been used.  |

| Technical Requirement | Minimum Level of Assessment | Assessment Procedure  |
|-----------------------|-----------------------------|---|
|                       |                             | Undertake sample independent calculations to confirm the accuracy of sampled outputs.   |
| 2.1.8.                | 3                           | Confirm the presence of wet towel rails, and where present, that the justification provided is valid, that the design does not impact return temperatures and it is in accordance with the HNTAS requirement.   |
| 2.1.9.                | 4                           | <p>Review the space heating distribution pipework sizing to confirm that the inputs and assumptions used are correct, that an appropriate methodology has been used, and it is in accordance with the HNTAS requirement and applicable technical standard(s).</p> <p>Undertake sample independent calculations to confirm the accuracy of sampled outputs.</p>  |
| 2.1.10.               | 5                           | <p>Undertake an in-depth review of the working pressure assessment to confirm that the assumptions made, the methodology used to calculate working pressures, and the outputs of the assessment are reasonable given the design characteristics of the system and are in accordance with the applicable technical standard(s).</p> <p>Where required, undertake independent calculations to confirm the accuracy of the working pressure assessment.</p> <p>Confirm that the identification and assessment of risks from the working pressure assessment has been undertaken in accordance with the applicable technical standard(s) and that mitigation measures have been considered and implemented where appropriate.</p> |
| 2.1.11.               | 5                           | Undertake an in-depth review to confirm that the Water Quality Strategy is in accordance with the applicable technical standard(s) and is suitable given the system characteristics.  |
| 2.1.12.               | 2                           | Confirm that a Water Quality Strategy has been provided. No review of contents is required.   |
| 2.1.13.               | 3                           | Confirm that oxygen ingress has been minimised in accordance with the applicable technical standard(s).   |
| 2.1.14.               | 3                           | Confirm that the risk of areas of stagnation has been mitigated in accordance with the applicable technical standard(s).  |

| Technical Requirement | Minimum Level of Assessment | Assessment Procedure  |
|-----------------------|-----------------------------|---|
| 2.1.15.               | 3                           | Confirm that water quality equipment has been specified in accordance with the applicable technical standard(s).  |
| 2.1.16.               | 3                           | Review the outline commissioning plan to confirm the inputs are correct, key items are present, the time order of activities appears reasonable and is in accordance with the applicable technical standard(s).<br><br>This Assessment Procedure is only applicable at Stage 3.   |
| 2.1.17.               | 3                           | Review the Acceptance Testing methodology and criteria to confirm that the inputs and criteria are correct and key items required to demonstrate performance are present.<br><br>This Assessment Procedure is only applicable at Stage 3.   |
| 2.1.18.               | 3                           | Review the list of specialist Heat Network design items to be completed at the Construction Design stage to confirm that the performance specification is present, specification requirements are appropriate for the item type and the applicable HNTAS standards are present.<br><br>This Assessment Procedure is only applicable at Stage 3. |
| 2.1.19.               | 4                           | Review the required drawings and schematics to confirm they are in accordance with the applicable technical standard(s).  |
| 2.1.20.               | 4                           | Confirm that the Technical Parameters Schedule has been completed (all parameters present, and references to correct documents present).<br><br>Undertake a review of a sample of parameters to confirm the accuracy of sampled outputs.  |

*Table 2: Assessment Procedures for Technical Requirements at Stage 2: Developed Design and Stage 3: Technical Design for the Consumer Heat System*

## 2.2. Assessment of Performance Monitoring Requirements

For each HNTAS Performance Monitoring Requirement, the Assessor shall follow the Assessment Procedures and minimum Level of Assessment specified in Table 3.

| Performance Monitoring Requirement | Minimum Level of Assessment | Assessment Procedure   |
|------------------------------------|-----------------------------|--|
| 2.2.1.                             | 4                           | <p>Review the KPI Schedule and ensure that the applicable Consumer Heat System KPIs are present, and the schedule contains the required content.</p> <p>Undertake sample check of KPIs, to confirm suitability of KPI thresholds and required measurement points for sampled KPIs.</p> |

*Table 3: Assessment Procedures for Performance Monitoring Requirements at Stage 2: Developed Design and Stage 3: Technical Design for the Consumer Heat System*