




Aginode LANmark-OF Micro-Bundle Universal 12x Multimode Cable

Aspect	Details
Images	
PSD Number	2507-0172
Product Type	Construction products – Cable/Wire Conduit/Ducting/Raceways
Product Identifiers	Brand: Aginode Diameter: 6.4mm Unique product ID: N167.MBUN12-AB Product Marking: LANmark OF by Nexans Micro-Bundle Universal-(U-DQ(ZN)BH)- 12XMM 50/125 OM4 – LSZH - B2ca S1a d0 a1 - FB – COUNTRY OF ORIGIN BELGIUM - 101455863 - XXXXXM Drum batch Number - 267706/2
Product Description	Internet LAN network cable.
Country of Origin	Belgium
Counterfeit	No
Risk Level	Not provided
Risk Type	Fire
Risk Description	Testing has indicated that the product failed to achieve its declared reaction to fire performance. The reaction to fire performance declared in the Manufacturers Declaration of Performance is class B2ca-s1a,d0,a1. Independent testing has indicated that the performance achieved by the product was Fca. The product therefore may not perform to the to the declared reaction to fire performance.
Corrective Measures	Aginode Belgium have withdrawn this batch of product from the market. Aginode Belgium have recalled the product from the supply chain in the UK and issued a warning notice to end users that the product may not meet its declared performance. The potential impact of lower performance of a product in relation to reaction



Product Recall

	to fire and building safety will vary on a project-by-project basis and will depend on factors unique to each building. Aginode have written to customers in the UK advising them that those who selected the identified product relying upon the declared reaction to fire Class of B2ca-s1a,d0,a1 are warned that the actual performance of this product may not achieve B2ca-s1a,d0,a1 classification and they should consider whether the lack of performance to Class B2ca-s1a,d0,a1 is material to the fire performance of the setting it is used in. Aginode have written to customers in the UK advising those responsible for buildings to consider whether this shortfall in performance affects the fire safety of the environment in which the product is used.
Online Marketplace	N/A
Notifier	Office for Product Safety and Standards