HS2

August 2026

Construction noise and vibration Monthly Report – August 2026

Solihull Metropolitan Borough Council

© HS2 Ltd.

Index

Non-Technical Summary

Abbreviations and Descriptions

1. Introduction

1.2 Measurement Locations

2. Summary of Results

2.1 Summary of Measured Noise and Vibration Levels

2.2 Exceedances of the LOAEL and SOAEL

Appendix A Site Locations

Appendix B Monitoring Locations

Appendix C Data

List of tables

Table 1: Table of Abbreviations

Table 2: Monitoring Locations

Table 3: Summary of Measured dB LAeq Data over the Monitoring Period

Table 4: Summary of Measured PPV Data over the Monitoring Period

Table 5: Summary of Exceedances of LOAEL and SOAEL

Table 6: Summary of Total Exceedances of SOAEL

Table 7: Summary of Exceedances of Trigger Levels

Table 8: Summary of Complaints

Non-Technical Summary

This Noise and Vibration Monitoring Report fulfils HS2 Limited's commitment detailed in the Environmental Minimum Requirements (EMRs), Annex 1, Code of Construction Practice, to present the results of noise and vibration monitoring carried out within Solihull Metropolitan Borough Council during the month of August 2026.

Within this period monitoring was undertaken at the following worksites:

- Coleshill Heath Road worksite (ref.: CHR), where no works were undertaken.
- Bickenhill Cutting worksite (ref.: BIC), where earthworks, culvert construction and landscape fill works were underway.
- Birmingham Interchange Station worksite (ref.: BIS), where earthworks, and embankment works were underway.
- Diddington Lane Embankment (ref.: DLE), where embankment works were underway.
- Blythe Bypass Embankment Worksite (ref.: BBE), where excavation and working platform installation, formwork installation, concrete works, waterproofing works, and earthwork activities were underway.
- A452 compound (ref.: A452), where ditch and culvert installation works and haul road operation activities were underway.
- Park Lane Worksite (ref.: PL) where drainage works, culvert dig and replace, earthworks, protection slab installation, concrete works and utility works were underway.
- Balsall Common Viaduct Worksite (ref.: BCV) where bridge deck works (rebar fixing and formwork), rebar installation, platform installation works, and waterproofing works were underway.
- Carol Green Rail Underbridge Worksite (ref.: CGRU), where underbridge works, piling and water proofing works were underway.
- Waste Lane Overbridge and Satellite Worksite (ref.: WLOS), where no works were undertaken.

There were no exceedances of the HS2 threshold levels for significant noise impacts during the reporting period at any monitoring position.

There were no exceedances of trigger levels as defined in section 61 consents during the reporting period at any monitoring position.

No complaints were received during the monitoring period

Abbreviations and Descriptions

The abbreviations, descriptions and project terminology used within this report can be found in Table 1.

Table 1: Table of Abbreviations

Acronym/Term	Definition
LAeq,T	See equivalent continuous sound pressure level.
Ambient Sound	A description of the all-encompassing sound at a given location and time which will include sound from many sources near and far. Ambient sound can be quantified in terms of the equivalent continuous sound pressure level, LpAeq,T
Decibel(s), or dB	Between the quietest audible sound and the loudest tolerable sound there is a million to one ratio in sound pressure (measured in Pascal (Pa)). Because of this wide range, a level scale called the decibel (dB) scale, based on a logarithmic ratio, is used in sound measurement. Audibility of sound covers a range of approximately 0-140dB.
Decibel(s) A-weighted, or dB(A)	The human ear system does not respond uniformly to sound across the detectable frequency range and consequently instrumentation used to measure sound is weighted to represent the performance of the ear. This is known as the 'A weighting' and is written as 'dB(A)'.
Equivalent continuous sound pressure level, or LAeq,T	An index used internationally for the assessment of environmental sound impacts. It is defined as the notional unchanging level that would, over a given period of time (T), deliver the same sound energy as the actual time-varying sound over the same period. Hence fluctuating sound levels can be described in terms of an equivalent single figure value, typically expressed as a decibel level.
Exclusion of data	Measurement of noise levels can be affected by weather conditions such as prolonged periods of rain, winds speeds higher than 5m/s and snow/ice ground cover. Noise levels measured during these periods are considered not representative of normal noise conditions at the site and, for the purposes of this report, are excluded from the assessment of exceedances and calculation of typical noise levels and are also greyed out in charts. Identifiable incongruous noise and vibration events not attributable to HS2 construction noise are also excluded.
Façade	A facade noise level is the noise level 1m in front of a large reflecting surface. The effect of reflection, is to produce a slightly higher (typically +2.5 to +3 dB) sound level than it would be if the reflecting surface was not there.
Free-field	A free-field noise level is the noise level measured at a location where no reflective surfaces, other than the ground, lies within 3.5 metres of the microphone position.
LOAEL	Lowest Observed Adverse Effect Level - the level above which adverse effects on health and quality of life can be detected.
Peak particle velocity, or PPV	Instantaneous maximum velocity reached by a vibrating element as it oscillates about its rest position. The PPV is a simple indicator of perceptibility and risk of damage to structures due to vibration. It is usually measured in mm/s.
SOAEL	Significant Observed Adverse Effect Level - the level above which significant adverse effects on health and quality of life occur.

Sound pressure level	The parameter by which sound levels are measured in air. It is measured in decibels. The threshold of hearing has been set at 0dB, while the threshold of pain is approximately 120dB. Normal speech is approximately 60dB at a distance of 1 metre and a change of 3dB in a time varying sound signal is commonly regarded as being just detectable. A change of 10dB is subjectively twice, or half, as loud.
Vibration dose value, or VDV	An index used to evaluate human exposure to vibration in buildings. While the PPV provides information regarding the magnitude of single vibration events, the VDV provides a measure of the total vibration experienced over a specified period of time (typically 16h daytime and 8h night-time). It takes into account the magnitude, the number and the duration of vibration events and can be used to quantify exposure to continuous, impulsive, occasional and intermittent vibration. The vibration dose value is measured in $m/s^{1.75}$.

1 Introduction

1.1.1 HS2 is required to undertake noise (and vibration) monitoring as necessary to comply with the requirements of the High Speed Rail (London-West Midlands) Environmental Minimum Requirements, including specifically Annex 1: Code of Construction Practice, in addition to any monitoring requirements arising from conditions imposed through consents under Section 61 of the Control of Pollution Act, 1974 or through Undertakings & Assurances given to third parties. Such monitoring may be undertaken for the following purposes:

- monitoring the impact of construction works;
- to investigate complaints, incidents and exceedance of trigger levels; or
- monitoring the effectiveness of noise and vibration control measures.

Monitoring data and interpretive reports are to be provided to each relevant local authority on a monthly basis and shall include a summary of the construction activities occurring, the data recorded over the monitoring period, any complaints received, any periods in exceedance of agreed trigger levels, the results of any investigations and any actions taken or mitigation measures implemented. This report provides noise data, and interpretation thereof, for monitoring carried out by HS2 within the Solihull Metropolitan Borough Council (SMBC) area for the period 1-31 August 2026.

1.1.2 Active construction sites in the local authority area during this period include:

- Coleshill Heath Road worksite, ref.: CHR (see Plan 1 in Appendix A), where no works were undertaken.
- Birmingham Interchange Station worksite, ref.: BIS (see Plan 2 in Appendix A), where works activities included:
    - Earthworks
    - Embankment cut works
- Bickenhill Cutting worksite, ref.: BIC (see Plan 2 in Appendix A), where works activities included:
    - Earthworks
    - Culvert construction
    - Landscape works
- Diddington Lane Embankment worksite: ref.: DLE (see Plan 2 in Appendix A), where works activities included:
    - Embankment works
- Blythe Bypass Embankment worksite, reference - BBE (see plan 3 in Appendix A), where works activities included:
    - Excavation and working platform installation
    - Formwork installation
    - Concrete works
    - Waterproofing works
    - Earthworks
- A452 worksite, reference - A452 (see plan 4 in Appendix A), where work activities included:
    - Ditch installation
    - Culvert installation
    - Haul road operation
- Park Lane worksite, reference - PL (see plan 5 in Appendix A), where work activities included:

    - Drainage works
    - Culvert dig and replace
    - Earthworks
    - Haul road operation
    - Protection slab installation
    - Concrete works
    - Utility works
- Carol Green Rail Underbridge worksite, reference - CGRU (see plan 6 in Appendix A), where work activities included:
    - Underbridge works
    - Piling
    - Water proofing works
- Balsall Common Viaduct worksite, reference - BCV (see plan 6 in Appendix A), where work activities included:
    - Bridge deck works (rebar fixing and formwork)
    - Rebar installation
    - Platform installation
    - Waterproofing works
- Waste Lane Overbridge and Satellite worksite, reference WLOS (see plan 7 in Appendix A), where no works were undertaken.

1.1.3 The applicable standards, guidance, and monitoring methodology is outlined in the construction noise and vibration monitoring methodology report which can be found at the following location https://www.gov.uk/government/collections/monitoring-the-environmental-effects-of-hs2. Noise and vibration monitoring reports for previous months can also be found at this location.

1.2 Measurement Locations

1.2.1 19 noise and 11 vibration monitoring installations were active in August in the Solihull Metropolitan Borough Council area. Tables 2a and 2b summarise the position of noise and vibration monitoring installations within the Solihull Metropolitan Borough Council area in August 2026.

1.2.2 Maps showing the position of noise and vibration monitoring installations are presented in Appendix B.

Table 2a: Noise Monitoring Locations

Worksite Reference	Measurement Reference	Address
A452	A452-N1	Marsh House Farm, Brandocks Marsh, Solihull
BBE	BBE-N1	Patricks Farm Meriden Road, Hampton-In-Arden, Solihull
BCV	BCV-N1	Cherry Tree Cottage, Truggist Lane, Balsall Common, Solihull
BIC	BIC-N1	Park Farm Barns, Chester Rd, Marston Green, Coventry
BIS	BIS-N1	(East of) Middle Bickenhill Lane, Bickenhill and Marston Green
CGRU	CGRU-N1	The Stables, Truggist Lane, Balsall Common, Solihull
CHR	CHR-N1	Fillingham Court, Coleshill Heath Road, Solihull,
CHRU	CHRU-N1	276 Yorkminster Drive, Birmingham
DLE	DLE-N1	Hampton Hill Hounds, Nursery Cottage, Coventry Rd, Bickenhill

	DLE-N2	Diddington Ln, Hampton in Arden, Solihull
	DLE-N3	Diddington Ln, Hampton in Arden, Solihull
PL	PL-N1	(east of) Final Home, Park Lane, Balsall Common, Coventry
	PL-N2	(North of) The Laurel, Balsall Common, Coventry
	PL-N3	(east of) Holly Acre Lodge, Kenilworth Road, Solihull
	PL-N5	Lavender Hall Lane Barn, Berkswell, Coventry
	PL-N7	Hornbrook Cottage, A452 Kenilworth Road, Balsall Common
WLOS	WLOS-N1	19 Hodgetts Lane, Burton Green, Warwickshire
	WLOS-N2	Little Beanitt Farm, Waste Lane, Balsall Common, Solihull
	WLOS-N3	(north of) Dragonflies, Waste Lane, Balsall Common, Solihull

Table 2b: Vibration Monitoring Locations

Worksite Reference	Measurement Reference	Address
A452	A452-V1	(north of) Barretts Lane, Balsall Common
BBE	BBE-V2	Patricks Farm, Meriden Road, Hampton-In-Arden, Solihull
BCV	BCV-V6	Cherry Tree Cottage, Truggist Lane, Balsall Common, Solihull
CHRU	CHRU-V1	276 Yorkminster Drive, Birmingham
DLE	DLE-V1	Hampton Hill Hounds, Nursery Cottage, Coventry Rd, Bickenhill, Hampton in Arden
PL	PL-V2	(east of) Final Home, Park Lane, Balsall Common, Coventry
	PL-V3	Lavender Hall Lane Barn, Berkswell, Coventry
	PL-V4	(east of) Holly Acre Lodge, Kenilworth Road, Solihull
WLOS	WLOS-V1	19 Hodgetts Lane, Burton Green, Warwickshire
	WLOS-V2	Little Beanitt Farm, Waste Lane, Balsall Common, Solihull
	WL-V12	Old Hall, Waste Lane, Berkswell

2 Summary of Results

2.1 Summary of Measured Noise and Vibration Levels

2.1.1 Table 3 presents a summary of the measured noise levels at each monitoring location over the reporting period. The LAeq,T is presented for each of the relevant time periods averaged over the calendar month, along with the highest single period LAeq,T that was found to occur within the month.

Table 3: Summary of Measured dB LAeq Data over the Monitoring Period

Worksite Reference.	Measurement Reference	Site Address	Free-Field or Façade Measurement	Weekday Average LAeq,T (Highest Day LAeq,T)					Saturday Average LAeq,T (Highest Day LAeq,T)					Sunday / Public Holiday LAeq,T (Highest Day LAeq,T)	
				0700 - 0800	0800 - 1800	1800 - 1900	1900 - 2200	2200 - 0700	0700 - 0800	0800 - 1300	1300 - 1400	1400 - 2200	2200 - 0700	0700 - 2200	2200 - 0700
BBE	BBE-N1	Patricks Farm Meriden Road, Hampton-In-Arden	Free field	52.0 (57.9)	62.0 (69.5)	50.9 (58.3)	48.1 (51.4)	45.3 (53.0)	50.0 (51.4)	52.6 (65.3)	49.4 (50.9)	48.1 (51.7)	43.8 (47.8)	48.5 (52.0)	45.0 (52.2)
WLOS	WLOS-N1	19 Hodgetts Lane, Burton Green	Facade	44.9 (52.1)	52.4 (57.3)	44.8 (51.1)	41.2 (53.2)	37.3 (51.3)	44.0 (45.1)	54.4 (59.4)	46.3 (55.0)	41.6 (51.9)	37.5 (45.5)	42.2 (49.1)	38.1 (51.4)
	WLOS-N2	Litte Beanitt Farm, Waste Lane	Free field	48.8 (54.3)	60.2 (65.3)	44.8 (53.3)	43.1 (53.9)	38.7 (46.0)	44.9 (45.9)	47.8 (50.7)	46.2 (49.2)	42.8 (46.2)	37.6 (46.7)	43.5 (49.8)	39.1 (49.0)
	WLOS-N3	Dragonflies, Waste Lane, Berkswell	Free field	60.2 (62.2)	61.0 (62.5)	58.8 (62.1)	55.8 (64.3)	50.5 (57.4)	55.4 (56.1)	60.7 (65.0)	59.1 (61.8)	56.6 (59.2)	48.8 (55.0)	57.3 (67.7)	50.4 (57.5)
BCV	BCV-N1	Cherry Tree Cottage, Truggist Lane, Balsall Common	Free field	56.4 (71.4)	62.1 (65.3)	55.8 (59.9)	53.5 (60.4)	47.6 (55.9)	55.4 (67.9)	57.6 (62.2)	55.6 (57.3)	54.7 (60.7)	47.6 (52.8)	53.9 (59.7)	47.6 (55.2)
CGRU	CGRU-N1	The Stables, Truggist Lane, Balsall Common	Free field	54.3 (57.9)	57.5 (68.4)	51.9 (54.8)	52.2 (55.6)	51.0 (57.1)	52.6 (54.1)	53.6 (55.0)	53.1 (53.9)	52.7 (55.1)	47.1 (55.9)	52.1 (55.3)	51.0 (55.7)
A452	A452-N1	Marsh House Farm, Brandocks Marsh	Free field	52.2 (56.1)	53.8 (62.4)	49.7 (53.5)	47.2 (51.4)	45.8 (55.9)	50.0 (51.3)	48.8 (51.2)	46.6 (50.2)	46.5 (51.1)	43.0 (48.2)	47.4 (55.6)	44.9 (51.4)
BIS	BIS-N1	(East of) Middle Bickenhill Lane	Free field	52.9 (55.6)	53.5 (67.7)	52.1 (61.1)	49.5 (55.1)	49.1 (56.4)	51.1 (53.9)	47.9 (50.4)	48.5 (50.1)	48.1 (53.6)	48.9 (56.7)	48.7 (54.8)	48.3 (56.7)
CHRU	CHRU-N1	276 Yorkminster Drive, Birmingham	Free field	58.6 (63.0)	59.3 (61.7)	58.9 (63.8)	58.2 (62.7)	55.5 (62.4)	55.9 (61.3)	57.0 (61.4)	57.2 (61.0)	57.1 (61.7)	54.3 (60.1)	56.6 (61.2)	55.8 (62.7)
DLE	DLE-N1	Hampton Hill Hounds, Nursery Cottage, Coventry Rd, Bickenhill,	Free field	52.1 (60.7)	54.1 (68.4)	50.2 (57.9)	48.5 (59.3)	47.9 (56.1)	50.8 (54.2)	47.9 (49.8)	49.8 (54.1)	52.6 (62.0)	48.3 (59.8)	49.6 (59.4)	47.1 (54.5)
	DLE-N2	44 Diddington Ln, Hampton in Arden,	Free field	50.4 (54.2)	53.5 (62.3)	47.8 (56.5)	47.6 (52.4)	47.4 (53.0)	50.0 (52.7)	56.1 (60.0)	47.6 (51.8)	46.5 (50.4)	47.0 (52.2)	46.5 (56.8)	47.5 (52.2)
	DLE-N3	Diddington Ln, Hampton in Arden, Solihull	Free field	53.8 (56.3)	55.6 (60.8)	50.4 (59.9)	47.2 (51.3)	47.2 (55.0)	52.1 (54.1)	54.0 (60.4)	49.7 (54.1)	46.7 (51.0)	46.1 (53.2)	47.4 (52.1)	47.2 (53.9)

CHR	CHR-N1	Fillingham Court, Coleshill Heath Road	Free field	60.1 (64.7)	63.1 (74.5)	60.0 (65.1)	58.8 (63.9)	55.9 (64.7)	58.3 (62.3)	59.9 (65.6)	59.9 (65.6)	60.3 (66.8)	56.1 (67.6)	60.3 (64.8)	57.0 (64.4)
BIC	BIC-N1	Park Farm Barns, Chester Rd	Free field	55.7 (59.3)	54.9 (57.2)	53.6 (59.4)	51.4 (54.8)	50.6 (58.8)	53.2 (55.1)	51.6 (54.7)	51.7 (55.1)	49.4 (54.4)	49.6 (56.6)	50.1 (55.1)	49.1 (55.4)
PL	PL-N1	Park Farm Barns, Chester Rd	Free field	54.6 (56.4)	60.3 (64.0)	52.2 (68.5)	46.2 (52.7)	44.6 (68.3)	46.7 (47.8)	50.5 (54.6)	47.4 (49.8)	44.5 (49.8)	41.8 (48.2)	46.1 (51.7)	43.8 (51.8)
	PL-N2	(North of) The Laurel, Balsall Common	Free field	50.4 (56.9)	59.9 (66.0)	54.0 (64.2)	42.8 (53.5)	39.5 (51.1)	43.6 (44.9)	48.0 (50.3)	45.0 (48.7)	41.7 (46.5)	36.7 (40.1)	42.2 (49.0)	39.6 (49.5)
	PL-N3	(east of) Holly Acre Lodge, Kenilworth Road	Free field	57.7 (59.6)	59.0 (65.0)	55.0 (61.2)	50.0 (61.1)	47.3 (56.6)	49.4 (52.0)	50.6 (55.0)	50.0 (53.4)	48.6 (56.4)	44.3 (52.3)	51.1 (67.8)	46.7 (54.4)
	PL-N5	Lavender Hall Lane Barn, Berkswell,	Free field	47.5 (60.8)	60.3 (65.6)	52.4 (63.9)	43.2 (54.7)	39.3 (51.3)	43.3 (45.5)	50.7 (64.1)	47.9 (53.5)	41.6 (46.2)	37.2 (44.3)	43.2 (52.1)	39.4 (49.6)
	PL-N7	Hornbrook Cottage, A452 Kenilworth Road, Balsall Common	Free field	51.0 (54.6)	53.9 (58.4)	49.0 (53.6)	47.2 (53.3)	45.6 (53.5)	48.7 (51.0)	48.4 (52.0)	49.3 (54.4)	46.4 (52.6)	42.5 (48.5)	47.1 (53.3)	45.0 (52.1)

2.1.2 Table 4: Summary of Measured PPV Data over the Monitoring Period presents a summary of the measured vibration levels at each monitoring location over the reporting period. The highest PPV measured during the monitoring along any axis is presented in the table.

Table 4: Summary of Measured PPV Data over the Monitoring Period

Worksite Reference	Measurement Reference	Monitor Address	Highest PPV measured in any axis, mm/s
A452	A452-V1	(north of) Barretts Lane, Balsall Common	3.52 (Z-axis)
BBE	BBE-V2	Patricks Farm, Meriden Road, Hampton-In-Arden, Solihull	2.95 (Y-axis)
BCV	BCV-V6	Cherry Tree Cottage, Truggist Lane, Balsall Common, Solihull	1.66 (Y-axis)
CHRU	CHRU-V1	276 Yorkminster Drive, Birmingham	1.20 (X-axis)
DLE	DLE-V1	Hampton Hill Hounds, Nursery Cottage, Coventry Rd, Bickenhill, Hampton in Arden, Solihull	1.22 (Z-axis)
PL	PL-V2	(east of) Final Home, Park Lane, Balsall Common, Coventry	0.96 (Y-axis)
	PL-V3	Lavender Hall Lane Barn, Berkswell, Coventry	2.65 (X-axis)
	PL-V4	(east of) Holly Acre Lodge, Kenilworth Road, Solihull, West Midlands	6.23 (Y-axis)
WLOS	WL-V12	Old Hall, Waste Lane, Berkswell, Metropolitan Borough of Solihull, West Midlands	0.98 (X-axis)
	WLOS-V1	19 Hodgetts Lane, Burton Green, Warwickshire	1.21 (X-axis)
	WLOS-V2	Little Beanitt Farm, Waste Lane, Balsall Common, Solihull	1.33 (X-axis)

2.1.3 Appendix C presents graphs of the noise and vibration monitoring data over the month for each of the measurement locations. Noise data presented consists of the hourly LAeq values and, where relevant, the LAeq,T values (where the time period T has been taken to be the averaging period as specified in Table 1 of HS2 Information Paper E23). Vibration data presented consist of hourly PPV values. The full data set for the monitoring equipment can be found at the following location: https://data.gov.uk/dataset/24542ae7-dd44-444f-b259-871c4cc43b5e/environmental-monitoring-data.

2.2 Exceedances of the LOAEL and SOAEL

2.2.1 The lowest observed adverse effect level (LOAEL) is defined in the Planning Practice Guidance – Noise (PPG) as the level above which "noise starts to cause small changes in behaviour and/or attitude, e.g. turning up volume of television; speaking more loudly; where there is no alternative ventilation, having to close windows for some of the time because of the noise. Potential for some reported sleep disturbance. Affects the acoustic character of the area such that there is a perceived change in the quality of life".

2.2.2 The significant observed adverse effect level (SOAEL) is defined in the 'Planning Practice Guidance – Noise' as the level above which "noise causes a material change in behaviour and/or attitude, e.g. avoiding certain activities during periods of intrusion; where there is no alternative ventilation, having to keep windows closed most of the time because of the noise. Potential for sleep disturbance resulting in difficulty in getting to sleep, premature awakening and difficulty in getting back to sleep. Quality of life diminished due to change in acoustic character of the area."

2.2.3 HS2 Phase One Information Paper E23: Control of Construction Noise and Vibration sets out the LOAEL and SOAELs for construction noise.

2.2.4 Where construction noise levels exceed the SOAEL, relevant periods will be identified, and summary statistics provided in order to evaluate ongoing qualification for noise insulation and temporary rehousing.

2.2.5 Table 5 presents a summary of recorded exceedances of the LOAEL and SOAEL at each measurement location over the reporting period, including the number of exceedances during each time period.

Table 5: Summary of Exceedances of LOAEL and SOAEL

Worksite Reference	Measurement Reference	Site Address	Day (Weekday, Saturday, Sunday, Night)	Time period	Number of exceedances of LOAEL	Number of exceedances of SOAEL
A452	A452-N1	Marsh House Farm	Weekday	All periods	No exceedances	No exceedances
BBE	BBE-N1	Patrick Farm House	Weekday	0800 - 1800	7	No exceedances
BCV	BCV-N1	Cherry Tree Cottage	Weekday	0700 - 0800	2	No exceedances
				0800 - 1800	6	No exceedances
			Saturday	0700 - 0800	1	No exceedances

BIC	BIC-N1	Park Farm Barns	Weekday	All periods	No exceedances	No exceedances
BIS	BIS-N1	Hollywell Brook, Middle Bickenhill Lane	Weekday	0800 - 1800	1	No exceedances
CGRU	CGRU-N1	(south east of) Annora House, Station Road, Berkswell, Balsall Common, Solihull	Weekday	0800 - 1800	1	No exceedances
CHR	CHR-N1	276 Yorkminster Drive, Birmingham	Weekday	All periods	No exceedances	No exceedances
CHRU	CHRU-N1	276 Yorkminster Drive, Birmingham	Weekday	All periods	No exceedances	No exceedances
DLE	DLE-N1	Hampton Hill Farmhouse, Coventry Road	Weekday	0700 - 0800 0800 - 1800	1 1	No exceedances No exceedances
	DLE-N2	Diddington Ln, Hampton in Arden	Weekday	All periods	No exceedances	No exceedances
	DLE-N3	Diddington Ln, Hampton in Arden, Solihull	Weekday	All periods	No exceedances	No exceedances
PL	PL-N1	east of) Final Home, Park Lane, Balsall Common, Coventry	Weekday	0800 - 1800	1	No exceedances
	PL-N2	(North of) The Laurel, Balsall Common, Coventry	Weekday	0800 - 1800	2	No exceedances
	PL-N3	(east of) Holly Acre Lodge, Kenilworth Road, Solihull, West Midlands	Weekday	0800 - 1800	1	No exceedances
	PL-N5	Lavender Hall Lane Barn, Berkswell, Coventry	Weekday Saturday	0700 - 0800 0800 - 1800 0800 - 1300	2 9 1	No exceedances No exceedances No exceedances
	PL-N7	Mercote Lodge and Hornbrook Cottage, A452 Kenilworth Road, Balsall Common	Weekday	All periods	No exceedances	No exceedances

WLOS	WLOS-N1	Little Beanitt Farm, Waste Lane	Weekday	All periods	No exceedances	No exceedances
	WLOS-N2	Old Hall, Waste Lane,	Weekday	All periods	No exceedances	No exceedances
	WLOS-N3	19 Hodgetts Lane	Weekday	All periods	No exceedances	No exceedances

2.2.6 There were exceedances of the LOAEL, during August 2026, due to HS2 construction works.

2.2.7 For the purpose of assessing eligibility for noise insulation or temporary rehousing, multiple exceedances of the SOAEL in a 24-hour period would be counted as a single exceedance during that day. Over the reporting period, the overall number of SOAEL exceedances at each measurement location is shown in Table 6 and may be lower than the total sum of individual exceedances reported in Table 5 for each location.

Table 6: Summary of Total Exceedances of SOAEL

Worksite Reference	Measurement Reference	Monitor Address	Total of SOAEL exceedances in the month
-	-	-	-

2.3 Exceedances of Trigger Level

2.3.1 Table 7 provides a summary of exceedances of the S61 trigger noise levels determined to be due to HS2 related construction noise measured during the reporting period, along with the findings of any investigation.

Table 7: Summary of Exceedances of Trigger Levels

Complaint Reference Number (if applicable)	Worksite Reference	Date and Time Period	Identified Source	Results of Investigation (including noise monitoring results)	Actions Taken
-	-	-	-	-	-

2.4 Complaints


2.4.1 Table 8 provides a summary of complaint information related to noise and vibration received during the reporting period, along with the findings of any investigation.

Table 8: Summary of Complaints


Complaint Reference Number	Worksite Reference	Description of Complaint	Results of Investigation	Actions Taken
-	-	-	-	-

Appendix A Site Locations

HS2 **Worksite Identification Plan - Overview**




Worksite Identification Plan - 1



HS2

Worksite Identification Plan - 2




Legend

Active Worksites


HS2

Worksite Identification Plan - 3




HS2

Worksite Identification Plan - 4




HS2

Worksite Identification Plan - 5




HS2

Worksite Identification Plan - 6



HS2

Worksite Identification Plan - 7




Legend


Active Worksites

Appendix B Monitoring Locations


HS2 **Noise and Vibration Monitoring Plan - 1**




HS2 Noise and Vibration Monitoring Plan - 2




HS2 **Noise and Vibration Monitoring Plan - 3**




HS2 Noise and Vibration Monitoring Plan - 4




HS2 Noise and Vibration Monitoring Plan - 5




HS2 Noise and Vibration Monitoring Plan - 6




Moat House Farm
BCV-1
BCV-V6
BCV
Berkswell House
TRUGGIST LANE
Berkswell
CGRU-1
CGRU
Truggist Hill Farm
N
Contains Ordnance Survey data © Crown copyright and database right 2020
Legend
Noise Monitor
Vibration Monitor
Active Worksites

Noise and Vibration Monitoring Plan - 8





Appendix C Data

Noise


The following graphs show the hourly measured ambient noise level LAeq,1h and, where relevant, the averaged noise level LAeq,T values, where the time period T is as specified in Table 1 of HS2 Information Paper E23. Periods where noise levels are adversely affected by weather or only measured for part of the period, which are not representative of HS2 construction works, have been greyed out and excluded from the calculation of the LAeq,T values in in Table 3 of the main report.

Worksite: BIS - Monitoring Ref: BIS-N1







Worksite: BIS Monitoring Ref: BIS-N1 15 August 2026 to 21 August 2026



Worksite: BIS Monitoring Ref: BIS-N1 22 August 2026 to 28 August 2026




Worksite: BIS Monitoring Ref: BIS-N1 29 August 2026 to 4 September 2026




Worksite: PL - Monitoring Ref: PL-N3


Worksite: PL Monitoring Ref: PL-N3 01 August 2026 to 07 August 2026




Worksite: PL Monitoring Ref: PL-N3 08 August 2026 to 14 August 2026




Worksite: PL Monitoring Ref: PL-N3 15 August 2026 to 21 August 2026



Worksite: PL Monitoring Ref: PL-N3 22 August 2026 to 28 August 2026




Worksite: PL Monitoring Ref: PL-N3 29 August 2026 to 4 September 2026




Worksite: A452 - Monitoring Ref: A452-N1


Worksite: A452 Monitoring Ref: A452-N1 01 August 2026 to 07 August 2026




Worksite: A452 Monitoring Ref: A452-N1 08 August 2026 to 14 August 2026




Worksite: A452 Monitoring Ref: A452-N1 15 August 2026 to 21 August 2026



Worksite: A452 Monitoring Ref: A452-N1 22 August 2026 to 28 August 2026




Worksite: A452 Monitoring Ref: A452-N1 29 August 2026 to 4 September 2026




Worksite: BCV - Monitoring Ref: BCV-N1


Worksite: BCV Monitoring Ref: BCV-N1 01 August 2026 to 07 August 2026




Worksite: BCV Monitoring Ref: BCV-N1 08 August 2026 to 14 August 2026




Worksite: BCV Monitoring Ref: BCV-N1 15 August 2026 to 21 August 2026



Worksite: BCV Monitoring Ref: BCV-N1 22 August 2026 to 28 August 2026




Worksite: BCV Monitoring Ref: BCV-N1 29 August 2026 to 4 September 2026




Worksite: DLE - Monitoring Ref: DLE-N2


Worksite: DLE Monitoring Ref: DLE-N2 01 August 2026 to 07 August 2026




Worksite: DLE Monitoring Ref: DLE-N2 08 August 2026 to 14 August 2026




Worksite: DLE Monitoring Ref: DLE-N2 15 August 2026 to 21 August 2026



Worksite: DLE Monitoring Ref: DLE-N2 22 August 2026 to 28 August 2026




Worksite: DLE Monitoring Ref: DLE-N2 29 August 2026 to 4 September 2026




Note: Missing data due to a fault with monitoring equipment.

Worksite: DLE - Monitoring Ref: DLE-N3


Worksite: DLE Monitoring Ref: DLE-N3 01 August 2026 to 07 August 2026




Worksite: DLE Monitoring Ref: DLE-N3 08 August 2026 to 14 August 2026




Worksite: DLE Monitoring Ref: DLE-N3 15 August 2026 to 21 August 2026



Worksite: DLE Monitoring Ref: DLE-N3 22 August 2026 to 28 August 2026




Worksite: DLE Monitoring Ref: DLE-N3 29 August 2026 to 4 September 2026




Worksite: PL - Monitoring Ref: PL-N1


Worksite: PL Monitoring Ref: PL-N1 01 August 2026 to 07 August 2026




Worksite: PL Monitoring Ref: PL-N1 08 August 2026 to 14 August 2026




Worksite: PL Monitoring Ref: PL-N1 15 August 2026 to 21 August 2026



Worksite: PL Monitoring Ref: PL-N1 22 August 2026 to 28 August 2026




Worksite: PL Monitoring Ref: PL-N1 29 August 2026 to 4 September 2026




Worksite: PL - Monitoring Ref: PL-N7


Worksite: PL Monitoring Ref: PL-N7 01 August 2026 to 07 August 2026




Worksite: PL Monitoring Ref: PL-N7 08 August 2026 to 14 August 2026




Worksite: PL Monitoring Ref: PL-N7 15 August 2026 to 21 August 2026



Worksite: PL Monitoring Ref: PL-N7 22 August 2026 to 28 August 2026




Worksite: PL Monitoring Ref: PL-N7 29 August 2026 to 4 September 2026




Worksite: DLE - Monitoring Ref: DLE-N1


Worksite: DLE Monitoring Ref: DLE-N1 01 August 2026 to 07 August 2026




Worksite: DLE Monitoring Ref: DLE-N1 08 August 2026 to 14 August 2026




Worksite: DLE Monitoring Ref: DLE-N1 15 August 2026 to 21 August 2026



Worksite: DLE Monitoring Ref: DLE-N1 22 August 2026 to 28 August 2026




Worksite: DLE Monitoring Ref: DLE-N1 29 August 2026 to 4 September 2026




Worksite: WLOS - Monitoring Ref: WLOS-N2

Worksite: WLOS Monitoring Ref: WLOS-N2 01 August 2026 to 07 August 2026




Note: Missing data due to a fault with monitoring equipment.

Worksite: WLOS Monitoring Ref: WLOS-N2 08 August 2026 to 14 August 2026




Note: Missing data due to a fault with monitoring equipment.


Worksite: WLOS Monitoring Ref: WLOS-N2 15 August 2026 to 21 August 2026



Worksite: WLOS Monitoring Ref: WLOS-N2 22 August 2026 to 28 August 2026




Worksite: WLOS Monitoring Ref: WLOS-N2 29 August 2026 to 4 September 2026




Worksite: CHR - Monitoring Ref: CHR-N1


Worksite: CHR Monitoring Ref: CHR-N1 01 August 2026 to 07 August 2026




Worksite: CHR Monitoring Ref: CHR-N1 08 August 2026 to 14 August 2026




Worksite: CHR Monitoring Ref: CHR-N1 15 August 2026 to 21 August 2026



Worksite: CHR Monitoring Ref: CHR-N1 22 August 2026 to 28 August 2026




Worksite: CHR Monitoring Ref: CHR-N1 29 August 2026 to 4 September 2026




Worksite: CGRU - Monitoring Ref: CGRU-N1


Worksite: CGRU Monitoring Ref: CGRU-N1 01 August 2026 to 07 August 2026




Worksite: CGRU Monitoring Ref: CGRU-N1 08 August 2026 to 14 August 2026




Worksite: CGRU Monitoring Ref: CGRU-N1 15 August 2026 to 21 August 2026



Worksite: CGRU Monitoring Ref: CGRU-N1 22 August 2026 to 28 August 2026




Worksite: CGRU Monitoring Ref: CGRU-N1 29 August 2026 to 4 September 2026




Worksite: CHRU - Monitoring Ref: CHRU-N1


Worksite: CHRU Monitoring Ref: CHRU-N1 01 August 2026 to 07 August 2026




Worksite: CHRU Monitoring Ref: CHRU-N1 08 August 2026 to 14 August 2026




Worksite: CHRU Monitoring Ref: CHRU-N1 15 August 2026 to 21 August 2026



Worksite: CHRU Monitoring Ref: CHRU-N1 22 August 2026 to 28 August 2026




Worksite: CHRU Monitoring Ref: CHRU-N1 29 August 2026 to 4 September 2026




Worksite: WLOS - Monitoring Ref: WLOS-N1


Worksite: WLOS Monitoring Ref: WLOS-N1 01 August 2026 to 07 August 2026




Worksite: WLOS Monitoring Ref: WLOS-N1 08 August 2026 to 14 August 2026




Worksite: WLOS Monitoring Ref: WLOS-N1 15 August 2026 to 21 August 2026



Worksite: WLOS Monitoring Ref: WLOS-N1 22 August 2026 to 28 August 2026




Worksite: WLOS Monitoring Ref: WLOS-N1 29 August 2026 to 4 September 2026




Worksite: PL - Monitoring Ref: PL-N2

Worksite: PL Monitoring Ref: PL-N2 01 August 2026 to 07 August 2026




Note: Missing data due to a fault with monitoring equipment.


Worksite: PL Monitoring Ref: PL-N2 08 August 2026 to 14 August 2026




Worksite: PL Monitoring Ref: PL-N2 15 August 2026 to 21 August 2026



Worksite: PL Monitoring Ref: PL-N2 22 August 2026 to 28 August 2026




Worksite: PL Monitoring Ref: PL-N2 29 August 2026 to 4 September 2026




Worksite: BIC - Monitoring Ref: BIC-N1


Worksite: BIC Monitoring Ref: BIC-N1 01 August 2026 to 07 August 2026




Worksite: BIC Monitoring Ref: BIC-N1 08 August 2026 to 14 August 2026




Worksite: BIC Monitoring Ref: BIC-N1 15 August 2026 to 21 August 2026



Worksite: BIC Monitoring Ref: BIC-N1 22 August 2026 to 28 August 2026




Worksite: BIC Monitoring Ref: BIC-N1 29 August 2026 to 4 September 2026




Worksite: WLOS - Monitoring Ref: WLOS-N3


Worksite: WLOS Monitoring Ref: WLOS-N3 01 August 2026 to 07 August 2026




Worksite: WLOS Monitoring Ref: WLOS-N3 08 August 2026 to 14 August 2026




Worksite: WLOS Monitoring Ref: WLOS-N3 15 August 2026 to 21 August 2026



Worksite: WLOS Monitoring Ref: WLOS-N3 22 August 2026 to 28 August 2026




Worksite: WLOS Monitoring Ref: WLOS-N3 29 August 2026 to 4 September 2026




Worksite: PL - Monitoring Ref: PL-N5


Worksite: PL Monitoring Ref: PL-N5 01 August 2026 to 07 August 2026




Worksite: PL Monitoring Ref: PL-N5 08 August 2026 to 14 August 2026




Worksite: PL Monitoring Ref: PL-N5 15 August 2026 to 21 August 2026



Worksite: PL Monitoring Ref: PL-N5 22 August 2026 to 28 August 2026




Worksite: PL Monitoring Ref: PL-N5 29 August 2026 to 4 September 2026




Worksite: BBE - Monitoring Ref: BBE-N1


Worksite: BBE Monitoring Ref: BBE-N1 01 August 2026 to 07 August 2026




Worksite: BBE Monitoring Ref: BBE-N1 08 August 2026 to 14 August 2026




Worksite: BBE Monitoring Ref: BBE-N1 15 August 2026 to 21 August 2026



Worksite: BBE Monitoring Ref: BBE-N1 22 August 2026 to 28 August 2026



Worksite: BBE Monitoring Ref: BBE-N1 29 August 2026 to 4 September 2026




Vibration


The following graphs show the hourly measured peak particle velocity PPV recorded during the monitoring period. The graphs show the resultant PPV due to vibration components on three orthogonal axis x, y and z. Where high values of PPV were caused by local interference with the vibration monitor, which are not representative of HS2 construction works, these values have been greyed out in the following charts and have been excluded to calculate values in Table 4 of the main report.

Worksite: WL - Monitoring Ref: WL-V12


Worksite: WL Monitoring Ref: WL-V12 01 August 2026 to 07 August 2026




Worksite: WL Monitoring Ref: WL-V12 08 August 2026 to 14 August 2026




Worksite: WL Monitoring Ref: WL-V12 15 August 2026 to 21 August 2026



Worksite: WL Monitoring Ref: WL-V12 22 August 2026 to 28 August 2026




Worksite: WL Monitoring Ref: WL-V12 29 August 2026 to 4 September 2026




Worksite: CHRU - Monitoring Ref: CHRU-V1


Worksite: CHRU Monitoring Ref: CHRU-V1 01 August 2026 to 07 August 2026




Worksite: CHRU Monitoring Ref: CHRU-V1 08 August 2026 to 14 August 2026




Worksite: CHRU Monitoring Ref: CHRU-V1 15 August 2026 to 21 August 2026



Worksite: CHRU Monitoring Ref: CHRU-V1 22 August 2026 to 28 August 2026




Worksite: CHRU Monitoring Ref: CHRU-V1 29 August 2026 to 4 September 2026




Worksite: PL - Monitoring Ref: PL-V3


Worksite: PL Monitoring Ref: PL-V3 01 August 2026 to 07 August 2026




Worksite: PL Monitoring Ref: PL-V3 08 August 2026 to 14 August 2026




Worksite: PL Monitoring Ref: PL-V3 15 August 2026 to 21 August 2026



Worksite: PL Monitoring Ref: PL-V3 22 August 2026 to 28 August 2026




Worksite: PL Monitoring Ref: PL-V3 29 August 2026 to 4 September 2026




Worksite: PL - Monitoring Ref: PL-V4


Worksite: PL Monitoring Ref: PL-V4 01 August 2026 to 07 August 2026




Worksite: PL Monitoring Ref: PL-V4 08 August 2026 to 14 August 2026




Worksite: PL Monitoring Ref: PL-V4 15 August 2026 to 21 August 2026



Worksite: PL Monitoring Ref: PL-V4 22 August 2026 to 28 August 2026




Worksite: PL Monitoring Ref: PL-V4 29 August 2026 to 4 September 2026




Worksite: WLOS - Monitoring Ref: WLOS-V1


Worksite: WLOS Monitoring Ref: WLOS-V1 01 August 2026 to 07 August 2026




Worksite: WLOS Monitoring Ref: WLOS-V1 08 August 2026 to 14 August 2026




Worksite: WLOS Monitoring Ref: WLOS-V1 15 August 2026 to 21 August 2026



Worksite: WLOS Monitoring Ref: WLOS-V1 22 August 2026 to 28 August 2026




Worksite: WLOS Monitoring Ref: WLOS-V1 29 August 2026 to 4 September 2026




Worksite: WLOS - Monitoring Ref: WLOS-V2


Worksite: WLOS Monitoring Ref: WLOS-V2 01 August 2026 to 07 August 2026




Worksite: WLOS Monitoring Ref: WLOS-V2 08 August 2026 to 14 August 2026




Worksite: WLOS Monitoring Ref: WLOS-V2 15 August 2026 to 21 August 2026



Worksite: WLOS Monitoring Ref: WLOS-V2 22 August 2026 to 28 August 2026




Worksite: WLOS Monitoring Ref: WLOS-V2 29 August 2026 to 4 September 2026




Worksite: BBE - Monitoring Ref: BBE-V2


Worksite: BBE Monitoring Ref: BBE-V2 01 August 2026 to 07 August 2026




Worksite: BBE Monitoring Ref: BBE-V2 08 August 2026 to 14 August 2026




Worksite: BBE Monitoring Ref: BBE-V2 15 August 2026 to 21 August 2026




Worksite: BBE Monitoring Ref: BBE-V2 22 August 2026 to 28 August 2026




Worksite: BBE Monitoring Ref: BBE-V2 29 August 2026 to 4 September 2026



Worksite: BCV - Monitoring Ref: BCV-V6




Note: Missing data was due to the monitor being replaced




Note: Missing data was due to the monitor being replaced

Worksite: BCV Monitoring Ref: BCV-V6 15 August 2026 to 21 August 2026




Note: Missing data was due to the monitor being replaced

Worksite: BCV Monitoring Ref: BCV-V6 22 August 2026 to 28 August 2026




Worksite: BCV Monitoring Ref: BCV-V6 29 August 2026 to 4 September 2026




Worksite: PL - Monitoring Ref: PL-V2


Worksite: PL Monitoring Ref: PL-V2 01 August 2026 to 07 August 2026




Worksite: PL Monitoring Ref: PL-V2 08 August 2026 to 14 August 2026




Worksite: PL Monitoring Ref: PL-V2 15 August 2026 to 21 August 2026



Worksite: PL Monitoring Ref: PL-V2 22 August 2026 to 28 August 2026




Worksite: PL Monitoring Ref: PL-V2 29 August 2026 to 4 September 2026




Worksite: DLE - Monitoring Ref: DLE-V1


Worksite: DLE Monitoring Ref: DLE-V1 01 August 2026 to 07 August 2026




Worksite: DLE Monitoring Ref: DLE-V1 08 August 2026 to 14 August 2026




Worksite: DLE Monitoring Ref: DLE-V1 15 August 2026 to 21 August 2026



Worksite: DLE Monitoring Ref: DLE-V1 22 August 2026 to 28 August 2026




Worksite: DLE Monitoring Ref: DLE-V1 29 August 2026 to 4 September 2026




Worksite: A452 - Monitoring Ref: A452-V1


Worksite: A452 Monitoring Ref: A452-V1 01 August 2026 to 07 August 2026




Worksite: A452 Monitoring Ref: A452-V1 08 August 2026 to 14 August 2026



Worksite: A452 Monitoring Ref: A452-V1 15 August 2026 to 21 August 2026



Worksite: A452 Monitoring Ref: A452-V1 22 August 2026 to 28 August 2026



Worksite: A452 Monitoring Ref: A452-V1 29 August 2026 to 4 September 2026

