Office for Product Safety & Standards

Product Safety Report

Kingsway SOLO FD30S and FD60S Single Action Doorsets	
Aspect	**Details**
PSD Number	2611-0072
Product Type	Construction Products – Doors (Interior)
Product Identifiers	Brand: Kingsway Models: SOLO FD30S and FD60S Single Action Doorsets. Only the smoke-control 'S' suffix is affected.
Product Description	Smoke rated single action fire door with wood frame and wooden leaf construction.
Country of Origin	United Kingdom
Counterfeit	No
Risk Level	High
Risk Type	Fire (Smoke)
Risk Description	Some of the SOLO FD30S and FD60S Single Action Doorsets were not fitted with the necessary smoke seals, and therefore did not perform as declared, in relation to smoke control performance, as 30 and 60 minute doorsets. Without smoke seals, smoke may pass through the gaps around a closed door in the early stages of a fire. Where the doorset protects an escape route, such as a stairway, lobby or corridor, this could let smoke into that route while people are leaving the building and impair or delay any evacuation. Where the necessary smoke seals are not fitted, the products may not meet the requirements of the General Product Safety Regulations 2005.
Corrective Measures	The manufacturer, Kingsway Group, have initiated a modification programme to fit the correct smoke seals where they are missing. Customers that are affected have been contacted by Kingsway with further information. Details have been provided to the affected customer of how the modification will be delivered by Kingsway at no cost. Responsible Persons for fire safety at each affected site are advised to consider this issue as part of the site's fire risk assessment. The manufacturer advises that doors are kept closed, and that it is checked the self-closers are working properly, until the doorset has been inspected. Customers who believe they have an affected product on their site, but have not been contacted, or any other customer who would like additional information to that which has already been provided, should email Customer.Service@kingswaygroup.co.uk, quoting reference KG-PSN-2026-01.
Online Marketplace	N/A
Lead Authority	Local Authority Trading Standards

The OPSS Product Safety Alerts, Reports and Recalls Site can be accessed at the following link: https://www.gov.uk/guidance/product-recalls-and-alerts